

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 02.07.2019 TO 08.07.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	2-Jul-19	BAGALKOT	110	110/11KV,HV3	BIJAPUR_110	20:44	21:04	0:20	HAND TRIPPED
2	2-Jul-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	0:00	11:19	11:19	LINE CLEAR AVAILED
3	2-Jul-19	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	15:04	15:51	0:47	LINE CLEAR AVAILED
4	2-Jul-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	13:02	14:24	1:22	LINE CLEAR AVAILED
5	2-Jul-19	BAGALKOT	220	CHIKKODI-BELGAUM 2	CHIKKODI_220	2:50	6:55	4:05	LINE CLEAR AVAILED
6	2-Jul-19	BENGALURU	66	HV2	MAASTHI	7:00	7:05	0:05	TRANSFORMER FAULT
7	2-Jul-19	BENGALURU	66	HV1	NARASAPURA	20:12	20:29	0:17	TRANSFORMER FAULT
8	2-Jul-19	BENGALURU	66	HV1	KONDASPURA	11:57	12:24	0:26	LINE CLEAR AVAILED
9	2-Jul-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	11:28	13:06	1:38	LINE CURTAILMENT
10	2-Jul-19	BENGALURU	66	DRDO(EHT) - MALLASANDRA	MALLASANDRA, DALASNUR, YELDUR	11:40	13:10	1:30	LINE CURTAILMENT
11	2-Jul-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	11:34	13:12	1:38	LINE CLEAR AVAILED
12	2-Jul-19	BENGALURU	220	HV1	KOLAR 220	11:41	13:04	1:23	LINE CLEAR AVAILED
13	2-Jul-19	BENGALURU	66	HV2	KODIHALLI (KANAKAPURA)	13:17	13:27	0:09	LINE CLEAR AVAILED
14	2-Jul-19	BENGALURU	66	GOWRIBIDANUR 220 - DB 2	THONDEBHAVI, MANCHENAHALLI	5:55	6:05	0:10	LINE FAULT
15	2-Jul-19	BENGALURU	66	HV1	AGALKOTE	14:40	15:20	0:40	LINE CLEAR AVAILED
16	2-Jul-19	BENGALURU	66	HV2	AGALKOTE	14:40	15:20	0:40	LINE CLEAR AVAILED
17	2-Jul-19	BENGALURU	66	HV2	EPIP 220	19:30	19:44	0:13	TRANSFORMER FAULT
18	2-Jul-19	BENGALURU	66	HV2	NAGANATHPURA 220	17:31	19:48	2:16	LINE CLEAR AVAILED
19	2-Jul-19	GULBARGA	110	GURUGUTA-KHEL_IPP	GURUGUNTA_110	0:00	0:42	0:42	LINE FAULT
20	2-Jul-19	GULBARGA	110	GURUGUTA-LJVL_IPP	GURUGUNTA_110	0:00	0:30	0:30	LINE FAULT
21	2-Jul-19	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110, DONGRAGOA_110, KAMALNAGAR_110, JANAWADA_110	5:24	5:33	0:09	LINE FAULT
22	2-Jul-19	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	2:30	2:44	0:14	LINE FAULT
23	2-Jul-19	GULBARGA	110	PDHALLI-JANAKIPWRPLNT	PD_HALLI_110	2:30	2:39	0:09	LINE FAULT
24	2-Jul-19	GULBARGA	110	LV2	KUSTAGI_220	11:35	11:40	0:05	TRANSFORMER FAULT
25	2-Jul-19	GULBARGA	110	GURUGUNTA-LJVL_IPP	GURUGUNTA_110	10:05	16:55	6:50	LINE FAULT
26	2-Jul-19	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURUGUNTA_110	10:05	16:54	6:49	LINE FAULT
27	2-Jul-19	GULBARGA	110	GURUGUNTA-LJVL_IPP	GURUGUNTA_110	0:45	1:00	0:15	LINE FAULT
28	2-Jul-19	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURUGUNTA_110	0:45	1:00	0:15	LINE FAULT
29	2-Jul-19	GULBARGA	110	HV1	GULBARGASOUTH_110	8:35	18:35	10:00	TRANSFORMER FAULT
30	2-Jul-19	GULBARGA	110	HV2	BHALKI_110	12:59	15:01	2:02	LINE CLEAR AVAILED
31	2-Jul-19	GULBARGA	110	HV2	BHALKI_110	16:17	18:00	1:43	LINE CLEAR AVAILED
32	2-Jul-19	GULBARGA	110	HV2	BHALKI_110	11:00	11:35	0:35	LINE CLEAR AVAILED
33	2-Jul-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	0:00	18:59	18:59	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
34	2-Jul-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	15:44	16:53	1:09	NFBC ISSUED
35	2-Jul-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	11:18	13:44	2:26	LINE CLEAR AVAILED
36	2-Jul-19	HASSAN	220	TALAGU-STRP2	TALAGU	0:00	18:58	18:58	LINE FAULT
37	2-Jul-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	4:31	12:03	7:32	LINE CLEAR AVAILED
38	2-Jul-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	15:45	16:53	1:08	LINE CLEAR AVAILED
39	2-Jul-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	11:07	13:44	2:37	NFBC ISSUED
40	2-Jul-19	HASSAN	110	HV1	HIRENALLUR_110	11:57	12:51	0:54	LINE CLEAR AVAILED
41	2-Jul-19	HASSAN	110	HV2	KUNDAPURA_110	9:01	17:17	8:16	LINE CLEAR AVAILED
42	2-Jul-19	HASSAN	110	HV1	MANIPAL_110	10:10	10:22	0:12	LINE CLEAR AVAILED
43	2-Jul-19	HASSAN	110	HV2	MANIPAL_110	10:23	10:34	0:11	LINE CLEAR AVAILED
44	2-Jul-19	HASSAN	66	HV1	CHIKMAGALUR_66	15:25	16:35	1:10	LINE CLEAR AVAILED
45	2-Jul-19	HASSAN	66	HV2	RAMPURA_66	9:14	9:19	0:05	TRANSFORMER FAULT
46	2-Jul-19	MYSORE	66	HV2	GUNDULPET_66	11:25	11:47	0:21	LINE CLEAR AVAILED
47	2-Jul-19	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66 , BILIKERE_66, GVGUDI_66, BHERYA_66, KRNAGARA_66	7:58	8:10	0:12	LINE FAULT
48	2-Jul-19	MYSORE	66	KUSHALANAGARA 220-BETTADHAPURA	BETTADHAPURA_66, KITTUR_66, RAVANDUR_66, CHUNCHUNKATTE_66	7:58	8:10	0:12	LINE FAULT
49	2-Jul-19	MYSORE	66	HV1	TUBINAKERE_220	13:40	16:54	3:13	LINE CLEAR AVAILED
50	2-Jul-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 SHIVALLY_66 KESLAGERE_66	23:26	23:34	0:07	LINE FAULT
51	2-Jul-19	TUMKUR	220	TR-2	ANTHRASANAHALLI_220	10:20	10:51	0:31	LINE CLEAR AVAILED
52	2-Jul-19	TUMKUR	110	TR-3	AMMASANDRA_110	12:45	15:17	2:32	LINE CLEAR AVAILED
53	2-Jul-19	TUMKUR	66	TR-2(LV2)	ANTHRASANAHALLI_220	10:18	10:52	0:34	LINE CLEAR AVAILED
54	2-Jul-19	TUMKUR	66	TR-2	DAVANAGERE_66	18:54	18:57	0:02	TRANSFORMER FAULT
55	2-Jul-19	TUMKUR	66	TR-2	DAVANAGERE_66	19:05	19:14	0:08	TRANSFORMER FAULT
56	2-Jul-19	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR_IPP_66	TATA SOLAR_IPP_66	14:18	14:32	0:14	HAND TRIPPED
57	2-Jul-19	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	20:05	20:44	0:38	LINE FAULT
58	2-Jul-19	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	12:48	17:50	5:02	LINE CLEAR AVAILED
59	2-Jul-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:15	17:29	8:13	LINE FAULT
60	03-Jul-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	1:50	7:20	5:30	LINE CLEAR AVAILED
61	03-Jul-19	BAGALKOT	110	220/110KV,LV2	BELGAUM_220	1:53	6:28	4:35	LINE CLEAR AVAILED
62	03-Jul-19	BAGALKOT	220	PONDA 1&2-AMBEWADI	AMBEWADI_220	11:08	23:59	12:51	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
63	03-Jul-19	BAGALKOT	110	110/11KV,HV1	BEDI_110	11:10	23:59	12:49	TRANSFORMER FAULT
64	03-Jul-19	BAGALKOT	220	220/110KV,HV2&LV2	GADAG_220	13:34	14:41	1:07	LINE CLEAR AVAILED
65	03-Jul-19	BAGALKOT	110	110/33KV,HV1	HANGAL_110,PALA_33,BASAPURA_33	10:40	17:50	7:10	LINE CLEAR AVAILED
66	03-Jul-19	BAGALKOT	110	110/33KV,HV2	HANGAL_110,BELAGALPET_33,BOM MANAHALLI_33	10:40	17:46	7:06	LINE CLEAR AVAILED
67	03-Jul-19	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	10:43	17:48	7:05	LINE CLEAR AVAILED
68	03-Jul-19	BAGALKOT	110	DSS SUGARS-HIREBEVANUR	HIREBEVANUR_110	13:16	13:35	0:19	LINE CLEAR AVAILED
69	03-Jul-19	BAGALKOT	110	RAIBAG 2-ITANAL	ITANAL_110	15:12	15:57	0:45	LINE CLEAR AVAILED
70	03-Jul-19	BAGALKOT	110	KUDUCHI220-MORAB	MORAB_110	6:04	6:21	0:17	LINE FAULT
71	03-Jul-19	BAGALKOT	110	110/11KV, HV2	SHIROL_110	14:41	15:08	0:27	TRANSFORMER FAULT
72	03-Jul-19	BAGALKOT	110	110/11KV, HV2	SHIROL_110	15:17	16:24	1:07	LINE CLEAR AVAILED
73	03-Jul-19	BAGALKOT	110	SHIRGUPPI-BILAGI	BILAGI_110	20:50	23:44	2:54	LINE CLEAR AVAILED
74	03-Jul-19	BAGALKOT	110	VPPL-SADALAGA	SADALAGA_110	5:53	7:20	1:27	LINE FAULT
75	03-Jul-19	BAGALKOT	110	RANEENNUR220-RATTIHALLI(TUMMINKATTI)	TUMMINKATTI_110	23:21	23:36	0:15	LINE FAULT
76	03-Jul-19	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	14:58	15:38	0:40	LINE CLEAR AVAILED
77	03-Jul-19	BAGALKOT	110	110/33KV, HV2	MURDESHWAR_110	14:29	17:15	2:46	LINE CLEAR AVAILED
78	03-Jul-19	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	1:05	20:50	19:45	LINE CLEAR AVAILED
79	03-Jul-19	BAGALKOT	110	110/33KV, HV4	LAKMANHALLI_110, ALNAVAR_33	15:11	16:11	1:00	LINE CLEAR AVAILED
80	03-Jul-19	BAGALKOT	110	110/11KV, HV1	LAKMANHALLI_110	15:12	16:10	0:58	LINE CLEAR AVAILED
81	03-Jul-19	BAGALKOT	110	110/11KV, HV2	LAKMANHALLI_110	15:11	16:10	0:59	LINE CLEAR AVAILED
82	03-Jul-19	BAGALKOT	110	110/33KV, HV1	KUMATA_110, ANKOLA_33, HONNAVAR_33	12:51	13:35	0:44	LINE CLEAR AVAILED
83	03-Jul-19	BAGALKOT	110	110/11KV, HV1	KUMATA_110	11:05	11:38	0:33	LINE CLEAR AVAILED
84	03-Jul-19	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE, MATHIKERE	15:35	16:05	0:30	LINE CLEAR AVAILED
85	03-Jul-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	4:04	4:10	0:05	LINE FAULT
86	03-Jul-19	BENGALURU	66	CHINTAMANI 220- LAKSHMIPURA	LAKSHMIPURA , ADDAGAL, SOMAYAJANAHALLI	7:08	7:16	0:07	LINE FAULT
87	03-Jul-19	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	0:06	0:17	0:10	LINE FAULT
88	03-Jul-19	BENGALURU	66	HV2	MAASTHI	12:07	12:12	0:04	TRANSFORMER FAULT
89	03-Jul-19	BENGALURU	66	HV1	SURYANAGAR	16:01	16:38	0:36	LINE CLEAR AVAILED
90	03-Jul-19	GULBARGA	400	BTPS-RTPS	BTPS_400	4:39	7:23	2:44	LINE FAULT
91	03-Jul-19	GULBARGA	220	BTPS-ALIPUR220	ALIPUR_220	4:39	12:29	7:50	LINE FAULT
92	03-Jul-19	GULBARGA	220	SINDHANOOR-LINGASUGUR	SIDHANOOR_220	12:19	16:28	4:09	NFBC ISSUED
93	03-Jul-19	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110, MADALAPURA_110, MANVI_110	5:06	5:11	0:05	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
94	03-Jul-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	KAMPLI_GLB_110, MUKUNDA_110, BTPS_WATERWORKS	13:38	14:11	0:33	LINE FAULT
95	03-Jul-19	GULBARGA	110	GURGUNTA-LJVL_IPP	LJVL_IPP	9:38	16:42	7:04	LINE CLEAR AVAILED
96	03-Jul-19	GULBARGA	110	GURGUNTA-KHEL_IPP	KHEL_IPP	9:19	16:41	7:22	LINE CLEAR AVAILED
97	03-Jul-19	GULBARGA	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	11:24	11:32	0:08	LINE CLEAR AVAILED
98	03-Jul-19	GULBARGA	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	15:54	16:03	0:09	LINE CLEAR AVAILED
99	03-Jul-19	GULBARGA	66	ITTAGI-BENNEHALLI	ITTAGI_220	15:25	15:30	0:05	LINE CLEAR AVAILED
100	03-Jul-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	2:09	6:42	4:33	LINE CLEAR AVAILED
101	03-Jul-19	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	9:20	12:55	3:35	NFBC ISSUED
102	03-Jul-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	9:24	16:32	7:08	LINE CLEAR AVAILED
103	03-Jul-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	9:25	16:31	7:06	NFBC ISSUED
104	03-Jul-19	HASSAN	110	BANTWA-KAVOOR	BANTWALA_110	10:32	14:31	3:59	LINE CLEAR AVAILED
105	03-Jul-19	HASSAN	66	HV1	ALDUR_66	18:05	18:20	0:15	LINE CLEAR AVAILED
106	03-Jul-19	HASSAN	66	HV2	BELUR_66	22:51	23:59	1:08	TRANSFORMER FAULT
107	03-Jul-19	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	12:17	16:28	4:11	MAIN SUPPLY FAILURE
108	03-Jul-19	HASSAN	66	HV1	BYACHANAHALLI_66	12:00	16:35	4:35	MAIN SUPPLY FAILURE
109	03-Jul-19	HASSAN	66	HN PURA-RAMNATHPURA	HNPURA_66	11:57	16:06	4:09	LINE CLEAR AVAILED
110	03-Jul-19	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	11:57	16:26	4:29	LINE CLEAR AVAILED
111	03-Jul-19	MYSORE	66	HV1	HUNSUR_66	9:17	9:26	0:08	TRANSFORMER FAULT
112	03-Jul-19	MYSORE	66	HV1	NANJANGUDU_66	9:45	14:17	4:32	LINE CLEAR AVAILED
113	03-Jul-19	MYSORE	66	HV2	NANJANGUDU_66	9:45	14:17	4:32	LINE CLEAR AVAILED
114	03-Jul-19	MYSORE	66	HV1	SANTHESARAGUR_66	10:46	10:51	0:05	TRANSFORMER FAULT
115	03-Jul-19	TUMKUR	110	TR-1	KBCROSS_220	14:18	14:33	0:15	LINE CLEAR AVAILED
116	03-Jul-19	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	ANCHEPALYA_220	11:27	16:59	5:32	LINE CLEAR AVAILED
117	03-Jul-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	12:23	12:41	0:17	TRANSFORMER FAULT
118	03-Jul-19	TUMKUR	66	TR-2	DAVANAGERE_66	3:25	4:18	0:52	TRANSFORMER FAULT
119	03-Jul-19	TUMKUR	66	TR-2	DAVANAGERE_66	10:27	10:28	0:01	LINE CLEAR AVAILED
120	03-Jul-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	5:43	5:48	0:05	LINE FAULT
121	03-Jul-19	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	18:17	18:27	0:10	MAIN SUPPLY FAILURE
122	03-Jul-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	12:01	17:32	5:31	LINE CLEAR AVAILED
123	03-Jul-19	TUMKUR	66	TAVAREKERE (C)- GOPPENAHALLI	TAVAREKERE(C)_66	12:01	17:35	5:33	LINE CLEAR AVAILED
124	03-Jul-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	8:47	17:46	8:58	LINE FAULT
125	03-Jul-19	TUMKUR	66	TR-2	THIMMASANDRA_66	17:37	18:36	0:58	LINE CLEAR AVAILED
126	03-Jul-19	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	11:10	12:50	1:40	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
127	03-Jul-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	11:58	12:26	0:28	HAND TRIPPED
128	03-Jul-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	9:35	10:01	0:25	LINE FAULT
129	03-Jul-19	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	12:36	14:05	1:28	LINE CLEAR AVAILED
130	4-Jul-19	BAGALKOT	220	ATHANI-MAHALINGAPUR	MAHALINGAPUR_220	10:31	17:07	6:36	LINE CLEAR AVAILED
131	4-Jul-19	BAGALKOT	110	AINAPUR-LIS AINAPUR	AINAPUR_110	14:51	17:55	3:04	LINE CLEAR AVAILED
132	4-Jul-19	BAGALKOT	110	AINAPUR-LIS AINAPUR	AINAPUR_110	19:54	20:03	0:09	LINE FAULT
133	4-Jul-19	BAGALKOT	110	AINAPUR-LIS AINAPUR	AINAPUR_110	20:06	20:22	0:16	LINE FAULT
134	4-Jul-19	BAGALKOT	110	AINAPUR-LIS AINAPUR	AINAPUR_110	20:27	23:59	3:32	LINE FAULT
135	4-Jul-19	BAGALKOT	110	220/110KV,LV2	BELGAUM_220	2:04	5:49	3:45	LINE CLEAR AVAILED
136	4-Jul-19	BAGALKOT	110	110/33KV,HV3	GOPANAKOPPA_110,KUSUGAL_33	10:00	19:32	9:32	LINE CLEAR AVAILED
137	4-Jul-19	BAGALKOT	110	110/33KV,HV4	GOPANAKOPPA_110,KMC_33	10:00	19:34	9:34	LINE CLEAR AVAILED
138	4-Jul-19	BAGALKOT	220	NAGJHARI 2-BIDNAL	BIDNAL_220	9:50	17:28	7:38	LINE CLEAR AVAILED
139	4-Jul-19	BAGALKOT	110	110/11KV,HV2	SHIROL_110	12:27	14:28	2:01	LINE CLEAR AVAILED
140	4-Jul-19	BAGALKOT	110	110/33KV,HV3	SANKESHWAR_110,HEBBAL_33,KANA GALA_33KV	12:13	12:14	0:01	LINE CLEAR AVAILED
141	4-Jul-19	BAGALKOT	110	110/33KV,HV3	SALAHALLI_110,HULKUND_33	12:59	13:32	0:33	LINE CLEAR AVAILED
142	4-Jul-19	BAGALKOT	110	110/11KV,HV1	PG HUNSHYAL_110	16:58	18:00	1:02	LINE CLEAR AVAILED
143	4-Jul-19	BAGALKOT	110	110/11KV,HV1	NANADI_110	13:55	14:26	0:31	LINE CLEAR AVAILED
144	4-Jul-19	BAGALKOT	110	110/11KV,HV2	ITNAL_110	18:45	21:10	2:25	LINE CLEAR AVAILED
145	4-Jul-19	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	16:29	16:45	0:16	TRANSFORMER FAULT
146	4-Jul-19	BENGALURU	66	HV1	AMARJYOTHI	18:44	18:53	0:09	MAIN SUPPLY FAILURE
147	4-Jul-19	BENGALURU	66	EPIP 220 - CHANDAPURA 2	KACHMARANAHALLI	13:39	13:55	0:15	MAIN SUPPLY FAILURE
148	4-Jul-19	BENGALURU	66	EPIP 220 - GITC (EHT)	GITC (EHT)	13:39	13:55	0:15	MAIN SUPPLY FAILURE
149	4-Jul-19	BENGALURU	66	BEGUR 220 - BIAL 2	BIAL	11:07	11:12	0:04	LINE FAULT
150	4-Jul-19	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	11:07	11:12	0:04	LINE FAULT
151	4-Jul-19	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO	REMCO	7:32	7:54	0:22	LINE FAULT
152	4-Jul-19	BENGALURU	66	ADUGODI - HAL 1	AUSTIN TOWN, AMARJYOTHI	12:46	12:58	0:12	LOAD CHANGEOVER
153	4-Jul-19	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	10:01	10:07	0:06	LOAD CHANGEOVER
154	4-Jul-19	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	10:01	10:08	0:07	LOAD CHANGEOVER
155	4-Jul-19	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	16:20	16:30	0:10	LOAD CHANGEOVER
156	4-Jul-19	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	16:20	16:34	0:14	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
157	4-Jul-19	BENGALURU	220	BEGUR 220 - HOSKOTE 220	HOSKOTE 220	11:07	11:09	0:02	LINE FAULT
158	4-Jul-19	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	11:08	11:17	0:08	LINE FAULT
159	4-Jul-19	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	12:19	12:30	0:11	LINE FAULT
160	4-Jul-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	11:07	11:27	0:20	MAIN SUPPLY FAILURE
161	4-Jul-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	11:07	11:26	0:19	MAIN SUPPLY FAILURE
162	4-Jul-19	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	11:07	11:27	0:20	MAIN SUPPLY FAILURE
163	4-Jul-19	BENGALURU	66	HV1	ABBIGERE	10:35	10:40	0:05	LINE CLEAR AVAILED
164	4-Jul-19	BENGALURU	66	HV2	ABBIGERE	11:52	11:56	0:03	LINE CLEAR AVAILED
165	4-Jul-19	BENGALURU	66	HV1	EPIP 220	13:39	13:55	0:15	MAIN SUPPLY FAILURE
166	4-Jul-19	BENGALURU	66	HV2	EPIP 220	13:39	13:55	0:15	MAIN SUPPLY FAILURE
167	4-Jul-19	BENGALURU	66	HV1	HEBBAL 220	12:17	13:23	1:06	LINE CLEAR AVAILED
168	4-Jul-19	BENGALURU	220	HV2	BEGUR 220	11:07	11:10	0:03	TRANSFORMER FAULT
169	4-Jul-19	BENGALURU	66	HV2	BEGUR 220	11:07	11:12	0:04	TRANSFORMER FAULT
170	4-Jul-19	BENGALURU	66	HV1	BEGUR 220	11:07	11:12	0:04	TRANSFORMER FAULT
171	4-Jul-19	BENGALURU	66	HV2	DEVANGONDHI	14:19	15:07	0:47	LINE CLEAR AVAILED
172	4-Jul-19	BENGALURU	66	HV1	HOSKOTE 220	11:08	11:25	0:17	MAIN SUPPLY FAILURE
173	4-Jul-19	BENGALURU	220	HV1	HOSKOTE 220	11:07	11:23	0:16	MAIN SUPPLY FAILURE
174	4-Jul-19	BENGALURU	220	HV2	HOSKOTE 220	11:07	11:24	0:16	MAIN SUPPLY FAILURE
175	4-Jul-19	BENGALURU	66	HV2	MAASTHI	6:40	6:44	0:03	TRANSFORMER FAULT
176	4-Jul-19	BENGALURU	66	HV1	DEVANAHALLI	13:43	13:49	0:05	TRANSFORMER FAULT
177	4-Jul-19	GULBARGA	110	BYAGWAT-WALKAMDINNI	BYAGAWAT_110	15:30	15:54	0:24	LINE FAULT
178	4-Jul-19	GULBARGA	110	BYAGWAT-ACMESOLAR_IPP	BYAGAWAT_110	15:30	16:18	0:48	LINE FAULT
179	4-Jul-19	GULBARGA	110	YELBURGA-PARAMPUJYA_IPP	YELBURGA_110	15:16	15:37	0:21	LINE FAULT
180	4-Jul-19	GULBARGA	110	LINGASUGUR-GURUGUNTA	GURUGUNTA_110	3:05	3:10	0:05	LINE FAULT
181	4-Jul-19	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURUGUNTA_110	3:05	3:15	0:10	LINE FAULT
182	4-Jul-19	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURUGUNTA_110	9:00	18:30	9:30	LINE CLEAR AVAILED
183	4-Jul-19	GULBARGA	110	GURUGUNTA-LJVL_IPP	GURUGUNTA_110	9:25	18:30	9:05	LINE CLEAR AVAILED
184	4-Jul-19	GULBARGA	110	SHAHAPUR220-SHAHBAD2	SHAHAPUR_110,NALWAR_110	16:20	23:59	7:39	LINE FAULT
185	4-Jul-19	GULBARGA	110	LINGAPUR-GUDADAHALLI2	GUDADAHALLI_220	9:55	17:42	7:47	LINE CLEAR AVAILED
186	4-Jul-19	GULBARGA	66	HV2	TAMBRAHALLI_66	16:36	17:18	0:42	LINE CLEAR AVAILED
187	4-Jul-19	GULBARGA	66	HV1	KOTTUR_66	20:00	20:34	0:34	LINE CLEAR AVAILED
188	4-Jul-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	2:08	6:41	4:33	LINE CLEAR AVAILED
189	4-Jul-19	HASSAN	220	ARSK2-HSN	ARASIKERE_220	16:05	23:59	7:54	NFBC ISSUED
190	4-Jul-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	14:51	23:59	9:08	LINE FAULT
191	4-Jul-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	12:20	14:27	2:07	LINE CLEAR AVAILED
192	4-Jul-19	HASSAN	220	HV1	HASSAN_220	10:14	14:26	4:12	LINE CLEAR AVAILED
193	4-Jul-19	HASSAN	220	HV2	KEMAR_220	8:01	17:11	9:10	LINE CLEAR AVAILED
194	4-Jul-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	0:00	14:43	14:43	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
195	4-Jul-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	14:51	23:59	9:08	LINE FAULT
196	4-Jul-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	12:21	14:26	2:05	LINE CLEAR AVAILED
197	4-Jul-19	HASSAN	110	HV1	MSEZ_220	10:08	11:22	1:14	LINE CLEAR AVAILED
198	4-Jul-19	HASSAN	110	LV2	KEMAR_220	8:01	17:11	9:10	LINE CLEAR AVAILED
199	4-Jul-19	HASSAN	110	HV3	BANTWALA_110	11:50	12:45	0:55	LINE CLEAR AVAILED
200	4-Jul-19	HASSAN	110	PUTTUR-PUTTUR1	PUTTUR_220	10:15	14:32	4:17	LINE CLEAR AVAILED
201	4-Jul-19	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	10:15	14:32	4:17	LINE CLEAR AVAILED
202	4-Jul-19	HASSAN	66	HASSN220-ARAKALGUD	HASSAN_220	10:08	14:28	4:20	LINE CLEAR AVAILED
203	4-Jul-19	HASSAN	66	HASSN220-CHIKAMAGLUR2	HASSAN_220	10:08	14:28	4:20	LINE CLEAR AVAILED
204	4-Jul-19	HASSAN	66	HASSN220-HN PURA	HASSAN_220	10:08	14:29	4:21	LINE CLEAR AVAILED
205	4-Jul-19	HASSAN	66	LV1	HASSAN_220	10:13	14:27	4:14	LINE CLEAR AVAILED
206	4-Jul-19	HASSAN	66	HASSN220-CRP1	HASSAN_220	10:08	15:25	5:17	LINE CLEAR AVAILED
207	4-Jul-19	HASSAN	66	HASSN220-CRP2	HASSAN_220	9:34	15:02	5:28	LINE CLEAR AVAILED
208	4-Jul-19	HASSAN	66	HV2	BELUR_66	0:00	14:39	14:39	TRANSFORMER FAULT
209	4-Jul-19	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	16:58	18:01	1:03	LINE CLEAR AVAILED
210	4-Jul-19	HASSAN	66	HV1	BYACHANAHALLI_66	16:56	18:01	1:05	LINE CLEAR AVAILED
211	4-Jul-19	HASSAN	66	BYARAPU-BAGUR	BYARAPU	11:35	11:50	0:15	LINE FAULT
212	4-Jul-19	HASSAN	66	HV1	HNPURA_66	12:45	14:35	1:50	LINE CLEAR AVAILED
213	4-Jul-19	HASSAN	66	HV2	HNPURA_66	11:00	12:12	1:12	LINE CLEAR AVAILED
214	4-Jul-19	HASSAN	66	HV2	RAMESHWARNAGAR_66	9:54	14:35	4:41	LINE CLEAR AVAILED
215	4-Jul-19	MYSORE	66	HV1	HONNALLY_MYS_66	10:00	12:54	2:54	LINE CLEAR AVAILED
216	4-Jul-19	MYSORE	66	HV2	HONNALLY_MYS_66	10:00	12:30	2:30	LINE CLEAR AVAILED
217	4-Jul-19	MYSORE	66	HV2	HONNALLY_MYS_66	12:55	13:19	0:24	LINE CLEAR AVAILED
218	4-Jul-19	MYSORE	66	HV1	KIKKERI_66	12:42	13:32	0:49	LINE CLEAR AVAILED
219	4-Jul-19	MYSORE	66	HV2	MADIKERI_66	10:30	12:16	1:46	LINE CLEAR AVAILED
220	4-Jul-19	MYSORE	66	HV1	PANDAVAPURA_66	12:47	13:42	0:55	LINE CLEAR AVAILED
221	4-Jul-19	MYSORE	66	HV1	SRIRANGAPATNA_66	9:11	9:24	0:12	TRANSFORMER FAULT
222	4-Jul-19	MYSORE	66	HV1	SRIRANGAPATNA_66	10:10	15:49	5:39	LINE CLEAR AVAILED
223	4-Jul-19	MYSORE	66	HV2	SRIRANGAPATNA_66	10:10	15:49	5:39	LINE CLEAR AVAILED
224	4-Jul-19	MYSORE	66	HV2	THALAKADU_66	15:03	15:09	0:06	TRANSFORMER FAULT
225	4-Jul-19	MYSORE	220	HV2	VAJAMANGALA_220	10:05	11:39	1:34	LINE CLEAR AVAILED
226	4-Jul-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	5:50	5:56	0:06	LINE FAULT
227	4-Jul-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	14:48	14:52	0:03	HAND TRIPPED
228	4-Jul-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	19:26	19:32	0:06	HAND TRIPPED
229	4-Jul-19	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	15:06	16:41	1:35	LINE CLEAR AVAILED
230	4-Jul-19	TUMKUR	110	TR-2(HV SIDE)	ANTHRASANAHALLI_220	16:42	16:52	0:10	LINE CLEAR AVAILED
231	4-Jul-19	TUMKUR	66	TR-2(LV2)	ANTHRASANAHALLI_220	15:06	16:52	1:46	LINE CLEAR AVAILED
232	4-Jul-19	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	12:19	14:25	2:06	LINE CLEAR AVAILED
233	4-Jul-19	TUMKUR	66	HANAGAL- AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	10:47	10:51	0:03	LINE FAULT
234	4-Jul-19	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	11:11	15:10	3:59	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
235	4-Jul-19	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	14:16	15:10	0:53	HAND TRIPPED
236	4-Jul-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	18:10	18:23	0:12	LINE FAULT
237	4-Jul-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	9:59	17:40	7:40	LINE CLEAR AVAILED
238	5-Jul-19	BAGALKOT	110	BAGEWADI-MAMDAPUR1&2	MAMDAPUR_110	2:56	3:10	0:14	LINE FAULT
239	5-Jul-19	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	16:18	17:03	0:45	LINE FAULT
240	5-Jul-19	BAGALKOT	220	BAGEWADI-ALAMATTI2	BAGEWADI_220	16:17	16:23	0:06	HAND TRIPPED
241	5-Jul-19	BAGALKOT	220	220/110KV, HV3&LV3	BAGEWADI_220, MUDDEBIHAL_110, SINDAGI_110	16:18	17:03	0:45	HAND TRIPPED
242	5-Jul-19	BAGALKOT	110	110/11KV, HV2	DAVALESHWAR_110	13:19	17:46	4:27	LINE CLEAR AVAILED
243	5-Jul-19	BAGALKOT	220	TADASINKOPPA2(HIREBENDIGERI2)- BIDNAL	BIDNAL_220	11:42	15:22	3:40	LINE CLEAR AVAILED
244	5-Jul-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	23:24	23:59	0:35	HAND TRIPPED
245	5-Jul-19	BAGALKOT	110	110/33KV, HV2	GAJENDRAGAD_110, WIND1&2_33	11:14	11:28	0:14	TRANSFORMER FAULT
246	5-Jul-19	BAGALKOT	110	110/33KV, HV2	GAJENDRAGAD_110, WIND1&2_33	15:12	15:22	0:10	TRANSFORMER FAULT
247	5-Jul-19	BAGALKOT	110	110/11KV, HV4	GHATAPRABHA_110	16:41	17:00	0:19	LINE CLEAR AVAILED
248	5-Jul-19	BAGALKOT	110	110/11KV, HV2	ITANAL_110	0:18	0:22	0:04	TRANSFORMER FAULT
249	5-Jul-19	BAGALKOT	110	110/11KV, HV2	ITANAL_110	10:54	12:21	1:27	LINE CLEAR AVAILED
250	5-Jul-19	BAGALKOT	110	KUDACHI220-AINAPUR	AINAPUR_110	10:50	11:25	0:35	LINE CLEAR AVAILED
251	5-Jul-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	15:43	15:49	0:06	LINE CLEAR AVAILED
252	5-Jul-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	16:10	16:45	0:35	LINE CLEAR AVAILED
253	5-Jul-19	BAGALKOT	110	110/11KV, HV1	BANAHATTI_110	10:36	13:46	3:10	LINE CLEAR AVAILED
254	5-Jul-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33KV,DHULKED_ 33KV,HALASANGI_33KV	10:00	10:03	0:03	TRANSFORMER FAULT
255	5-Jul-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33KV,DHULKED_ 33KV,HALASANGI_33KV	14:37	14:40	0:03	TRANSFORMER FAULT
256	5-Jul-19	BAGALKOT	220	RANEENNUR-GUTTUR	RANEENNUR_220	0:00	14:52	14:52	LINE CLEAR AVAILED
257	5-Jul-19	BAGALKOT	220	RANEENNUR- SHIROLKOPPA(BALLIGAVI)	RANEENNUR_220	14:54	15:03	0:09	HAND TRIPPED
258	5-Jul-19	BAGALKOT	220	RANEENNUR-GUTTUR	RANEENNUR_220	15:56	23:59	8:03	LINE CLEAR AVAILED
259	5-Jul-19	BAGALKOT	110	110/33KV,HV2	RATTIHALLI_110,HALLUR_33KV,MASS UR_33KV	14:03	14:41	0:38	LINE CLEAR AVAILED
260	5-Jul-19	BAGALKOT	110	RANEENNUR-RATTIHALLI	RATTIHALLI_110	14:43	14:53	0:10	LINE FAULT
261	5-Jul-19	BAGALKOT	220	220/110KV,HV3,LV3	MAHALINGAPUR_220	11:09	12:16	1:07	LINE CLEAR AVAILED
262	5-Jul-19	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	11:06	12:32	1:26	LINE CLEAR AVAILED
263	5-Jul-19	BAGALKOT	220	KUDUCHI-MAHALINGAPUR	KUDUCHI_220	8:27	12:30	4:03	NFBC ISSUED
264	5-Jul-19	BAGALKOT	110	NAVALGUND -KONNUR	KONNUR_110	10:43	15:53	5:10	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
265	5-Jul-19	BENGALURU	66	HV1	CHAKAVELU	11:06	12:14	1:08	LINE CLEAR AVAILED
266	5-Jul-19	BENGALURU	66	GOWRIBIDANUR 220 - DB 2	THONDEBHAVI, MANCHENAHALLI	9:18	10:20	1:02	LINE CLEAR AVAILED
267	5-Jul-19	BENGALURU	66	HV2	HOSUR RAMAPURA	15:56	16:15	0:18	TRANSFORMER FAULT
268	5-Jul-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	14:17	15:04	0:47	LINE CLEAR AVAILED
269	5-Jul-19	BENGALURU	66	HV1	KYALANUR	11:14	11:23	0:09	TRANSFORMER FAULT
270	5-Jul-19	BENGALURU	66	HV2	MAASTHI	11:14	11:23	0:09	TRANSFORMER FAULT
271	5-Jul-19	BENGALURU	66	HV2	TYAMAGONDLU	10:30	10:56	0:26	LINE CLEAR AVAILED
272	5-Jul-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	RBI, SOUTH CITY	1:05	1:54	0:49	LINE FAULT
273	5-Jul-19	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	16:41	17:07	0:26	MAIN SUPPLY FAILURE
274	5-Jul-19	BENGALURU	66	HSR LAYOUT 220 - KORAMANGALA	KORAMANGALA, K & C VALLEY, NAL (EHT)	16:41	17:07	0:26	MAIN SUPPLY FAILURE
275	5-Jul-19	BENGALURU	66	PADMANABHANAGAR - SUBRAMANYAPURA 220	PADMANABHANAGAR	7:39	7:47	0:07	LOAD CHANGEOVER
276	5-Jul-19	BENGALURU	66	HV1	VICTORIA	23:31	23:48	0:16	TRANSFORMER FAULT
277	5-Jul-19	BENGALURU	220	HV1	HSR LAYOUT 220	16:41	17:07	0:26	TRANSFORMER FAULT
278	5-Jul-19	BENGALURU	220	HV2	HSR LAYOUT 220	16:41	17:07	0:26	TRANSFORMER FAULT
279	5-Jul-19	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	16:41	17:07	0:26	MAIN SUPPLY FAILURE
280	5-Jul-19	GULBARGA	220	SHAHPUR220-KAPNOOR	SHAHAPUR_220	15:08	15:16	0:08	LINE FAULT
281	5-Jul-19	GULBARGA	220	HV1	SHAHAPUR_220	17:39	19:06	1:27	TRANSFORMER FAULT
282	5-Jul-19	GULBARGA	220	HV2 ,LV2	SHAHAPUR_220	19:07	19:36	0:29	TRANSFORMER FAULT
283	5-Jul-19	GULBARGA	220	SHAHPUR220-RTPS1	SHAHAPUR_220	19:47	19:59	0:12	LINE FAULT
284	5-Jul-19	GULBARGA	220	SHAHPUR220-RTPS2	SHAHAPUR_220	19:47	20:00	0:13	LINE FAULT
285	5-Jul-19	GULBARGA	220	SHAHPUR220-SHAHBAD	SHAHBAD_220	19:47	20:32	0:45	LINE FAULT
286	5-Jul-19	GULBARGA	110	SINDHANOOR220-PGLRWIND_IPP	SIDHANOOR_220	2:30	2:40	0:10	LINE FAULT
287	5-Jul-19	GULBARGA	110	SINDHANOOR220-PGLRWIND_IPP	SIDHANOOR_220	2:55	3:18	0:23	LINE FAULT
288	5-Jul-19	GULBARGA	110	HV2	YELBURGA_110	9:06	9:14	0:08	TRANSFORMER FAULT
289	5-Jul-19	GULBARGA	110	SINDHANOOR-MASKI	MASKI_110	13:19	13:41	0:22	LINE CLEAR AVAILED
290	5-Jul-19	GULBARGA	110	MASKI-RNWSLR_IPP	RENEWSOLAR_IPP	13:20	13:43	0:23	HAND TRIPPED
291	5-Jul-19	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	SHAHISOLAR_IPP	14:35	16:00	1:25	LINE FAULT
292	5-Jul-19	GULBARGA	110	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	12:25	12:42	0:17	LINE CLEAR AVAILED
293	5-Jul-19	GULBARGA	110	ITTAGI-CLEANMAX_IPP	ITTAGI_220	12:25	12:38	0:13	LINE CLEAR AVAILED
294	5-Jul-19	GULBARGA	110	SHAHPUR220-SHAHPUR1	SHAHPUR_110,NALWAR_110	15:02	15:25	0:23	LINE CLEAR AVAILED
295	5-Jul-19	GULBARGA	110	SHAHPUR220-SHAHPUR2	SHAHPUR_110,GOOGLE_110	0:00	15:17	15:17	LINE FAULT
296	5-Jul-19	GULBARGA	110	SHAHPUR220-SHAHPUR2	SHAHPUR_110,GOOGLE_110	15:41	17:02	1:21	LINE FAULT
297	5-Jul-19	GULBARGA	110	SHAHPUR220-SHAHPUR1	SHAHPUR_110,NALWAR_110	16:05	16:08	0:03	LINE CLEAR AVAILED
298	5-Jul-19	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURUGUNTA_110	10:15	19:25	9:10	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
299	5-Jul-19	GULBARGA	110	GURUGUNTA-LJVL_IPP	GURUGUNTA_110	10:15	19:25	9:10	LINE CLEAR AVAILED
300	5-Jul-19	GULBARGA	66	HV1	KOTTUR_66	11:12	12:14	1:02	LINE CLEAR AVAILED
301	5-Jul-19	GULBARGA	66	HV1	KOTTUR_66	14:03	14:17	0:14	LINE CLEAR AVAILED
302	5-Jul-19	GULBARGA	66	HV1	CHORNOOR_66	17:15	17:25	0:10	TRANSFORMER FAULT
303	5-Jul-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	1:07	7:01	5:54	LINE CLEAR AVAILED
304	5-Jul-19	HASSAN	220	ARSK2-HSN	ARASIKERE_220	0:00	0:10	0:10	NFBC ISSUED
305	5-Jul-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	0:00	13:10	13:10	LINE FAULT
306	5-Jul-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	0:00	13:06	13:06	LINE FAULT
307	5-Jul-19	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	14:41	15:23	0:42	LINE FAULT
308	5-Jul-19	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	14:42	15:13	0:31	LINE FAULT
309	5-Jul-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	14:42	15:04	0:22	LINE CURTAILMENT
310	5-Jul-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	14:42	15:04	0:22	LINE CURTAILMENT
311	5-Jul-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	14:42	15:04	0:22	LINE CURTAILMENT
312	5-Jul-19	HASSAN	110	KAVOOR-AMR	KAVOOR_220	11:12	13:40	2:28	LINE CLEAR AVAILED
313	5-Jul-19	HASSAN	66	HASSN22-SKPURA	HASSAN_220	16:01	16:13	0:12	HAND TRIPPED
314	5-Jul-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:17	16:38	6:21	LINE CLEAR AVAILED
315	5-Jul-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:16	16:37	6:21	LINE CLEAR AVAILED
316	5-Jul-19	HASSAN	66	HV1	ALDUR_66	10:16	16:41	6:25	LINE CLEAR AVAILED
317	5-Jul-19	HASSAN	66	HV2	BELUR_66	10:59	17:04	6:05	LINE CLEAR AVAILED
318	5-Jul-19	HASSAN	66	HV2	BELUR_66	17:56	18:00	0:04	HAND TRIPPED
319	5-Jul-19	HASSAN	66	HV2	BELUR_66	18:03	19:13	1:10	LINE CLEAR AVAILED
320	5-Jul-19	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	13:45	16:45	3:00	LINE CLEAR AVAILED
321	5-Jul-19	HASSAN	66	BELR66-MUDIGERE	BELUR_66	17:15	17:40	0:25	LINE CLEAR AVAILED
322	5-Jul-19	HASSAN	66	HV1	CHIKMAGALUR_66	11:08	11:22	0:14	LINE CLEAR AVAILED
323	5-Jul-19	HASSAN	66	HV2	CHIKMAGALUR_66	11:08	11:22	0:14	LINE CLEAR AVAILED
324	5-Jul-19	HASSAN	66	HV1	CHIKMAGALUR_66	16:46	17:01	0:15	LINE CLEAR AVAILED
325	5-Jul-19	HASSAN	66	HV2	CHIKMAGALUR_66	16:46	17:01	0:15	LINE CLEAR AVAILED
326	5-Jul-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	10:23	16:37	6:14	LINE CLEAR AVAILED
327	5-Jul-19	HASSAN	66	GENDEHA-HASSAN	GENDEHALLI_66	13:40	16:46	3:06	LINE CURTAILMENT
328	5-Jul-19	HASSAN	66	GENDEHA-HASSAN	GENDEHALLI_66	17:10	17:40	0:30	LINE CURTAILMENT
329	5-Jul-19	HASSAN	66	HV1	GENDEHALLI_66	13:40	16:46	3:06	LINE CURTAILMENT
330	5-Jul-19	HASSAN	66	HV1	GENDEHALLI_66	17:10	17:40	0:30	LINE CURTAILMENT
331	5-Jul-19	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	1:57	12:01	10:04	LINE CLEAR AVAILED
332	5-Jul-19	HASSAN	66	HV2	RAMNATHPURA_66	12:00	12:52	0:52	LINE CLEAR AVAILED
333	5-Jul-19	HASSAN	66	HV2	SINGAPURA_66	5:59	6:07	0:08	TRANSFORMER FAULT
334	5-Jul-19	HASSAN	66	HV2	SINGAPURA_66	13:16	14:41	1:25	LINE CLEAR AVAILED
335	5-Jul-19	MYSORE	66	HV1	COWDALLI_66	11:39	13:26	1:47	LINE CLEAR AVAILED
336	5-Jul-19	MYSORE	66	HV2	COWDALLI_66	12:45	13:30	0:45	LINE CLEAR AVAILED
337	5-Jul-19	MYSORE	66	COWDALLI-MARTHALLI	RAMAPURA_MYS_66 MARTAHALLI_66	10:59	11:04	0:04	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
338	5-Jul-19	MYSORE	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	6:00	6:15	0:15	LINE FAULT
339	5-Jul-19	MYSORE	66	HV1	KIADBMANDYA_66	6:24	6:46	0:21	HAND TRIPPED
340	5-Jul-19	MYSORE	66	HV2	KIADBMANDYA_66	6:24	6:46	0:21	HAND TRIPPED
341	5-Jul-19	MYSORE	66	KIADBMANDYA-THUMBEEKERE	TUMBEEKERE_66	6:24	6:46	0:21	HAND TRIPPED
342	5-Jul-19	MYSORE	66	KIADBMANDYA-MADDUR	SOMANAHALLI_66 MADDUR_66	6:24	6:46	0:21	HAND TRIPPED
343	5-Jul-19	MYSORE	66	HV1	KIKKERI_66	13:01	23:59	10:58	LINE CLEAR AVAILED
344	5-Jul-19	MYSORE	66	HV3	SFCSHIVA_66	9:30	12:09	2:39	LINE CLEAR AVAILED
345	5-Jul-19	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	15:12	18:24	3:11	LINE CLEAR AVAILED
346	5-Jul-19	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	11:33	18:08	6:35	LINE CLEAR AVAILED
347	5-Jul-19	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	15:14	18:23	3:09	LINE CLEAR AVAILED
348	5-Jul-19	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	14:34	19:27	4:52	LINE CLEAR AVAILED
349	5-Jul-19	TUMKUR	220	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEL DIAMOND SOLAR_IPP_66	16:00	16:27	0:27	HAND TRIPPED
350	5-Jul-19	TUMKUR	110	TR-1	BANDIHALLI_110	10:47	13:42	2:55	LINE CLEAR AVAILED
351	5-Jul-19	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	12:20	13:45	1:24	LINE CLEAR AVAILED
352	5-Jul-19	TUMKUR	66	CHITRADURGA 220kV- SUZLON 1	SUZLON1_IPP_66, SUZLON2_IPP_66	15:09	15:48	0:38	HAND TRIPPED
353	5-Jul-19	TUMKUR	66	TR-2	DAVANAGERE_66	12:03	12:09	0:06	TRANSFORMER FAULT
354	5-Jul-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	13:46	13:56	0:10	LINE FAULT
355	5-Jul-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:06	16:15	0:09	LINE FAULT
356	5-Jul-19	TUMKUR	66	TR-1	GARAGA_66	18:27	18:46	0:19	LINE CLEAR AVAILED
357	5-Jul-19	TUMKUR	66	TR-2	GARAGA_66	18:02	18:24	0:21	LINE CLEAR AVAILED
358	5-Jul-19	TUMKUR	66	H D PURA- MMCLWINDMILL	MMCLWINDMILL_IPP_66	14:34	15:02	0:28	LINE FAULT
359	5-Jul-19	TUMKUR	66	MELKOTE-BADIHALLI	BADDIHALLI_66	12:17	12:45	0:27	LINE CLEAR AVAILED
360	5-Jul-19	TUMKUR	66	TR-2	MELKOTE_66	12:17	13:07	0:49	LINE CLEAR AVAILED
361	5-Jul-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:02	17:44	8:42	LINE FAULT
362	6-Jul-19	BAGALKOT	110	110/33KV,HV3	ANKALI_110, NANDIKURALI_33	17:32	17:48	0:16	TRANSFORMER FAULT
363	6-Jul-19	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	11:54	13:07	1:13	LINE CLEAR AVAILED
364	6-Jul-19	BAGALKOT	110	BAGALKOT220-BAGALKOT110	BAGALKOT_110	1:57	2:14	0:17	LINE FAULT
365	6-Jul-19	BAGALKOT	110	GADAG-BETAGERI	BETAGERI_110	11:34	14:57	3:23	LINE CLEAR AVAILED
366	6-Jul-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	0:00	7:34	7:34	LINE CLEAR AVAILED
367	6-Jul-19	BAGALKOT	110	GADAG220-BETAGERI	BETAGERI_110	10:46	14:46	4:00	LINE CLEAR AVAILED
368	6-Jul-19	BAGALKOT	110	RON 1&2-GAJENDRAGAD	GAJENDRAGAD_110	11:21	11:26	0:05	MAIN SUPPLY FAILURE
369	6-Jul-19	BAGALKOT	110	RON 1-GAJENDRAGAD	GAJENDRAGAD_110	14:53	14:56	0:03	HAND TRIPPED
370	6-Jul-19	BAGALKOT	110	110/33KV,HV2	GAJENDRAGAD_110	16:35	20:04	3:29	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
371	6-Jul-19	BAGALKOT	110	RON 2-GAJENDRAGAD	GAJENDRAGAD_110	14:53	23:59	9:06	LINE FAULT
372	6-Jul-19	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	11:23	23:59	12:36	MAIN SUPPLY FAILURE
373	6-Jul-19	BAGALKOT	110	GSML 1&2-MAHALINGAPUR	MAHALINGAPUR_220	8:59	17:47	8:48	LINE CLEAR AVAILED
374	6-Jul-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DHULKED_33	7:56	8:04	0:08	TRANSFORMER FAULT
375	6-Jul-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DHULKED_33	8:48	8:52	0:04	TRANSFORMER FAULT
376	6-Jul-19	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	11:38	12:00	0:22	LINE CLEAR AVAILED
377	6-Jul-19	BAGALKOT	110	GAMESHA-RON	RON_110	11:38	15:35	3:57	LINE CLEAR AVAILED
378	6-Jul-19	BAGALKOT	110	110/11KV, HV2	RON_110	15:50	16:37	0:47	TRANSFORMER FAULT
379	6-Jul-19	BAGALKOT	110	110/33KV, HV3	RON_110, MUSIGHERI_33	15:50	16:41	0:51	TRANSFORMER FAULT
380	6-Jul-19	BAGALKOT	220	NARENDRA-BIDNAL	NARENDRA_220	11:54	13:06	1:12	LINE CLEAR AVAILED
381	6-Jul-19	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	10:39	11:32	0:53	TRANSFORMER FAULT
382	6-Jul-19	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	12:52	12:58	0:06	TRANSFORMER FAULT
383	6-Jul-19	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	16:25	16:34	0:09	TRANSFORMER FAULT
384	6-Jul-19	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	16:39	16:59	0:20	TRANSFORMER FAULT
385	6-Jul-19	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	18:30	19:00	0:30	TRANSFORMER FAULT
386	6-Jul-19	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	19:44	19:57	0:13	TRANSFORMER FAULT
387	6-Jul-19	BAGALKOT	110	110/11KV, HV1	NANADI_110	10:15	14:48	4:33	LINE CLEAR AVAILED
388	6-Jul-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	20:03	23:59	3:56	LINE CLEAR AVAILED
389	6-Jul-19	BAGALKOT	110	MK HUBLI220-HIREBAGEWADI	HIREBAGEWADI_110	20:09	23:59	3:50	LINE CLEAR AVAILED
390	6-Jul-19	BENGALURU	66	TK HALLI 220 - SHIMSHA 2	TK HALLI 220	13:32	13:54	0:21	LINE FAULT
391	6-Jul-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	13:40	13:53	0:12	MAIN SUPPLY FAILURE
392	6-Jul-19	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	13:41	13:51	0:10	MAIN SUPPLY FAILURE
393	6-Jul-19	BENGALURU	220	LV2	TK HALLI 220	13:32	13:40	0:08	TRANSFORMER FAULT
394	6-Jul-19	BENGALURU	220	LV2	TK HALLI 220	13:40	13:50	0:10	TRANSFORMER FAULT
395	6-Jul-19	BENGALURU	220	HV2	TK HALLI 220	13:32	13:38	0:05	TRANSFORMER FAULT
396	6-Jul-19	BENGALURU	220	HV2	TK HALLI 220	13:40	13:49	0:09	TRANSFORMER FAULT
397	6-Jul-19	BENGALURU	66	HV2	ST JOHNS	11:01	11:06	0:04	LINE CLEAR AVAILED
398	6-Jul-19	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	9:51	13:38	3:46	LINE CLEAR AVAILED
399	6-Jul-19	BENGALURU	66	HV2	NRS 220	11:09	11:37	0:27	MAIN SUPPLY FAILURE
400	6-Jul-19	BENGALURU	66	HV2	EPIP 220	15:47	17:22	1:35	LINE CLEAR AVAILED
401	6-Jul-19	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	0:00	20:48	20:48	LINE FAULT
402	6-Jul-19	BENGALURU	66	YERANDANAHALLI 220	HV2	12:20	12:26	0:06	LOAD CHANGE OVER
403	6-Jul-19	BENGALURU	66	HAROBEL - KODIHALLI	KODIHALLI, HUNSENAHALLI, BIJJAHALLI	11:00	11:20	0:20	LINE CLEAR AVAILED
404	6-Jul-19	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	10:58	13:25	2:27	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
405	6-Jul-19	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	13:40	13:45	0:05	LINE FAULT
406	6-Jul-19	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	13:50	14:00	0:10	LINE FAULT
407	6-Jul-19	BENGALURU	66	KODIHALLI - HUNSENAHALLI	HUNSENAHALLI, BIJJAHALLI	10:39	11:26	0:47	LINE FAULT
408	6-Jul-19	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE, MATHIKERE	21:15	21:34	0:19	LINE FAULT
409	6-Jul-19	BENGALURU	66	HV1	CB PURA URBAN	13:29	13:50	0:21	LINE CLEAR AVAILED
410	6-Jul-19	BENGALURU	66	HV2	MALLASANDRA	14:21	14:49	0:28	TRANSFORMER FAULT
411	6-Jul-19	BENGALURU	66	HV2	MALLASANDRA	11:52	12:00	0:08	TRANSFORMER FAULT
412	6-Jul-19	BENGALURU	66	ITTAGI-SUZLON1,2	ITTAGI_220	9:03	9:27	0:24	LINE CLEAR AVAILED
413	6-Jul-19	BENGALURU	66	ITTAGI-CLEANMAX2_IPP	ITTAGI_220	10:34	10:42	0:08	LINE CLEAR AVAILED
414	6-Jul-19	BENGALURU	66	ITTAGI-HIREHADAGALLI2	HIREHADAGALI_66,GIRIYAPURA_110, SOVENAHALLI_66,TUNGABHADRA_IP P,MAGALA_66	5:42	5:50	0:08	LINE FAULT
415	6-Jul-19	BENGALURU	66	HV3	HAGARIBOMMANAHALLI_66	6:50	7:45	0:55	TRANSFORMER FAULT
416	6-Jul-19	BENGALURU	66	HV3	HAGARIBOMMANAHALLI_66	11:20	12:10	0:50	LINE CLEAR AVAILED
417	6-Jul-19	BENGALURU	66	HV3	HAGARIBOMMANAHALLI_66	12:40	12:45	0:05	TRANSFORMER FAULT
418	6-Jul-19	BENGALURU	66	HV1	HAGARIBOMMANAHALLI_66	16:30	16:35	0:05	TRANSFORMER FAULT
419	6-Jul-19	BENGALURU	66	HV1	HANASI_66	7:34	7:43	0:09	TRANSFORMER FAULT
420	6-Jul-19	BENGALURU	66	KOGALI-ATRSOLAR_IPP	KOGALI_66	11:55	11:58	0:03	LINE CLEAR AVAILED
421	6-Jul-19	BENGALURU	66	HV1	HAMPASAGAR_66	14:54	15:03	0:09	TRANSFORMER FAULT
422	6-Jul-19	BENGALURU	66	ITTAGI-SUZLON1	ITTAGI_220	17:20	17:32	0:12	LINE FAULT
423	6-Jul-19	BENGALURU	66	ITTAGI-SUZLON1	ITTAGI_220	18:10	18:20	0:10	LINE FAULT
424	6-Jul-19	BENGALURU	66	HNPR2-MYSOR1	HOLENARASIPURA_220	18:56	19:04	0:08	LINE FAULT
425	6-Jul-19	BENGALURU	66	HV2	HNPURA_66	19:07	19:08	0:01	MAIN SUPPLY FAILURE
426	6-Jul-19	BENGALURU	66	HNPURA-SOMANAHALLI	HNPURA_66	19:07	19:08	0:01	MAIN SUPPLY FAILURE
427	6-Jul-19	BENGALURU	66	HV2	RAMNATHPURA_66	11:40	11:55	0:15	LINE CLEAR AVAILED
428	6-Jul-19	BENGALURU	66	HV2	RAMNATHPURA_66	14:24	15:16	0:52	LINE CLEAR AVAILED
429	6-Jul-19	BENGALURU	66	SAKALE-IPCL2	SAKLESHPURA_66	7:42	7:54	0:12	LINE FAULT
430	6-Jul-19	BENGALURU	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	9:26	9:42	0:16	LINE FAULT
431	6-Jul-19	BENGALURU	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	15:05	18:25	3:20	LINE CLEAR AVAILED
432	6-Jul-19	BENGALURU	66	COWDALLI-MARTHALLI	MARTAHALLI_66 RAMAPURA_MYS_66	5:55	7:21	1:26	LINE FAULT
433	6-Jul-19	BENGALURU	66	CR NAGARA-YALANDUR	MAMBALLI_66 YELANDUR_66	14:47	14:54	0:07	LINE FAULT
434	6-Jul-19	BENGALURU	66	HV1	GUNDULPET_66	3:21	6:22	3:01	TRANSFORMER FAULT
435	6-Jul-19	BENGALURU	66	HV2	GUNDULPET_66	4:05	5:15	1:10	LINE CLEAR AVAILED
436	6-Jul-19	BENGALURU	66	HV1	GUNDULPET_66	5:30	6:22	0:52	LINE CLEAR AVAILED
437	6-Jul-19	BENGALURU	66	HV2	GUNDULPET_66	5:30	6:05	0:35	LINE CLEAR AVAILED
438	6-Jul-19	BENGALURU	66	HOOTAGALLI-DATAGALLI	DATTAGALLY_66	10:47	17:23	6:36	LINE CLEAR AVAILED
439	6-Jul-19	BENGALURU	66	KADAKOLA-SARAGURU 2	DOORA_66 HURA_66 HULLAHALLI_66	19:58	20:06	0:08	LINE FAULT
440	6-Jul-19	BENGALURU	66	HV1	KHBCOLONY_66	16:18	16:38	0:20	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
441	6-Jul-19	BENGALURU	66	HV1	K_HONNALGERE_66	13:33	13:52	0:18	HAND TRIPPED
442	6-Jul-19	BENGALURU	66	HV2	K_HONNALGERE_66	13:33	13:52	0:18	HAND TRIPPED
443	6-Jul-19	BENGALURU	66	HV1	KIADBMANDYA_66	13:33	13:55	0:21	HAND TRIPPED
444	6-Jul-19	BENGALURU	66	HV2	KIADBMANDYA_66	13:33	13:55	0:21	HAND TRIPPED
445	6-Jul-19	BENGALURU	66	HV1	KRNAGARA_66	8:01	8:20	0:18	TRANSFORMER FAULT
446	6-Jul-19	BENGALURU	66	HV2	KRPET_66	13:21	13:40	0:19	LINE CLEAR AVAILED
447	6-Jul-19	BENGALURU	66	HV3	KRPET_66	14:01	14:16	0:15	LINE CLEAR AVAILED
448	6-Jul-19	BENGALURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66 YELANDUR_66	5:55	23:59	18:04	LINE FAULT
449	6-Jul-19	BENGALURU	66	HV1	MADHUVANAHALLI_220	6:10	6:43	0:33	HAND TRIPPED
450	6-Jul-19	BENGALURU	66	HV2	MADHUVANAHALLI_220	6:10	6:50	0:40	HAND TRIPPED
451	6-Jul-19	BENGALURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	5:55	23:59	18:04	TRIPPED ON DPR & KEPT OPEN DUE TO (R, Y & B-PH) BREAKER LIMBS FLASH OVER. LC ISSUED TO TLI JE MADHUVANAHALLI @ 12:45 TO CARRYOUT RE-STRINGING WORK @ TOWER NO. 02 & 03 LC RETURNED @ 17:50. SUPPLY RESTORED VIA BUS COUPLER & UNDER HUNG GOS. PG PALYA STATION INTERRUPTED UPTO 18:18Hrs
452	6-Jul-19	BENGALURU	66	RK NAGARA-DATAGALLI	DATTAGALLY_66	10:17	17:30	7:13	NFBC ISSUED
453	6-Jul-19	BENGALURU	66	HV1	TUBINAKERE_220	21:56	22:13	0:17	HAND TRIPPED
454	6-Jul-19	BENGALURU	66	HV2	TUBINAKERE_220	21:56	22:13	0:17	HAND TRIPPED
455	6-Jul-19	BENGALURU	66	ANCHEPALYA 220kV- BG NAGAR	YEDIYUR_66	13:34	13:43	0:08	LINE FAULT
456	6-Jul-19	BENGALURU	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	21:05	21:15	0:10	LINE FAULT
457	6-Jul-19	BENGALURU	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	12:07	17:36	5:29	LINE FAULT
458	6-Jul-19	BENGALURU	66	TR-2	BELLAVI_66	11:59	12:37	0:37	TRANSFORMER FAULT
459	6-Jul-19	BENGALURU	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	5:58	6:20	0:22	LINE FAULT
460	6-Jul-19	BENGALURU	66	TR-2	KUNIGAL_66	12:48	12:56	0:08	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
461	6-Jul-19	BENGALURU	66	NEELAGUNDA 220kv-PUNABHAGHATTA	PUNABHAGHATTA_66,HARAPPANAH ALLI_66,HALUVAGALU_66,TELAGI_66	0:36	0:48	0:11	LINE FAULT
462	6-Jul-19	BENGALURU	66	TR-2	NITRAHALLI_66	16:10	17:53	1:42	LINE CLEAR AVAILED
463	6-Jul-19	BENGALURU	66	SASALUHALLA-MAYAKONDA	SASALUHALLA_66	8:23	13:20	4:57	LINE CLEAR AVAILED
464	6-Jul-19	GULBARGA	400	JSWVL400-GUTTUR	JSWVL_400	1:03	6:50	5:47	LINE FAULT
465	6-Jul-19	GULBARGA	400	JSWVL400-GUTTUR	JSWVL_400	18:00	23:59	5:59	LINE FAULT
466	6-Jul-19	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	5:21	5:31	0:10	LINE FAULT
467	6-Jul-19	GULBARGA	110	HV1	KUDITINI_110	15:40	15:53	0:13	TRANSFORMER FAULT
468	6-Jul-19	GULBARGA	110	HV1	HANUMASAGAR_110	13:00	13:25	0:25	TRANSFORMER FAULT
469	6-Jul-19	GULBARGA	110	HV1	HANUMASAGAR_110	14:05	14:15	0:10	TRANSFORMER FAULT
470	6-Jul-19	GULBARGA	110	HV1	RAICHUR_110	11:05	11:42	0:37	TRANSFORMER FAULT
471	6-Jul-19	GULBARGA	110	YELBURGA-PARAMPUJYA_IPP	YELBURGA_110	15:41	15:55	0:14	LINE FAULT
472	6-Jul-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	1:58	2:15	0:17	LINE FAULT
473	6-Jul-19	GULBARGA	110	KAPNOOR-GULBARGA NORTH1,2	GULBARGANORTH_110,GULBARGASO UTH_110,GULBARGAUNIVERSITY_110	10:16	10:55	0:39	LINE CLEAR AVAILED
474	6-Jul-19	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	KOLHAR_110	13:19	13:29	0:10	LINE CLEAR AVAILED
475	6-Jul-19	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURUGUNTA_110	10:45	19:10	8:25	LINE CLEAR AVAILED
476	6-Jul-19	GULBARGA	110	GURUGUNTA-LJVL_IPP	GURUGUNTA_110	10:45	19:11	8:26	LINE CLEAR AVAILED
477	6-Jul-19	GULBARGA	110	HV2	MADIYAL_110	14:34	14:39	0:05	TRANSFORMER FAULT
478	6-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:07	6:33	6:26	LINE CLEAR AVAILED
479	6-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	20:05	23:54	3:49	LINE CLEAR AVAILED
480	6-Jul-19	HASSAN	110	ARSK2-BANAVARA	ARSIKERE_220	11:20	23:59	12:39	LINE CLEAR AVAILED
481	6-Jul-19	HASSAN	110	ARSK2-GERUMARA	ARSIKERE_220	12:39	12:47	0:08	HAND TRIPPED
482	6-Jul-19	HASSAN	110	HV2	BAIKAMPADI_110	12:15	13:11	0:56	LINE CLEAR AVAILED
483	6-Jul-19	HASSAN	110	HV2	SAGARA_110	10:11	10:27	0:16	HAND TRIPPED
484	6-Jul-19	MYSORE	220	HV2	KRPET_220	13:36	15:00	1:23	TRANSFORMER FAULT
485	6-Jul-19	MYSORE	220	HV1	MADHUVANAHALLI_220 DODDINADUVADI_66 BANDALLI_66 COWDALLI_66 KOTTANUR_66 HANNUR_66 KOLLEGALA_66 PARINAMIPURA_66 THALAKADU_66 SATHEGALA_66 BGPURA_66 CHANDALLI_66 MARTAHALLI_66 YELANDUR_66 MAMBALLI_66 RAMAPURA_MYS_66 PGPALYA_66	5:55	6:41	0:46	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
486	6-Jul-19	MYSORE	220	HV2	MADHUVANAHALLI_220 DODDINADUVADI_66 BANDALLI_66 COWDALLI_66 KOTTANUR_66 HANNUR_66 KOLLEGALA_66 PARINAMIPURA_66 THALAKADU_66 SATHEGALA_66 BGPURA_66 CHANDALLI_66 MARTAHALLI_66 YELANDUR_66 MAMBALLI_66 RAMAPURA_MYS_66 PGPALYA_66	5:55	6:47	0:52	TRANSFORMER FAULT
487	6-Jul-19	MYSORE	220	HV1	TUBINAKERE_220	21:56	22:10	0:14	TRANSFORMER FAULT
488	6-Jul-19	TUMKUR	220	ANCHEPALYA 220kV- MAGADI	ANCHEPALYA_220	18:49	19:19	0:30	LINE CLEAR AVAILED
489	6-Jul-19	TUMKUR	110	TR-1	TALKERE_110	12:28	12:57	0:29	LINE CLEAR AVAILED
490	6-Jul-19	TUMKUR	110	BANDIHALLI- TIPTUR	TIPTUR_110, HONNAVALLI_110	17:16	19:24	2:07	LINE FAULT
491	7-Jul-19	BAGALKOT	110	ATHANI-RENUKA SUGARS	ATHANI_110	6:17	17:55	11:38	LINE CLEAR AVAILED
492	7-Jul-19	BAGALKOT	110	110/11KV,HV2	BABALESHWAR_110	7:17	7:46	0:29	TRANSFORMER FAULT
493	7-Jul-19	BAGALKOT	110	BAGEWADI-NIDAGUNDI(RAMPUR)	NIDAGINDI_110	13:27	13:43	0:16	LINE FAULT
494	7-Jul-19	BAGALKOT	220	BELGAUM-KANABARGI2	BELGAUM_220	17:29	23:59	6:30	LINE CLEAR AVAILED
495	7-Jul-19	BAGALKOT	110	220/110KV,LV2	BELGAUM_220	1:57	5:03	3:06	LINE CLEAR AVAILED
496	7-Jul-19	BAGALKOT	110	110/33KV,HV2	GAJENDRAGAD_110	14:24	15:00	0:36	TRANSFORMER FAULT
497	7-Jul-19	BAGALKOT	110	110/33KV, HV3	UGARKHUD_110, SHEDBAL_33, MANGSULI_33	10:40	11:29	0:49	TRANSFORMER FAULT
498	7-Jul-19	BAGALKOT	110	110/33KV, HV1	HUBLI_220, TAUSHI_33	23:48	23:59	0:11	TRANSFORMER FAULT
499	7-Jul-19	BAGALKOT	220	NAGJHARI2-HUBLI	HUBLI_220	21:42	22:20	0:38	LINE FAULT
500	7-Jul-19	BAGALKOT	110	BLGUM_SLR-MAMADAPUR	MAMADAPUR(B)_110	13:31	13:54	0:23	LINE CURTAILMENT
501	7-Jul-19	BAGALKOT	110	110/33KV, HV3	MUDDEBIHAL_110,NALATAWAD_33K V	13:39	14:12	0:33	TRANSFORMER FAULT
502	7-Jul-19	BAGALKOT	110	110/33KV, HV3	MUDDEBIHAL_110,NALATAWAD_33K V	14:31	14:38	0:07	TRANSFORMER FAULT
503	7-Jul-19	BENGALURU	66	BIDADI 220 - BOSCH (EHT)	BOSCH (EHT)	9:40	14:23	4:43	LINE CLEAR AVAILED
504	7-Jul-19	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220		11:50	12:04	0:14	LOAD CHANGEOR
505	7-Jul-19	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220		13:43	13:48	0:05	LINE CLEAR AVAILED
506	7-Jul-19	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	22:52	23:06	0:13	LOAD CHANGEOR
507	7-Jul-19	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	22:38	22:44	0:05	LOAD CHANGEOR
508	7-Jul-19	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	GOKULA, BEL (EHT), HMT (EHT)	7:15	8:44	1:28	LINE FAULT
509	7-Jul-19	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	GOKULA, BEL (EHT), HMT (EHT)	8:45	10:17	1:32	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
510	7-Jul-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	16:25	16:31	0:06	LINE FAULT
511	7-Jul-19	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	12:52	13:16	0:23	LINE FAULT
512	7-Jul-19	BENGALURU	66	CB PURA I/A - CB PURA URBAN	CB PURA URBAN	11:26	13:08	1:41	LINE CLEAR AVAILED
513	7-Jul-19	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	15:12	15:20	0:08	LINE FAULT
514	7-Jul-19	BENGALURU	66	HV2	MAASTHI	10:10	10:14	0:04	TRANSFORMER FAULT
515	7-Jul-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	9:19	14:00	4:41	LINE CLEAR AVAILED
516	7-Jul-19	BENGALURU	66	HV3	JIGANI 66	9:20	19:10	9:50	MAIN SUPPLY FAILURE
517	7-Jul-19	BENGALURU	66	HV2	JIGANI 66	9:20	19:10	9:50	MAIN SUPPLY FAILURE
518	7-Jul-19	BENGALURU	66	HV1	JIGANI 66	9:26	19:50	10:24	MAIN SUPPLY FAILURE
519	7-Jul-19	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	7:35	8:25	0:50	LINE FAULT
520	7-Jul-19	BENGALURU	66	ITTAGI-CLNMAX_SOLAR1	ITTAGI_220	9:55	10:00	0:05	HAND TRIPPED
521	7-Jul-19	BENGALURU	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	10:40	10:45	0:05	HAND TRIPPED
522	7-Jul-19	BENGALURU	66	ITTAGI-BENNEHALLI	ITTAGI_220	13:10	13:18	0:08	HAND TRIPPED
523	7-Jul-19	BENGALURU	66	HV1	KRPET_220	18:24	18:44	0:20	TRANSFORMER FAULT
524	7-Jul-19	BENGALURU	66	HV1	TUBINAKERE_220	20:01	20:30	0:29	HAND TRIPPED
525	7-Jul-19	BENGALURU	66	HV2	TUBINAKERE_220	20:01	20:30	0:29	HAND TRIPPED
526	7-Jul-19	BENGALURU	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	13:27	14:10	0:42	HAND TRIPPED
527	7-Jul-19	BENGALURU	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	13:40	14:07	0:27	HAND TRIPPED
528	7-Jul-19	BENGALURU	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	4:01	4:13	0:11	LINE FAULT
529	7-Jul-19	BENGALURU	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	21:48	22:15	0:26	HAND TRIPPED
530	7-Jul-19	BENGALURU	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	13:26	14:08	0:42	HAND TRIPPED
531	7-Jul-19	BENGALURU	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	4:27	5:16	0:49	LINE FAULT
532	7-Jul-19	BENGALURU	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	14:39	15:11	0:32	HAND TRIPPED
533	7-Jul-19	BENGALURU	66	TR-1	YNHOSKOTE_66	16:53	16:56	0:03	TRANSFORMER FAULT
534	7-Jul-19	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	9:06	15:17	6:11	LINE CLEAR AVAILED
535	7-Jul-19	GULBARGA	110	SINDHANOOR-SUZLON1	SIDHANOOR_220	1:33	2:25	0:52	LINE FAULT
536	7-Jul-19	GULBARGA	110	SIDHANOOR-PGLR_WIND	SIDHANOOR_220	3:00	3:32	0:32	LINE FAULT
537	7-Jul-19	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURUGUNTA_110	19:19	19:41	0:22	LINE CLEAR AVAILED
538	7-Jul-19	GULBARGA	110	GURUGUNTA-LJVL_IPP	GURUGUNTA_110	19:19	19:41	0:22	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
539	7-Jul-19	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	KOLHAR_110	12:15	12:55	0:40	LINE CLEAR AVAILED
540	7-Jul-19	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	KOLHAR_110	16:50	17:55	1:05	LINE CLEAR AVAILED
541	7-Jul-19	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	KOLHAR_110	14:00	14:20	0:20	HAND TRIPPED
542	7-Jul-19	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	KOLHAR_110	20:25	20:30	0:05	LINE FAULT
543	7-Jul-19	GULBARGA	110	KOLHAR-NSSK	KOLHAR_110	20:25	20:30	0:05	LINE FAULT
544	7-Jul-19	GULBARGA	110	HV3	KOLHAR_110	11:00	12:15	1:15	LINE CLEAR AVAILED
545	7-Jul-19	GULBARGA	110	YELBURGA-PARAMPUJYA_IPP	YELBURGA_110	14:58	15:15	0:17	LINE FAULT
546	7-Jul-19	GULBARGA	110	YELBURGA-PARAMPUJYA_IPP	YELBURGA_110	15:20	15:30	0:10	LINE FAULT
547	7-Jul-19	GULBARGA	110	YELBURGA-PARAMPUJYA_IPP	YELBURGA_110	15:50	16:33	0:43	LINE FAULT
548	7-Jul-19	GULBARGA	110	HV2	SHORAPUR_110	10:35	10:55	0:20	TRANSFORMER FAULT
549	7-Jul-19	GULBARGA	110	HV2	SHORAPUR_110	15:30	15:55	0:25	TRANSFORMER FAULT
550	7-Jul-19	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHPUR_110,NALWAR_110	15:16	19:35	4:19	LINE FAULT
551	7-Jul-19	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	8:29	20:09	11:40	NFBC ISSUED
552	7-Jul-19	HASSAN	110	HV1	ARSIKERE_220	5:00	5:27	0:27	TRANSFORMER FAULT
553	7-Jul-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	12:38	12:45	0:07	LINE FAULT
554	7-Jul-19	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	12:45	12:52	0:07	MAIN SUPPLY FAILURE
555	7-Jul-19	HASSAN	110	HV2	SHIKARIPURA_110	13:00	13:21	0:21	LINE CLEAR AVAILED
556	7-Jul-19	MYSORE	220	HV1	TUBINAKERE_220	20:01	20:23	0:22	TRANSFORMER FAULT
557	08-Jul-19	BAGALKOT	110	110/33KV, HV1	HUBLI_220, TAUSHI_33	0:00	0:42	0:42	LINE CLEAR AVAILED
558	08-Jul-19	BAGALKOT	220	SHARAVATHY2-SIRSI	SIRSI_220	11:22	19:24	8:02	LINE FAULT
559	08-Jul-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	16:27	16:40	0:13	LINE FAULT
560	08-Jul-19	BAGALKOT	110	110/11KV, HV1	SHIRAHATTI_110	15:22	17:15	1:53	LINE CLEAR AVAILED
561	08-Jul-19	BAGALKOT	110	RON-GAJENDRAGAD1&2	GAJENDRAGAD_110	11:23	11:28	0:05	HAND TRIPPED
562	08-Jul-19	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	11:23	11:29	0:06	HAND TRIPPED
563	08-Jul-19	BAGALKOT	110	GAMESHA-RON	RON_110	11:23	11:38	0:15	HAND TRIPPED
564	08-Jul-19	BAGALKOT	110	RON-GAJENDRAGAD1	GAJENDRAGAD_110	19:59	21:19	1:20	LINE FAULT
565	08-Jul-19	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	19:59	20:15	0:16	LINE FAULT
566	08-Jul-19	BAGALKOT	110	PG HUNSHYAL-MUDALGI(NAGNUR)	NAGNUR_110	17:41	17:55	0:14	LINE FAULT
567	08-Jul-19	BAGALKOT	110	NAREGAL-RON	RON_110	11:13	11:19	0:06	HAND TRIPPED
568	08-Jul-19	BAGALKOT	220	BELGAUM-KANABARGI2	BELGAUM_220	0:00	6:29	6:29	LINE CLEAR AVAILED
569	08-Jul-19	BAGALKOT	110	110/33KV,HV2	GAJENDRAGAD_110, WIND1&2_33	14:49	15:30	0:41	TRANSFORMER FAULT
570	08-Jul-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	17:46	23:59	6:13	LINE CLEAR AVAILED
571	08-Jul-19	BAGALKOT	110	110/11KV, HV1	DAMBAL_110	11:52	12:59	1:07	LINE CLEAR AVAILED
572	08-Jul-19	BAGALKOT	110	SUZLON2-DAMBAL	DAMBAL_110	19:09	20:58	1:49	LINE FAULT
573	08-Jul-19	BAGALKOT	110	GADAG220-BETAGERI	BETAGERI_110, NAREGAL_110,RON_110, GAJENDRGAD_110, HIREHAL_110	10:44	11:11	0:27	LINE FAULT
574	08-Jul-19	BAGALKOT	110	ATHANI220-BALIGERI(TAUSHI)	BALIGERI(TAUSHI)_110	13:46	19:12	5:26	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
575	08-Jul-19	BAGALKOT	110	RENUKA SUGARS-ATHANI110	ATHANI_110	18:10	18:46	0:36	LINE CLEAR AVAILED
576	08-Jul-19	BAGALKOT	110	RENUKA SUGARS-ATHANI110	ATHANI_110	19:45	20:05	0:20	LINE CLEAR AVAILED
577	08-Jul-19	BAGALKOT	110	RENUKA SUGARS-ATHANI110	ATHANI_110	21:41	22:48	1:07	LINE CLEAR AVAILED
578	08-Jul-19	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	16:38	16:54	0:16	LINE FAULT
579	08-Jul-19	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	16:56	17:01	0:05	HAND TRIPPED
580	08-Jul-19	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	17:39	23:59	6:20	LINE FAULT
581	08-Jul-19	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	1:58	2:05	0:07	LOAD CHANGEOVER
582	08-Jul-19	BENGALURU	66	GOKULA - RMV	GOKULA, BEL (EHT), HMT (EHT)	1:36	1:52	0:16	LOAD CHANGEOVER
583	08-Jul-19	BENGALURU	66	HV2	BAGHMANE WORLD TECH PARK	12:07	13:08	1:00	LINE CLEAR AVAILED
584	08-Jul-19	BENGALURU	66	HV2	YEDUMADU	12:54	13:18	0:23	LINE CLEAR AVAILED
585	08-Jul-19	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	11:46	12:00	0:14	LINE FAULT
586	08-Jul-19	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	12:00	12:14	0:13	LINE FAULT
587	08-Jul-19	GULBARGA	400	JSWVL400-GUTTUR	JSWVL_400	0:00	9:05	9:05	LINE FAULT
588	08-Jul-19	GULBARGA	400	BTPS-JSWVL	BTPS_400	2:43	7:10	4:27	LINE FAULT
589	08-Jul-19	GULBARGA	400	BTPS-RTPS	BTPS_400	5:21	6:38	1:17	LINE FAULT
590	08-Jul-19	GULBARGA	220	ALIPUR-GOOTY	ALIPUR_220	10:37	13:45	3:08	LINE CLEAR AVAILED
591	08-Jul-19	GULBARGA	220	KAPANOOR-HUMNABAD1	MARAGUTTI_110,MAHAGAON_110	17:00	17:06	0:06	LINE FAULT
592	08-Jul-19	GULBARGA	220	KAPANOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110	20:10	20:33	0:23	LINE FAULT
593	08-Jul-19	GULBARGA	220	KAPANOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110	22:41	22:48	0:07	LINE FAULT
594	08-Jul-19	GULBARGA	220	HV1	KUSTAGI_220	13:25	13:35	0:10	TRANSFORMER FAULT
595	08-Jul-19	GULBARGA	220	HV1	KUSTAGI_220	15:00	15:15	0:15	TRANSFORMER FAULT
596	08-Jul-19	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,VALKAMDI NNI_110	0:56	1:10	0:14	LINE FAULT
597	08-Jul-19	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110, MADALAPURA_110, MANVI_110	11:27	11:37	0:10	LINE FAULT
598	08-Jul-19	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110, MADALAPURA_110, MANVI_110	11:37	12:40	1:03	LINE CLEAR AVAILED
599	08-Jul-19	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110, MADALAPURA_110, MANVI_110	3:03	3:34	0:31	LINE FAULT
600	08-Jul-19	GULBARGA	110	SINDHANOOR-SUZLON1	SIDHANOOR_220	1:53	2:18	0:25	LINE FAULT
601	08-Jul-19	GULBARGA	110	SINDHANOOR-SUZLON1	SIDHANOOR_220	3:50	4:08	0:18	LINE FAULT
602	08-Jul-19	GULBARGA	110	BETAGERA-KSHVCMNT_SLR	BETAGERA_110	19:09	19:16	0:07	LINE FAULT
603	08-Jul-19	GULBARGA	110	SHAHPUR220-SHAHPUR2	SHAHPUR_110	6:01	23:59	17:58	LINE FAULT
604	08-Jul-19	GULBARGA	66	ITTAGI-RNWSLR2	ITTAGI_220	10:42	10:49	0:07	LINE CLEAR AVAILED
605	08-Jul-19	GULBARGA	66	ITTAGI-SUZLON1,2	ITTAGI_220	11:15	11:30	0:15	LINE CLEAR AVAILED
606	08-Jul-19	GULBARGA	66	ITTAGI-CLNMAX1,2	ITTAGI_220	12:30	12:35	0:05	LINE CLEAR AVAILED
607	08-Jul-19	GULBARGA	66	KOGAL-ASTROSLR	KOGALI_66	14:20	14:29	0:09	LINE CLEAR AVAILED
608	08-Jul-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	9:24	9:24	LINE CLEAR AVAILED
609	08-Jul-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	12:24	23:59	11:35	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
610	08-Jul-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	15:33	15:53	0:20	LINE FAULT
611	08-Jul-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	15:33	15:53	0:20	LINE FAULT
612	08-Jul-19	HASSAN	110	HV1	BANTWALA_110	10:22	12:04	1:42	LINE CLEAR AVAILED
613	08-Jul-19	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	10:28	12:49	2:21	LINE CLEAR AVAILED
614	08-Jul-19	HASSAN	110	HV2	SORABA_110	12:12	13:05	0:53	LINE CLEAR AVAILED
615	08-Jul-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	8:51	13:57	5:06	LINE FAULT
616	08-Jul-19	HASSAN	66	HV2	RAMPURA_66	13:11	13:57	0:46	LINE CLEAR AVAILED
617	08-Jul-19	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	13:05	13:15	0:10	LINE FAULT
618	08-Jul-19	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	14:42	14:52	0:10	LINE FAULT
619	08-Jul-19	MYSORE	66	CHUNCHUN KATTE-KR NAGAR	MIRLE_66	12:15	14:05	1:50	NFBC ISSUED
620	08-Jul-19	MYSORE	66	KADAKOLA-SARGUR 2	DOORA_66 HULLAHALLI_66 CHANDRAWAD_66I HURA_66	7:37	10:07	2:30	LINE CLEAR AVAILED
621	08-Jul-19	MYSORE	66	KUSHAL NAGARA 220-MYSORE 1	MIRLE_66	11:49	14:03	2:13	LINE CLEAR AVAILED
622	08-Jul-19	MYSORE	66	HV1	PANDAVAPURA_66	11:16	11:27	0:10	HAND TRIPPED
623	08-Jul-19	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 1	ANCHEPALYA_220	15:10	18:47	3:36	LINE CLEAR AVAILED
624	08-Jul-19	TUMKUR	220	TR-1	ANTHRASANAHALLI_220	15:20	15:28	0:08	LINE CLEAR AVAILED
625	08-Jul-19	TUMKUR	220	TR-2	ANTHRASANAHALLI_220	15:09	15:16	0:06	LINE CLEAR AVAILED
626	08-Jul-19	TUMKUR	110	TR-1	KADABA_110	12:45	13:15	0:29	LINE CLEAR AVAILED
627	08-Jul-19	TUMKUR	66	TR-2(HV2)	ANTHRASANAHALLI_220	15:34	15:42	0:08	LINE CLEAR AVAILED
628	08-Jul-19	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	15:20	15:28	0:08	LINE CLEAR AVAILED
629	08-Jul-19	TUMKUR	66	TR-2(LV 2)	ANTHRASANAHALLI_220	15:09	15:16	0:06	LINE CLEAR AVAILED
630	08-Jul-19	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	12:00	16:00	4:00	LINE CLEAR AVAILED
631	08-Jul-19	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	15:07	15:32	0:25	LINE CLEAR AVAILED
632	08-Jul-19	TUMKUR	66	TR-2	GARAGA_66	15:24	16:06	0:42	LINE CLEAR AVAILED
633	08-Jul-19	TUMKUR	66	TR-1	HANAGAL_66	12:09	12:41	0:31	LINE CLEAR AVAILED
634	08-Jul-19	TUMKUR	66	TR-1	HARIHAR_66	8:36	9:22	0:45	TRANSFORMER FAULT
635	08-Jul-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	9:40	9:48	0:08	HAND TRIPPED