

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 15.03.2022 TO 21.03.2022

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	15-Mar-22	BAGALKOT	110	110/11KV, HV1	HUBLI_220	13:53	14:18	0:25	HAND TRIPPED
2	15-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KUDALASANGAM_110	7:53	7:58	0:05	TRANSFORMER FAULT
3	15-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KUDALASANGAM_110	6:16	6:25	0:09	TRANSFORMER FAULT
4	15-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KUDALASANGAM_110	2:15	2:23	0:08	TRANSFORMER FAULT
5	15-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NAVALAGI_110	14:33	15:29	0:56	TRANSFORMER FAULT
6	15-Mar-22	BAGALKOT	110	110/11KV, HV1	ARATAGAL_110	10:00	17:00	7:00	LINE CLEAR AVOIDED
7	15-Mar-22	BAGALKOT	110	110/11KV, HV2	HUBLI_220	13:53	14:01	0:08	HAND TRIPPED
8	15-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NIPPANI_110	20:58	22:32	1:34	TRANSFORMER FAULT
9	15-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NAVALAGI_110	14:33	15:29	0:56	TRANSFORMER FAULT
10	15-Mar-22	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	20:55	22:35	1:40	TRANSFORMER FAULT
11	15-Mar-22	BAGALKOT	110	110/11KV, HV2	ARATAGAL_110	10:00	17:00	7:00	LINE CLEAR AVOIDED
12	15-Mar-22	BAGALKOT	110	110/11KV, HV1	GADAG_110	15:16	15:47	0:31	TRANSFORMER FAULT
13	15-Mar-22	BAGALKOT	110	110/11KV, HV1	KANABARGI LAYOUT_110	14:35	16:45	2:10	LINE CLEAR AVOIDED
14	15-Mar-22	BAGALKOT	110	110/11KV, HV1	MAMADAPUR(B)_110	15:15	16:31	1:16	LINE CLEAR AVOIDED
15	15-Mar-22	BAGALKOT	110	110/11KV, HV1(HV4)	GOPPANAKOPPA_110	12:53	13:17	0:24	LINE CLEAR AVOIDED
16	15-Mar-22	BAGALKOT	110	110/11KV, HV2	BELGAUM_110	7:57	17:54	9:57	LINE CLEAR AVOIDED
17	15-Mar-22	BAGALKOT	110	110/11KV, HV2	BELGAUM_110	18:22	18:38	0:16	LINE CLEAR AVOIDED
18	15-Mar-22	BAGALKOT	110	110/11KV, HV2	AMINAGAD_33, KARADI_33, MYTRA_33 STATION NOT AFFECTED HUNAGUND_110	15:10	15:58	0:48	LINE CLEAR AVOIDED
19	15-Mar-22	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	18:41	18:51	0:10	TRANSFORMER FAULT
20	15-Mar-22	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	15:15	16:36	1:21	LINE CLEAR AVOIDED
21	15-Mar-22	BAGALKOT	110	110/33KV, HV3	HUBLI_220, TAUSHI_33	13:53	14:14	0:38	HAND TRIPPED
22	15-Mar-22	BAGALKOT	110	110/33KV, HV4	HUBLI_220, VRL_33	13:53	13:55	0:02	HAND TRIPPED
23	15-Mar-22	BAGALKOT	110	110/33KV, HV3	HONNUTAGI_33, NAGATAN_33 KIADB BIJAPUR_110	18:35	18:59	0:24	LINE CLEAR AVOIDED
24	15-Mar-22	BAGALKOT	110	110/33KV, HV3	MAMADAPUR(B)_110, DEVAR GENNUR_33, LINDALLI_LIS	16:50	17:21	0:31	LINE CLEAR AVOIDED
25	15-Mar-22	BAGALKOT	110	220/110KV, LV2	GADAG_220	13:10 (15.03.2022)			TRANSFORMER OPEN: LINE CLEAR AVOIDED
26	15-Mar-22	BAGALKOT	110	CHIKKODI220- CHIKKODI	CHIKKODI_110	14:40	15:40	1:00	LINE CLEAR AVOIDED
27	15-Mar-22	BAGALKOT	110	CHIKKODI220- RAIBAG	RAIBAG_110	14:40	16:05	1:25	LINE CLEAR AVOIDED
28	15-Mar-22	BAGALKOT	110	CHIKKODI220- SANKESHWAR	SANKESHWAR_110	14:40	15:32	0:52	HAND TRIPPED
29	15-Mar-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN: LINE CLEAR AVOIDED
30	15-Mar-22	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	8:35	14:18	5:43	LINE FAULT
31	15-Mar-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
32	15-Mar-22	BAGALKOT	110	HIREHAL-MF SOLAR	STATION NOT AFFECTED HIREHAL_110	8:31	8:36	0:05	HAND TRIPPED
33	15-Mar-22	BAGALKOT	110	HUBLI- KADANKOPPA	HUBLI_220	10:20	15:13	4:53	LINE CLEAR AVAILED
34	15-Mar-22	BAGALKOT	110	HUBLI- SIRSI(KALGHATAGI)	HUBLI_220	10:27	15:11	4:44	LINE CLEAR AVAILED
35	15-Mar-22	BAGALKOT	110	HUBLI- TARIHAL1	HUBLI_220	13:53	22:05	8:12	LINE FAULT
36	15-Mar-22	BAGALKOT	110	HUBLI- TARIHAL2	HUBLI_220	13:53	22:05	8:12	NFBC ISSUED
37	15-Mar-22	BAGALKOT	110	HUBLI220- KADANKOPPA	STATION NOT AFFECTED KADANKOPPA_110	10:14	15:23	5:09	LINE CLEAR AVAILED
38	15-Mar-22	BAGALKOT	110	HUDALI-ANKALAGI	STATION NOT AFFECTED HUDALI_110	19:26 (12.03.2022)	15:21 (15.03.2022)	67:55 hrs	LINE CHARGED
39	15-Mar-22	BAGALKOT	110	ILKAL-KUSTAGI1	STATION NOT AFFECTED ILKAL_110	11:30	13:15	1:45	LINE CLEAR AVAILED
40	15-Mar-22	BAGALKOT	110	ILKAL-KUSTAGI2	STATION NOT AFFECTED ILKAL_110	13:18	14:08	0:50	LINE CLEAR AVAILED
41	15-Mar-22	BAGALKOT	110	KHADAKALAT- NIPPANI	NIPPANI_110	14:51	15:34	0:43	HAND TRIPPED
42	15-Mar-22	BAGALKOT	110	KULIGOD-GMSH	KULIGOD_110	9:55	19:05	9:10	LINE CLEAR AVAILED
43	15-Mar-22	BAGALKOT	110	MAHALINGAPUR- BANAHATTI	MAHALINGAPUR_220	14:29	15:14	0:45	HAND TRIPPED
44	15-Mar-22	BAGALKOT	110	MAHALINGAPUR- HIDIKAL	MAHALINGAPUR_220	15:14	15:48	0:34	HAND TRIPPED
45	15-Mar-22	BAGALKOT	110	MAHALINGAPUR- HIDIKAL	MAHALINGAPUR_220	17:02	17:20	0:18	HAND TRIPPED
46	15-Mar-22	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	MAHALINGAPUR_220	17:02	17:10	0:08	HAND TRIPPED
47	15-Mar-22	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	MAHALINGAPUR_220	15:14	15:22	0:08	HAND TRIPPED
48	15-Mar-22	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	MAHALINGAPUR_220	16:45	17:10	0:25	HAND TRIPPED
49	15-Mar-22	BAGALKOT	110	MAHALINGAPUR- TERDAL	MAHALINGAPUR_220	14:33	15:29	0:56	HAND TRIPPED
50	15-Mar-22	BAGALKOT	110	MAHALINGAPUR-GSML1&2	MAHALINGAPUR_220	14:33	15:25	0:52	HAND TRIPPED
51	15-Mar-22	BAGALKOT	110	MANTUR-TUNGABHADRA SOLAR	TUNGABHADRA SOLAR_110 MANTUR(GTPR)_110	15:39	15:49	0:10	LINE FAULT
52	15-Mar-22	BAGALKOT	110	MKHUBLI220-BAILHONGAL	MKHUBLI_220	13:05	13:31	0:26	LINE FAULT
53	15-Mar-22	BAGALKOT	110	MUGHLKOD220-KULIGOD	MAMADAPUR(B)_110	14:35	15:55	1:20	MAIN SUPPLY FAILURE
54	15-Mar-22	BAGALKOT	110	MUNAVALLI-ARATAGAL(SOUDATTI)	ARATAGAL_110	12:24	16:55	4:31	LINE CLEAR AVAILED
55	15-Mar-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
56	15-Mar-22	BAGALKOT	110	RANEBENNUR- HIREKERUR	STATION NOT AFFECTED RANEBENNUR_220	12:15	13:10	0:55	LINE CLEAR AVAILED
57	15-Mar-22	BAGALKOT	110	RANEBENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEBENNUR_220	18:42 (14.02.2022)			LINE OPEN:LINE CLEAR AVAILED
58	15-Mar-22	BAGALKOT	110	SADALAGA- VPPL	SADALAGA_110	12:05	14:00	1:55	LINE CLEAR AVAILED
59	15-Mar-22	BAGALKOT	110	SADALAGA-VPPL COGEN	VPPL COGEN_110 STATION NOT AFFECTED SADALAGA_110	11:56	14:21	2:25	LINE CLEAR AVAILED
60	15-Mar-22	BAGALKOT	110	TARIHAL-HUBLI220	STATION NOT AFFECTED TARIHAL_110	13:46	20:23	6:37	LINE FAULT
61	15-Mar-22	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	VAJRAMATTI_220	14:59	15:17	0:18	HAND TRIPPED
62	15-Mar-22	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	VAJRAMATTI_220	15:22	16:03	0:41	HAND TRIPPED
63	15-Mar-22	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	VAJRAMATTI_220	16:42 (15.03.2022)			LINE OPEN:LINE CLEAR AVAILED
64	15-Mar-22	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	VAJRAMATTI_220	14:30	15:54	1:24	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
65	15-Mar-22	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR2	VAJRAMATTI_220	14:50 (15.03.2022)			LINE OPEN:LINE FAULT
66	15-Mar-22	BAGALKOT	220	220/110KV, HV1	MAHALINGAPUR_220	14:33	15:00	0:27	HAND TRIPPED
67	15-Mar-22	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED HUBLI_220	9:26 (14.03.2022)	16:41 (15.03.2022)	31:15 hrs	TRANSFORMER CHARGED
68	15-Mar-22	BAGALKOT	220	220/110KV, HV1&LV1, HV2&LV2	MUGALKHOD_220, RAIBAG_110, ITANAL_110, KULIGOD_110, NAGANUR_110, HIDIKAL_110, PG HUNSHYAL_110, SAIDAPUR_110	14:44	15:43	0:59	HAND TRIPPED
69	15-Mar-22	BAGALKOT	220	220/110KV, HV2	MAHALINGAPUR_220	14:29	15:14	0:45	HAND TRIPPED
70	15-Mar-22	BAGALKOT	220	220/110KV, HV2&LV2	HUBLI_220	13:53	13:58	7:14	TRANSFORMER FAULT
71	15-Mar-22	BAGALKOT	220	220/110KV, HV3	MAHALINGAPUR_220	14:29	15:14	0:45	HAND TRIPPED
72	15-Mar-22	BAGALKOT	220	220/110KV, HV3	MAHALINGAPUR_220	16:45	17:05	0:20	TRANSFORMER FAULT
73	15-Mar-22	BAGALKOT	220	220/110KV,HV1	VAJRAMATTI_220,KATARAKI_110,BI LAGI_110,MELLIGERI_110,MUDHOL _110,JUMBAGI_110,HALKI_110,MA NTUR_110,GIRISAGAR_110,TOLAMA TTI_110,BISNAL_110,SHIRAGUPPI_1 10,VAJRAMATTI_110	15:13	16:06	0:53	HAND TRIPPED
74	15-Mar-22	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	16:05 (08.03.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
75	15-Mar-22	BAGALKOT	220	220/110KV,HV2	VAJRAMATTI_220,KATARAKI_110,BI LAGI_110,MELLIGERI_110,MUDHOL _110,JUMBAGI_110,HALKI_110,MA NTUR_110,GIRISAGAR_110,TOLAMA TTI_110,BISNAL_110,SHIRAGUPPI_1 10,VAJRAMATTI_110	15:13	16:08	0:55	HAND TRIPPED
76	15-Mar-22	BAGALKOT	220	220/110KV,LV1	VAJRAMATTI_220	15:02	16:07	1:05	LINE CLEAR AVAILED
77	15-Mar-22	BAGALKOT	220	220/110KV,LV2	VAJRAMATTI_220	15:02	16:09	1:07	LINE CLEAR AVAILED
78	15-Mar-22	BAGALKOT	220	AMBEWADI- NAGJHARI1	AMBEWADI_220	17:48	19:47	1:59	LINE CLEAR AVAILED
79	15-Mar-22	BAGALKOT	220	AMBEWADI- NAGJHARI2	AMBEWADI_220	17:20	19:45	2:25	LINE FAULT
80	15-Mar-22	BAGALKOT	220	BAGALKOT-VAJARAMATTI1	BAGALKOT_220	14:35	21:45	7:10	LINE FAULT
81	15-Mar-22	BAGALKOT	220	BAGALKOT-VAJARAMATTI2	BAGALKOT_220	14:35	16:02	1:27	LINE FAULT
82	15-Mar-22	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
83	15-Mar-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
84	15-Mar-22	BAGALKOT	220	CHIKKODI- BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
85	15-Mar-22	BAGALKOT	220	CHIKKODI- BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:43 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
86	15-Mar-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
87	15-Mar-22	BAGALKOT	220	CHIKKODI- KUDACHI1&2	CHIKKODI_220	15:03	15:27	0:24	HAND TRIPPED
88	15-Mar-22	BAGALKOT	220	CHIKKODI- MUGULKHOD1&2	CHIKKODI_220	15:26	15:58	0:32	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
89	15-Mar-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
90	15-Mar-22	BAGALKOT	220	GHATAPRABHA- NARENDRA1	GHATAPRABHA_220	10:25	15:51	5:26	NFBC ISSUED
91	15-Mar-22	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	10:52	18:50	7:58	LINE CLEAR AVAILED
92	15-Mar-22	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	10:52	18:50	7:58	LINE CLEAR AVAILED
93	15-Mar-22	BAGALKOT	220	KUDACHI- MAHALINGAPUR	KUDACHI_220	5:33	6:08	0:35	LINE FAULT
94	15-Mar-22	BAGALKOT	220	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	14:33	15:14	0:41	HAND TRIPPED
95	15-Mar-22	BAGALKOT	220	MAHALINGAPUR- NARENDRA2	MAHALINGAPUR_220	14:33	15:15	0:42	HAND TRIPPED
96	15-Mar-22	BAGALKOT	220	MAHALINGAPUR- SOUDATTI	MAHALINGAPUR_220	16:31	18:48	2:17	LINE FAULT
97	15-Mar-22	BAGALKOT	220	MAHALINGAPUR- SOUDATTI	MAHALINGAPUR_220	14:33	15:00	0:27	HAND TRIPPED
98	15-Mar-22	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI1	MAHALINGAPUR_220	14:33	15:53	1:20	LINE FAULT
99	15-Mar-22	BAGALKOT	220	MAHALINGAPUR-ATHANI	MAHALINGAPUR_220	14:33	15:28	0:55	HAND TRIPPED
100	15-Mar-22	BAGALKOT	220	MAHALINGAPUR-KUDACHI	MAHALINGAPUR_220	14:33	15:20	0:47	HAND TRIPPED
101	15-Mar-22	BAGALKOT	220	NARENDRA-HUBLI1	NARENDRA_220	10:51	17:10	6:19	NFBC ISSUED
102	15-Mar-22	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	10:51	17:11	6:20	NFBC ISSUED
103	15-Mar-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	10:13 (12.03.2022)			LINE OPEN:LINE CLEAR AVAILED
104	15-Mar-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	10:14 (12.03.2022)			LINE OPEN:LINE CLEAR AVAILED
105	15-Mar-22	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	16:31	18:28	1:57	LINE FAULT
106	15-Mar-22	BAGALKOT	220	VAJRAMATTI-BAGALKOT2	VAJRAMATTI_220	15:28	16:03	0:35	HAND TRIPPED
107	15-Mar-22	BAGALKOT	220	VAJRAMATTI-ENERGON SOLAR	VAJRAMATTI_220	15:02	16:04	1:02	LINE CLEAR AVAILED
108	15-Mar-22	BAGALKOT	220	VAJRAMATTI-KAVATAGI	VAJRAMATTI_220	14:30	16:25	1:55	LINE CLEAR AVAILED
109	15-Mar-22	BAGALKOT	220	VAJRAMATTI-KUDAGI1	VAJRAMATTI_220	15:02	19:13	4:11	LINE CLEAR AVAILED
110	15-Mar-22	BAGALKOT	220	VAJRAMATTI-KUDAGI2	VAJRAMATTI_220	15:02	19:14	4:12	LINE CLEAR AVAILED
111	15-Mar-22	BENGALURU	66	AVANI - MULBAGLU	MULBAGLU	12:25	12:40	0:15	LINE CLEAR AVAILED
112	15-Mar-22	BENGALURU	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	10:30	12:48	2:18	LINE CLEAR AVAILED
113	15-Mar-22	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	19:25	20:20	0:55	LINE CLEAR AVAILED
114	15-Mar-22	BENGALURU	66	HOODY 220 - GRAPHITE INDIA (EHT)	GRAPHITE INDIA (EHT)	19:25	20:15	0:50	LINE CLEAR AVAILED
115	15-Mar-22	BENGALURU	66	HOODY 220 - HAL 1	BAGMANE WORLD TECH PARK	19:25	19:35	0:10	LINE CLEAR AVAILED
116	15-Mar-22	BENGALURU	66	HOODY 220 - HAL 2	NO STATION AFFECTED	19:25	20:25	1:00	LINE CLEAR AVAILED
117	15-Mar-22	BENGALURU	66	HOODY 220 - HP (EHT)	HP (EHT)	19:25	20:24	0:59	LINE CLEAR AVAILED
118	15-Mar-22	BENGALURU	66	HOODY 220 - PRESTIGE SHANTINIKETHAN	PRESTIGE SHANTINIKETHAN	19:25:00(15/03/2021)			LINE OPEN:LINE FAULT
119	15-Mar-22	BENGALURU	66	HV1	AMAR JYOTHI	19:18	19:50	0:32	MAIN SUPPLY FAILURE
120	15-Mar-22	BENGALURU	66	HV1	HOODY 220	19:25	20:18	0:53	LINE CLEAR AVAILED
121	15-Mar-22	BENGALURU	66	HV1	HSR LAYOUT 220	8:19	8:28	0:09	TRANSFORMER FAULT
122	15-Mar-22	BENGALURU	66	HV1	KENGERI SATELLITE TOWN	13:22	17:24	4:02	TRANSFORMER FAULT
123	15-Mar-22	BENGALURU	66	HV1	TUBUGERE	12:19	12:30	0:10	LINE CLEAR AVAILED
124	15-Mar-22	BENGALURU	66	HV1	JULLUPALYA	15:11	15:42	0:31	LINE CLEAR AVAILED
125	15-Mar-22	BENGALURU	66	HV1	HUKUNDA	11:55	12:46	0:50	LINE CLEAR AVAILED
126	15-Mar-22	BENGALURU	66	HV1	DOMMASANDRA	6:26	6:30	0:03	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
127	15-Mar-22	BENGALURU	66	HV1	DOMMASANDRA	18:07	18:19	0:11	LOAD CHANGE OVER
128	15-Mar-22	BENGALURU	66	HV2	HAL 220	14:57	15:06	0:09	LINE CLEAR AVAILED
129	15-Mar-22	BENGALURU	66	HV2	HOODY 220	19:25	20:18	0:53	LINE CLEAR AVAILED
130	15-Mar-22	BENGALURU	66	HV2	REMCO	11:43	11:53	0:10	LOAD CHANGE OVER
131	15-Mar-22	BENGALURU	66	HV2	REMCO	17:06	17:08	0:02	LOAD CHANGE OVER
132	15-Mar-22	BENGALURU	66	HV2	BIDADI 220	9:27	9:32	0:05	TRANSFORMER FAULT
133	15-Mar-22	BENGALURU	66	HV2	BIDADI 220	11:14	11:22	0:08	TRANSFORMER FAULT
134	15-Mar-22	BENGALURU	66	HV2	HUKUNDA	12:53	14:25	1:31	LINE CLEAR AVAILED
135	15-Mar-22	BENGALURU	66	HV2	HAROBELA	14:40	15:34	0:54	LINE CLEAR AVAILED
136	15-Mar-22	BENGALURU	66	HV3	NAGANATHPURA 220	12:53	15:08	2:15	LINE CLEAR AVAILED
137	15-Mar-22	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	12:09	12:14	0:05	LOAD CHANGE OVER
138	15-Mar-22	BENGALURU	66	JAYADEVA - SARA KKI	JAYADEVA	13:01	13:07	0:06	LOAD CHANGE OVER
139	15-Mar-22	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	15:16	15:19	0:03	LINE FAULT
140	15-Mar-22	BENGALURU	66	KGF - KAMASAMUDRA	KAMASAMUDRA	11:40	11:50	0:10	LINE FAULT
141	15-Mar-22	BENGALURU	66	KGF - T GOLLAHALLI 220	KGF, KAMASAMUDRA	16:30	16:40	0:10	LOAD CHANGE OVER
142	15-Mar-22	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NO STATION AFFECTED	15:57	16:07	0:10	LINE FAULT
143	15-Mar-22	BENGALURU	66	KORAMANGALA 220 - AMARJYOTHI	AMARJYOTHI	19:18	19:50	0:32	LINE FAULT
144	15-Mar-22	BENGALURU	66	KORAMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	18:57	22:12	3:15	LINE FAULT
145	15-Mar-22	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	7:44	9:01	1:17	LINE CLEAR AVAILED
146	15-Mar-22	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	15:37	16:54	1:17	LINE CLEAR AVAILED
147	15-Mar-22	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALSANUR	17:01	17:07	0:05	LINE CLEAR AVAILED
148	15-Mar-22	BENGALURU	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	9:04	12:23	3:18	LINE FAULT
149	15-Mar-22	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), KGF, KAMASAMUDRA	11:01	12:23	1:22	LINE CLEAR AVAILED
150	15-Mar-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	3:17	3:29	0:12	LINE FAULT
151	15-Mar-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	15:53	16:11	0:17	LINE FAULT
152	15-Mar-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	16:27	16:32	0:04	LOAD CHANGE OVER
153	15-Mar-22	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI	16:27	16:32	0:04	LOAD CHANGE OVER
154	15-Mar-22	BENGALURU	66	NRS 220 - SRS 2	NO STATION AFFECTED	15:12	15:50	0:38	LINE FAULT
155	15-Mar-22	BENGALURU	66	PRESTIGE SHANTINIKETHAN - HOODY 220	PRESTIGE SHANTINIKETHAN	19:25	23:15	3:50	LINE FAULT
156	15-Mar-22	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	RBI	2:45	3:05	0:20	LINE FAULT
157	15-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	11:05	11:42	0:37	LINE CLEAR AVAILED
158	15-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	11:05	11:42	0:37	LINE CLEAR AVAILED
159	15-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	11:05	11:42	0:37	LINE CLEAR AVAILED
160	15-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	15:01	16:25	1:24	LINE CLEAR AVAILED
161	15-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 2	NO STATION AFFECTED	12:20	13:00	0:40	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
162	15-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML	12:20	13:00	0:40	LINE FAULT
163	15-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	11:05	11:42	0:37	LINE CLEAR AVAILED
164	15-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	11:05	11:42	0:37	LINE CLEAR AVAILED
165	15-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	12:32	12:42	0:10	LINE FAULT
166	15-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	14:20	14:41	0:21	LINE FAULT
167	15-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:37	16:23	0:46	LINE FAULT
168	15-Mar-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	5:30	5:37	0:07	LINE FAULT
169	15-Mar-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	12:15	14:03	1:48	LINE FAULT
170	15-Mar-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	14:03	15:13	1:10	LINE CLEAR AVAILED
171	15-Mar-22	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	11:30	15:40	4:10	LOAD CURTAILMENT
172	15-Mar-22	BENGALURU	220	HV1	T GOLLAHALLI 220	11:05	11:40	0:35	TRANSFORMER FAULT
173	15-Mar-22	BENGALURU	220	HV2	HOODY 220	19:25	20:40	1:15	TRANSFORMER FAULT
174	15-Mar-22	BENGALURU	220	HV2	T GOLLAHALLI 220	11:05	11:40	0:35	TRANSFORMER FAULT
175	15-Mar-22	BENGALURU	220	HV3	HOODY 220	19:25	19:56	0:31	TRANSFORMER FAULT
176	15-Mar-22	BENGALURU	220	HV4	HOODY 220	19:25	20:55	1:30	TRANSFORMER FAULT
177	15-Mar-22	BENGALURU	220	T GOLLAHALLI 220 - PGCIL 1 & 2	T GOLLAHALLI 220	11:05	11:40	0:35	LINE FAULT
178	15-Mar-22	GULBARGA	66	HV1	ITTAGI_220	20:32 (11.03.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
179	15-Mar-22	GULBARGA	66	HV2	HARAPANAHALLI_66	15:40	17:10	1:30	TRANSFORMER FAULT
180	15-Mar-22	GULBARGA	110	HATTI-GAMESH IPP	HATTI_110	2:21(15.03.2022)			LINE OPEN:LINE FAULT
181	15-Mar-22	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	16:13	17:15	1:02	LINE FAULT
182	15-Mar-22	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	5:45	6:00	0:15	MAIN SUPPLY FAILURE
183	15-Mar-22	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	19:45	20:00	0:15	MAIN SUPPLY FAILURE
184	15-Mar-22	GULBARGA	110	HV1	RAICHUR_220	14:30	14:38	0:08	TRANSFORMER FAULT
185	15-Mar-22	GULBARGA	110	HV1	BEVOOR_110	17:30	19:00	1:30	LINE CLEAR AVAILED
186	15-Mar-22	GULBARGA	110	HV1	HATTI_110	20:41	20:48	0:07	TRANSFORMER FAULT
187	15-Mar-22	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	12:31	12:52	0:21	LINE CLEAR AVAILED
188	15-Mar-22	GULBARGA	110	KAPNOOR-GULBARGA WEST2	GULBARGA WEST_110,GULBARGA SOUTH_110	8:45 (15/03/2022)			LINE OPEN:LINE CLEAR AVAILED
189	15-Mar-22	GULBARGA	110	KUSHTAGI-ILKAL1	ILKAL_110	11:35	13:15	1:40	LINE CLEAR AVAILED
190	15-Mar-22	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAR_110,HIREGONNAGAR_110,HANUMANAL_110	21:45	22:00	0:15	LINE FAULT
191	15-Mar-22	GULBARGA	110	RAICHUR-MATMARI	MATMARI_110	14:23	14:28	0:05	LINE FAULT
192	15-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	19:14	19:23	0:09	LINE FAULT
193	15-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	21:14	21:19	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
194	15-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	22:10	22:15	0:05	LINE FAULT
195	15-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	23:10	23:15	0:05	LINE FAULT
196	15-Mar-22	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110	21:12	21:18	0:06	LINE FAULT
197	15-Mar-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
198	15-Mar-22	GULBARGA	110	SHAHABAD-FAHARTABAD	FAHARTABAD_110	11:15	13:15	2:00	LINE CLEAR AVAILED
199	15-Mar-22	GULBARGA	110	SHAHAPUR110-SHAHAPUR	SHAHAPUR_110	15:30	15:40	0:10	MAIN SUPPLY FAILURE
200	15-Mar-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP,H UNASIGI_110,ASKI_110	5:45	6:00	0:15	LINE FAULT
201	15-Mar-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	15:30	16:11	0:41	LINE FAULT
202	15-Mar-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	15:30	16:11	0:41	LINE FAULT
203	15-Mar-22	GULBARGA	110	SHAHAPUR-SHAHAPUR 1 & 2	SHAHAPUR_110	11:40	12:17	0:37	LINE CLEAR AVAILED
204	15-Mar-22	GULBARGA	110	SHAHAPUR-SHAHAPUR 1 & 2	SHAHAPUR_110	19:40	19:50	0:10	LINE CLEAR AVAILED
205	15-Mar-22	GULBARGA	110	STARMETALLIC-MUNIRABAD	MUNIRABAD_220	14:36	15:10	0:34	LINE FAULT
206	15-Mar-22	GULBARGA	220	HV1 & HV2	ITTAGI_220	14:33	14:43	0:10	TRANSFORMER FAULT
207	15-Mar-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
208	15-Mar-22	GULBARGA	220	HV2	SHAHAPUR_220	14:50	15:56	1:06	LINE CLEAR AVAILED
209	15-Mar-22	GULBARGA	220	LINGAPUR-BMM	BMM ISPAT_220	14:30	15:55	1:25	LINE FAULT
210	15-Mar-22	GULBARGA	220	RAICHUR-RTPS1	RAICHUR_220	18:30	19:03	0:33	LINE CLEAR AVAILED
211	15-Mar-22	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	7:20	7:35	0:15	LINE FAULT
212	15-Mar-22	HASSAN	66	BANDISH-ADANI	BANDISHETTIHALY_66	8:15	13:42	5:27	LINE CLEAR AVAILED
213	15-Mar-22	HASSAN	66	BANDISH-HNPURA	BANDISHETTIHALY_66	8:15	13:42	5:27	LINE CLEAR AVAILED
214	15-Mar-22	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLY_66	8:20	12:00	3:40	NFBC ISSUED
215	15-Mar-22	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	12:03	15:29	3:26	MAIN SUPPLY FAILURE
216	15-Mar-22	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	12:03	15:29	3:26	MAIN SUPPLY FAILURE
217	15-Mar-22	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	12:03	15:40	3:37	MAIN SUPPLY FAILURE
218	15-Mar-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	12:03	15:40	3:37	MAIN SUPPLY FAILURE
219	15-Mar-22	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	12:03	15:40	3:37	MAIN SUPPLY FAILURE
220	15-Mar-22	HASSAN	66	CRPATNA-CRPTNA1	CRPATNA_220	12:01	15:28	3:27	LINE CLEAR AVAILED
221	15-Mar-22	HASSAN	66	CRPATNA-CRPTNA2	CRPATNA_220	12:01	15:28	3:27	LINE CLEAR AVAILED
222	15-Mar-22	HASSAN	66	CRPATNA-HNPURA	CRPATNA_220	11:30	14:20	2:50	LINE CLEAR AVAILED
223	15-Mar-22	HASSAN	66	CRPATNA-KIKKERI	CRPATNA_220	11:28	14:01	2:33	LINE CLEAR AVAILED
224	15-Mar-22	HASSAN	66	CRPATNA-KRPET	CRPATNA_220	11:28	14:01	2:33	LINE CLEAR AVAILED
225	15-Mar-22	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	11:30	14:01	2:31	LINE CLEAR AVAILED
226	15-Mar-22	HASSAN	66	CRPATNA-SBELAGOLA	CRPATNA_220	11:30	14:30	3:00	LINE CLEAR AVAILED
227	15-Mar-22	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	11:06	12:02	0:56	LINE CLEAR AVAILED
228	15-Mar-22	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	9:00	11:23	2:23	LINE CLEAR AVAILED
229	15-Mar-22	HASSAN	66	HV1	BANDISHETTIHALY_66	8:15	13:42	5:27	LINE CLEAR AVAILED
230	15-Mar-22	HASSAN	66	HV1	BYACHAN	8:20	12:00	3:40	NFBC ISSUED
231	15-Mar-22	HASSAN	66	HV1	RAMPURA_66	11:22	14:51	3:29	LINE CLEAR AVAILED
232	15-Mar-22	HASSAN	66	HV1	YESLUR_66	13:25	14:55	1:30	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
233	15-Mar-22	HASSAN	66	HV1	CHANNARAYAPATNA_66	12:03	15:29	3:26	MAIN SUPPLY FAILURE
234	15-Mar-22	HASSAN	66	HV2	RAMPURA_66	12:14	14:51	2:37	LINE CLEAR AVAILED
235	15-Mar-22	HASSAN	66	HV2	CHANNARAYAPATNA_66	12:03	15:40	3:37	MAIN SUPPLY FAILURE
236	15-Mar-22	HASSAN	66	LV1	CRPATNA_220	12:03	13:54	1:51	LINE CLEAR AVAILED
237	15-Mar-22	HASSAN	66	LV2	CRPATNA_220	12:03	13:54	1:51	LINE CLEAR AVAILED
238	15-Mar-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
239	15-Mar-22	HASSAN	66	RAMPUR-BEGUR	RAMPURA_66	12:14	14:20	2:06	LINE CLEAR AVAILED
240	15-Mar-22	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	11:32	11:58	0:26	MAIN SUPPLY FAILURE
241	15-Mar-22	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	14:18	14:20	0:02	MAIN SUPPLY FAILURE
242	15-Mar-22	HASSAN	110	BRAHMAV-NITTUR	BRAHMAVARA_110	11:39	11:47	0:08	HAND TRIPPED
243	15-Mar-22	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	10:14	13:44	3:30	MAIN SUPPLY FAILURE
244	15-Mar-22	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	18:45(14.3.2022)	6:56(15.03.2022)	12:11HRS	LINE CHARGED
245	15-Mar-22	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	8:05	17:55	9:50	LINE CLEAR AVAILED
246	15-Mar-22	HASSAN	110	HV1	BIRUR_110	11:47	15:10	3:23	LINE CLEAR AVAILED
247	15-Mar-22	HASSAN	110	HV1	GURUPURA_110	11:27	17:39	6:12	LINE CLEAR AVAILED
248	15-Mar-22	HASSAN	110	HV1	KADUR_220	11:45	13:45	2:00	LINE CLEAR AVAILED
249	15-Mar-22	HASSAN	110	HV1	BRAHMAVARA_110	12:06	13:19	1:13	LINE CLEAR AVAILED
250	15-Mar-22	HASSAN	110	HV1	SHIVPURA_110	11:45	14:45	3:00	MAIN SUPPLY FAILURE
251	15-Mar-22	HASSAN	110	HV2	BRAHMAVARA_110	10:19	12:09	1:50	LINE CLEAR AVAILED
252	15-Mar-22	HASSAN	110	KADUR-NERLEKERE	KADUR_220	11:44	14:43	2:59	LINE CLEAR AVAILED
253	15-Mar-22	HASSAN	110	KADUR-NGNHL	KADUR_220	11:44	13:49	2:05	LINE CLEAR AVAILED
254	15-Mar-22	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			LINE OPEN:LINE CLEAR AVAILED
255	15-Mar-22	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	10:02	17:38	7:36	LINE CLEAR AVAILED
256	15-Mar-22	HASSAN	110	LV1	KADUR_220	11:44	13:45	2:01	LINE CLEAR AVAILED
257	15-Mar-22	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	10:11	13:29	3:18	LINE CLEAR AVAILED
258	15-Mar-22	HASSAN	110	SHIVAPU-BIRUR	SHIVPURA_110	11:48	14:47	2:59	MAIN SUPPLY FAILURE
259	15-Mar-22	HASSAN	110	SHIVAPU-NERLEKERE	SHIVPURA_110	11:48	14:44	2:56	MAIN SUPPLY FAILURE
260	15-Mar-22	HASSAN	220	HV1	CRPATNA_220	12:05	13:53	1:48	LINE CLEAR AVAILED
261	15-Mar-22	HASSAN	220	HV2	CRPATNA_220	12:04	13:54	1:50	LINE CLEAR AVAILED
262	15-Mar-22	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			LINE OPEN:LINE CLEAR AVAILED
263	15-Mar-22	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	11:18	16:33	5:15	LINE CLEAR AVAILED
264	15-Mar-22	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	18:07	22:01	3:54	LINE FAULT
265	15-Mar-22	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			LINE OPEN:LINE CLEAR AVAILED
266	15-Mar-22	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			LINE OPEN:LINE CLEAR AVAILED
267	15-Mar-22	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	11:21	16:27	5:06	LINE CLEAR AVAILED
268	15-Mar-22	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	18:07	22:01	3:54	LINE FAULT
269	15-Mar-22	MYSURU	66	C R NAGARA-HONAGANURU	HONGANURU_66	6:12	6:25	0:13	LINE FAULT
270	15-Mar-22	MYSURU	66	DODDINDUVADI-KOTHNUR	NO STATIONS EFFECTED	20:30	20:50	0:20	LINE FAULT
271	15-Mar-22	MYSURU	66	DODDINDUVADI-KOTHNUR	NO STATIONS EFFECTED	21:45	21:50	0:05	LINE FAULT
272	15-Mar-22	MYSURU	66	DODDINDUVADI-KOTHNUR	NO STATIONS EFFECTED	23:40	23:45	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
273	15-Mar-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00(8/12/2021)			LINE OPEN:LINE CLEAR AVAIED
274	15-Mar-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58(13.03.22)			LINE OPEN:LINE CLEAR AVAIED
275	15-Mar-22	MYSURU	66	HV2	TUBINAKERE_220	11:02	12:10	1:08	LINE CLEAR AVAIED
276	15-Mar-22	MYSURU	66	HV2	CHANDAKAVADI_66	16:07	16:32	0:25	LINE CLEAR AVAIED
277	15-Mar-22	MYSURU	66	HV2	KIRUGAVALU_66	12:07	12:15	0:08	LINE CLEAR AVAIED
278	15-Mar-22	MYSURU	66	K M DODDI-T K HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	4:08	4:25	0:17	LINE FAULT
279	15-Mar-22	MYSURU	66	K M DODDI-T K HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	5:29	5:50	0:21	LINE FAULT
280	15-Mar-22	MYSURU	66	K M DODDI-T K HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	12:15	12:30	0:15	HAND TRIPPED
281	15-Mar-22	MYSURU	66	K M DODDI-T K HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	14:05	14:15	0:10	HAND TRIPPED
282	15-Mar-22	MYSURU	66	K M DODDI-T K HALLI	NO STATIONS EFFECTED	14:15	15:12	0:57	NFBC ISSUED
283	15-Mar-22	MYSURU	66	VAJAMANGALA-HEBBANI	NO STATIONS EFFECTED	18:50	18:54	0:04	LINE FAULT
284	15-Mar-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	19:16(14.03.22)			LINE OPEN:LINE CLEAR AVAIED
285	15-Mar-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	19:16(14.03.22)			LINE OPEN:LINE CLEAR AVAIED
286	15-Mar-22	TUMKUR	66	BENKIKERE 220KV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	10:34	14:02	3:27	LINE CLEAR AVAIED
287	15-Mar-22	TUMKUR	66	BENKIKERE 220KV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	17:02	17:22	0:19	LINE FAULT
288	15-Mar-22	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	12:45	13:41	0:56	LINE CLEAR AVAIED
289	15-Mar-22	TUMKUR	66	HIRIYUR 220KV- ENERCON-2	ENERCON1_IPP_66	14:01	20:11	6:09	LINE CLEAR AVAIED
290	15-Mar-22	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	12:45	13:39	0:54	LINE CLEAR AVAIED
291	15-Mar-22	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	12:45	13:39	0:54	LINE CLEAR AVAIED
292	15-Mar-22	TUMKUR	66	HIRIYUR 220KV-SIRA	HIRIYUR_66	12:45	13:40	0:55	LINE CLEAR AVAIED
293	15-Mar-22	TUMKUR	66	HONNALLI 220kv- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	20:55	21:08	0:12	LINE FAULT
294	15-Mar-22	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR_IPP_66	BPCLSOLAR_IPP_66	18:58	19:00	0:01	MAIN SUPPLY FAILURE
295	15-Mar-22	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	NAYAKANAHATTI_66	9:16	10:00	0:43	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
296	15-Mar-22	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	NAYAKANAHATTI_66	11:41:00 PM(15.3.22)	0:15:00 (16.3.22)	0:34 hrs	LINE CHARGED
297	15-Mar-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	18:27	18:33	0:05	LINE FAULT
298	15-Mar-22	TUMKUR	66	SIRA220 - BUKKAPATNA	BUKKAPATNA_66	18:25	18:39	0:13	LINE FAULT
299	15-Mar-22	TUMKUR	66	SIRA220- MADHUGIRI 1	BUKKAPATNA_66, KALLAMBELLA_66	18:25	18:36	0:11	LINE FAULT
300	15-Mar-22	TUMKUR	66	TR-1	GARAGA_66	10:09	10:20	0:10	LINE CLEAR AVAILED
301	15-Mar-22	TUMKUR	66	TR-1	PANDARAHALLI_66	17:33	17:41	0:08	TRANSFORMER FAULT
302	15-Mar-22	TUMKUR	66	TR-1	SIRA_66	15:57	16:15	0:17	TRANSFORMER FAULT
303	15-Mar-22	TUMKUR	66	TR-1	SIRA_66	16:30	16:40	0:10	TRANSFORMER FAULT
304	15-Mar-22	TUMKUR	66	TR-2	BADAVANAHALLI_66	12:05	12:32	0:26	LINE CLEAR AVAILED
305	15-Mar-22	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	15:15	18:18	3:03	LINE CLEAR AVAILED
306	15-Mar-22	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	11:38	13:52	2:14	LINE CLEAR AVAILED
307	15-Mar-22	TUMKUR	110	NITTUR 220kV- SOMALAPURA	NITTUR_220	13:07	13:29	0:22	LINE CLEAR AVAILED
308	15-Mar-22	TUMKUR	110	TR-1	KALLUR_110	10:16	18:46	8:30	LINE CLEAR AVAILED
309	15-Mar-22	TUMKUR	110	TR-1	KALLUR_110	18:56	19:33	0:36	TRANSFORMER FAULT
310	15-Mar-22	TUMKUR	110	TR-1	KALLUR_110	11:43:07 PM(15.3.22)	12:20:00 (16.3.22)	0:36 hrs	TRANSFORMER CHARGED
311	15-Mar-22	TUMKUR	110	TR-1	NITTUR_220	13:47	15:27	1:39	LINE CLEAR AVAILED
312	15-Mar-22	TUMKUR	110	TR-2	NITTUR_220	7:04	7:11	0:07	TRANSFORMER FAULT
313	15-Mar-22	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR_IPP_66	AZURE POWER SOLAR_IPP_66	12:40	13:32	0:52	LINE FAULT
314	15-Mar-22	TUMKUR	220	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	12:40	13:35	0:55	LINE FAULT
315	15-Mar-22	TUMKUR	220	HIRIYUR220-MADHUGIRI	MADHUGIRI_220	12:40	13:34	0:54	LINE FAULT
316	15-Mar-22	TUMKUR	220	MADHUGIRI 220KV-GOWRIBIDANUR220	MADHUGIRI_220	13:41	16:46	3:04	LINE CLEAR AVAILED
317	15-Mar-22	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	15:46	18:09	2:22	LINE CLEAR AVAILED
318	15-Mar-22	TUMKUR	220	TR-1	HIRIYUR_220	12:43	13:38	0:55	TRANSFORMER FAULT
319	15-Mar-22	TUMKUR	220	TR-2	HIRIYUR_220	12:43	13:32	0:49	TRANSFORMER FAULT
320	15-Mar-22	TUMKUR	220	TR-2	NITTUR_220	15:14	16:59	1:44	LINE CLEAR AVAILED
321	15-Mar-22	TUMKUR	220	TR-3	HIRIYUR_220	12:43	13:38	0:55	TRANSFORMER FAULT
322	16-Mar-22	BAGALKOT	110	110/11KV, HV1	NIPPANI_110	12:10	12:45	0:35	LINE CLEAR AVAILED
323	16-Mar-22	BAGALKOT	110	110/11KV, HV1	NIPPANI_110	16:40	17:20	0:40	LINE CLEAR AVAILED
324	16-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TAKKALAKI_110	6:20	6:55	0:35	HAND TRIPPED
325	16-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED YADAWAD_110	10:04	10:40	0:36	HAND TRIPPED
326	16-Mar-22	BAGALKOT	110	110/11KV, HV1	SHIRAHATTI_110	17:45	17:50	0:05	HAND TRIPPED
327	16-Mar-22	BAGALKOT	110	110/11KV, HV1	BELLATTI_110	10:13	18:03	7:50	LINE CLEAR AVAILED
328	16-Mar-22	BAGALKOT	110	110/11KV, HV1	LAXMESHWAR_110	10:25	17:55	7:30	LINE CLEAR AVAILED
329	16-Mar-22	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	12:05	12:45	0:40	LINE CLEAR AVAILED
330	16-Mar-22	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	16:25	18:20	1:55	LINE CLEAR AVAILED
331	16-Mar-22	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	18:25	18:45	0:20	LINE CLEAR AVAILED
332	16-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NIPPANI_110	18:46	18:47	0:01	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
333	16-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NIPPANI_110	18:28	18:44	0:16	LINE CLEAR AVAILED
334	16-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NIPPANI_110	16:26	18:22	1:56	LINE CLEAR AVAILED
335	16-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NIPPANI_110	12:05	12:59	0:54	LINE CLEAR AVAILED
336	16-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YADAWAD_110	15:44	17:23	1:39	LINE CLEAR AVAILED
337	16-Mar-22	BAGALKOT	110	110/11KV, HV2	SHIRAHATTI_110	17:45	17:50	0:05	HAND TRIPPED
338	16-Mar-22	BAGALKOT	110	110/11KV, HV3	BELLATTI_110	10:05	18:04	7:59	LINE CLEAR AVAILED
339	16-Mar-22	BAGALKOT	110	110/11KV,HV1	KUDALASANGAM_110	17:48	22:11	4:23	LINE CLEAR AVAILED
340	16-Mar-22	BAGALKOT	110	110/11KV,HV2	KAGAWAD_110	18:50	18:57	0:07	TRANSFORMER FAULT
341	16-Mar-22	BAGALKOT	110	110/11KV,HV3	BELLATTI_110	10:05	18:06	8:01	LINE CLEAR AVAILED
342	16-Mar-22	BAGALKOT	110	110/33KV, HV2	BELLATTI_110	10:05	18:04	7:59	LINE CLEAR AVAILED
343	16-Mar-22	BAGALKOT	110	110/33KV, HV3	LAKMANAHALLI_110, ALNAVAR_33, RAYAPUR_33, VIDYAGIRI_33	2:25	2:40	0:15	TRANSFORMER FAULT
344	16-Mar-22	BAGALKOT	110	110/33KV, HV3	LAKMANAHALLI_110, ALNAVAR_33, RAYAPUR_33, VIDYAGIRI_33	3:12	3:17	0:05	TRANSFORMER FAULT
345	16-Mar-22	BAGALKOT	110	110/33KV, HV3	LAKMANAHALLI_110, ALNAVAR_33, RAYAPUR_33, VIDYAGIRI_33	6:03	6:10	0:07	TRANSFORMER FAULT
346	16-Mar-22	BAGALKOT	110	110/33KV, HV3	LAKMANAHALLI_110, ALNAVAR_33, RAYAPUR_33, VIDYAGIRI_33	6:30	6:40	0:10	TRANSFORMER FAULT
347	16-Mar-22	BAGALKOT	110	110/33KV, HV3	LAKMANAHALLI_110, ALNAVAR_33, RAYAPUR_33, VIDYAGIRI_33	6:50	6:55	0:05	TRANSFORMER FAULT
348	16-Mar-22	BAGALKOT	110	110/33KV, HV3	LAKMANAHALLI_110, ALNAVAR_33, RAYAPUR_33, VIDYAGIRI_33	8:10	8:15	0:05	TRANSFORMER FAULT
349	16-Mar-22	BAGALKOT	110	220/110KV, LV1	MUGALKHOD_220, RAIBAG_110, ITANAL_110, SULTANPUR_110, KULIGOD_110, NAGANUR_110, MUDALGI_110	13:19	13:36	0:17	HAND TRIPPED
350	16-Mar-22	BAGALKOT	110	220/110KV, LV2	MUGALKHOD_220, RAIBAG_110, ITANAL_110, SULTANPUR_110, KULIGOD_110, NAGANUR_110, MUDALGI-110	13:19	13:37	0:18	HAND TRIPPED
351	16-Mar-22	BAGALKOT	110	220/110KV,LV4	STATION NOT AFFECTED GADAG_220	13:10 (15.03.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
352	16-Mar-22	BAGALKOT	110	BELLATTI- AB SOLAR	BELLATTI_110	10:13	18:10	7:57	LINE CLEAR AVAILED
353	16-Mar-22	BAGALKOT	110	BELLATTI- ENERCON2	BELLATTI_110	10:02	18:30	8:28	LINE CLEAR AVAILED
354	16-Mar-22	BAGALKOT	110	BELLATTI- LAXMESHWAR	LAXMESHWAR_110	10:10	18:01	7:51	LINE CLEAR AVAILED
355	16-Mar-22	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	10:13	18:11	7:58	LINE CLEAR AVAILED
356	16-Mar-22	BAGALKOT	110	BELLATTI-ENERCON 2	BELLATTI_110	10:02	18:30	8:28	LINE CLEAR AVAILED
357	16-Mar-22	BAGALKOT	110	CHIKKODI220-BHOJ	BHOJ_110	13:35	13:42	0:07	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
358	16-Mar-22	BAGALKOT	110	CHIKKODI220-CHIKODI	CHIKODI_110	13:35	13:42	0:07	HAND TRIPPED
359	16-Mar-22	BAGALKOT	110	CHIKKODI-ANKALI	ANKALI_110	13:35	13:42	0:07	HAND TRIPPED
360	16-Mar-22	BAGALKOT	110	GADAG- LAXMESHWAR	LAXMESHWAR_110	10:25	17:45	7:20	LINE CLEAR AVAILED
361	16-Mar-22	BAGALKOT	110	GADAG- SHIRAHATTI	SHIRAHATTI_110	17:45	17:55	0:10	LINE FAULT
362	16-Mar-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
363	16-Mar-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
364	16-Mar-22	BAGALKOT	110	HIREMASALI-ATHARGA	ATHARAGA_110	13:14	13:43	0:29	LINE CLEAR AVAILED
365	16-Mar-22	BAGALKOT	110	HUBLI-TARIHAL 1&2	STATION NOT AFFECTED HUBLI_220	8:44 (16.03.2022)			LINE OPEN:LINE CLEAR AVAILED
366	16-Mar-22	BAGALKOT	110	HUNGUND -KUDALASANGAM	KUDALASANGAM_110	10:34	17:52	7:18	LINE CLEAR AVAILED
367	16-Mar-22	BAGALKOT	110	HUNGUND -KUDALASANGAM(B,BAGEWADI)	HUNGUND_110 (STATION NOT AFFECTED)	10:40	17:47	7:07	LINE CLEAR AVAILED
368	16-Mar-22	BAGALKOT	110	INDI220- ZALKI	ZALKI_110	17:30	17:34	0:04	HAND TRIPPED
369	16-Mar-22	BAGALKOT	110	INDI220-HIREMASALI	HIREMASALI_110	13:17	13:43	0:26	LINE CLEAR AVAILED
370	16-Mar-22	BAGALKOT	110	KULIGOD-GAMESH IPP	GAMESH IPP_110 KULIGOD_110	9:20	17:05	7:45	LINE CLEAR AVAILED
371	16-Mar-22	BAGALKOT	110	LAXMESHWAR- BELLATTI	LAXMESHWAR_110	10:10	18:01	7:51	LINE CLEAR AVAILED
372	16-Mar-22	BAGALKOT	110	LAXMESHWAR- SHIRAHATTI	SHIRAHATTI_110	10:10	17:40	7:30	LINE CLEAR AVAILED
373	16-Mar-22	BAGALKOT	110	LAXMESHWAR- SHIRAHATTI	LAXMESHWAR_110	8:50	10:50	2:00	LINE FAULT
374	16-Mar-22	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	RANNABELAGALI_110	15:40	16:03	0:23	LINE FAULT
375	16-Mar-22	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	RANNABELAGALI_110	16:40	17:18	0:38	LINE CLEAR AVAILED
376	16-Mar-22	BAGALKOT	110	MUGALKHOD- KULIGOD	MUGALKHOD_220	16:18	17:01	0:43	LINE FAULT
377	16-Mar-22	BAGALKOT	110	NAVALGUND-KONNUR	NAVALGUND_110 KONNUR_110	17:00	17:43	0:43	LINE FAULT
378	16-Mar-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
379	16-Mar-22	BAGALKOT	110	RANEBENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEBENNUR_220	18:42 (14.02.2022)			LINE OPEN:LINE CLEAR AVAILED
380	16-Mar-22	BAGALKOT	110	SHIRAHATTI- BPCL1	SHIRAHATTI_110	17:45	18:00	0:15	HAND TRIPPED
381	16-Mar-22	BAGALKOT	110	SHIRAHATTI- BPCL2	SHIRAHATTI_110	17:45	18:10	0:25	HAND TRIPPED
382	16-Mar-22	BAGALKOT	110	SHIRAHATTI-LAXMESHWAR	LAXMESHWAR_110	10:25	10:50	0:25	LINE CLEAR AVAILED
383	16-Mar-22	BAGALKOT	110	SHIRHATTI-BPCL2	BPCL IPP_110 SHIRHATTI_110	18:09	18:14	0:05	HAND TRIPPED
384	16-Mar-22	BAGALKOT	110	UGARKHUD-UGAR SUGARS	UGAR SUGARS_110 STATION NOT AFFECTED UGARKHUD_110	15:38	16:49	1:11	LINE CLEAR AVAILED
385	16-Mar-22	BAGALKOT	110	VAJRAMATTI-KATARAKI	KATARAKI_110	13:10	17:30	4:20	LINE CLEAR AVAILED
386	16-Mar-22	BAGALKOT	110	YADAWAD-IZRA SOLAR	IZRA SOLAR_110 STATION NOT AFFECTED YADAWAD_110	12:13	12:20	0:07	LINE FAULT
387	16-Mar-22	BAGALKOT	110	YADAWAD-IZRA SOLAR	IZRA SOLAR_110 STATION NOT AFFECTED YADAWAD_110	6:19	6:38	0:19	LOAD CURTAILMENT
388	16-Mar-22	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	STATION NOT AFFECTED VAJRAMATTI_220	16:42 (15.03.2022)	14:40 (16.03.2022)	21:58 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
389	16-Mar-22	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	14:50 (15.03.2022)	20:33 (16.03.2022)	29:43 hrs	LINE CHARGED
390	16-Mar-22	BAGALKOT	220	220/110KV, HV1	RANEBENNUR_220, HIREKERUR_110, BYADAGI_110, TUMMINAKATTE_110, HONNATTI_110	10:48	12:08	1:20	TRANSFORMER FAULT
391	16-Mar-22	BAGALKOT	220	220/110KV, HV2	RANEBENNUR_220, HIREKERUR_110, BYADAGI_110, TUMMINAKATTE_110, HONNATTI_110	10:48	11:30	0:42	TRANSFORMER FAULT
392	16-Mar-22	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	16:05 (08.03.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
393	16-Mar-22	BAGALKOT	220	BAGALKOT - VAJARAMATTI1	STATION NOT AFFECTED BAGALKOT_220	14:30	14:41	0:11	HAND TRIPPED
394	16-Mar-22	BAGALKOT	220	BAGALKOT - VAJARAMATTI2	STATION NOT AFFECTED BAGALKOT_220	19:40	22:14	2:34	LINE CLEAR AVAILED
395	16-Mar-22	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
396	16-Mar-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
397	16-Mar-22	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM_220	13:58	15:35	1:37	LINE FAULT
398	16-Mar-22	BAGALKOT	220	BIDNAL-NAGJHARI2	BIDNAL_220	17:09	18:10	1:01	LINE FAULT
399	16-Mar-22	BAGALKOT	220	CHIKKODI- BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
400	16-Mar-22	BAGALKOT	220	CHIKKODI- BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:43 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
401	16-Mar-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
402	16-Mar-22	BAGALKOT	220	CHIKKODI-KUDACHI1&2	STATION NOT AFFECTED CHIKKODI_220	13:40	13:46	0:06	HAND TRIPPED
403	16-Mar-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
404	16-Mar-22	BAGALKOT	220	GHATAPRABHA-NARENDRA1	STATION NOT AFFECTED GHATPRBHA_220	13:15	13:41	0:26	LINE FAULT
405	16-Mar-22	BAGALKOT	220	GHATAPRABHA-NARENDRA2	STATION NOT AFFECTED GHATPRBHA_220	13:17	13:40	0:23	LINE FAULT
406	16-Mar-22	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	13:10	17:46	4:36	LINE FAULT
407	16-Mar-22	BAGALKOT	220	HUBLI-NARENDRA1	STATION NOT AFFECTED HUBLI_220	10:40	17:58	7:13	LINE CLEAR AVAILED
408	16-Mar-22	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	10:40	17:58	7:12	LINE CLEAR AVAILED
409	16-Mar-22	BAGALKOT	220	KUDACHI-ATHANI	ATHANI_220	12:51	19:09	6:18	LINE CLEAR AVAILED
410	16-Mar-22	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI2	STATION NOT AFFECTED MAHALINGAPUR_220	14:33 (15.03.2022)	20:34 (16.03.2022)	30:01 hrs	LINE CHARGED
411	16-Mar-22	BAGALKOT	220	MAHALINGAPUR-KUDUCHI	KUDUCHI_220	12:48	19:26	6:38	LINE CLEAR AVAILED
412	16-Mar-22	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	10:48	17:52	7:04	LINE CLEAR AVAILED
413	16-Mar-22	BAGALKOT	220	NARENDRA- HUBLI2	NARENDRA_220	11:48	17:53	7:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
414	16-Mar-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_ 220	10:13 (12.03.2022)			LINE OPEN:LINE CLEAR AVAILED
415	16-Mar-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_ 220	10:14 (12.03.2022)			LINE OPEN:LINE CLEAR AVAILED
416	16-Mar-22	BAGALKOT	220	VAJRAMATTI-BAGALKOT-2	STATION NOT AFFECTED VAJRAMATTI_ 220	14:43 (16.03.2022)			LINE OPEN:LINE CLEAR AVAILED
417	16-Mar-22	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA, SAHAKAR NAGAR	18:13	18:44	0:31	LINE CLEAR AVAILED
418	16-Mar-22	BENGALURU	66	ATTUR YELAHANKA - DG4	ATTUR YELAHANKA	16:17	16:24	0:07	LINE FAULT
419	16-Mar-22	BENGALURU	66	DODDABELAVANGALA - DB PURA 220	DODDABELAVANGALA	12:34	12:38	0:03	LINE FAULT
420	16-Mar-22	BENGALURU	66	HV1	KORAMANGALA 220	10:56	10:58	0:02	LINE CLEAR AVAILED
421	16-Mar-22	BENGALURU	66	HV1	NGEF	13:00	14:50	1:50	LINE CLEAR AVAILED
422	16-Mar-22	BENGALURU	66	HV1	SIDDLAGHATTA	17:24	17:38	0:14	LINE CLEAR AVAILED
423	16-Mar-22	BENGALURU	66	HV1	H GOLLAHALLI	18:55	19:00	0:04	LINE CLEAR AVAILED
424	16-Mar-22	BENGALURU	66	HV1	DOMMASANDRA	12:56	13:00	0:03	LINE CLEAR AVAILED
425	16-Mar-22	BENGALURU	66	HV1	ANDERSONPET	15:39	16:05	0:25	TRANSFORMER FAULT
426	16-Mar-22	BENGALURU	66	HV1	TUBUGERE	11:00	11:05	0:05	LINE CLEAR AVAILED
427	16-Mar-22	BENGALURU	66	HV2	MATHIKERE	10:20	10:25	0:05	LINE CLEAR AVAILED
428	16-Mar-22	BENGALURU	66	HV2	MATHIKERE	12:20	12:25	0:05	LINE CLEAR AVAILED
429	16-Mar-22	BENGALURU	66	HV2	NGEF	13:00	14:50	1:50	LINE CLEAR AVAILED
430	16-Mar-22	BENGALURU	66	HV2	KEMBODI	4:25	4:45	0:20	LINE CLEAR AVAILED
431	16-Mar-22	BENGALURU	66	HV2	DODDABELAVANGALA	12:10	14:06	1:56	LINE CLEAR AVAILED
432	16-Mar-22	BENGALURU	66	HV2	TUBUGERE	13:20	13:35	0:15	LINE CLEAR AVAILED
433	16-Mar-22	BENGALURU	66	HV2	KEMBODI	13:30	15:13	1:43	LINE CLEAR AVAILED
434	16-Mar-22	BENGALURU	66	HV3	BIDADI 220	6:55	7:05	0:10	TRANSFORMER FAULT
435	16-Mar-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	10:20	10:24	0:04	LINE FAULT
436	16-Mar-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	15:32	15:46	0:13	LINE FAULT
437	16-Mar-22	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	16:38	16:51	0:13	LINE CLEAR AVAILED
438	16-Mar-22	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	14:15	14:20	0:05	LOAD CHANGEOVER
439	16-Mar-22	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	11:38	11:45	0:07	LOAD CHANGEOVER
440	16-Mar-22	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	12:25	12:45	0:19	LINE FAULT
441	16-Mar-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	8:31	8:39	0:08	LINE FAULT
442	16-Mar-22	BENGALURU	66	PLATINUM CITY - ATTUR YELAHANKA	PLATINUM CITY	16:18	16:30	0:12	MAIN SUPPLY FAILURE
443	16-Mar-22	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	21:25	21:34	0:09	LOAD CHANGEOVER
444	16-Mar-22	BENGALURU	66	PRESTIGE SHANTINIKETHAN - DARSHITA(EHT)	PRESTIGE SHANTINIKETHAN	15:05	15:10	0:05	LOAD CHANGEOVER
445	16-Mar-22	BENGALURU	66	VRISHABHAVATHI 220 - SIR MV LAYOUT	KENGERI SATELLITE TOWN, SIR MV LAYOUT	9:40(16/03/2022)			LINE OPEN:LINE FAULT
446	16-Mar-22	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	22:00	22:05	0:05	LOAD CHANGEOVER
447	16-Mar-22	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	18:35	18:43	0:08	LOAD CHANGEOVER
448	16-Mar-22	BENGALURU	220	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	13:29	18:45	5:16	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
449	16-Mar-22	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	12:18	14:18	2:00	LINE FAULT
450	16-Mar-22	BENGALURU	220	KOTIPURA 220 - TUBINAKERE 1& 2 220	KOTIPURA 220	16:38	16:50	0:12	MAIN SUPPLY FAILURE
451	16-Mar-22	GULBARGA	66	HV1	ITTAGI_220	20:32 (11.03.2022)	23:30 (16.03.2022)	122:58 HRS	TRANSFORMER CHARGED
452	16-Mar-22	GULBARGA	66	HV2	ITTAGI_220	11:55	14:50	2:55	LINE CLEAR AVAILED
453	16-Mar-22	GULBARGA	66	KUDLIGI-GUDEKOTE	KUDLIGI_66,HANSI_66	11:55	12:40	0:45	LINE CLEAR AVAILED
454	16-Mar-22	GULBARGA	66	MUNIRABAD-MHD LINE	VENKATAPUR_66,UPANAYAKANAHALLI_66,HAGARIBOMMANAHALLI_66,RR STEELS_IPP	4:59	11:01	6:02	LINE FAULT
455	16-Mar-22	GULBARGA	110	GALAG-MALLAT	GALAG_110	10:20	16:00	5:40	MAIN SUPPLY FAILURE
456	16-Mar-22	GULBARGA	110	HATTI-GAMESH IPP	HATTI_110	2:21(15.03.2022)	13:54(16.03.2022)	35:33 hrs	LINE CHARGED
457	16-Mar-22	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	13:22	13:47	0:25	LINE CLEAR AVAILED
458	16-Mar-22	GULBARGA	110	HV1	GHATTARGA_110	12:46	12:52	0:06	TRANSFORMER FAULT
459	16-Mar-22	GULBARGA	110	HV1	SIRIGERICROSS_110	19:50	20:00	0:10	TRANSFORMER FAULT
460	16-Mar-22	GULBARGA	110	HV1	TEKKALKOTE_110	12:45	16:49	4:04	LINE CLEAR AVAILED
461	16-Mar-22	GULBARGA	110	HV2	BISILAHALLI_110	16:27	16:37	0:10	TRANSFORMER FAULT
462	16-Mar-22	GULBARGA	110	HV2	CHITAGUPPA_110	10:30	18:30	8:00	LINE CLEAR AVAILED
463	16-Mar-22	GULBARGA	110	KAPNOOR-GULBARGA WEST2	GULBARGA WEST_110,GULBARGA SOUTH_110	8:45 (15.03.2022)			LINE OPEN:LINE CLEAR AVAILED
464	16-Mar-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	10:30	14:30	4:00	LINE CLEAR AVAILED
465	16-Mar-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	10:30	14:30	4:00	LINE CLEAR AVAILED
466	16-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	3:45	3:50	0:05	LINE FAULT
467	16-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	4:20	4:25	0:05	LINE FAULT
468	16-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:45	5:50	0:05	LINE FAULT
469	16-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	15:12	15:18	0:06	LINE FAULT
470	16-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	19:01	19:08	0:07	LINE FAULT
471	16-Mar-22	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110	2:00	2:05	0:05	LINE FAULT
472	16-Mar-22	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110	2:50	2:55	0:05	LINE FAULT
473	16-Mar-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
474	16-Mar-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	6:10	6:23	0:13	LINE FAULT
475	16-Mar-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	0:44	0:54	0:10	LINE FAULT
476	16-Mar-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	6:15	6:20	0:05	LINE FAULT
477	16-Mar-22	GULBARGA	110	YERADONA-SINDHANOOR	YERADONA_110	6:00	6:15	0:15	MAIN SUPPLY FAILURE
478	16-Mar-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
479	16-Mar-22	GULBARGA	220	LINGAPUR-SULEKAL1	LINGAPUR_220	10:33	14:38	4:05	LINE CLEAR AVAILED
480	16-Mar-22	GULBARGA	220	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	21:04	21:15	0:11	LINE FAULT
481	16-Mar-22	GULBARGA	220	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	23:38	23:50	0:12	LINE FAULT
482	16-Mar-22	GULBARGA	220	MALLAT-RTPS	RTPS_220	3:28	4:33	1:05	LINE FAULT
483	16-Mar-22	GULBARGA	220	SHAHAPUR-KAPNOOR	SHAHAPUR_220	13:01	13:51	0:50	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
484	16-Mar-22	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	13:51	13:58	0:07	MAIN SUPPLY FAILURE
485	16-Mar-22	HASSAN	66	AREHALI-SAKLESPUR	AREHALLI_66	10:16	19:14	8:58	LINE CLEAR AVAILED
486	16-Mar-22	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	15:15	18:36	3:21	NFBC ISSUED
487	16-Mar-22	HASSAN	66	CRPATNA-SBELAGOLA	CHANNARAYAPATNA_66	11:43	11:59	0:16	LINE FAULT
488	16-Mar-22	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLI_66	13:46	14:12	0:26	LINE FAULT
489	16-Mar-22	HASSAN	66	HANUBAL-SAKLESPUR	HANUBAL_66	10:12	19:13	9:01	LINE CLEAR AVAILED
490	16-Mar-22	HASSAN	66	HASSN22-ARAKALGU1	HASSAN_220	11:06	13:04	1:58	LINE CLEAR AVAILED
491	16-Mar-22	HASSAN	66	HASSN22-ARAKALGUD2	HASSAN_220	11:25	13:19	1:54	LINE CLEAR AVAILED
492	16-Mar-22	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	10:15	10:21	0:06	HAND TRIPPED
493	16-Mar-22	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	12:37	12:42	0:05	HAND TRIPPED
494	16-Mar-22	HASSAN	66	HNPR2-RNPR2	HNPURA_220	19:01	21:05	2:04	LINE CLEAR AVAILED
495	16-Mar-22	HASSAN	66	HV1	MALLAPURA_66	9:28	17:08	7:40	LINE CLEAR AVAILED
496	16-Mar-22	HASSAN	66	HV1	AREHALLI_66	10:16	19:14	8:58	LINE CLEAR AVAILED
497	16-Mar-22	HASSAN	66	HV1	BYACHANAHALLI_66	19:00	21:10	2:10	MAIN SUPPLY FAILURE
498	16-Mar-22	HASSAN	66	HV1	DODDAHALLI_66	13:46	13:51	0:05	TRANSFORMER FAULT
499	16-Mar-22	HASSAN	66	HV1	HANUBAL_66	10:12	19:13	9:01	LINE CLEAR AVAILED
500	16-Mar-22	HASSAN	66	HV1	KUDLIGERE_66	9:31	11:19	1:48	LINE CLEAR AVAILED
501	16-Mar-22	HASSAN	66	HV1	MALALI_66	8:21	12:20	3:59	LINE CLEAR AVAILED
502	16-Mar-22	HASSAN	66	HV1	MALLIPATNA_66	15:19	15:27	0:08	TRANSFORMER FAULT
503	16-Mar-22	HASSAN	66	HV1	SAKALESHPURA_66	10:45	19:05	8:20	LINE CLEAR AVAILED
504	16-Mar-22	HASSAN	66	HV1	YESLUR_66	11:05	13:05	2:00	MAIN SUPPLY FAILURE
505	16-Mar-22	HASSAN	66	HV2	MALLAPURA_66	9:28	17:08	7:40	LINE CLEAR AVAILED
506	16-Mar-22	HASSAN	66	HV2	SHANTHIGRAMA_66	6:37	6:44	0:07	TRANSFORMER FAULT
507	16-Mar-22	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	10:37	18:43	8:06	MAIN SUPPLY FAILURE
508	16-Mar-22	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	9:32	11:05	1:33	LINE CLEAR AVAILED
509	16-Mar-22	HASSAN	66	MALALI-CRPATNA	MALALI_66	10:30	12:19	1:49	NFBC ISSUED
510	16-Mar-22	HASSAN	66	MALALI-HASSAN	MALALI_66	11:02	12:19	1:17	LINE CLEAR AVAILED
511	16-Mar-22	HASSAN	66	MALALI-SIGEBAGI	KUDLIGERE_66	9:32	10:57	1:25	LINE CLEAR AVAILED
512	16-Mar-22	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	9:28	17:08	7:40	LINE CLEAR AVAILED
513	16-Mar-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
514	16-Mar-22	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGARA_66	10:25	12:35	2:10	MAIN SUPPLY FAILURE
515	16-Mar-22	HASSAN	66	SAKALE-HANBAL	SAKALESHPURA_66	10:10	19:15	9:05	LINE CLEAR AVAILED
516	16-Mar-22	HASSAN	66	SAKALE-HASSAN	SAKALESHPURA_66	10:40	19:05	8:25	NFBC ISSUED
517	16-Mar-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	10:25	19:45	9:20	LINE CLEAR AVAILED
518	16-Mar-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	10:25	19:45	9:20	LINE CLEAR AVAILED
519	16-Mar-22	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	9:33	10:56	1:23	LINE CLEAR AVAILED
520	16-Mar-22	HASSAN	110	ANVATI-BARNGI	ANAVATTI_66	9:00	9:20	0:20	HAND TRIPPED
521	16-Mar-22	HASSAN	110	BARANG-ANVATTI	BARANGI_66	9:00	9:20	0:20	HAND TRIPPED
522	16-Mar-22	HASSAN	110	HV1	KONAJE_110	14:34	14:39	0:05	HAND TRIPPED
523	16-Mar-22	HASSAN	110	HV2	KONAJE_110	14:34	14:39	0:05	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
524	16-Mar-22	HASSAN	110	HV3	KONAJE_110	14:34	14:39	0:05	HAND TRIPPED
525	16-Mar-22	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			LINE OPEN:LINE CLEAR AVAILED
526	16-Mar-22	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	9:59	11:07	1:08	MAIN SUPPLY FAILURE
527	16-Mar-22	HASSAN	110	LPH-LST3	gen_lph	9:57	11:52	1:55	LINE CLEAR AVAILED
528	16-Mar-22	HASSAN	110	LPH-LST4	gen_lph	11:58	13:24	1:26	LINE CLEAR AVAILED
529	16-Mar-22	HASSAN	110	LPH-MGHE 1	gen_lph	9:42	13:30	3:48	LINE CLEAR AVAILED
530	16-Mar-22	HASSAN	110	LPH-MGHE 2	gen_lph	9:56	13:27	3:31	LINE CLEAR AVAILED
531	16-Mar-22	HASSAN	110	SAGARA-LST4	SAGARA_110	11:59	13:18	1:19	LINE CLEAR AVAILED
532	16-Mar-22	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	9:55	14:15	4:20	LINE FAULT
533	16-Mar-22	HASSAN	110	TALAGU-L1-LST 3 LPH	TALAGUPPA_110	10:00	11:38	1:38	LINE CLEAR AVAILED
534	16-Mar-22	HASSAN	220	GERSOPA-TALGUPA1	gern_gerusoppa	15:14	15:44	0:30	LINE FAULT
535	16-Mar-22	HASSAN	220	GERSOPA-TALGUPA2	gern_gerusoppa	15:14	15:39	0:25	LINE FAULT
536	16-Mar-22	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			LINE OPEN:LINE CLEAR AVAILED
537	16-Mar-22	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	15:06	15:44	0:38	LINE FAULT
538	16-Mar-22	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			LINE OPEN:LINE CLEAR AVAILED
539	16-Mar-22	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			LINE OPEN:LINE CLEAR AVAILED
540	16-Mar-22	HASSAN	220	SHRAVITY-TALAGUPPA1	gen_sharavathy	12:07	14:37	2:30	LINE CLEAR AVAILED
541	16-Mar-22	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	12:07	14:37	2:30	LINE CLEAR AVAILED
542	16-Mar-22	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	15:06	15:31	0:25	LINE FAULT
543	16-Mar-22	MYSURU	66	HANNUR-KOTHANURU	NO STATIONS EFFECTED	1:20	1:30	0:10	LINE FAULT
544	16-Mar-22	MYSURU	66	HANNUR-KOTHANURU	NO STATIONS EFFECTED	6:05	6:10	0:05	LINE FAULT
545	16-Mar-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN:LINE CLEAR AVAILED
546	16-Mar-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58(13.03.22)			LINE OPEN:LINE CLEAR AVAILED
547	16-Mar-22	MYSURU	66	HV1	MADDUR-	12:59	13:03	0:04	TRANSFORMER FAULT
548	16-Mar-22	MYSURU	66	HV1	MADDUR-	17:16	17:22	0:06	TRANSFORMER FAULT
549	16-Mar-22	MYSURU	66	HV2	DEVANUR MYSORE-	12:09	15:08	2:59	LINE CLEAR AVAILED
550	16-Mar-22	MYSURU	66	KK HALLI-MANDYA	KK HALLI	16:15	19:05	2:50	LINE CLEAR AVAILED
551	16-Mar-22	MYSURU	66	R K NAGARA-DATTAGALLI	R K NAGARA	10:05	16:19	6:14	NFBC ISSUED
552	16-Mar-22	MYSURU	66	TUBINAKERE-PANDAVAPURA	BELAGOLA_66 DODDABYADARAHALLI_66 BANANGADI_66 PANDAVAPURA_66	1:58	2:06	0:08	LINE FAULT
553	16-Mar-22	MYSURU	66	TUBINAKERE-PANDAVAPURA	BELAGOLA_66 DODDABYADARAHALLI_66 BANANGADI_66 PANDAVAPURA_66	10:24	10:29	0:05	LINE FAULT
554	16-Mar-22	MYSURU	66	VAJAMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	18:46	18:54	0:08	LINE FAULT
555	16-Mar-22	MYSURU	66	YERALLI HAND POST-HD KOTE	HD KOTE & ANTRASANTHE	11:00	15:20	4:20	LINE CLEAR AVAILED
556	16-Mar-22	MYSURU	66	YERALLI HAND POST-HD KOTE	HD KOTE & ANTRASANTHE	17:30	17:45	0:15	HAND TRIPPED
557	16-Mar-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	19:16(14.12.21)			LINE OPEN:LINE CLEAR AVAILED
558	16-Mar-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	19:16(14.12.21)			LINE OPEN:LINE CLEAR AVAILED
559	16-Mar-22	MYSURU	220	HUYGONAHALLI-TUBINAKERE	NO STATIONS EFFECTED	16:35	16:47	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
560	16-Mar-22	MYSURU	220	TUBINAKERE-BASTIPURA	TUBINAKERE_220 SHIVALLY_66 BASARALU_66 TARIPURA_66 ARAKERE_66 GAMANAHALLY_66 MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 GARUDANAUKADDA_66 KOPPA_66 PANDAVAPURA_66 SRIRANGAPATNA_66 BESAGARAHALLI_66 DODDABYADARAHALLI_66 BELAGOLA_66 BANANGADI_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 G MALLIGERE_66 SHIVALLY_66 NAGAMANGALA_66	16:35	17:27	0:52	LINE FAULT
561	16-Mar-22	MYSURU	220	TUBINAKERE-YELIYUR	NO STATIONS EFFECTED	10:31	13:42	3:11	LINE CLEAR AVAILED
562	16-Mar-22	TUMKUR	66	HANAGAL-AVADASOLAR_IPP_66(ASEP)	AVADASOLAR_IPP_66	13:39	13:58	0:19	LINE CLEAR AVAILED
563	16-Mar-22	TUMKUR	66	ANCHEPALYA 220- HEBBUR	HEBBUR_66	9:25	9:32	0:07	LOAD CURTAILMENT
564	16-Mar-22	TUMKUR	66	BENKIKERE 220kV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	12:40	13:01	0:21	LINE FAULT
565	16-Mar-22	TUMKUR	66	BENKIKERE 220kV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	13:09	13:37	0:28	LINE FAULT
566	16-Mar-22	TUMKUR	66	BENKIKERE 220kV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	13:52	14:56	1:03	LINE FAULT
567	16-Mar-22	TUMKUR	66	BENKIKERE 220kV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	17:03	17:45	0:42	LINE CLEAR AVAILED
568	16-Mar-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	0:28	0:39	0:10	LINE FAULT
569	16-Mar-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:20	14:30	0:10	LINE FAULT
570	16-Mar-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:30	15:43	0:13	LINE FAULT
571	16-Mar-22	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	14:08	14:11	0:02	LINE FAULT
572	16-Mar-22	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	14:08	14:12	0:04	LINE FAULT
573	16-Mar-22	TUMKUR	66	HIRIYUR 220KV-SIRA(HIRIYUR)	HIRIYUR_66	14:08	14:12	0:03	LINE FAULT
574	16-Mar-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	13:06	13:10	0:04	LINE FAULT
575	16-Mar-22	TUMKUR	66	THALLAK 220KV- P R PURA	PR PURA_66	14:09	17:20	3:11	LINE FAULT
576	16-Mar-22	TUMKUR	66	TR-1	AMRUTHUR_66	16:24	16:29	0:04	TRANSFORMER FAULT
577	16-Mar-22	TUMKUR	66	TR-1	BILCHODU_66	14:01	14:23	0:21	LINE CLEAR AVAILED
578	16-Mar-22	TUMKUR	66	TR-1	BILCHODU_66	14:33	14:40	0:06	TRANSFORMER FAULT
579	16-Mar-22	TUMKUR	66	TR-1	BILCHODU_66	14:42	14:45	0:02	TRANSFORMER FAULT
580	16-Mar-22	TUMKUR	66	TR-1	DAVANGERE_220	2:24	14:47	12:23	TRANSFORMER FAULT
581	16-Mar-22	TUMKUR	66	TR-1& 2	MAVINAKATTE_66	13:41	14:08	0:27	LINE CLEAR AVAILED
582	16-Mar-22	TUMKUR	66	TR-1& 2	MAVINAKATTE_66	18:27	18:35	0:07	LINE CLEAR AVAILED
583	16-Mar-22	TUMKUR	66	TR-2	KADAJJI_66	9:00	9:05	0:04	TRANSFORMER FAULT
584	16-Mar-22	TUMKUR	66	TR-2	NITRAHALLI_66	20:25	20:34	0:08	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
585	16-Mar-22	TUMKUR	110	KB CROSS 220KV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	12:19	13:22	1:03	LINE FAULT
586	16-Mar-22	TUMKUR	110	TR-2	KADEHALLI_110	14:29	14:40	0:11	TRANSFORMER FAULT
587	16-Mar-22	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR_IPP_66	AZURE POWER SOLAR_IPP_66	13:29	14:08	0:38	LINE FAULT
588	16-Mar-22	TUMKUR	220	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	13:29	14:08	0:38	LINE FAULT
589	16-Mar-22	TUMKUR	220	HIRIYUR 220KV- THALLAK	THALLAK_66	13:29	13:59	0:29	LINE FAULT
590	16-Mar-22	TUMKUR	220	TR-1& 3	HIRIYUR_220	13:29	14:08	0:39	TRANSFORMER FAULT
591	16-Mar-22	TUMKUR	220	TR-2	HIRIYUR_220	13:29	14:00	0:30	TRANSFORMER FAULT
592	17-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NIDAGUNDI_110	10:16	10:20	0:04	TRANSFORMER FAULT
593	17-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED HUBLI_220	5:14	5:40	0:26	HAND TRIPPED
594	17-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED HUBLI_220	5:14	6:53	1:39	LINE CLEAR AVAILED
595	17-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED UAS DHARWAD_110	13:50	16:59	3:09	TRANSFORMER FAULT
596	17-Mar-22	BAGALKOT	110	110/11KV,HV1	KUDALASANGAM_110	6:26	6:29	0:03	TRANSFORMER FAULT
597	17-Mar-22	BAGALKOT	110	110/11KV,HV1	KUDALASANGAM_110	8:10	8:11	0:01	TRANSFORMER FAULT
598	17-Mar-22	BAGALKOT	110	110/11KV,HV1	KUDALASANGAM_110	8:17	8:56	0:39	TRANSFORMER FAULT
599	17-Mar-22	BAGALKOT	110	110/11KV,HV1	BETAGERI_110	13:00	14:17	1:17	TRANSFORMER FAULT
600	17-Mar-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	9:39	9:41	0:02	TRANSFORMER FAULT
601	17-Mar-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	10:02	10:05	0:03	TRANSFORMER FAULT
602	17-Mar-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	15:47	16:45	0:58	LINE CLEAR AVAILED
603	17-Mar-22	BAGALKOT	110	110/11KV,HV2	KAMBAGI_110	10:04	10:11	0:07	TRANSFORMER FAULT
604	17-Mar-22	BAGALKOT	110	110/11KV,HV2	MUKARTIHAL_110	17:01	17:16	0:15	TRANSFORMER FAULT
605	17-Mar-22	BAGALKOT	110	110/11KV,HV4	BELGAUM_110	17:42	18:18	0:36	LINE CLEAR AVAILED
606	17-Mar-22	BAGALKOT	110	110/11KV,HV4	LAKAMANAHALLI_110	14:22	16:35	2:13	LINE CLEAR AVAILED
607	17-Mar-22	BAGALKOT	110	110/33KV, HV4	STATION NOT AFFECTED HUBLI_220	5:14	5:32	0:18	HAND TRIPPED
608	17-Mar-22	BAGALKOT	110	220/110KV,LV4	STATION NOT AFFECTED GADAG_220	13:10 (15.03.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
609	17-Mar-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)	17:16 (17.03.2022)	2233:34 hrs	LINE CHARGED
610	17-Mar-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
611	17-Mar-22	BAGALKOT	110	HALYAL-ALNAVAR(GMR)	ALNAVAR_110	12:14	12:43	0:29	HAND TRIPPED
612	17-Mar-22	BAGALKOT	110	HOSAHONNATTI-AREMALLAPUR(F2)	AREMALLAPUR_110	12:27	16:57	4:30	LINE CLEAR AVAILED
613	17-Mar-22	BAGALKOT	110	HUBLI220-ANANDANAGAR	ANANDANAGAR_110	5:14	5:25	0:11	HAND TRIPPED
614	17-Mar-22	BAGALKOT	110	HUBLI220-KADANAKOPPA	KADANAKOPPA_110	5:18	6:43	1:25	LINE CLEAR AVAILED
615	17-Mar-22	BAGALKOT	110	HUBLI220-KALAGHATAGI (SIRSI)	KALAGHATAGI_110	5:17	7:33	2:16	LINE CLEAR AVAILED
616	17-Mar-22	BAGALKOT	110	HUBLI220-PH COUMPOUND	PH COUMPOUND_110	5:20	7:08	1:48	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
617	17-Mar-22	BAGALKOT	110	HUBLI220-TARIHAL2	STATION NOT AFFECTED HUBLI_220	0:00	4:32	4:32	LINE CLEAR AVAILED
618	17-Mar-22	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	5:17	6:48	1:31	LINE FAULT
619	17-Mar-22	BAGALKOT	110	ITNAL-KABBUR	ITNAL_110	9:44	21:34	11:50	LINE CLEAR AVAILED
620	17-Mar-22	BAGALKOT	110	KULIGOD-GAMESH	KULIGOD_110	19:51	19:59	0:08	HAND TRIPPED
621	17-Mar-22	BAGALKOT	110	MAHALINGPUR-HIDIKAL	HIDIKAL_110	10:03	10:05	0:02	HAND TRIPPED
622	17-Mar-22	BAGALKOT	110	NAREGALL-BETAGERI	BETAGERI_110	10:25	12:20	1:55	LINE CLEAR AVAILED
623	17-Mar-22	BAGALKOT	110	NARENDRA-KUD DHARWAD1	KUD DHARWAD_110	3:39	3:51	0:12	LINE FAULT
624	17-Mar-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
625	17-Mar-22	BAGALKOT	110	RANEENNUR- BYADAGI	STATION NOT AFFECTED RANEENNUR_220	14:01	17:09	3:08	LINE FAULT
626	17-Mar-22	BAGALKOT	110	RANEENNUR-BYADAGI	STATION NOT AFFECTED BYADAGI_110	14:06	18:47	4:41	LINE CLEAR AVAILED
627	17-Mar-22	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)	14:52 (17.03.2022)	68:10 hrs	LINE CHARGED
628	17-Mar-22	BAGALKOT	110	SATTI-RABAKAVI	RABAKAVI_110	9:32	9:37	0:05	HAND TRIPPED
629	17-Mar-22	BAGALKOT	110	SHIRHATTI-LAXMESHWER	STATION NOT AFFECTED SHIRHATTI_110	17:45 (16.03.2022)	10:49 (17.03.2022)	17:04 hrs	LINE CHARGED
630	17-Mar-22	BAGALKOT	110	SULTANPUR-MUGALKHOD220	STATION NOT AFFECTED SULTANPUR_110	8:59	21:33	12:34	LINE CLEAR AVAILED
631	17-Mar-22	BAGALKOT	110	TADASINAKOPPA-KIADB GAMANAGATTI	STATION NOT AFFECTED TADASINAKOPPA_110	10:10	10:48	0:38	LINE FAULT
632	17-Mar-22	BAGALKOT	110	TADASINAKOPPA-KIADB GAMANAGATTI	STATION NOT AFFECTED TADASINAKOPPA_110	4:24	4:36	0:12	LINE FAULT
633	17-Mar-22	BAGALKOT	110	TADASINAKOPPA-KIADB GAMANAGATTI	STATION NOT AFFECTED TADASINAKOPPA_110	4:11	4:21	0:10	LINE FAULT
634	17-Mar-22	BAGALKOT	110	TARIHAL-HUBLI220	STATION NOT AFFECTED TARIHAL_110	11:32	14:08	2:36	NFBC ISSUED
635	17-Mar-22	BAGALKOT	110	TARIHAL-HUBLI220-2	STATION NOT AFFECTED TARIHAL_110	9:00 (16.03.2022)	4:57 (17.03.2022)	19:57 hrs	LINE CHARGED
636	17-Mar-22	BAGALKOT	110	TARIHAL-KIADB GAMANAGATTI (IDLE)	STATION NOT AFFECTED TARIHAL_110	11:28	11:32	0:04	HAND TRIPPED
637	17-Mar-22	BAGALKOT	110	TARIHAL-KIADB GAMANAGATTI (IDLE)	STATION NOT AFFECTED TARIHAL_110	4:57	10:41	5:44	LINE CLEAR AVAILED
638	17-Mar-22	BAGALKOT	220	220/110, HV2	STATION NOT AFFECTED HUBLI_220	5:00	6:36	1:36	LINE CLEAR AVAILED
639	17-Mar-22	BAGALKOT	220	220/110KV, HV1 & LV1	STATION NOT AFFECTED HUBLI_220	5:14	15:41	10:27	LINE CLEAR AVAILED
640	17-Mar-22	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	16:05 (08.03.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
641	17-Mar-22	BAGALKOT	220	ATHANI-KUDACHI	STATION NOT AFFECTED ATHANI_220	9:03	19:56	10:53	NFBC ISSUED
642	17-Mar-22	BAGALKOT	220	BAGALKOT - VAJARAMATTI2	STATION NOT AFFECTED BAGALKOT_220	13:29	13:36	0:07	HAND TRIPPED
643	17-Mar-22	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
644	17-Mar-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
645	17-Mar-22	BAGALKOT	220	BIDNAL-HUBLI3	STATION NOT AFFECTED BIDNAL_220	4:59	6:47	1:48	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
646	17-Mar-22	BAGALKOT	220	CHIKKODI- BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
647	17-Mar-22	BAGALKOT	220	CHIKKODI- BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:43 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
648	17-Mar-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
649	17-Mar-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
650	17-Mar-22	BAGALKOT	220	HUBLI-NARENDRA1	STATION NOT AFFECTED HUBLI_220	12:17	12:32	0:15	LINE CLEAR AVAILED
651	17-Mar-22	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	12:17	12:33	0:16	LINE CLEAR AVAILED
652	17-Mar-22	BAGALKOT	220	KUDACHI-ATHANI	STATION NOT AFFECTED KUDACHI_220	9:03	19:58	10:55	LINE CLEAR AVAILED
653	17-Mar-22	BAGALKOT	220	KUDACHI-CHIKKODI1	STATION NOT AFFECTED KUDACHI_220	5:50	8:52	3:02	LINE FAULT
654	17-Mar-22	BAGALKOT	220	KUDACHI-MAHALINGAPUR2	STATION NOT AFFECTED KUDACHI_220	9:03	20:54	11:51	LINE CLEAR AVAILED
655	17-Mar-22	BAGALKOT	220	NARENDRA-HUBLI 1&2	NARENDRA_220	4:59	5:20	0:21	LINE FAULT
656	17-Mar-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	10:13 (12.03.2022)			LINE OPEN:LINE CLEAR AVAILED
657	17-Mar-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	10:14 (12.03.2022)			LINE OPEN:LINE CLEAR AVAILED
658	17-Mar-22	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	16:04	19:06	3:02	LINE CLEAR AVAILED
659	17-Mar-22	BAGALKOT	220	VAJRAMATTI-BAGALKOT-2	STATION NOT AFFECTED VAJRAMATTI_220	14:43 (16.03.2022)	13:36 (17.03.2022)	22:58 hrs	LINE CHARGED
660	17-Mar-22	BENGALURU	66	A STATION 220 - A STATION 1	A STATION 66	12:27	12:38	0:11	LINE CLEAR AVAILED
661	17-Mar-22	BENGALURU	66	A STATION 220 - A STATION 1 66	A STATION 66	12:14	12:21	0:07	LINE CLEAR AVAILED
662	17-Mar-22	BENGALURU	66	A STATION 220 - A STATION 2	A STATION 66	12:27	12:38	0:11	LINE CLEAR AVAILED
663	17-Mar-22	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	12:14	12:21	0:07	LINE CLEAR AVAILED
664	17-Mar-22	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	12:27	12:38	0:11	LINE CLEAR AVAILED
665	17-Mar-22	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	13:38	13:40	0:02	LOAD CHANGE OVER
666	17-Mar-22	BENGALURU	66	A STATION 220 - SHOBHA INDRAPRASTA	SHOBHA INDRAPRASTA	12:14	12:21	0:07	LINE CLEAR AVAILED
667	17-Mar-22	BENGALURU	66	A STATION 220 - SHOBHA INDRAPRASTA	SHOBHA INDRAPRASTA	12:27	12:38	0:11	LINE CLEAR AVAILED
668	17-Mar-22	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	12:27	12:38	0:11	LINE CLEAR AVAILED
669	17-Mar-22	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	13:23	13:27	0:04	LOAD CHANGE OVER
670	17-Mar-22	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA	5:47	5:51	0:04	LOAD CHANGE OVER
671	17-Mar-22	BENGALURU	66	AUSTIN TOWN - EAST DIVISION COMPOUND 220	AUSTIN TOWN	12:14	12:54	0:40	MAIN SUPPLY FAILURE
672	17-Mar-22	BENGALURU	66	AUSTIN TOWN - EAST DIVISION COMPOUND 220	AUSTIN TOWN	14:00	14:06	0:06	LOAD CHANGE OVER
673	17-Mar-22	BENGALURU	66	BAGHMANE WTP - ITI 220	BAGMANE WTP	11:21	11:27	0:06	LOAD CHANGE OVER
674	17-Mar-22	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	17:41	17:44	0:02	LOAD CHANGE OVER
675	17-Mar-22	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	12:14	12:52	0:38	LINE CLEAR AVAILED
676	17-Mar-22	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI	12:14	12:52	0:38	LINE CLEAR AVAILED
677	17-Mar-22	BENGALURU	66	HAL 220 - B STATION 1 & 2	B STATION	12:14	12:50	0:36	LINE CLEAR AVAILED
678	17-Mar-22	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI	12:14	12:28	0:14	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
679	17-Mar-22	BENGALURU	66	HOODY 220 - BAGHMANE TECH PARK 2	NO STATION AFFECTED	12:15	17:36	5:21	LINE FAULT
680	17-Mar-22	BENGALURU	66	HV1	THAYALUR	11:17	11:20	0:02	LINE CLEAR AVOIDED
681	17-Mar-22	BENGALURU	66	HV1	THAYALUR	17:35	17:54	0:19	LINE CLEAR AVOIDED
682	17-Mar-22	BENGALURU	66	HV1	SADLI	13:23	15:00	1:37	TRANSFORMER FAULT
683	17-Mar-22	BENGALURU	66	HV1	KANAKAPURA 66	10:50	10:55	0:05	LINE CLEAR AVOIDED
684	17-Mar-22	BENGALURU	66	HV1	SARJAPURA 220	12:56	13:50	0:53	MAIN SUPPLY FAILURE
685	17-Mar-22	BENGALURU	66	HV1	SADLI	10:00(16-3-2022)	13:11(17-3-2022)	27:10 hrs	TRANSFORMER CHARGED
686	17-Mar-22	BENGALURU	66	HV2	KYALANUR	12:07	12:10	0:02	LINE CLEAR AVOIDED
687	17-Mar-22	BENGALURU	66	HV2	BANGARPET	21:13	21:16	0:02	TRANSFORMER FAULT
688	17-Mar-22	BENGALURU	66	HV2	SARJAPURA 220	12:56	14:00	1:03	MAIN SUPPLY FAILURE
689	17-Mar-22	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	13:21	13:25	0:04	LOAD CHANGE OVER
690	17-Mar-22	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KENGERI SATELLITE TOWN	7:30	7:50	0:20	MAIN SUPPLY FAILURE
691	17-Mar-22	BENGALURU	66	KORMANGALA 220 - AMARJYOTHI	AMARJYOTHI	12:14	12:38	0:24	LINE CLEAR AVOIDED
692	17-Mar-22	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	12:14	12:38	0:24	LINE CLEAR AVOIDED
693	17-Mar-22	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU	7:30	7:46	0:16	LINE FAULT
694	17-Mar-22	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	12:16	12:23	0:07	LINE FAULT
695	17-Mar-22	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), KGF, KAMASAMUDRA	20:31	20:55	0:23	LINE FAULT
696	17-Mar-22	BENGALURU	66	NIMHANS 220 - BMTC	BMTC, NATIONAL COLLEGE	12:14	12:53	0:39	LINE CLEAR AVOIDED
697	17-Mar-22	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	12:14	12:52	0:38	LINE CLEAR AVOIDED
698	17-Mar-22	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	12:14	12:52	0:38	LINE CLEAR AVOIDED
699	17-Mar-22	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	12:27	12:48	0:21	LINE FAULT
700	17-Mar-22	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	12:14	12:19	0:05	MAIN SUPPLY FAILURE
701	17-Mar-22	BENGALURU	66	PATHPALYA - SOMANATHPURA	THIMMAMPALLI	11:30	11:40	0:10	LINE FAULT
702	17-Mar-22	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	12:56	13:53	0:56	MAIN SUPPLY FAILURE
703	17-Mar-22	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:56	13:57	1:00	MAIN SUPPLY FAILURE
704	17-Mar-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:56	13:55	0:59	MAIN SUPPLY FAILURE
705	17-Mar-22	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	7:30	7:46	0:16	LINE FAULT
706	17-Mar-22	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	17:26	17:29	0:03	LOAD CHANGE OVER
707	17-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	16:48	17:08	0:20	LOAD CHANGE OVER
708	17-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	13:46	15:45	1:59	LINE FAULT
709	17-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	15:45	17:10	1:25	LINE CLEAR AVOIDED
710	17-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	16:48	17:08	0:20	LOAD CHANGE OVER
711	17-Mar-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	6:00	6:14	0:14	LINE FAULT
712	17-Mar-22	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTURU	GUNDLU KOTTURU	16:18	16:26	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
713	17-Mar-22	BENGALURU	66	VIKAS TECH PARK 220 - CESSNA TECH PARK 1	CESSNA TECH PARK	12:57	14:04	1:07	LINE CLEAR AVAILED
714	17-Mar-22	BENGALURU	66	VIKAS TECH PARK 220 - CESSNA TECH PARK 2	CESSNA TECH PARK	12:57	14:04	1:07	LINE CLEAR AVAILED
715	17-Mar-22	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	12:57	13:42	0:45	LINE CLEAR AVAILED
716	17-Mar-22	BENGALURU	66	VIKAS TECH PARK 220 - EXORA	EXORA	12:57	13:57	1:00	LINE CLEAR AVAILED
717	17-Mar-22	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	12:57	13:42	0:45	LINE CLEAR AVAILED
718	17-Mar-22	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	12:57	13:42	0:45	LINE CLEAR AVAILED
719	17-Mar-22	BENGALURU	66	VRISHABHAVATHI 220 - SIR MV LAYOUT	KENGERI SATELLITE TOWN, SIR MV LAYOUT	9:40(16/03/2022)	7:29(17/03/2022)	21:48 hrs	LINE CHARGED
720	17-Mar-22	BENGALURU	220	A STATION 220 - EAST DIVISION COMPOUND 220	A STATION 220	12:14	12:21	0:07	MAIN SUPPLY FAILURE
721	17-Mar-22	BENGALURU	220	A STATION 220 - NRS 220	A STATION 220	12:27	12:38	0:11	MAIN SUPPLY FAILURE
722	17-Mar-22	BENGALURU	220	EAST DIVISION COMPOUND - HAL 220	EAST DIVISION COMPOUND 220	12:14	12:35	0:21	MAIN SUPPLY FAILURE
723	17-Mar-22	BENGALURU	220	HAL 220 - EAST DIVISION COMPOUND 220	EAST DIVISION COMPOUND 220	12:14	12:34	0:20	LINE CLEAR AVAILED
724	17-Mar-22	BENGALURU	220	HAL 220 - HOODY 1 400	HAL 220	12:14	12:24	0:10	LINE FAULT
725	17-Mar-22	BENGALURU	220	HAL 220 - HOODY 2 400	HAL 220	12:14	13:19	1:05	LINE FAULT
726	17-Mar-22	BENGALURU	220	HAL 220 - HOODY 2 400	HAL 220	13:19	13:48	0:29	LINE FAULT
727	17-Mar-22	BENGALURU	220	HAL 220 - HOODY 2 400	HAL 220	13:48	23:53	10:05	LINE CLEAR AVAILED
728	17-Mar-22	BENGALURU	220	HOODY 220 - MALUR 220	SARJAPURA 220, VIKAS TECH PARK 220	12:57	13:32	0:35	LINE FAULT
729	17-Mar-22	BENGALURU	220	HOODY 400 - HAL 2 220	HAL 220	12:14	13:19	1:05	LINE FAULT
730	17-Mar-22	BENGALURU	220	HOODY 400 - HAL 2 220	HAL 220	13:19	13:48	0:29	LINE FAULT
731	17-Mar-22	BENGALURU	220	HOODY 400 - HAL 2 220	HAL 220	13:48	23:53	10:05	LINE CLEAR AVAILED
732	17-Mar-22	BENGALURU	220	HV1	NIMHANS 220	12:14	12:51	0:37	LINE CLEAR AVAILED
733	17-Mar-22	BENGALURU	220	HV1	NRS 220	12:27	12:30	0:03	LINE CLEAR AVAILED
734	17-Mar-22	BENGALURU	220	HV1	T GOLLAHALLI 220	16:49	17:09	0:20	LOAD CHANGE OVER
735	17-Mar-22	BENGALURU	220	HV1	SARJAPURA 220	12:56	13:55	0:58	MAIN SUPPLY FAILURE
736	17-Mar-22	BENGALURU	220	HV2	HAL 220	12:14	12:38	0:24	LINE CLEAR AVAILED
737	17-Mar-22	BENGALURU	220	HV2	NIMHANS 220	12:14	13:05	0:51	LINE CLEAR AVAILED
738	17-Mar-22	BENGALURU	220	HV2	NRS 220	12:27	12:40	0:13	LINE CLEAR AVAILED
739	17-Mar-22	BENGALURU	220	HV2	SARJAPURA 220	12:56	13:50	0:53	MAIN SUPPLY FAILURE
740	17-Mar-22	BENGALURU	220	KORAMANGALA 220 - NIMHANS 220	KORAMANGALA 220	12:14	12:37	0:23	MAIN SUPPLY FAILURE
741	17-Mar-22	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	12:56	13:39	0:42	LINE FAULT
742	17-Mar-22	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 3	NRS 220	12:27	12:38	0:10	LINE FAULT
743	17-Mar-22	BENGALURU	220	NIMHANS 220 - EAST DIVISION COMPOUND 220	NIMHANS 220	12:14	12:50	0:36	MAIN SUPPLY FAILURE
744	17-Mar-22	BENGALURU	220	NRS 220 - NELAMANGALA 400	NRS 220	12:27	12:38	0:11	MAIN SUPPLY FAILURE
745	17-Mar-22	BENGALURU	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	12:45	14:43	1:58	LINE FAULT
746	17-Mar-22	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	12:57	13:40	0:43	MAIN SUPPLY FAILURE
747	17-Mar-22	GULBARGA	66	HV1	BENNEHALLI_66	11:05	11:10	0:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
748	17-Mar-22	GULBARGA	110	HV1	NANDUR_110	10:35	11:35	1:00	LINE CLEAR AVAILED
749	17-Mar-22	GULBARGA	110	HV2	MANGALORE_110	12:00	13:10	1:10	LINE CLEAR AVAILED
750	17-Mar-22	GULBARGA	110	HV2	NIRNA_110	13:57	14:03	0:06	TRANSFORMER FAULT
751	17-Mar-22	GULBARGA	110	KAPNOOR-GULBARGA WEST2	GULBARGA WEST_110,GULBARGA SOUTH_110	8:45 (15/03/2022)			LINE OPEN:LINE CLEAR AVAILED
752	17-Mar-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	21:54	23:04	1:10	LINE FAULT
753	17-Mar-22	GULBARGA	110	NALWAR-SHAHPUR	NALWAR_110	5:50	6:00	0:10	LINE FAULT
754	17-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	2:26	2:31	0:05	LINE FAULT
755	17-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:41	20:47	0:06	LINE FAULT
756	17-Mar-22	GULBARGA	110	RAJESHWAR-HUMNABAD	SASTHAPUR_110,RAJESHWAR_110	1:19	1:23	0:04	LINE FAULT
757	17-Mar-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
758	17-Mar-22	GULBARGA	110	SHAHABAD-RAICHUR1	NALWAR_110	18:50(17.03.2022)			LINE OPEN:LINE CLEAR AVAILED
759	17-Mar-22	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	15:40	16:10	0:30	LINE CLEAR AVAILED
760	17-Mar-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERD ONA_110,SRNAGAR_110,MALLAPU RA_110	13:01	13:20	0:19	LINE FAULT
761	17-Mar-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERD ONA_110,SRNAGAR_110,MALLAPU RA_110	15:40	16:10	0:30	LINE CLEAR AVAILED
762	17-Mar-22	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	22:30	22:40	0:10	LINE FAULT
763	17-Mar-22	GULBARGA	110	SIRWAR-RAICHUR	SIRWAR_110	10:55	11:05	0:10	LINE CLEAR AVAILED
764	17-Mar-22	GULBARGA	110	SULEKAL(GANGAVATI)-KANAKAGIRI	KANAKAGIRI_110	18:35	19:40	1:05	LINE FAULT
765	17-Mar-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
766	17-Mar-22	GULBARGA	220	ITTAGI-HARAKNAL_IPP	ITTAGI_220	12:25	19:52	7:27	LINE CLEAR AVAILED
767	17-Mar-22	GULBARGA	220	SINDHANOOR-SULEKAL(GANGAVATHI)	SULEKAL_220	13:05	13:37	0:32	LINE CLEAR AVAILED
768	17-Mar-22	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLI_66	15:15	15:40	0:25	LINE FAULT
769	17-Mar-22	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	15:15	15:40	0:25	LINE FAULT
770	17-Mar-22	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	14:05	14:57	0:52	HAND TRIPPED
771	17-Mar-22	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	14:05	14:57	0:52	HAND TRIPPED
772	17-Mar-22	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	14:05	14:57	0:52	HAND TRIPPED
773	17-Mar-22	HASSAN	66	HV1	DODDAKADANUR_66	15:15	15:40	0:25	TRANSFORMER FAULT
774	17-Mar-22	HASSAN	66	HV1	HALEBEEDU_66	17:10	17:20	0:10	HAND TRIPPED
775	17-Mar-22	HASSAN	66	HV2	HOLENARASIPURA_220	14:05	14:57	0:52	TRANSFORMER FAULT
776	17-Mar-22	HASSAN	66	Lv2	HOLENARASIPURA_220	14:05	17:47	3:42	LINE CLEAR AVAILED
777	17-Mar-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
778	17-Mar-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	9:53	18:40	8:47	LINE CLEAR AVAILED
779	17-Mar-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	9:53	18:40	8:47	LINE CLEAR AVAILED
780	17-Mar-22	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	15:39	16:29	0:50	NFBC ISSUED
781	17-Mar-22	HASSAN	110	HGUNJE-LN2	HEGGUNJE_220	15:37	16:37	1:00	LINE CLEAR AVAILED
782	17-Mar-22	HASSAN	110	HV1	KAVOOR_220	10:15	14:15	4:00	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
783	17-Mar-22	HASSAN	110	HV1	HEGGUNJE_220	11:11	14:14	3:03	LINE CLEAR AVAILED
784	17-Mar-22	HASSAN	110	HV2	KULASHEKARA_110	20:17	20:38	0:21	TRANSFORMER FAULT
785	17-Mar-22	HASSAN	110	KMS110-MRS-ANDPR	KUMSI_110	8:43	11:30	2:47	LINE FAULT
786	17-Mar-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:20	14:40	0:20	HAND TRIPPED
787	17-Mar-22	HASSAN	110	SAGARA-SORABA	SAGARA_110	11:45	11:54	0:09	LOAD CHANGEOVER
788	17-Mar-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	9:00 (17.03.2022)			LINE OPEN:LINE CLEAR AVAILED
789	17-Mar-22	HASSAN	220	GERUSOPA-TALAGUP1	gen_gerusoppa	11:57	14:17	2:20	LINE FAULT
790	17-Mar-22	HASSAN	220	HV2	GOPALPURA_220	14:40	15:50	1:10	LINE CLEAR AVAILED
791	17-Mar-22	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	8:59 (22.02.2022)	17:17(17.03.2022)	536:17 hrs	LINE CHARGED
792	17-Mar-22	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	8:59 (22.02.2022)	17:17(17.03.2022)	536:17 hrs	LINE CHARGED
793	17-Mar-22	HASSAN	220	MRSSHM-SHRAVITY1	MRSMSG_220	13:30	13:48	0:18	HAND TRIPPED
794	17-Mar-22	HASSAN	220	MRSSHM-SHRAVITY1	MRSMSG_220	15:36	18:15	2:39	LINE FAULT
795	17-Mar-22	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	11:57	14:17	2:20	LINE FAULT
796	17-Mar-22	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)	17:13(17.03.2022)	536:13 hrs	LINE CHARGED
797	17-Mar-22	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)	17:13(17.03.2022)	536:13 hrs	LINE CHARGED
798	17-Mar-22	MYSURU	66	BEGUR 220kv-SINDHUVALLI	SINDHUVALLI_66	8:03	8:06	0:03	LINE FAULT
799	17-Mar-22	MYSURU	66	BGPURA-SFC	BGPURA_66	12:51	13:20	0:29	LINE CLEAR AVAILED
800	17-Mar-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN:LINE CLEAR AVAILED
801	17-Mar-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58(17.03.22)			LINE OPEN:LINE CLEAR AVAILED
802	17-Mar-22	MYSURU	66	HV 2	MADHUVANAHALLI_220	7:57:00 PM (3/16/2022)	12:09:00 (3/17/2022)	16:12 hrs	TRANSFORMER CHARGED
803	17-Mar-22	MYSURU	66	HV1	AKKIEBBAL_66	17:17	17:43	0:25	LINE CLEAR AVAILED
804	17-Mar-22	MYSURU	66	HV1	DEVANORNGUDU_66	17:13	18:57	1:44	LINE CLEAR AVAILED
805	17-Mar-22	MYSURU	66	HV1	DUNDANAHALLI_66	11:00	19:08	8:07	LINE CLEAR AVAILED
806	17-Mar-22	MYSURU	66	HV1	MADDUR_66	14:02	14:06	0:04	TRANSFORMER FAULT
807	17-Mar-22	MYSURU	66	HV1	PERIYAPATNA_66	13:47	14:11	0:24	LINE CLEAR AVAILED
808	17-Mar-22	MYSURU	66	HV1	KAGGERE HAMPAPURA_66	14:10	15:00	0:50	HAND TRIPPED
809	17-Mar-22	MYSURU	66	HV1	KAGGERE HAMPAPURA_66	15:10	15:40	0:30	HAND TRIPPED
810	17-Mar-22	MYSURU	66	HV1	SOMANAHALLI_66	13:00	14:42	1:42	LINE CLEAR AVAILED
811	17-Mar-22	MYSURU	66	HV1	JAIPUR_66	10:57:37 AM (3/17/2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
812	17-Mar-22	MYSURU	66	K M DODDI-T K HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	6:00	6:12	0:12	LINE FAULT
813	17-Mar-22	MYSURU	66	KADAKOLA-DEVANUR NANJANGUDU	DEVANORNGUDU_66 SUTTUR_66	18:28	18:45	0:16	LINE FAULT
814	17-Mar-22	MYSURU	66	KOLLEGALA-PARINAMIPURA	PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	18:34	18:41	0:07	LINE FAULT
815	17-Mar-22	MYSURU	66	KUSHALANAGARA-MYSORE 1	NO STATIONS EFFECTED	10:22	10:32	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
816	17-Mar-22	MYSURU	66	KUSHALANAGARA-MYSORE 2	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66 CHUNCHUNKATTE_66 MIRLE_66 KRNAGARA_66 BILIKERE_66 GVGUDI_66 DMG_HALLI_66	10:22	10:34	0:12	LINE FAULT
817	17-Mar-22	MYSURU	66	MADHUVANAHALLI-HANNUR 1	NO STATIONS EFFECTED	7:01	12:01	5:00	LINE CLEAR AVAILED
818	17-Mar-22	MYSURU	66	MALAVALLI-TKHALLI	MALAVALLI_66	16:40	16:46	0:06	HAND TRIPPED
819	17-Mar-22	MYSURU	66	MANDYA-CHIKKAMANDYA	CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66	16:03	16:12	0:08	LINE FAULT
820	17-Mar-22	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 BASARALU_66	6:29	6:34	0:05	LINE FAULT
821	17-Mar-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	19:16 (14.12.21)			LINE OPEN:LINE CLEAR AVAILED
822	17-Mar-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	19:16 (14.12.21)			LINE OPEN:LINE CLEAR AVAILED
823	17-Mar-22	TUMKUR	66	ANCHEPALYA 220kV- B G NAGARA_66	B G NAGARA_66,JIDDEGERE_66,THIPPU R_66,YEDIYUR_66	23:11	23:20	0:08	LINE FAULT
824	17-Mar-22	TUMKUR	66	BEVINAHALLI- AFTL SOLAR_IPP_66	AFTL SOLAR_IPP_66	9:20	9:46	0:25	LINE FAULT
825	17-Mar-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	0:03	0:41	0:37	LINE CLEAR AVAILED
826	17-Mar-22	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE66	NAYAKANHATTI_66, HIREMALLANAHOLE_66	22:01	22:31	0:29	LINE FAULT
827	17-Mar-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	19:13	19:17	0:03	LINE FAULT
828	17-Mar-22	TUMKUR	66	PAVAGADA220-SHYLAPURA_66	SHYLAURA_66	16:58	17:05	0:07	LINE FAULT
829	17-Mar-22	TUMKUR	66	TR-1	AVAREGERE_66	7:48	8:35	0:47	TRANSFORMER FAULT
830	17-Mar-22	TUMKUR	66	TR-1	BENKIKERE_66	10:10	10:19	0:09	TRANSFORMER FAULT
831	17-Mar-22	TUMKUR	66	TR-1	BENKIKERE_66	15:43	15:52	0:09	TRANSFORMER FAULT
832	17-Mar-22	TUMKUR	66	TR-1	BILCHODU_66	12:55	13:44	0:48	LINE CLEAR AVAILED
833	17-Mar-22	TUMKUR	66	TR-1	BRAMASANDRA_66	13:02	18:14	5:11	LINE CLEAR AVAILED
834	17-Mar-22	TUMKUR	66	TR-1	HOLALKERE_66	11:31	16:27	4:56	LINE CLEAR AVAILED
835	17-Mar-22	TUMKUR	66	TR-1	SIRA_66	15:14	16:38	1:23	TRANSFORMER FAULT
836	17-Mar-22	TUMKUR	66	TR-1	PAVAGADA_220	9:45	9:50	0:04	TRANSFORMER FAULT
837	17-Mar-22	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	7:51	8:59	1:08	LINE CLEAR AVAILED
838	17-Mar-22	TUMKUR	66	TR-2	KADAJI_66	5:24	5:31	0:07	TRANSFORMER FAULT
839	17-Mar-22	TUMKUR	66	TR-2	MALEBENNUR_66	12:13	17:21	5:08	TRANSFORMER FAULT
840	17-Mar-22	TUMKUR	66	TR-2	HOLALKERE_66	13:34	13:49	0:15	TRANSFORMER FAULT
841	17-Mar-22	TUMKUR	66	TR-2	PAVAGADA_66	17:06	17:12	0:05	TRANSFORMER FAULT
842	17-Mar-22	TUMKUR	66	TR-2	PAVAGADA_66	17:55	17:58	0:03	TRANSFORMER FAULT
843	17-Mar-22	TUMKUR	66	TR-2(LV SIDE)	ANCHEPALYA_220	6:15	7:49	1:33	LINE CLEAR AVAILED
844	17-Mar-22	TUMKUR	110	SHETTIKERE- HANDANKERE(C N HALLI)	SHETYKERE_110	14:05	14:20	0:14	LINE CLEAR AVAILED
845	17-Mar-22	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	18:31	18:37	0:05	TRANSFORMER FAULT
846	17-Mar-22	TUMKUR	110	TR-2	SHETYKERE_110	13:09	14:20	1:10	LINE CLEAR AVAILED
847	17-Mar-22	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 2(MAGADI)	ANCHEPALYA_220	12:32	13:26	0:53	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
848	17-Mar-22	TUMKUR	220	ANCHEPALYA 220KV- NELMANGALA-1(NAGAMANGALA 2)	ANCHEPALYA_220	12:32	13:25	0:53	LINE CLEAR AVAILED
849	17-Mar-22	TUMKUR	220	KB CROSS 220KV-ANTHRASANAHALI66	KBCROSS_220	12:14	18:32	6:18	LINE CLEAR AVAILED
850	17-Mar-22	TUMKUR	220	THALLAK 220KV- SEI VENUS DIAMOND IPP 66	SEI VENUS DIAMOND_IPP_66	13:46	16:45	2:59	LINE CLEAR AVAILED
851	17-Mar-22	TUMKUR	220	TR-1	ANCHEPALYA_220	7:51	8:58	1:07	LINE CLEAR AVAILED
852	17-Mar-22	TUMKUR	220	TR-1(HV SIDE)	KBCROSS_220	18:31	18:37	0:05	TRANSFORMER FAULT
853	17-Mar-22	TUMKUR	220	TR-2	ANCHEPALYA_220	6:16	7:48	1:32	LINE CLEAR AVAILED
854	17-Mar-22	TUMKUR	220	TR-2(HV SIDE)	KBCROSS_220	18:31	18:37	0:05	TRANSFORMER FAULT
855	17-Mar-22	TUMKUR	400	GUTTUR 400KV- KAIGA 2 400KV	GUTUR_400	12:08	19:25	7:17	LINE CLEAR AVAILED
856	18-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED UKKALI_110	13:57	14:15	0:18	TRANSFORMER FAULT
857	18-Mar-22	BAGALKOT	110	110/11KV, HV1	KULIGOD_110	19:10 (17.03.2022)	14:34 (18.03.2022)	19:34 hrs	TRANSFORMER CHARGED
858	18-Mar-22	BAGALKOT	110	110/11KV, HV1	SADALAGA_110	16:50	19:20	2:30	LINE CLEAR AVAILED
859	18-Mar-22	BAGALKOT	110	110/11KV,HV1	GADAG_110	8:01	8:26	0:25	TRANSFORMER FAULT
860	18-Mar-22	BAGALKOT	110	110/11KV,HV1	MUDEBIHAL_110	16:35	17:05	0:30	HAND TRIPPED
861	18-Mar-22	BAGALKOT	110	110/11KV,HV2	KULAGERI CROSS_110	20:23	22:29	2:06	TRANSFORMER FAULT
862	18-Mar-22	BAGALKOT	110	110/11KV,HV2	MUKARTHIHAL_110	22:56	23:58	1:02	LINE CLEAR AVAILED
863	18-Mar-22	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	21:53	22:03	0:10	TRANSFORMER FAULT
864	18-Mar-22	BAGALKOT	110	110/11KV,HV4	LAKAMANAHALLI_110	16:38	17:13	0:35	HAND TRIPPED
865	18-Mar-22	BAGALKOT	110	110/33KV, HV2	HALLUR_33 & MASUR_33 STATION NOT AFFECTED RATTIHALI_110	12:20	12:23	0:03	TRANSFORMER FAULT
866	18-Mar-22	BAGALKOT	110	110/33KV, HV3	AMBUJA_33 & SHIGGAON_33 STATION NOT AFFECTED SHIGGAON_110	16:28	16:40	0:12	TRANSFORMER FAULT
867	18-Mar-22	BAGALKOT	110	110/33KV, HV4	HALASANGI_33, NIVERGI_33 & DULAKHED_33 STATION NOT AFFECTED ZALKI_110	13:14	13:19	0:05	TRANSFORMER FAULT
868	18-Mar-22	BAGALKOT	110	110/33KV, HV4	HALASANGI_33, NIVERGI_33 & DULAKHED_33 STATION NOT AFFECTED ZALKI_110	5:54	8:04	2:10	TRANSFORMER FAULT
869	18-Mar-22	BAGALKOT	110	220/110KV,LV4	STATION NOT AFFECTED GADAG_220	13:10 (15.03.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
870	18-Mar-22	BAGALKOT	110	AMBEWADI- NK-2 (KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	16:18 (18.03.2022)			LINE OPEN:LINE FAULT
871	18-Mar-22	BAGALKOT	110	ATHANI220- ATHANI110	ATHANI_220	5:56	8:32	2:36	LINE CLEAR AVAILED
872	18-Mar-22	BAGALKOT	110	ATHANI220- ATHANI110	ATHANI_220	5:56	6:33	0:37	HAND TRIPPED
873	18-Mar-22	BAGALKOT	110	ATHANI220- SATTI	ATHANI_220	5:56	6:26	0:30	MAIN SUPPLY FAILURE
874	18-Mar-22	BAGALKOT	110	BELGAUM220- ANKALAGI	ANKALAGI_110	4:14	4:38	0:25	MAIN SUPPLY FAILURE
875	18-Mar-22	BAGALKOT	110	BELGAUM-HUDLI	HUDLI_110	4:14	4:38	0:24	LINE FAULT
876	18-Mar-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
877	18-Mar-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
878	18-Mar-22	BAGALKOT	110	HATTARGI- HUKKERI	HUKKERI_110	13:15	13:50	0:35	LINE FAULT
879	18-Mar-22	BAGALKOT	110	HATTARGI- HUKKERI	HUKKERI_110	14:50	14:55	0:05	LINE FAULT
880	18-Mar-22	BAGALKOT	110	HUKKERI-HATTARAGI	HATTARAGI_110	13:17	13:53	0:36	HAND TRIPPED
881	18-Mar-22	BAGALKOT	110	HUKKERI-HATTARAGI	HATTARAGI_110	14:49	14:55	0:06	HAND TRIPPED
882	18-Mar-22	BAGALKOT	110	KULIGOD-GAMESH	KULIGOD_110 (STATION NOT AFFECTED)	13:15	14:34	1:19	LINE CLEAR AVAILED
883	18-Mar-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
884	18-Mar-22	BAGALKOT	110	RANEBENNUR- BYADAGI	STATION NOT AFFECTED RANEBENNUR_220	5:30	16:07	10:37	LINE FAULT
885	18-Mar-22	BAGALKOT	110	RANEBENNUR- HIREKERUR	STATION NOT AFFECTED RANEBENNUR_220	13:12	16:07	2:55	LINE CLEAR AVAILED
886	18-Mar-22	BAGALKOT	110	RANEBENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEBENNUR_220	18:42 (14.02.2022)	6:17 (18.03.2022)	755:35 hrs	LINE CHARGED
887	18-Mar-22	BAGALKOT	110	SHIGGAON-AVANTI SOLAR	AVANTI SOLAR_110 STATION NOT AFFECTED SHIGGAON_110	16:27	17:00	0:33	LINE FAULT
888	18-Mar-22	BAGALKOT	110	SIRSI220- UMMACHAGI	STATION NOT AFFECTED SIRSI_220	17:53	19:07	1:14	LINE FAULT
889	18-Mar-22	BAGALKOT	110	SIRSI-ESSALE1 (SIRSI220)	STATION NOT AFFECTED SIRSI_110	18:31 (18.03.2022)			LINE OPEN:LINE CLEAR AVAILED
890	18-Mar-22	BAGALKOT	110	SIRSI-ESSALE2(SIRSI220)	STATION NOT AFFECTED SIRSI_110	17:58 (18.03.2022)			LINE OPEN:LINE FAULT
891	18-Mar-22	BAGALKOT	110	SIRSI-KIRUVATTI	STATION NOT AFFECT KIRUVATTI_110	11:38	19:27	7:49	LINE CLEAR AVAILED
892	18-Mar-22	BAGALKOT	110	SIRSI-KUMATA	KUMATA_110	18:41	18:50	0:09	LINE FAULT
893	18-Mar-22	BAGALKOT	110	UGARKUD-UGAR SUGARS	UGAR SUGARS_110 UGARKHUD_110	5:10	5:32	0:22	HAND TRIPPED
894	18-Mar-22	BAGALKOT	110	YALLAMMANAWADI-AIGALI	YALLAMMANAWADI_110	5:54	6:34	0:40	LINE FAULT
895	18-Mar-22	BAGALKOT	220	220/110KV, LV1	ATHANI_220, ATHANI_110, BALIGERI_110, SATTI_110, HALIYAL_110	5:56	6:26	0:30	TRANSFORMER FAULT
896	18-Mar-22	BAGALKOT	220	220/110KV, HV1&LV1	ATHANI_220, ATHANI_110, BALIGERI_110, SATTI_110, HALIYAL_110	7:11	8:06	0:55	MAIN SUPPLY FAILURE
897	18-Mar-22	BAGALKOT	220	220/110KV, HV2&LV2	ATHANI_220, ATHANI_110, BALIGERI_110, SATTI_110, HALIYAL_110	5:56	6:30	0:34	TRANSFORMER FAULT
898	18-Mar-22	BAGALKOT	220	220/110KV, HV2&LV2	ATHANI_220, ATHANI_110, BALIGERI_110, SATTI_110, HALIYAL_110	7:11	8:06	0:55	MAIN SUPPLY FAILURE
899	18-Mar-22	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	16:05 (08.03.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
900	18-Mar-22	BAGALKOT	220	AMBEWADI- NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	16:20 (18.03.2022)			LINE OPEN:LINE FAULT
901	18-Mar-22	BAGALKOT	220	ATHANI- KUDACHI	ATHANI_220	7:02	9:21	2:19	LINE FAULT
902	18-Mar-22	BAGALKOT	220	ATHANI- MAHALINGAPUR	ATHANI_220	7:11	8:06	0:55	LINE FAULT
903	18-Mar-22	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
904	18-Mar-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
905	18-Mar-22	BAGALKOT	220	BIDNAL-NAGZARI	STATION NOT AFFECTED BIDNAL_220	10:28	14:19	3:51	LINE CLEAR AVAILED
906	18-Mar-22	BAGALKOT	220	CHIKKODI- BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
907	18-Mar-22	BAGALKOT	220	CHIKKODI- BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:43 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
908	18-Mar-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
909	18-Mar-22	BAGALKOT	220	CHIKKODI- KUDACHI1	CHIKKODI_220	5:51	8:46	2:55	LINE FAULT
910	18-Mar-22	BAGALKOT	220	CHIKKODI- KUDACHI2	CHIKKODI_220	5:47	8:32	2:45	LINE FAULT
911	18-Mar-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
912	18-Mar-22	BAGALKOT	220	HUBLI- NAGJHARI	STATION NOT AFFECTED HUBLI_220	17:54	18:41	0:47	LINE FAULT
913	18-Mar-22	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	10:12	17:08	6:56	LINE CLEAR AVAILED
914	18-Mar-22	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTED HUBLI_220	10:12	17:08	6:56	LINE CLEAR AVAILED
915	18-Mar-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	10:13 (12.03.2022)			LINE OPEN:LINE CLEAR AVAILED
916	18-Mar-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	10:14 (12.03.2022)			LINE OPEN:LINE CLEAR AVAILED
917	18-Mar-22	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	6:25	6:48	0:23	LOAD CHANGE OVER
918	18-Mar-22	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	10:04	10:08	0:04	LOAD CHANGE OVER
919	18-Mar-22	BENGALURU	66	AREHALI - SUBRAMANYAPURA 220	AREHALI	1:28	1:52	0:24	LOAD CHANGE OVER
920	18-Mar-22	BENGALURU	66	BANASWADI - ITI 220	BANASWADI	9:07	9:10	0:03	LOAD CHANGE OVER
921	18-Mar-22	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	BG ROAD	22:12	22:25	0:13	LOAD CHANGE OVER
922	18-Mar-22	BENGALURU	66	BRIGADE MEADOWS - SOMANAHALLI 220	BRIGADE MEADOWS	6:30	6:38	0:08	MAIN SUPPLY FAILURE
923	18-Mar-22	BENGALURU	66	BRIGADE MEADOWS - SOMANAHALLI 220	BRIGADE MEADOWS	11:42	11:47	0:05	MAIN SUPPLY FAILURE
924	18-Mar-22	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	5:44	5:50	0:06	LOAD CHANGE OVER
925	18-Mar-22	BENGALURU	66	ELITE PROMENEDE - RBI	ELITE PROMENEDE	12:32	12:43	0:11	LOAD CHANGE OVER
926	18-Mar-22	BENGALURU	66	HBR LAYOUT - DG3	HBR LAYOUT	15:13	15:18	0:05	LOAD CHANGE OVER
927	18-Mar-22	BENGALURU	66	HBR LAYOUT 220 - HBR LAYOUT	HBR LAYOUT	13:15	14:40	1:25	MAIN SUPPLY FAILURE
928	18-Mar-22	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	7:58	9:06	1:08	LINE FAULT
929	18-Mar-22	BENGALURU	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSURU RAMAPURA, NITRALLI	19:23	19:48	0:25	LINE FAULT
930	18-Mar-22	BENGALURU	66	HOSUR RAMAPURA - NITRALLI	NITRALLI	19:23	22:14	2:50	LINE CLEAR AVAILED
931	18-Mar-22	BENGALURU	66	HULLENHALLI - KUDUR	KUDUR	0:20	0:28	0:08	LOAD CURTAILMENT
932	18-Mar-22	BENGALURU	66	HV1	KORMANGALA 66	9:30	9:44	0:14	LOAD CHANGE OVER
933	18-Mar-22	BENGALURU	66	HV1	KENGERI SATELLITE TWON	13:53	14:20	0:27	TRANSFORMER FAULT
934	18-Mar-22	BENGALURU	66	HV2	SOUTH CITY	21:01	21:36	0:35	TRANSFORMER FAULT
935	18-Mar-22	BENGALURU	66	HV2	KORMANGALA 66	9:30	9:44	0:14	LOAD CHANGE OVER
936	18-Mar-22	BENGALURU	66	HV3	NAGANATHPURA 220	10:10	10:18	0:08	TRANSFORMER FAULT
937	18-Mar-22	BENGALURU	66	JAYADEVA - SARAKKI	JAYADEVA	1:11	1:15	0:04	LOAD CHANGE OVER
938	18-Mar-22	BENGALURU	66	JIGANI - SOMANAHALLI 220	JIGANI	22:25	22:31	0:06	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
939	18-Mar-22	BENGALURU	66	JIGANI - SOMANAHALLI 220	JIGANI 66	0:15	1:04	0:49	MAIN SUPPLY FAILURE
940	18-Mar-22	BENGALURU	66	KGF - KAMASAMUDRA	KAMASAMUDRA	17:14	17:39	0:24	LOAD CURTAILMENT
941	18-Mar-22	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NARASAPURA	6:50	7:08	0:18	LINE FAULT
942	18-Mar-22	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NARASAPURA	7:48	7:54	0:06	LINE FAULT
943	18-Mar-22	BENGALURU	66	KONDASPURA - HBR LAYOUT	HBR LAYOUT	13:15	13:31	0:16	MAIN SUPPLY FAILURE
944	18-Mar-22	BENGALURU	66	KORMANGALA 220 - AMARJYOTHI	AMARJYOTHI	9:30	9:44	0:14	LOAD CHANGEOVER
945	18-Mar-22	BENGALURU	66	KORMANGALA 220 - AMARJYOTHI	AMARJYOTHI	1:06	1:34	0:28	LOAD CHANGEOVER
946	18-Mar-22	BENGALURU	66	KORMANGALA 220 - AUSTIN TOWN	AUSTIN TOWN	1:06	1:25	0:19	LOAD CHANGEOVER
947	18-Mar-22	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY	9:30	9:44	0:14	LOAD CHANGEOVER
948	18-Mar-22	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY	1:06	1:34	0:28	LOAD CHANGEOVER
949	18-Mar-22	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	23:00	23:18	0:18	LINE FAULT
950	18-Mar-22	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	17:08	23:33	6:25	LINE CLEAR AVAILED
951	18-Mar-22	BENGALURU	66	NRS 220 - VICTORIA	VICTORIA	14:59	15:01	0:01	LINE CLEAR AVAILED
952	18-Mar-22	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	19:05	19:13	0:08	LOAD CHANGEOVER
953	18-Mar-22	BENGALURU	66	PADMANABHANAGAR - SUBRAMANYAPURA 220	PADMANABHANAGAR	1:01	1:07	0:06	LOAD CHANGEOVER
954	18-Mar-22	BENGALURU	66	RBI - ELITA	RBI	5:32	5:36	0:04	LOAD CHANGEOVER
955	18-Mar-22	BENGALURU	66	RBI - ELITA	RBI	19:17	19:31	0:14	LOAD CHANGEOVER
956	18-Mar-22	BENGALURU	66	SARIJAPURA 220 - CHANDAPURA	CHANDAPURA	7:27	7:34	0:06	LOAD CHANGEOVER
957	18-Mar-22	BENGALURU	66	SHOBHA FOREST VIEW - SOMANAHALLI 220	SHOBHA FOREST VIEW	0:38	1:02	0:23	LOAD CHANGEOVER
958	18-Mar-22	BENGALURU	66	SHOBHA FOREST VIEW - SUBRAMANYAPURA	SHOBHA FOREST VIEW	18:54	18:58	0:04	LOAD CHANGEOVER
959	18-Mar-22	BENGALURU	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	0:49	1:06	0:16	LOAD CHANGEOVER
960	18-Mar-22	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	RBI	0:38	0:58	0:19	LOAD CHANGEOVER
961	18-Mar-22	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	RBI	12:32	12:38	0:06	LOAD CHANGEOVER
962	18-Mar-22	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD	0:38	1:07	0:28	LINE FAULT
963	18-Mar-22	BENGALURU	66	SOMANAHALLI 220 - KANAKAPURA 1	HANUMANTHNAGAR, YEDUMADU	12:15	12:17	0:01	LOAD CHANGEOVER
964	18-Mar-22	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	12:12	12:14	0:02	LOAD CHANGEOVER
965	18-Mar-22	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	0:38	0:58	0:19	LOAD CHANGEOVER
966	18-Mar-22	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	6:20	6:34	0:14	LOAD CHANGEOVER
967	18-Mar-22	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	11:48	11:57	0:09	LOAD CHANGEOVER
968	18-Mar-22	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	5:03	5:05	0:02	LOAD CHANGEOVER
969	18-Mar-22	BENGALURU	66	SOMANAHALLI 220 - VR DODDI	VR DODDI, GURUVINAPURA, BV HALLI	0:38	1:06	0:27	LOAD CHANGEOVER
970	18-Mar-22	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	21:01	21:36	0:35	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
971	18-Mar-22	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, K HONALGERE	8:33	8:44	0:11	MAIN SUPPLY FAILURE
972	18-Mar-22	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, BV HALLI	8:33	8:38	0:05	MAIN SUPPLY FAILURE
973	18-Mar-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR	8:33	8:46	0:13	MAIN SUPPLY FAILURE
974	18-Mar-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	5:38	5:42	0:04	LINE FAULT
975	18-Mar-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	8:51	8:53	0:01	MAIN SUPPLY FAILURE
976	18-Mar-22	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	5:38	5:48	0:09	LINE FAULT
977	18-Mar-22	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	5:42	5:48	0:06	MAIN SUPPLY FAILURE
978	18-Mar-22	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	TK HALLI 220	8:33	8:50	0:17	LINE FAULT
979	18-Mar-22	BENGALURU	66	VR DODDI - SOMANAHALLI 220	VR DODDI, GURUVINAPURA, BV HALLI	7:00	7:02	0:02	MAIN SUPPLY FAILURE
980	18-Mar-22	BENGALURU	66	VR DODDI - TK HALLI 220	VR DODDI, GURUVINAPURA, BV HALLI	15:43	15:46	0:03	MAIN SUPPLY FAILURE
981	18-Mar-22	GULBARGA	66	HALVAGALU-HARVI	HARVI_66	23:35	23:40	0:05	LINE FAULT
982	18-Mar-22	GULBARGA	66	HV1	GUDEKOTE_66	0:10	14:00	13:50	TRANSFORMER FAULT
983	18-Mar-22	GULBARGA	66	HV1	GUDEKOTE_66	16:25	16:50	0:25	TRANSFORMER FAULT
984	18-Mar-22	GULBARGA	66	HV1	ITTAGI_220	13:15	13:45	0:30	LINE CLEAR AVAILED
985	18-Mar-22	GULBARGA	66	HV2	GUDEKOTE_66	5:30	6:20	0:50	LINE CLEAR AVAILED
986	18-Mar-22	GULBARGA	66	HV2	GUDEKOTE_66	11:30	13:40	2:10	LINE CLEAR AVAILED
987	18-Mar-22	GULBARGA	66	HV2	ITTAGI_220	13:10	13:40	0:30	LINE CLEAR AVAILED
988	18-Mar-22	GULBARGA	66	KUDLIGI-GUDEKOTE	KUDLIGI_66,HANSI_66	0:10	0:40	0:30	LINE FAULT
989	18-Mar-22	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	14:28	14:40	0:12	MAIN SUPPLY FAILURE
990	18-Mar-22	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	9:30	9:40	0:10	MAIN SUPPLY FAILURE
991	18-Mar-22	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	14:07	14:17	0:10	MAIN SUPPLY FAILURE
992	18-Mar-22	GULBARGA	110	HV1	JEWARGI_110	11:30	16:36	5:06	LINE CLEAR AVAILED
993	18-Mar-22	GULBARGA	110	HV1	HUNSIGI_110	6:15	6:20	0:05	TRANSFORMER FAULT
994	18-Mar-22	GULBARGA	110	JEWARGI-SHAHABAD	JEWARGI_110	8:30	12:40	4:10	LINE CLEAR AVAILED
995	18-Mar-22	GULBARGA	110	KAPNOOR-GULBARGA WEST2	GULBARGA WEST_110,GULBARGA SOUTH_110	8:45 (15/03/2022)			LINE OPEN:LINE CLEAR AVAILED
996	18-Mar-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSL SUGAR FACTORY, CHOWDAPUR_110	14:08	14:21	0:13	LINE FAULT
997	18-Mar-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110,MANVI_110	2:16	2:26	0:10	LINE FAULT
998	18-Mar-22	GULBARGA	110	MUNIRABAD-KOPPAL	KIRLOSHKAR_IPP,HARE KRISHNA_IPP, STATR METALIC_IPP	12:50	14:25	1:35	LINE CLEAR AVAILED
999	18-Mar-22	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110,SASTHAPUR_110	21:45	21:54	0:09	LINE FAULT
1000	18-Mar-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
1001	18-Mar-22	GULBARGA	110	SHAHABAD-RAICHUR1	NALWAR_110	18:50(17.03.2022)	12:32(18.03.2022)	17:34HRS	LINE CHARGED
1002	18-Mar-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1003	18-Mar-22	GULBARGA	220	HV2	KUSTAGI_220	17:23	18:01	0:38	LINE CLEAR AVAILED
1004	18-Mar-22	GULBARGA	220	LINGASUGUR-SHAHAPUR	LINGASUGUR_220	10:21	17:26	7:05	LINE CLEAR AVAILED
1005	18-Mar-22	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	16:01	16:16	0:15	LINE FAULT
1006	18-Mar-22	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	12:34	14:35	2:01	LINE CLEAR AVAILED
1007	18-Mar-22	HASSAN	66	GANGUR-HASSAN	GANGUR_66	10:16	13:56	3:40	NFBC ISSUED
1008	18-Mar-22	HASSAN	66	HAGARE-HASSAN	HAGARE_66	10:05	13:58	3:53	MAIN SUPPLY FAILURE
1009	18-Mar-22	HASSAN	66	HV1	HALEBEEDU_66	10:11	13:59	3:48	NFBC ISSUED
1010	18-Mar-22	HASSAN	66	HV2	HALEBEEDU_66	10:11	13:59	3:48	NFBC ISSUED
1011	18-Mar-22	HASSAN	66	HV2	HOLALUR_66	16:40	17:29	0:49	TRANSFORMER FAULT
1012	18-Mar-22	HASSAN	66	HV2	TAVARECHATNAHALLY_66	11:57	12:29	0:32	TRANSFORMER FAULT
1013	18-Mar-22	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	12:42	14:57	2:15	LINE CLEAR AVAILED
1014	18-Mar-22	HASSAN	66	MATTA NAV-HIRISAVE	MATTANAVILE_66	19:39	20:02	0:23	LINE FAULT
1015	18-Mar-22	HASSAN	66	MRS SHM-HOLUR	MRS MG_220	10:00	10:04	0:04	LINE FAULT
1016	18-Mar-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1017	18-Mar-22	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	8:00	8:07	0:07	LINE FAULT
1018	18-Mar-22	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	20:11	20:28	0:17	LINE FAULT
1019	18-Mar-22	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	11:07	11:15	0:08	HAND TRIPPED
1020	18-Mar-22	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	18:25	19:14	0:49	HAND TRIPPED
1021	18-Mar-22	HASSAN	110	HV1	TOGARS I_110	23:59(18.03.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
1022	18-Mar-22	HASSAN	110	HV1	ARASIKERE_220	10:38	12:20	1:42	LINE CLEAR AVAILED
1023	18-Mar-22	HASSAN	110	HV1	GURUVAYANAKERE_110	5:56	6:04	0:08	TRANSFORMER FAULT
1024	18-Mar-22	HASSAN	110	HV1	SHIVAPURA_110	11:57	13:42	1:45	LINE CLEAR AVAILED
1025	18-Mar-22	HASSAN	110	HV2	ANAVATTI_110	17:09	19:25	2:16	TRANSFORMER FAULT
1026	18-Mar-22	HASSAN	110	HV2	NERALAKERE_110	10:30	11:23	0:53	LINE CLEAR AVAILED
1027	18-Mar-22	HASSAN	110	HV3	GURUVAYANAKERE_110	5:56	6:04	0:08	TRANSFORMER FAULT
1028	18-Mar-22	HASSAN	110	HV3	HIRIYADKA_110	18:21	18:25	0:04	TRANSFORMER FAULT
1029	18-Mar-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	11:58	12:05	0:07	HAND TRIPPED
1030	18-Mar-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	15:08	15:16	0:08	HAND TRIPPED
1031	18-Mar-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	9:00 (17.03.2022)	13:44(18.03.2022)	28:44HRS	LINE CHARGED
1032	18-Mar-22	MYSURU	66	C R NAGARA-HONGANURU	HONGANURU_66	11:38	11:49	0:11	LINE FAULT
1033	18-Mar-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1034	18-Mar-22	MYSURU	66	HEBBANI-SHIMSHA	HADLI_66 MALAVALLI_66	8:33	8:53	0:20	LINE FAULT
1035	18-Mar-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58(17.03.22)			LINE OPEN:LINE CLEAR AVAILED
1036	18-Mar-22	MYSURU	66	HOOTAGALLI-DATTAGALLI	DATTAGALLY_66	10:35	17:43	7:08	NFBC ISSUED
1037	18-Mar-22	MYSURU	66	HUNSUR-BANNIKUPPE	NO STATIONS EFFECTED	17:35	17:51	0:16	HAND TRIPPED
1038	18-Mar-22	MYSURU	66	HUNSUR-HANAGUDU	NO STATIONS EFFECTED	17:34	17:55	0:20	HAND TRIPPED
1039	18-Mar-22	MYSURU	66	HUNSUR-ILAWALA	NO STATIONS EFFECTED	17:34	17:52	0:17	HAND TRIPPED
1040	18-Mar-22	MYSURU	66	HUNSUR-PERIYAPATNA	NO STATIONS EFFECTED	5:52:42 PM (3/18/2022)			LINE OPEN:LINE CLEAR AVAILED
1041	18-Mar-22	MYSURU	66	HV1	DUNDANAHALLI_66	10:26	19:19	8:53	LINE CLEAR AVAILED
1042	18-Mar-22	MYSURU	66	HV1	AYRALLI_66	1:50	2:05	0:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1043	18-Mar-22	MYSURU	66	HV1	JAIPUR_66	10:57:37 AM (3/17/2022)	4:27:41 PM (3/18/2022)	5:30 hrs	TRANSFORMER CHARGED
1044	18-Mar-22	MYSURU	66	K M DODDI-T K HALLI	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 KADKOTHANAHALLI_66 SOMANAHALLI_66 TUMBEKERE _66 TALAGVADI_66	5:37	5:42	0:05	HAND TRIPPED
1045	18-Mar-22	MYSURU	66	K M DODDI-T K HALLI	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 KADKOTHANAHALLI_66 SOMANAHALLI_66 TUMBEKERE _66 TALAGVADI_66	5:50	6:00	0:10	HAND TRIPPED
1046	18-Mar-22	MYSURU	66	K M DODDI-T K HALLI	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 KADKOTHANAHALLI_66 SOMANAHALLI_66 TUMBEKERE _66 TALAGVADI_66	8:33	8:50	0:17	HAND TRIPPED
1047	18-Mar-22	MYSURU	66	KADAKOLA-SARGUR 1	HAMPAPURA_66 JAYAPURA_66	19:38	19:43	0:05	LINE FAULT
1048	18-Mar-22	MYSURU	66	TUBINAKERE-S R PATNA	NO STATIONS EFFECTED	13:17	14:20	1:03	LINE CLEAR AVAILED
1049	18-Mar-22	MYSURU	66	YELANDURU-HONGANURU	NO STATIONS EFFECTED	11:37	11:49	0:11	LINE FAULT
1050	18-Mar-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	19:16 (14.12.21)			LINE OPEN:LINE CLEAR AVAILED
1051	18-Mar-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	19:16 (14.12.21)			LINE OPEN:LINE CLEAR AVAILED
1052	18-Mar-22	MYSURU	220	HOOTAGALLI-HV3	HUNSUR_66 ELAVALA_66 HOSURGATE_66 HANAGODU_66 BANNIKUPPE_66	16:28	17:32	1:04	LINE FAULT
1053	18-Mar-22	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	9:53	10:50	0:57	MAIN SUPPLY FAILURE
1054	18-Mar-22	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:51	11:15	0:24	MAIN SUPPLY FAILURE
1055	18-Mar-22	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:05	15:15	0:10	MAIN SUPPLY FAILURE
1056	18-Mar-22	TUMKUR	66	JAVAGONDANAHALLI- HIRIYUR220	JAVAGONDANAHALLI_66	14:32	18:12	3:40	MAIN SUPPLY FAILURE
1057	18-Mar-22	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	15:35	19:22	3:47	LINE CLEAR AVAILED
1058	18-Mar-22	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	9:50	10:00	0:10	MAIN SUPPLY FAILURE
1059	18-Mar-22	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	14:30	14:40	0:10	MAIN SUPPLY FAILURE
1060	18-Mar-22	TUMKUR	66	LINGADAHALLI- SHYLAPURA	LINGADAHALLY_66	18:55	23:43	4:47	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1061	18-Mar-22	TUMKUR	66	LOKIKERE66-KUKWADA66(CHYAGALE)	LOKIKERE_66	9:50	10:00	0:10	LINE FAULT
1062	18-Mar-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	14:58	15:06	0:08	LINE FAULT
1063	18-Mar-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	18:21	18:29	0:08	LINE FAULT
1064	18-Mar-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	18:32	18:38	0:06	LINE FAULT
1065	18-Mar-22	TUMKUR	66	PAVAGADA220-MEDEGESHI66	MEDIGESHI_66,I D HALLI_66,HOSKERE_66	4:00	4:10	0:09	LINE FAULT
1066	18-Mar-22	TUMKUR	66	PAVAGADA220-PAVAGADA1	PAVAGADA_220	4:00	4:18	0:17	LINE FAULT
1067	18-Mar-22	TUMKUR	66	PAVAGADA220-SHYLAPURA66	SHYLAPURA_66	4:00	4:16	0:15	LINE FAULT
1068	18-Mar-22	TUMKUR	66	PAVAGADA220-SHYLAPURA66	SHYLAPURA_66	17:33	17:44	0:11	LINE FAULT
1069	18-Mar-22	TUMKUR	66	PAVAGADA220-SHYLAPURA66	SHYLAPURA_66	18:08	18:26	0:17	LINE FAULT
1070	18-Mar-22	TUMKUR	66	PAVAGADA66-YNKOSKOTE	Y N HOSKOTE_66	4:00	4:17	0:16	LINE FAULT
1071	18-Mar-22	TUMKUR	66	SIRA220- L2 SIRA66	SIRA_66	10:27	10:40	0:12	LINE CLEAR AVAILED
1072	18-Mar-22	TUMKUR	66	SIRA220-KALLAMBELLA66	KALLAMBELLA_66	10:28	10:44	0:15	LINE CLEAR AVAILED
1073	18-Mar-22	TUMKUR	66	SIRA220-L9 TAVAREKERE66	TAVAREKERE_66	16:00	16:09	0:08	LINE CLEAR AVAILED
1074	18-Mar-22	TUMKUR	66	SIRA220-SIRA66	SIRA_66	10:29	10:42	0:12	LINE CLEAR AVAILED
1075	18-Mar-22	TUMKUR	66	TR-1	TURUVANUR_66	10:53	15:44	4:51	LINE CLEAR AVAILED
1076	18-Mar-22	TUMKUR	66	TR-1	CHANNAGIRI_66	12:18	13:51	1:33	LINE CLEAR AVAILED
1077	18-Mar-22	TUMKUR	66	TR-1	PANDRAHALLI_66	14:28	14:52	0:23	LINE CLEAR AVAILED
1078	18-Mar-22	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	4:05	4:20	0:15	TRANSFORMER FAULT
1079	18-Mar-22	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	17:42	17:44	0:01	TRANSFORMER FAULT
1080	18-Mar-22	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	18:17	18:22	0:04	TRANSFORMER FAULT
1081	18-Mar-22	TUMKUR	66	TR-2	KADAJJI_66	6:05	6:10	0:05	TRANSFORMER FAULT
1082	18-Mar-22	TUMKUR	66	TR-2(LV SIDE)	SIRA_220	10:27	10:40	0:12	TRANSFORMER FAULT
1083	18-Mar-22	TUMKUR	66	TR-2(LV SIDE)	PAVAGADA_220	4:05	4:20	0:15	TRANSFORMER FAULT
1084	18-Mar-22	TUMKUR	66	TR-2(LV SIDE)	PAVAGADA_220	17:42	17:44	0:01	TRANSFORMER FAULT
1085	18-Mar-22	TUMKUR	66	TR-2(LV SIDE)	PAVAGADA_220	18:17	18:22	0:04	TRANSFORMER FAULT
1086	18-Mar-22	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL_110	12:30	12:48	0:18	LINE CLEAR AVAILED
1087	18-Mar-22	TUMKUR	110	HONNAVALI 110- KADUR110	HONNAVALI_110	7:41	12:20	4:38	LINE CLEAR AVAILED
1088	18-Mar-22	TUMKUR	110	HONNAVALI 110-DMKURKE	DMKURKE_110	7:41	12:20	4:38	LINE CLEAR AVAILED
1089	18-Mar-22	TUMKUR	110	HONNAVALI 110-TIPTUR	HONNAVALI_110	7:15	12:45	5:30	LINE FAULT
1090	18-Mar-22	TUMKUR	110	TR-1	HONNAVALI_110	7:41	12:20	4:38	LINE CLEAR AVAILED
1091	18-Mar-22	TUMKUR	220	KB CROSS 220KV-ANTHRASANAHALLI66	KBCROSS_220	11:14	19:49	8:35	LINE CLEAR AVAILED
1092	18-Mar-22	TUMKUR	220	TR-1(HV SIDE)	PAVAGADA_220	4:05	4:20	0:15	TRANSFORMER FAULT
1093	18-Mar-22	TUMKUR	220	TR-1(HV SIDE)	PAVAGADA_220	17:42	17:44	0:01	TRANSFORMER FAULT
1094	18-Mar-22	TUMKUR	220	TR-1(HV SIDE)	PAVAGADA_220	18:17	18:22	0:04	TRANSFORMER FAULT
1095	18-Mar-22	TUMKUR	220	TR-2(HV SIDE)	SIRA_220	10:27	10:39	0:11	TRANSFORMER FAULT
1096	18-Mar-22	TUMKUR	220	TR-2(HV SIDE)	PAVAGADA_220	4:05	4:20	0:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1097	18-Mar-22	TUMKUR	220	TR-2(HV SIDE)	PAVAGADA_220	17:42	17:44	0:01	TRANSFORMER FAULT
1098	18-Mar-22	TUMKUR	220	TR-2(HV SIDE)	PAVAGADA_220	18:17	18:22	0:04	TRANSFORMER FAULT
1099	19-Mar-22	BAGALKOT	110	110/11KV, HV1	ATHANI_220	10:37	14:14	3:37	LINE CLEAR AVAILED
1100	19-Mar-22	BAGALKOT	110	110/11KV, HV1	GANESH GUDI_110	11:31	11:50	0:19	HAND TRIPPED
1101	19-Mar-22	BAGALKOT	110	110/11KV, HV1	STATIO NOT AFFECTED LAKAMANAHALLI_110	21:02	23:01	1:59	TRANSFORMER FAULT
1102	19-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUKARTIHAL_110	22:55 (18.03.2022)	0:28 (19.03.2022)	1:33 hrs	TRANSFORMER CHARGED
1103	19-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED RANNABELAGALI_110	16:32	19:10	2:38	LINE CLEAR AVAILED
1104	19-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED RON_110	19:37	20:40	1:03	TRANSFORMER FAULT
1105	19-Mar-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	14:05	14:21	0:16	HAND TRIPPED
1106	19-Mar-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	19:02	19:04	0:02	TRANSFORMER FAULT
1107	19-Mar-22	BAGALKOT	110	110/11KV,HV2	KUD DHARAWD_110	14:45	15:34	0:49	LINE CLEAR AVAILED
1108	19-Mar-22	BAGALKOT	110	110/11KV,HV4	BELGAUM_110	19:47(19.03.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
1109	19-Mar-22	BAGALKOT	110	110/1KV,HV3	HIREKERUR_110	12:31	16:30	3:59	LINE CLEAR AVAILED
1110	19-Mar-22	BAGALKOT	110	110/33KV, HV4	HALASANGI_33, DULAKHED_33 NERVARGI_33 STATION NOT AFFECTED ZALKI_110	7:19	7:22	0:03	TRANSFORMER FAULT
1111	19-Mar-22	BAGALKOT	110	220/110KV, LV4	STATION NOT AFFECTED GADAG_220	13:10 (15.03.2022)	18:18 (19.03.2022)	101:08 hrs	TRANSFORMER CHARGED
1112	19-Mar-22	BAGALKOT	110	AMBEWADI- NK-2 (KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	16:18 (18.03.2022)	17:36 (19.03.2022)	25:18 hrs	LINE CHARGED
1113	19-Mar-22	BAGALKOT	110	BADAMI-KERUR	KERUR_110	18:52	19:21	0:29	LINE FAULT
1114	19-Mar-22	BAGALKOT	110	BELLATTI-ENERCON2	BELLATTI_110 ,(STATION NOT AFFECTED)	21:40 (19.03.2022)			LINE OPEN:LINE FAULT
1115	19-Mar-22	BAGALKOT	110	CHIKKODI 220-CHIKKODI 110	CHIKKODI_110	17:02	22:50	5:48	LINE FAULT
1116	19-Mar-22	BAGALKOT	110	CHIKKODI220- CHIKKODI	CHIKKODI_220	17:03	19:35	2:32	LINE FAULT
1117	19-Mar-22	BAGALKOT	110	CHIKKODI220- CHIKKODI	CHIKKODI_220	19:35	22:20	2:45	LINE CLEAR AVAILED
1118	19-Mar-22	BAGALKOT	110	CHIKKODI220- CHIKKODI	CHIKKODI_220	22:22	22:50	0:28	LINE FAULT
1119	19-Mar-22	BAGALKOT	110	CHIKKODI220- CHIKKODI	CHIKKODI_220	23:54 (19.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1120	19-Mar-22	BAGALKOT	110	CHIKKODI220- RAIBAG	CHIKKODI_220	11:12	14:20	3:08	LINE CLEAR AVAILED
1121	19-Mar-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1122	19-Mar-22	BAGALKOT	110	GADAG220-GADAG1(GADAG)	GADAG_110	9:49	10:51	1:02	LINE CLEAR AVAILED
1123	19-Mar-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
1124	19-Mar-22	BAGALKOT	110	KONNUR-KERUR	KERUR_110	18:52	18:56	0:04	HAND TRIPPED
1125	19-Mar-22	BAGALKOT	110	KULIGOD-GAMESH IPP	GAMESH IPP_110 KULIGOD_110	18:00	18:34	0:34	LINE CLEAR AVAILED
1126	19-Mar-22	BAGALKOT	110	KULIGOD-MUGALKHOD220	KULIGOD_110	18:00	18:34	0:34	LINE CLEAR AVAILED
1127	19-Mar-22	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	RANNABELAGALI_110	17:16	17:45	0:29	LINE FAULT
1128	19-Mar-22	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	STATION NOT AFFECTED MAHALINGAPUR_220	17:45	18:55	1:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1129	19-Mar-22	BAGALKOT	110	MAMADAPUR-BABALESHWAR	BABALESHWAR_110	15:26	21:09	5:43	LINE FAULT
1130	19-Mar-22	BAGALKOT	110	MAMADAPUR-BABALESHWAR	BABALESHWAR_110	16:43	17:02	0:19	LINE FAULT
1131	19-Mar-22	BAGALKOT	110	MUGALKHOD-(LN1)RAIBAG1	STATION NOT AFFECTED MUGALKHOD_220	11:03	14:05	3:02	LINE CLEAR AVAILED
1132	19-Mar-22	BAGALKOT	110	NAGANUR-MUDALAGI	MUDALAGI_110	17:23	18:01	0:38	LINE FAULT
1133	19-Mar-22	BAGALKOT	110	NARAGUND-BPCL IPP	BPCL IPP_110 STATION NOT AFFECTED NARAGUND_110	12:04	13:00	0:56	LINE CLEAR AVAILED
1134	19-Mar-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1135	19-Mar-22	BAGALKOT	110	RANNABELAGALI-MAHALINGAPUR220	RANNABELAGALI_110	17:49	19:10	1:21	LINE CLEAR AVAILED
1136	19-Mar-22	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	19:37	19:39	0:02	HAND TRIPPED
1137	19-Mar-22	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	19:37	19:39	0:02	HAND TRIPPED
1138	19-Mar-22	BAGALKOT	110	RON-GAMESH IPP	GAMESH IPP_110 STATION NOT AFFECTED RON_110	19:37	19:46	0:09	HAND TRIPPED
1139	19-Mar-22	BAGALKOT	110	SIRSI-ESSALE1 (SIRSI220)	STATION NOT AFFECTED SIRSI_110	18:31 (18.03.2022)	10:00 (19.03.2022)	15:29 hrs	LINE CHARGED
1140	19-Mar-22	BAGALKOT	110	SIRSI-ESSALE2 (SIRSI220)	STATION NOT AFFECTED SIRSI_110	17:58 (18.03.2022)	10:10 (19.03.2022)	16:12 hrs	LINE CHARGED
1141	19-Mar-22	BAGALKOT	220	220/110KV, HV2,LV2	MAHALINGAPUR_220	17:16	17:39	0:23	TRANSFORMER FAULT
1142	19-Mar-22	BAGALKOT	220	220/110KV, HV2,LV2	MAHALINGAPUR_220	17:42	17:48	0:06	TRANSFORMER FAULT
1143	19-Mar-22	BAGALKOT	220	220/110KV, HV3	CHIKKODI_220	17:31	17:45	0:14	TRANSFORMER FAULT
1144	19-Mar-22	BAGALKOT	220	220/110KV, HV3	HUBLI_220	10:11	18:02	7:51	LINE CLEAR AVAILED
1145	19-Mar-22	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	16:05 (08.03.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1146	19-Mar-22	BAGALKOT	220	AMBEWADI- NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	16:20 (18.03.2022)	12:22 (19.03.2022)	20:02 hrs	LINE CHARGED
1147	19-Mar-22	BAGALKOT	220	BAGALKOT - KOPPAL LIS	STATION NOT AFFECTED BAGALKOT_220	19:28	21:15	1:47	LINE FAULT
1148	19-Mar-22	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI-RBRK	17:13	17:23	0:10	LINE FAULT
1149	19-Mar-22	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1150	19-Mar-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1151	19-Mar-22	BAGALKOT	220	CHIKKODI- BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1152	19-Mar-22	BAGALKOT	220	CHIKKODI- BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:43 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1153	19-Mar-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
1154	19-Mar-22	BAGALKOT	220	CHIKKODI- KOLHAPUR1(TALANDAGI)	STATION NOT AFFECTED CHIKKODI_220	23:18 (19.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1155	19-Mar-22	BAGALKOT	220	CHIKKODI- MUGALKHOD1	CHIKKODI_220	17:23	18:17	0:54	LINE FAULT
1156	19-Mar-22	BAGALKOT	220	CHIKKODI- MUGALKHOD2	CHIKKODI_220	17:31	18:24	0:53	LINE FAULT
1157	19-Mar-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1158	19-Mar-22	BAGALKOT	220	HUBLI- SIRSI1	STATION NOT AFFECTED HUBLI_220	16:47 (18.03.2022)	18:48 (19.03.2022)	26:01 hrs	LINE CHARGED
1159	19-Mar-22	BAGALKOT	220	MUGALKHOD-CHIKKODI2	STATION NOT AFFECTED MUGALKHOD_220	17:31	18:24	0:53	LINE FAULT
1160	19-Mar-22	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	10:49	15:37	4:48	LINE CLEAR AVAILED
1161	19-Mar-22	BAGALKOT	220	NARENDRA -BELUR1	STATION NOT AFFECTED NARENDRA_220	10:15	18:17	8:02	LINE CLEAR AVAILED
1162	19-Mar-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	10:13 (12.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1163	19-Mar-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	10:14 (12.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1164	19-Mar-22	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR	20:18	20:25	0:07	LOAD CHANGEOVER
1165	19-Mar-22	BENGALURU	66	BANGARPETE - MALUR 220	BANGARPETE	15:25	15:45	0:20	LINE CLEAR AVAILED
1166	19-Mar-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	7:17	7:27	0:10	LINE FAULT
1167	19-Mar-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	13:05	13:10	0:05	LINE FAULT
1168	19-Mar-22	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	18:49	19:03	0:14	LINE FAULT
1169	19-Mar-22	BENGALURU	66	HEBBAL 220 - C STATION 1	C STATION	12:49	13:09	0:20	LINE CLEAR AVAILED
1170	19-Mar-22	BENGALURU	66	HEBBAL 220 - C STATION 2	C STATION	12:49	13:09	0:20	LINE CLEAR AVAILED
1171	19-Mar-22	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	12:49	12:57	0:08	LINE CLEAR AVAILED
1172	19-Mar-22	BENGALURU	66	HEBBAL 220 - LR BANDE	NO STATION AFFECTED	18:56	19:42	0:46	LINE FAULT
1173	19-Mar-22	BENGALURU	66	HV1	ANEKAL	11:53	12:00	0:06	LINE CLEAR AVAILED
1174	19-Mar-22	BENGALURU	66	HV1	BANASAWADI	12:49	12:57	0:08	LOAD CHANGEOVER
1175	19-Mar-22	BENGALURU	66	HV1	BANASAWADI	13:15	13:18	0:03	LOAD CHANGEOVER
1176	19-Mar-22	BENGALURU	66	HV1	DABUSPET 220	13:09	13:17	0:08	LINE CLEAR AVAILED
1177	19-Mar-22	BENGALURU	66	HV1	DODDABELAVANGALA	7:09	7:20	0:10	TRANSFORMER FAULT
1178	19-Mar-22	BENGALURU	66	HV1	HOODY 220	11:36	11:42	0:06	LOAD CHANGEOVER
1179	19-Mar-22	BENGALURU	66	HV1	KUNDANA	15:39	15:45	0:05	LINE CLEAR AVAILED
1180	19-Mar-22	BENGALURU	66	HV1	MELUR	11:59	12:05	0:05	LINE CLEAR AVAILED
1181	19-Mar-22	BENGALURU	66	HV1	N G HULKUR	17:39	18:00	0:21	LINE CLEAR AVAILED
1182	19-Mar-22	BENGALURU	66	HV2	CHATRA	13:26	13:40	0:14	LINE CLEAR AVAILED
1183	19-Mar-22	BENGALURU	66	HV2	HSR LAYOUT 220	10:40	11:10	0:30	TRANSFORMER FAULT
1184	19-Mar-22	BENGALURU	66	HV2	VICTORIA	4:05	4:40	0:35	TRANSFORMER FAULT
1185	19-Mar-22	BENGALURU	66	HV2	YELAHANKA 220	9:59	11:59	1:59	TRANSFORMER FAULT
1186	19-Mar-22	BENGALURU	66	HV3	BANASAWADI	12:49	12:57	0:08	LOAD CHANGEOVER
1187	19-Mar-22	BENGALURU	66	HV3	BANASAWADI	13:15	13:18	0:03	LOAD CHANGEOVER
1188	19-Mar-22	BENGALURU	66	IIsc - HEBBALA 220	IIsc	12:49	12:59	0:10	MAIN SUPPLY FAILURE
1189	19-Mar-22	BENGALURU	66	IIsc - NRS 220	IIsc	14:30	14:34	0:04	LOAD CHANGEOVER
1190	19-Mar-22	BENGALURU	66	JAGANI 220 - JIGANI 66	JIGANI 66	19:41	20:31	0:50	MAIN SUPPLY FAILURE
1191	19-Mar-22	BENGALURU	66	JAGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGANODDI	19:41	20:31	0:50	MAIN SUPPLY FAILURE
1192	19-Mar-22	BENGALURU	66	JIGANI 66 - JIGANI LINK ROAD	JIGANI LINK ROAD, KIRLOSKAR (EHT)	19:41	20:01	0:20	MAIN SUPPLY FAILURE
1193	19-Mar-22	BENGALURU	66	JIGANI LINK ROAD - KIRLOSKAR (EHT)	KIRLOSKAR (EHT)	21:25(19-3-2022)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1194	19-Mar-22	BENGALURU	66	KADUBISANAHALLI - HSR LAYOUT 220	KADUBISANAHALLI	17:08	17:30	0:22	LINE CLEAR AVAILED
1195	19-Mar-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALALLI	4:40	4:50	0:10	LINE FAULT
1196	19-Mar-22	BENGALURU	66	KGF - MALUR 220	KGF, BEML(EHT), KAMASAMUDRA	13:20	13:45	0:25	LOAD CHANGEOVER
1197	19-Mar-22	BENGALURU	66	KOLAR 220 - MULBAGAL	NO STATION AFFECTED	6:53	7:14	0:21	LINE FAULT
1198	19-Mar-22	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	17:43	18:04	0:21	LINE FAULT
1199	19-Mar-22	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), KGF, KAMASAMUDRA	12:49	12:55	0:06	LINE FAULT
1200	19-Mar-22	BENGALURU	66	MELUR - VIJAYPURA	MELUR	17:45	17:55	0:10	LOAD CHANGEOVER
1201	19-Mar-22	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	18:50	19:07	0:17	LOAD CHANGEOVER
1202	19-Mar-22	BENGALURU	66	NIMHANS 220 - BMTC	BMTC	18:48	18:52	0:04	LINE FAULT
1203	19-Mar-22	BENGALURU	66	SHOBHA FOREST - SOMANAHALLI 220	SHOBHA FOREST	10:08	15:12	5:04	LINE CLEAR AVAILED
1204	19-Mar-22	BENGALURU	66	SIDLAGHATTA - CHINTAMANI 220	SIDLAGHATTA	15:35	17:20	1:45	LINE CLEAR AVAILED
1205	19-Mar-22	BENGALURU	66	SIDLAGHATTA - MELUR	MELUR	15:35	16:00	0:25	LINE CLEAR AVAILED
1206	19-Mar-22	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, BIEC	18:42	19:40	0:58	LINE FAULT
1207	19-Mar-22	BENGALURU	66	SRS PEENYA 220 - NRS 1	NANDINI LAYOUT	18:50	19:07	0:17	LINE FAULT
1208	19-Mar-22	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	8:11	8:20	0:09	LOAD CHANGEOVER
1209	19-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML	4:25	5:35	1:10	LINE FAULT
1210	19-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 2	NO STATION AFFECTED	8:55	13:30	4:35	LINE CLEAR AVAILED
1211	19-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	13:14	14:15	1:01	LINE FAULT
1212	19-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	14:30	15:28	0:58	LINE FAULT
1213	19-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:28	16:25	0:57	LINE FAULT
1214	19-Mar-22	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	16:42	16:58	0:16	LINE CLEAR AVAILED
1215	19-Mar-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR, K HONALGERE, YATHAMBADI	16:42	17:05	0:23	LINE CLEAR AVAILED
1216	19-Mar-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	16:42	16:58	0:16	LINE CLEAR AVAILED
1217	19-Mar-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	16:42	16:58	0:16	LINE CLEAR AVAILED
1218	19-Mar-22	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTURU	GUNDLU KOTTURU	6:02	6:30	0:27	LINE FAULT
1219	19-Mar-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	12:56	17:20	4:24	LINE FAULT
1220	19-Mar-22	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	13:52	18:19	4:27	LOAD CURTAILMENT
1221	19-Mar-22	BENGALURU	220	HEBBALA 220 - CPRI(EHT)	CPRI(EHT)	12:49	13:13	0:24	LINE CLEAR AVAILED
1222	19-Mar-22	BENGALURU	220	HEBBALA 220 - MANYATHA TECH PARK 220	HEBBALA 220	12:49	13:04	0:15	MAIN SUPPLY FAILURE
1223	19-Mar-22	BENGALURU	220	HV1	HEBBALA 220	12:49	13:10	0:21	LINE CLEAR AVAILED
1224	19-Mar-22	BENGALURU	220	HV1	JIGANI 220	19:41	20:25	0:44	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1225	19-Mar-22	BENGALURU	220	HV1	TK HALLI 220	16:42	16:51	0:09	LINE CLEAR AVAILED
1226	19-Mar-22	BENGALURU	220	HV1	YARANDANAHALLI 220	12:56	14:06	1:10	TRANSFORMER FAULT
1227	19-Mar-22	BENGALURU	220	HV2	HEBBALA 220	12:49	13:10	0:21	LINE CLEAR AVAILED
1228	19-Mar-22	BENGALURU	220	HV2	JIGANI 220	19:41	20:31	0:50	MAIN SUPPLY FAILURE
1229	19-Mar-22	BENGALURU	220	HV2	TK HALLI 220	16:42	16:51	0:09	LINE CLEAR AVAILED
1230	19-Mar-22	BENGALURU	220	HV3	HEBBALA 220	12:49	13:10	0:21	LINE CLEAR AVAILED
1231	19-Mar-22	BENGALURU	220	JIGANI 220 - MYLASANDRA 400	JIGANI 220	19:41	20:20	0:39	LINE FAULT
1232	19-Mar-22	BENGALURU	220	MANYATHA TECH PARK 220 - HEBBALA 220	HEBBALA 220	12:49	13:03	0:14	LINE FAULT
1233	19-Mar-22	BENGALURU	220	TK HALLI 220 - VAJAMANGALA 220	TK HALLI 220	16:42	16:50	0:08	MAIN SUPPLY FAILURE
1234	19-Mar-22	GULBARGA	66	HARAPANAHALLI-NEELAGUNDA	HARAPANAHALLI_66,HARVI_66	13:10	13:50	0:40	LINE CLEAR AVAILED
1235	19-Mar-22	GULBARGA	66	NEELGUNDA-TELADI	TELADI_66, KURUBANAHALLI_66,YEREGUNTA_66	1:20	1:31	0:11	LINE FAULT
1236	19-Mar-22	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	14:23	14:30	0:07	LINE FAULT
1237	19-Mar-22	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	15:12	15:33	0:21	MAIN SUPPLY FAILURE
1238	19-Mar-22	GULBARGA	110	HALBARGA-CHIDRI1(KAMTHANA)	CHIDRI_1_110, HABSİKOTE_110	16:59	17:04	0:05	LINE FAULT
1239	19-Mar-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110, KADAGANCHI_110	11:59	14:15	2:16	LINE FAULT
1240	19-Mar-22	GULBARGA	110	HV1	MATAMARI_110	20:05	20:15	0:10	TRANSFORMER FAULT
1241	19-Mar-22	GULBARGA	110	HV1	MATAMARI_110	20:05	20:15	0:10	TRANSFORMER FAULT
1242	19-Mar-22	GULBARGA	110	JAWALGERA-SINDHNOOR	JAWALGERA_110	20:55	21:00	0:05	MAIN SUPPLY FAILURE
1243	19-Mar-22	GULBARGA	110	JAWALGERA-SINDHNOOR	JAWALGERA_110	9:00	12:40	3:40	LINE CLEAR AVAILED
1244	19-Mar-22	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	14:13	14:20	0:07	LINE FAULT
1245	19-Mar-22	GULBARGA	110	KAPNOOR-GULBARGA WEST2	GULBARGA WEST_110,GULBARGA SOUTH_110	8:45 (15/03/2022)			LINE OPEN:LINE CLEAR AVAILED
1246	19-Mar-22	GULBARGA	110	KAPNOOR-GULBARGA WEST2	GULBARGA WEST_110,GULBARGA SOUTH_110	8:45 (15/03/2022)	14:10(20.03.2022)	125:25HRS	LINE CHARGED
1247	19-Mar-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPURA_110, NSL SUGARS FACTORY	9:16	9:25	0:09	LINE FAULT
1248	19-Mar-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPURA_110, NSL SUGARS FACTORY	15:13	15:33	0:20	LINE FAULT
1249	19-Mar-22	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAR_110,HIREGONNAGAR_110,HANUMANAL_110	18:45	19:42	0:57	LINE FAULT
1250	19-Mar-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	20:52	21:03	0:11	LINE FAULT
1251	19-Mar-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	10:23	10:33	0:10	LINE FAULT
1252	19-Mar-22	GULBARGA	110	MANGALORE-BEVOOR	MANGALORE_110	16:20	17:20	1:00	MAIN SUPPLY FAILURE
1253	19-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	16:18	17:00	0:42	LINE FAULT
1254	19-Mar-22	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DE VANGAON_110,RENUKA_IPP,AFZAL PUR_110,KARAJAGI_110	16:02	16:15	0:13	LOAD CURTAILMENT
1255	19-Mar-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	16:04	16:16	0:12	LOAD CURTAILMENT
1256	19-Mar-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1257	19-Mar-22	GULBARGA	110	SINDHANOOR-ADVIAMARESHWARA	JAVLAGERA_110,ADAVIAMARESHWARA_110	8:45	13:20	4:35	LINE CLEAR AVAILED
1258	19-Mar-22	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	22:14	22:24	0:10	LINE FAULT
1259	19-Mar-22	GULBARGA	110	TAWARGER-KUSHTAGI	TAWARGER_110	16:20	17:26	1:06	MAIN SUPPLY FAILURE
1260	19-Mar-22	GULBARGA	110	YAKATPUR-KAMTHANA	YAKATPUR_110	17:00	17:05	0:05	MAIN SUPPLY FAILURE
1261	19-Mar-22	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110,KUKUNOOR_110,VARABANDI_110	16:19	17:17	0:58	MAIN SUPPLY FAILURE
1262	19-Mar-22	GULBARGA	110	YELBURGA-PARAM POOJYA IPP	YELBURGA_110	19:17	19:46	0:29	LINE FAULT
1263	19-Mar-22	GULBARGA	220	HV1	KUSTAGI_220	16:20	17:17	0:57	TRANSFORMER FAULT
1264	19-Mar-22	GULBARGA	220	HV1	SHAHBAD_220	10:05(19.03.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1265	19-Mar-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1266	19-Mar-22	GULBARGA	220	HV2	KUSTAGI_220	16:20	17:45	1:25	LINE CLEAR AVAILED
1267	19-Mar-22	GULBARGA	220	HV2	RAICHUR_220	13:05	14:31	1:26	LINE CLEAR AVAILED
1268	19-Mar-22	GULBARGA	220	ITTAGI-BMM ISPAT	ITTAGI_220	10:00	18:50	8:50	LINE CLEAR AVAILED
1269	19-Mar-22	GULBARGA	220	JSWL-BPS1	BPS_400	17:40	20:48	3:08	LINE FAULT
1270	19-Mar-22	GULBARGA	220	JSWL-BPS2	BPS_400	17:40	20:48	3:08	LINE FAULT
1271	19-Mar-22	GULBARGA	220	KUSTAGI-SULEKAL	KUSTAGI_220	16:18	20:52	4:34	LINE FAULT
1272	19-Mar-22	GULBARGA	220	KUSTAGI-SULEKAL	KUSTAGI_220	20:52	23:59	3:07	LINE FAULT
1273	19-Mar-22	GULBARGA	220	KUSTATGI-LINGASUGUR	LINGASUGUR_220	15:19	17:13	1:54	LINE FAULT
1274	19-Mar-22	GULBARGA	220	SHAHABAD-KAPNOOR	KAPNOOR_22	15:58	16:08	0:10	LINE FAULT
1275	19-Mar-22	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	15:58	16:05	0:07	LINE FAULT
1276	19-Mar-22	GULBARGA	400	RTPS-MEHOBUBNAGAR	MEHOBUBNAGAR_400	10:17	17:50	7:33	LINE CLEAR AVAILED
1277	19-Mar-22	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	17:30	18:05	0:35	MAIN SUPPLY FAILURE
1278	19-Mar-22	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_220	17:31	17:56	0:25	MAIN SUPPLY FAILURE
1279	19-Mar-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_220	17:30	17:51	0:21	MAIN SUPPLY FAILURE
1280	19-Mar-22	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_220	17:30	17:51	0:21	MAIN SUPPLY FAILURE
1281	19-Mar-22	HASSAN	66	CRPATNA-CRPTNA1	CHANNARAYAPATNA_66	17:30	17:43	0:13	LINE FAULT
1282	19-Mar-22	HASSAN	66	CRPATNA-CRPTNA2	CHANNARAYAPATNA_66	17:30	17:49	0:19	LINE FAULT
1283	19-Mar-22	HASSAN	66	DIDIGA-CRPATNA	DIDIGA_66	9:48	10:09	0:21	LINE FAULT
1284	19-Mar-22	HASSAN	66	DIDIGA-CRPATNA	DIDIGA_66	11:31	14:05	2:34	LINE FAULT
1285	19-Mar-22	HASSAN	66	HV1	MALLIPATNA_66	14:37	14:46	0:09	TRANSFORMER FAULT
1286	19-Mar-22	HASSAN	66	HV1	MOSALEHOSHALLY_66	10:14	10:28	0:14	HAND TRIPPED
1287	19-Mar-22	HASSAN	66	HV1	MOSALEHOSHALLY_66	11:54	11:58	0:04	HAND TRIPPED
1288	19-Mar-22	HASSAN	66	HV1	RAMESHWARNAGARA_66	10:00	15:38	5:38	LINE CLEAR AVAILED
1289	19-Mar-22	HASSAN	66	HV1	RAMESHWARNAGARA_66	16:17	16:42	0:25	LINE CLEAR AVAILED
1290	19-Mar-22	HASSAN	66	HV2	DIDIGA_66	9:48	10:09	0:21	TRANSFORMER FAULT
1291	19-Mar-22	HASSAN	66	HV2	DIDIGA_66	11:31	14:05	2:34	TRANSFORMER FAULT
1292	19-Mar-22	HASSAN	66	HV2	RAMESHWARNAGARA_66	12:56	14:37	1:41	LINE CLEAR AVAILED
1293	19-Mar-22	HASSAN	66	HV2	RAMESHWARNAGARA_66	16:17	17:11	0:54	LINE CLEAR AVAILED
1294	19-Mar-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE FAULT
1295	19-Mar-22	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	17:53	17:58	0:05	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1296	19-Mar-22	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	17:53	17:58	0:05	HAND TRIPPED
1297	19-Mar-22	HASSAN	110	HV1	TOGARSI_110	23:59(18.03.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
1298	19-Mar-22	HASSAN	110	HV2	KADUR_220	10:40	12:15	1:35	TRANSFORMER FAULT
1299	19-Mar-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	9:03	14:48	5:45	LINE FAULT
1300	19-Mar-22	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	13:32	16:21	2:49	LINE FAULT
1301	19-Mar-22	HASSAN	220	SHRAVTY-SHIMOGA4	gen_sharavathy	13:32	16:21	2:49	LINE FAULT
1302	19-Mar-22	MYSURU	66	BANNUR-VAJMANGALA	NO STATIONS EFFECTED	17:34	20:59	3:24	LINE CLEAR AVAILED
1303	19-Mar-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1304	19-Mar-22	MYSURU	66	HEBBANI-SHIMSA	MALAVALLI_66 HADLI_66	16:40	17:04	0:24	LINE FAULT
1305	19-Mar-22	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	16:40	16:59	0:19	LINE FAULT
1306	19-Mar-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58(17.03.22)			LINE OPEN:LINE CLEAR AVAILED
1307	19-Mar-22	MYSURU	66	HUNSUR-PERIYAPATNA	NO STATIONS EFFECTED	5:52:42 PM (3/18/2022)			LINE OPEN:LINE CLEAR AVAILED
1308	19-Mar-22	MYSURU	66	HV1	BOGADHI_66	10:26	17:43	7:17	LINE CLEAR AVAILED
1309	19-Mar-22	MYSURU	66	HV1	JAIPURA_66	9:32	10:05	0:33	LINE CLEAR AVAILED
1310	19-Mar-22	MYSURU	66	HV1	JAIPURA_66	10:10	10:20	0:10	HAND TRIPPED
1311	19-Mar-22	MYSURU	66	HV1	JAIPURA_66	15:08	15:31	0:22	TRANSFORMER FAULT
1312	19-Mar-22	MYSURU	66	HV1	KIADBMANDYA_66	17:10	17:17	0:07	TRANSFORMER FAULT
1313	19-Mar-22	MYSURU	66	HV1	TUBINKERE_66	10:08	12:11	2:03	LINE CLEAR AVAILED
1314	19-Mar-22	MYSURU	66	HV2	KIKKERI_66	14:18	17:01	2:43	LINE CLEAR AVAILED
1315	19-Mar-22	MYSURU	66	KADAKOLA-DKMAIDANA	NO STATIONS EFFECTED	10:31	12:28	1:56	LINE CLEAR AVAILED
1316	19-Mar-22	MYSURU	66	KADAKOLA-DKMAIDANA	NO STATIONS EFFECTED	17:48	17:55	0:07	LINE FAULT
1317	19-Mar-22	MYSURU	66	KADAKOLA-RK NAGARA	NO STATIONS EFFECTED	10:31	12:30	1:59	LINE CLEAR AVAILED
1318	19-Mar-22	MYSURU	66	KADAKOLA-SARGUR1	JAYAPURA_66 HAMPAPURA_66	17:43	17:54	0:11	LINE FAULT
1319	19-Mar-22	MYSURU	66	KADAKOLA-SARGUR2	DOORA_66 HURA_66 HULLALLI_66	17:45	17:55	0:09	LINE FAULT
1320	19-Mar-22	MYSURU	66	KUSHALNAGARA-RAMANTHAPURA1	RUDRAPATNA_66 KANAGALU_66 CHIKKABOMMANAHALLI_66 ALUR SIDDARPURA_66	10:03	10:19	0:16	HAND TRIPPED
1321	19-Mar-22	MYSURU	66	KUSHALNAGARA-RAMANTHAPURA1	RUDRAPATNA_66 KANAGALU_66 CHIKKABOMMANAHALLI_66 ALUR SIDDARPURA_66	10:42	10:49	0:07	HAND TRIPPED
1322	19-Mar-22	MYSURU	66	MEGHALAPURA-VAJMANGALA	NO STATIONS EFFECTED	17:30	21:00	3:29	LINE CLEAR AVAILED
1323	19-Mar-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	19:16(14.03.22)	16:51:00 (19.3.2022)	120:00 hrs	LINE CHARGED
1324	19-Mar-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	20:50:00 (19.3.2022)			LINE OPEN:LINE CLEAR AVAILED
1325	19-Mar-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	19:16(14.03.22)	16:51:00 (19.3.2022)	120:00 hrs	LINE CHARGED
1326	19-Mar-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	20:50:00 (19.3.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1327	19-Mar-22	MYSURU	220	KUSHALNAGARA-HV1	BETTADAPURA_66 KITTUR_66 MIRLE_66 KR NAGARA_66 CHUNCHUNKATTE_66 RAVANDUR_66 KAMPLAPURA_66 GAVADGERE_66 GVGUDI_66 BANNIKUPPE_66 SUNTIKOPPA_66 MADIKERE_66 BYLAKUPPR_66 VIRAJPERE_66 PONNAMPETE_66 PERIYAPATNA_66 .BILIKERE_66 BHERYA_66 RUDRAPATNA_66 KANAGALU_66 CHIKKABOMMANAHALLI_66 ALUR SIDDARPURA_66	8:08	8:12	0:04	LINE FAULT
1328	19-Mar-22	MYSURU	220	KUSHALNAGARA-HV2	NO STATIONS EFFECTED	15:06	16:36	1:30	LINE CLEAR AVAILED
1329	19-Mar-22	MYSURU	220	VAJMANGALA-HOOTGALLY	NO STATIONS EFFECTED	18:00	20:15	2:15	NFBC ISSUED
1330	19-Mar-22	MYSURU	220	VAJMANGALA-HOOTGALLY	VAJMANGALA_220 FTS_66 JYOTHINGARAR_66 DEVNOOEMYS_66DK MAIDANA_66 MEGHALAPURA_66 BANNUR_66 AYRAHALLI_66 MARADIHUNDI_66	16:40	17:49	1:09	LINE FAULT
1331	19-Mar-22	MYSURU	220	VAJMANGALA-TK HALLI	KIADB MANDYA_66 KOLKARANADODDI_66 KMDODDI_66 TALAGAWADI_66 MADDUR_66 TUIMBEKERE_66 KIADB SOMANAHALLI_66 KHONNALAGERE_66 IGLUR_66	16:40	17:32	0:52	HAND TRIPPED
1332	19-Mar-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:16	16:25	0:08	LINE FAULT
1333	19-Mar-22	TUMKUR	66	HANAGAL- B G KERE(GUDIKOTE)	BGKERE_66,GUDEKOTE_66	16:37	18:14	1:37	LINE CLEAR AVAILED
1334	19-Mar-22	TUMKUR	66	KATTIGE- RENEW WIND IPP	RENEW WIND IPP	19:17	21:17	1:59	LINE CLEAR AVAILED
1335	19-Mar-22	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	NAYAKANAHATTI_66	17:02	17:15	0:12	LINE FAULT
1336	19-Mar-22	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	NAYAKANAHATTI_66	18:16	18:30	0:14	LINE FAULT
1337	19-Mar-22	TUMKUR	66	PAVAGADA 220kv- SHYLAPURA	SHYLAPURA_66	8:40	9:33	0:53	LINE CLEAR AVAILED
1338	19-Mar-22	TUMKUR	66	PAVAGADA 220kv- SHYLAPURA	SHYLAPURA_66	15:56	16:05	0:08	LINE FAULT
1339	19-Mar-22	TUMKUR	66	PKOTE-AZURE SOLAR	PKOTE_66	15:51	16:07	0:15	MAIN SUPPLY FAILURE
1340	19-Mar-22	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	15:51	16:08	0:16	MAIN SUPPLY FAILURE
1341	19-Mar-22	TUMKUR	66	PKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	15:51	16:09	0:17	MAIN SUPPLY FAILURE
1342	19-Mar-22	TUMKUR	66	SIRA220 - BUKKAPATNA	BUKKAPATNA_66	15:28	15:40	0:12	LOAD CURTAILMENT
1343	19-Mar-22	TUMKUR	66	SIRA220-PATNAYAKANAHALLI	PATNAYAKANAHALLI	15:49	15:52	0:03	LOAD CURTAILMENT
1344	19-Mar-22	TUMKUR	66	TR-1	HALURAMESWARA_66	16:33	16:40	0:06	TRANSFORMER FAULT
1345	19-Mar-22	TUMKUR	66	TR-1	KALMARANAHALLI_66	7:27	9:19	1:52	LINE CLEAR AVAILED
1346	19-Mar-22	TUMKUR	66	TR-1	MAVINAKATTE_66	23:59	0:07	0:07	TRANSFORMER FAULT
1347	19-Mar-22	TUMKUR	66	TR-1	NITRAHALLI_66	7:00	10:00	3:00	LINE CLEAR AVAILED
1348	19-Mar-22	TUMKUR	66	TR-1	PD KOTE_66	15:51	16:07	0:15	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1349	19-Mar-22	TUMKUR	66	TR-2	BENNNIKERE_66	3:05	3:11	0:06	TRANSFORMER FAULT
1350	19-Mar-22	TUMKUR	66	TR-2	NITRAHALLI_66	10:11	11:16	1:04	LINE CLEAR AVAILED
1351	19-Mar-22	TUMKUR	66	TR-2	PD KOTE_66	15:51	16:06	0:14	MAIN SUPPLY FAILURE
1352	19-Mar-22	TUMKUR	66	TR-3	HARIYABBE_66	20:47	21:13	0:25	TRANSFORMER FAULT
1353	19-Mar-22	TUMKUR	66	TR-3	HARIYABBE_66	22:05	22:18	0:12	LINE CLEAR AVAILED
1354	19-Mar-22	TUMKUR	110	HONNAVALLI 110-ADAN SOLAR_	HONNAVALLI_110	15:56	16:27	0:30	LINE CLEAR AVAILED
1355	19-Mar-22	TUMKUR	110	TR-1	HUNASEGHATTA_110	14:15	14:45	0:30	LINE CLEAR AVAILED
1356	20-Mar-22	BAGALKOT	110	110/11KV, HV1	MANTUR(B)_110	2:00	2:05	0:05	TRANSFORMER FAULT
1357	20-Mar-22	BAGALKOT	110	110/11KV, HV1	MK HUBLI_220	9:40	14:32	4:52	LINE CLEAR AVAILED
1358	20-Mar-22	BAGALKOT	110	110/11KV, HV1	UMMACHAGI_110	16:45	17:10	0:25	TRANSFORMER FAULT
1359	20-Mar-22	BAGALKOT	110	110/11KV, HV1	VAJJRAMATTI_110	10:03	18:07	8:04	LINE CLEAR AVAILED
1360	20-Mar-22	BAGALKOT	110	110/11KV, HV1	YARAGATTI_110	10:14	18:18	8:04	LINE CLEAR AVAILED
1361	20-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YARAGATTI_110	10:14	18:22	8:08	LINE CLEAR AVAILED
1362	20-Mar-22	BAGALKOT	110	110/11KV, HV2	VAJJRAMATTI_110	10:03	18:06	8:03	LINE CLEAR AVAILED
1363	20-Mar-22	BAGALKOT	110	110/11KV,HV 1&2	BENAKATTI_110	10:30	18:17	7:47	LINE CLEAR AVAILED
1364	20-Mar-22	BAGALKOT	110	110/11KV,HV1	HIRESMASALI_110	13:55	14:00	0:05	TRANSFORMER FAULT
1365	20-Mar-22	BAGALKOT	110	110/11KV,HV1	KANABARGI LAYOUT_110	10:34	15:09	4:35	LINE CLEAR AVAILED
1366	20-Mar-22	BAGALKOT	110	110/11KV,HV1&2	GARAG+110	10:03	17:12	7:09	LINE CLEAR AVAILED
1367	20-Mar-22	BAGALKOT	110	110/11KV,HV2	ANKALAGI_110	11:15	16:27	5:12	LINE CLEAR AVAILED
1368	20-Mar-22	BAGALKOT	110	110/11KV,HV2	CHIKKODI_110	10:35	11:11	0:36	HAND TRIPPED
1369	20-Mar-22	BAGALKOT	110	110/11KV,HV2	ITANAL_110	11:09	11:12	0:03	TRANSFORMER FAULT
1370	20-Mar-22	BAGALKOT	110	110/11KV,HV4	STATION NOT AFFECTED BELGAUM_110	19:47 (19.03.2022)	13:42 (20.03.2022)	17:55 hrs	TRANSFORMER CHARGED
1371	20-Mar-22	BAGALKOT	110	110/33KV, HV2	ONTAGODI_33, YADAWAD_33 UTTUR_110	11:08	17:11	6:03	LINE CLEAR AVAILED
1372	20-Mar-22	BAGALKOT	110	110/33KV, HV4	HALASANGI_33, DULAKHED_33 NERVARGI_33 STATION NOT AFFECTED ZALKI_110	11:03	11:09	0:06	TRANSFORMER FAULT
1373	20-Mar-22	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI_220	8:56	14:23	5:27	LINE CLEAR AVAILED
1374	20-Mar-22	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	11:23	14:22	2:59	LINE CLEAR AVAILED
1375	20-Mar-22	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	4:57	17:37	12:40	LINE FAULT
1376	20-Mar-22	BAGALKOT	110	BELGAUM220-ANKALAGI	STATION NOT AFFECTED BELGAUM_220	11:10	14:19	3:09	LINE CLEAR AVAILED
1377	20-Mar-22	BAGALKOT	110	BELGAUM220-BELGAUM110	BELGAUM_110	10:34	13:35	3:01	LINE CLEAR AVAILED
1378	20-Mar-22	BAGALKOT	110	BELGAUM220-HUDALI	HUDALI_110	11:14	14:21	3:07	LINE CLEAR AVAILED
1379	20-Mar-22	BAGALKOT	110	BELGAUM220-KANABARAGI LAYOUT	KANABARGI LAYOUT_110	10:34	15:03	4:29	LINE CLEAR AVAILED
1380	20-Mar-22	BAGALKOT	110	BELGAUM220-NEHARUNAGAR	NEHARUNAGAR_110	10:34	13:14	2:40	LINE CLEAR AVAILED
1381	20-Mar-22	BAGALKOT	110	BELGAUM220-VADAGOAN	STATION NOT AFFECTED BELGAUM_220	11:46	14:36	2:50	LINE CLEAR AVAILED
1382	20-Mar-22	BAGALKOT	110	BELLATTI-ENERCON2	BELLATTI_110 (STATION NOT AFFECTED)	21:40 (19.03.2022)	16:27 (20.03.2022)	18:47 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1383	20-Mar-22	BAGALKOT	110	BENAKATTI- YARGATTI	YARAGATTI_110	15:34	18:15	2:41	MAIN SUPPLY FAILURE
1384	20-Mar-22	BAGALKOT	110	BIJAPUR-ENERCON(BAGEWADI)	BIJAPUR_220	12:18	17:43	5:25	LINE CLEAR AVAILED
1385	20-Mar-22	BAGALKOT	110	CHIKKODI 220-CHIKKODI 110	CHIKKODI_110	0:10	1:25	1:15	NFBC ISSUED
1386	20-Mar-22	BAGALKOT	110	CHIKKODI 220-CHIKKODI 110	CHIKKODI_110	14:32	16:17	1:45	NFBC ISSUED
1387	20-Mar-22	BAGALKOT	110	CHIKKODI 220-KHADAKLAT	KHADAKLAT_110	11:00	12:44	1:44	LINE CLEAR AVAILED
1388	20-Mar-22	BAGALKOT	110	CHIKKODI220- CHIKKODI	CHIKKODI_220	23:54 (19.03.2022)	1:23 (20.03.2022)	1:29 hrs	LINE CHARGED
1389	20-Mar-22	BAGALKOT	110	CHIKKODI220- CHIKKODI	CHIKKODI_220	14:30	16:16	1:46	LINE CLEAR AVAILED
1390	20-Mar-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1391	20-Mar-22	BAGALKOT	110	GHATAPRABHA220-SURYODAYA SOLAR	STATION NOT AFFECTED GHATAPRABHA_220	7:20	7:45	0:25	LINE FAULT
1392	20-Mar-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
1393	20-Mar-22	BAGALKOT	110	KADANAKOPPA-KAVALWAD	KAVALAWAD_110	11:15	11:20	0:05	HAND TRIPPED
1394	20-Mar-22	BAGALKOT	110	KHADAKLAT-NIPPANI	NIPPANI_110	11:00	12:44	1:44	LINE CLEAR AVAILED
1395	20-Mar-22	BAGALKOT	110	KUDACHI 220-MORAB(TERADAL)	MORAB_110	11:29	14:02	2:33	LINE CLEAR AVAILED
1396	20-Mar-22	BAGALKOT	110	MK HUBLI220- BAILHONGAL	BAILHONGAL_110	10:20	17:40	7:20	LINE CLEAR AVAILED
1397	20-Mar-22	BAGALKOT	110	MK HUBLI220- MK HUBLI1	MK HUBLI_220	10:30	17:47	7:17	LINE CLEAR AVAILED
1398	20-Mar-22	BAGALKOT	110	MK HUBLI-BAILHONGAL	BAILHONGAL_110	10:17	17:46	7:29	LINE CLEAR AVAILED
1399	20-Mar-22	BAGALKOT	110	MKHUBLI-220MKHUBLI1(BAILHONGAL)	MKHUBLI_110	10:40	17:46	7:06	LINE CLEAR AVAILED
1400	20-Mar-22	BAGALKOT	110	MKHUBLI-KITTUR (NARENDRA)	MKHUBLI_110	10:40	17:47	7:07	LINE CLEAR AVAILED
1401	20-Mar-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1402	20-Mar-22	BAGALKOT	110	RON 1&2-GAJENDRAGAD	GAJENDRAGAD_110	14:10	14:50	0:40	HAND TRIPPED
1403	20-Mar-22	BAGALKOT	110	RON-GAMESH IPP	GAMESH IPP_110 RON_110	14:28	14:36	0:08	HAND TRIPPED
1404	20-Mar-22	BAGALKOT	110	SOUDATTI220- BENAKATTI	SOUDATTI_220	15:34	18:11	2:37	LINE CLEAR AVAILED
1405	20-Mar-22	BAGALKOT	110	TAKKALAKI-KN SOLAR	KN SOLAR_110 TAKKALAKI_110	10:35	10:37	0:02	HAND TRIPPED
1406	20-Mar-22	BAGALKOT	110	TAKKALAKI-WARDHA SOLAR	WARDHA SOLAR_110 TAKKALAKI_110	10:35	10:37	0:02	HAND TRIPPED
1407	20-Mar-22	BAGALKOT	110	VAJRAMATTI220- VAJRAMATTI	VAJRAMATTI_110	10:09	18:02	7:53	LINE CLEAR AVAILED
1408	20-Mar-22	BAGALKOT	110	VAJRAMATTI220- VAJRAMATTI	VAJRAMATTI_110	10:09	18:02	7:53	LINE CLEAR AVAILED
1409	20-Mar-22	BAGALKOT	110	YARAGATTI- KATAKOL	KATAKOL_110	15:34	18:15	2:41	MAIN SUPPLY FAILURE
1410	20-Mar-22	BAGALKOT	220	220/110KV ,HV2	BIJAPUR_220	9:28	9:31	0:03	HAND TRIPPED
1411	20-Mar-22	BAGALKOT	220	220/110KV ,HV2	BIJAPUR_220	10:31	10:36	0:05	HAND TRIPPED
1412	20-Mar-22	BAGALKOT	220	220/110KV, HV1	SOUDATTI_220	10:14	14:51	4:37	LINE CLEAR AVAILED
1413	20-Mar-22	BAGALKOT	220	220/110KV, HV1& LV1	INDI_220, DEVARHIPPARAGI_110, ATHARGA_110, INDI_110, ZALKI_110, LACHYAN_110, HIREBEVNUR_110, CHADCHAN_110, RODAGI_110, INCHAGERI_110	10:32	10:36	0:04	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1414	20-Mar-22	BAGALKOT	220	220/110KV, HV1,LV1	STATION NOT AFFECTED BELGAUM_220	10:58	11:48	0:50	HAND TRIPPED
1415	20-Mar-22	BAGALKOT	220	220/110KV, HV1,LV1	STATION NOT AFFECTED BELGAUM_220	11:52	13:32	1:40	LINE CLEAR AVAILED
1416	20-Mar-22	BAGALKOT	220	220/110KV, HV2	SOUDATTI_220	15:38	18:14	2:36	LINE CLEAR AVAILED
1417	20-Mar-22	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED MK HUBLI_220	8:58	14:20	5:22	LINE CLEAR AVAILED
1418	20-Mar-22	BAGALKOT	220	220/110KV, HV2& LV2	INDI_220, DEVARHIPPARAGI_110, ATHARGA_110, INDI_110, ZALKI_110, LACHYAN_110, HIREBEVNUR_110, CHADCHAN_110, RODAGI_110, INCHAGERI_110	10:32	10:36	0:04	MAIN SUPPLY FAILURE
1419	20-Mar-22	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	16:05 (08.03.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1420	20-Mar-22	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1421	20-Mar-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1422	20-Mar-22	BAGALKOT	220	BIJAPUR-INDI1	BIJAPUR_220	9:51	9:56	0:05	HAND TRIPPED
1423	20-Mar-22	BAGALKOT	220	BIJAPUR-NANDYAL1(BAGEWADI 1)	BIJAPUR_220	9:23	9:27	0:04	HAND TRIPPED
1424	20-Mar-22	BAGALKOT	220	BIJAPUR-NANDYAL1(BAGEWADI 1)	BIJAPUR_220	10:31	10:36	0:05	HAND TRIPPED
1425	20-Mar-22	BAGALKOT	220	BIJAPUR-NANDYAL2(BAGEWADI 2)	BIJAPUR_220	10:31	10:36	0:05	HAND TRIPPED
1426	20-Mar-22	BAGALKOT	220	BIJAPUR-VAISHALI1	BIJAPUR_220	10:31	10:36	0:05	HAND TRIPPED
1427	20-Mar-22	BAGALKOT	220	CHIKKODI- BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1428	20-Mar-22	BAGALKOT	220	CHIKKODI- BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:43 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1429	20-Mar-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
1430	20-Mar-22	BAGALKOT	220	CHIKKODI- KOLHAPUR1(TALANDAGI)	STATION NOT AFFECTED CHIKKODI_220	23:18 (19.03.2022)	19:38 (20.03.2022)	20:20 hrs	LINE CHARGED
1431	20-Mar-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1432	20-Mar-22	BAGALKOT	220	INDI- BIJAPUR1	INDI_220	9:52	9:55	0:03	HAND TRIPPED
1433	20-Mar-22	BAGALKOT	220	INDI- BIJAPUR1	INDI_220	10:32	10:36	0:04	MAIN SUPPLY FAILURE
1434	20-Mar-22	BAGALKOT	220	INDI- BIJAPUR2	STATION NOT AFFECTED INDI_220	9:40	9:48	0:08	HAND TRIPPED
1435	20-Mar-22	BAGALKOT	220	INDI- BIJAPUR2	STATION NOT AFFECTED INDI_220	10:25	16:25	6:00	LINE CLEAR AVAILED
1436	20-Mar-22	BAGALKOT	220	INDI- SAVALASANGA	INDI_220	10:32	10:36	0:04	MAIN SUPPLY FAILURE
1437	20-Mar-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	10:13 (12.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1438	20-Mar-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	10:14 (12.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1439	20-Mar-22	BENGALURU	66	ABBIGERE - ATTUR YELAHANAKA	ABBIGERE	11:46	11:49	0:03	LOAD CHANGE OVER
1440	20-Mar-22	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	13:57	14:07	0:10	LOAD CHANGE OVER
1441	20-Mar-22	BENGALURU	66	ANEKAL - ATTIBELE	ATTIBELE	10:36	17:46	7:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1442	20-Mar-22	BENGALURU	66	CB PURA I/A - CB PURA URBAN	CB PURA URBAN	7:37	7:50	0:12	LINE FAULT
1443	20-Mar-22	BENGALURU	66	CESSNA - HAL 220	CESSNA	9:05	9:10	0:05	LOAD CHANGEOVER
1444	20-Mar-22	BENGALURU	66	CESSNA - HAL 220	CESSNA	13:41	13:48	0:07	LOAD CHANGEOVER
1445	20-Mar-22	BENGALURU	66	CESSNA - VIKAS TECH PARK 220	CESSNA	5:43	5:53	0:10	MAIN SUPPLY FAILURE
1446	20-Mar-22	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	6:30	6:37	0:07	LOAD CHANGEOVER
1447	20-Mar-22	BENGALURU	66	DABUSPET 220 - AVERAHALLI	AVERAHALLI	9:00	18:00	9:00	LINE CLEAR AVAILED
1448	20-Mar-22	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	9:00	18:00	9:00	LINE CLEAR AVAILED
1449	20-Mar-22	BENGALURU	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	9:00	18:00	9:00	LINE CLEAR AVAILED
1450	20-Mar-22	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	9:30	19:17	9:47	LINE CLEAR AVAILED
1451	20-Mar-22	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	9:00	18:00	9:00	LINE CLEAR AVAILED
1452	20-Mar-22	BENGALURU	66	DABUSPET 220 - SK STEEL (EHT)	SK STEEL (EHT)	9:00	18:00	9:00	LINE CLEAR AVAILED
1453	20-Mar-22	BENGALURU	66	DABUSPET 220 - T BEGUR	NO STATION AFFECTED	9:00	18:00	9:00	LINE CLEAR AVAILED
1454	20-Mar-22	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	9:00	18:00	9:00	LINE CLEAR AVAILED
1455	20-Mar-22	BENGALURU	66	DEVARABISANAHALLI - CESSNA PARK	DEVARABISANAHALLI, GLOBAL TECH PARK	10:49	10:59	0:10	LINE FAULT
1456	20-Mar-22	BENGALURU	66	EXORA - HAL 220	EXORA	9:05	9:10	0:05	MAIN SUPPLY FAILURE
1457	20-Mar-22	BENGALURU	66	EXORA - HAL 220	EXORA	13:42	13:50	0:08	LOAD CHANGEOVER
1458	20-Mar-22	BENGALURU	66	EXORA - VIKAS TECH PARK 220	EXORA	5:43	5:53	0:10	MAIN SUPPLY FAILURE
1459	20-Mar-22	BENGALURU	66	HANUMANTHNAGARA - KANAKAPURA 220	HANUMANTHNAGARA	13:15	13:25	0:10	LOAD CHANGEOVER
1460	20-Mar-22	BENGALURU	66	HANUMANTHNAGARA - SOMANAHALLI 220	HANUMANTHNAGARA	10:00	10:10	0:10	LOAD CHANGEOVER
1461	20-Mar-22	BENGALURU	66	HEBBAL 220 - C STATION 1	C STATION	15:58	16:22	0:24	LINE CLEAR AVAILED
1462	20-Mar-22	BENGALURU	66	HEBBAL 220 - C STATION 2	C STATION	15:58	16:22	0:24	LINE CLEAR AVAILED
1463	20-Mar-22	BENGALURU	66	HEBBAL 220 - LR BANDE	NO STATION AFFECTED	15:25	15:33	0:08	LINE FAULT
1464	20-Mar-22	BENGALURU	66	HEBBAL 220 - LR BANDE	NO STATION AFFECTED	15:58	18:45	2:47	LINE CLEAR AVAILED
1465	20-Mar-22	BENGALURU	66	HV1	ATTUR YELAHANKA	9:42	9:47	0:05	LOAD CHANGEOVER
1466	20-Mar-22	BENGALURU	66	HV1	ATTUR YELAHANKA	12:10	12:15	0:05	LOAD CHANGEOVER
1467	20-Mar-22	BENGALURU	66	HV1	ATTUR YELAHANKA	19:23	19:29	0:06	LOAD CHANGEOVER
1468	20-Mar-22	BENGALURU	66	HV1	BANASAWADI	15:33	15:41	0:08	LOAD CHANGEOVER
1469	20-Mar-22	BENGALURU	66	HV1	BANASAWADI	18:43	18:47	0:04	LOAD CHANGEOVER
1470	20-Mar-22	BENGALURU	66	HV1	DODDABELAVANGALA	7:25	7:32	0:06	TRANSFORMER FAULT
1471	20-Mar-22	BENGALURU	66	HV1	GODUR	4:48	6:20	1:31	LINE CLEAR AVAILED
1472	20-Mar-22	BENGALURU	66	HV1	LEELA VENTURE	8:08	8:11	0:03	LOAD CHANGEOVER
1473	20-Mar-22	BENGALURU	66	HV1	MANYATHA TECH PARK 220	16:03	16:44	0:41	LINE CLEAR AVAILED
1474	20-Mar-22	BENGALURU	66	HV1	N G HULKUR	16:49	16:53	0:04	LINE CLEAR AVAILED
1475	20-Mar-22	BENGALURU	66	HV1	NELAMANGALA 66	9:30	20:36	11:06	LINE CLEAR AVAILED
1476	20-Mar-22	BENGALURU	66	HV1	SARJAPURA 220	7:58	8:06	0:08	MAIN SUPPLY FAILURE
1477	20-Mar-22	BENGALURU	66	HV1	SARJAPURA 220	13:30	13:32	0:02	LOAD CHANGEOVER
1478	20-Mar-22	BENGALURU	66	HV1	VIJAYANAGARA	19:05	19:06	0:01	LOAD CHANGEOVER
1479	20-Mar-22	BENGALURU	66	HV2	ATTUR YELAHANKA	9:42	9:47	0:05	LOAD CHANGEOVER
1480	20-Mar-22	BENGALURU	66	HV2	ATTUR YELAHANKA	12:10	12:15	0:05	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1481	20-Mar-22	BENGALURU	66	HV2	ATTUR YELAHANKA	19:23	19:29	0:06	LOAD CHANGE OVER
1482	20-Mar-22	BENGALURU	66	HV2	DALSANUR	18:05	18:28	0:23	TRANSFORMER FAULT
1483	20-Mar-22	BENGALURU	66	HV2	DODDABELAVANGALA	11:04	11:46	0:41	LINE CLEAR AVAILED
1484	20-Mar-22	BENGALURU	66	HV2	GUDIBANDE	8:10	10:20	2:10	TRANSFORMER FAULT
1485	20-Mar-22	BENGALURU	66	HV2	GUDIBANDE	10:20	10:40	0:20	TRANSFORMER FAULT
1486	20-Mar-22	BENGALURU	66	HV2	GUDIBANDE	10:40	10:45	0:05	TRANSFORMER FAULT
1487	20-Mar-22	BENGALURU	66	HV2	MANYATHA TECH PARK 220	16:03	16:44	0:41	LINE CLEAR AVAILED
1488	20-Mar-22	BENGALURU	66	HV2	N G HULKUR	16:49	16:53	0:04	LINE CLEAR AVAILED
1489	20-Mar-22	BENGALURU	66	HV2	NELAMANGALA 66	9:30	19:20	9:50	LINE CLEAR AVAILED
1490	20-Mar-22	BENGALURU	66	HV2	SARJAPURA 220	7:58	8:06	0:08	MAIN SUPPLY FAILURE
1491	20-Mar-22	BENGALURU	66	HV2	SARJAPURA 220	13:30	13:32	0:02	LOAD CHANGE OVER
1492	20-Mar-22	BENGALURU	66	HV2	YELAHANKA 220	15:04	15:13	0:08	TRANSFORMER FAULT
1493	20-Mar-22	BENGALURU	66	HV3	BANASAWADI	15:33	15:41	0:08	LOAD CHANGE OVER
1494	20-Mar-22	BENGALURU	66	HV3	BANASAWADI	18:43	18:47	0:04	LOAD CHANGE OVER
1495	20-Mar-22	BENGALURU	66	HV3	NELAMANGALA 66	9:30	19:34	10:04	LINE CLEAR AVAILED
1496	20-Mar-22	BENGALURU	66	HV4	MANYATHA TECH PARK 220	16:03	16:44	0:41	LINE CLEAR AVAILED
1497	20-Mar-22	BENGALURU	66	IISc - HEBBALA 220	IISc	15:58	16:13	0:15	MAIN SUPPLY FAILURE
1498	20-Mar-22	BENGALURU	66	IISc - NRS 220	IISc	20:44	20:49	0:05	LOAD CHANGE OVER
1499	20-Mar-22	BENGALURU	66	JIGANU LINK ROAD - KIRLOS KAR (EHT)	KIRLOS KAR (EHT)	21:25(19-3-2022)	14:02(20-03-2022)	16:36 hrs	LINE CHARGED
1500	20-Mar-22	BENGALURU	66	KGF - MALUR 220	KGF, BEM(L(EHT), KAMASAMUDRA	21:20	21:50	0:30	LOAD CHANGE OVER
1501	20-Mar-22	BENGALURU	66	KOLAR 220 - MULBAGAL	NO STATION AFFECTED	19:40	22:02	2:22	LINE CLEAR AVAILED
1502	20-Mar-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	17:47	18:01	0:13	LINE FAULT
1503	20-Mar-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	18:01	22:00	3:59	LINE CLEAR AVAILED
1504	20-Mar-22	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALS NUR	19:40	22:02	2:22	LINE CLEAR AVAILED
1505	20-Mar-22	BENGALURU	66	KOLAR 220 - THAYLUR	TAMAKA	19:40	22:14	2:34	LINE CLEAR AVAILED
1506	20-Mar-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	16:40	17:02	0:22	LINE FAULT
1507	20-Mar-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	18:31	18:59	0:27	LINE FAULT
1508	20-Mar-22	BENGALURU	66	MANYATHA TECH PARK 220 - MANYATHA TECH PARK 66	MANYATHA TECH PARK 66	16:03	16:44	0:41	LINE CLEAR AVAILED
1509	20-Mar-22	BENGALURU	66	MELUR - SIDLAGHATTA	MELUR	8:50	9:00	0:10	LOAD CHANGE OVER
1510	20-Mar-22	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	6:15	6:20	0:05	LOAD CHANGE OVER
1511	20-Mar-22	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE	18:48	18:53	0:05	LINE FAULT
1512	20-Mar-22	BENGALURU	66	PLATINUM CITY - PUTTENAHALLI 220	PLATINUM CITY	19:30	19:40	0:10	MAIN SUPPLY FAILURE
1513	20-Mar-22	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	13:56	14:00	0:04	LOAD CHANGE OVER
1514	20-Mar-22	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	9:10	9:15	0:05	LOAD CHANGE OVER
1515	20-Mar-22	BENGALURU	66	REMCO - NRS	VIJAYANAGARA	17:16	17:25	0:09	LINE FAULT
1516	20-Mar-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	5:46	6:09	0:23	MAIN SUPPLY FAILURE
1517	20-Mar-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	10:50	11:13	0:23	MAIN SUPPLY FAILURE
1518	20-Mar-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	13:24	13:40	0:16	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1519	20-Mar-22	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	7:56	17:50	9:54	MAIN SUPPLY FAILURE
1520	20-Mar-22	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	NO STATION AFFECTED	6:32	8:06	1:34	MAIN SUPPLY FAILURE
1521	20-Mar-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	7:56	8:07	0:11	MAIN SUPPLY FAILURE
1522	20-Mar-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	13:21	13:36	0:15	LOAD CHANGEOVER
1523	20-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	17:00	17:15	0:15	LINE FAULT
1524	20-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	17:15	18:15	1:00	LINE FAULT
1525	20-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	18:15	19:46	1:31	LINE FAULT
1526	20-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	19:46	21:32	1:46	LINE CLEAR AVAILED
1527	20-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML	19:58	20:25	0:27	LINE CLEAR AVAILED
1528	20-Mar-22	BENGALURU	66	WELCASTE STEEL - ABBIGERE	WELCAST STEEL	11:35	11:40	0:05	LOAD CHANGEOVER
1529	20-Mar-22	BENGALURU	66	WELCASTE STEEL - SRS PEENYA 220	WELCAST STEEL	14:14	14:17	0:03	LOAD CHANGEOVER
1530	20-Mar-22	BENGALURU	66	YELAHANKA 220 - LINE3	WHEELS & AXLE(EHT), ESCORTS (EHT)YHT(9), ATTUR YELAHANKA	12:18	13:19	1:00	LINE CLEAR AVAILED
1531	20-Mar-22	BENGALURU	66	YELAHANKA 220 - LINE4/DG4	SAHAKARINAGAR, ESCORTS(EHT)YHT(8), PLATINUM CITY.	9:45	12:07	2:21	LINE CLEAR AVAILED
1532	20-Mar-22	BENGALURU	220	DABUSPETE 220 - NELAMANGALA 400	DABUSPET 220	9:00	18:00	9:00	LINE CLEAR AVAILED
1533	20-Mar-22	BENGALURU	220	HEBBALA 220 - CPRI(EHT)	CPRI(EHT)	15:58	18:30	2:32	LINE CLEAR AVAILED
1534	20-Mar-22	BENGALURU	220	HEBBALA 220 - MANYATHA TECH PARK 220	HEBBALA 220	15:58	17:43	1:45	MAIN SUPPLY FAILURE
1535	20-Mar-22	BENGALURU	220	HEBBALA 220 - MANYATHA TECH PARK 220	HEBBALA 220	15:58	17:40	1:42	LINE FAULT
1536	20-Mar-22	BENGALURU	220	HV1	HEBBALA 220	15:58	17:50	1:52	LINE CLEAR AVAILED
1537	20-Mar-22	BENGALURU	220	HV1	MANYATHA TECH PARK 220	16:03	16:44	0:41	MAIN SUPPLY FAILURE
1538	20-Mar-22	BENGALURU	220	HV1	SARJAPURA 220	7:57	13:20	5:23	MAIN SUPPLY FAILURE
1539	20-Mar-22	BENGALURU	220	HV2	HEBBALA 220	15:58	17:50	1:52	LINE CLEAR AVAILED
1540	20-Mar-22	BENGALURU	220	HV2	SARJAPURA 220	7:57	13:20	5:23	MAIN SUPPLY FAILURE
1541	20-Mar-22	BENGALURU	220	HV3	HEBBALA 220	15:58	17:50	1:52	LINE CLEAR AVAILED
1542	20-Mar-22	BENGALURU	220	MALUR 220 - SOMANAHALLI 1	SARJAPURA 220, VIKAS TECH PARK 220	8:00	13:18	5:18	LINE CLEAR AVAILED
1543	20-Mar-22	BENGALURU	220	VIKAS TECH PARK 220 - HSR LAYOUT 220	VIKAS TECH PARK 220	10:50	11:10	0:20	MAIN SUPPLY FAILURE
1544	20-Mar-22	BENGALURU	220	VIKAS TECH PARK 220 - HSR LAYOUT 220	VIKAS TECH PARK 220	13:23	13:41	0:18	LOAD CHANGEOVER
1545	20-Mar-22	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	5:50	6:12	0:22	LOAD CHANGEOVER
1546	20-Mar-22	BENGALURU	220	YELAHANKA 220 - NELAMANGALA 220	MANYATHA 220	16:04	18:09	2:05	LINE FAULT
1547	20-Mar-22	BENGALURU	400	DEVANAHALLI 400 - NELAMANGALA 400	NO STATION AFFECTED	11:56	15:51	3:55	LINE FAULT
1548	20-Mar-22	BENGALURU	400	DEVANAHALLI 400 - SINGANAYAKANAHALLI 400	NO STATION AFFECTED	11:56	15:51	3:55	LINE FAULT
1549	20-Mar-22	GULBARGA	66	HARAPANAHALLI-NEELAGUNDA	HARAPANAHALLI_66,HARVI_66	9:20	18:00	8:40	LINE CLEAR AVAILED
1550	20-Mar-22	GULBARGA	66	ITTAGI-HBHALI	HB HALLI_66,UP HALLI_66	8:15	15:45	7:30	LINE CLEAR AVAILED
1551	20-Mar-22	GULBARGA	110	AURAD-DONGARGAON	DONGARGOAN_110	18:05	18:15	0:10	LINE FAULT
1552	20-Mar-22	GULBARGA	110	GALAG-MALLAT	GALAG_110	1:00	1:20	0:20	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1553	20-Mar-22	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	10:55	11:30	0:35	LINE CLEAR AVAILED
1554	20-Mar-22	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	16:00	16:17	0:17	MAIN SUPPLY FAILURE
1555	20-Mar-22	GULBARGA	110	HV2	BISILAHALLI_110	16:04	16:12	0:08	TRANSFORMER FAULT
1556	20-Mar-22	GULBARGA	110	HV2	MATAMARI_110	9:18	9:35	0:17	TRANSFORMER FAULT
1557	20-Mar-22	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	5:55	6:05	0:10	LINE FAULT
1558	20-Mar-22	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVATHI_110,DR NAGAR_110,KARATAGI_110	14:55	15:02	0:07	LINE FAULT
1559	20-Mar-22	GULBARGA	110	NANDUR-SHAHABAD	NANDUR_110	15:58	16:01	0:03	MAIN SUPPLY FAILURE
1560	20-Mar-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
1561	20-Mar-22	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADEGERA_110,SANNATHI_110,GREEN SUGAR IPP	9:48	10:05	0:17	LINE FAULT
1562	20-Mar-22	GULBARGA	110	SHAHPUR-YADGIRI	YADGIRI_110	18:02(20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
1563	20-Mar-22	GULBARGA	110	SHAHPUR-YADGIRI	YADGIRI_110	9:55	10:05	0:10	LINE CLEAR AVAILED
1564	20-Mar-22	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	5:55	6:10	0:15	LINE FAULT
1565	20-Mar-22	GULBARGA	220	HV1	HUMNABAD_220	11:25	12:05	0:40	LINE CLEAR AVAILED
1566	20-Mar-22	GULBARGA	220	HV1	SHAHBAD_220	10:05(19.03.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1567	20-Mar-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1568	20-Mar-22	GULBARGA	220	JSWL-BPS1	BPS_400	16:23	18:32	2:09	NFBC ISSUED
1569	20-Mar-22	GULBARGA	220	KUSTAGI-SULEKAL	KUSTAGI_220	0:00	11:43	11:43	NFBC ISSUED
1570	20-Mar-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE FAULT
1571	20-Mar-22	HASSAN	66	UDDURKO-SUZLON2	UDDURKOPPLU_66	6:31	10:27	3:56	LINE FAULT
1572	20-Mar-22	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	7:55	8:10	0:15	MAIN SUPPLY FAILURE
1573	20-Mar-22	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	17:30	17:45	0:15	LINE FAULT
1574	20-Mar-22	HASSAN	110	BARANG-ANVATTI	BARANGI_110	11:50	17:30	5:40	LINE FAULT
1575	20-Mar-22	HASSAN	110	HV1	BARANGI_110	10:30	12:30	2:00	TRANSFORMER FAULT
1576	20-Mar-22	HASSAN	110	HV1	GANDASI_110	0:35	8:58	8:23	TRANSFORMER FAULT
1577	20-Mar-22	HASSAN	110	HV1	JAVAGAL_110	20:17(20.3.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
1578	20-Mar-22	HASSAN	110	HV1	TOGARSI_110	23:59(18.03.2022)	12:27(20.03.2022)	36:28HRS	TRANSFORMER CHARGED
1579	20-Mar-22	HASSAN	110	HV3	BAIKAMPADY_110	9:06	10:51	1:45	TRANSFORMER FAULT
1580	20-Mar-22	HASSAN	110	HV3	KULASHEKARA_110	10:01	12:10	2:09	TRANSFORMER FAULT
1581	20-Mar-22	HASSAN	110	HV3	PUTUR_110	2:39	3:05	0:26	TRANSFORMER FAULT
1582	20-Mar-22	HASSAN	110	HV4	BAIKAMPADY_110	10:49	13:59	3:10	TRANSFORMER FAULT
1583	20-Mar-22	HASSAN	110	HV4	BAIKAMPADY_110	22:45	23:07	0:22	TRANSFORMER FAULT
1584	20-Mar-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	9:22	10:17	0:55	LINE FAULT
1585	20-Mar-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	7:55	8:07	0:12	MAIN SUPPLY FAILURE
1586	20-Mar-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	7:54	8:00	0:06	MAIN SUPPLY FAILURE
1587	20-Mar-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	7:55	8:00	0:05	MAIN SUPPLY FAILURE
1588	20-Mar-22	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	7:55	8:01	0:06	MAIN SUPPLY FAILURE
1589	20-Mar-22	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	7:55	8:18	0:23	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1590	20-Mar-22	HASSAN	220	KADUR-DABUSET	KADUR_220	10:28	17:39	7:11	LINE FAULT
1591	20-Mar-22	HASSAN	220	SHRAVTY-BELIGAVI	gen_sharavathy	7:48	9:18	1:30	LINE FAULT
1592	20-Mar-22	HASSAN	220	SHRAVTY-SHIMOGA1	gen_sharavathy	7:48	9:01	1:13	LINE FAULT
1593	20-Mar-22	HASSAN	220	SHRAVTY-ST3	gen_sharavathy	7:48	11:42	3:54	LINE FAULT
1594	20-Mar-22	HASSAN	220	SHRAVTY-TALAGUPPA1	gen_sharavathy	7:48	9:03	1:15	LINE FAULT
1595	20-Mar-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	7:55	9:12	1:17	LINE FAULT
1596	20-Mar-22	HASSAN	220	TALAGU-STRP1	TALAGUPPA_400	11:15	11:41	0:26	LINE FAULT
1597	20-Mar-22	MYSURU	66	CR NAGARA-BADANAGUPPE-2	BADANAGUPPE_66	9:09	16:16	7:07	LINE CLEAR AVAILED
1598	20-Mar-22	MYSURU	66	CR NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	10:49	17:04	6:15	LINE CLEAR AVAILED
1599	20-Mar-22	MYSURU	66	CR NAGARA-PANNIYADAHUNDI	PANDYADAHUNDI_66	11:54	14:09	2:15	LINE CLEAR AVAILED
1600	20-Mar-22	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	9:42	13:39	3:56	LINE CLEAR AVAILED
1601	20-Mar-22	MYSURU	66	HEBBAL-HOOTAGALLY	HEBBAL_66	10:28	16:05	5:36	NFBC ISSUED
1602	20-Mar-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00(8/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1603	20-Mar-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1604	20-Mar-22	MYSURU	66	HUNSUR-PERIYAPATNA	NO STATIONS EFFECTED	5:52:42 PM (3/18/2022)			LINE OPEN:LINE CLEAR AVAILED
1605	20-Mar-22	MYSURU	66	HV1	JANNUR_66	11:00	14:00	3:00	LINE CLEAR AVAILED
1606	20-Mar-22	MYSURU	66	HV1	MALAVALLI_66	8:33	10:00	1:26	LINE CLEAR AVAILED
1607	20-Mar-22	MYSURU	66	HV1	PANDYADAHUNDI_66	10:00	14:10	4:10	LINE CLEAR AVAILED
1608	20-Mar-22	MYSURU	66	HV2	MALAVALLI_66	4:51	10:00	5:08	TRANSFORMER FAULT
1609	20-Mar-22	MYSURU	66	HV2	PANDYADAHUNDI_66	10:00	14:10	4:10	LINE CLEAR AVAILED
1610	20-Mar-22	MYSURU	66	KADAKOLA-DK MAIDANA	DKMAIDANA_66	13:24	13:30	0:06	LINE FAULT
1611	20-Mar-22	MYSURU	66	KR PETE 220-MADESHWARAPURA	JAKKANAHALLY_66 MADESWARAPURA_66	0:51	0:58	0:06	LINE FAULT
1612	20-Mar-22	MYSURU	66	METAGALLI-HEBBAL	METAGALLY_66	10:18	17:22	7:03	NFBC ISSUED
1613	20-Mar-22	MYSURU	66	METAGALLI-VIKRANTH	NO STATIONS EFFECTED	10:18	17:25	7:06	NFBC ISSUED
1614	20-Mar-22	MYSURU	66	THANDYA-ITC	NO STATIONS EFFECTED	11:05	13:45	2:40	NFBC ISSUED
1615	20-Mar-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	20:50:00 (19.3.2022)	10:07(20.03.22)	13:17 Hrs	LINE CHARGED
1616	20-Mar-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37(20.3.22)			LINE OPEN:LINE CLEAR AVAILED
1617	20-Mar-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	20:50:00 (19.3.2022)	10:07(20.03.22)	13:17 Hrs	LINE CHARGED
1618	20-Mar-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37(20.3.22)			LINE OPEN:LINE CLEAR AVAILED
1619	20-Mar-22	MYSURU	220	HV2	KRPET_220	20:21	21:01	0:39	TRANSFORMER FAULT
1620	20-Mar-22	MYSURU	220	KADAKOLA-CR NAGARA 1	NO STATIONS EFFECTED	10:01	14:24	4:23	LINE CLEAR AVAILED
1621	20-Mar-22	MYSURU	220	KADAKOLA-CR NAGARA 2	NO STATIONS EFFECTED	10:01	14:24	4:22	LINE CLEAR AVAILED
1622	20-Mar-22	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMNAVATTUR_66, YADAVANI_66	8:02	9:19	1:16	LINE CLEAR AVAILED
1623	20-Mar-22	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMNAVATTUR_66, YADAVANI_66	16:45	17:24	0:39	LINE CLEAR AVAILED
1624	20-Mar-22	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	18:44	20:17	1:32	LINE FAULT
1625	20-Mar-22	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	20:27	20:30	0:03	LINE CLEAR AVAILED
1626	20-Mar-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:42	16:57	0:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1627	20-Mar-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:11	18:23	0:11	LINE FAULT
1628	20-Mar-22	TUMKUR	66	H D PURA- MMCLWINDMILL	HD PURA_66	6:11	6:29	0:17	LINE FAULT
1629	20-Mar-22	TUMKUR	66	HARIYABBE-CHIKKABANAGERE(P D KOTE)	HARIYABBE_66	6:20	8:10	1:50	LINE CLEAR AVAILED
1630	20-Mar-22	TUMKUR	66	HARIYABBE-CHIKKABANAGERE(P D KOTE)	HARIYABBE_66	20:39	20:44	0:04	LINE FAULT
1631	20-Mar-22	TUMKUR	66	HIREHALLI - BADDIHALLI(MELEKOTE)	MELEKOTE_66, BADDIHALLI_66	9:34	17:57	8:22	MAIN SUPPLY FAILURE
1632	20-Mar-22	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	1:57	2:11	0:14	LINE FAULT
1633	20-Mar-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	15:58	16:02	0:04	LINE FAULT
1634	20-Mar-22	TUMKUR	66	KDBVNP- TMTP	TMTP_66	9:10	16:35	7:25	LINE CLEAR AVAILED
1635	20-Mar-22	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	NAYAKANAHATTI_66	0:50	1:17	0:26	LINE FAULT
1636	20-Mar-22	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	NAYAKANAHATTI_66	21:08	21:30	0:22	LINE FAULT
1637	20-Mar-22	TUMKUR	66	PATTNAYAKANAHALLI-TAVAREKERE(SIRA)	PATTNAYAKANAHALLI_66	18:44	19:04	0:20	LINE FAULT
1638	20-Mar-22	TUMKUR	66	SIRA220-SIRA 3	SIRA_66	6:35	7:20	0:44	LINE FAULT
1639	20-Mar-22	TUMKUR	66	TMTP66-KIADBVNP220	TMTP_66	9:12	16:50	7:38	MAIN SUPPLY FAILURE
1640	20-Mar-22	TUMKUR	66	TMTP66-THOVINAKERE	THOVINAKERE_66	9:12	16:49	7:37	MAIN SUPPLY FAILURE
1641	20-Mar-22	TUMKUR	66	TR-1	BHARAMASAGARA	15:14	19:11	3:56	LINE CLEAR AVAILED
1642	20-Mar-22	TUMKUR	66	TR-1	KIADB V N PURA_220	9:08	16:49	7:41	LINE CLEAR AVAILED
1643	20-Mar-22	TUMKUR	66	TR-1	MAVINAKATTE_66	15:26	15:42	0:15	TRANSFORMER FAULT
1644	20-Mar-22	TUMKUR	66	TR-1	MYLANAHALLI	13:55	14:01	0:05	TRANSFORMER FAULT
1645	20-Mar-22	TUMKUR	66	TR-1(HV & LV)	TMTP_66	9:11	16:37	7:25	MAIN SUPPLY FAILURE
1646	20-Mar-22	TUMKUR	66	TR-2	CHANNAGIRI_66	2:07	2:25	0:18	TRANSFORMER FAULT
1647	20-Mar-22	TUMKUR	66	TR-2	CHANNAGIRI_66	2:49	2:58	0:09	TRANSFORMER FAULT
1648	20-Mar-22	TUMKUR	66	TR-2	KIADB V N PURA_220	9:08	16:39	7:30	LINE CLEAR AVAILED
1649	20-Mar-22	TUMKUR	66	TR-2(HV & LV)	TMTP_66	9:11	16:37	7:25	MAIN SUPPLY FAILURE
1650	20-Mar-22	TUMKUR	110	TR-2	NITTUR_220	0:12	0:24	0:11	TRANSFORMER FAULT
1651	20-Mar-22	TUMKUR	220	KDBVNP- MADHUGIRI220	MADHUGIRI_220	8:47	16:28	7:40	LINE CLEAR AVAILED
1652	20-Mar-22	TUMKUR	220	KDBVNP_PGCL	KDBVNP_220	9:52	16:58	7:05	LINE CLEAR AVAILED
1653	20-Mar-22	TUMKUR	220	MADHUGIRI 220kv-PVGD1(KIADBVNP220)	MADHUGIRI_220	8:47	16:27	7:40	NFBC ISSUED
1654	20-Mar-22	TUMKUR	220	TR-1	KDBVNP_220	9:11	16:32	7:20	LINE CLEAR AVAILED
1655	20-Mar-22	TUMKUR	220	TR-2	KDBVNP_220	9:09	16:32	7:22	LINE CLEAR AVAILED
1656	21-Mar-22	BAGALKOT	110	110/11KV, HV1	CHIKKODI_110	10:50	14:40	3:50	LINE CLEAR AVAILED
1657	21-Mar-22	BAGALKOT	110	110/11KV, HV1	KATARKI_110	18:25	19:25	1:00	LINE CLEAR AVAILED
1658	21-Mar-22	BAGALKOT	110	110/11KV, HV1	PH COMPOUND_110	12:07	12:31	0:24	LINE CLEAR AVAILED
1659	21-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TAKKALAKI_110	6:31	7:30	0:59	HAND TRIPPED
1660	21-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TOLAMATTI_110	18:31	19:23	0:52	LINE CLEAR AVAILED
1661	21-Mar-22	BAGALKOT	110	110/11KV, HV1	UCHAGOAN_110	10:37	16:54	6:17	LINE CLEAR AVAILED
1662	21-Mar-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	9:54	9:55	0:01	TRANSFORMER FAULT
1663	21-Mar-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	10:36	10:55	0:19	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1664	21-Mar-22	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	2:33	2:57	0:24	TRANSFORMER FAULT
1665	21-Mar-22	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	9:00	9:26	0:26	TRANSFORMER FAULT
1666	21-Mar-22	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	10:47	10:49	0:02	TRANSFORMER FAULT
1667	21-Mar-22	BAGALKOT	110	110/11KV,HV2	MANTUR(G)_110	12:36	12:44	0:08	TRANSFORMER FAULT
1668	21-Mar-22	BAGALKOT	110	110/11KV,HV4	LAKAMANAHALLI_110	11:50	17:20	5:30	LINE CLEAR AVAILED
1669	21-Mar-22	BAGALKOT	110	110/33KV,HV2	BISANAL_110	14:56	15:04	0:08	TRANSFORMER FAULT
1670	21-Mar-22	BAGALKOT	110	110/33KV,HV2	MATTIHAL_110, KOLAR W/S_33, KARJOL LIS_33	16:27	17:35	1:08	LINE CLEAR AVAILED
1671	21-Mar-22	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110 & RUSTUM PUR & BGM W/S_33	14:58	16:51	1:53	LINE CLEAR AVAILED
1672	21-Mar-22	BAGALKOT	110	110/33KV,HV4	GOPANAKOPPA_110	16:00	17:24	1:24	LINE CLEAR AVAILED
1673	21-Mar-22	BAGALKOT	110	BIJAPUR220-KIADB 2	KIADB BIJAPUR_110	18:48	18:57	0:09	LINE FAULT
1674	21-Mar-22	BAGALKOT	110	BIJAPUR220-KIADB2	BIJAPUR_220	18:48	18:57	0:09	LINE FAULT
1675	21-Mar-22	BAGALKOT	110	CHIKKODI220-CHIKKODI 110	CHIKKODI110	10:52	15:09	4:17	LINE CLEAR AVAILED
1676	21-Mar-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)	16:50 (21.03.2022)	2305:08 hrs	LINE CHARGED
1677	21-Mar-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
1678	21-Mar-22	BAGALKOT	110	INDI220- ZALKI1	INDI_220	15:06	15:12	0:06	LINE FAULT
1679	21-Mar-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1680	21-Mar-22	BAGALKOT	110	TADASINAKOPPA-KUD DHARWAD(GAMANAGATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	12:15	18:11	5:56	LINE CLEAR AVAILED
1681	21-Mar-22	BAGALKOT	110	TAKKALAKI-KN SOLAR	KN SOLAR_110 TAKKALAKI_110	18:52	19:08	0:16	HAND TRIPPED
1682	21-Mar-22	BAGALKOT	110	VAJRAMATTI220- KATARKI	KATARKI_110	13:54	13:59	0:05	LINE FAULT
1683	21-Mar-22	BAGALKOT	110	VAJRAMATTI220- SHIRAGUPPI	SHIRAGUPPI_110	13:55	14:05	0:10	LINE FAULT
1684	21-Mar-22	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	16:05 (08.03.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1685	21-Mar-22	BAGALKOT	220	AMBEWADI NAGJHARI2	AMBEWADI_220	10:12	13:34	3:22	LINE CLEAR AVAILED
1686	21-Mar-22	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1687	21-Mar-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1688	21-Mar-22	BAGALKOT	220	BIDNAL-NAGJHARI2	BIDNAL_220	23:31 (21.03.2022)			LINE OPEN:LINE FAULT
1689	21-Mar-22	BAGALKOT	220	CHIKKODI- BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	10:42 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1690	21-Mar-22	BAGALKOT	220	CHIKKODI- BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:43 (11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1691	21-Mar-22	BAGALKOT	220	CHIKKODI- GHATAPRABHA2(KUDACHI2)	STATION NOT AFFECTED CHIKKODI_220	17:55 (21.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1692	21-Mar-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
1693	21-Mar-22	BAGALKOT	220	CHIKKODI- KUDACHI1	STATION NOT AFFECTED CHIKKODI_220	17:55 (21.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1694	21-Mar-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1695	21-Mar-22	BAGALKOT	220	HAVERI-GUTTUR1	HAVERI_220	11:11	14:11	3:00	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1696	21-Mar-22	BAGALKOT	220	KUDUCHI-CHIKKODI1	KUDUCHI_220	17:54 (21.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1697	21-Mar-22	BAGALKOT	220	KUDUCHI-CHIKKODI2	KUDUCHI_220	17:55 (21.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1698	21-Mar-22	BAGALKOT	220	NARENDRA-BELUR1	NARENDRA_220	11:36	13:15	1:39	LINE CLEAR AVAILED
1699	21-Mar-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	10:13 (12.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1700	21-Mar-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	10:14 (12.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1701	21-Mar-22	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA	6:19	6:22	0:03	LOAD CHANGEOVER
1702	21-Mar-22	BENGALURU	66	AVANI - MULBAGLU	MULBAGAL	11:00	13:44	2:44	LINE CLEAR AVAILED
1703	21-Mar-22	BENGALURU	66	BAGMANE WTP - ITI 220	BAGMANE WTP	13:42	13:50	0:08	LOAD CHANGEOVER
1704	21-Mar-22	BENGALURU	66	BEGUR 220 - BIAL 1	NO STATION AFFECTED	16:43	17:34	0:51	MAIN SUPPLY FAILURE
1705	21-Mar-22	BENGALURU	66	BEGUR 220 - BIAL 1	NO STATION AFFECTED	20:14	21:01	0:47	MAIN SUPPLY FAILURE
1706	21-Mar-22	BENGALURU	66	BEGUR 220 - BIAL 2	AIRPORT	16:43	17:36	0:53	MAIN SUPPLY FAILURE
1707	21-Mar-22	BENGALURU	66	BEGUR 220 - BIAL 2	AIRPORT	20:14	20:34	0:20	MAIN SUPPLY FAILURE
1708	21-Mar-22	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	16:43	17:20	0:37	MAIN SUPPLY FAILURE
1709	21-Mar-22	BENGALURU	66	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	16:43	17:42	0:59	MAIN SUPPLY FAILURE
1710	21-Mar-22	BENGALURU	66	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	20:14	20:58	0:44	MAIN SUPPLY FAILURE
1711	21-Mar-22	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	16:43	17:42	0:59	MAIN SUPPLY FAILURE
1712	21-Mar-22	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	20:14	20:56	0:42	MAIN SUPPLY FAILURE
1713	21-Mar-22	BENGALURU	66	BEGUR 220 - VIDYANAGAR	VIDYANAGAR, HENNUR CROSS	16:43	17:40	0:57	MAIN SUPPLY FAILURE
1714	21-Mar-22	BENGALURU	66	BEGUR 220 - VIDYANAGAR	VIDYANAGAR, HENNUR CROSS	20:14	20:43	0:29	MAIN SUPPLY FAILURE
1715	21-Mar-22	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	16:39	17:20	0:41	MAIN SUPPLY FAILURE
1716	21-Mar-22	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	20:15	21:25	1:10	MAIN SUPPLY FAILURE
1717	21-Mar-22	BENGALURU	66	BOODIGERE - HOSKOTE 220	BOODIGERE	17:30	17:40	0:10	LOAD CHANGEOVER
1718	21-Mar-22	BENGALURU	66	C STATION 1 & 2 - A STATION 220	C STATION 1 & 2	6:40	6:45	0:05	LOAD CHANGEOVER
1719	21-Mar-22	BENGALURU	66	GOLF LINK - HAL 220	GOLF LINK	15:05	15:10	0:05	LOAD CHANGEOVER
1720	21-Mar-22	BENGALURU	66	GOLF LINK - KORAMANGALA 220	GOLF LINK	17:20	18:25	1:05	MAIN SUPPLY FAILURE
1721	21-Mar-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	16:45	17:10	0:25	LINE CLEAR AVAILED
1722	21-Mar-22	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	7:53	7:57	0:04	LOAD CHANGEOVER
1723	21-Mar-22	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	13:47	14:04	0:17	MAIN SUPPLY FAILURE
1724	21-Mar-22	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	16:39	16:56	0:17	MAIN SUPPLY FAILURE
1725	21-Mar-22	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	17:56	18:00	0:04	LOAD CHANGEOVER
1726	21-Mar-22	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	20:13	20:23	0:10	MAIN SUPPLY FAILURE
1727	21-Mar-22	BENGALURU	66	HOODY 220 - BMRCL (EHT)	NO STATION AFFECTED	19:55(22/03/2022)			LINE OPEN:LINE FAULT
1728	21-Mar-22	BENGALURU	66	HOSKOTE 220 - BIAL BEGUR 220	NO STATION AFFECTED	20:12	21:03	0:51	MAIN SUPPLY FAILURE
1729	21-Mar-22	BENGALURU	66	HOSKOTE 220 - BOODIGERE	BOODIGERE	20:12	21:03	0:51	MAIN SUPPLY FAILURE
1730	21-Mar-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	20:12	20:58	0:46	MAIN SUPPLY FAILURE
1731	21-Mar-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	BELL CERAMICS (EHT)	20:12	20:56	0:44	MAIN SUPPLY FAILURE
1732	21-Mar-22	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	20:12	20:58	0:46	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1733	21-Mar-22	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	20:12	20:47	0:35	MAIN SUPPLY FAILURE
1734	21-Mar-22	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	20:12	20:53	0:41	MAIN SUPPLY FAILURE
1735	21-Mar-22	BENGALURU	66	HV1	AMAR JYOTHI	17:21	18:21	1:00	MAIN SUPPLY FAILURE
1736	21-Mar-22	BENGALURU	66	HV1	AMAR JYOTHI	18:35	20:44	2:09	MAIN SUPPLY FAILURE
1737	21-Mar-22	BENGALURU	66	HV1	AMAR JYOTHI	21:08	21:09	0:01	MAIN SUPPLY FAILURE
1738	21-Mar-22	BENGALURU	66	HV1	BIAL BEGUR 220	16:43	17:34	0:51	MAIN SUPPLY FAILURE
1739	21-Mar-22	BENGALURU	66	HV1	BIAL BEGUR 220	20:14	20:38	0:24	MAIN SUPPLY FAILURE
1740	21-Mar-22	BENGALURU	66	HV1	BTM 4TH PHASE	11:02	16:38	5:36	LINE CLEAR AVAILED
1741	21-Mar-22	BENGALURU	66	HV1	CB PURA I/A	16:53	17:45	0:52	TRANSFORMER FAULT
1742	21-Mar-22	BENGALURU	66	HV1	CB PURA I/A	17:45	17:53	0:08	TRANSFORMER FAULT
1743	21-Mar-22	BENGALURU	66	HV1	ELECTRONIC CITY	11:25	13:41	2:16	LINE CLEAR AVAILED
1744	21-Mar-22	BENGALURU	66	HV1	HUKUNDA	23:38	23:41	0:03	TRANSFORMER FAULT
1745	21-Mar-22	BENGALURU	66	HV1	ITI 220	13:40	14:25	0:45	LINE CLEAR AVAILED
1746	21-Mar-22	BENGALURU	66	HV1	JIGANI 220	10:33	10:42	0:09	TRANSFORMER FAULT
1747	21-Mar-22	BENGALURU	66	HV1	KHODAYS 220	10:55	11:00	0:05	LOAD CHANGE OVER
1748	21-Mar-22	BENGALURU	66	HV1	KHODAYS 220	14:30	14:35	0:05	LOAD CHANGE OVER
1749	21-Mar-22	BENGALURU	66	HV1	KOLAR 220	22:35	22:45	0:10	MAIN SUPPLY FAILURE
1750	21-Mar-22	BENGALURU	66	HV1	KORAMANGALA 220	9:41	9:47	0:06	LOAD CHANGE OVER
1751	21-Mar-22	BENGALURU	66	HV1	MATHIKERE NELAMANAGALA	9:20	9:25	0:05	TRANSFORMER FAULT
1752	21-Mar-22	BENGALURU	66	HV1	MATHIKERE NELAMANGALA	6:20	6:29	0:09	TRANSFORMER FAULT
1753	21-Mar-22	BENGALURU	66	HV1	PALLICHERLU	17:51	18:03	0:12	TRANSFORMER FAULT
1754	21-Mar-22	BENGALURU	66	HV1	PALLICHERLU	13:05	13:18	0:13	LINE CLEAR AVAILED
1755	21-Mar-22	BENGALURU	66	HV1	SANKALGERE	9:45	9:58	0:13	LINE CLEAR AVAILED
1756	21-Mar-22	BENGALURU	66	HV1	T GOLLAHALI 220	12:54	15:02	2:08	LINE CLEAR AVAILED
1757	21-Mar-22	BENGALURU	66	HV2	AMAR JYOTHI	20:44	20:56	0:12	LOAD CHANGE OVER
1758	21-Mar-22	BENGALURU	66	HV2	BANASAWADI	13:40	14:02	0:22	LINE CLEAR AVAILED
1759	21-Mar-22	BENGALURU	66	HV2	BANASAWADI	14:36	14:41	0:05	LOAD CHANGE OVER
1760	21-Mar-22	BENGALURU	66	HV2	BIAL BEGUR 220	16:43	17:39	0:56	MAIN SUPPLY FAILURE
1761	21-Mar-22	BENGALURU	66	HV2	BIAL BEGUR 220	20:14	20:43	0:29	MAIN SUPPLY FAILURE
1762	21-Mar-22	BENGALURU	66	HV2	BTM 4TH PHASE	11:02	16:38	5:36	LINE CLEAR AVAILED
1763	21-Mar-22	BENGALURU	66	HV2	EXORA	17:30	17:35	0:05	TRANSFORMER FAULT
1764	21-Mar-22	BENGALURU	66	HV2	EXORA	20:42	20:47	0:05	TRANSFORMER FAULT
1765	21-Mar-22	BENGALURU	66	HV2	ITI 220	13:40	14:25	0:45	LINE CLEAR AVAILED
1766	21-Mar-22	BENGALURU	66	HV2	KHODAYS 220	10:55	11:00	0:05	LOAD CHANGE OVER
1767	21-Mar-22	BENGALURU	66	HV2	KHODAYS 220	14:30	14:35	0:05	LOAD CHANGE OVER
1768	21-Mar-22	BENGALURU	66	HV2	KIADB DB PURA 220	11:07	11:19	0:11	TRANSFORMER FAULT
1769	21-Mar-22	BENGALURU	66	HV2	KOLAR 220	22:35	22:45	0:10	MAIN SUPPLY FAILURE
1770	21-Mar-22	BENGALURU	66	HV2	KORAMANGALA 220	9:41	9:47	0:06	LOAD CHANGE OVER
1771	21-Mar-22	BENGALURU	66	HV2	MALLASANDRA	13:01	13:15	0:13	TRANSFORMER FAULT
1772	21-Mar-22	BENGALURU	66	HV2	REMCO	20:49	21:12	0:23	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1773	21-Mar-22	BENGALURU	66	HV2	VIJAYPURA	16:00	16:05	0:05	LINE CLEAR AVAILED
1774	21-Mar-22	BENGALURU	66	HV3	ITI 220	13:40	14:25	0:45	LINE CLEAR AVAILED
1775	21-Mar-22	BENGALURU	66	ITI 220 - BAGHMANE WORLD TECH PARK	BAGHMANE WORLD TECH PARK	13:40	13:53	0:13	LINE CLEAR AVAILED
1776	21-Mar-22	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	13:40	14:25	0:45	LINE CLEAR AVAILED
1777	21-Mar-22	BENGALURU	66	ITI 220 - NGEF	NGEF, NGEF(EHT)	13:40	14:25	0:45	LINE CLEAR AVAILED
1778	21-Mar-22	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	10:55	11:00	0:05	LOAD CHANGEOVER
1779	21-Mar-22	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	14:30	14:35	0:05	LOAD CHANGEOVER
1780	21-Mar-22	BENGALURU	66	KHODAYS 220 - SOUTH CITY	SOUTH CITY	10:55	11:00	0:05	LOAD CHANGEOVER
1781	21-Mar-22	BENGALURU	66	KHODAYS 220 - SOUTH CITY	SOUTH CITY	14:30	14:35	0:05	LOAD CHANGEOVER
1782	21-Mar-22	BENGALURU	66	KIADB HARDWARE PARK 220 - BPH(EHT)	BPH(EHT)	20:12	20:48	0:36	MAIN SUPPLY FAILURE
1783	21-Mar-22	BENGALURU	66	KIADB HARDWARE PARK 220 - SHELL(EHT)	SHELL(EHT)	20:12	20:47	0:35	MAIN SUPPLY FAILURE
1784	21-Mar-22	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NO STATION AFFECTED	22:35	22:46	0:11	MAIN SUPPLY FAILURE
1785	21-Mar-22	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	22:35	22:47	0:12	MAIN SUPPLY FAILURE
1786	21-Mar-22	BENGALURU	66	KOLAR 220 - PGCIL AUX	PGCIL AUX, SUGUTUR	22:34	22:42	0:08	MAIN SUPPLY FAILURE
1787	21-Mar-22	BENGALURU	66	KOLAR 220 - PGCIL AUX	PGCIL AUX, SUGUTUR	8:01	8:38	0:36	LINE FAULT
1788	21-Mar-22	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	22:35	22:44	0:09	MAIN SUPPLY FAILURE
1789	21-Mar-22	BENGALURU	66	KONDASPURA - EPIP 220	KONDASPURA	17:40	17:50	0:10	LOAD CHANGEOVER
1790	21-Mar-22	BENGALURU	66	KONDASPURA - HOSKOTE 220	KONDASPURA	19:18	19:23	0:05	LOAD CHANGEOVER
1791	21-Mar-22	BENGALURU	66	KORAMANGALA 220 - AUSTIN TOWN 1	NO STATION AFFECTED	17:03	18:28	1:25	LINE FAULT
1792	21-Mar-22	BENGALURU	66	KORAMANGALA 220 - AUSTIN TOWN 2	NO STATION AFFECTED	17:02	18:20	1:18	LINE FAULT
1793	21-Mar-22	BENGALURU	66	KORAMANGALA 220 - GOLF LINK HAL 1	AMARIYOTHI	17:21	18:15	0:54	LINE FAULT
1794	21-Mar-22	BENGALURU	66	KORAMANGALA 220 - GOLF LINK HAL 1	AMARIYOTHI	18:15	20:54	2:39	LINE FAULT
1795	21-Mar-22	BENGALURU	66	KORAMANGALA 220 - GOLF LINK HAL 2	NO STATION AFFECTED	6:57	7:58	1:01	LINE CLEAR AVAILED
1796	21-Mar-22	BENGALURU	66	KORMANGALA 220 - GOLF LINK HAL 1	NO STATION AFFECTED	21:08(21/03/2022)			LINE OPEN:LINE FAULT
1797	21-Mar-22	BENGALURU	66	KORMANGALA 220 - GOLF LINK HAL 1	NO STATION AFFECTED	21:08(21/03/2022)	14:32(22/03/2022)	17:24HRS	LINE CHARGED
1798	21-Mar-22	BENGALURU	66	LEELA VENTURE - HAL 2 220	LEELA VENTURE	15:01	15:05	0:04	MAIN SUPPLY FAILURE
1799	21-Mar-22	BENGALURU	66	LR BANDE - HBR LAYOUT	LR BANDE	15:00	15:04	0:04	LOAD CHANGEOVER
1800	21-Mar-22	BENGALURU	66	LV1	MAGADI 220	20:02	20:27	0:24	MAIN SUPPLY FAILURE
1801	21-Mar-22	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARAMAHALLI, HOSPALYA	20:22	20:31	0:09	MAIN SUPPLY FAILURE
1802	21-Mar-22	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	20:22	20:28	0:06	MAIN SUPPLY FAILURE
1803	21-Mar-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	19:15	19:22	0:07	LINE FAULT
1804	21-Mar-22	BENGALURU	66	MANYATHA TECH PARK 220 - BYATRAYANAPURA	BYATRAYANAPURA	13:40	14:12	0:32	LINE CLEAR AVAILED
1805	21-Mar-22	BENGALURU	66	MANYATHA TECH PARK 220 - SHOBHA CITY	SHOBHA CITY	13:40	14:12	0:32	LINE CLEAR AVAILED
1806	21-Mar-22	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	21:42	21:52	0:09	LINE FAULT
1807	21-Mar-22	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	15:31	15:34	0:03	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1808	21-Mar-22	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	13:14	13:22	0:08	LINE CLEAR AVAILED
1809	21-Mar-22	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	8:12	8:17	0:05	LOAD CHANGEOVER
1810	21-Mar-22	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	13:09	13:13	0:04	LOAD CHANGEOVER
1811	21-Mar-22	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	21:05	21:12	0:07	LOAD CHANGEOVER
1812	21-Mar-22	BENGALURU	66	POTTERY ROAD - HEBBALA 220	POTTERY ROAD	14:40	14:45	0:05	LOAD CHANGEOVER
1813	21-Mar-22	BENGALURU	66	POTTERY ROAD - ITI 220	POTTERY ROAD	13:40	13:57	0:17	MAIN SUPPLY FAILURE
1814	21-Mar-22	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	20:49	21:18	0:29	MAIN SUPPLY FAILURE
1815	21-Mar-22	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	23:50	23:53	0:03	LOAD CHANGEOVER
1816	21-Mar-22	BENGALURU	66	SIDLAGATTA - MELUR	MELUR	10:49	11:44	0:55	LINE CLEAR AVAILED
1817	21-Mar-22	BENGALURU	66	SOMENAHALLI - AFTL SOLAR IPP	NO STATION AFFECTED	21:42	22:11	0:29	LINE FAULT
1818	21-Mar-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	RR NAGAR, REMCO, GLOBAL VILLAGE (EHT)	20:49	21:18	0:29	LINE FAULT
1819	21-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	15:18	18:15	2:57	LOAD CHANGEOVER
1820	21-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML	15:14	18:20	3:06	LOAD CHANGEOVER
1821	21-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	11:40	11:45	0:05	LOAD CHANGEOVER
1822	21-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	13:35	13:40	0:05	LOAD CHANGEOVER
1823	21-Mar-22	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	12:15	12:32	0:17	LINE CLEAR AVAILED
1824	21-Mar-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR, K HONALGERE, YATHAMBADI	12:15	12:32	0:17	LINE CLEAR AVAILED
1825	21-Mar-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	17:01	17:12	0:11	LINE FAULT
1826	21-Mar-22	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	17:01	17:14	0:13	LINE FAULT
1827	21-Mar-22	BENGALURU	220	BIAL BEGUR 220 - HOODY 220	NO STATION AFFECTED	16:40	17:25	0:45	MAIN SUPPLY FAILURE
1828	21-Mar-22	BENGALURU	220	BIAL BEGUR 220 - HOODY 220	NO STATION AFFECTED	20:14	20:30	0:16	LINE FAULT
1829	21-Mar-22	BENGALURU	220	BIAL BEGUR 220 - KIADB HARDWARE PARK 1	NO STATION AFFECTED	16:39	21:57	5:18	LINE FAULT
1830	21-Mar-22	BENGALURU	220	BIAL BEGUR 220 - KIADB HARDWARE PARK 2	BIAL BEGUR 220	16:43	17:20	0:37	LINE FAULT
1831	21-Mar-22	BENGALURU	220	BIAL BEGUR 220 - KIADB HARDWARE PARK 2	BIAL BEGUR 220	20:14	20:30	0:16	LINE FAULT
1832	21-Mar-22	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	12:10	18:45	6:35	LOAD CURTAILMENT
1833	21-Mar-22	BENGALURU	220	DEVANAHALLI 400 - DEVANAHALLI 1	NO STATION AFFECTED	16:39	21:09	4:30	LINE FAULT
1834	21-Mar-22	BENGALURU	220	DEVANAHALLI 400 - DEVANAHALLI 2	KIADB HARDWARE PARK 220	20:12	20:38	0:26	LINE FAULT
1835	21-Mar-22	BENGALURU	220	HOODY 220 - BIAL BEGUR 220	NO STATION AFFECTED	16:39	17:17	0:38	LINE FAULT
1836	21-Mar-22	BENGALURU	220	HOODY 220 - BIAL BEGUR 220	NO STATION AFFECTED	20:13	20:30	0:17	LINE FAULT
1837	21-Mar-22	BENGALURU	220	HOODY 220 - ITI 220	MANYATHA TECH PARK 220, ITI 220	13:40	14:42	1:02	LINE CLEAR AVAILED
1838	21-Mar-22	BENGALURU	220	HV1	BIAL BEGUR 220	16:43	17:32	0:49	MAIN SUPPLY FAILURE
1839	21-Mar-22	BENGALURU	220	HV1	BIAL BEGUR 220	20:14	20:32	0:18	MAIN SUPPLY FAILURE
1840	21-Mar-22	BENGALURU	220	HV1	HOSKOTE 220	20:12	20:48	0:36	MAIN SUPPLY FAILURE
1841	21-Mar-22	BENGALURU	220	HV1	KIADB HARDWARE PARK 220	20:12	20:43	0:31	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1842	21-Mar-22	BENGALURU	220	HV1	MAGADI 220	20:02	20:26	0:24	TRANSFORMER FAULT
1843	21-Mar-22	BENGALURU	220	HV2	BIAL BEGUR 220	16:43	17:33	0:50	MAIN SUPPLY FAILURE
1844	21-Mar-22	BENGALURU	220	HV2	BIAL BEGUR 220	20:14	20:32	0:18	MAIN SUPPLY FAILURE
1845	21-Mar-22	BENGALURU	220	HV2	HOSKOTE 220	20:12	20:52	0:40	MAIN SUPPLY FAILURE
1846	21-Mar-22	BENGALURU	220	HV2	KIADB HARDWARE PARK 220	20:12	20:44	0:32	MAIN SUPPLY FAILURE
1847	21-Mar-22	BENGALURU	220	HV2	TK HALLI 220	12:15	12:27	0:12	TRANSFORMER FAULT
1848	21-Mar-22	BENGALURU	220	ITI 220 - MANYATHA TECH PARK 220	ITI 220	13:40	14:25	0:45	MAIN SUPPLY FAILURE
1849	21-Mar-22	BENGALURU	220	KIADB HARDWARE PARK 220 - BIAL BEGUR 1	BIAL BEGUR 220	16:39	21:57	5:18	LINE FAULT
1850	21-Mar-22	BENGALURU	220	KIADB HARDWARE PARK 220 - BIAL BEGUR 2	BIAL BEGUR 220	16:43	17:03	0:20	LINE FAULT
1851	21-Mar-22	BENGALURU	220	KIADB HARDWARE PARK 220 - HOSKOTE 1	HOSKOTE 220	20:12	20:45	0:33	MAIN SUPPLY FAILURE
1852	21-Mar-22	BENGALURU	220	KIADB HARDWARE PARK 220 - HOSKOTE 2	HOSKOTE 220	20:12	20:46	0:34	MAIN SUPPLY FAILURE
1853	21-Mar-22	BENGALURU	220	LV2	KOLAR 220	22:34	22:43	0:09	LINE CLEAR AVAILED
1854	21-Mar-22	BENGALURU	220	MANYATHA TECH PARK 220 - HOODY 220	MANYATHA TECH PARK 220	13:40	14:12	0:32	MAIN SUPPLY FAILURE
1855	21-Mar-22	GULBARGA	66	HV2	HALVAGALU_66	19:15	19:20	0:05	TRANSFORMER FAULT
1856	21-Mar-22	GULBARGA	66	HV2	PUNABGHATA_66	2:15	2:20	0:05	LINE CLEAR AVAILED
1857	21-Mar-22	GULBARGA	66	MAGALA-HIREHADAGALLI	MAGALA_66	13:00	14:54	1:54	LINE CLEAR AVAILED
1858	21-Mar-22	GULBARGA	110	BISILAHALLI-ALIPUR	BISILAHALLI_110	2:36	2:50	0:14	MAIN SUPPLY FAILURE
1859	21-Mar-22	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	2:36	2:50	0:14	MAIN SUPPLY FAILURE
1860	21-Mar-22	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	16:20	17:03	0:43	LINE CLEAR AVAILED
1861	21-Mar-22	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	17:43	18:40	0:57	LINE CLEAR AVAILED
1862	21-Mar-22	GULBARGA	110	HALBARAGA-KOLHAR2	KOLHAR_110,JANAWADA_110,NSSK SUGAR FACTORY	15:25	16:55	1:30	LINE CLEAR AVAILED
1863	21-Mar-22	GULBARGA	110	HATTI-SOMMANMARDI	HATTI_110	22:33	22:37	0:04	LINE FAULT
1864	21-Mar-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	18:58	19:20	0:22	LINE FAULT
1865	21-Mar-22	GULBARGA	110	HV1	MANVI_110	17:28(20.03.2022)	16:30(21.03.2022)	23:02 hrs	TRANSFORMER CHARGED
1866	21-Mar-22	GULBARGA	110	HV1	MANVI_110	17:36	18:23	0:47	LINE CLEAR AVAILED
1867	21-Mar-22	GULBARGA	110	HV1	MATAMARI_110	11:30	11:45	0:15	TRANSFORMER FAULT
1868	21-Mar-22	GULBARGA	110	HV2	JEEWARGI_110	15:00	15:20	0:20	LINE CLEAR AVAILED
1869	21-Mar-22	GULBARGA	110	HV2	MANVI_110	8:50	9:26	0:36	LINE CLEAR AVAILED
1870	21-Mar-22	GULBARGA	110	HV2	YELBURGA_110	10:31	16:50	6:19	LINE CLEAR AVAILED
1871	21-Mar-22	GULBARGA	110	HV3	KEMBHAVI_110	11:25	15:10	3:45	LINE CLEAR AVAILED
1872	21-Mar-22	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	11:05	18:45	7:40	LINE CLEAR AVAILED
1873	21-Mar-22	GULBARGA	110	MATAMARI-RAICHUR	MATAMARI_110	18:50	19:05	0:15	MAIN SUPPLY FAILURE
1874	21-Mar-22	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUR_110,MASKI_110	11:15	16:45	5:30	LINE CLEAR AVAILED
1875	21-Mar-22	GULBARGA	110	RAICHUR-MATMARI	MATMARI_110	18:15	19:00	0:45	LOAD CURTAILMENT
1876	21-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,GABBUR_110	18:57	19:02	0:05	LOAD CURTAILMENT
1877	21-Mar-22	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI_110	18:57	19:03	0:06	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1878	21-Mar-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
1879	21-Mar-22	GULBARGA	110	SHAHABAD-FARATHABAD	FARTHABAD_110,GULBARGA SOUTH_110	14:25	14:30	0:05	LOAD CURTAILMENT
1880	21-Mar-22	GULBARGA	110	SHAHABAD-FARATHABAD	FARTHABAD_110,GULBARGA SOUTH_110	14:30	14:40	0:10	LINE FAULT
1881	21-Mar-22	GULBARGA	110	SHAHABAD-FARATHABAD	FARTHABAD_110,GULBARGA SOUTH_110	14:50	14:58	0:08	LOAD CURTAILMENT
1882	21-Mar-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEEWARAGI_110	19:44(21.03.2022)			LOAD CURTAILMENT
1883	21-Mar-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP,H UNASIGI_110,ASKI_110	2:16	2:22	0:06	LINE FAULT
1884	21-Mar-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WA DAGERA_110,SANNATHI_IPP,COREG REENSUGARS_IPP	5:14	5:18	0:04	LINE FAULT
1885	21-Mar-22	GULBARGA	110	SHAHPUR-YADGIRI	YADGIRI_110	18:02(20/03/2022)	12:43 (21.03.2022)	18:41 HRS	LINE CHARGED
1886	21-Mar-22	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110,MUDDAPUR_11 0,MASKI_110,VALAKAMADINNI_110	12:36	14:01	1:25	LINE CLEAR AVAILED
1887	21-Mar-22	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110,KUKUNOOR_110	16:10	16:45	0:35	LINE CLEAR AVAILED
1888	21-Mar-22	GULBARGA	220	HV1	SHAHBAD_220	10:05(19.03.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1889	21-Mar-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1890	21-Mar-22	GULBARGA	220	HV2	RAICHUR_220	10:49	18:56	8:07	LINE CLEAR AVAILED
1891	21-Mar-22	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	0:04	0:23	0:19	LINE FAULT
1892	21-Mar-22	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	15:04	15:57	0:53	MAIN SUPPLY FAILURE
1893	21-Mar-22	HASSAN	66	CHANNARA-MALLALI	CHANNARAYAPATNA_66	15:03	15:55	0:52	MAIN SUPPLY FAILURE
1894	21-Mar-22	HASSAN	66	CHANNARA-UDAYAPURA	CHANNARAYAPATNA_66	15:03	15:54	0:51	MAIN SUPPLY FAILURE
1895	21-Mar-22	HASSAN	66	CHIKABO-SIDPR	CHIKABOMENAHALLY_66	7:37	7:46	0:09	LINE FAULT
1896	21-Mar-22	HASSAN	66	CRPATNA2-CHMUNDSUG	CHANNARAYAPATNA_220	15:02	15:56	0:54	MAIN SUPPLY FAILURE
1897	21-Mar-22	HASSAN	66	CRPATNA2-CRPTNA1	CHANNARAYAPATNA_220	15:02	15:48	0:46	MAIN SUPPLY FAILURE
1898	21-Mar-22	HASSAN	66	CRPATNA2-CRPTNA2	CHANNARAYAPATNA_220	15:02	15:48	0:46	MAIN SUPPLY FAILURE
1899	21-Mar-22	HASSAN	66	CRPATNA2-HNPURA	CHANNARAYAPATNA_220	15:02	15:51	0:49	MAIN SUPPLY FAILURE
1900	21-Mar-22	HASSAN	66	CRPATNA2-MATTANAVILE	CHANNARAYAPATNA_220	10:05	10:15	0:10	LINE FAULT
1901	21-Mar-22	HASSAN	66	CRPATNA2-MATTANAVILE	CHANNARAYAPATNA_220	15:02	15:50	0:48	MAIN SUPPLY FAILURE
1902	21-Mar-22	HASSAN	66	CRPATNA2-SBELAGOLA	CHANNARAYAPATNA_220	10:05	10:17	0:12	LINE FAULT
1903	21-Mar-22	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLY_66	8:39	21:17	12:38	LINE FAULT
1904	21-Mar-22	HASSAN	66	HASSN22-UDDURKOPLU	HASSN_220	8:42	9:47	1:05	LINE FAULT
1905	21-Mar-22	HASSAN	66	HNPR2-HASS2	HOLENARSIPURA_220	13:47	13:55	0:08	LINE FAULT
1906	21-Mar-22	HASSAN	66	HNPR2-HASS3	HOLENARSIPURA_220	12:02	13:32	1:30	LINE CLEAR AVAILED
1907	21-Mar-22	HASSAN	66	HNPR2-RNPR1	HOLENARSIPURA_220	15:12	15:17	0:05	HAND TRIPPED
1908	21-Mar-22	HASSAN	66	HNPR2-RNPR1	HOLENARSIPURA_220	17:04	17:12	0:08	HAND TRIPPED
1909	21-Mar-22	HASSAN	66	HV1	ARAKALGUD_66	9:17	9:48	0:31	LINE CLEAR AVAILED
1910	21-Mar-22	HASSAN	66	HV1	CHANNARAYAPATNA_220	15:02	15:38	0:36	MAIN SUPPLY FAILURE
1911	21-Mar-22	HASSAN	66	HV1	HOLENARSIPURA_220	10:47	13:52	3:05	LINE CLEAR AVAILED
1912	21-Mar-22	HASSAN	66	HV1	MOSALEHOSHALLY_66	11:36	13:50	2:14	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1913	21-Mar-22	HASSAN	66	HV1	SIGEBAGI_66	17:06	17:57	0:51	LINE CLEAR AVAILED
1914	21-Mar-22	HASSAN	66	HV2	CHANNARAYAPATNA_66	15:06	15:51	0:45	MAIN SUPPLY FAILURE
1915	21-Mar-22	HASSAN	66	HV2	HOLEHNNUR_66	15:32	15:52	0:20	TRANSFORMER FAULT
1916	21-Mar-22	HASSAN	66	HV2	SALAGAME_66	12:58	13:53	0:55	TRANSFORMER FAULT
1917	21-Mar-22	HASSAN	66	LV1	CHANNARAYAPATNA_220	15:02	23:33	8:31	MAIN SUPPLY FAILURE
1918	21-Mar-22	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSHALLY_66	11:36	13:50	2:14	LINE CLEAR AVAILED
1919	21-Mar-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE FAULT
1920	21-Mar-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE FAULT
1921	21-Mar-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	10:09	18:06	7:57	LINE FAULT
1922	21-Mar-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	10:10	17:46	7:36	LINE CLEAR AVAILED
1923	21-Mar-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	10:09	18:07	7:58	LINE FAULT
1924	21-Mar-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	10:10	17:46	7:36	LINE CLEAR AVAILED
1925	21-Mar-22	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	15:18	15:51	0:33	MAIN SUPPLY FAILURE
1926	21-Mar-22	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	15:57(21.03.2022)			LINE OPEN:LINE FAULT
1927	21-Mar-22	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	15:57(21.03.2022)	12:12(22.03.2022)	20:15HRS	LINE CHARGED
1928	21-Mar-22	HASSAN	66	UDDURKO-SUZLON	UDDURKOPPALU_66	8:42	9:51	1:09	MAIN SUPPLY FAILURE
1929	21-Mar-22	HASSAN	66	UDDURKO-UDDUR	UDDURKOPPALU_66	8:42	8:57	0:15	MAIN SUPPLY FAILURE
1930	21-Mar-22	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	9:07	13:00	3:53	LINE FAULT
1931	21-Mar-22	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	10:01	13:32	3:31	LINE CLEAR AVAILED
1932	21-Mar-22	HASSAN	110	HV1	HEGGUNJE_220	10:15	17:49	7:34	LINE CLEAR AVAILED
1933	21-Mar-22	HASSAN	110	HV1	JAVAGAL_110	20:17(20.3.2022)	3:12(21.3.2022)	6:55hrs	TRANSFORMER CHARGED
1934	21-Mar-22	HASSAN	110	HV1	JAVAGAL_110	13:27	13:32	0:05	HAND TRIPPED
1935	21-Mar-22	HASSAN	110	HV1	NANDIKUR_110	8:08	8:15	0:07	TRANSFORMER FAULT
1936	21-Mar-22	HASSAN	110	HV1	SHIVAPURA_110	10:32	11:11	0:39	TRANSFORMER FAULT
1937	21-Mar-22	HASSAN	110	HV1	SHIVAPURA_110	12:41	14:40	1:59	TRANSFORMER FAULT
1938	21-Mar-22	HASSAN	110	HV1	SHIVAPURA_110	10:26	13:15	2:49	LINE CLEAR AVAILED
1939	21-Mar-22	HASSAN	110	HV2	BHADRAVATY_110	10:34	11:36	1:02	LINE CLEAR AVAILED
1940	21-Mar-22	HASSAN	110	HV2	KEMAR_220	3:49	4:45	0:56	TRANSFORMER FAULT
1941	21-Mar-22	HASSAN	110	HV2	NERALEKERE_110	19:07	19:20	0:13	TRANSFORMER FAULT
1942	21-Mar-22	HASSAN	110	HV3	MANIPAL_110	10:11	13:40	3:29	LINE CLEAR AVAILED
1943	21-Mar-22	HASSAN	110	HV4	MANIPAL_110	10:53	11:10	0:17	LINE CLEAR AVAILED
1944	21-Mar-22	HASSAN	110	KADUR-TNGL	KADUR_220	10:15	15:04	4:49	LINE CLEAR AVAILED
1945	21-Mar-22	HASSAN	110	KADUR-YGTI	KADUR_220	13:31	14:05	0:34	HAND TRIPPED
1946	21-Mar-22	HASSAN	110	KAVOOR-Kulashkhara1	KAVOOR_220	9:14	17:25	8:11	LINE CLEAR AVAILED
1947	21-Mar-22	HASSAN	110	KAVOOR-Kulashkhara1	KAVOOR_220	17:07	17:25	0:18	HAND TRIPPED
1948	21-Mar-22	HASSAN	110	LV2	KADUR_220	10:20	14:50	4:30	LINE CLEAR AVAILED
1949	21-Mar-22	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	9:08	13:00	3:52	LINE FAULT
1950	21-Mar-22	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	10:03	13:37	3:34	NFBC ISSUED
1951	21-Mar-22	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	10:21	13:51	3:30	LINE CLEAR AVAILED
1952	21-Mar-22	HASSAN	110	NANDIKUR-ISTR	NANDIKUR_110	11:48	12:42	0:54	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1953	21-Mar-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	11:18	12:09	0:51	HAND TRIPPED
1954	21-Mar-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	11:18	12:13	0:55	HAND TRIPPED
1955	21-Mar-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:18	11:58	0:40	HAND TRIPPED
1956	21-Mar-22	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	11:18	12:08	0:50	HAND TRIPPED
1957	21-Mar-22	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	11:18	12:06	0:48	HAND TRIPPED
1958	21-Mar-22	HASSAN	110	SORABA-MAVALI	SORABA_110	18:45	23:55	5:10	MAIN SUPPLY FAILURE
1959	21-Mar-22	HASSAN	220	CRPATNA2-HSN400	CHANNARAYAPATNA_220	15:02	23:31	8:29	LINE FAULT
1960	21-Mar-22	HASSAN	220	GOPALPUR-HSN400	GOPALAPR	18:00	23:05	5:05	LINE FAULT
1961	21-Mar-22	HASSAN	220	HV1	CHANNARAYAPATNA_220	15:02	23:33	8:31	MAIN SUPPLY FAILURE
1962	21-Mar-22	HASSAN	220	HV2	KADUR_220	10:20	14:50	4:30	LINE CLEAR AVAILED
1963	21-Mar-22	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	3:38	4:55	1:17	LINE FAULT
1964	21-Mar-22	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	12:46	13:49	1:03	LINE CLEAR AVAILED
1965	21-Mar-22	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMG_220	13:22	14:39	1:17	LINE FAULT
1966	21-Mar-22	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	3:38	4:55	1:17	LINE FAULT
1967	21-Mar-22	HASSAN	220	SHRAVTY-SHIMOGA1	gen_sharavathy	13:22	14:39	1:17	LINE FAULT
1968	21-Mar-22	HASSAN	220	SHRAVTY-SHIRALKOPPA	gen_sharavathy	11:18	14:05	2:47	LINE FAULT
1969	21-Mar-22	HASSAN	220	SHRAVTY-TALAGU	gen_sharavathy	13:08	14:24	1:16	LINE FAULT
1970	21-Mar-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:18	14:05	2:47	LINE FAULT
1971	21-Mar-22	HASSAN	220	TALAGU-STRP1	TALAGUPPA_400	13:35	14:24	0:49	LINE FAULT
1972	21-Mar-22	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	8:09	14:56	6:47	LINE CLEAR AVAILED
1973	21-Mar-22	MYSURU	66	DK MAIDANA-KADAKOLA	NO STATIONS EFFECTED	10:48	16:19	5:30	LINE CLEAR AVAILED
1974	21-Mar-22	MYSURU	66	HANNUR-KOTHANUR	NO STATIONS EFFECTED	12:18(22.03.22)			LINE OPEN:LINE FAULT
1975	21-Mar-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00(8/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1976	21-Mar-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1977	21-Mar-22	MYSURU	66	HEBBANI-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	16:56	17:06	0:10	LINE FAULT
1978	21-Mar-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1979	21-Mar-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1980	21-Mar-22	MYSURU	66	HUNSUR-PERIYAPATNA	NO STATIONS EFFECTED	5:52:42 PM (3/18/2022)			LINE OPEN:LINE CLEAR AVAILED
1981	21-Mar-22	MYSURU	66	HUNSUR-PERIYAPATNA	NO STATIONS EFFECTED	5:52:42 PM (3/18/2022)			LINE OPEN:LINE CLEAR AVAILED
1982	21-Mar-22	MYSURU	66	HV1	BEGUR_66	12:43	12:53	0:10	TRANSFORMER FAULT
1983	21-Mar-22	MYSURU	66	HV1	BEGUR_66	19:49	19:54	0:05	TRANSFORMER FAULT
1984	21-Mar-22	MYSURU	66	HV1	GUDDENAHALLI_66	8:10	21:35	13:25	MAIN SUPPLY FAILURE
1985	21-Mar-22	MYSURU	66	HV1	HEBBAL_66	12:41	12:44	0:02	TRANSFORMER FAULT
1986	21-Mar-22	MYSURU	66	HV1	HEBBAL_66	12:46	12:50	0:03	TRANSFORMER FAULT
1987	21-Mar-22	MYSURU	66	HV1	HEBBAL_66	12:58	13:07	0:09	TRANSFORMER FAULT
1988	21-Mar-22	MYSURU	66	HV1	HUNSUR_66	13:10	13:38	0:28	LINE CLEAR AVAILED
1989	21-Mar-22	MYSURU	66	HV1	JAIPUR_66	13:27	18:26	4:58	LINE CLEAR AVAILED
1990	21-Mar-22	MYSURU	66	HV1	KIADBMANDYA_66	12:17	12:28	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1991	21-Mar-22	MYSURU	66	HV1	MADDUR_66	12:16	12:29	0:12	MAIN SUPPLY FAILURE
1992	21-Mar-22	MYSURU	66	HV1	MADDUR_66	13:11	13:40	0:28	LINE CLEAR AVAILED
1993	21-Mar-22	MYSURU	66	HV1	SOMANAHALLI KIADB_66	12:15	12:30	0:15	MAIN SUPPLY FAILURE
1994	21-Mar-22	MYSURU	66	HV2	BEGUR_66	12:43	12:53	0:10	TRANSFORMER FAULT
1995	21-Mar-22	MYSURU	66	HV2	DEVANOORMYS_66	11:22	14:45	3:22	LINE CLEAR AVAILED
1996	21-Mar-22	MYSURU	66	HV2	GUDDENAHALLI_66	8:10	21:37	13:27	MAIN SUPPLY FAILURE
1997	21-Mar-22	MYSURU	66	HV2	KIADBMANDYA_66	12:17	12:28	0:10	MAIN SUPPLY FAILURE
1998	21-Mar-22	MYSURU	66	HV2	MADDUR_66	12:16	12:31	0:14	MAIN SUPPLY FAILURE
1999	21-Mar-22	MYSURU	66	HV2	MADIKERI_66	11:00	14:20	3:20	LINE CLEAR AVAILED
2000	21-Mar-22	MYSURU	66	HV2	SRIRANGAPATNA_66	9:10	18:02	8:52	LINE CLEAR AVAILED
2001	21-Mar-22	MYSURU	66	HV5	SFCSHIVA_66	11:30	13:24	1:53	LINE CLEAR AVAILED
2002	21-Mar-22	MYSURU	66	JAKKANAHALLI-NAGAMANGLA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66	11:24	13:06	1:41	NFBC ISSUED
2003	21-Mar-22	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66, SUTTUR_66	6:42	6:49	0:06	LINE FAULT
2004	21-Mar-22	MYSURU	66	KADAKOLA-NANJANGUDU 2	NO STATIONS EFFECTED	11:00	13:25	2:25	LINE CLEAR AVAILED
2005	21-Mar-22	MYSURU	66	KIADB MANDYA-TUMBEKERE	TUMBEKERE_66	12:19	12:29	0:09	MAIN SUPPLY FAILURE
2006	21-Mar-22	MYSURU	66	KK HALLI-MANDYA	KADKOTHANAHALLI_66	16:15	18:10	1:55	LINE CLEAR AVAILED
2007	21-Mar-22	MYSURU	66	KK HALLI-SHIMSHA	HADLI_66, MALAVALLI_66	15:15	15:50	0:35	LINE CLEAR AVAILED
2008	21-Mar-22	MYSURU	66	KM DODDI-TK HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI KIADB_66, TUMBEKERE_66 K_HONNALGERE_66 TALAGAVADI_66	16:59	17:14	0:15	MAIN SUPPLY FAILURE
2009	21-Mar-22	MYSURU	66	LOKKANAHALLI-PG PALYA	PGPALYA_66	6:30	6:35	0:05	LINE FAULT
2010	21-Mar-22	MYSURU	66	NAGAMANGALA-NAGAMANGALA 220	NAGAMANGALA_66	8:10	19:20	11:10	NFBC ISSUED
2011	21-Mar-22	MYSURU	66	NAGAMANGALA-TUBINKERE 1	NO STATIONS EFFECTED	8:20	19:17	10:57	NFBC ISSUED
2012	21-Mar-22	MYSURU	66	PERIYAPATNA-HANAGODU	PONNAMPET_66, VIRAJPET_66	20:18	20:28	0:09	LINE FAULT
2013	21-Mar-22	MYSURU	66	PERIYAPATNA-HANAGODU	PONNAMPET_66, VIRAJPET_66	20:28(21.03.22)			LINE OPEN:LINE FAULT
2014	21-Mar-22	MYSURU	66	PERIYAPATNA-HANAGODU	PONNAMPET_66, VIRAJPET_66	11:38	11:45	0:07	LINE FAULT
2015	21-Mar-22	MYSURU	66	PERIYAPATNA-HANAGODU	PONNAMPET_66, VIRAJPET_66	11:50	16:20	4:30	LINE CLEAR AVAILED
2016	21-Mar-22	MYSURU	66	PERIYAPATNA-HANAGODU	PONNAMPET_66, VIRAJPET_66	20:28:48 (21.03.2022)	7:13(22.03.22)	10:44Hrs	LINE CHARGED
2017	21-Mar-22	MYSURU	66	PERIYAPATNA-HUNSUR	KAMPALAPURA_66	15:29	15:39	0:10	LINE FAULT
2018	21-Mar-22	MYSURU	66	SATHEGALA-BPCL	NO STATIONS EFFECTED	10:24	18:13	7:49	LINE CLEAR AVAILED
2019	21-Mar-22	MYSURU	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	8:37	12:12	3:34	NFBC ISSUED
2020	21-Mar-22	MYSURU	66	SR PATNA-METAGALLY	NO STATIONS EFFECTED	13:05	14:00	0:55	LINE CLEAR AVAILED
2021	21-Mar-22	MYSURU	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	15:10	15:20	0:10	HAND TRIPPED
2022	21-Mar-22	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	HARADANAHALLI(JAK)_66 SHIVALLY _66	8:09	10:06	1:56	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
2023	21-Mar-22	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	HARADANAHALLI(JAK)_66 SHIVALLY_66	17:40	19:23	1:42	LINE CLEAR AVAILED
2024	21-Mar-22	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	HARADANAHALLI(JAK)_66 SHIVALLY_66	8:10	10:04	1:54	LINE CLEAR AVAILED
2025	21-Mar-22	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	HARADANAHALLI(JAK)_66 SHIVALLY_66	17:40	19:16	1:35	LINE CLEAR AVAILED
2026	21-Mar-22	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLI STATION INTERRUPTED	15:09	15:25	0:15	HAND TRIPPED
2027	21-Mar-22	MYSURU	66	TUBINAKERE-PANDAVAPURA	BANANGADI_66 DODDABYADARAHALLI_66 PANDAVAPURA_66	15:09	15:19	0:10	HAND TRIPPED
2028	21-Mar-22	MYSURU	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	5:30	5:39	0:09	LINE FAULT
2029	21-Mar-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN:LINE CLEAR AVAILED
2030	21-Mar-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN:LINE CLEAR AVAILED
2031	21-Mar-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN:LINE CLEAR AVAILED
2032	21-Mar-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN:LINE CLEAR AVAILED
2033	21-Mar-22	MYSURU	220	HV2	HEBBANI-	12:15	12:33	0:18	TRANSFORMER FAULT
2034	21-Mar-22	MYSURU	220	HV3	HOOTAGALLI-	12:40	12:58	0:18	TRANSFORMER FAULT
2035	21-Mar-22	MYSURU	220	TUBINAKERE-BASTIPURA	NO STATIONS EFFECTED	1:45	5:32	3:47	LINE FAULT
2036	21-Mar-22	MYSURU	220	TUBINAKERE-BASTIPURA	NO STATIONS EFFECTED	5:32	11:25	5:53	LINE FAULT
2037	21-Mar-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	7:13	19:57	12:44	LINE CLEAR AVAILED
2038	21-Mar-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	19:58	20:05	0:06	LINE FAULT
2039	21-Mar-22	TUMKUR	66	BENKIKERE 220kv-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	1:13	1:17	0:03	LINE CLEAR AVAILED
2040	21-Mar-22	TUMKUR	66	CHITRADURGA 220kv-SOKKE	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	15:32	15:56	0:24	LINE FAULT
2041	21-Mar-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	8:42	8:44	0:01	LINE FAULT
2042	21-Mar-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:52	19:01	0:08	LINE FAULT
2043	21-Mar-22	TUMKUR	66	HONNALLI 220KV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	16:23	16:32	0:08	LINE FAULT
2044	21-Mar-22	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	10:07	10:17	0:09	LINE FAULT
2045	21-Mar-22	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	15:31	15:41	0:09	LINE FAULT
2046	21-Mar-22	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	NAYAKANAHATTI_66	2:31	3:00	0:28	LINE FAULT
2047	21-Mar-22	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	NAYAKANAHATTI_66	5:34	6:00	0:25	LINE FAULT
2048	21-Mar-22	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	NAYAKANAHATTI_66	20:15	20:40	0:24	LINE FAULT
2049	21-Mar-22	TUMKUR	66	PATTNAYAKANAHALLI-TAVAREKERE(SIRA)	PATTNAYAKANAHALLI_66	9:49	10:01	0:12	LINE FAULT
2050	21-Mar-22	TUMKUR	66	PKOTE-AZURE SOLAR	AZURE SOLAR_66	10:05	10:34	0:29	MAIN SUPPLY FAILURE
2051	21-Mar-22	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	10:05	10:34	0:29	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
2052	21-Mar-22	TUMKUR	66	PKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	10:05	10:34	0:29	MAIN SUPPLY FAILURE
2053	21-Mar-22	TUMKUR	66	TR-1	PD KOTE_66	10:05	10:33	0:28	MAIN SUPPLY FAILURE
2054	21-Mar-22	TUMKUR	66	TR-1	SANTEMAVATTUR_66	11:29	13:06	1:36	LINE CLEAR AVAILED
2055	21-Mar-22	TUMKUR	66	TR-2	ANTHARASANAHALI_220	10:47	11:29	0:42	LINE CLEAR AVAILED
2056	21-Mar-22	TUMKUR	66	TR-2	HULIYURDURGA_66	21:49	22:01	0:11	TRANSFORMER FAULT
2057	21-Mar-22	TUMKUR	66	TR-2	LINGADAHALLY_66	12:35	12:40	0:04	LINE CLEAR AVAILED
2058	21-Mar-22	TUMKUR	66	TR-2	MADHUGIRI_220	16:50	17:05	0:15	TRANSFORMER FAULT
2059	21-Mar-22	TUMKUR	66	TR-2	MALEBENNUR_66	17:22	17:58	0:36	TRANSFORMER FAULT
2060	21-Mar-22	TUMKUR	66	TR-2	PD KOTE_66	10:05	10:33	0:28	MAIN SUPPLY FAILURE
2061	21-Mar-22	TUMKUR	110	NITTUR 220kv- GUBBI	GUBBI_110, BIDARE_110	13:09	13:25	0:15	LINE FAULT
2062	21-Mar-22	TUMKUR	110	NITTUR 220kv- KG TEMPLE	KGTEMPLE_110, UNGRA_110	13:09	13:29	0:19	LINE FAULT
2063	21-Mar-22	TUMKUR	110	NITTUR 220kv- SOMALAPURA	SOMALAPURA_66	7:17	8:48	1:30	LINE FAULT
2064	21-Mar-22	TUMKUR	110	TR-1(LV1)	NITTUR_110	7:17	7:53	0:35	TRANSFORMER FAULT
2065	21-Mar-22	TUMKUR	220	ANCHEPALYA 220kv- NELMANGALA 1(NAGAMANGALA 1)	ANCHEPALYA_220	11:27	14:31	3:04	LINE CLEAR AVAILED
2066	21-Mar-22	TUMKUR	220	ANCHEPALYA 220kv- NELMANGALA 2 (NAGAMANGALA 2)(MAGADI)	ANCHEPALYA_220	11:27	14:32	3:04	LINE CLEAR AVAILED
2067	21-Mar-22	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	11:11	14:11	3:00	NFBC ISSUED

[illegible]

[illegible]

