

### 400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM : 29.12.2020 TO 04.01.2021

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	29-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVOIDED
2	29-Dec-20	BAGALKOT	110	110/11KV HV2	AMBEWADI_110	13:52	13:54	0:02	TRANSFORMER FAULT
3	29-Dec-20	BAGALKOT	110	110/11KV, HV3	SAVALAGI_110	13:36	13:43	0:07	LINE CLEAR AVOIDED
4	29-Dec-20	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
5	29-Dec-20	BAGALKOT	110	110/11KV,HV 4	HUKKERI_110	14:00	14:23	0:23	TRANSFORMER FAULT
6	29-Dec-20	BAGALKOT	110	110/11KV,HV1	HIDIKAL DAM_110	14:37	15:07	0:30	LINE CLEAR AVOIDED
7	29-Dec-20	BAGALKOT	110	110/11KV,HV3	BIJAPUR_110	15:42	16:28	0:46	LINE CLEAR AVOIDED
8	29-Dec-20	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110 & RUSYUMPUR,W/S1&2_33	8:17	15:09	6:52	LINE CLEAR AVOIDED
9	29-Dec-20	BAGALKOT	110	110/33KV,HV 1	KADANAKOPPA_110 &DHUMWAD,TRAFFIC POLE_33	14:21	14:32	0:11	HAND TRIPPED
10	29-Dec-20	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	15:51	17:30	1:39	LINE CLEAR AVOIDED
11	29-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVOIDED
12	29-Dec-20	BAGALKOT	110	HIDIKAL DAM-ANAKALAGI	ANKALAGI_110	15:51	17:30	1:39	LINE CLEAR AVOIDED
13	29-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN: LINE CLEAR AVOIDED
14	29-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
15	29-Dec-20	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN: LINE FAULT
16	29-Dec-20	BAGALKOT	110	RANEBENNUR- BYADAGI (GUTTAL)	GUTTAL_110	14:18 (29.12.2020)			LINE OPEN: LINE CLEAR AVOIDED
17	29-Dec-20	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
18	29-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN: LINE CLEAR AVOIDED
19	29-Dec-20	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	21:10 (28.12.2020)	7:45 (29.12.2020)	10:35	LINE CHARGED
20	29-Dec-20	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVOIDED
21	29-Dec-20	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI2	MAHALINGAPUR_220	11:31	12:36	1:05	LINE CLEAR AVOIDED
22	29-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
23	29-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
24	29-Dec-20	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	VAJRAMATTI_220	12:49	13:20	0:31	HAND TRIPPED
25	29-Dec-20	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR2	VAJRAMATTI_220	11:29	12:36	1:07	LINE CLEAR AVOIDED
26	29-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN: LINE CLEAR AVOIDED
27	29-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
28	29-Dec-20	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	06:59	07:07	00:08	LINE FAULT
29	29-Dec-20	BENGALURU	66	DB PURA 220 - VIJAYAPURA	NO STATION AFFECTED	07:07	09:37	02:30	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
30	29-Dec-20	BENGALURU	66	HV2	ELECTRONIC CITY	10:42	10:50	00:08	LINE CLEAR AVAILED
31	29-Dec-20	BENGALURU	66	HV2	SUBRAMANYAPURA 66	09:56	10:02	00:06	LINE CLEAR AVAILED
32	29-Dec-20	BENGALURU	66	MITTEMARI 220 - SADALI	SADALI, DIBBURAHALLI	06:24	06:32	00:08	LINE FAULT
33	29-Dec-20	BENGALURU	66	VIJAYAPURA - DB PURA 220	JANGAMAKOTE, VIJAYAPURA	06:59	07:45	00:46	MAIN SUPPLY FAILURE
34	29-Dec-20	BENGALURU	66	VIJAYAPURA - MELUR	JANGAMAKOTE, VIJAYAPURA	09:20	09:40	00:20	LOAD CHANGE OVER
35	29-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN: LINE CLEAR AVAILED
36	29-Dec-20	GULBARGA	110	HUMNABAD-HUMNABAD1	HUMNABAD_110	11:54	12:32	00:38	LINE CLEAR AVAILED
37	29-Dec-20	GULBARGA	110	HUMNABAD-HUMNABAD2	HUMNABAD_110	12:40	17:30	04:50	LINE CLEAR AVAILED
38	29-Dec-20	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	08:13	08:18	00:05	LINE FAULT
39	29-Dec-20	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	11:45	12:24	00:39	NFBC ISSUED
40	29-Dec-20	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	15:03	17:44	02:41	NFBC ISSUED
41	29-Dec-20	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	15:10	17:44	02:34	LINE CLEAR AVAILED
42	29-Dec-20	GULBARGA	110	HV1	KURKUNTA_110	04:55	16:00	11:05	TRANSFORMER FAULT
43	29-Dec-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HUNSAGI_110	06:10	06:19	00:09	LINE FAULT
44	29-Dec-20	GULBARGA	220	HUMNABAD-KAPNOOR	HUMNABAD_220	00:32	07:26	06:54	LINE CLEAR AVAILED
45	29-Dec-20	GULBARGA	220	HV1	RAICHUR_220	15:25	17:08	01:43	TRANSFORMER FAULT
46	29-Dec-20	GULBARGA	220	HV2	HUMNABAD_220	22:55(28.12.2020)	9:46(29.12.2020)	10:51 HRS	TRANSFORMER CHARGED
47	29-Dec-20	GULBARGA	220	HV2	RAICHUR_220	15:25	16:17	00:52	TRANSFORMER FAULT
48	29-Dec-20	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	00:55	05:30	04:35	LINE CLEAR AVAILED
49	29-Dec-20	GULBARGA	400	JINDAL-BTPS	JINDAL_400	16:37(28.12.2020)			LINE OPEN: LINE CLEAR AVAILED
50	29-Dec-20	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	07:00	07:05	00:05	LINE FAULT
51	29-Dec-20	HASSAN	66	HV1	HIRISAVE_66	11:25	11:36	00:11	TRANSFORMER FAULT
52	29-Dec-20	HASSAN	66	HV2	RAMPURA_66	17:25	17:45	00:20	LINE CLEAR AVAILED
53	29-Dec-20	HASSAN	66	HV2	RAMPURA_66	22:10	22:20	00:10	TRANSFORMER FAULT
54	29-Dec-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
55	29-Dec-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
56	29-Dec-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
57	29-Dec-20	HASSAN	66	MRSSHM-DVG2	MRSMSG_110	15:07	15:19	00:12	LINE FAULT
58	29-Dec-20	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	10:20	10:30	00:10	HAND TRIPPED
59	29-Dec-20	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	12:20	12:40	00:20	LINE FAULT
60	29-Dec-20	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	10:00	10:10	00:10	HAND TRIPPED
61	29-Dec-20	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	15:32	17:23	01:51	LINE CLEAR AVAILED
62	29-Dec-20	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	17:20	17:37	00:17	MAIN SUPPLY FAILURE
63	29-Dec-20	HASSAN	110	HV1	BARANGI_110	09:30	09:35	00:05	TRANSFORMER FAULT
64	29-Dec-20	HASSAN	110	HV1	BARANGI_110	10:40	10:45	00:05	HAND TRIPPED
65	29-Dec-20	HASSAN	110	HV1	BELAGUMBA_110	12:14	16:50	04:36	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
66	29-Dec-20	HASSAN	110	HV2	ANANDAPURA_110	14:17	17:48	03:31	LINE CLEAR AVAILED
67	29-Dec-20	HASSAN	110	HV2	BARANGI_110	10:40	10:45	00:05	HAND TRIPPED
68	29-Dec-20	HASSAN	110	HV2	BARANGI_110	15:45	17:10	01:25	LINE CLEAR AVAILED
69	29-Dec-20	HASSAN	110	HV2	BELAGUMBA_110	12:14	16:50	04:36	LINE CLEAR AVAILED
70	29-Dec-20	HASSAN	110	HV2	KONAJE_110	17:11	17:22	00:11	MAIN SUPPLY FAILURE
71	29-Dec-20	HASSAN	110	JOG-JLT4	mghejog_gen	11:11 (28.12.2020)			LINE OPEN: LINE CLEAR AVAILED
72	29-Dec-20	HASSAN	110	KMS110-MRS-ANDPR	KUMSI_110	18:40	19:40	01:00	LINE FAULT
73	29-Dec-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	13:07	13:17	00:10	HAND TRIPPED
74	29-Dec-20	HASSAN	220	MRSSHM-VARAH2	MRSMSG_110	17:47 (28.12.2020)	12:54 (29.12.2020)	19:06 hrs	LINE CHARGED
75	29-Dec-20	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	17:47 (28.12.2020)	12:54 (29.12.2020)	19:06 hrs	LINE CHARGED
76	29-Dec-20	MYSORE	66	BEGUR 220-BEGUR 2	NO STATIONS EFFECTED	12:35	12:52	0:17	LINE CLEAR AVAILED
77	29-Dec-20	MYSORE	66	BEGUR 220-HARVEY	NO STATIONS EFFECTED	13:08	13:21	0:13	LINE CLEAR AVAILED
78	29-Dec-20	MYSORE	66	BEGUR 220-SARGUR	NO STATIONS EFFECTED	13:01	13:16	0:15	LINE CLEAR AVAILED
79	29-Dec-20	MYSORE	66	BEGUR 220-SINDUVALLIPURA	NO STATIONS EFFECTED	12:05	12:58	0:53	LINE CLEAR AVAILED
80	29-Dec-20	MYSORE	66	BEGUR-B-MATGERE	NO STATIONS EFFECTED	3:25	3:35	0:10	LINE FAULT
81	29-Dec-20	MYSORE	66	BILIKERE-GVGUDI	GVGUDI_66	10:57	18:45	7:48	LINE CLEAR AVAILED
82	29-Dec-20	MYSORE	66	BILIKERE-KHB	DMG_HALLI_66	15:56	18:34	2:38	NFBC ISSUED
83	29-Dec-20	MYSORE	66	BILIKERE-KR NAGARA	BILIKERE_66	15:20	15:48	0:28	HAND TRIPPED
84	29-Dec-20	MYSORE	66	BILIKERE-KR NAGARA	BILIKERE_66	15:55	18:45	2:50	LINE CLEAR AVAILED
85	29-Dec-20	MYSORE	66	HANNUR-AMPS SOLAR	NO STATIONS EFFECTED	6:57	7:12	0:15	LINE FAULT
86	29-Dec-20	MYSORE	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:33	6:48	0:14	LINE FAULT
87	29-Dec-20	MYSORE	66	HV1	BILIKERE_66	10:35	15:49	5:13	LINE CLEAR AVAILED
88	29-Dec-20	MYSORE	66	HV1	KOPPA_66	15:30	15:41	0:11	HAND TRIPPED
89	29-Dec-20	MYSORE	66	HV1	MADESWARAPURA_66	13:46	14:18	0:31	LINE CLEAR AVAILED
90	29-Dec-20	MYSORE	66	HV1	MALAVALLI_66	16:00	16:21	0:21	LINE CLEAR AVAILED
91	29-Dec-20	MYSORE	66	HV2	BILIKERE_66	15:05	18:37	3:31	LINE CLEAR AVAILED
92	29-Dec-20	MYSORE	66	HV2	MADESWARAPURA_66	13:20	14:20	1:00	LINE CLEAR AVAILED
93	29-Dec-20	MYSORE	66	HV2	MALAVALLI_66	15:35	16:22	0:46	LINE CLEAR AVAILED
94	29-Dec-20	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	1:23	1:33	0:10	LINE FAULT
95	29-Dec-20	MYSORE	66	KUSHALANAGARA 220-RAMANTHAPURA1	ALUR SIDDAPURA_66 KANAGAL_66	15:47	15:52	0:04	LINE FAULT
96	29-Dec-20	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	14:09	14:28	0:18	LINE FAULT
97	29-Dec-20	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	17:03	17:31	0:27	LINE CLEAR AVAILED
98	29-Dec-20	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	6:24	7:15	0:51	LINE FAULT
99	29-Dec-20	TUMKUR	66	NEELAGUNDA 220KV- PUNABHAGHATTA	PUNABHAGHATTA_66, UCHCHANGIDURGA_6 6, PALLAGATTE_66, SOKKE_66	9:06	9:16	0:10	LINE FAULT
100	29-Dec-20	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	8:05	12:54	4:48	LINE FAULT
101	29-Dec-20	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	13:49	14:08	0:18	LINE FAULT
102	29-Dec-20	TUMKUR	66	TR-1	ANTHRASANAHALI_220	10:13	11:34	1:20	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
103	29-Dec-20	TUMKUR	66	TR-1	BELADARA_66	14:19	14:42	0:23	LINE CLEAR AVAILED
104	29-Dec-20	TUMKUR	66	TR-1	HOLALKERE_66	11:00	12:48	1:48	LINE CLEAR AVAILED
105	29-Dec-20	TUMKUR	66	TR-1	KUNDUR_66	8:32	8:48	0:16	TRANSFORMER FAULT
106	29-Dec-20	TUMKUR	66	TR-1	MYLANAHALLI_66	8:10	8:16	0:05	TRANSFORMER FAULT
107	29-Dec-20	TUMKUR	66	TR-1	MYLANAHALLI_66	8:53	9:05	0:11	TRANSFORMER FAULT
108	29-Dec-20	TUMKUR	66	TR-2	CHANNAGIRI_66	18:23	18:32	0:09	TRANSFORMER FAULT
109	29-Dec-20	TUMKUR	66	TR-2	HOLALKERE_66	11:00	12:48	1:48	LINE CLEAR AVAILED
110	29-Dec-20	TUMKUR	66	TR-3	HARIYABBE_66	13:50	14:06	0:15	LINE CLEAR AVAILED
111	29-Dec-20	TUMKUR	110	TR-1	AMMASANDRA_110	13:10	13:51	0:41	LINE CLEAR AVAILED
112	29-Dec-20	TUMKUR	220	NEELAGUNDA220KV- ITTAGI 220KV	NEELAGUNDA_220	13:00	19:27	6:27	LINE CLEAR AVAILED
113	30-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
114	30-Dec-20	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED RANNABELAGALI_110	10:44	13:30	2:46	LINE CLEAR AVAILED
115	30-Dec-20	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED RANNABELAGALI_110	14:08	14:18	0:10	LINE CLEAR AVAILED
116	30-Dec-20	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
117	30-Dec-20	BAGALKOT	110	110/11KV,HV1	BABLESHWAR_110	09:05	09:37	0:32	LINE CLEAR AVAILED
118	30-Dec-20	BAGALKOT	110	110/11KV,HV1	MORATAGI_110	15:30	15:53	0:23	LINE CLEAR AVAILED
119	30-Dec-20	BAGALKOT	110	110/11KV,HV1	MORATAGI_110	15:54	15:56	0:02	LINE CLEAR AVAILED
120	30-Dec-20	BAGALKOT	110	110/11KV,HV2	KUDACHI_110,CHINCHALI_33	9:00	9:22	0:22	TRANSFORMER FAULT
121	30-Dec-20	BAGALKOT	110	GHATAPRABHA-MANTUR	MANTUR_110	6:53	7:23	0:30	LINE FAULT
122	30-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
123	30-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN: LINE CLEAR AVAILED
124	30-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
125	30-Dec-20	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN: LINE FAULT
126	30-Dec-20	BAGALKOT	110	RANEBENNUR- BYADAGI (GUTTAL)	RANEBENNUR_220	14:18 (29.12.2020)	8:16 (30.12.2020)	17:58hrs	LINE CHARGED
127	30-Dec-20	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
128	30-Dec-20	BAGALKOT	220	220/110KV,HV1,LV1	NO STATION AFFECTED GADAG_220	11:12	17:24	6:12	LINE CLEAR AVAILED
129	30-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN: LINE CLEAR AVAILED
130	30-Dec-20	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	11:10	17:37	6:27	NFBC ISSUED
131	30-Dec-20	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVAILED
132	30-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
133	30-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
134	30-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN: LINE CLEAR AVAILED
135	30-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
136	30-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN: LINE CLEAR AVAILED
137	30-Dec-20	GULBARGA	400	JINDAL-BTPS	JINDAL_400	16:37(28.12.2020)	15:07(30.12.2020)	46:30HRS	LINE CHARGED
138	30-Dec-20	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	06:40	07:03	00:23	LINE FAULT
139	30-Dec-20	HASSAN	66	GANGUR-HASSAN	GANGUR_66	15:01	15:20	00:19	LINE CLEAR AVAILED
140	30-Dec-20	HASSAN	66	HV1	GANGUR_66	15:01	15:21	00:20	LINE CLEAR AVAILED
141	30-Dec-20	HASSAN	66	HV2	MAGGE_66	10:42	11:25	00:43	LINE CLEAR AVAILED
142	30-Dec-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
143	30-Dec-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
144	30-Dec-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
145	30-Dec-20	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	09:39	09:52	00:13	HAND TRIPPED
146	30-Dec-20	HASSAN	110	HV1	BARANGI_110	12:55	12:59	00:04	HAND TRIPPED
147	30-Dec-20	HASSAN	110	HV2	BARANGI_110	12:55	12:59	00:04	HAND TRIPPED
148	30-Dec-20	HASSAN	110	JOG-JLT4	mghejog_gen	11:11 (28.12.2020)			LINE OPEN: LINE CLEAR AVAILED
149	30-Dec-20	HASSAN	110	KADUR-AJAMPURA	KADUR_220	11:19	11:34	00:15	LINE CLEAR AVAILED
150	30-Dec-20	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	15:02	15:30	00:28	LINE FAULT
151	30-Dec-20	MYSORE	66	CR NAGARA-YALANDUR	YELANDUR_66	23:44	23:52	0:08	LINE FAULT
152	30-Dec-20	MYSORE	66	KADAKOLA-MANDAKALLI	NO STATIONS EFFECTED	15:32	15:37	0:04	LINE CLEAR AVAILED
153	30-Dec-20	MYSORE	66	KADAKOLA-SARGUR 1	NO STATIONS EFFECTED	15:34	15:37	0:02	LINE CLEAR AVAILED
154	30-Dec-20	MYSORE	66	KADAKOLA-SARGUR 2	NO STATIONS EFFECTED	15:34	15:37	0:02	LINE CLEAR AVAILED
155	30-Dec-20	MYSORE	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	6:26	6:35	0:08	LINE FAULT
156	30-Dec-20	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	4:48	4:54	0:05	LINE FAULT
157	30-Dec-20	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	6:41	6:47	0:06	LINE FAULT
158	30-Dec-20	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66 MALIYURU_66	6:46	7:00	0:14	LINE FAULT
159	30-Dec-20	MYSORE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	10:48	16:21	5:32	NFBC ISSUED
160	30-Dec-20	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	11:04	11:11	0:07	LINE FAULT
161	30-Dec-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:55	13:08	0:12	LINE FAULT
162	30-Dec-20	TUMKUR	66	TR-1	MYLANAHALLI_66	8:08	8:16	0:07	TRANSFORMER FAULT
163	30-Dec-20	TUMKUR	66	TR-1	PAVAGADA_220	9:50	9:52	0:02	TRANSFORMER FAULT
164	30-Dec-20	TUMKUR	66	TR-1	PAVAGADA_220	10:52	10:55	0:03	TRANSFORMER FAULT
165	30-Dec-20	TUMKUR	66	TR-2	GULIGENAHALLI_66	11:04	11:28	0:24	LINE CLEAR AVAILED
166	30-Dec-20	TUMKUR	66	TR-2	MADANAYAKANAHALLI_66	8:57	9:11	0:14	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
167	30-Dec-20	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,TALKERE_110	16:52	16:54	0:01	HAND TRIPPED
168	30-Dec-20	TUMKUR	110	TR-2	HULIYAR_110	13:47	20:45	6:58	MAIN SUPPLY FAILURE
169	30-Dec-20	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	13:05	13:41	0:35	TRANSFORMER FAULT
170	30-Dec-20	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR_IPP_66	AZURE POWER SOLAR_IPP_66	12:21	12:22	0:01	LINE CLEAR AVAILED
171	30-Dec-20	TUMKUR	220	TR-3	KBCROSS_220	13:13	13:36	0:23	TRANSFORMER FAULT
172	30-Dec-20	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	11:25:08 AM(30.12.2020)			LINE OPEN: LINE CLEAR AVAILED
173	31-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
174	31-Dec-20	BAGALKOT	110	110/11KV, HV2	ZALKI_110	16:05	18:25	2:20	LINE CLEAR AVAILED
175	31-Dec-20	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	10:05	10:27	0:22	TRANSFORMER FAULT
176	31-Dec-20	BAGALKOT	110	110/11KV, HV2	LAKMANHALLI_110	3:34	3:48	0:14	HAND TRIPPED
177	31-Dec-20	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
178	31-Dec-20	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	13:25	14:40	1:15	LINE CLEAR AVAILED
179	31-Dec-20	BAGALKOT	110	110/33KV, HV1	JAMKHANDI_110, HIPPARGI_33	15:25	16:08	0:43	LINE CLEAR AVAILED
180	31-Dec-20	BAGALKOT	110	110/33KV, HV1	JAMKHANDI_110, HIPPARGI_33	17:15	17:48	0:33	LINE CLEAR AVAILED
181	31-Dec-20	BAGALKOT	110	110/33KV, HV2	JAMKHANDI_110, HIPPARGI_33	11:08	13:48	2:40	LINE CLEAR AVAILED
182	31-Dec-20	BAGALKOT	110	110/33KV, HV2	JAMKHANDI_110, HIPPARGI_33	15:25	16:08	0:43	LINE CLEAR AVAILED
183	31-Dec-20	BAGALKOT	110	110/33KV, HV2	JAMKHANDI_110, HIPPARGI_33	16:09	17:13	1:04	LINE CLEAR AVAILED
184	31-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
185	31-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN: LINE CLEAR AVAILED
186	31-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
187	31-Dec-20	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN: LINE FAULT
188	31-Dec-20	BAGALKOT	110	RANEBENNUR- GUTTAL	GUTTAL_110	14:32	20:53	6:21	LINE CLEAR AVAILED
189	31-Dec-20	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
190	31-Dec-20	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED GADAG_220	10:53	18:48	7:55	LINE CLEAR AVAILED
191	31-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)	18:42 (31.12.2020)	1394:21 hrs	LINE CHARGED
192	31-Dec-20	BAGALKOT	220	BAGEWADI-ATRIA2	BAGEWADI_220	13:23	18:43	5:20	LINE CLEAR AVAILED
193	31-Dec-20	BAGALKOT	220	BELGAUM- KANABARGI (NARENDRA2)	BELGAUM_220	13:37	18:11	4:34	LINE CLEAR AVAILED
194	31-Dec-20	BAGALKOT	220	BIDNAL-HIREBEBNDIGERI 1 (TADAS1)	BIDNAL_220	11:35	12:49	1:14	NFBC ISSUED
195	31-Dec-20	BAGALKOT	220	BIDNAL-HIREBEBNDIGERI 2 (TADAS2)	BIDNAL_220	14:48	16:54	2:06	NFBC ISSUED
196	31-Dec-20	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVAILED
197	31-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
198	31-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
199	31-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN: LINE CLEAR AVAILED
200	31-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
201	31-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN: LINE CLEAR AVAILED
202	31-Dec-20	HASSAN	66	BHADRA-SHMG 1	bhadra_gen	11:28	11:45	00:17	HAND TRIPPED
203	31-Dec-20	HASSAN	66	HV1	SOMANAHALLI_66	10:47	12:55	02:08	LINE CLEAR AVAILED
204	31-Dec-20	HASSAN	66	HV2	UDAYAPURA_66	14:00	14:45	00:45	TRANSFORMER FAULT
205	31-Dec-20	HASSAN	66	HV2	UDAYAPURA_66	14:50	14:55	00:05	TRANSFORMER FAULT
206	31-Dec-20	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
207	31-Dec-20	HASSAN	66	LV3	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
208	31-Dec-20	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
209	31-Dec-20	HASSAN	66	MRSSHM-BD-1	MRSMG_220	11:28	11:45	00:17	HAND TRIPPED
210	31-Dec-20	HASSAN	110	HV1	ARASIKERE_220	11:17	13:00	01:43	LINE CLEAR AVAILED
211	31-Dec-20	HASSAN	110	HV1	KADUR_110	09:41	10:05	00:24	HAND TRIPPED
212	31-Dec-20	HASSAN	110	HV2	ARASIKERE_110	17:14	17:38	00:24	HAND TRIPPED
213	31-Dec-20	HASSAN	110	HV2	BAIKAMPADY_110	09:49	16:50	07:01	LINE CLEAR AVAILED
214	31-Dec-20	HASSAN	110	HV2	ESSUR_110	15:36	17:47	02:11	LINE CLEAR AVAILED
215	31-Dec-20	HASSAN	110	HV2	KADUR_110	09:41	10:05	00:24	HAND TRIPPED
216	31-Dec-20	HASSAN	110	HV2	KADUR_110	09:41	10:05	00:24	HAND TRIPPED
217	31-Dec-20	HASSAN	110	JOG-JLT4	mghejog_gen	11:11 (28.12.2020)			LINE OPEN: LINE CLEAR AVAILED
218	31-Dec-20	HASSAN	110	KADUR-AJAMPURA	KADUR_110	06:40	06:55	00:15	HAND TRIPPED
219	31-Dec-20	HASSAN	110	KADUR-AJAMPURA	KADUR_110	09:41	10:05	00:24	HAND TRIPPED
220	31-Dec-20	HASSAN	110	KADUR-NERELEKERE	KADUR_110	06:40	06:55	00:15	HAND TRIPPED
221	31-Dec-20	HASSAN	110	KADUR-NERELEKERE	KADUR_110	07:03	08:47	01:44	LINE CLEAR AVAILED
222	31-Dec-20	HASSAN	110	KADUR-NERELEKERE	KADUR_110	09:41	10:05	00:24	HAND TRIPPED
223	31-Dec-20	HASSAN	110	KADUR-NGNHL	KADUR_110	06:40	06:55	00:15	HAND TRIPPED
224	31-Dec-20	HASSAN	110	KADUR-NGNHL	KADUR_110	09:41	10:05	00:24	HAND TRIPPED
225	31-Dec-20	HASSAN	110	KADUR-TNGL	KADUR_110	06:40	06:55	00:15	HAND TRIPPED
226	31-Dec-20	HASSAN	110	KADUR-TNGL	KADUR_110	09:41	10:05	00:24	HAND TRIPPED
227	31-Dec-20	HASSAN	110	KADUR-YGTI	KADUR_110	06:40	06:55	00:15	HAND TRIPPED
228	31-Dec-20	HASSAN	110	KADUR-YGTI	KADUR_110	09:41	13:00	03:19	LINE CLEAR AVAILED
229	31-Dec-20	HASSAN	110	LV1	KADUR_110	03:36	08:46	05:10	TRANSFORMER FAULT
230	31-Dec-20	HASSAN	110	LV1	KADUR_110	09:41	10:05	00:24	HAND TRIPPED
231	31-Dec-20	HASSAN	110	LV2	KADUR_110	06:40	06:42	00:02	TRANSFORMER FAULT
232	31-Dec-20	HASSAN	110	LV2	KADUR_110	07:00	07:05	00:05	TRANSFORMER FAULT
233	31-Dec-20	HASSAN	110	LV2	KADUR_110	09:41	10:05	00:24	HAND TRIPPED
234	31-Dec-20	HASSAN	220	HV1	KADUR_110	03:35	03:40	00:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
235	31-Dec-20	HASSAN	220	HV1	KADUR_110	07:55	08:45	00:50	LINE CLEAR AVAILED
236	31-Dec-20	HASSAN	220	HV2	KADUR_110	06:40	06:42	00:02	TRANSFORMER FAULT
237	31-Dec-20	HASSAN	220	HV2	KADUR_110	07:00	07:05	00:05	TRANSFORMER FAULT
238	31-Dec-20	HASSAN	220	KEMAR-Varahi2	KEMAR_220	14:33	17:54	03:21	LINE FAULT
239	31-Dec-20	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	14:29	16:25	01:56	LINE FAULT
240	31-Dec-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	14:38	17:52	03:14	LINE FAULT
241	31-Dec-20	MYSORE	66	HV1	ATTIGULIPURA_66	13:13	13:28	0:14	LINE CLEAR AVAILED
242	31-Dec-20	MYSORE	66	HV1	BOMMALAPURA_66	15:14	17:05	1:50	LINE CLEAR AVAILED
243	31-Dec-20	MYSORE	66	HV1	KOLLEGALA_66	8:04	8:53	0:48	TRANSFORMER FAULT
244	31-Dec-20	MYSORE	66	HV2	MALAVALLI_66	9:47	11:56	2:09	LINE CLEAR AVAILED
245	31-Dec-20	MYSORE	66	HV3	MALAVALLI_66	16:58	20:20	3:22	LINE CLEAR AVAILED
246	31-Dec-20	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	9:14	9:23	0:08	LINE FAULT
247	31-Dec-20	MYSORE	66	KADAKOLA-SARGUR 2	NO STATIONS EFFECTED	9:14	9:23	0:08	LINE FAULT
248	31-Dec-20	MYSORE	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	12:01	12:07	0:05	LINE FAULT
249	31-Dec-20	MYSORE	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	18:00	18:24	0:24	LINE FAULT
250	31-Dec-20	MYSORE	66	SFCSIVA-PGL	NO STATIONS EFFECTED	18:00	18:15	0:14	LINE FAULT
251	31-Dec-20	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENHALLI_66	6:49	6:59	0:09	LINE FAULT
252	31-Dec-20	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	10:00	13:26	3:26	LINE CLEAR AVAILED
253	31-Dec-20	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	17:46	17:48	0:01	MAIN SUPPLY FAILURE
254	31-Dec-20	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	17:41	17:53	0:12	MAIN SUPPLY FAILURE
255	31-Dec-20	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	6:42	6:57	0:15	LINE FAULT
256	31-Dec-20	TUMKUR	66	TR-2	CHIKKABANAGERE_66	16:03	17:06	1:03	LINE CLEAR AVAILED
257	31-Dec-20	TUMKUR	66	TR-2	HARIHAR_66	14:35	15:30	0:55	LINE CLEAR AVAILED
258	31-Dec-20	TUMKUR	66	TR-2	HARIHAR_66	15:43	16:20	0:37	LINE CLEAR AVAILED
259	31-Dec-20	TUMKUR	66	TR-2	HONNUDIKE_66	16:35	16:53	0:17	LINE CLEAR AVAILED
260	31-Dec-20	TUMKUR	110	SAMPIGE- RENEWIND_IPP_110	RENEW_WIND_IPP_110	18:16	20:26	2:09	LINE CLEAR AVAILED
261	31-Dec-20	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	8:56	9:05	0:08	TRANSFORMER FAULT
262	31-Dec-20	TUMKUR	110	TR-1	SOMLPURA_110	22:15	22:23	0:08	TRANSFORMER FAULT
263	31-Dec-20	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN: LINE CLEAR AVAILED
264	31-Dec-20	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN: LINE CLEAR AVAILED
265	31-Dec-20	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR_IPP_66	AZURE POWER SOLAR_IPP_66	15:20	15:34	0:13	LINE FAULT
266	31-Dec-20	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR_IPP_66	AZURE POWER SOLAR_IPP_66	18:02	19:33	1:30	LINE FAULT
267	31-Dec-20	TUMKUR	220	KB CROSS 220kv- SHIMOGA1	KBCROSS_220	14:29	16:30	2:01	LINE FAULT
268	31-Dec-20	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	11:25:08 AM(30.12.2020)			LINE OPEN: LINE CLEAR AVAILED
269	1-Jan-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
270	1-Jan-21	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	14:34	15:25	0:51	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
271	1-Jan-21	BAGALKOT	110	110/11KV, HV2	YELPARHATTI_110	11:03	11:38	0:35	LINE CLEAR AVAILED
272	1-Jan-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
273	1-Jan-21	BAGALKOT	110	110/33KV HV2	HUNGUND_110 & AMINAGAD & KARADI_33	17:50	17:56	0:06	TRANSFORMER FAULT
274	1-Jan-21	BAGALKOT	110	BIJAPUR-ENERCON	(STATION NOT AFFECTED) BIJAPUR_220	6:29	06:41	0:12	LINE FAULT
275	1-Jan-21	BAGALKOT	110	BPCL- ITANAL	ITANAL_110	4:13	5:33	1:20	LINE FAULT
276	1-Jan-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
277	1-Jan-21	BAGALKOT	110	HIREBEVANUR-SHIVSAGARSUGARS	HIREBEVANUR_110	12:59	13:00	0:01	HAND TRIPPED
278	1-Jan-21	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN: LINE CLEAR AVAILED
279	1-Jan-21	BAGALKOT	110	JAMKHANDI- MAHALINGAPUR (NAVALGI)	JAMKHANDI_110	12:17	12:28	0:11	LINE CLEAR AVAILED
280	1-Jan-21	BAGALKOT	110	JAMKHANDI- MAHALINGAPUR (NAVALGI)	JAMKHANDI_110	16:45	17:40	0:55	LINE CLEAR AVAILED
281	1-Jan-21	BAGALKOT	110	JAMKHANDI- PRABHULINGESHWAR (SIDDAPUR)	STATION NOT AFFECTED JAMKHANDI_110	12:22	16:54	4:32	LINE CLEAR AVAILED
282	1-Jan-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
283	1-Jan-21	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN: LINE FAULT
284	1-Jan-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
285	1-Jan-21	BAGALKOT	220	220/110KV,HV 2 & LV 2	BIJAPUR_220	06:29	07:15	0:46	TRANSFORMER FAULT
286	1-Jan-21	BAGALKOT	220	BELGAUM- KANABARGI1(NARENDRA1)	BELGAUM_220	10:23	16:44	6:21	LINE CLEAR AVAILED
287	1-Jan-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVAILED
288	1-Jan-21	BAGALKOT	220	NARENDRA- KANABARGI1(BELGAUM1)	NARENDRA_220	10:29	16:44	6:15	NFBC ISSUED
289	1-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
290	1-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
291	1-Jan-21	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN: LINE CLEAR AVAILED
292	1-Jan-21	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
293	1-Jan-21	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN: LINE CLEAR AVAILED
294	1-Jan-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
295	1-Jan-21	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
296	1-Jan-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
297	1-Jan-21	HASSAN	66	TAVAREC-IDLE	TAVARECHATNAHALLI_66	17:20	17:54	00:34	LINE FAULT
298	1-Jan-21	HASSAN	110	HV2	BAIKAMPADI_110	11:16	17:10	05:54	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
299	1-Jan-21	HASSAN	110	JOG-JLT4	mghejog_gen	11:11 (28.12.2020)			LINE OPEN: LINE CLEAR AVAILED
300	1-Jan-21	HASSAN	110	KADUR-NERELEKERE	KADUR_220	11:34	11:43	00:09	LINE FAULT
301	1-Jan-21	HASSAN	220	MRSSHM-VARAH1	MRS MG_220	12:31	17:34	05:03	LINE CLEAR AVAILED
302	1-Jan-21	HASSAN	220	MRSSHM-VARAH2	MRS MG_220	12:31	17:34	05:03	LINE CLEAR AVAILED
303	1-Jan-21	HASSAN	220	MRSSHM-VARAH3	MRS MG_220	12:31	17:41	05:10	LINE CLEAR AVAILED
304	1-Jan-21	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	15:35	15:53	00:18	HAND TRIPPED
305	1-Jan-21	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	12:31	17:34	05:03	LINE CLEAR AVAILED
306	1-Jan-21	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	12:31	17:34	05:03	LINE CLEAR AVAILED
307	1-Jan-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	10:37	14:00	03:23	LINE CLEAR AVAILED
308	1-Jan-21	HASSAN	400	TALGU-NELAMANGALA#2	TALAGUPPA_400	21:03 (1.01.2021)			LINE OPEN: LINE CLEAR AVAILED
309	1-Jan-21	HASSAN	400	TALGU-NELAMANGALA#2	TALAGUPPA_400	02:04	07:34	05:30	LINE CLEAR AVAILED
310	1-Jan-21	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATION EFFECTED	11:18	12:37	1:19	NFBC ISSUED
311	1-Jan-21	MYSORE	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66 AJJIPURA_66	14:38	15:25	0:46	LINE CLEAR AVAILED
312	1-Jan-21	MYSORE	66	HV1	NAGAMANGALA_66	16:06	17:28	1:22	LINE CLEAR AVAILED
313	1-Jan-21	MYSORE	66	HV1	SUTTUR_66	19:13	19:20	0:06	HAND TRIPPED
314	1-Jan-21	MYSORE	66	HV1	DUNDANAHALLI_66	06:54 (31.12.2020)	13:39	30:45HRS	TRANSFORMER CHARGED
315	1-Jan-21	MYSORE	66	HV2	SUTTUR_66	19:13	19:20	0:06	HAND TRIPPED
316	1-Jan-21	MYSORE	66	KUSHALANAGARA 220-RAMANTHAPURA1	ALUR SIDDAPURA_66 KANAGAL_66	10:27	10:36	0:08	LINE FAULT
317	1-Jan-21	MYSORE	66	MADHUVANAHALLI-KOLLEGALA 1	NO STATION EFFECTED	12:41	13:31	0:50	NFBC ISSUED
318	1-Jan-21	MYSORE	66	MADHUVANAHALLI-PGPALYA	PGPALYA_66	5:37	5:44	0:06	LINE FAULT
319	1-Jan-21	MYSORE	66	MADHUVANAHALLI-SFC	NO STATION EFFECTED	17:53	18:03	0:09	LINE FAULT
320	1-Jan-21	MYSORE	66	MEGHALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	6:41	6:48	0:06	LINE FAULT
321	1-Jan-21	MYSORE	66	SATHEGALA-SFC	NO STATION EFFECTED	6:12	6:20	0:07	LINE FAULT
322	1-Jan-21	MYSORE	66	SFCSIVA-10MW	NO STATION EFFECTED	6:12	6:35	0:23	LINE FAULT
323	1-Jan-21	MYSORE	66	SFCSIVA-5MW	NO STATION EFFECTED	6:12	6:15	0:03	LINE FAULT
324	1-Jan-21	MYSORE	66	SFCSIVA-PGL	NO STATION EFFECTED	6:12	6:20	0:07	LINE FAULT
325	1-Jan-21	TUMKUR	66	NEELAGUNDA 220KV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDURGA_66,PALLAGATTE_66,SOKKE_66	10:42	10:56	0:14	LINE FAULT
326	1-Jan-21	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	8:17	9:13	0:55	LINE FAULT
327	1-Jan-21	TUMKUR	66	TR-2	CHELURU_66	9:35	9:38	0:03	TRANSFORMER FAULT
328	1-Jan-21	TUMKUR	66	TR-2	HARAPPANAHALLI_66	9:01	9:12	0:11	TRANSFORMER FAULT
329	1-Jan-21	TUMKUR	66	TR-2	HIREGUNTANUR_66	9:59	10:05	0:06	TRANSFORMER FAULT
330	1-Jan-21	TUMKUR	66	TR-2	HIREGUNTANUR_66	18:04	18:10	0:05	TRANSFORMER FAULT
331	1-Jan-21	TUMKUR	66	TR-2	RAMPURA_66	15:02	15:26	0:24	LINE CLEAR AVAILED
332	1-Jan-21	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	22:44	22:54	0:10	TRANSFORMER FAULT
333	1-Jan-21	TUMKUR	110	TR-1	KALLUR_110	11:13	11:53	0:39	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
334	1-Jan-21	TUMKUR	110	TR-1	SOMLPURA_110	22:15	22:24	0:09	TRANSFORMER FAULT
335	1-Jan-21	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	22:44	22:54	0:10	TRANSFORMER FAULT
336	1-Jan-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10(31.12.2020			LINE OPEN: LINE CLEAR AVAILED
337	1-Jan-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11(31.12.2020)			LINE OPEN: LINE CLEAR AVAILED
338	1-Jan-21	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	11:25 (30.12.2020)	16:44:51(01.01.2021)	53:19hrs	LINE CHARGED
339	1-Jan-21	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	20:15(01.01.2021)			LINE OPEN: LINE FAULT
340	2-Jan-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
341	2-Jan-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED HUBLI_220	11:26	12:17	0:51	LINE CLEAR AVAILED
342	2-Jan-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TODALABAGI_110	17:32	17:50	0:18	LOAD CURTAILMENT
343	2-Jan-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TODALABAGI_110	17:51	18:11	0:20	LOAD CURTAILMENT
344	2-Jan-21	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	12:47	17:13	4:26	LINE CLEAR AVAILED
345	2-Jan-21	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	18:01	18:03	0:02	HAND TRIPPED
346	2-Jan-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
347	2-Jan-21	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	17:50	18:10	0:20	LOAD CURTAILMENT
348	2-Jan-21	BAGALKOT	110	110/11KV,HV1	BABLESHWAR_110	17:32	18:44	1:12	LINE CLEAR AVAILED
349	2-Jan-21	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	13:09	18:49	5:40	LINE CLEAR AVAILED
350	2-Jan-21	BAGALKOT	110	110/11KV,HV1	GAJENDRAGAD_110	12:00	12:40	0:40	LINE CLEAR AVAILED
351	2-Jan-21	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	17:35	17:41	0:06	LOAD CURTAILMENT
352	2-Jan-21	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	17:50	17:58	0:08	LOAD CURTAILMENT
353	2-Jan-21	BAGALKOT	110	110/11KV,HV2	KUDALASANGAM_110	17:35	17:41	0:06	TRANSFORMER FAULT
354	2-Jan-21	BAGALKOT	110	110/11KV,HV2	KUDALASANGAM_110	17:50	17:58	0:08	TRANSFORMER FAULT
355	2-Jan-21	BAGALKOT	110	110/11KV,HV4(HV2)	GAJENDRAGAD_110	17:35	18:02	0:27	TRANSFORMER FAULT
356	2-Jan-21	BAGALKOT	110	110/33KV, HV1	SAVALAGI_110, HIREPADASALAGI_33, KALABILGI_33	17:35	17:54	0:19	LOAD CURTAILMENT
357	2-Jan-21	BAGALKOT	110	110/33KV,HV1	HANAGAL_110,PALA_33	17:52	18:01	0:09	LOAD CURTAILMENT
358	2-Jan-21	BAGALKOT	110	110/33KV,HV1	MUNDUGANUR_110	17:34	17:40	0:06	LOAD CURTAILMENT
359	2-Jan-21	BAGALKOT	110	110/33KV,HV1	MUNDUGANUR_110	17:47	17:59	0:12	LOAD CURTAILMENT
360	2-Jan-21	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA_33,MYTRA SOLAR_33	17:35	17:42	0:07	LOAD CURTAILMENT
361	2-Jan-21	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA_33,MYTRA SOLAR_33	17:50	18:14	0:24	LOAD CURTAILMENT
362	2-Jan-21	BAGALKOT	110	BIDNAL-GADAG ROAD	GADAG ROAD_110	10:15	17:12	6:57	NFBC ISSUED
363	2-Jan-21	BAGALKOT	110	GADAG ROAD-GOPANAKOPPA	STATION NOT AFFECTED GOPPANAKOPPA_110	9:34 02.01.2021)			LINE OPEN: LINE CLEAR AVAILED
364	2-Jan-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
365	2-Jan-21	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN: LINE CLEAR AVAILED
366	2-Jan-21	BAGALKOT	110	KIADB BIJAPUR-BHUTNAL	BHUTNAL_110	07:36	07:41	0:05	LINE FAULT
367	2-Jan-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
368	2-Jan-21	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)	13:35 (02.01.2020)	456:25hrs	LINE CHARGED
369	2-Jan-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
370	2-Jan-21	BAGALKOT	110	RON-GAMESH	RON_110, GAMESH IPP_110	12:48	13:08	0:20	LINE CLEAR AVAILED
371	2-Jan-21	BAGALKOT	110	SHIRAGUPPI SUGARS-KAGAWAD	KAGAWAD_110	13:50	14:54	1:04	LINE FAULT
372	2-Jan-21	BAGALKOT	110	UGARKHUD-KAGAWAD	KAGAWAD_110	13:06	14:50	1:44	LINE FAULT
373	2-Jan-21	BAGALKOT	110	UGARKHUD-UGARSUGARS	UGARKHUD_110, UGARSUGARS IPP_110	14:12	14:14	0:02	LINE FAULT
374	2-Jan-21	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	15:32	18:41	3:09	LINE CLEAR AVAILED
375	2-Jan-21	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM_220	10:30	15:17	4:47	LINE CLEAR AVAILED
376	2-Jan-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVAILED
377	2-Jan-21	BAGALKOT	220	HUBLI-NAGAJHARI2	STATION NOT AFFECTED HUBLI_220	15:15	15:56	0:41	LINE FAULT
378	2-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
379	2-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
380	2-Jan-21	BENGALURU	66	ABBIGERE - DG3	ABBIGERE	08:40	08:58	00:18	MAIN SUPPLY FAILURE
381	2-Jan-21	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	13:44	13:49	00:05	LOAD CHANGE OVER
382	2-Jan-21	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	14:38	14:49	00:11	LOAD CHANGE OVER
383	2-Jan-21	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	11:12	11:16	00:04	LOAD CHANGE OVER
384	2-Jan-21	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	08:40	08:54	00:14	LINE FAULT
385	2-Jan-21	BENGALURU	66	ATTUR YELAHANKA - DG 4	ATTUR YELAHANKA	13:20	13:26	00:06	LOAD CHANGE OVER
386	2-Jan-21	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN: LINE CLEAR AVAILED
387	2-Jan-21	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
388	2-Jan-21	BENGALURU	66	HANUMANTHNAGAR - KANAKAPURA 220	HANUMANTHNAGAR	12:05	12:20	00:15	LOAD CHANGE OVER
389	2-Jan-21	BENGALURU	66	HANUMANTHNAGAR - SOMANAHALLI 220	HANUMANTHNAGAR	18:00	18:10	00:10	LOAD CHANGE OVER
390	2-Jan-21	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	08:35	08:40	00:05	LOAD CHANGE OVER
391	2-Jan-21	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	19:00	19:05	00:05	LOAD CHANGE OVER
392	2-Jan-21	BENGALURU	66	HV2	APPAREL PARK	10:23	10:30	00:07	LINE CLEAR AVAILED
393	2-Jan-21	BENGALURU	66	HV2	YELAHANKA 220	11:40	11:42	00:02	LINE CLEAR AVAILED
394	2-Jan-21	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI, EXORA	14:20	14:30	00:10	LOAD CHANGE OVER
395	2-Jan-21	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI, EXORA	10:10	10:20	00:10	LOAD CHANGE OVER
396	2-Jan-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, YEDUMADU, GODUR	12:08	17:55	05:47	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
397	2-Jan-21	BENGALURU	66	WELCAST - ABBIGERE	WELCAST	08:40	08:50	00:10	LOAD CHANGE OVER
398	2-Jan-21	BENGALURU	66	WELCAST - SRS PEENYA 220	WELCAST	14:10	14:15	00:05	LOAD CHANGE OVER
399	2-Jan-21	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN: LINE CLEAR AVOIDED
400	2-Jan-21	GULBARGA	110	HV2	GINIGERA_110	09:25	09:50	00:25	LINE CLEAR AVOIDED
401	2-Jan-21	GULBARGA	110	HV2	HATTI_110	17:34	17:47	00:13	LOAD CURTAILMENT
402	2-Jan-21	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONNAGAR_110,HANUMNAL_110	10:35(2.1.2021)			LINE OPEN: LINE FAULT
403	2-Jan-21	GULBARGA	110	SHAHAPUR-KEMBAVI1	KEMBAVI_110,ASKI_110,HUNSAGI_110	23:33	23:46	00:13	LINE FAULT
404	2-Jan-21	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	17:16	17:35	00:19	LINE FAULT
405	2-Jan-21	GULBARGA	110	SINDHANOOR-SIRIGUPPA	SIRIGUPPA_110,TEKALKOTE_110,DHADESUGUR_110	11:33	11:38	00:05	LINE CLEAR AVOIDED
406	2-Jan-21	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	00:30	07:41	07:11	LINE CLEAR AVOIDED
407	2-Jan-21	GULBARGA	220	SHAHAPUR-LINGASUGUR	LINGASUGUR_220(IDLE LINE)	06:32	06:52	00:20	LINE FAULT
408	2-Jan-21	GULBARGA	220	SHAHAPUR-LINGASUGUR	LINGASUGUR_220(IDLE LINE)	07:00	15:40	08:40	LINE CLEAR AVOIDED
409	2-Jan-21	HASSAN	66	HASSN22-HN PURA	HASSAN_220	14:00	17:31	03:31	LINE FAULT
410	2-Jan-21	HASSAN	66	HASSN22-MALLALI	HASSAN_220	16:43	17:16	00:33	HAND TRIPPED
411	2-Jan-21	HASSAN	66	HV1	SHRAVANABELAGOLA_66	17:33	18:41	01:08	LOAD CURTAILMENT
412	2-Jan-21	HASSAN	66	HV1	BALEHONNUR_66	17:35	17:44	00:09	LOAD CURTAILMENT
413	2-Jan-21	HASSAN	66	HV1	BALEHONNUR_66	17:48	18:11	00:23	LOAD CURTAILMENT
414	2-Jan-21	HASSAN	66	HV1	HANGARANAHALLY_66	17:00	17:38	00:38	LOAD CURTAILMENT
415	2-Jan-21	HASSAN	66	HV1	MAGGE_66	11:02	12:31	01:29	LINE CLEAR AVOIDED
416	2-Jan-21	HASSAN	66	HV2	RAMESHWARNAGAR_66	17:37	17:50	00:13	LOAD CURTAILMENT
417	2-Jan-21	HASSAN	66	HV2	RAMESHWARNAGAR_66	17:54	18:24	00:30	LOAD CURTAILMENT
418	2-Jan-21	HASSAN	66	HV2	SALAGAME_66	17:37	18:02	00:25	LOAD CURTAILMENT
419	2-Jan-21	HASSAN	66	HV2	MAGGE_66	11:02	12:31	01:29	LINE CLEAR AVOIDED
420	2-Jan-21	HASSAN	66	HV2	BASAVAGHATTA_66	17:38	17:50	00:12	LOAD CURTAILMENT
421	2-Jan-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVOIDED
422	2-Jan-21	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVOIDED
423	2-Jan-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVOIDED
424	2-Jan-21	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	13:40	13:51	00:11	HAND TRIPPED
425	2-Jan-21	HASSAN	110	HV2	GANDSI_110	17:37	17:51	00:14	LOAD CURTAILMENT
426	2-Jan-21	HASSAN	110	HV2	GANDSI_110	17:55	18:15	00:20	LOAD CURTAILMENT
427	2-Jan-21	HASSAN	110	HV2	GERUMARA_110	17:38	17:58	00:20	LOAD CURTAILMENT
428	2-Jan-21	HASSAN	110	JOG-JLT4	mghejog_gen	11:11 (28.12.2020)			LINE OPEN: LINE CLEAR AVOIDED
429	2-Jan-21	HASSAN	110	SAGARA-LST4	SAGARA_110	10:00	17:20	07:20	NFBC ISSUED
430	2-Jan-21	HASSAN	110	SAGARA-SORABA	SAGARA_110	11:20	11:25	00:05	HAND TRIPPED
431	2-Jan-21	HASSAN	110	SHRLKP-MULKY	SHIRALKOPPA_220	11:08	17:14	06:06	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
432	2-Jan-21	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN: LINE CLEAR AVAILED
433	2-Jan-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	21:10 (2.01.2021)			LINE OPEN: LINE FAULT
434	2-Jan-21	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	21:10 (2.01.2021)			LINE OPEN: LINE FAULT
435	2-Jan-21	HASSAN	400	TALGU-NELAMANGALA#2	TALAGUPPA_400	21:03 (1.01.2021)	8:55 (2.01.2021)	11:51 hrs	LINE CHARGED
436	2-Jan-21	MYSORE	66	ANEGOLA-HUYGONALLI	ANEGOLAL_66	10:09	16:24	6:14	LINE CLEAR AVAILED
437	2-Jan-21	MYSORE	66	BEGUR 220-SARGUR	NO STATIONS EFFECTED	11:11	11:18	0:07	LINE FAULT
438	2-Jan-21	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	17:24(2.1.21)			LINE OPEN: LINE CLEAR AVAILED
439	2-Jan-21	MYSORE	66	HV1	BGNAGARA_66	17:38	17:44	0:06	LOAD CURTAILMENT
440	2-Jan-21	MYSORE	66	HV1	BGPURA_66	17:32	17:41	0:09	LOAD CURTAILMENT
441	2-Jan-21	MYSORE	66	HV1	BILIKERE_66	17:38	18:04	0:26	LOAD CURTAILMENT
442	2-Jan-21	MYSORE	66	HV1	DODDINADUVADI_66	17:38	17:43	0:05	LOAD CURTAILMENT
443	2-Jan-21	MYSORE	66	HV1	DEVANOORMYS_66	17:01	17:06	0:04	HAND TRIPPED
444	2-Jan-21	MYSORE	66	HV1	HANAGODU_66	17:36	18:25	0:48	TRANSFORMER FAULT
445	2-Jan-21	MYSORE	66	HV1	KRPET_66	17:36	17:57	0:20	LOAD CURTAILMENT
446	2-Jan-21	MYSORE	66	HV1	NAGAMANGALA_66	17:39	17:42	0:03	LOAD CURTAILMENT
447	2-Jan-21	MYSORE	66	HV1	PANDAVAPURA_66	17:37	17:56	0:19	LOAD CURTAILMENT
448	2-Jan-21	MYSORE	66	HV1	RAMAPURA_MYS_66	17:37	17:41	0:04	LOAD CURTAILMENT
449	2-Jan-21	MYSORE	66	HV1	RAMAPURA_MYS_66	17:47	18:16	0:28	LOAD CURTAILMENT
450	2-Jan-21	MYSORE	66	HV1	SATHEGALA_66	17:35	17:39	0:04	LOAD CURTAILMENT
451	2-Jan-21	MYSORE	66	HV1	SATHEGALA_66	17:46	18:01	0:15	LOAD CURTAILMENT
452	2-Jan-21	MYSORE	66	HV2	ADDIHALLI_66	17:38	17:45	0:06	LOAD CURTAILMENT
453	2-Jan-21	MYSORE	66	HV2	AKKIHEBBAL_66	17:33	17:40	0:07	LOAD CURTAILMENT
454	2-Jan-21	MYSORE	66	HV2	AKKIHEBBAL_66	17:46	18:00	0:13	LOAD CURTAILMENT
455	2-Jan-21	MYSORE	66	HV2	BILIKERE_66	13:22	13:34	0:11	TRANSFORMER FAULT
456	2-Jan-21	MYSORE	66	HV2	BOOKANAKERE_66	17:32	17:37	0:05	LOAD CURTAILMENT
457	2-Jan-21	MYSORE	66	HV2	BOOKANAKERE_66	17:47	17:52	0:05	LOAD CURTAILMENT
458	2-Jan-21	MYSORE	66	HV2	BOOKANAKERE_66	17:54	18:04	0:10	LOAD CURTAILMENT
459	2-Jan-21	MYSORE	66	HV2	CHINAKURALI_66	17:36	18:06	0:30	LOAD CURTAILMENT
460	2-Jan-21	MYSORE	66	HV2	GVGUDI_66	17:38	17:42	0:03	LOAD CURTAILMENT
461	2-Jan-21	MYSORE	66	HV2	HDKOTE_66	17:38	17:48	0:10	LOAD CURTAILMENT
462	2-Jan-21	MYSORE	66	HV2	JAIPUR_66	17:38	17:46	0:08	LOAD CURTAILMENT
463	2-Jan-21	MYSORE	66	HV2	KIRUGAVALU_66	17:37	17:54	0:17	LOAD CURTAILMENT
464	2-Jan-21	MYSORE	66	HV2	KIRUGAVALU_66	17:54	18:19	0:24	LOAD CURTAILMENT
465	2-Jan-21	MYSORE	66	HV2	KMDODDI_66	17:38	18:01	0:22	LOAD CURTAILMENT
466	2-Jan-21	MYSORE	66	HV2	KOLLEGALA_66	17:38	17:41	0:02	LOAD CURTAILMENT
467	2-Jan-21	MYSORE	66	HV2	MALAVALLI_66	17:37	17:46	0:09	TRANSFORMER FAULT
468	2-Jan-21	MYSORE	66	HV2	MALAVALLI_66	17:47	17:56	0:09	TRANSFORMER FAULT
469	2-Jan-21	MYSORE	66	HV2	MEGALAPURA_66	16:08	16:28	0:19	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
470	2-Jan-21	MYSORE	66	HV2	PONNAMPET_66	17:37	17:42	0:05	LOAD CURTAILMENT
471	2-Jan-21	MYSORE	66	HV2	SANTHEMARAHALLI_66	17:34	17:46	0:12	LOAD CURTAILMENT
472	2-Jan-21	MYSORE	66	HV2	SANTHEMARAHALLI_66	17:47	18:06	0:19	LOAD CURTAILMENT
473	2-Jan-21	MYSORE	66	HV2	THALAKADU_66	17:35	17:45	0:10	LOAD CURTAILMENT
474	2-Jan-21	MYSORE	66	HV2	THALAKADU_66	17:46	18:03	0:16	LOAD CURTAILMENT
475	2-Jan-21	MYSORE	66	HV2	TUBINAKERE_220	12:03	12:56	0:52	LINE CLEAR AVAILED
476	2-Jan-21	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	11:11	16:08	4:57	LINE CLEAR AVAILED
477	2-Jan-21	MYSORE	66	KADAKOLA-SARGUR 2	DOORA_66 HURA_66 HULLAHALLI_66,	11:11	16:09	4:58	LINE CLEAR AVAILED
478	2-Jan-21	MYSORE	66	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	11:19	18:12	6:53	NFBC ISSUED
479	2-Jan-21	MYSORE	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	13:47(2.1.21)			LINE OPEN: LINE CLEAR AVAILED
480	2-Jan-21	MYSORE	66	KUSHALNAGARA-BYLKUPPE	BYLUKUPPE_66	15:37	15:48	0:11	LINE FAULT
481	2-Jan-21	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	8:33	18:16	9:42	LINE CLEAR AVAILED
482	2-Jan-21	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	13:49	13:56	0:07	LINE FAULT
483	2-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	14:04	18:35	4:30	LINE CLEAR AVAILED
484	2-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	14:04	18:40	4:35	LINE CLEAR AVAILED
485	2-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	DODDASARANGI_66,MELKOTE_66, BADDIHALLI_66, HONNUDIKE_66, HIREHALLY_66	14:04	15:23	1:19	LINE CLEAR AVAILED
486	2-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	14:04	14:37	0:33	HAND TRIPPED
487	2-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	18:47	18:50	0:02	HAND TRIPPED
488	2-Jan-21	TUMKUR	66	GULIGENAHALLI- MADHUGIRI-1	GULIGENAHALLI_66	17:53	20:17	2:24	LINE CLEAR AVAILED
489	2-Jan-21	TUMKUR	66	H D PURA- CHITRADURGA220	HDPURA_66	12:39	12:42	0:02	MAIN SUPPLY FAILURE
490	2-Jan-21	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 1	HOLAVINAHALLY_66	17:51	18:00	0:09	HAND TRIPPED
491	2-Jan-21	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	17:51	17:58	0:06	HAND TRIPPED
492	2-Jan-21	TUMKUR	66	MADHUGIRI 220kV- SIRA 1	SIRA_66,GULIGENAHALLI_66,	17:51	20:12	2:20	LINE CLEAR AVAILED
493	2-Jan-21	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	MADHUGIRI_66	12:34	13:33	0:58	LINE CLEAR AVAILED
494	2-Jan-21	TUMKUR	66	MADHUGIRI 66kV- MADHUGIRI	MADHUGIRI_66	17:51	18:56	1:05	LINE CLEAR AVAILED
495	2-Jan-21	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	17:51	18:19	0:27	HAND TRIPPED
496	2-Jan-21	TUMKUR	66	MELKOTE-BADIHALLI	MELKOTE_66	14:09	19:07	4:58	LINE CLEAR AVAILED
497	2-Jan-21	TUMKUR	66	SASALUHALLA-MAYAKONDA	MAYAKONDA_66	10:33	10:53	0:20	HAND TRIPPED
498	2-Jan-21	TUMKUR	66	TR-1	HOSKERE_66	10:37	12:44	2:06	LINE CLEAR AVAILED
499	2-Jan-21	TUMKUR	66	TR-1	MADHUGIRI_66	12:34	13:33	0:58	LINE CLEAR AVAILED
500	2-Jan-21	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	14:06	18:31	4:25	LINE CLEAR AVAILED
501	2-Jan-21	TUMKUR	66	TR-2	MADHUGIRI_66	12:17	13:33	1:15	LINE CLEAR AVAILED
502	2-Jan-21	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	14:06	18:32	4:26	LINE CLEAR AVAILED
503	2-Jan-21	TUMKUR	66	URDIGERE-ANTHRASANAHALLI	URDIGERE_66	14:06	18:40	4:34	LINE CLEAR AVAILED
504	2-Jan-21	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	14:06	14:35	0:29	HAND TRIPPED
505	2-Jan-21	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	18:13	18:42	0:29	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
506	2-Jan-21	TUMKUR	110	TR-1	BANDIHALLI_110	12:00	13:04	1:03	LINE CLEAR AVAILED
507	2-Jan-21	TUMKUR	110	TR-1	BIDARE_110	11:50	13:32	1:41	LINE CLEAR AVAILED
508	2-Jan-21	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	15:42	15:56	0:13	TRANSFORMER FAULT
509	2-Jan-21	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	15:42	15:56	0:13	TRANSFORMER FAULT
510	2-Jan-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN: LINE CLEAR AVAILED
511	2-Jan-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN: LINE CLEAR AVAILED
512	2-Jan-21	TUMKUR	220	TR-2	ANTHRASANAHALLI_220	14:06	18:32	4:26	LINE CLEAR AVAILED
513	2-Jan-21	TUMKUR	220	TR-2	MADHUGIRI_220	15:28	17:51	2:23	TRANSFORMER FAULT
514	2-Jan-21	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	20:15(01.01.2021)	10:13:40 AM(02.01.2021)	14:00hrs	LINE CHARGED
515	3-Jan-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
516	3-Jan-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED ZALKI_110, HORTI_33	15:43	16:43	1:00	LINE CLEAR AVAILED
517	3-Jan-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
518	3-Jan-21	BAGALKOT	110	110/11KV,HV1	BELGAUM_110	09:05	17:29	8:24	LINE CLEAR AVAILED
519	3-Jan-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED ZALKI_110, HORTI_33	08:08	08:11	0:03	TRANSFORMER FAULT
520	3-Jan-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED ZALKI_110	15:15	15:20	0:05	TRANSFORMER FAULT
521	3-Jan-21	BAGALKOT	110	110/33KV,HV1,HV2	BELGAUM_110,RM1_33,SADASHIVA NAGAR_33,KLE_33,PORT_33	09:05	17:29	8:24	LINE CLEAR AVAILED
522	3-Jan-21	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	20:50	23:13	2:23	LOAD CURTAILMENT
523	3-Jan-21	BAGALKOT	110	BELGAUM220-BELGAUM	BELGAUM_110	09:05	17:27	8:22	LINE CLEAR AVAILED
524	3-Jan-21	BAGALKOT	110	BELGAUM220-BELGAUM	BELGAUM_110	9:04	15:05	6:01	LINE CLEAR AVAILED
525	3-Jan-21	BAGALKOT	110	BELGAUM220-VADAGON	STATION NOT AFFECTED VADAGON_110	09:39	15:16	5:37	LINE CLEAR AVAILED
526	3-Jan-21	BAGALKOT	110	ENERCON-BIJAPUR	BIJAPUR_220	17:20	18:36	1:16	LINE CLEAR AVAILED
527	3-Jan-21	BAGALKOT	110	GADAG ROAD-GOPANAKOPPA	GOPPANAKOPPA_110	9:34 02.01.2021)			LINE OPEN: LINE CLEAR AVAILED
528	3-Jan-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
529	3-Jan-21	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN: LINE CLEAR AVAILED
530	3-Jan-21	BAGALKOT	110	KANABARGI LAYOUT-NEHARUNAGAR(BELGAUM)	BELGAUM_110	9:16 (03.01.2021)			LINE OPEN: LINE CLEAR AVAILED
531	3-Jan-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
532	3-Jan-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
533	3-Jan-21	BAGALKOT	110	SHIRAGUPPI SUGARS-KAGAWAD	KAGAWAD_110	7:09	7:10	0:01	LINE FAULT
534	3-Jan-21	BAGALKOT	110	UGARKHUD-KAGAWAD	KAGAWAD_110	6:40	7:00	0:20	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
535	3-Jan-21	BAGALKOT	110	UGARKHUD-UGARSUGARS	UGARKHUD_110, UGARSUGARS IPP_110	6:49	6:51	0:02	LINE FAULT
536	3-Jan-21	BAGALKOT	220	220/110KV,HV2,LV2	NO STATION AFFECTED BELGAUM_220	10:23	14:22	3:59	LINE CLEAR AVOIDED
537	3-Jan-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	20:10 (03.01.2021)			LOAD CURTAILMENT
538	3-Jan-21	BAGALKOT	220	BELGAUM-CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	20:11 (03.01.2021)			LOAD CURTAILMENT
539	3-Jan-21	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	20:07 (03.01.2021)			LOAD CURTAILMENT
540	3-Jan-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVOIDED
541	3-Jan-21	BAGALKOT	220	NARENDRA-BELGAUM1	STATION NOT AFFECTED NARENDRA_220	20:12 (03.01.2021)			LOAD CURTAILMENT
542	3-Jan-21	BAGALKOT	220	RBRK-BAGEWADI	STATION NOT AFFECTED BAGEWADI_220	14:56	15:07	0:11	LINE FAULT
543	3-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
544	3-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
545	3-Jan-21	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN: LINE CLEAR AVOIDED
546	3-Jan-21	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
547	3-Jan-21	BENGALURU	66	GUNDLU KOTTUR - GOWRIBIDANUR 220	GUNDLU KOTTUR	10:00	13:00	03:00	LINE CLEAR AVOIDED
548	3-Jan-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	20:16	20:29	00:13	LINE FAULT
549	3-Jan-21	BENGALURU	66	HV2	KADUGODI	11:35	13:01	01:26	LINE CLEAR AVOIDED
550	3-Jan-21	BENGALURU	66	PLATINUM CITY - DG 3	PLATINUM CITY	13:36	14:00	00:24	LOAD CHANGE OVER
551	3-Jan-21	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	17:00	17:10	00:10	LOAD CHANGE OVER
552	3-Jan-21	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN: LINE CLEAR AVOIDED
553	3-Jan-21	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONNAGAR_110, HANUMNAL_110	10:35(2.1.2021)	16:02(3.1.2021)	29:25 HRS	LINE CHARGED
554	3-Jan-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADONA_110, SRERAMNAGAR_110,MALLAPURA_110	13:55	14:20	00:25	LINE FAULT
555	3-Jan-21	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	01:26	12:57	11:31	LINE CLEAR AVOIDED
556	3-Jan-21	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	10:03	13:05	03:02	LINE CLEAR AVOIDED
557	3-Jan-21	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:11	11:25	01:14	MAIN SUPPLY FAILURE
558	3-Jan-21	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	12:30	13:15	00:45	MAIN SUPPLY FAILURE
559	3-Jan-21	HASSAN	66	HV1	GORUR_66	16:20	16:59	00:39	LINE CLEAR AVOIDED
560	3-Jan-21	HASSAN	66	HV1	MALALI_66	10:05	11:21	01:16	MAIN SUPPLY FAILURE
561	3-Jan-21	HASSAN	66	HV1	MALALI_66	12:31	13:10	00:39	MAIN SUPPLY FAILURE
562	3-Jan-21	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
563	3-Jan-21	HASSAN	66	LV3	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
564	3-Jan-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
565	3-Jan-21	HASSAN	66	MALALI-CRPATNA	MALALI_66	10:05	11:21	01:16	MAIN SUPPLY FAILURE
566	3-Jan-21	HASSAN	66	MALALI-CRPATNA	MALALI_66	12:31	13:10	00:39	MAIN SUPPLY FAILURE
567	3-Jan-21	HASSAN	66	MALALI-HASSAN	MALALI_66	10:05	13:10	03:05	MAIN SUPPLY FAILURE
568	3-Jan-21	HASSAN	66	SHANTHI-MALALI	SHANTHIGRAMMA_66	10:05	11:15	01:10	MAIN SUPPLY FAILURE
569	3-Jan-21	HASSAN	66	SHANTHI-MALALI	SHANTHIGRAMMA_66	12:32	13:10	00:38	HAND TRIPPED
570	3-Jan-21	HASSAN	110	HV2	HALADY_110	10:35	11:01	00:26	HAND TRIPPED
571	3-Jan-21	HASSAN	110	HV2	BAIKAMPADI_110	10:14	15:52	05:38	LINE CLEAR AVAILED
572	3-Jan-21	HASSAN	110	HV2	SAGARA_110	23:15	23:40	00:25	TRANSFORMER FAULT
573	3-Jan-21	HASSAN	110	HV4	BAIKAMPADI_110	13:03	14:42	01:39	LINE CLEAR AVAILED
574	3-Jan-21	HASSAN	110	JOG-JLT4	mghejog_gen	11:11 (28.12.2020)			LINE OPEN: LINE CLEAR AVAILED
575	3-Jan-21	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN: LINE CLEAR AVAILED
576	3-Jan-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	10:56	16:21	05:25	LINE CLEAR AVAILED
577	3-Jan-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	11:27	16:22	04:55	LINE CLEAR AVAILED
578	3-Jan-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	10:56	16:21	05:25	LINE CLEAR AVAILED
579	3-Jan-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	21:10 (2.01.2021)	8:16 (03.01.2021)	11:05 hrs	LINE CHARGED
580	3-Jan-21	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	21:10 (2.01.2021)	8:16 (03.01.2021)	11:05 hrs	LINE CHARGED
581	3-Jan-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	11:13	16:21	05:08	LINE CLEAR AVAILED
582	3-Jan-21	HASSAN	400	TALGU-NELAMANGALA#2	TALAGUPPA_400	21:33 (3.01.2021)			LINE OPEN: LINE CLEAR AVAILED
583	3-Jan-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	19:37 (3.01.2021)			LINE OPEN: LINE CLEAR AVAILED
584	3-Jan-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	00:07	07:39	07:32	LINE CLEAR AVAILED
585	3-Jan-21	MYSORE	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	13:55	14:01	0:06	LINE FAULT
586	3-Jan-21	MYSORE	66	CR NAGARA-HONNALLI	ATTIGULIPURA_66 HONNALLY_MYS_66	13:55	14:03	0:07	LINE FAULT
587	3-Jan-21	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	17:24 (02.01.2021)	17:13	23:48HRS	LINE CHARGED
588	3-Jan-21	MYSORE	66	DR PETE-KUNTHUR	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 SANTHEMARAHALLI_66	11:28	11:36	0:08	LINE FAULT
589	3-Jan-21	MYSORE	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	8:03	16:04	8:01	NFBC ISSUED
590	3-Jan-21	MYSORE	66	KOLLEGALA-SATHEGALA	KOLLEGALA_66	10:55	18:09	7:14	NFBC ISSUED
591	3-Jan-21	MYSORE	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	13:47 (02.01.2021)	19:06	29:19HRS	LINE CHARGED
592	3-Jan-21	MYSORE	66	KOPPA 66-NSL	NO STATIONS EFFECTED	10:52	11:09	0:17	HAND TRIPPED
593	3-Jan-21	MYSORE	66	MADHUVANAHALLI-HANNUR 1	NO STATIONS EFFECTED	15:00	15:06	0:05	LINE FAULT
594	3-Jan-21	MYSORE	66	PANDAVAPURA-ATRIA1	NO STATIONS EFFECTED	9:47	19:32	9:44	LINE CLEAR AVAILED
595	3-Jan-21	MYSORE	66	PANDAVAPURA-ATRIA2	NO STATIONS EFFECTED	9:47	19:32	9:44	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
596	3-Jan-21	MYSORE	66	PANDAVAPURA-TUBINKERE	PANDAVAPURA_66	10:08	17:51	7:42	LINE CLEAR AVAILED
597	3-Jan-21	MYSORE	66	TALKADU-ADANI	NO STATIONS EFFECTED	7:37	7:47	0:09	LINE FAULT
598	3-Jan-21	MYSORE	66	TALKADU-PARINAMIPURA	CHANDALLI_66 THALAKADU_66	7:37	7:43	0:05	LINE FAULT
599	3-Jan-21	MYSORE	66	TN PURA-MUGUR	TNARASIPURA_66	8:05	8:11	0:06	HAND TRIPPED
600	3-Jan-21	MYSORE	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	11:44	14:11	2:27	NFBC ISSUED
601	3-Jan-21	MYSORE	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	16:24	16:59	0:34	NFBC ISSUED
602	3-Jan-21	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	19:47	20:06	0:18	LINE FAULT
603	3-Jan-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:50	15:59	0:09	LINE FAULT
604	3-Jan-21	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	11:32	12:19	0:46	HAND TRIPPED
605	3-Jan-21	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	PULAMG_66	11:48	12:17	0:28	HAND TRIPPED
606	3-Jan-21	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	PULAMG_66	18:04	18:22	0:17	HAND TRIPPED
607	3-Jan-21	TUMKUR	66	PAVAGADA66-MADHUGIRI	PAVAGADA_66	6:36	6:49	0:13	LINE FAULT
608	3-Jan-21	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	6:36	6:52	0:16	LINE FAULT
609	3-Jan-21	TUMKUR	66	TR-1	MADHUGIRI 220kv	11:35	11:49	0:13	HAND TRIPPED
610	3-Jan-21	TUMKUR	66	TR-1	VENKATAPURA_66	9:04	9:24	0:19	TRANSFORMER FAULT
611	3-Jan-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN: LINE CLEAR AVAILED
612	3-Jan-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN: LINE CLEAR AVAILED
613	3-Jan-21	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	20:55(03.01.2021)			LINE OPEN: LINE CLEAR AVAILED
614	4-Jan-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
615	4-Jan-21	BAGALKOT	110	110/11KV, HV1	MUNDAGANUR_110	8:13	8:27	0:14	LOAD CURTAILMENT
616	4-Jan-21	BAGALKOT	110	110/11KV, HV2	SHIROL_110	17:03	18:15	1:12	LINE CLEAR AVAILED
617	4-Jan-21	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	15:20	15:56	0:36	LINE CLEAR AVAILED
618	4-Jan-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
619	4-Jan-21	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	11:21 (04.01.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
620	4-Jan-21	BAGALKOT	110	110/11KV,HV2	AIGALI_110	10:06	10:20	0:14	TRANSFORMER FAULT
621	4-Jan-21	BAGALKOT	110	110/33KV,HV2	ANKOLA_110 & SEABIRD_33,MASTIKATTA_33	12:29	12:37	0:08	TRANSFORMER FAULT
622	4-Jan-21	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MKHUBLI_220	2:13	8:55	6:42	LOAD CURTAILMENT
623	4-Jan-21	BAGALKOT	110	AINAPUR-ATHANI SUGARS	STATION NOT AFFECTED AINAPUR_110	12:20	12:33	0:13	LINE FAULT
624	4-Jan-21	BAGALKOT	110	BIDNAL -GADAG ROAD	GADAG ROAD_110	10:46	11:56	1:10	LINE CLEAR AVAILED
625	4-Jan-21	BAGALKOT	110	BIJAPUR-ENERCON(BAGEWADI)	STATION NOT AFFECTED BIJAPUR_220	19:20	19:34	0:14	LINE FAULT
626	4-Jan-21	BAGALKOT	110	GADAG ROAD-GOPANAKOPPA	GOPPANAKOPPA_110	9:34 02.01.2021)	12:15 (04.01.2021)	50:41hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
627	4-Jan-21	BAGALKOT	110	GADAG-DAMBAL1	STATION NOT AFFECTED GADAG_110	16:15	18:19	2:04	LINE CLEAR AVOIDED
628	4-Jan-21	BAGALKOT	110	HALIYAL-GMR	(STATION NOT AFFECTED) HALIYAL_110	18:50	19:06	0:16	LINE FAULT
629	4-Jan-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVOIDED
630	4-Jan-21	BAGALKOT	110	HAVERI-TILUVALLI (HANAGAL)	TILUVALLI_110	15:51	18:38	2:47	LINE CLEAR AVOIDED
631	4-Jan-21	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN: LINE CLEAR AVOIDED
632	4-Jan-21	BAGALKOT	110	ITANAL-RAIBAG 1	STATION NOT AFFECTED ITNAL_110	20:21	20:27	0:06	LINE CLEAR AVOIDED
633	4-Jan-21	BAGALKOT	110	ITANAL-RAIBAG 2	STATION NOT AFFECTED ITNAL_110	19:49	20:21	0:32	LINE FAULT
634	4-Jan-21	BAGALKOT	110	KAGAWAD- SHIRAGUPPI SUGARS	STATION NOT AFFECTED KAGAWAD_110	17:55	19:07	1:12	LINE CLEAR AVOIDED
635	4-Jan-21	BAGALKOT	110	KANABARGI LAYOUT-NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN: LINE CLEAR AVOIDED
636	4-Jan-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
637	4-Jan-21	BAGALKOT	110	KUD DHARWAD- TADASINKOPPA	STATION NOT AFFECTED TADASINKOPPA_110	11:23	17:46	6:23	NFBC ISSUED
638	4-Jan-21	BAGALKOT	110	KUDACHI220- UGARKHUD (KUDACHI110)	KUDACHI_110	10:37	15:27	4:50	LINE CLEAR AVOIDED
639	4-Jan-21	BAGALKOT	110	KUMATA- SIRSI1	STATION NOT AFFECTED KUMATA_110	16:59 (04.01.2021)			LINE OPEN: LINE FAULT
640	4-Jan-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
641	4-Jan-21	BAGALKOT	110	SAMBAPUR ROAD- GADAG	STATION NOT AFFECTED SAMBAPUR ROAD_110	16:15	18:19	2:04	LINE CLEAR AVOIDED
642	4-Jan-21	BAGALKOT	110	SIRSI(AMBEWADI- KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	18:50 (04.01.2021)			LINE OPEN: LINE FAULT
643	4-Jan-21	BAGALKOT	110	SOUDATTI220- MUNAVALLY	STATION NOT AFFECTED MUNVALLY_110	11:37	12:53	1:16	LINE CLEAR AVOIDED
644	4-Jan-21	BAGALKOT	220	220/110KV,HV2 & LV 2	STATION NOT AFFECTED GADAG_220	10:37	18:16	7:39	LINE CLEAR AVOIDED
645	4-Jan-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	20:10 (03.01.2021)	8:08 (04.01.2021)	12:01	LOAD CURTAILMENT
646	4-Jan-21	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	20:07 (03.01.2021)	8:06 (04.01.2021)	11:59	LOAD CURTAILMENT
647	4-Jan-21	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	11:50	14:55	3:05	LINE CLEAR AVOIDED
648	4-Jan-21	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	17:25	17:31	0:06	HAND TRIPPED
649	4-Jan-21	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM_220	15:16	17:13	1:57	LINE CLEAR AVOIDED
650	4-Jan-21	BAGALKOT	220	BIDNAL-HAVERI	STATION NOT AFFECTED BIDNAL_220	22:45 (04.01.2021)			LINE OPEN: LINE FAULT
651	4-Jan-21	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	20:11 (03.01.2021)	8:08 (04.01.2021)	12:02	LOAD CURTAILMENT
652	4-Jan-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
653	4-Jan-21	BAGALKOT	220	HAVERI-BIDNAL (NARENDRA 1)	STATION NOT AFFECTED HAVERI_220	22:46 (04.01.2021)			LINE OPEN: LINE FAULT
654	4-Jan-21	BAGALKOT	220	MKHUBLI- NARENDRA1	STATION NOT AFFECTED MKHUBLI_220	10:38	18:48	8:10	LINE CLEAR AVALIED
655	4-Jan-21	BAGALKOT	220	NARENDRA-BELGAUM1	STATION NOT AFFECTED NARENDRA_220	20:12 (03.01.2021)	8:07 (04.01.2021)	11:55	LOAD CURTAILMENT
656	4-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
657	4-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
658	4-Jan-21	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN: LINE CLEAR AVALIED
659	4-Jan-21	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
660	4-Jan-21	BENGALURU	66	HV1	MEI LAYOUT	12:59	13:04	00:05	LINE CLEAR AVALIED
661	4-Jan-21	BENGALURU	66	HV1	S M MANGALA	12:30	13:09	00:39	LINE CLEAR AVALIED
662	4-Jan-21	BENGALURU	66	HV2	BRIGADE MEADOWS	19:50	20:58	01:08	TRANSFORMER FAULT
663	4-Jan-21	BENGALURU	66	HV3	NELAMANGALA 66	11:05	13:08	02:03	LINE CLEAR AVALIED
664	4-Jan-21	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN: LINE CLEAR AVALIED
665	4-Jan-21	GULBARGA	110	HV2	GINIGERA_110	08:50	09:30	00:40	LINE CLEAR AVALIED
666	4-Jan-21	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HUNSAGI_110	04:25	04:32	00:07	LINE FAULT
667	4-Jan-21	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	22:50	23:05	00:15	LINE FAULT
668	4-Jan-21	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	15:45	15:48	00:03	LINE CLEAR AVALIED
669	4-Jan-21	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	10:09	10:54	00:45	LINE CLEAR AVALIED
670	4-Jan-21	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	10:54	14:54	04:00	LINE FAULT
671	4-Jan-21	GULBARGA	220	SINDHANOOR-LINGAPUR	SINDHANOOR_220	08:20	14:15	05:55	LINE CLEAR AVALIED
672	4-Jan-21	GULBARGA	400	BTPS-RTPS	RTPS_400	02:02	07:22	05:20	LINE CLEAR AVALIED
673	4-Jan-21	HASSAN	66	HV1	HAGARE_66	12:59	13:13	00:14	LINE CLEAR AVALIED
674	4-Jan-21	HASSAN	66	HV1	HALEBEEDU_66	12:30	18:30	06:00	LINE CLEAR AVALIED
675	4-Jan-21	HASSAN	66	HV1	HALEBEEDU_66	18:55	20:25	01:30	LINE CLEAR AVALIED
676	4-Jan-21	HASSAN	66	HV1	HANGARANAHALLY_66	08:15	08:30	00:15	LOAD CURTAILMENT
677	4-Jan-21	HASSAN	66	HV1	HOLEHONNUR_66	11:14	17:48	06:34	LINE CLEAR AVALIED
678	4-Jan-21	HASSAN	66	HV1	MATTNAVILE_66	12:45	14:31	01:46	LINE CLEAR AVALIED
679	4-Jan-21	HASSAN	66	HV1	MALLAPURA_66	01:03	06:54	05:51	MAIN SUPPLY FAILURE
680	4-Jan-21	HASSAN	66	HV2	HOLALUR_66	17:39	18:23	00:44	LINE CLEAR AVALIED
681	4-Jan-21	HASSAN	66	HV2	HOLEHONNUR_66	10:37	17:48	07:11	LINE CLEAR AVALIED
682	4-Jan-21	HASSAN	66	HV2	MATTNAVILE_66	11:55	12:45	00:50	LINE CLEAR AVALIED
683	4-Jan-21	HASSAN	66	HV2	MALLAPURA_66	01:03	06:54	05:51	MAIN SUPPLY FAILURE
684	4-Jan-21	HASSAN	66	HV2	BASAVAGHATTA_66	08:15	08:29	00:14	LOAD CURTAILMENT
685	4-Jan-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVALIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
686	4-Jan-21	HASSAN	66	LV3	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
687	4-Jan-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
688	4-Jan-21	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	01:03	06:52	05:49	MAIN SUPPLY FAILURE
689	4-Jan-21	HASSAN	110	HV1	ANAVATTI_110	16:05	16:10	00:05	TRANSFORMER FAULT
690	4-Jan-21	HASSAN	110	HV2	ANAVATTI_110	16:05	16:10	00:05	TRANSFORMER FAULT
691	4-Jan-21	HASSAN	110	HV2	BAIKAMPADI_110	10:04	13:08	03:04	LINE CLEAR AVAILED
692	4-Jan-21	HASSAN	110	HV2	GERUMARA_110	08:15	08:38	00:23	LOAD CURTAILMENT
693	4-Jan-21	HASSAN	110	HV2	GURUPURA_110	11:02	11:59	00:57	LINE CLEAR AVAILED
694	4-Jan-21	HASSAN	110	HV2	SAGARA_110	01:09	16:57	15:48	TRANSFORMER FAULT
695	4-Jan-21	HASSAN	110	JOG-JLT4	mghejog_gen	11:11 (28.12.2020)			LINE OPEN: LINE CLEAR AVAILED
696	4-Jan-21	HASSAN	110	SAGARA-LST4	SAGARA_110	14:33	18:05	03:32	NFBC ISSUED
697	4-Jan-21	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_110	19:13	20:33	01:20	LINE FAULT
698	4-Jan-21	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN: LINE CLEAR AVAILED
699	4-Jan-21	HASSAN	220	KEMAR-Varahi3	KEMAR_220	11:18	17:26	06:08	LINE CLEAR AVAILED
700	4-Jan-21	HASSAN	220	VARAHI-KEMAR3	varahi_gen	11:18	17:26	06:08	NFBC ISSUED
701	4-Jan-21	HASSAN	400	TALGU-NELAMANGALA#2	TALAGUPPA_400	21:33 (3.01.2021)	8:27 (4.01.2021)	10:53 hrs	LINE CHARGED
702	4-Jan-21	HASSAN	400	TALGU-NELAMANGALA#2	TALAGUPPA_400	21:33 (3.01.2021)			LINE OPEN: LINE CLEAR AVAILED
703	4-Jan-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	19:37 (3.01.2021)	7:20(4.01.2021)	11:42 hrs	LINE CHARGED
704	4-Jan-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:10 (4.01.2021)			LINE OPEN: LINE CLEAR AVAILED
705	4-Jan-21	MYSORE	66	BESAGRALLI-DUNDANAHALLI	NO STATIONS EFFECTED	12:03	13:48	1:44	LINE CLEAR AVAILED
706	4-Jan-21	MYSORE	66	BESAGRALLI-KOPPA	BESAGARAHALLI_66	13:10	13:40	0:30	LINE CLEAR AVAILED
707	4-Jan-21	MYSORE	66	HEBBANI-VADKEPURA	NO STATIONS EFFECTED	14:45	15:01	0:15	LINE FAULT
708	4-Jan-21	MYSORE	66	HV1	BGNAGARA_66	8:14	8:19	0:04	LOAD CURTAILMENT
709	4-Jan-21	MYSORE	66	HV1	BGPURA_66	8:14	8:32	0:18	LOAD CURTAILMENT
710	4-Jan-21	MYSORE	66	HV1	BILIKERE_66	8:14	8:30	0:16	LOAD CURTAILMENT
711	4-Jan-21	MYSORE	66	HV1	DODDINADUVADI_66	8:14	8:20	0:05	LOAD CURTAILMENT
712	4-Jan-21	MYSORE	66	HV1	KUSHALANAGARA_66	8:14	8:21	0:07	LOAD CURTAILMENT
713	4-Jan-21	MYSORE	66	HV1	MADHUVANAHALLI_220	15:04	15:25	0:20	LINE CLEAR AVAILED
714	4-Jan-21	MYSORE	66	HV1	MALAVALLI_66	8:45	18:23	9:38	LINE CLEAR AVAILED
715	4-Jan-21	MYSORE	66	HV1	SATHEGALA_66	8:12	8:45	0:32	LOAD CURTAILMENT
716	4-Jan-21	MYSORE	66	HV1	BEGUR_220	13:20	13:46	0:26	LINE CLEAR AVAILED
717	4-Jan-21	MYSORE	66	HV2	ADDIHALLI_66	8:14	8:21	0:07	LOAD CURTAILMENT
718	4-Jan-21	MYSORE	66	HV2	AKKIHEBBAL_66	8:14	8:23	0:09	LOAD CURTAILMENT
719	4-Jan-21	MYSORE	66	HV2	BOOKANAKERE_66	8:14	8:24	0:09	LOAD CURTAILMENT
720	4-Jan-21	MYSORE	66	HV2	CHINAKURALI_66	8:14	8:26	0:12	LOAD CURTAILMENT
721	4-Jan-21	MYSORE	66	HV2	HDKOTE_66	8:14	8:38	0:23	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
722	4-Jan-21	MYSORE	66	HV2	JAIPUR_66	8:15	8:37	0:22	LOAD CURTAILMENT
723	4-Jan-21	MYSORE	66	HV2	MALAVALLI_66	8:45	18:23	9:38	LINE CLEAR AVAILED
724	4-Jan-21	MYSORE	66	HV2	MEGALAPURA_66	12:17	13:00	0:43	LINE CLEAR AVAILED
725	4-Jan-21	MYSORE	66	HV2	SANTHEMARAHALLI_66	8:12	8:44	0:31	LOAD CURTAILMENT
726	4-Jan-21	MYSORE	66	HV2	THALAKADU_66	8:13	8:34	0:21	LOAD CURTAILMENT
727	4-Jan-21	MYSORE	66	HV3	KIKKERI_66	13:19	14:13	0:54	LOAD CURTAILMENT
728	4-Jan-21	MYSORE	66	HV3	KRPET_66	12:14 (04.01.20201)			TRANSFORMER OPEN: LINE CLEAR AVAILED
729	4-Jan-21	MYSORE	66	KOLLEGALA-MADHUVANAHALLI	KOLLEGALA_66	16:45	16:50	0:05	MAIN SUPPLY FAILURE
730	4-Jan-21	MYSORE	66	KOLLEGALA-PARINAMIPURA	CHANDALLI_66, PARINAMIPURA_66 , THALAKADU_66	16:45	16:50	0:05	LINE FAULT
731	4-Jan-21	MYSORE	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	16:45	16:50	0:05	MAIN SUPPLY FAILURE
732	4-Jan-21	MYSORE	66	MALAVALLI-MANDYA	MALAVALLI_66 HADLI_66	13:50	15:03	1:12	NFBC ISSUED
733	4-Jan-21	MYSORE	66	MEGHALAPURA-HEBBANI	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	14:45	14:58	0:12	LINE FAULT
734	4-Jan-21	MYSORE	66	VAJMANGALA-BANNUR	NO STATIONS EFFECTED	8:29	8:36	0:07	LINE FAULT
735	4-Jan-21	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	9:18	10:04	0:45	HAND TRIPPED
736	4-Jan-21	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI(HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	8:22	8:44	0:21	LOAD CURTAILMENT
737	4-Jan-21	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	12:11	12:22	0:11	LINE FAULT
738	4-Jan-21	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	CHITRADURGA_66	9:55	10:20	0:25	MAIN SUPPLY FAILURE
739	4-Jan-21	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:11	13:48	4:36	LINE CLEAR AVAILED
740	4-Jan-21	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	15:46	16:00	0:13	LINE CLEAR AVAILED
741	4-Jan-21	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	11:22	13:11	1:49	LINE CLEAR AVAILED
742	4-Jan-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	17:30	17:48	0:17	LINE FAULT
743	4-Jan-21	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	17:30	17:46	0:15	LINE FAULT
744	4-Jan-21	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	11:30	14:44	3:14	LINE CLEAR AVAILED
745	4-Jan-21	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	MADHUGIRI_66	11:10	14:51	3:41	LINE CLEAR AVAILED
746	4-Jan-21	TUMKUR	66	MADHUGIRI 66kV- MADHUGIRI	MADHUGIRI_66	11:10	14:45	3:35	LINE CLEAR AVAILED
747	4-Jan-21	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	11:38	12:21	0:43	LINE FAULT
748	4-Jan-21	TUMKUR	66	TR-1	CHANNAGIRI_66	17:45	17:48	0:03	TRANSFORMER FAULT
749	4-Jan-21	TUMKUR	66	TR-1	TAVAREKERE(C)_66	4:05	4:10	0:05	TRANSFORMER FAULT
750	4-Jan-21	TUMKUR	66	TR-1	THIMMASANDRA_66	12:10	12:41	0:30	LINE CLEAR AVAILED
751	4-Jan-21	TUMKUR	66	TR-2	HOSAKERE_66	10:57	11:22	0:24	LINE CLEAR AVAILED
752	4-Jan-21	TUMKUR	66	TR-2	LINGADAHALLI_TM2_66	1:32	9:28	7:56	LINE CLEAR AVAILED
753	4-Jan-21	TUMKUR	66	TR-2	MADHUGIRI_66	15:13	15:49	0:35	TRANSFORMER FAULT
754	4-Jan-21	TUMKUR	66	TR-2	THIMMASANDRA_66	11:44	12:08	0:24	LINE CLEAR AVAILED
755	4-Jan-21	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,TALKERE_110	11:57	12:10	0:12	LINE CLEAR AVAILED
756	4-Jan-21	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,TALKERE_110	14:07	14:16	0:08	LINE CLEAR AVAILED
757	4-Jan-21	TUMKUR	110	TR-2	NITTUR_220	10:27	10:28	0:01	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
758	4-Jan-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN: LINE CLEAR AVAILED
759	4-Jan-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN: LINE CLEAR AVAILED
760	4-Jan-21	TUMKUR	220	TR-2	MADHUGIRI 220kv	17:10	17:17	0:07	LINE CLEAR AVAILED
761	4-Jan-21	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	20:55:54 (03.01.2021)	7:17:29 (04.01.2021)	10:22hrs	LINE CHARGED
762	4-Jan-21	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	9:45:16 PM(04.01.2020)			LINE OPEN: LINE CLEAR AVAILED