

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 17.09.2019 TO 23.09.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	17-Sep-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	6:01	9:25	3:24	LINE CLEAR AVAILED
2	17-Sep-19	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	0:00	9:23	9:23	LINE CLEAR AVAILED
3	17-Sep-19	BAGALKOT	110	BELGAUM-UCHAGOAN(HUKKERI)	UCHAGOAN_110	6:16	9:49	3:33	LINE CLEAR AVAILED
4	17-Sep-19	BAGALKOT	110	110/11KV,HV 1&3	BILAGI_110	15:54	16:06	0:12	TRANSFORMER FAULT
5	17-Sep-19	BAGALKOT	110	CHIKKODI-SADALAGA	SADALAGA_110	10:28	12:21	1:53	LINE CLEAR AVAILED
6	17-Sep-19	BAGALKOT	110	110/33KV,HV4	HIDIKAL_110KV &ALGAWADI_33KV	14:30	14:38	0:08	HAND TRIPPED
7	17-Sep-19	BAGALKOT	110	KADANKOPPA-KAVLWAD	KAVALWAD_110	11:20	16:24	5:04	LINE CLEAR AVAILED
8	17-Sep-19	BAGALKOT	110	110/33KV, HV3	TODALBAGI_110, BIDARI_33, HIREPADASLAGI_33	12:15	12:26	0:11	LINE CLEAR AVAILED
9	17-Sep-19	BAGALKOT	110	JAMKHANDI SUGARS-TODALBAGI	TODALBAGI_110	20:08	20:13	0:05	LINE FAULT
10	17-Sep-19	BAGALKOT	110	110/33KV, HV3	TARIHAL_110, DUMMAWAD_33, IE_33	22:08	22:35	0:27	TRANSFORMER FAULT
11	17-Sep-19	BAGALKOT	220	220/110KV, HV2&LV2	NARENDRA_220	13:49	13:58	0:09	TRANSFORMER FAULT
12	17-Sep-19	BAGALKOT	110	110/33KV, HV3	LAXMESHVAR_110, MMCL_33, SSM_33	8:18	8:41	0:23	TRANSFORMER FAULT
13	17-Sep-19	BAGALKOT	110	110/11KV, HV1	KUD DHARWAD_110	11:08	11:31	0:23	LINE CLEAR AVAILED
14	17-Sep-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	7:14	7:22	0:08	LINE FAULT
15	17-Sep-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	11:27	11:30	0:03	LINE CLEAR AVAILED
16	17-Sep-19	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHAPURA	23:23	23:30	0:07	LINE FAULT
17	17-Sep-19	BENGALURU	66	HV2	GOWRIBIDANUR 220	8:43	8:48	0:05	TRANSFORMER FAULT
18	17-Sep-19	BENGALURU	66	HV1	VOLVO	11:42	12:47	1:05	LINE CLEAR AVAILED
19	17-Sep-19	BENGALURU	66	HV2	VOLVO	11:42	12:48	1:06	LINE CLEAR AVAILED
20	17-Sep-19	BENGALURU	66	HV1	ISRO LAYOUT	8:46	10:34	1:47	LINE CLEAR AVAILED
21	17-Sep-19	BENGALURU	66	HV1	ISRO LAYOUT	2:48	7:50	5:02	TRANSFORMER FAULT
22	17-Sep-19	BENGALURU	66	HV2	KADUBISANAHALLI	14:42	16:03	1:21	LINE CLEAR AVAILED
23	17-Sep-19	BENGALURU	66	HV1	KADUBISANAHALLI	14:43	16:05	1:21	LINE CLEAR AVAILED
24	17-Sep-19	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	12:06	12:41	0:34	LINE CLEAR AVAILED
25	17-Sep-19	GULBARGA	220	SHAHPUR-LINGASUGUR	SHAHPUR_220	4:28	14:47	10:19	LINE FAULT
26	17-Sep-19	GULBARGA	220	HV1	ITTAGI_220	23:38	23:50	0:12	TRANSFORMER FAULT
27	17-Sep-19	GULBARGA	220	ITTAGI-NEELAGUNDA	ITTAGI_220	13:25	15:56	2:31	NFBC ISSUED
28	17-Sep-19	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110, NIRNA_110	6:13	6:33	0:20	LINE FAULT
29	17-Sep-19	GULBARGA	110	SINDHANOOR-TURUVIHAL	TURVIHAL_110	4:35	4:48	0:13	LINE FAULT
30	17-Sep-19	GULBARGA	110	HV2	ITTAGI_220	11:48	14:00	2:12	LINE CLEAR AVAILED
31	17-Sep-19	GULBARGA	110	MASKI-RNWSLR_IPP	MASKI_110	10:40	10:47	0:07	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
32	17-Sep-19	GULBARGA	110	HV3	SHORAPUR_110	0:02	0:05	0:03	TRANSFORMER FAULT
33	17-Sep-19	GULBARGA	110	HV2	SHORAPUR_110	23:28	23:35	0:07	TRANSFORMER FAULT
34	17-Sep-19	GULBARGA	110	HV3	BEVOOR_110	17:55	18:02	0:07	TRANSFORMER FAULT
35	17-Sep-19	GULBARGA	66	MUNIRABAD220-MSDLINE	HANASI_66	0:00	9:05	9:05	LINE FAULT
36	17-Sep-19	GULBARGA	66	HV1	HBHALLI_66	10:15	13:05	2:50	LINE CLEAR AVAILED
37	17-Sep-19	GULBARGA	66	HV1	HBHALLI_66	13:10	13:35	0:25	LINE CLEAR AVAILED
38	17-Sep-19	GULBARGA	66	HV2	HBHALLI_66	12:13	12:30	0:17	LINE CLEAR AVAILED
39	17-Sep-19	GULBARGA	66	ITTAGI-CLEANMAX1_IPP, CLEANMAX2_IPP	ITTAGI_220	14:00	14:10	0:10	LINE FAULT
40	17-Sep-19	GULBARGA	66	ITTAGI-TAMBRAHALLI	TAMBRAHALLI_66 , MORAGERE_66, HAMPASAGAR_66	14:00	14:10	0:10	LINE FAULT
41	17-Sep-19	GULBARGA	66	ITTAGI-HAGARIBOMMANAHALLI	HAGARIBOMMANAHALLI_66	11:38	11:43	0:05	LINE FAULT
42	17-Sep-19	GULBARGA	66	ITTAGI-CLEANMAX1_IPP, CLEANMAX2_IPP	ITTAGI_220	11:38	11:55	0:17	LINE FAULT
43	17-Sep-19	GULBARGA	66	ITTAGI-TAMBRAHALLI	TAMBRAHALLI_66 , MORAGERE_66, HAMPASAGAR_66	11:38	11:50	0:12	LINE FAULT
44	17-Sep-19	GULBARGA	66	LV2	ITTAGI_220	17:13	17:16	0:03	LINE CLEAR AVAILED
45	17-Sep-19	GULBARGA	66	LV2	ITTAGI_220	23:38	23:52	0:14	TRANSFORMER FAULT
46	17-Sep-19	GULBARGA	66	ITTAGI-SUZLON1	ITTAGI_220	23:55	23:59	0:04	LINE FAULT
47	17-Sep-19	HASSAN	66	HV2	RAMNATHPURA_66	16:59	17:14	0:15	TRANSFORMER FAULT
48	17-Sep-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:28	11:57	1:29	NFBC ISSUED
49	17-Sep-19	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	15:38	15:39	0:01	LINE FAULT
50	17-Sep-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	10:29	11:55	1:26	LINE CLEAR AVAILED
51	17-Sep-19	HASSAN	110	HV2	KEMAR_220	10:47	12:37	1:50	LINE CLEAR AVAILED
52	17-Sep-19	HASSAN	110	HV2	BHADRAVATHI_110	10:37	11:06	0:29	LINE CLEAR AVAILED
53	17-Sep-19	HASSAN	110	HV1	GURUPURA_110	10:31	17:01	6:30	LINE CLEAR AVAILED
54	17-Sep-19	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	10:32	17:01	6:29	LINE CLEAR AVAILED
55	17-Sep-19	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	10:37	11:21	0:44	LINE CLEAR AVAILED
56	17-Sep-19	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	10:34	13:51	3:17	LINE CLEAR AVAILED
57	17-Sep-19	HASSAN	66	HV1	CHIKMAGALUR_66	13:36	14:02	0:26	LINE CLEAR AVAILED
58	17-Sep-19	HASSAN	66	HV1	CHIKMAGALUR_66	15:14	16:08	0:54	LINE CLEAR AVAILED
59	17-Sep-19	HASSAN	66	HV1	CHIKMAGALUR_66	18:30	18:38	0:08	HAND TRIPPED
60	17-Sep-19	HASSAN	66	HV2	CHIKMAGALUR_66	13:36	13:57	0:21	LINE CLEAR AVAILED
61	17-Sep-19	HASSAN	66	HV2	CHIKMAGALUR_66	15:14	16:06	0:52	LINE CLEAR AVAILED
62	17-Sep-19	HASSAN	66	HV2	CHIKMAGALUR_66	18:31	18:38	0:07	HAND TRIPPED
63	17-Sep-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	7:38	7:47	0:09	LINE FAULT
64	17-Sep-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	7:52	7:58	0:06	LINE FAULT
65	17-Sep-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	18:39	18:51	0:12	LINE FAULT
66	17-Sep-19	HASSAN	66	HNUPURA-RAMNATHPURA	HNUPURA_66	7:51	8:50	0:59	LINE FAULT
67	17-Sep-19	HASSAN	66	HV1	SAKLESHPURA_66	10:31	17:51	7:20	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
68	17-Sep-19	MYSORE	66	HV1	ARAKERE_66	15:06	15:22	0:15	HAND TRIPPED
69	17-Sep-19	MYSORE	66	BILIKERE-KR NAGARA	BILIKERE_66	10:15	17:00	6:45	NFBC ISSUED
70	17-Sep-19	MYSORE	66	BILIKERE-GV GUDI	GVGUDI_66	10:15	17:00	6:45	NFBC ISSUED
71	17-Sep-19	MYSORE	66	HV2	DKMAIDANA_66	11:40	13:12	1:32	LINE CLEAR AVAILED
72	17-Sep-19	MYSORE	66	HV2	DEVANOORMYS_66	11:32	14:15	2:42	LINE CLEAR AVAILED
73	17-Sep-19	MYSORE	66	HV1	ELAVALA_66	14:01	14:03	0:02	TRANSFORMER FAULT
74	17-Sep-19	MYSORE	66	HV1	ELAVALA_66	15:52	15:57	0:05	TRANSFORMER FAULT
75	17-Sep-19	MYSORE	66	HV2	GUNDULPET_66	12:12	12:24	0:12	LINE CLEAR AVAILED
76	17-Sep-19	MYSORE	66	HV1	HAMPAPURA_66	9:25	15:30	6:05	LINE CLEAR AVAILED
77	17-Sep-19	MYSORE	66	HV2	HAMPAPURA_66	9:26	15:34	6:07	LINE CLEAR AVAILED
78	17-Sep-19	MYSORE	66	HV1	KIADBMANDYA_66	8:40	9:13	0:33	LINE CLEAR AVAILED
79	17-Sep-19	MYSORE	66	HV2	KMDODDI_66	9:58	10:56	0:57	LINE CLEAR AVAILED
80	17-Sep-19	MYSORE	66	HV1	KRNAGARA_66	14:46	14:56	0:10	TRANSFORMER FAULT
81	17-Sep-19	MYSORE	66	KUSHALANAGARA 220-BYLUKUPPE	BYLUKUPPE_66	15:00	17:06	2:06	LINE CLEAR AVAILED
82	17-Sep-19	MYSORE	66	KUSHALANAGARA 220-PERİYAPATNA-1	PERİYAPATNA_66	15:00	17:06	2:06	LINE CLEAR AVAILED
83	17-Sep-19	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66, YELANDUR_66	14:55	15:01	0:05	LINE FAULT
84	17-Sep-19	MYSORE	66	HV2	MYSORESOUTH_66	12:03	12:51	0:47	LINE CLEAR AVAILED
85	17-Sep-19	MYSORE	66	HV1	NANJANGUDU_66	11:00	12:13	1:13	LINE CLEAR AVAILED
86	17-Sep-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	11:28	12:53	1:24	LINE CLEAR AVAILED
87	17-Sep-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	16:29	23:59	7:29	LINE CLEAR AVAILED
88	17-Sep-19	TUMKUR	220	TR-2(HV SIDE)	ANCHEPALYA_220	10:25	13:12	2:47	LINE CLEAR AVAILED
89	17-Sep-19	TUMKUR	220	TR-2(HV SIDE)	KBCROSS_220	15:38	15:44	0:06	TRANSFORMER FAULT
90	17-Sep-19	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	MRSMG_220	15:38	15:59	0:20	LINE FAULT
91	17-Sep-19	TUMKUR	220	TR-1	NEELAGUNDA_220	12:57	13:52	0:55	LINE CLEAR AVAILED
92	17-Sep-19	TUMKUR	220	NEELAGUNDA- ITTAGI	NEELAGUNDA_220	13:52	19:51	5:58	LINE CLEAR AVAILED
93	17-Sep-19	TUMKUR	110	TR-1	BANDIHALLI_110	15:13	15:55	0:41	LINE CLEAR AVAILED
94	17-Sep-19	TUMKUR	110	TR-1	KADABA_110	12:12	14:04	1:52	LINE CLEAR AVAILED
95	17-Sep-19	TUMKUR	110	TR-2	KADABA_110	12:12	14:04	1:52	LINE CLEAR AVAILED
96	17-Sep-19	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	15:38	15:44	0:06	TRANSFORMER FAULT
97	17-Sep-19	TUMKUR	66	TR-2(LV SIDE)	ANCHEPALYA_220	10:25	13:17	2:52	LINE CLEAR AVAILED
98	17-Sep-19	TUMKUR	66	ANCHEPALYA 66kV-ANCHEPALYA 1	ANCHEPALYA_66	15:48	16:05	0:16	LINE FAULT
99	17-Sep-19	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	12:49	12:53	0:03	MAIN SUPPLY FAILURE
100	17-Sep-19	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	8:53	9:27	0:34	MAIN SUPPLY FAILURE
101	17-Sep-19	TUMKUR	66	TR-2	DYAVARANAHALLI_66	12:37	12:57	0:19	TRANSFORMER FAULT
102	17-Sep-19	TUMKUR	66	HANAGAL- AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	19:02	19:15	0:12	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
103	17-Sep-19	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:33	15:20	2:46	LINE CLEAR AVAILED
104	17-Sep-19	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	12:33	15:20	2:46	LINE CLEAR AVAILED
105	17-Sep-19	TUMKUR	66	MADHUGIRI-SIRA-2	KALLAMBELLA_66, BUKKAPATNA_66	12:32	12:43	0:10	LINE FAULT
106	17-Sep-19	TUMKUR	66	TR-1	MADHUGIRI_220	16:50	18:09	1:18	TRANSFORMER FAULT
107	17-Sep-19	TUMKUR	66	NEELAGUNDA 220kV-HARAPPANAHALLI	HARAPPANAHALLI_66	13:11	13:36	0:24	HAND TRIPPED
108	17-Sep-19	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	13:11	13:35	0:23	HAND TRIPPED
109	17-Sep-19	TUMKUR	66	TR-2	NEELAGUNDA_220	13:35	13:50	0:15	HAND TRIPPED
110	17-Sep-19	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,HARAPPANAHALLI_66,HALUVAGALU_66,TELAGI_66	13:11	13:50	0:38	HAND TRIPPED
111	17-Sep-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	11:28	11:33	0:04	LINE FAULT
112	17-Sep-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	13:11	13:36	0:24	HAND TRIPPED
113	17-Sep-19	TUMKUR	66	TR-2	TELAGI_66	14:50	15:27	0:37	LINE CLEAR AVAILED
114	17-Sep-19	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	5:49	6:22	0:33	LINE FAULT
115	17-Sep-19	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	6:03	6:10	0:06	HAND TRIPPED
116	17-Sep-19	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	5:49	6:23	0:33	TRANSFORMER FAULT
117	17-Sep-19	TUMKUR	66	THALLAK 220kV- NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLANAHOLE_66	6:03	6:12	0:08	HAND TRIPPED
118	17-Sep-19	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEL DIAMOND SOLAR_IPP_66	6:04	6:23	0:19	HAND TRIPPED
119	18-Sep-19	BAGALKOT	110	ANKOLA-ARGA(L1)	ARGA_110	9:24	17:09	7:45	LINE CLEAR AVAILED
120	18-Sep-19	BAGALKOT	110	110/11KV,HV 2	ARGA_111	10:08	11:50	1:42	LINE CLEAR AVAILED
121	18-Sep-19	BAGALKOT	110	110/11KV,HV 1	ATHRGA_110	18:38	18:48	0:10	LOAD CURTAILMENT
122	18-Sep-19	BAGALKOT	110	BAGALKOT-GULEDGUDD_110	GULEDGUDD_110	21:50	23:59	2:09	LINE FAULT
123	18-Sep-19	BAGALKOT	110	110/11KV,HV2	VIJAYAPUR_110	11:24	18:40	7:16	LINE CLEAR AVAILED
124	18-Sep-19	BAGALKOT	220	220/110KV,HV 1 &LV 1	CHIKKODI_220	16:03	16:23	0:20	LINE CLEAR AVAILED
125	18-Sep-19	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	10:29	12:10	1:41	LINE CLEAR AVAILED
126	18-Sep-19	BAGALKOT	110	110/11KV,HV 2	DHAVALESHWAR_110	11:13	11:58	0:45	LINE CLEAR AVAILED
127	18-Sep-19	BAGALKOT	110	110/11KV,HV 4	GAJENDRAGAD_110	18:37	18:48	0:11	LOAD CURTAILMENT
128	18-Sep-19	BAGALKOT	110	110/33KV,HV 3	GHATAPRABHA_110 & GOKAK MILL,RIDDI SIDDDI,KALLOLLOI_33KV	10:52	11:42	0:50	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
129	18-Sep-19	BAGALKOT	110	110/11KV,HV1	HANAGAL_110	18:31	18:46	0:15	LOAD CURTAILMENT
130	18-Sep-19	BAGALKOT	110	110/11KV,HV 3	HIDIKAL_110	18:38	18:39	0:01	LOAD CURTAILMENT
131	18-Sep-19	BAGALKOT	110	110/33KV,HV4	HUKKERI_110 & DADDI LIS 33_KV	10:32	17:45	7:13	LINE CLEAR AVAILED
132	18-Sep-19	BAGALKOT	110	HUKKERI-KOTAWAGI	KOTAWAGI_110	10:15	17:40	7:25	LINE CLEAR AVAILED
133	18-Sep-19	BAGALKOT	110	110/33KV, HV3	TODALBAGI_110, BIDARI_33, HIREPADASALI_33	12:36	12:42	0:06	HAND TRIPPED
134	18-Sep-19	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	18:31	18:38	0:07	LOAD CURTAILMENT
135	18-Sep-19	BAGALKOT	110	110/11KV, HV1	TARIHAL_110	16:16	17:10	0:54	LINE CLEAR AVAILED
136	18-Sep-19	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	23:12	23:49	0:37	TRANSFORMER FAULT
137	18-Sep-19	BAGALKOT	110	110/11KV, HV1	MUNDARGI_110	18:06	18:21	0:15	TRANSFORMER FAULT
138	18-Sep-19	BAGALKOT	220	220/110KV, HV2&LV2	MAHALINGAPUR_220	11:33	16:15	4:42	LINE CLEAR AVAILED
139	18-Sep-19	BAGALKOT	110	110/11KV, HV1	LAXMESHVAR_110	18:37	18:44	0:07	LOAD CURTAILMENT
140	18-Sep-19	BAGALKOT	110	110/11KV, HV1	LAKMANHALLI_110	10:11	18:57	8:46	LINE CLEAR AVAILED
141	18-Sep-19	BAGALKOT	220	DHONI1-GADAG	GADAG_220	10:16	14:31	4:15	LINE CLEAR AVAILED
142	18-Sep-19	BAGALKOT	220	DHONI2-GADAG	GADAG_220	10:17	14:31	4:14	LINE CLEAR AVAILED
143	18-Sep-19	BAGALKOT	220	HARTI1-GADAG	GADAG_220	13:15	14:29	1:14	LINE CLEAR AVAILED
144	18-Sep-19	BAGALKOT	110	JAMKHANDI-MAHALINGAPUR (NAVALGI)	NAVALGI_110	11:25	11:35	0:10	HAND TRIPPED
145	18-Sep-19	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	10:15	13:35	3:20	LINE CLEAR AVAILED
146	18-Sep-19	BAGALKOT	110	HIRA SUGAR1&2-SANKESHWAR	SANKESHWAR_110	10:05	16:50	6:45	LINE CLEAR AVAILED
147	18-Sep-19	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, KARADI_33, AMINGAD_33	11:01	16:07	5:06	LINE CLEAR AVAILED
148	18-Sep-19	BAGALKOT	220	DHONI-ARESS STEEL	DHONI_400	8:34	14:21	5:47	LINE CLEAR AVAILED
149	18-Sep-19	BAGALKOT	220	DHONI-LINGAPUR	DHONI_400	8:49	14:27	5:38	LINE CLEAR AVAILED
150	18-Sep-19	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1 & 2	BAGEPALLI, PATHPALYA, THIMAMPALLI, SOMANATHAPURA	10:15	18:40	8:25	LINE CLEAR AVAILED
151	18-Sep-19	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1 & 2	VATADAHOSAHALLI, VIDURASHWATHA, GUNDLU KOTTUR	10:30	17:20	6:50	LINE CLEAR AVAILED
152	18-Sep-19	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	10:30	17:20	6:50	LINE CLEAR AVAILED
153	18-Sep-19	BENGALURU	66	GOWRIBIDANUR 220 - DB 1	MANCHENAHALLI, GUNDAMGERE	10:30	17:20	6:50	LINE CLEAR AVAILED
154	18-Sep-19	BENGALURU	66	GOWRIBIDANUR 220 - DB 2	THONDEBHAVI	10:30	17:20	6:50	LINE CLEAR AVAILED
155	18-Sep-19	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	10:30	17:20	6:50	LINE CLEAR AVAILED
156	18-Sep-19	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSUR RAMAPURA	10:30	17:20	6:50	LINE CLEAR AVAILED
157	18-Sep-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SOMENAHALLI, SADALI, JULUPALYA	18:43	19:06	0:22	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
158	18-Sep-19	BENGALURU	66	CHINTMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA, Y HUNSENAHALLI	18:43	19:06	0:22	LOAD CURTAILMENT
159	18-Sep-19	BENGALURU	66	HV1	JANGAMAKOTE	11:17	13:18	2:01	LINE CLEAR AVAILED
160	18-Sep-19	BENGALURU	66	HV2	JANGAMAKOTE	11:17	13:18	2:01	LINE CLEAR AVAILED
161	18-Sep-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	18:41	19:05	0:24	LOAD CURTAILMENT
162	18-Sep-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	18:43	19:07	0:24	LOAD CURTAILMENT
163	18-Sep-19	BENGALURU	66	HV2	KYALANUR	12:59	13:07	0:07	TRANSFORMER FAULT
164	18-Sep-19	BENGALURU	66	HV3	NELAMANGALA 66	4:56	6:07	1:10	TRANSFORMER FAULT
165	18-Sep-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	16:56	17:02	0:05	LINE FAULT
166	18-Sep-19	GULBARGA	220	BTPS-LINGAPUR	BTPS_400	2:07	5:33	3:26	LINE FAULT
167	18-Sep-19	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHAPUR_220	10:25	23:59	13:34	LINE CLEAR AVAILED
168	18-Sep-19	GULBARGA	220	HUMNABAD_HALBARGA1	HALBARGA_220	6:44	6:59	0:15	LINE FAULT
169	18-Sep-19	GULBARGA	220	HV2	RAICHURSA_220	4:40	10:03	5:23	TRANSFORMER FAULT
170	18-Sep-19	GULBARGA	220	HV2	RAICHURSA_220	10:03	11:14	1:11	LINE CLEAR AVAILED
171	18-Sep-19	GULBARGA	220	LINGAPUR_GADAG1	LINGAPUR_220	8:59	14:58	5:59	NFBC ISSUED
172	18-Sep-19	GULBARGA	110	HV2	SRERAMANAGAR_110	14:05	14:30	0:25	TRANSFORMER FAULT
173	18-Sep-19	GULBARGA	110	HV2	SRERAMANAGAR_110	14:50	14:55	0:05	TRANSFORMER FAULT
174	18-Sep-19	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADA GERA_110,SANNATHI_IPP,COREGREEN SUGAR_IPP,NALWAR_110	5:14	5:22	0:08	LINE FAULT
175	18-Sep-19	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADA GERA_110,SANNATHI_IPP,COREGREEN SUGAR_IPP,NALWAR_110	5:57	6:05	0:08	LINE FAULT
176	18-Sep-19	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110	6:00	6:08	0:08	LINE FAULT
177	18-Sep-19	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,B HALKISUGAR_IPP	6:18	6:26	0:08	LINE FAULT
178	18-Sep-19	GULBARGA	110	HALBARGA-KOLHAR2	KOLHAR_110,JANAWADA_110, NSSKSUGAR_IPP	8:50	11:50	3:00	LINE CLEAR AVAILED
179	18-Sep-19	GULBARGA	110	HALBARGA-KOLHAR2	KOLHAR_110,JANAWADA_110, NSSKSUGAR_IPP	15:30	19:00	3:30	LINE CLEAR AVAILED
180	18-Sep-19	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAWAT_110,VALKAMDINNI_110	0:50	1:05	0:15	LINE FAULT
181	18-Sep-19	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAWAT_110,VALKAMDINNI_110	2:28	3:17	0:49	LINE FAULT
182	18-Sep-19	GULBARGA	110	SEDAM-VICATSAGAR	VICATSAGAR_IPP	3:46	4:07	0:21	LINE FAULT
183	18-Sep-19	GULBARGA	110	SEDAM-MALKHED RAILWAY TRACTION	MALKHED RAILWAY TRACTION_110	7:29	7:49	0:20	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
184	18-Sep-19	GULBARGA	110	SHAKTINAGAR-RAICHURBIO	SHAKTINAGAR_110	0:48	0:53	0:05	LINE FAULT
185	18-Sep-19	GULBARGA	110	SINDHANOOR_TURVIHAL	TURVIHAL_110	0:10	0:20	0:10	LINE FAULT
186	18-Sep-19	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:05	20:17	0:12	LINE FAULT
187	18-Sep-19	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARTAGI_110,GANGAVATHI_110,SRER AMANAGAR_110,VENKATAGIRI_110	7:27	19:48	12:21	LINE FAULT
188	18-Sep-19	GULBARGA	110	SINDHANOOR-SINDHANOOR1	MASKI_110,MUDDAPUR_110	20:50	21:00	0:10	LINE FAULT
189	18-Sep-19	GULBARGA	110	SIDHANOOR-PGLR_WIND_IPP	SIDHANOOR_220	22:03	22:23	0:20	LINE FAULT
190	18-Sep-19	GULBARGA	110	SINDHANOOR_TURVIHAL	TURVIHAL_110	23:02	23:12	0:10	LINE FAULT
191	18-Sep-19	GULBARGA	110	LINGASUGUR-MUDGAL	MUDAGAL_110	3:16	5:29	2:13	LINE FAULT
192	18-Sep-19	GULBARGA	110	HV1	SRERAMANAGAR_110	20:20	20:40	0:20	TRANSFORMER FAULT
193	18-Sep-19	GULBARGA	110	HV2	SRERAMANAGAR_110	14:05	14:30	0:25	TRANSFORMER FAULT
194	18-Sep-19	GULBARGA	110	HV2	SRERAMANAGAR_110	14:45	14:50	0:05	TRANSFORMER FAULT
195	18-Sep-19	GULBARGA	110	SRERAMNAGAR-SINDHANOOR	SRERAMANAGAR_110	9:15	19:45	10:30	NFBC ISSUED
196	18-Sep-19	GULBARGA	110	HV1	SRERAMANAGAR_110	20:50	20:55	0:05	LINE CLEAR AVAILED
197	18-Sep-19	GULBARGA	110	SRERAMNAGAR-SINDHANOOR	SRERAMANAGAR_110	22:00	22:10	0:10	LINE FAULT
198	18-Sep-19	GULBARGA	110	HV3	YELBURGA_110	18:37	18:58	0:21	LOAD CURTAILMENT
199	18-Sep-19	GULBARGA	110	HV4	YELBURGA_110	18:37	18:58	0:21	LOAD CURTAILMENT
200	18-Sep-19	GULBARGA	110	HV1	SIRWAR_110	18:30	18:40	0:10	TRANSFORMER FAULT
201	18-Sep-19	GULBARGA	110	HV1	SHORAPUR_110	18:45	19:08	0:23	TRANSFORMER FAULT
202	18-Sep-19	GULBARGA	110	HV2	CHICKSUGUR_110	6:39	6:56	0:17	TRANSFORMER FAULT
203	18-Sep-19	GULBARGA	110	HV1	CHICKSUGUR_110	7:07	11:36	4:29	LINE CLEAR AVAILED
204	18-Sep-19	GULBARGA	110	HV1	CHINCHOLI_110	18:29	18:38	0:09	LOAD CURTAILMENT
205	18-Sep-19	GULBARGA	110	BHALKI-LADHA	LADHA_110	16:31	16:36	0:05	LINE FAULT
206	18-Sep-19	GULBARGA	110	HV2	GULBARGAUNIVERSITY_110	12:25	12:45	0:20	LINE CLEAR AVAILED
207	18-Sep-19	GULBARGA	110	HV1	AFZALPUR_110	13:25	13:47	0:22	LINE CLEAR AVAILED
208	18-Sep-19	GULBARGA	110	HV2	AFZALPUR_110	14:35	15:00	0:25	LINE CLEAR AVAILED
209	18-Sep-19	GULBARGA	66	HV1	CJHALLI_66	18:29	18:40	0:11	LOAD CURTAILMENT
210	18-Sep-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	5:40	5:50	0:10	TRANSFORMER FAULT
211	18-Sep-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	14:10	15:10	1:00	LINE CLEAR AVAILED
212	18-Sep-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	13:00	13:05	0:05	TRANSFORMER FAULT
213	18-Sep-19	GULBARGA	66	HV1	SOVENAHALLI_66	19:30	19:35	0:05	LOAD CURTAILMENT
214	18-Sep-19	GULBARGA	66	HV1	TAMBRAHALLI_66	12:10	12:25	0:15	LINE CLEAR AVAILED
215	18-Sep-19	GULBARGA	66	HV3	HBHALLI_66	14:10	15:10	1:00	LINE CLEAR AVAILED
216	18-Sep-19	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINAHADAGALLI_66	6:05	6:15	0:10	LINE FAULT
217	18-Sep-19	GULBARGA	66	ITTAGI-SUZLON1	ITTAGI_220	0:00	0:05	0:05	LINE FAULT
218	18-Sep-19	HASSAN	220	HV1	PUTTUR_220	10:00	13:08	3:08	LINE CLEAR AVAILED
219	18-Sep-19	HASSAN	110	LV1	PUTTUR_220	10:00	13:08	3:08	LINE CLEAR AVAILED
220	18-Sep-19	HASSAN	110	HV2	AJJAMPURA_110	10:35	15:29	4:54	LINE CLEAR AVAILED
221	18-Sep-19	HASSAN	110	HV1	AJJAMPURA_110	10:35	14:10	3:35	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
222	18-Sep-19	HASSAN	110	HV2	BANAVARA_110	9:30	14:50	5:20	LINE CLEAR AVAILED
223	18-Sep-19	HASSAN	110	HV1	BANAVARA_110	9:30	17:30	8:00	LINE CLEAR AVAILED
224	18-Sep-19	HASSAN	110	HV1	BIRUR_110	18:37	18:50	0:13	MAIN SUPPLY FAILURE
225	18-Sep-19	HASSAN	110	HV1	DMKURKE_110	18:30	19:03	0:33	MAIN SUPPLY FAILURE
226	18-Sep-19	HASSAN	110	HV2	GANDSI_110	18:31	18:40	0:09	MAIN SUPPLY FAILURE
227	18-Sep-19	HASSAN	110	HV2	GERUMARA_110	18:30	18:41	0:11	MAIN SUPPLY FAILURE
228	18-Sep-19	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_110	10:39	12:04	1:25	MAIN SUPPLY FAILURE
229	18-Sep-19	HASSAN	110	HV1	JAVAGAL_110	18:36	19:03	0:27	MAIN SUPPLY FAILURE
230	18-Sep-19	HASSAN	110	KADUR-AJAMPURA	KADUR_220	10:38	12:08	1:30	LINE CLEAR AVAILED
231	18-Sep-19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	11:00	13:10	2:10	LINE CLEAR AVAILED
232	18-Sep-19	HASSAN	110	HV2	MANIPAL_110	10:39	10:54	0:15	LINE CLEAR AVAILED
233	18-Sep-19	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	17:24	17:28	0:04	LINE CLEAR AVAILED
234	18-Sep-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	12:55	13:41	0:46	LINE CLEAR AVAILED
235	18-Sep-19	HASSAN	110	HV2	SORABA_110	12:02	17:46	5:44	LINE CLEAR AVAILED
236	18-Sep-19	HASSAN	66	HV2	BASAVAGHATTA_66	18:37	18:39	0:02	MAIN SUPPLY FAILURE
237	18-Sep-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	18:30	18:42	0:12	MAIN SUPPLY FAILURE
238	18-Sep-19	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	9:54	13:30	3:36	NFBC ISSUED
239	18-Sep-19	HASSAN	66	HV1	HANGARANAHALLY_66	11:26	13:58	2:32	LINE CLEAR AVAILED
240	18-Sep-19	HASSAN	66	HV1	HANGARANAHALLY_66	18:30	18:51	0:21	MAIN SUPPLY FAILURE
241	18-Sep-19	HASSAN	66	HASSN220-MALLALI	HASSAN_220	12:06	13:59	1:53	LINE CLEAR AVAILED
242	18-Sep-19	HASSAN	66	HASSN220-R R NAGAR	HASSAN_220	12:06	13:59	1:53	LINE CLEAR AVAILED
243	18-Sep-19	HASSAN	66	KIADB HA-RAMESWARNAGAR	KIADB_66	10:54	14:53	3:59	LINE CLEAR AVAILED
244	18-Sep-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	11:53	12:26	0:33	LINE CLEAR AVAILED
245	18-Sep-19	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	10:08	14:53	4:45	LINE CLEAR AVAILED
246	18-Sep-19	HASSAN	66	HV2	RAMESHWARNAGAR_66	10:23	14:54	4:31	LINE CLEAR AVAILED
247	18-Sep-19	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	10:09	15:06	4:57	LINE CLEAR AVAILED
248	18-Sep-19	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHIGRAMMA_66	10:10	15:39	5:29	LINE CLEAR AVAILED
249	18-Sep-19	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	10:10	15:39	5:29	LINE CLEAR AVAILED
250	18-Sep-19	HASSAN	66	HV2	SINGAPURA_66	18:31	18:45	0:14	MAIN SUPPLY FAILURE
251	18-Sep-19	HASSAN	66	HV2	UDAYAPURA_66	11:01	12:34	1:33	LINE CLEAR AVAILED
252	18-Sep-19	MYSORE	66	HV2	ADDIHALLI_66	18:29	18:35	0:05	LOAD CURTAILMENT
253	18-Sep-19	MYSORE	66	HV1	BILIKERE_66	18:29	19:30	1:00	LOAD CURTAILMENT
254	18-Sep-19	MYSORE	66	HV2	BOOKANAKERE_66	18:29	18:37	0:08	LOAD CURTAILMENT
255	18-Sep-19	MYSORE	66	HV2	CHINAKURALI_66	18:29	19:00	0:30	LOAD CURTAILMENT
256	18-Sep-19	MYSORE	66	CHUNCHUNKATTE-K R NAGARA	KRNAGARA_66	15:17	17:16	1:58	LINE CLEAR AVAILED
257	18-Sep-19	MYSORE	66	HV1	DODDINADUVADI_66	10:10	18:35	8:25	LINE CLEAR AVAILED
258	18-Sep-19	MYSORE	66	HV2	DODDINADUVADI_66	10:10	18:35	8:25	LINE CLEAR AVAILED
259	18-Sep-19	MYSORE	66	HV2	ELAVALA_66	18:29	18:40	0:10	LOAD CURTAILMENT
260	18-Sep-19	MYSORE	66	HV2	GVGUDI_66	18:30	18:51	0:21	LOAD CURTAILMENT
261	18-Sep-19	MYSORE	66	HV1	HANAGODU_66	18:36	18:52	0:15	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
262	18-Sep-19	MYSORE	66	HV1	HANGLA_66	13:25	15:25	2:00	LINE CLEAR AVAILED
263	18-Sep-19	MYSORE	66	HV2	HANGLA_66	15:45	17:25	1:40	LINE CLEAR AVAILED
264	18-Sep-19	MYSORE	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	10:07	15:30	5:22	LINE CLEAR AVAILED
265	18-Sep-19	MYSORE	66	HANNUR-MADUVANAHALLY 2	HANNUR_66	10:31	15:30	4:58	NFBC ISSUED
266	18-Sep-19	MYSORE	66	HANNUR-MADUVANAHALLY 1	HANNUR_66	10:45	15:30	4:45	NFBC ISSUED
267	18-Sep-19	MYSORE	66	HANNUR-KOTHANUR	KOTTANUR_66	10:32	15:30	4:57	NFBC ISSUED
268	18-Sep-19	MYSORE	66	HV2	HDKOTE_66	18:30	18:40	0:09	LOAD CURTAILMENT
269	18-Sep-19	MYSORE	66	HOOTAGALLI-HUNSUR	BADANAGUPPE_66, HOSURGATE_66	10:47	15:29	4:41	LINE CLEAR AVAILED
270	18-Sep-19	MYSORE	66	HV2	HULLAHALLI_66	9:07	13:55	4:47	LINE CLEAR AVAILED
271	18-Sep-19	MYSORE	66	HV2	JAIPUR_66	18:30	18:39	0:09	LOAD CURTAILMENT
272	18-Sep-19	MYSORE	66	HV1	K_HONNALGERE_66	11:41	11:51	0:09	HAND TRIPPED
273	18-Sep-19	MYSORE	66	HV2	K_HONNALGERE_66	11:41	11:51	0:09	HAND TRIPPED
274	18-Sep-19	MYSORE	66	HV2	KIRUGAVALU_66	18:37	19:02	0:25	LOAD CURTAILMENT
275	18-Sep-19	MYSORE	66	KR NAGARA-MYSORE 1	KRNAGARA_66 MIRLE_66	10:40	18:25	7:45	LINE CLEAR AVAILED
276	18-Sep-19	MYSORE	66	HV1	KALAMANDIRA_66	11:19	13:49	2:29	LINE CLEAR AVAILED
277	18-Sep-19	MYSORE	66	HV2	KALAMANDIRA_66	13:50	15:44	1:53	LINE CLEAR AVAILED
278	18-Sep-19	MYSORE	66	HV2	KMDODDI_66	18:30	18:47	0:17	LOAD CURTAILMENT
279	18-Sep-19	MYSORE	66	HV2	KOLLEGALA_66	18:30	18:48	0:18	LOAD CURTAILMENT
280	18-Sep-19	MYSORE	66	HV1	KUSHALNAGARA_220	18:29	18:42	0:12	LOAD CURTAILMENT
281	18-Sep-19	MYSORE	66	HV1	MADHUVANAHALLI_220	13:09	16:50	3:41	LINE CLEAR AVAILED
282	18-Sep-19	MYSORE	66	HV2	MADHUVANAHALLI_220	16:53	17:27	0:34	LINE CLEAR AVAILED
283	18-Sep-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	10:30	0:00	13:29	LINE CLEAR AVAILED
284	18-Sep-19	MYSORE	66	HV1	NAGAMANGALA_66	18:30	18:50	0:19	LOAD CURTAILMENT
285	18-Sep-19	MYSORE	66	HV1	SATHEGALA_66	18:31	18:33	0:01	LOAD CURTAILMENT
286	18-Sep-19	MYSORE	66	HV2	SANTHESARAGUR_66	18:31	18:43	0:11	LOAD CURTAILMENT
287	18-Sep-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	18:31	0:00	5:28	LOAD CURTAILMENT
288	18-Sep-19	TUMKUR	220	TR-1(HV SIDE)	MADHUGIRI_220	13:18	13:42	0:23	LINE CLEAR AVAILED
289	18-Sep-19	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	11:33	12:38	1:05	LINE CLEAR AVAILED
290	18-Sep-19	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	16:14	16:15	0:00	LINE FAULT
291	18-Sep-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	8:22	8:36	0:13	LINE FAULT
292	18-Sep-19	TUMKUR	66	HONNALLI 220KV- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	5:41	5:53	0:11	LINE FAULT
293	18-Sep-19	TUMKUR	66	TR-2	HOSAKERE_66	12:42	15:11	2:29	TRANSFORMER FAULT
294	18-Sep-19	TUMKUR	66	TR-1	KATTIGE_66	12:22	12:29	0:06	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
295	18-Sep-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	3:28	3:40	0:11	LINE FAULT
296	18-Sep-19	TUMKUR	66	TR-1(LV SIDE)	MADHUGIRI_220	13:18	13:42	0:24	LINE CLEAR AVAILED
297	18-Sep-19	TUMKUR	66	MADHUGIRI 220kV- SIRA 1	GULIGENAHALLI_66,SIRA_66	18:52	19:13	0:21	LOAD CURTAILMENT
298	18-Sep-19	TUMKUR	66	MADHUGIRI 220kV- SIRA 2	GULIGENAHALLI_66,SIRA_66	18:52	19:13	0:21	LINE FAULT
299	18-Sep-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	12:42	14:11	1:28	LINE CLEAR AVAILED
300	18-Sep-19	TUMKUR	66	NITRAHALLI 66 -CLEAN SOLAR	CLEAN SOLAR_IPP_66	8:28	12:08	3:40	LINE CLEAR AVAILED
301	18-Sep-19	TUMKUR	66	TR-2	NITRAHALLI_66	8:28	12:11	3:42	LINE CLEAR AVAILED
302	18-Sep-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	13:58	15:29	1:31	LINE CLEAR AVAILED
303	18-Sep-19	TUMKUR	66	TR-2	TAVAREKERE(C)_66	13:54	14:31	0:37	LINE CLEAR AVAILED
304	19-Sep-19	BAGALKOT	110	ATHANI-TAUSHI	TAUSHI_110	23:40	23:53	0:13	LINE FAULT
305	19-Sep-19	BAGALKOT	110	BAGALKOT-GULEDGUDD	GULEDGUDD_110	0:00	2:09	2:09	LINE CLEAR AVAILED
306	19-Sep-19	BAGALKOT	110	110/11KV,HV 2	BHUTANAL_110	7:59	8:12	0:13	HAND TRIPPED
307	19-Sep-19	BAGALKOT	110	DAMBAL-EILS(L1)ENERCON	DAMBAL_110	4:46	9:18	4:32	LINE FAULT
308	19-Sep-19	BAGALKOT	110	110/11KV,HV1	GOPANAKOPPA_110	10:10	16:32	6:22	LINE CLEAR AVAILED
309	19-Sep-19	BAGALKOT	110	110/11KV,HV1	GULEDGUDD_110	2:34	3:01	0:27	MAIN SUPPLY FAILURE
310	19-Sep-19	BAGALKOT	110	110/33KV,HV2	GULEDGUDD_110 &KAMATAGI,SIRUR_33	2:34	3:01	0:27	MAIN SUPPLY FAILURE
311	19-Sep-19	BAGALKOT	110	110/11KV,HV2	HATTARGI_110	14:10	14:55	0:45	HAND TRIPPED
312	19-Sep-19	BAGALKOT	66	DAVANAGERE-HOSPET	HARIHAR-HOSPET_66	10:23	14:03	3:40	LINE CLEAR AVAILED
313	19-Sep-19	BAGALKOT	66	66/11KV,HV2	HARIHAR-HOSPET_66	10:49	14:03	3:14	LINE CLEAR AVAILED
314	19-Sep-19	BAGALKOT	110	HUBLI-KADANKOPPA	KADANKOPPA_110	7:12	16:25	9:13	LINE FAULT
315	19-Sep-19	BAGALKOT	110	110/11KV, HV1	SAIDAPUR_110	16:54	17:05	0:11	TRANSFORMER FAULT
316	19-Sep-19	BAGALKOT	110	110/33KV, HV1	KUMATA_110, ANKOLA_33, HONNAVAR_33	12:59	13:26	0:27	LINE CLEAR AVAILED
317	19-Sep-19	BAGALKOT	110	110/33KV, HV1	JAMKHANDI_110	10:11	18:16	8:05	LINE CLEAR AVAILED
318	19-Sep-19	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, KARADI_33, AMINGAD_33	5:00	5:25	0:25	TRANSFORMER FAULT
319	19-Sep-19	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, KARADI_33, AMINGAD_33	5:59	6:06	0:07	TRANSFORMER FAULT
320	19-Sep-19	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, KARADI_33, AMINGAD_33	6:23	6:36	0:13	TRANSFORMER FAULT
321	19-Sep-19	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, KARADI_33, AMINGAD_33	10:18	10:21	0:03	TRANSFORMER FAULT
322	19-Sep-19	BAGALKOT	110	110/11KV, HV4	HUKKERI_110	10:38	10:57	0:19	LINE CLEAR AVAILED
323	19-Sep-19	BAGALKOT	110	110/33KV, HV3	HIDIKAL DAM_110, LIS_33, WATER SUPPLY1&2_33	10:13	17:49	7:36	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
324	19-Sep-19	BENGALURU	66	VIDHURASHWATHA - GOWRIBIDANUR 220	VIDHURASHWATHA, GUNDLU KOTTUR, BAGEPALLI	15:25	15:30	0:05	LINE CLEAR AVAILED
325	19-Sep-19	BENGALURU	66	VIDHURASHWATHA - GOWRIBIDANUR 220	VIDHURASHWATHA, GUNDLU KOTTUR, BAGEPALLI	17:00	17:10	0:10	LINE CLEAR AVAILED
326	19-Sep-19	BENGALURU	66	HV1	AMARJYOTHI	13:18	13:22	0:03	LOAD CHANGEOVER
327	19-Sep-19	BENGALURU	66	HV1	AMARJYOTHI	14:29	15:24	0:55	MAIN SUPPLY FAILURE
328	19-Sep-19	BENGALURU	66	HV2	AMARJYOTHI	14:29	15:24	0:55	MAIN SUPPLY FAILURE
329	19-Sep-19	BENGALURU	400	HV1	HOODY 400	14:29	15:02	0:32	TRANSFORMER FAULT
330	19-Sep-19	BENGALURU	400	HV3	HOODY 400	14:29	15:06	0:36	TRANSFORMER FAULT
331	19-Sep-19	BENGALURU	220	HV1	HOODY 220	14:30	15:29	0:59	MAIN SUPPLY FAILURE
332	19-Sep-19	BENGALURU	220	HV2	HOODY 220	14:29	15:24	0:54	MAIN SUPPLY FAILURE
333	19-Sep-19	BENGALURU	220	HV1	HOODY 220	14:30	15:30	1:00	LINE CLEAR AVAILED
334	19-Sep-19	BENGALURU	220	HV2	HOODY 220	14:29	15:25	0:56	TRANSFORMER FAULT
335	19-Sep-19	BENGALURU	220	HV3	HOODY 220	14:29	16:10	1:41	TRANSFORMER FAULT
336	19-Sep-19	BENGALURU	220	HV4	HOODY 220	14:30	15:09	0:39	LINE CLEAR AVAILED
337	19-Sep-19	BENGALURU	220	HV1	NIMHANS 220	14:29	15:01	0:32	MAIN SUPPLY FAILURE
338	19-Sep-19	BENGALURU	220	HV2	NIMHANS 220	14:29	15:02	0:33	MAIN SUPPLY FAILURE
339	19-Sep-19	BENGALURU	220	HV1	EDC 220	14:29	16:22	1:53	MAIN SUPPLY FAILURE
340	19-Sep-19	BENGALURU	66	HV1	EDC 220	14:29	16:25	1:56	MAIN SUPPLY FAILURE
341	19-Sep-19	BENGALURU	66	HV2	EDC 220	14:29	16:23	1:54	MAIN SUPPLY FAILURE
342	19-Sep-19	BENGALURU	66	HV1	HAL 220	12:41	13:38	0:56	MAIN SUPPLY FAILURE
343	19-Sep-19	BENGALURU	66	HV1	HAL 220	13:38	14:02	0:23	MAIN SUPPLY FAILURE
344	19-Sep-19	BENGALURU	220	HV1	HAL 220	14:29	15:18	0:49	MAIN SUPPLY FAILURE
345	19-Sep-19	BENGALURU	220	HV2	HAL 220	14:29	15:17	0:48	MAIN SUPPLY FAILURE
346	19-Sep-19	BENGALURU	66	HV2	HAL 220	14:29	15:22	0:53	MAIN SUPPLY FAILURE
347	19-Sep-19	BENGALURU	66	HV2	SOUTH CITY	14:54	15:23	0:29	LINE CLEAR AVAILED
348	19-Sep-19	BENGALURU	220	HOODY 400 - HAL 1	HAL 220, EDC 220	14:29	15:16	0:46	LINE FAULT
349	19-Sep-19	BENGALURU	220	HOODY 400 - HAL 2	HAL 220, EDC 220	14:30	18:47	4:17	LINE FAULT
350	19-Sep-19	BENGALURU	66	HOODY 220 - BMRCL (EHT)	BMRCL (EHT)	14:30	15:26	0:56	MAIN SUPPLY FAILURE
351	19-Sep-19	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	14:30	15:45	1:15	MAIN SUPPLY FAILURE
352	19-Sep-19	BENGALURU	66	HOODY 220 - GRAPHITE INDIA (EHT)	GRAPHITE INDIA (EHT)	14:30	15:43	1:13	MAIN SUPPLY FAILURE
353	19-Sep-19	BENGALURU	66	HOODY 220 - HAL 1	BAGMANE WORLD TECH PARK, NGEF, NGEF (EHT)	14:30	15:44	1:14	MAIN SUPPLY FAILURE
354	19-Sep-19	BENGALURU	66	HOODY 220 - HP (EHT)	HP (EHT)	14:30	16:02	1:32	MAIN SUPPLY FAILURE
355	19-Sep-19	BENGALURU	66	HOODY 220 - ITI	ITI	14:30	15:56	1:26	MAIN SUPPLY FAILURE
356	19-Sep-19	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	14:30	15:46	1:16	MAIN SUPPLY FAILURE
357	19-Sep-19	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	14:30	15:03	0:33	MAIN SUPPLY FAILURE
358	19-Sep-19	BENGALURU	66	HOODY 220 - SHANTHINIKETHAN	SHANTHINIKETHAN	14:30	15:58	1:28	MAIN SUPPLY FAILURE
359	19-Sep-19	BENGALURU	220	HOODY 220 - RAILWAYS 1 (EHT)	RAILWAYS 1 (EHT)	14:30	15:05	0:35	MAIN SUPPLY FAILURE
360	19-Sep-19	BENGALURU	220	HOODY 220 - RAILWAYS 2 (EHT)	RAILWAYS 2 (EHT)	14:30	15:16	0:46	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
361	19-Sep-19	BENGALURU	66	NIMHANS 220 - BMTC	BMTC, NATIONAL COLLEGE	14:29	15:25	0:56	MAIN SUPPLY FAILURE
362	19-Sep-19	BENGALURU	220	NIMHANS 220 - HSR LAYOUT 220	NIMHANS 220	14:29	14:53	0:24	MAIN SUPPLY FAILURE
363	19-Sep-19	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	14:30	15:03	0:33	MAIN SUPPLY FAILURE
364	19-Sep-19	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	14:29	15:02	0:33	MAIN SUPPLY FAILURE
365	19-Sep-19	BENGALURU	66	POTTERY ROAD - HBR LAYOUT	POTTERY ROAD	15:39	15:45	0:05	LOAD CHANGEOVER
366	19-Sep-19	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	18:17	18:35	0:17	LINE FAULT
367	19-Sep-19	BENGALURU	66	HSR LAYOUT 220 - KORAMANGALA	K & C VALLEY, NAL (EHT)	8:48	10:43	1:55	LINE FAULT
368	19-Sep-19	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	14:36	16:36	2:00	MAIN SUPPLY FAILURE
369	19-Sep-19	BENGALURU	66	EDC 220 - B STATION	B STATION	14:37	15:43	1:06	MAIN SUPPLY FAILURE
370	19-Sep-19	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	14:30	15:22	0:52	MAIN SUPPLY FAILURE
371	19-Sep-19	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI	14:30	15:29	0:58	MAIN SUPPLY FAILURE
372	19-Sep-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	14:31	15:26	0:55	MAIN SUPPLY FAILURE
373	19-Sep-19	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	14:31	15:25	0:54	MAIN SUPPLY FAILURE
374	19-Sep-19	BENGALURU	66	HEBBAL 220 - IISC	IISC	13:01	15:28	2:27	LINE CLEAR AVAILED
375	19-Sep-19	BENGALURU	220	HV1	GOWRIBIDANUR 220	4:10	4:20	0:10	TRANSFORMER FAULT
376	19-Sep-19	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	17:02	17:22	0:20	MAIN SUPPLY FAILURE
377	19-Sep-19	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSUR RAMAPURA	17:02	17:22	0:20	MAIN SUPPLY FAILURE
378	19-Sep-19	BENGALURU	66	GOWRIBIDANUR 220 - AFTL (EHT)	AFTL (EHT)	17:02	17:22	0:20	MAIN SUPPLY FAILURE
379	19-Sep-19	BENGALURU	66	HV2	KUNDANA	12:01	12:57	0:55	LINE CLEAR AVAILED
380	19-Sep-19	BENGALURU	66	HV1	KUNDANA	12:01	12:57	0:56	TRANSFORMER FAULT
381	19-Sep-19	BENGALURU	66	HV2	KYALANUR	16:29	16:29	0:00	LINE CLEAR AVAILED
382	19-Sep-19	BENGALURU	66	HV2	KYALANUR	16:31	16:33	0:02	LINE CLEAR AVAILED
383	19-Sep-19	BENGALURU	66	HV1	NANGALI	4:55	5:40	0:45	TRANSFORMER FAULT
384	19-Sep-19	BENGALURU	66	HV1	VTG DODDI	11:12	11:36	0:23	MAIN SUPPLY FAILURE
385	19-Sep-19	BENGALURU	66	HV1	VTG DODDI	12:54	13:55	1:00	LINE CLEAR AVAILED
386	19-Sep-19	GULBARGA	400	YTPS-BPS2	YTPS_400	16:54	23:59	7:05	LINE CLEAR AVAILED
387	19-Sep-19	GULBARGA	400	YTPS-BPS1	YTPS_400	0:00	16:42	16:42	LINE FAULT
388	19-Sep-19	GULBARGA	220	LINGASUGUR-RTPS1,3	LINGASUGUR_220	3:16	3:30	0:14	LINE FAULT
389	19-Sep-19	GULBARGA	220	LINGSUGUR-SHAHAPUR	SHAHAPUR_220	4:45	4:45	0:00	LINE FAULT
390	19-Sep-19	GULBARGA	220	LINGSUGUR-SHAHAPUR	SHAHAPUR_220	5:38	5:38	0:00	LINE FAULT
391	19-Sep-19	GULBARGA	220	HV1	KUSTAGI_220	12:10	20:08	7:58	TRANSFORMER FAULT
392	19-Sep-19	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHAPUR_220	0:00	11:42	11:42	LINE CLEAR AVAILED
393	19-Sep-19	GULBARGA	220	LINGSUGUR-KUSTAGI	KUSTAGI_220	12:41	19:07	6:26	LINE FAULT
394	19-Sep-19	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	2:13	7:57	5:44	LINE CLEAR AVAILED
395	19-Sep-19	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	4:20	4:40	0:20	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
396	19-Sep-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGAR_IPP	4:05	4:25	0:20	LINE FAULT
397	19-Sep-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGAR_IPP	4:52	5:02	0:10	LINE FAULT
398	19-Sep-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGAR_IPP	5:23	5:38	0:15	LINE FAULT
399	19-Sep-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGAR_IPP	5:58	6:18	0:20	LINE FAULT
400	19-Sep-19	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	5:15	5:22	0:07	LINE FAULT
401	19-Sep-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	11:29	11:40	0:11	LINE FAULT
402	19-Sep-19	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARTAGI_110,GANGAVATHI_110,SRER AMANAGAR_110,VENKATAGIRI_110	12:48	13:00	0:12	LINE FAULT
403	19-Sep-19	GULBARGA	110	HV2	SHORAPUR_110	7:20	7:25	0:05	TRANSFORMER FAULT
404	19-Sep-19	GULBARGA	110	KUSTAGI-HANUMSAGAR	HANUMSAGAR_110, HIREGONNAGAR_110,HANUMNAL_11 0	10:25	11:05	0:40	LINE FAULT
405	19-Sep-19	GULBARGA	110	MUNIRABAD-SINDHANOOR1	KARTAGI_110,GANGAVATHI_110,SRER AMANAGAR_110,VENKATAGIRI_110	10:57	12:56	1:59	LINE CLEAR AVAILED
406	19-Sep-19	GULBARGA	110	HV4	SHORAPUR_110	3:14	3:28	0:14	TRANSFORMER FAULT
407	19-Sep-19	GULBARGA	110	HV3	SHORAPUR_110	7:09	7:25	0:16	TRANSFORMER FAULT
408	19-Sep-19	GULBARGA	110	HV3	SHORAPUR_110	12:22	12:30	0:08	TRANSFORMER FAULT
409	19-Sep-19	GULBARGA	110	HV3	SHORAPUR_110	14:57	15:06	0:09	TRANSFORMER FAULT
410	19-Sep-19	GULBARGA	110	HV4	SHORAPUR_110	15:36	15:41	0:05	TRANSFORMER FAULT
411	19-Sep-19	GULBARGA	110	BETAGERA-KESHAVCEMENT_SLR	BETAGERA_110	4:46	5:19	0:33	LINE FAULT
412	19-Sep-19	GULBARGA	110	RAICHUR-SINSHANOOR1	VALKAMDINNI_110,ALKOD_110,SIRWA R_110	9:50	10:00	0:10	LINE FAULT
413	19-Sep-19	GULBARGA	110	RAICHUR-SINSHANOOR1	VALKAMDINNI_110,ALKOD_110,SIRWA R_110	23:25	23:34	0:09	LINE FAULT
414	19-Sep-19	GULBARGA	110	LINGASUGUR-GURUGUNTA	GURUGUNTA_110	1:30	1:40	0:10	LINE FAULT
415	19-Sep-19	GULBARGA	110	LINGASUGUR-GURUGUNTA	GURUGUNTA_110	5:35	5:43	0:08	LINE FAULT
416	19-Sep-19	GULBARGA	110	GURUMITKAL-SEDAM	GURUMITKAL_110	9:25	9:40	0:15	LINE FAULT
417	19-Sep-19	GULBARGA	110	GURUMITKAL-KONKAL	KONKAL_110	9:25	9:40	0:15	LINE FAULT
418	19-Sep-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGAR_IPP	19:17	19:30	0:13	LINE FAULT
419	19-Sep-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGAR_IPP	5:58	6:18	0:20	LINE FAULT
420	19-Sep-19	GULBARGA	66	HV2	CHORNOOR_66	4:26	4:30	0:04	TRANSFORMER FAULT
421	19-Sep-19	GULBARGA	66	HV1	CHORNOOR_66	10:09	11:31	1:22	LINE CLEAR AVAILED
422	19-Sep-19	GULBARGA	66	HV1	CHORNOOR_66	14:59	15:23	0:24	TRANSFORMER FAULT
423	19-Sep-19	GULBARGA	66	HV1	HANASI_66	12:28	12:44	0:16	LINE CLEAR AVAILED
424	19-Sep-19	GULBARGA	66	HV2	HAGRIBOMMANAHALLI_66	11:25	12:15	0:50	LINE CLEAR AVAILED
425	19-Sep-19	GULBARGA	66	MUNIRABAD220-MSDLNE	MUNIRABAD_220	5:55	6:00	0:05	LINE FAULT
426	19-Sep-19	GULBARGA	66	HV2	HAGRIBOMMANAHALLI_66	15:53	15:55	0:02	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
427	19-Sep-19	GULBARGA	66	ITTAGI-TAMBRAHALI	TAMBRAHALI_66, MORAGERA_66, HAMPASAGAR_66	10:10	14:45	4:35	LINE CLEAR AVAILED
428	19-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	9:00	9:00	LINE FAULT
429	19-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	9:04	23:59	14:55	LINE FAULT
430	19-Sep-19	HASSAN	220	HV3	KAVOOR_220	9:21	16:21	7:00	LINE CLEAR AVAILED
431	19-Sep-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	12:02	13:52	1:50	LINE CLEAR AVAILED
432	19-Sep-19	HASSAN	220	MRSSHM-VARAH1	MRS MG_220	9:07	18:36	9:29	LINE CLEAR AVAILED
433	19-Sep-19	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	12:08	13:53	1:45	NFBC ISSUED
434	19-Sep-19	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	9:05	18:34	9:29	NFBC ISSUED
435	19-Sep-19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	10:39	13:01	2:22	LINE CLEAR AVAILED
436	19-Sep-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:40	13:01	2:21	LINE CLEAR AVAILED
437	19-Sep-19	HASSAN	110	HV1	BANAVARA_110	11:30	12:00	0:30	LINE CLEAR AVAILED
438	19-Sep-19	HASSAN	110	HV1	BANAVARA_110	13:15	13:30	0:15	LINE CLEAR AVAILED
439	19-Sep-19	HASSAN	110	HV1	JAVAGAL_110	11:09	16:55	5:46	LINE CLEAR AVAILED
440	19-Sep-19	HASSAN	110	HV2	MANIPAL_110	10:28	12:51	2:23	LINE CLEAR AVAILED
441	19-Sep-19	HASSAN	66	HV1	BELUR_66	12:10	12:20	0:10	TRANSFORMER FAULT
442	19-Sep-19	HASSAN	66	HV1	CHIKMAGALUR_66	15:28	16:40	1:12	LINE CLEAR AVAILED
443	19-Sep-19	MYSORE	66	HV2	DKMAIDANA_66	10:49	20:02	9:13	LINE CLEAR AVAILED
444	19-Sep-19	MYSORE	66	HV1	DUNDANAHALLI_66	11:05	11:25	0:20	HAND TRIPPED
445	19-Sep-19	MYSORE	66	HV2	DUNDANAHALLI_66	11:05	11:25	0:20	HAND TRIPPED
446	19-Sep-19	MYSORE	66	HV2	FTS_66	15:18	16:24	1:06	LINE CLEAR AVAILED
447	19-Sep-19	MYSORE	66	G UKKADA-SR PATNA	SRIRANGAPATNA_66	14:06	17:20	3:13	NFBC ISSUED
448	19-Sep-19	MYSORE	66	HV1	HOOTAGALLY_220	12:17	15:20	3:02	LINE CLEAR AVAILED
449	19-Sep-19	MYSORE	66	HV1	HOOTAGALLY_220	16:51	17:50	0:58	LINE CLEAR AVAILED
450	19-Sep-19	MYSORE	66	HV2	HOOTAGALLY_220	9:39	13:05	3:25	LINE CLEAR AVAILED
451	19-Sep-19	MYSORE	66	HV2	HOOTAGALLY_220	14:59	15:21	0:21	HAND TRIPPED
452	19-Sep-19	MYSORE	66	HV2	HULLAHALLI_66	12:43	14:20	1:36	LINE CLEAR AVAILED
453	19-Sep-19	MYSORE	66	HV2	HULLAHALLI_66	14:25	15:02	0:37	LINE CLEAR AVAILED
454	19-Sep-19	MYSORE	66	JYOTHINAGARA-VAJAMANGALA	JYOTHINAGARA_66	10:20	17:20	7:00	NFBC ISSUED
455	19-Sep-19	MYSORE	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	18:19	18:24	0:05	LINE FAULT
456	19-Sep-19	MYSORE	66	KIADB MANDYA-TUMBEKERE	TUMBEKERE_66	14:28	15:28	1:00	LINE CLEAR AVAILED
457	19-Sep-19	MYSORE	66	KUSHALANAGARA 220-PERİYAPATNA-1	PERİYAPATNA_66, BYLUKUPPE_66	10:06	10:32	0:26	LINE FAULT
458	19-Sep-19	MYSORE	220	KUSHALANAGARA 220-BASTIPURA 1	KUSHALNAGARA_220	10:30	15:23	4:53	LINE CLEAR AVAILED
459	19-Sep-19	MYSORE	220	KUSHALANAGARA 220-BASTIPURA 2	KUSHALNAGARA_220	10:30	15:23	4:53	LINE CLEAR AVAILED
460	19-Sep-19	MYSORE	66	HV1	KUSHALANAGARA_66	10:03	17:52	7:49	LINE CLEAR AVAILED
461	19-Sep-19	MYSORE	66	HV3	KUSHALANAGARA_66	10:05	17:52	7:46	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
462	19-Sep-19	MYSORE	66	HV4	KUSHALANAGARA_66	10:02	17:45	7:43	LINE CLEAR AVAILED
463	19-Sep-19	MYSORE	66	KUSHALANAGARA 220-MERCERA-1	MADIKERI_66	10:02	0:00	13:57	LINE CLEAR AVAILED
464	19-Sep-19	MYSORE	66	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	10:02	17:32	7:29	LINE CLEAR AVAILED
465	19-Sep-19	MYSORE	66	KUSHALANAGARA 220-RAMANTHAPURA1	ALUR SIDDAPUR_66, KANAGAL_66	10:04	17:13	7:09	LINE CLEAR AVAILED
466	19-Sep-19	MYSORE	66	HV1	MALAVALLI_66	12:02	12:10	0:08	TRANSFORMER FAULT
467	19-Sep-19	MYSORE	66	METAGALLI-G UKKADA	SRIRANGAPATNA_66	14:45	0:00	9:14	NFBC ISSUED
468	19-Sep-19	MYSORE	66	HV1	SRIRANGAPATNA_66	10:12	0:00	13:47	LINE CLEAR AVAILED
469	19-Sep-19	MYSORE	66	HV2	SRIRANGAPATNA_66	10:12	17:21	7:08	LINE CLEAR AVAILED
470	19-Sep-19	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA_220 1	MADHUGIRI 220kV	9:05	15:29	6:23	LINE CLEAR AVAILED
471	19-Sep-19	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA_220 2	MADHUGIRI 220kV	9:05	15:29	6:23	LINE CLEAR AVAILED
472	19-Sep-19	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	10:38	13:18	2:39	LINE CLEAR AVAILED
473	19-Sep-19	TUMKUR	110	TR-1	SAMPIGE_110	12:33	13:57	1:24	LINE CLEAR AVAILED
474	19-Sep-19	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	11:04	11:34	0:29	LINE CLEAR AVAILED
475	19-Sep-19	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	11:04	11:34	0:29	LINE CLEAR AVAILED
476	19-Sep-19	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	11:04	11:34	0:29	LINE CLEAR AVAILED
477	19-Sep-19	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	11:04	11:34	0:29	LINE CLEAR AVAILED
478	19-Sep-19	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI(HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	11:04	11:34	0:29	LINE CLEAR AVAILED
479	19-Sep-19	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	ANCHEPALYA_220	11:04	11:34	0:29	LINE CLEAR AVAILED
480	19-Sep-19	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	11:04	11:34	0:29	LINE CLEAR AVAILED
481	19-Sep-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66	8:24	8:26	0:01	LINE FAULT
482	19-Sep-19	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	6:02	6:39	0:37	LINE FAULT
483	19-Sep-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:05	10:11	0:05	HAND TRIPPED
484	19-Sep-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	13:46	13:49	0:02	HAND TRIPPED
485	19-Sep-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	9:59	10:04	0:05	HAND TRIPPED
486	19-Sep-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	13:39	13:46	0:06	HAND TRIPPED
487	19-Sep-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:17	10:20	0:02	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
488	19-Sep-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:23	10:44	0:21	HAND TRIPPED
489	19-Sep-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	13:54	14:00	0:05	HAND TRIPPED
490	19-Sep-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:11	10:17	0:05	HAND TRIPPED
491	19-Sep-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	13:49	13:52	0:03	HAND TRIPPED
492	19-Sep-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	6:00	6:08	0:08	LINE FAULT
493	19-Sep-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	17:55	18:06	0:10	LINE FAULT
494	19-Sep-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	13:53	13:59	0:06	LINE FAULT
495	19-Sep-19	TUMKUR	66	HOSAKERE- MIDIGESHI	MEDIGESHI_66, PAVAGADA_66, VENKATAPURA_66	11:37	11:41	0:04	LINE FAULT
496	19-Sep-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	13:43	13:48	0:05	LINE FAULT
497	19-Sep-19	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	11:19	11:59	0:40	HAND TRIPPED
498	19-Sep-19	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	17:17	17:43	0:25	HAND TRIPPED
499	19-Sep-19	TUMKUR	66	LINGADAHALLI- P R PURA	LINGADAHALLI_TMK2_66	15:00	15:53	0:53	HAND TRIPPED
500	19-Sep-19	TUMKUR	66	TR-1	MAYAKONDA_66	13:13	20:33	7:19	LINE CLEAR AVAILED
501	19-Sep-19	TUMKUR	66	TR-2	NAGALMADIKE_66	13:41	14:47	1:05	MAIN SUPPLY FAILURE
502	19-Sep-19	TUMKUR	66	NAGALAMADIKE- MUNIRAJ SOLAR_IPP_66	MUNIRAJ SOLAR_IPP_66	13:01	13:23	0:21	MAIN SUPPLY FAILURE
503	19-Sep-19	TUMKUR	66	NAGALAMADIKE- RNS INFRA SOLAR_IPP_66	RNS INFRA SOLAR_IPP_66	13:01	15:02	2:01	MAIN SUPPLY FAILURE
504	19-Sep-19	TUMKUR	66	NAGALAMADIKE- SUNDARRAJ SOLAR_IPP_66	SUNDARRAJ SOLAR_IPP_66	11:49	13:55	2:05	MAIN SUPPLY FAILURE
505	19-Sep-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	9:16	9:26	0:09	LINE FAULT
506	19-Sep-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	8:23	8:27	0:03	HAND TRIPPED
507	19-Sep-19	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	9:40	11:08	1:28	LINE CLEAR AVAILED
508	19-Sep-19	TUMKUR	66	SAVALANGA 66KV-HNLI220_NYMT	SAVALANGA_66	9:57	12:15	2:18	LINE CLEAR AVAILED
509	19-Sep-19	TUMKUR	66	TR-1	SAVALANGA_66	9:56	12:15	2:19	LINE CLEAR AVAILED
510	19-Sep-19	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	10:02	15:47	5:45	LOAD CURTAILMENT
511	20-Sep-19	BAGALKOT	110	110/33KV,HV2	ANKOLA_110 &MASTKATTA,SEABIRD_33	17:32	17:57	0:25	HAND TRIPPED
512	20-Sep-19	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	9:51	16:21	6:30	LINE CLEAR AVAILED
513	20-Sep-19	BAGALKOT	220	BAGALKOT-GADAG 1	BAGALKOT_220	12:07	14:48	2:41	LINE CLEAR AVAILED
514	20-Sep-19	BAGALKOT	220	BAGALKOT-GADAG 2	BAGALKOT_220	15:33	16:26	0:53	HAND TRIPPED
515	20-Sep-19	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	17:46	17:52	0:06	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
516	20-Sep-19	BAGALKOT	220	NAGJHARI 2-BIDNAL	BIDNAL_220	3:58	12:44	8:46	LINE FAULT
517	20-Sep-19	BAGALKOT	110	110/11KV,HV 1	BILAGI_110	10:00	10:07	0:07	TRANSFORMER FAULT
518	20-Sep-19	BAGALKOT	110	110/11KV,HV 1	BILAGI_110	11:25	12:15	0:50	TRANSFORMER FAULT
519	20-Sep-19	BAGALKOT	110	GADAG-BETAGERI	BETAGERI_110	11:09	17:07	5:58	LINE CLEAR AVAILED
520	20-Sep-19	BAGALKOT	110	HIDIKAL-RAIBAG	RAIBAG_110	15:44	16:35	0:51	HAND TRIPPED
521	20-Sep-19	BAGALKOT	110	INDI-ZALKI	ZALKI_110, CHADCHAN_110	16:00	17:12	1:12	LINE FAULT
522	20-Sep-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	11:24	13:52	2:28	LINE CLEAR AVAILED
523	20-Sep-19	BAGALKOT	220	HUBLI-SIRS12	HUBLI_220	13:19	13:52	0:33	LINE FAULT
524	20-Sep-19	BAGALKOT	110	SHIVSAGAR SUGARS-SALAHALLI	SALAHALLI_110	8:17	9:54	1:37	LINE FAULT
525	20-Sep-19	BAGALKOT	220	220/110KV, HV1&LV1	NARENDRA_220	11:18	17:19	6:01	LINE CLEAR AVAILED
526	20-Sep-19	BAGALKOT	110	110/11KV, HV3	MUDALGI_33	10:37	16:52	6:15	TRANSFORMER FAULT
527	20-Sep-19	BAGALKOT	110	LOKAPUR-SALAHALLI	SALAHALLI_110	7:36	8:09	0:33	LINE FAULT
528	20-Sep-19	BAGALKOT	110	NAREGAL-RON	RON_110	16:57	17:06	0:09	HAND TRIPPED
529	20-Sep-19	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	18:42	19:00	0:18	MAIN SUPPLY FAILURE
530	20-Sep-19	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	19:32	19:34	0:02	LOAD CHANGEOVER
531	20-Sep-19	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	17:42	18:20	0:38	MAIN SUPPLY FAILURE
532	20-Sep-19	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	6:05	6:14	0:09	LOAD CHANGEOVER
533	20-Sep-19	BENGALURU	66	VR DODDI - SOMANAHALLI 220	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	7:29	7:55	0:25	LINE FAULT
534	20-Sep-19	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	17:44	17:57	0:13	MAIN SUPPLY FAILURE
535	20-Sep-19	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	18:51	18:53	0:02	LOAD CHANGEOVER
536	20-Sep-19	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	17:44	18:32	0:48	LINE FAULT
537	20-Sep-19	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	17:44	18:32	0:48	LINE FAULT
538	20-Sep-19	BENGALURU	66	SRS PEENYA 220 - WEL CAST	WEL CAST	17:44	18:01	0:17	MAIN SUPPLY FAILURE
539	20-Sep-19	BENGALURU	66	HV2	RMV	10:30	10:35	0:05	LINE CLEAR AVAILED
540	20-Sep-19	BENGALURU	66	HV1	RMV	11:32	11:35	0:03	LINE CLEAR AVAILED
541	20-Sep-19	BENGALURU	66	HV2	SOUTH CITY	15:58	16:07	0:09	LINE CLEAR AVAILED
542	20-Sep-19	BENGALURU	66	HV2	ELECTRONIC CITY P2 S2	1:53	10:42	8:48	TRANSFORMER FAULT
543	20-Sep-19	BENGALURU	66	HV2	ELECTRONIC CITY P2 S2	13:12	14:03	0:51	LINE CLEAR AVAILED
544	20-Sep-19	BENGALURU	66	HV1	AMARJYOTHI	17:26	17:55	0:28	LOAD CHANGEOVER
545	20-Sep-19	BENGALURU	66	HV1	AMARJYOTHI	18:09	18:15	0:05	LOAD CHANGEOVER
546	20-Sep-19	BENGALURU	220	HV1	SRS PEENYA 220	17:44	18:51	1:07	TRANSFORMER FAULT
547	20-Sep-19	BENGALURU	66	WELCAST STEEL - DG 3	WELCAST STEEL	18:54	19:01	0:07	LOAD CHANGEOVER
548	20-Sep-19	BENGALURU	400	NELAMANGALA 400 - TALAGUPPA		13:33	23:59	10:26	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
549	20-Sep-19	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	17:17	17:50	0:32	LINE FAULT
550	20-Sep-19	GULBARGA	400	JSWVL400-BTPS	JSWVL_400	3:50	10:38	6:48	LINE FAULT
551	20-Sep-19	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	3:05	6:25	3:20	LINE CLEAR AVAILED
552	20-Sep-19	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	2:13	7:57	5:44	LINE CLEAR AVAILED
553	20-Sep-19	GULBARGA	220	KAPNOOR-HUMNBAD1	KAPNOOR_220	3:04	6:24	3:20	LINE FAULT
554	20-Sep-19	GULBARGA	220	MALLAT-RTPS	MALLAT_220	22:38	23:59	1:21	LINE FAULT
555	20-Sep-19	GULBARGA	220	RTPS-LINGSUGUR3	RTPS_220	22:35	23:59	1:24	LINE FAULT
556	20-Sep-19	GULBARGA	110	LV1	KUSTAGI_220	0:00	0:18	0:18	LINE CLEAR AVAILED
557	20-Sep-19	GULBARGA	110	GURUMITKAL-GMSH WIND_IPP	GURUMITKAL_110	3:43	4:09	0:26	LINE FAULT
558	20-Sep-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	12:49	12:53	0:04	LINE FAULT
559	20-Sep-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	13:11	13:19	0:08	LINE FAULT
560	20-Sep-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	16:05	16:24	0:19	LINE FAULT
561	20-Sep-19	GULBARGA	110	KAPNOOR-HUMNBAD2	KAPNOOR_220	6:15	6:23	0:08	LINE FAULT
562	20-Sep-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGAR_IPP	23:38	23:50	0:12	LINE FAULT
563	20-Sep-19	GULBARGA	110	PDHALLI-CLEANSOLAR_IPP	PDHALLI_110	19:15	19:53	0:38	LINE FAULT
564	20-Sep-19	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPURA_110, MANVI_110	20:05	20:10	0:05	LINE FAULT
565	20-Sep-19	GULBARGA	66	HV2	HBHALLI_66	10:06	16:30	6:24	LINE CLEAR AVAILED
566	20-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	13:28	13:28	LINE FAULT
567	20-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:33	23:59	10:26	LINE FAULT
568	20-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	10:15	10:15	LINE CLEAR AVAILED
569	20-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:56	23:59	2:03	LINE CLEAR AVAILED
570	20-Sep-19	HASSAN	220	MRSSHM-HSN4001	MRSMDG_220	9:48	19:21	9:33	LINE CLEAR AVAILED
571	20-Sep-19	HASSAN	110	HV2	MANIPAL_110	9:10	9:24	0:14	LINE CLEAR AVAILED
572	20-Sep-19	HASSAN	66	HV1	HARIHARAPURA_66	9:25	12:48	3:23	LINE CLEAR AVAILED
573	20-Sep-19	HASSAN	66	HARIHAR-KADUVINKOTE	HARIHARAPURA_66	9:25	12:48	3:23	LINE CLEAR AVAILED
574	20-Sep-19	HASSAN	66	HV1	HOLALUR_66	12:54	14:27	1:33	TRANSFORMER FAULT
575	20-Sep-19	HASSAN	66	KIDB HA-RAMESWARNAGAR	KIADB_66	8:26	8:51	0:25	LINE FAULT
576	20-Sep-19	HASSAN	66	HV2	MATTNAVILE_66	12:24	14:23	1:59	LINE CLEAR AVAILED
577	20-Sep-19	HASSAN	66	HV2	RAMPURA_66	10:32	11:20	0:48	TRANSFORMER FAULT
578	20-Sep-19	HASSAN	66	HV2	RAMPURA_66	11:37	12:13	0:36	TRANSFORMER FAULT
579	20-Sep-19	MYSORE	66	HV1	BOMMALAPURA_66	16:40	16:50	0:10	TRANSFORMER FAULT
580	20-Sep-19	MYSORE	66	HV2	BOMMALAPURA_66	17:15	17:23	0:07	TRANSFORMER FAULT
581	20-Sep-19	MYSORE	66	CR NAGARA-GUNDLUPETE 2	TERAKANAMBE_66	18:38	18:44	0:06	LINE FAULT
582	20-Sep-19	MYSORE	66	HV1	ELAVALA_66	12:11	12:15	0:04	TRANSFORMER FAULT
583	20-Sep-19	MYSORE	66	HV1	KIADBMANDYA_66	17:00	17:28	0:28	LINE CLEAR AVAILED
584	20-Sep-19	MYSORE	66	HV2	KOLLEGALA_66	13:25	13:53	0:27	TRANSFORMER FAULT
585	20-Sep-19	MYSORE	66	HV1	KOPPA_66	10:04	14:57	4:52	LINE CLEAR AVAILED
586	20-Sep-19	MYSORE	66	HV2	KOPPA_66	10:16	17:48	7:32	LINE CLEAR AVAILED
587	20-Sep-19	MYSORE	66	HV1	KRPET_220	10:30	18:45	8:15	LINE CLEAR AVAILED
588	20-Sep-19	MYSORE	66	HV1	KRPET_220	18:45	19:00	0:15	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
589	20-Sep-19	MYSORE	66	HV2	KRPET_220	12:36	17:06	4:29	LINE CLEAR AVAILED
590	20-Sep-19	MYSORE	66	KUSHALANAGARA 220-BETTADAPURA	BETTADHAPURA_66, KITTUR_66, RAVANDUR_66	10:36	17:22	6:46	LINE CLEAR AVAILED
591	20-Sep-19	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	10:18	15:12	4:54	LINE CLEAR AVAILED
592	20-Sep-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	10:13	15:19	5:06	LINE CLEAR AVAILED
593	20-Sep-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	10:14	15:40	5:25	LINE CLEAR AVAILED
594	20-Sep-19	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	10:19	15:11	4:51	LINE CLEAR AVAILED
595	20-Sep-19	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	10:17	15:13	4:56	LINE CLEAR AVAILED
596	20-Sep-19	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	10:14	15:17	5:03	LINE CLEAR AVAILED
597	20-Sep-19	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	10:13	15:14	5:00	LINE CLEAR AVAILED
598	20-Sep-19	TUMKUR	66	BADDIHALLI- MELEKOTE	BADDIHALLI_66	10:39	10:53	0:14	MAIN SUPPLY FAILURE
599	20-Sep-19	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	12:02	12:09	0:07	HAND TRIPPED
600	20-Sep-19	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	14:58	17:09	2:11	LINE CLEAR AVAILED
601	20-Sep-19	TUMKUR	66	TR-2	BALENAHALLI_66	14:46	17:07	2:21	LINE CLEAR AVAILED
602	20-Sep-19	TUMKUR	66	BELLAVI-ANTHRASANAHALLI	BELLAVI_66	10:12	15:23	5:10	LINE CLEAR AVAILED
603	20-Sep-19	TUMKUR	66	TR-2	BELLAVI_66	10:12	15:23	5:10	LINE CLEAR AVAILED
604	20-Sep-19	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	11:35	11:43	0:07	LINE FAULT
605	20-Sep-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	11:10	11:23	0:13	LINE FAULT
606	20-Sep-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:41	11:45	0:03	LINE FAULT
607	20-Sep-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	9:54	10:08	0:14	LINE FAULT
608	20-Sep-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	11:14	11:28	0:13	LINE FAULT
609	20-Sep-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	13:22	15:03	1:41	LINE CLEAR AVAILED
610	20-Sep-19	TUMKUR	66	TR-1	MAYAKONDA_66	9:14	10:19	1:04	LINE CLEAR AVAILED
611	20-Sep-19	TUMKUR	66	MELKOTE-ANTHRASANAHALLI	MELKOTE_66	10:56	15:24	4:28	LINE CLEAR AVAILED
612	20-Sep-19	TUMKUR	66	TR-2	MELKOTE_66	3:30	4:03	0:32	HAND TRIPPED
613	20-Sep-19	TUMKUR	66	NAGALAMADIKE-MADHUGIRI	NAGALMADIKE_66	10:47	10:53	0:05	LINE FAULT
614	20-Sep-19	TUMKUR	66	NAGALAMADIKE- ATRIA_IPP_66	ATRIA_IPP_66	10:53	11:24	0:31	HAND TRIPPED
615	20-Sep-19	TUMKUR	66	THALLAK 220kv- CHALLAKERE-1	CHALLAKERE_66, SANIKERE_66	11:42	16:56	5:13	LINE CLEAR AVAILED
616	20-Sep-19	TUMKUR	66	THALLAK 220kv- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	11:49	15:26	3:37	LINE CLEAR AVAILED
617	20-Sep-19	TUMKUR	66	TR-2	TUMKUR_66	10:13	15:48	5:35	LINE CLEAR AVAILED
618	20-Sep-19	TUMKUR	66	TR-1	YEDIYUR_66	10:13	11:16	1:02	LINE CLEAR AVAILED
619	21-Sep-19	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	12:57	17:26	4:29	LINE CLEAR AVAILED
620	21-Sep-19	BAGALKOT	110	BIDNAL220-GADAG ROAD	GADAG ROAD_110	10:10	16:13	6:03	LINE CLEAR AVAILED
621	21-Sep-19	BAGALKOT	110	GADAG ROAD-GOPPANAKOPPA	GOPPANAKOPPA_110	9:42	16:53	7:11	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
622	21-Sep-19	BAGALKOT	110	110/33KV,HV3	GOPPANAKOPPA_110,KUSHAGAL_33	11:38	12:05	0:27	TRANSFORMER FAULT
623	21-Sep-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	11:17	13:18	2:01	LINE CLEAR AVAILED
624	21-Sep-19	BAGALKOT	220	HAVERI-NARENDRA2	HAVERI_220	13:35	14:52	1:17	LINE CLEAR AVAILED
625	21-Sep-19	BAGALKOT	110	110/33KV,HV2	HIREKERUR_110,CHIKKA KERUR_33,KODA_33	17:18	17:23	0:05	LINE CLEAR AVAILED
626	21-Sep-19	BAGALKOT	110	110/11KV,HV1	HIREKERUR_110	17:30	17:32	0:02	LINE CLEAR AVAILED
627	21-Sep-19	BAGALKOT	110	110/11KV,HV2	KALAGHATAGI_110	11:03	18:26	7:23	LINE CLEAR AVAILED
628	21-Sep-19	BAGALKOT	110	110/11KV,HV2	KHANAPUR_110	11:31	17:26	5:55	LINE CLEAR AVAILED
629	21-Sep-19	BAGALKOT	110	KUD DHARAWAD-LAKAMANAHALLI	LAKAMANAHALLI_110	1:56	10:46	8:50	LINE FAULT
630	21-Sep-19	BAGALKOT	110	110/11KV,HV3	MUDALGI_110	12:14	13:10	0:56	LINE CLEAR AVAILED
631	21-Sep-19	BAGALKOT	110	110/33KV,HV2	MATTIHAL_110,KARJOL LIS_33	3:46	3:48	0:02	TRANSFORMER FAULT
632	21-Sep-19	BAGALKOT	110	110/11KV,HV1	MATTIHAL_110	11:20	13:20	2:00	LINE CLEAR AVAILED
633	21-Sep-19	BAGALKOT	110	110/11KV,HV2	MUNDAGOD_110	7:47	10:42	2:55	LINE CLEAR AVAILED
634	21-Sep-19	BAGALKOT	110	110/11KV,HV1	MUNDAGOD_110	10:38	14:21	3:43	LINE CLEAR AVAILED
635	21-Sep-19	BAGALKOT	110	CHIKKODI220-NANADI	NANADI_110	10:51	13:25	2:34	LINE CLEAR AVAILED
636	21-Sep-19	BAGALKOT	110	110/11KV,HV2	NANADI_110	11:03	13:28	2:25	LINE CLEAR AVAILED
637	21-Sep-19	BAGALKOT	110	110/11KV,HV1	NANADI_110	11:03	11:25	0:22	LINE CLEAR AVAILED
638	21-Sep-19	BAGALKOT	110	DODDANAVAR SOLAR-NANADI	NANADI_110	10:51	13:41	2:50	LINE CLEAR AVAILED
639	21-Sep-19	BAGALKOT	110	SIRSI220-SIRSI1&2	SIRSI_110	10:41	15:01	4:20	NFBC ISSUED
640	21-Sep-19	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	10:30	15:07	4:37	LINE CLEAR AVAILED
641	21-Sep-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	10:30	17:34	7:04	LINE CLEAR AVAILED
642	21-Sep-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	18:02	18:12	0:10	LINE FAULT
643	21-Sep-19	BAGALKOT	110	SIRSI-KUMTA 1&2	KUMTA_110	9:44	15:06	5:22	LINE CLEAR AVAILED
644	21-Sep-19	BAGALKOT	110	SIRSI-KUMTA 1	KUMTA_110	15:08	23:59	8:51	LINE FAULT
645	21-Sep-19	BAGALKOT	110	110/11KV,HV1	SIRSI_110	10:30	17:54	7:24	LINE CLEAR AVAILED
646	21-Sep-19	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	10:19	15:23	5:04	LINE CLEAR AVAILED
647	21-Sep-19	BAGALKOT	110	NAVALGUND-KONNUR	KONNUR_110	10:16	15:56	5:40	LINE CLEAR AVAILED
648	21-Sep-19	BAGALKOT	110	NAVALGUND-DHARWAD BIO	NAVALGUND_110	10:18	16:29	6:11	LINE CLEAR AVAILED
649	21-Sep-19	BAGALKOT	110	NAVALGUND-DHARWAD BIO	NAVALGUND_110	17:24	18:54	1:30	LINE CLEAR AVAILED
650	21-Sep-19	BAGALKOT	110	NAVALGUND-DHARWAD BIO	NAVALGUND_110	20:29	23:59	3:30	LINE CLEAR AVAILED
651	21-Sep-19	BAGALKOT	220	220/110KV,HV1,LV1	NARENDRA_220	11:30	15:07	3:37	LINE CLEAR AVAILED
652	21-Sep-19	BAGALKOT	220	220/110KV,HV2,LV2	NARENDRA_220	15:10	16:33	1:23	LINE CLEAR AVAILED
653	21-Sep-19	BAGALKOT	110	NARENDRA-KUD DHARWAD	KUD DHARWAD_110	1:23	1:50	0:27	LINE FAULT
654	21-Sep-19	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	10:07	18:03	7:56	LINE CLEAR AVAILED
655	21-Sep-19	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	12:53	18:17	5:24	LINE CLEAR AVAILED
656	21-Sep-19	BAGALKOT	110	NAREGAL-RON	RON_110	12:53	18:10	5:17	LINE CLEAR AVAILED
657	21-Sep-19	BAGALKOT	110	110/11KV,HV1	ZALKI_110	18:59	19:01	0:02	TRANSFORMER FAULT
658	21-Sep-19	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	1:46	2:36	0:49	MAIN SUPPLY FAILURE
659	21-Sep-19	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI	1:46	2:37	0:50	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
660	21-Sep-19	BENGALURU	220	HOODY 220 - RAILWAYS 2 (EHT)	RAILWAYS 2 (EHT)	12:30	12:38	0:07	LOAD CHANGEOVER
661	21-Sep-19	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	10:55	10:58	0:03	LOAD CHANGEOVER
662	21-Sep-19	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	9:00	9:24	0:24	LINE FAULT
663	21-Sep-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	14:17	14:22	0:05	LINE CLEAR AVAILED
664	21-Sep-19	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	13:04	13:15	0:11	LOAD CHANGEOVER
665	21-Sep-19	BENGALURU	66	HV3	AUSTIN PARK	14:00	14:18	0:18	LINE CLEAR AVAILED
666	21-Sep-19	BENGALURU	66	HV2	GOLF LINKS	11:55	11:57	0:01	LINE CLEAR AVAILED
667	21-Sep-19	BENGALURU	66	HV3	ELECTRONIC CIT	12:09	12:54	0:45	LINE CLEAR AVAILED
668	21-Sep-19	BENGALURU	66	HV1	ELECTRONIC CIT	13:02	13:36	0:34	LINE CLEAR AVAILED
669	21-Sep-19	BENGALURU	66	HV2	ELECTRONIC CIT	13:41	14:04	0:23	LINE CLEAR AVAILED
670	21-Sep-19	BENGALURU	220	HV2	HAL 220	1:46	2:26	0:39	TRANSFORMER FAULT
671	21-Sep-19	BENGALURU	66	HV2	HAL 220	1:46	2:26	0:39	MAIN SUPPLY FAILURE
672	21-Sep-19	BENGALURU	66	HV1	HAL 220	1:46	2:26	0:39	MAIN SUPPLY FAILURE
673	21-Sep-19	BENGALURU	220	HV2	HOODY 220	12:30	12:38	0:07	LOAD CHANGEOVER
674	21-Sep-19	BENGALURU	66	HV2	KADUGODI	13:00	13:31	0:31	LINE CLEAR AVAILED
675	21-Sep-19	BENGALURU	66	HV2	NRS 220	9:01	9:22	0:21	LOAD CHANGEOVER
676	21-Sep-19	BENGALURU	66	HV2	NRS 220	10:57	10:59	0:01	LOAD CHANGEOVER
677	21-Sep-19	BENGALURU	66	SRS PEENYA 220 - DG 2	ALUR, NELAMANGALA	17:28	17:53	0:25	LINE FAULT
678	21-Sep-19	BENGALURU	66	ALUR - DABUSPET 220	ALUR	19:55	19:58	0:03	LOAD CHANGEOVER
679	21-Sep-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	10:35	10:48	0:12	LINE CLEAR AVAILED
680	21-Sep-19	BENGALURU	66	HV1	KANASWADI	10:45	11:50	1:05	LINE CLEAR AVAILED
681	21-Sep-19	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	19:55	20:01	0:06	LOAD CHANGEOVER
682	21-Sep-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	17:49	17:52	0:03	LOAD CHANGEOVER
683	21-Sep-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	19:55	20:01	0:06	LOAD CHANGEOVER
684	21-Sep-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:00	14:01	2:00	LINE CLEAR AVAILED
685	21-Sep-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	15:54	15:57	0:03	LINE CLEAR AVAILED
686	21-Sep-19	BENGALURU	66	HV1	WELCAST	10:05	10:10	0:04	LINE CLEAR AVAILED
687	21-Sep-19	BENGALURU	66	HV2	WELCAST	11:30	13:05	1:35	LINE CLEAR AVAILED
688	21-Sep-19	BENGALURU	66	HV1	WELCAST	11:00	11:06	0:06	LINE CLEAR AVAILED
689	21-Sep-19	BENGALURU	66	HV2	MAASTHI	22:10	22:14	0:04	TRANSFORMER FAULT
690	21-Sep-19	GULBARGA	220	HV1	HALBARGA_220	10:51	11:10	0:19	TRANSFORMER FAULT
691	21-Sep-19	GULBARGA	220	HV2	HALBARGA_220	10:51	11:10	0:19	TRANSFORMER FAULT
692	21-Sep-19	GULBARGA	220	MALLAT-RTPS	MALLAT_220	0:00	14:05	14:05	LINE CLEAR AVAILED
693	21-Sep-19	GULBARGA	220	RTPS-LINGSUGUR3	RTPS_220	0:00	14:04	14:04	LINE FAULT
694	21-Sep-19	GULBARGA	220	RAICHUR-RTPS1	RAICHUR_220	9:36	18:01	8:25	NFBC ISSUED
695	21-Sep-19	GULBARGA	110	BHALKI-LADHA	LADHA_110	5:56	6:05	0:09	LINE FAULT
696	21-Sep-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	6:02	6:15	0:13	LINE FAULT
697	21-Sep-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	13:13	13:18	0:05	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
698	21-Sep-19	GULBARGA	110	ITTAGI-TAMBRAHALLI	TAMBRAHALLI_66	6:30	6:46	0:16	LINE FAULT
699	21-Sep-19	GULBARGA	110	ITTAGI-KUDILIGI1,2	KUDILIGI_66,KOGALI_66,HANASI_66	11:55	18:00	6:05	LINE CLEAR AVAILED
700	21-Sep-19	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	4:36	4:46	0:10	LINE FAULT
701	21-Sep-19	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	9:05	9:33	0:28	LINE FAULT
702	21-Sep-19	GULBARGA	110	RAICHUR-SINDHANOOR2	SINDHANOOR_110	9:54	11:35	1:41	LINE CLEAR AVAILED
703	21-Sep-19	GULBARGA	110	HV2	HANUMANAL_110	12:40	12:50	0:10	TRANSFORMER FAULT
704	21-Sep-19	GULBARGA	110	HV1	HANUMANAL_110	12:40	13:10	0:30	TRANSFORMER FAULT
705	21-Sep-19	GULBARGA	110	SINDHANOOR-RAICHUR1	VALKAMDINNI_110,ALKOD_110,SIRWAR_110	20:06	20:26	0:20	LINE FAULT
706	21-Sep-19	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	21:57	22:02	0:05	LINE FAULT
707	21-Sep-19	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	19:01	19:06	0:05	LINE FAULT
708	21-Sep-19	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	19:20	19:25	0:05	LINE FAULT
709	21-Sep-19	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	21:00	21:05	0:05	LINE FAULT
710	21-Sep-19	GULBARGA	66	HANSI-MUNIRABAD	HANSI_66	16:40	16:45	0:05	LINE FAULT
711	21-Sep-19	GULBARGA	66	BANAVEKAL-SOLAR_IPP	BANAVEKAL_66	11:50	18:23	6:33	LINE CLEAR AVAILED
712	21-Sep-19	GULBARGA	66	LV2	ITTAGI_220	6:30	6:42	0:12	TRANSFORMER FAULT
713	21-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	16:46	16:46	LINE FAULT
714	21-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:49	23:59	7:10	LINE FAULT
715	21-Sep-19	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	8:54	16:25	7:31	LINE CLEAR AVAILED
716	21-Sep-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	9:43	13:39	3:56	LINE CLEAR AVAILED
717	21-Sep-19	HASSAN	110	HV5	MRSMSG_220	9:56	14:24	4:28	LINE CLEAR AVAILED
718	21-Sep-19	HASSAN	110	MRSSHM-SS2	MRSMSG_220	10:45	16:35	5:50	LINE CLEAR AVAILED
719	21-Sep-19	HASSAN	110	MRSSHM-SHIMOGA	ANANDAPURA_110	10:45	16:35	5:50	NFBC ISSUED
720	21-Sep-19	HASSAN	110	CHANDRA-BELIGAVI	CHANDRAGUTTI_110	15:18	16:25	1:07	MAIN SUPPLY FAILURE
721	21-Sep-19	HASSAN	66	HV1	SHRAVANABELAGOLA_66	11:00	14:50	3:50	LINE CLEAR AVAILED
722	21-Sep-19	MYSORE	66	HV1	BOOKANAKERE_66	17:03	18:00	0:56	LINE CLEAR AVAILED
723	21-Sep-19	MYSORE	66	HV2	DKMAIDANA_66	12:03	15:41	3:38	LINE CLEAR AVAILED
724	21-Sep-19	MYSORE	66	HV1	JAKKANAHALLY_66	11:49	13:45	1:55	LINE CLEAR AVAILED
725	21-Sep-19	MYSORE	66	HV2	JAKKANAHALLY_66	10:13	12:10	1:56	LINE CLEAR AVAILED
726	21-Sep-19	MYSORE	66	KADAKOLA-NANJANGUD 1	NANJANGUDU_66	16:35	16:57	0:21	LINE FAULT
727	21-Sep-19	MYSORE	66	KADAKOLA-NANJANGUD 2	THANDYA_66	16:35	17:34	0:59	LINE FAULT
728	21-Sep-19	MYSORE	66	HV1	KIKKERI_66	10:15	16:04	5:49	LINE CLEAR AVAILED
729	21-Sep-19	MYSORE	66	HV2	KIKKERI_66	10:15	16:04	5:49	LINE CLEAR AVAILED
730	21-Sep-19	MYSORE	66	HV3	KIKKERI_66	10:15	18:55	8:40	LINE CLEAR AVAILED
731	21-Sep-19	MYSORE	66	HV1	MADDUR_66	9:47	17:41	7:54	LINE CLEAR AVAILED
732	21-Sep-19	MYSORE	66	HV2	MADDUR_66	9:47	17:05	7:18	LINE CLEAR AVAILED
733	21-Sep-19	MYSORE	66	MUGUR-KUNTHUR	MUGUR_66, JANNUR_66, TNARASIPURA_66,THAYURU_66	3:07	3:20	0:13	LINE FAULT
734	21-Sep-19	MYSORE	66	HV1	RAVANDUR_66	10:49	11:30	0:40	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
735	21-Sep-19	MYSORE	66	HV1	VIRAJPET_66	10:00	16:35	6:35	LINE CLEAR AVAILED
736	21-Sep-19	MYSORE	66	HV2	VIRAJPET_66	10:00	16:35	6:35	LINE CLEAR AVAILED
737	21-Sep-19	MYSORE	66	HV1	PONNAMPET_66	10:00	15:10	5:10	LINE CLEAR AVAILED
738	21-Sep-19	MYSORE	66	HV2	PONNAMPET_66	10:00	15:10	5:10	LINE CLEAR AVAILED
739	21-Sep-19	MYSORE	66	HV3	PONNAMPET_66	10:00	15:10	5:10	LINE CLEAR AVAILED
740	21-Sep-19	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	8:48	8:49	0:00	HAND TRIPPED
741	21-Sep-19	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	MRS MG_220	8:17	16:28	8:11	LINE CLEAR AVAILED
742	21-Sep-19	TUMKUR	220	TR-2(HV SIDE)	KBCROSS_220	16:49	17:10	0:20	TRANSFORMER FAULT
743	21-Sep-19	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	16:49	17:38	0:48	MAIN SUPPLY FAILURE
744	21-Sep-19	TUMKUR	110	TR-1	GUBBI_110	0:33	0:40	0:06	TRANSFORMER FAULT
745	21-Sep-19	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETTYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	16:49	17:13	0:24	LINE FAULT
746	21-Sep-19	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	16:49	17:10	0:20	TRANSFORMER FAULT
747	21-Sep-19	TUMKUR	110	TR-2(LV SIDE)	NITTUR_220	15:53	17:42	1:49	LINE CLEAR AVAILED
748	21-Sep-19	TUMKUR	110	TR-2	SAMPIGE_110	14:30	17:19	2:48	LINE CLEAR AVAILED
749	21-Sep-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	11:33	13:00	1:26	LINE CLEAR AVAILED
750	21-Sep-19	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	16:27	16:41	0:13	LINE CLEAR AVAILED
751	21-Sep-19	TUMKUR	66	TR-1	DYAVARANAHALLI_66	16:27	16:40	0:12	LINE CLEAR AVAILED
752	21-Sep-19	TUMKUR	66	DYAVARANAHALLI-MYLANAHALLI	DYAVARANAHALLI_66	16:27	16:40	0:12	LINE CLEAR AVAILED
753	21-Sep-19	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	17:50	17:57	0:07	LINE FAULT
754	21-Sep-19	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	20:53	21:01	0:08	LINE FAULT
755	21-Sep-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	14:40	14:51	0:10	LINE FAULT
756	21-Sep-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	15:05	15:16	0:11	LINE FAULT
757	21-Sep-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	6:01	6:04	0:02	LINE FAULT
758	21-Sep-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	17:50	18:15	0:25	LINE FAULT
759	21-Sep-19	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	14:59	17:25	2:25	MAIN SUPPLY FAILURE
760	21-Sep-19	TUMKUR	66	NAGALAMADIKE- SUNDARRAJ SOLAR_IPP_66	SUNDARRAJ SOLAR_IPP_66	11:00	11:07	0:07	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
761	21-Sep-19	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,HARAPPANAHALLI_66,HALUVAGALU_66,TELAGI_66	12:16	12:25	0:09	LINE FAULT
762	21-Sep-19	TUMKUR	66	TR-2	TELAGI_66	9:58	10:30	0:31	LINE CLEAR AVAILED
763	21-Sep-19	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	7:11	7:44	0:33	LINE FAULT
764	22-Sep-19	BAGALKOT	110	ATHANI220-BALIGERI(TAUSHI)	BALIGERI(TAUSHI)_110	6:08	6:27	0:19	LINE FAULT
765	22-Sep-19	BAGALKOT	110	110/11KV,HV4	BAILAHONGAL_110	9:09	16:45	7:36	TRANSFORMER FAULT
766	22-Sep-19	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	1:24	1:39	0:15	LINE FAULT
767	22-Sep-19	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	6:31	6:41	0:10	LINE FAULT
768	22-Sep-19	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	11:45	12:38	0:53	LINE CLEAR AVAILED
769	22-Sep-19	BAGALKOT	110	ITNAL-RAIBAG1&2	RAIBAG_110	12:04	12:40	0:36	LINE CLEAR AVAILED
770	22-Sep-19	BAGALKOT	110	110/11KV,HV1	KUD DHARAWAD_110	8:40	23:59	15:19	TRANSFORMER FAULT
771	22-Sep-19	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110,ALNAVAR_33	21:36	21:45	0:09	TRANSFORMER FAULT
772	22-Sep-19	BAGALKOT	110	110/33KV,HV3	MAMADAPUR(B)_110,DEVARAGENNU R_33	13:53	14:18	0:25	TRANSFORMER FAULT
773	22-Sep-19	BAGALKOT	110	SAUBHAGYALAXMI-MAMADAPUR(G)	MAMADAPUR(G)_110	9:45	12:10	2:25	LINE CLEAR AVAILED
774	22-Sep-19	BAGALKOT	110	SPV SOLAR-MUKARTHIHAL	MUKARTHIHAL_110	13:33	14:02	0:29	LINE CLEAR AVAILED
775	22-Sep-19	BAGALKOT	110	110/33KV,HV2	YARAGATTI_110,K SHIVAPUR_33KV,CHUNCHNURLIS_33KV,BOSCH SOLAR_33KV	17:20	19:21	2:01	LINE CLEAR AVAILED
776	22-Sep-19	BAGALKOT	110	110/11KV,HV1	YARAGATTI_110	10:05	19:18	9:13	LINE CLEAR AVAILED
777	22-Sep-19	BAGALKOT	110	110/11KV,HV3	YARAGATTI_110	10:05	17:14	7:09	LINE CLEAR AVAILED
778	22-Sep-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	11:25	23:59	12:34	LINE FAULT
779	22-Sep-19	BAGALKOT	220	HUBLI-NAGJHARI1	HUBLI_220	12:01	12:21	0:20	LINE FAULT
780	22-Sep-19	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	12:53	13:37	0:44	LINE FAULT
781	22-Sep-19	BAGALKOT	110	HUBLI-TARIHAL 1 &2	TARIHAL_110	10:47	17:56	7:09	NFBC ISSUED
782	22-Sep-19	BAGALKOT	110	110/11KV,HV1&HV2	TARIHAL_110	10:20	18:48	8:28	LINE CLEAR AVAILED
783	22-Sep-19	BAGALKOT	110	110/11KV,HV3	TARIHAL_110,DUMMAVAD_33KV,IE_33KV	10:20	18:48	8:28	LINE CLEAR AVAILED
784	22-Sep-19	BAGALKOT	110	110/11KV,HV1	TODALBAGI	10:45	12:47	2:02	TRANSFORMER FAULT
785	22-Sep-19	BAGALKOT	110	110/11KV,HV1	SOUDATTI_220	10:10	12:07	1:57	LINE CLEAR AVAILED
786	22-Sep-19	BAGALKOT	110	SOUDATTI-RAMDURGA1	RAMDURGA_110	9:52	17:30	7:38	LINE CLEAR AVAILED
787	22-Sep-19	BAGALKOT	110	SOUDATTI-MUNAVALLI	MUNAVALLI_110	10:11	16:53	6:42	LINE CLEAR AVAILED
788	22-Sep-19	BAGALKOT	110	SOUDATTI-YARAGATTI	YARAGATTI_110	10:12	16:10	5:58	LINE CLEAR AVAILED
789	22-Sep-19	BAGALKOT	110	SOUDATTI-UDIKERI	UDIKERI_110	9:50	16:07	6:17	LINE CLEAR AVAILED
790	22-Sep-19	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	1:43	1:59	0:16	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
791	22-Sep-19	BAGALKOT	110	NAVALGUND-DHARWAD BIO	NAVALGUND_110	0:00	17:28	17:28	LINE CLEAR AVAILED
792	22-Sep-19	BENGALURU	220	SOMANAHALLI 220 - KHODAYS 220	KHODAYS 220, SUBRAMANYAPURA 220	12:16	12:28	0:12	LINE FAULT
793	22-Sep-19	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHANAGARA, YEDMADU, GODUR	0:42	0:55	0:13	LINE FAULT
794	22-Sep-19	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	5:20	5:27	0:07	LOAD CHANGEOVER
795	22-Sep-19	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	8:24	8:29	0:05	LOAD CHANGEOVER
796	22-Sep-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	12:16	12:38	0:22	MAIN SUPPLY FAILURE
797	22-Sep-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	12:16	12:46	0:29	MAIN SUPPLY FAILURE
798	22-Sep-19	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	12:16	12:30	0:13	MAIN SUPPLY FAILURE
799	22-Sep-19	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	12:16	12:30	0:13	MAIN SUPPLY FAILURE
800	22-Sep-19	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	8:27	12:38	4:11	LINE CLEAR AVAILED
801	22-Sep-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	10:58	11:08	0:10	LINE FAULT
802	22-Sep-19	BENGALURU	220	HV2	SUBRAMANYAPURA 220	12:16	12:32	0:16	MAIN SUPPLY FAILURE
803	22-Sep-19	BENGALURU	220	HV3	SUBRAMANYAPURA 220	12:16	12:33	0:17	MAIN SUPPLY FAILURE
804	22-Sep-19	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	5:21	5:27	0:06	LINE CLEAR AVAILED
805	22-Sep-19	BENGALURU	66	ALUR - DABUSPET 220	ALUR	8:14	8:20	0:06	LOAD CHANGEOVER
806	22-Sep-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	14:11	15:06	0:55	LINE FAULT
807	22-Sep-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	14:11	14:50	0:39	LINE FAULT
808	22-Sep-19	BENGALURU	66	HV1	ATTIBELE	11:28	11:30	0:01	LINE CLEAR AVAILED
809	22-Sep-19	BENGALURU	66	HV1	ATTIBELE	13:20	13:27	0:07	LINE CLEAR AVAILED
810	22-Sep-19	BENGALURU	66	HV1	BANGARPET	14:30	15:10	0:40	TRANSFORMER FAULT
811	22-Sep-19	BENGALURU	220	BEGUR 220 - KIADB HARDWARE PARK 220	KIADB HARDWARE PARK 220	9:55	17:04	7:08	LINE CLEAR AVAILED
812	22-Sep-19	BENGALURU	66	KIADB HARDWARE PARK 220 - SHELL (EHT)	SHELL (EHT)	9:55	17:05	7:10	MAIN SUPPLY FAILURE
813	22-Sep-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	6:29	6:34	0:04	LINE FAULT
814	22-Sep-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	12:51	12:59	0:07	LINE FAULT
815	22-Sep-19	BENGALURU	220	HOSKOTE 220 - KIADB HARDWARE PARK 220	HOSKOTE 220	9:52	17:11	7:19	LINE CLEAR AVAILED
816	22-Sep-19	BENGALURU	220	HV1	HOSKOTE 220	9:52	17:12	7:20	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
817	22-Sep-19	BENGALURU	220	HV2	HOSKOTE 220	9:52	17:11	7:19	LINE CLEAR AVAILED
818	22-Sep-19	BENGALURU	66	HV1	HOSKOTE 220	9:52	17:11	7:19	LINE CLEAR AVAILED
819	22-Sep-19	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, PILLAGUMPA	9:52	17:20	7:28	LINE CLEAR AVAILED
820	22-Sep-19	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	9:52	17:21	7:29	LINE CLEAR AVAILED
821	22-Sep-19	BENGALURU	66	HOSKOTE 220 - BOODIGERE	BOODIGERE	9:52	17:38	7:46	LINE CLEAR AVAILED
822	22-Sep-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	9:52	17:42	7:50	LINE CLEAR AVAILED
823	22-Sep-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	9:52	17:46	7:54	LINE CLEAR AVAILED
824	22-Sep-19	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	9:56	10:06	0:10	LOAD CHANGEOVER
825	22-Sep-19	BENGALURU	66	HBR LAYOUT - MANYATA TECH PARK 220	HBR LAYOUT	17:55	18:00	0:05	LOAD CHANGEOVER
826	22-Sep-19	BENGALURU	220	MANYATA TECH PARK 220 - YELAHANKA 220	MANYATA TECH PARK 220	14:02	14:20	0:18	LINE FAULT
827	22-Sep-19	BENGALURU	66	MANYATA TECH PARK 220 - MANYATA TECH PARK 66	MANYATA TECH PARK 66	14:02	14:20	0:18	MAIN SUPPLY FAILURE
828	22-Sep-19	BENGALURU	66	MANYATA TECH PARK 220 - HBR LAYOUT	HBR LAYOUT	14:02	14:20	0:18	MAIN SUPPLY FAILURE
829	22-Sep-19	BENGALURU	66	HV2	JANGAMAKOTE	8:05	8:21	0:15	TRANSFORMER FAULT
830	22-Sep-19	BENGALURU	66	HV2	JANGAMAKOTE	8:23	8:43	0:19	TRANSFORMER FAULT
831	22-Sep-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	21:23	21:38	0:14	LINE FAULT
832	22-Sep-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	21:38	22:54	1:16	LINE FAULT
833	22-Sep-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	22:05	23:10	1:05	LINE CLEAR AVAILED
834	22-Sep-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	8:01	8:18	0:16	LINE FAULT
835	22-Sep-19	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	5:21	5:25	0:04	MAIN SUPPLY FAILURE
836	22-Sep-19	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	8:15	8:22	0:07	LOAD CHANGEOVER
837	22-Sep-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	5:25	5:27	0:02	LOAD CHANGEOVER
838	22-Sep-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	8:15	8:20	0:05	LOAD CHANGEOVER
839	22-Sep-19	GULBARGA	220	HUMNABAD-SEDAM2	KAPNOOR_220	3:15	4:29	1:14	LINE FAULT
840	22-Sep-19	GULBARGA	220	HUMNABAD-SEDAM1	HALBARGA_220	3:15	16:16	13:01	LINE FAULT
841	22-Sep-19	GULBARGA	220	HV1	SEDAM_220	0:48	11:28	10:40	LINE CLEAR AVAILED
842	22-Sep-19	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110, NIRNA_110	12:15	12:29	0:14	LINE FAULT
843	22-Sep-19	GULBARGA	110	SEDAM-MALKHED RAILWAY TRACTION	MALKHED RAILWAY TRACTION_110	1:21	11:43	10:22	LINE CLEAR AVAILED
844	22-Sep-19	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	12:53	15:19	2:26	LINE CLEAR AVAILED
845	22-Sep-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	BTPSWATERWORKS_IPP,MUKUNDA_110,KAMPLI_110	10:50	11:00	0:10	LINE FAULT
846	22-Sep-19	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110, HABSIKOTE_110	3:11	4:02	0:51	LINE FAULT
847	22-Sep-19	GULBARGA	110	ALIPUR-PDHALLI	PDHALLI_110	6:04	6:13	0:09	LINE FAULT
848	22-Sep-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGAR_IPP	0:31	0:41	0:10	LINE FAULT
849	22-Sep-19	GULBARGA	110	HV2	BELLARYSOUTH_110	11:30	12:31	1:01	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
850	22-Sep-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGAR_IPP	4:58	5:04	0:06	LINE FAULT
851	22-Sep-19	GULBARGA	110	SHAHAPUR-WARDHASOLAR_IPP	SHAHAPUR_220	18:24	23:59	5:35	LINE FAULT
852	22-Sep-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	13:32	13:46	0:14	LINE FAULT
853	22-Sep-19	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	9:31	14:59	5:28	LINE CLEAR AVAILED
854	22-Sep-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:31	11:51	0:20	LINE FAULT
855	22-Sep-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	13:32	23:59	10:27	LINE FAULT
856	22-Sep-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	9:10	12:21	3:11	LINE FAULT
857	22-Sep-19	HASSAN	66	HV1	HOLALUR_66	21:27	22:08	0:41	TRANSFORMER FAULT
858	22-Sep-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	15:55	16:07	0:12	LINE FAULT
859	22-Sep-19	HASSAN	66	HV1	SAKLESH PURA_66	6:56	7:17	0:21	TRANSFORMER FAULT
860	22-Sep-19	MYSORE	66	HV2	BGNAGARA_66	15:58	16:29	0:31	LINE CLEAR AVAILED
861	22-Sep-19	MYSORE	220	HV1	BOMMALAPURA_66, BHARGI_66 DODDARAYAPET_66, CHANDAKAVADI_66, ATTIGULIPURA_66, GUNDULPET_66, HANGLA_66, KABHALLY_66, HARVEY_66, HONNALLY_MYS_66, TERAKANAMBE_66	10:43	18:08	7:25	LINE CLEAR AVAILED
862	22-Sep-19	MYSORE	220	HV2	BOMMALAPURA_66, BHARGI_66 DODDARAYAPET_66, CHANDAKAVADI_66, ATTIGULIPURA_66, GUNDULPET_66, HANGLA_66, KABHALLY_66, HARVEY_66, HONNALLY_MYS_66, TERAKANAMBE_66	10:43	18:08	7:25	LINE CLEAR AVAILED
863	22-Sep-19	MYSORE	66	HV1	CRNAGAR_220	10:40	19:19	8:39	LINE CLEAR AVAILED
864	22-Sep-19	MYSORE	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	18:39	19:03	0:23	LINE FAULT
865	22-Sep-19	MYSORE	66	HV1	ELAVALA_66	12:12	12:20	0:08	TRANSFORMER FAULT
866	22-Sep-19	MYSORE	66	HV1	ELAVALA_66	13:18	13:31	0:12	TRANSFORMER FAULT
867	22-Sep-19	MYSORE	66	HV1	JAKKANAHALLY_66	11:00	11:10	0:10	LINE CLEAR AVAILED
868	22-Sep-19	MYSORE	66	HV2	JAKKANAHALLY_66	11:00	11:10	0:10	LINE CLEAR AVAILED
869	22-Sep-19	MYSORE	66	HV1	JAKKANAHALLY_66	12:26	12:38	0:11	LINE CLEAR AVAILED
870	22-Sep-19	MYSORE	66	HV2	JAKKANAHALLY_66	12:26	12:38	0:11	LINE CLEAR AVAILED
871	22-Sep-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66, KIADBMANDYA_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	10:58	11:09	0:11	LINE FAULT
872	22-Sep-19	MYSORE	66	HV2	METAGALLY_66	10:21	13:15	2:54	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
873	22-Sep-19	MYSORE	66	HV1	PANDAVAPURA_66	19:53	20:11	0:18	HAND TRIPPED
874	22-Sep-19	MYSORE	66	HV2	PANDAVAPURA_66	19:53	20:11	0:18	HAND TRIPPED
875	22-Sep-19	MYSORE	66	PANDAVAPURA-TUBINAKERE	DODDABYADARAHALLI_66, PANDAVAPURA_66	5:46	5:55	0:08	LINE FAULT
876	22-Sep-19	MYSORE	66	HV5	SFCSHIVA_66	14:04	14:10	0:05	TRANSFORMER FAULT
877	22-Sep-19	MYSORE	66	HV2	THANDYA_66	11:18	14:28	3:10	LINE CLEAR AVAILED
878	22-Sep-19	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	22:11	22:19	0:07	TRANSFORMER FAULT
879	22-Sep-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	12:33	12:44	0:11	LINE FAULT
880	22-Sep-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	14:56	15:12	0:16	LINE FAULT
881	22-Sep-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	17:04	18:08	1:04	LINE CLEAR AVAILED
882	22-Sep-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	14:52	15:07	0:14	LINE FAULT
883	22-Sep-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	15:10	18:08	2:58	LINE FAULT
884	22-Sep-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	12:02	12:13	0:10	LINE FAULT
885	22-Sep-19	TUMKUR	66	TR-1	KATTIGE_66	10:21	10:27	0:06	TRANSFORMER FAULT
886	22-Sep-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	23:08	23:15	0:07	LINE FAULT
887	22-Sep-19	TUMKUR	66	TR-2	HOSAKERE_66	12:24	14:23	1:58	LINE CLEAR AVAILED
888	23-Sep-19	BAGALKOT	110	SUPA1-AMBEWADI	AMBEWADI_220	16:08	16:19	0:11	LINE FAULT
889	23-Sep-19	BAGALKOT	110	ANKALAGI-HIDIKAL	HIDIKAL_110	12:55	17:53	4:58	LINE CLEAR AVAILED
890	23-Sep-19	BAGALKOT	110	BPCL-ITNAL	ITNAL_110	7:01	8:18	1:17	LINE FAULT
891	23-Sep-19	BAGALKOT	110	HUNGUND-KUDALASAGAM	KUDALASANGAM_110	12:40	12:52	0:12	HAND TRIPPED
892	23-Sep-19	BAGALKOT	110	KUDALASANGAM-RAMPUR	RAMPUR_110	12:40	13:11	0:31	HAND TRIPPED
893	23-Sep-19	BAGALKOT	110	KUDALASANGAM-RAMPUR	RAMPUR_110	13:25	13:35	0:10	LINE FAULT
894	23-Sep-19	BAGALKOT	110	KUDALASANGAM-RAMPUR	RAMPUR_110	13:50	13:55	0:05	LINE FAULT
895	23-Sep-19	BAGALKOT	110	110/11KV,HV3	MUDALAGI_11	12:13	12:56	0:43	HAND TRIPPED
896	23-Sep-19	BAGALKOT	110	110/11KV,HV1	TARIHAL_110	16:25	17:02	0:37	TRANSFORMER FAULT
897	23-Sep-19	BAGALKOT	110	110/11KV,HV2	SHIROL	0:23	1:23	1:00	TRANSFORMER FAULT
898	23-Sep-19	BAGALKOT	110	110/11KV,HV3	SAVALGI_110	12:03	12:38	0:35	LINE CLEAR AVAILED
899	23-Sep-19	BAGALKOT	110	RANEENNUR-RATTIHAL	RATTIHAL_110	6:03	10:53	4:50	LINE FAULT
900	23-Sep-19	BAGALKOT	110	RANEENNUR-RATTIHAL	RATTIHAL_110	13:15	13:48	0:33	HAND TRIPPED
901	23-Sep-19	BAGALKOT	220	HUBLI-SIRS12	HUBLI_220	0:00	16:23	16:23	LINE CLEAR AVAILED
902	23-Sep-19	BAGALKOT	220	HUBLI-SIRS11	HUBLI_220	10:26	16:23	5:57	LINE CLEAR AVAILED
903	23-Sep-19	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	11:39	15:04	3:25	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
904	23-Sep-19	BAGALKOT	110	NAVLGUND-DHARWAD BIO	NAVALGUND_110	13:09	14:42	1:33	LINE CLEAR AVAILED
905	23-Sep-19	BAGALKOT	110	NAVLGUND-DHARWAD BIO	NAVALGUND_110	16:53	18:45	1:52	LINE CLEAR AVAILED
906	23-Sep-19	BENGALURU	66	ANEKAL - ATTIBELE	ANEKAL, SURYANAGAR	9:48	9:59	0:11	LOAD CHANGEOVER
907	23-Sep-19	BENGALURU	66	BAGMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	17:08	17:58	0:49	LINE FAULT
908	23-Sep-19	BENGALURU	66	BAGMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	17:58	22:56	4:58	LINE FAULT
909	23-Sep-19	BENGALURU	66	BAGMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	22:56	23:59	1:02	LINE FAULT
910	23-Sep-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	18:47	19:45	0:57	LINE FAULT
911	23-Sep-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	18:47	19:45	0:57	LINE FAULT
912	23-Sep-19	BENGALURU	66	DEVANAHALLI - DB PURA 2	DEVANAHALLI	18:47	20:02	1:14	LINE FAULT
913	23-Sep-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	14:32	14:33	0:01	LINE CLEAR AVAILED
914	23-Sep-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	9:34	10:04	0:30	LINE CLEAR AVAILED
915	23-Sep-19	BENGALURU	220	JIGANI 220 - SOMANAHALLI 220	JIGANI 220	3:31	5:10	1:39	MAIN SUPPLY FAILURE
916	23-Sep-19	BENGALURU	66	HV1	JIGANI 220	3:31	5:10	1:39	MAIN SUPPLY FAILURE
917	23-Sep-19	BENGALURU	66	HV2	JIGANI 220	3:31	5:10	1:39	MAIN SUPPLY FAILURE
918	23-Sep-19	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	3:31	4:50	1:19	MAIN SUPPLY FAILURE
919	23-Sep-19	BENGALURU	66	HV1	JIGANI 220	11:47	12:18	0:31	LOAD CHANGEOVER
920	23-Sep-19	BENGALURU	66	HV2	JIGANI 220	11:47	12:18	0:31	LOAD CHANGEOVER
921	23-Sep-19	BENGALURU	66	HV2	MAASTHI	17:45	17:51	0:05	TRANSFORMER FAULT
922	23-Sep-19	BENGALURU	66	HV2	SARJAPURA 220	12:03	12:06	0:02	LINE CLEAR AVAILED
923	23-Sep-19	BENGALURU	66	HV2	SARJAPURA 220	13:25	13:26	0:01	LINE CLEAR AVAILED
924	23-Sep-19	BENGALURU	66	YELAHANKA 220 - LINE 7	KANASWADI	14:14	14:35	0:20	LINE FAULT
925	23-Sep-19	BENGALURU	66	KANASWADI - DB PURA 220	KANASWADI	16:50	16:55	0:05	LOAD CHANGEOVER
926	23-Sep-19	BENGALURU	66	YELAHANKA 220 - LINE 3	ATTUR YELAHANKA, ABBIGERE	5:55	6:20	0:25	LINE FAULT
927	23-Sep-19	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	6:20	7:05	0:45	MAIN SUPPLY FAILURE
928	23-Sep-19	BENGALURU	66	ATTUR YELAHANKA - DG 4	ATTUR YELAHANKA	7:33	7:34	0:01	LINE FAULT
929	23-Sep-19	BENGALURU	220	TK HALLI 220 - VAJAMANGALA 220		14:05	14:25	0:20	LINE FAULT
930	23-Sep-19	BENGALURU	66	ATTUR YELAHANKA - DG 4	ATTUR YELAHANKA	9:40	9:50	0:10	LOAD CHANGEOVER
931	23-Sep-19	BENGALURU	66	ABBIGERE - DG 3	ABBIGERE	10:06	10:10	0:04	LOAD CHANGEOVER
932	23-Sep-19	BENGALURU	66	ADUGODI - HSR LAYOUT 1	ADUGODI, BOSCH (EHT), AMARJYOTHI	6:56	7:03	0:07	LOAD CHANGEOVER
933	23-Sep-19	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	12:24	12:35	0:11	LOAD CHANGEOVER
934	23-Sep-19	BENGALURU	66	HEBBAL 220 - C STATION 1	C STATION	5:55	6:46	0:51	MAIN SUPPLY FAILURE
935	23-Sep-19	BENGALURU	66	HEBBAL 220 - IISC	IISC	5:55	6:50	0:55	MAIN SUPPLY FAILURE
936	23-Sep-19	BENGALURU	66	HEBBAL 220 - IISC	IISC	7:04	7:14	0:09	LINE CLEAR AVAILED
937	23-Sep-19	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	5:55	6:45	0:50	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
938	23-Sep-19	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	5:55	6:48	0:53	MAIN SUPPLY FAILURE
939	23-Sep-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	4:51	6:01	1:09	MAIN SUPPLY FAILURE
940	23-Sep-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	4:51	5:27	0:35	MAIN SUPPLY FAILURE
941	23-Sep-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	4:51	6:02	1:10	MAIN SUPPLY FAILURE
942	23-Sep-19	BENGALURU	220	SOMANAHALLI 220 - NAGNATHPURA 220	NAGNATHPURA 220	4:51	5:16	0:25	LINE FAULT
943	23-Sep-19	BENGALURU	220	SOMANAHALLI 220 - NAGNATHPURA 220	NAGNATHPURA 220	5:35	19:50	14:15	LINE FAULT
944	23-Sep-19	BENGALURU	220	SOMANAHALLI 220 - YARANDANAHALLI 220	JIGANI 220, YARANDANAHALLI 220	3:31	3:56	0:24	LINE FAULT
945	23-Sep-19	BENGALURU	220	SOMANAHALLI 220 - YARANDANAHALLI 220	JIGANI 220, YARANDANAHALLI 220	3:56	4:10	0:13	LINE FAULT
946	23-Sep-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	3:31	5:09	1:37	MAIN SUPPLY FAILURE
947	23-Sep-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	11:51	12:05	0:13	LOAD CHANGEOVER
948	23-Sep-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	4:10	6:55	2:44	MAIN SUPPLY FAILURE
949	23-Sep-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	9:39	9:46	0:06	LOAD CHANGEOVER
950	23-Sep-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	1:50	2:07	0:16	LINE FAULT
951	23-Sep-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	1:50	2:09	0:18	LINE FAULT
952	23-Sep-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	6:44	9:05	2:21	LINE CLEAR AVAILED
953	23-Sep-19	BENGALURU	66	HV2	BANASWADI	17:10	17:39	0:29	MAIN SUPPLY FAILURE
954	23-Sep-19	BENGALURU	220	HV1	HEBBAL 220	5:55	6:43	0:48	MAIN SUPPLY FAILURE
955	23-Sep-19	BENGALURU	66	HV1	HEBBAL 220	5:55	6:47	0:52	MAIN SUPPLY FAILURE
956	23-Sep-19	BENGALURU	220	HV2	HEBBAL 220	5:55	6:44	0:49	MAIN SUPPLY FAILURE
957	23-Sep-19	BENGALURU	66	HV2	HEBBAL 220	5:55	6:47	0:52	MAIN SUPPLY FAILURE
958	23-Sep-19	BENGALURU	66	HV3	HEBBAL 220	5:55	6:47	0:52	MAIN SUPPLY FAILURE
959	23-Sep-19	BENGALURU	66	HV1	NAGNATHPURA 220	4:51	6:03	1:11	MAIN SUPPLY FAILURE
960	23-Sep-19	BENGALURU	66	HV2	NAGNATHPURA 220	4:51	5:22	0:30	MAIN SUPPLY FAILURE
961	23-Sep-19	BENGALURU	66	HV2	NAGNATHPURA 220	5:31	6:00	0:28	MAIN SUPPLY FAILURE
962	23-Sep-19	BENGALURU	220	HV2	YERANDANAHALLI 2200	4:10	12:02	7:52	MAIN SUPPLY FAILURE
963	23-Sep-19	BENGALURU	66	HV1	YERANDANAHALLI 2200	3:31	4:10	0:38	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
964	23-Sep-19	BENGALURU	66	HV2	YERANDANAHALLI 2200	3:31	4:12	0:40	MAIN SUPPLY FAILURE
965	23-Sep-19	BENGALURU	66	HV3	YERANDANAHALLI 2200	4:10	4:13	0:02	MAIN SUPPLY FAILURE
966	23-Sep-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	3:31	4:43	1:11	MAIN SUPPLY FAILURE
967	23-Sep-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	3:31	4:43	1:11	MAIN SUPPLY FAILURE
968	23-Sep-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	11:55	12:06	0:11	LOAD CHANGEOVER
969	23-Sep-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	11:55	12:06	0:11	LOAD CHANGEOVER
970	23-Sep-19	GULBARGA	110	HV1, HV2	BISIHALLI_110	12:03	14:00	1:57	LINE CLEAR AVAILED
971	23-Sep-19	GULBARGA	110	HV2	BISIHALLI_110	7:08	8:05	0:57	TRANSFORMER FAULT
972	23-Sep-19	GULBARGA	110	HV1	HALBURGA_220	14:50	15:25	0:35	LINE CLEAR AVAILED
973	23-Sep-19	GULBARGA	110	SEDAM-VICATSAGAR_CEMENTS	VICATSAGAR_CEMENTS	4:54	5:05	0:11	LINE FAULT
974	23-Sep-19	GULBARGA	110	SEDAM-VICATSAGAR_CEMENTS	VICATSAGAR_CEMENTS	5:05	6:08	1:03	LINE FAULT
975	23-Sep-19	GULBARGA	110	SHAHAPUR-SHAHBAD1	SHAHAPUR_110	4:30	7:20	2:50	LINE FAULT
976	23-Sep-19	GULBARGA	110	HV2	YELBURGA_110	6:02	6:15	0:13	TRANSFORMER FAULT
977	23-Sep-19	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPURA_110	5:54	6:05	0:11	LINE FAULT
978	23-Sep-19	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	8:52	8:58	0:06	LINE FAULT
979	23-Sep-19	GULBARGA	220	RTPS-RAICHUR2	RAICHUR_220	9:30	17:31	8:01	LINE CLEAR AVAILED
980	23-Sep-19	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	15:19	15:35	0:16	LINE FAULT
981	23-Sep-19	GULBARGA	220	SHAHAPUR-LINGASUGUR	LINGASUGUR_220	16:18	17:15	0:57	LINE CLEAR AVAILED
982	23-Sep-19	GULBARGA	220	SHAHAPUR-SHAHBAD	SHAHABAD_220	17:13	23:59	6:46	LINE CLEAR AVAILED
983	23-Sep-19	GULBARGA	110	SHAHAPUR-WARDHASOLAR_IPP	SHAHAPUR_220	0:00	2:26	2:26	LINE FAULT
984	23-Sep-19	GULBARGA	110	HUMNABAD-SEDAM2	SEDAM_220	15:18	15:32	0:14	LINE FAULT
985	23-Sep-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	17:14	17:25	0:11	LINE CLEAR AVAILED
986	23-Sep-19	GULBARGA	110	HUMNABAD-CHUTGUPPA	CHITGUPPA_110, NIRNA_110	17:14	17:25	0:11	LINE CLEAR AVAILED
987	23-Sep-19	GULBARGA	110	HUMNABAD-HUMNABAD2	HUMNABAD_110	17:20	17:25	0:05	LINE CLEAR AVAILED
988	23-Sep-19	GULBARGA	110	SHAHAPUR-WARDHASOLAR_IPP	SHAHAPUR_220	19:49	21:27	1:38	LINE FAULT
989	23-Sep-19	GULBARGA	66	HV2	TAMBRAHALLI_66	22:45	22:50	0:05	TRANSFORMER FAULT
990	23-Sep-19	GULBARGA	66	HV1 & HV2	TAMBRAHALLI_66	15:40	17:10	1:30	LINE CLEAR AVAILED
991	23-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGU	16:33	23:59	7:26	LINE FAULT
992	23-Sep-19	HASSAN	400	UPCL-HASSAN1	UPCL	0:00	9:50	9:50	LINE CLEAR AVAILED
993	23-Sep-19	HASSAN	400	UPCL-HASSAN1	UPCL	22:17	23:59	1:42	LINE CLEAR AVAILED
994	23-Sep-19	HASSAN	220	HV1	KEMAR	11:50	12:23	0:33	LINE CLEAR AVAILED
995	23-Sep-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSSHM	12:13	16:26	4:13	LINE CLEAR AVAILED
996	23-Sep-19	HASSAN	220	MRSSHM-VARAH1	MRSSHM	0:00	8:42	8:42	LINE FAULT
997	23-Sep-19	HASSAN	220	MRSSHM-VARAH12	MRSSHM	10:09	23:59	13:50	LINE CLEAR AVAILED
998	23-Sep-19	HASSAN	220	VARAH1-SHIMOGA2	VARAH1	8:44	10:08	1:24	LINE CLEAR AVAILED
999	23-Sep-19	HASSAN	110	LV1	KEMAR	11:50	12:24	0:34	LINE CLEAR AVAILED
1000	23-Sep-19	HASSAN	110	NANDIKU-KEMAR1	NANDIKU	0:00	15:12	15:12	NFBC ISSUED
1001	23-Sep-19	HASSAN	110	HV2	SORABA	13:27	15:33	2:06	LINE CLEAR AVAILED
1002	23-Sep-19	HASSAN	66	HV1	BASAVAGT	5:25	8:18	2:53	TRANSFORMER FAULT
1003	23-Sep-19	HASSAN	66	HV1	HARIHAR	4:31	4:42	0:11	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1004	23-Sep-19	HASSAN	66	HV1	HOLALU	12:02	17:00	4:58	LINE CLEAR AVAILED
1005	23-Sep-19	HASSAN	66	KIADB HA-RAMESWARNAGAR	KIADB HA	18:55	19:46	0:51	LINE CLEAR AVAILED
1006	23-Sep-19	HASSAN	66	RMWNGR-SHANTI	RMWNGR	17:40	20:15	2:35	NFBC ISSUED
1007	23-Sep-19	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHI	11:15	20:29	9:14	LINE FAULT
1008	23-Sep-19	MYSORE	66	HV1	BANANGADI_66	12:33	12:37	0:03	HAND TRIPPED
1009	23-Sep-19	MYSORE	66	HV1	BANNUR_66	10:40	18:30	7:50	LINE CLEAR AVAILED
1010	23-Sep-19	MYSORE	66	HV2	BANNUR_66	10:50	18:30	7:40	LINE CLEAR AVAILED
1011	23-Sep-19	MYSORE	66	HV1	BANNUR_66	18:55	18:57	0:02	TRANSFORMER FAULT
1012	23-Sep-19	MYSORE	66	HV2	DK MAIDANA-	10:48	12:48	2:00	TRANSFORMER FAULT
1013	23-Sep-19	MYSORE	66	JAKKANAHALLI-NAGMANGLA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, NAGAMANGALA_66	2:57	3:27	0:29	LINE FAULT
1014	23-Sep-19	MYSORE	66	HV1	K_HONNALGERE_66	13:26	13:32	0:06	HAND TRIPPED
1015	23-Sep-19	MYSORE	66	HV2	K_HONNALGERE_66	13:26	13:32	0:06	HAND TRIPPED
1016	23-Sep-19	MYSORE	66	MADDUR	MADDUR_66, SOMANAHALLI_66	2:42	9:21	6:38	LINE CLEAR AVAILED
1017	23-Sep-19	MYSORE	66	HV1	KIADBMANDYA_66	1:50	2:12	0:22	HAND TRIPPED
1018	23-Sep-19	MYSORE	66	HV2	KIADBMANDYA_66	1:50	2:12	0:22	HAND TRIPPED
1019	23-Sep-19	MYSORE	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66, MADDUR_66, SOMANAHALLI_66 TUMBEKERE_66	2:32	9:16	6:44	NFBC ISSUED
1020	23-Sep-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66	6:48	9:07	2:19	LINE CLEAR AVAILED
1021	23-Sep-19	MYSORE	66	HV1	KRPET_66	9:23	11:23	2:00	LINE CLEAR AVAILED
1022	23-Sep-19	MYSORE	66	HV1	MADDUR_66	1:49	2:11	0:22	HAND TRIPPED
1023	23-Sep-19	MYSORE	66	HV2	MADDUR_66	1:49	2:11	0:22	HAND TRIPPED
1024	23-Sep-19	MYSORE	66	HV1	MADDUR_66	2:30	2:40	0:10	HAND TRIPPED
1025	23-Sep-19	MYSORE	66	HV2	MADDUR_66	2:30	2:40	0:10	HAND TRIPPED
1026	23-Sep-19	MYSORE	66	MALLAVALLI-KADKOTHANAHALLI	MALAVALLI_66, HADLI_66	12:52	14:15	1:23	NFBC ISSUED
1027	23-Sep-19	MYSORE	66	HV2	THALAKADU_66	22:44	22:51	0:07	LINE CLEAR AVAILED
1028	23-Sep-19	MYSORE	66	VAJMANGALA-KADKOLA 1	AYRALLI_66, MARADIHUNDI_66	7:34	7:39	0:05	LINE FAULT
1029	23-Sep-19	TUMKUR	220	TR-1(HV SIDE)	HONNALLI_220	16:02	17:24	1:21	LINE CLEAR AVAILED
1030	23-Sep-19	TUMKUR	66	TR-1(HV SIDE)	HONNALLI_220	15:35	16:24	0:48	LINE CLEAR AVAILED
1031	23-Sep-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	17:26	17:33	0:06	LINE FAULT
1032	23-Sep-19	TUMKUR	66	TR-1(LV SIDE)	HONNALLI_220	16:02	17:25	1:22	LINE CLEAR AVAILED