

400/220/110/66 kV TRANSMISSION OUTAGES FROM 10.05.22 TO 16.05.22

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	10-May-22	BAGALKOT	110	110/11KV, HV1	ATHANI_220	10:20	12:41	2:21	LINE CLEAR AVAILED
2	10-May-22	BAGALKOT	110	110/11KV, HV1	HALKI_110	17:20	17:30	0:10	TRANSFORMER FAULT
3	10-May-22	BAGALKOT	110	110/11KV, HV1	MAREGUDDI_110	12:00	12:15	0:15	LINE CLEAR AVAILED
4	10-May-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KUDACHI_220	11:12	13:23	2:11	HAND TRIPPED
5	10-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED GIRISAGAR_110	9:40 (05.05.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
6	10-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MAMADAPUR(B)_110	11:31	11:34	0:03	TRANSFORMER FAULT
7	10-May-22	BAGALKOT	110	110/11KV, HV2	UDIKERI_110	17:25	18:40	1:15	LINE CLEAR AVAILED
8	10-May-22	BAGALKOT	110	110/11KV, HV2	YARAGATTI_110	3:54	4:54	1:00	LINE CLEAR AVAILED
9	10-May-22	BAGALKOT	110	110/11KV, HV3	RATTIHALLI_110	12:12	12:21	00:09	TRANSFORMER FAULT
10	10-May-22	BAGALKOT	110	110/11KV, HV3	SAVALAGI_110	12:03	20:15	08:12	TRANSFORMER FAULT
11	10-May-22	BAGALKOT	110	110/11KV,HV1	HALAKI_110	17:19	17:28	0:09	TRANSFORMER FAULT
12	10-May-22	BAGALKOT	110	110/11KV,HV1	KALGHATAGI_110	15:48	17:31	1:43	LINE CLEAR AVAILED
13	10-May-22	BAGALKOT	110	110/11KV,HV1	MALGHAN(S)_110	09:32	13:18	3:46	LINE CLEAR AVAILED
14	10-May-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	09:13	10:26	1:13	HAND TRIPPED
15	10-May-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	11:19	11:44	0:25	HAND TRIPPED
16	10-May-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	18:53	18:56	0:03	TRANSFORMER FAULT
17	10-May-22	BAGALKOT	110	110/11KV,HV2	GOKAK_110	12:20	12:27	0:07	TRANSFORMER FAULT
18	10-May-22	BAGALKOT	110	110/11KV,HV2	MALGHAN(S)_110	10:49	17:08	6:19	LINE CLEAR AVAILED
19	10-May-22	BAGALKOT	110	110/11KV,HV2	SHIRBUR_110	12:19	12:54	0:35	HAND TRIPPED
20	10-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
21	10-May-22	BAGALKOT	110	110/11KV,HV3	BILAGI_110	16:45	17:12	0:27	LINE CLEAR AVAILED
22	10-May-22	BAGALKOT	110	110/33KV,HV3	KANABARGI_110 & BALEKUNDRI&GARISON_33	11:25	12:40	1:15	LINE CLEAR AVAILED
23	10-May-22	BAGALKOT	110	AMBEWADI- NK1 (KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	9:30 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
24	10-May-22	BAGALKOT	110	AMBEWADI- NK2 (HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	9:33 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
25	10-May-22	BAGALKOT	110	KARWAR220- BINAGA	KARWAR_220	12:35	15:01	2:26	LINE CLEAR AVAILED
26	10-May-22	BAGALKOT	110	KARWAR220- KUMATA	KARWAR_220	12:33	15:05	2:32	LINE CLEAR AVAILED
27	10-May-22	BAGALKOT	110	KIADB BIJAPUR-BHUTANAL	BHUTANAL_110	11:46	11:55	0:09	LINE FAULT
28	10-May-22	BAGALKOT	110	MUNDARGI- VIJAYANAGAR SUGARS	MUNDARGI_110	20:24 (10.05.2022)			LINE OPEN:LINE FAULT
29	10-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
30	10-May-22	BAGALKOT	110	SAVALAGI- AIGALI	STATION NOT AFFECTED SAVALAGI_110	12:18	18:05	05:47	HAND TRIPPED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
31	10-May-22	BAGALKOT	110	SHIGGOAN-SAVANUR	STATION NOT AFFECTED SHIGGOAN_110	13:25	14:10	0:45	LINE CLEAR AVALIED
32	10-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
33	10-May-22	BAGALKOT	110	TAKKALAKI-THORVI	STATION NOT AFFECTED TAKKALAKI_110	05:48	11:39	5:51	LINE CLEAR AVALIED
34	10-May-22	BAGALKOT	110	THORVI-TIKOTA	TIKOTA_110	05:45	11:40	5:55	LINE CLEAR AVALIED
35	10-May-22	BAGALKOT	110	THORVI-TIKOTA	TIKOTA_110	11:48	12:00	0:12	LINE FAULT
36	10-May-22	BAGALKOT	110	TIKOTA- BHUTNAL(HONAWAD)	HONAWAD_110	10:13	10:17	0:04	LINE FAULT
37	10-May-22	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED VAJRAMATTI_220	6:52	7:43	0:51	LINE CLEAR AVALIED
38	10-May-22	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED BELGAUM_220	10:34 (24.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVALIED
39	10-May-22	BAGALKOT	220	ATHANI- KAKMARI2	STATION NOT AFFECTED ATHANI_220	7:26 (09.05.2022)	16:34 (10.05.2022)	33:08 hrs	NFBC ISSUED
40	10-May-22	BAGALKOT	220	ATHANI-KAKMARI-1	STATION NOT AFFECTED ATHANI_220	9:04 (07.05.2022)	16:34 (10.05.2022)	31:30 hrs	NFBC ISSUED
41	10-May-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	9:18 (09.05.2022)			LINE OPEN:LINE CLEAR AVALIED
42	10-May-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVALIED
43	10-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVALIED
44	10-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVALIED
45	10-May-22	BAGALKOT	220	VAJRAMATTI- BAGALKOT2	STATION NOT AFFECTED VAJRAMATTI_220	11:42	15:43	4:01	HAND TRIPPED
46	10-May-22	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	00:00	00:23	00:23	LINE FAULT
47	10-May-22	BENGALURU	66	HV1	CHANDAPURA	08:58	09:17	00:19	LINE CLEAR AVALIED
48	10-May-22	BENGALURU	66	HV1	HUKUNDA	01:21	01:25	00:04	TRANSFORMER FAULT
49	10-May-22	BENGALURU	66	HV1	HUKUNDA	09:16	09:27	00:11	TRANSFORMER FAULT
50	10-May-22	BENGALURU	66	HV1	HUKUNDA	12:01	13:26	01:24	LINE CLEAR AVALIED
51	10-May-22	BENGALURU	66	HV1	HUKUNDA	16:07	16:12	00:05	TRANSFORMER FAULT
52	10-May-22	BENGALURU	66	HV1	KOTIPURA 220	21:57	22:20	00:23	TRANSFORMER FAULT
53	10-May-22	BENGALURU	66	HV1	MANDIKAL	04:23	04:51	00:27	TRANSFORMER FAULT
54	10-May-22	BENGALURU	66	HV1	MITTEMARI 220	14:14	14:23	00:09	LINE CLEAR AVALIED
55	10-May-22	BENGALURU	66	HV2	BG ROAD	11:46	11:51	00:05	TRANSFORMER FAULT
56	10-May-22	BENGALURU	66	HV2	CHANDAPURA	08:53	09:14	00:21	LINE CLEAR AVALIED
57	10-May-22	BENGALURU	66	HV2	HUKUNDA	13:23	14:14	00:51	LINE CLEAR AVALIED
58	10-May-22	BENGALURU	66	HV2	MAASTHI	10:10	10:25	00:15	LINE CLEAR AVALIED
59	10-May-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	16:52	17:02	00:10	LINE FAULT
60	10-May-22	BENGALURU	66	MAASTHI - ADANI SOLAR (IPP)	NO STATION AFFECTED	10:30	10:40	00:10	LINE CLEAR AVALIED
61	10-May-22	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI, PERESANDRA	03:09	03:17	00:08	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
62	10-May-22	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI, PERESANDRA	03:58	04:04	00:05	LINE FAULT
63	10-May-22	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI, PERESANDRA	04:04	04:25	00:20	LINE FAULT
64	10-May-22	BENGALURU	66	SOMENAHALLI - PERESANDRA	PERESANDRA	10:23	16:53	06:29	LINE CLEAR AVAILED
65	10-May-22	BENGALURU	66	SOMENAHALLI - PERESANDRA	PERESANDRA	03:09	03:18	00:08	LINE FAULT
66	10-May-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	00:00	00:40	00:40	LINE CLEAR AVAILED
67	10-May-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML	00:00	00:40	00:40	LINE CLEAR AVAILED
68	10-May-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, NG HULKUR, MALLANAYAKANAHALLI	01:25	03:45	02:20	LINE CLEAR AVAILED
69	10-May-22	BENGALURU	66	THAYLUR - MALLANAYAKANAHALLI	MALLANAYAKANAHALLI	22:05(9-5-2022)	3:55(10-5-2022)	05:49	LINE CHARGED
70	10-May-22	BENGALURU	66	THAYLUR - N G HULKUR	N G HULKUR	22:05(9-5-2022)	3:55(10-5-2022)	05:49	LINE CHARGED
71	10-May-22	BENGALURU	66	THAYLUR - T GOLLAHALLI 220	THAYALUR, NG HULKUR, MALLANAYAKANAHALLI	22:05(9-5-2022)	3:50(10-5-2022)	05:44	LINE CHARGED
72	10-May-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	00:00	00:20	00:20	LINE FAULT
73	10-May-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, SAMANDURU	00:00	00:18	00:18	LINE FAULT
74	10-May-22	GULBARGA	66	HV1	BENNEHALLI_66	18:10	18:25	00:15	TRANSFORMER FAULT
75	10-May-22	GULBARGA	66	HV1	KUDLIGI_220	19:10	19:20	00:10	TRANSFORMER FAULT
76	10-May-22	GULBARGA	66	ITTAGI-BENNEHALLI	BENNEHALLI_66,UJJAINI_66,KO TTUR_66	16:55	17:05	00:10	LINE FAULT
77	10-May-22	GULBARGA	66	ITTAGI-BENNEHALLI	BENNEHALLI_66,UJJAINI_66,KO TTUR_66	09:32	09:40	00:08	LINE FAULT
78	10-May-22	GULBARGA	66	ITTAGI-HAGRIBOMMANHALLI	HB HALLI_66,UP HALLI_66	18:00	18:58	00:58	LINE FAULT
79	10-May-22	GULBARGA	66	ITTAGI-KUDLIGI_2	CHORNOOR_66,BANVIKAL_66,K UDLIGI_220	18:00 (10.05.2022)			LINE OPEN:LINE CLEAR AVAILED
80	10-May-22	GULBARGA	66	KOGALI-KUDLIGI	KOGALI_66,KUDLIGI_66,HANSI_66,CHORNOOR_66,BANVIKAL_66,KUDLIGI_220	19:25	19:50	00:25	LINE FAULT
81	10-May-22	GULBARGA	66	MAGALA-ITTAGGI	MAGALA_66	10:08	17:15	07:07	LINE CLEAR AVAILED
82	10-May-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	09:45	09:52	00:07	MAIN SUPPLY FAILURE
83	10-May-22	GULBARGA	110	AURAD-DONGARGAON	DONGARGAON_110	08:45	08:50	00:05	LINE FAULT
84	10-May-22	GULBARGA	110	AURAD-DONGARGAON	DONGARGAON_110	13:40	13:45	00:05	LINE FAULT
85	10-May-22	GULBARGA	110	AURAD-DONGARGAON	DONGARGAON_110	15:30	15:35	00:05	LINE FAULT
86	10-May-22	GULBARGA	110	AURAD-DONGARGAON	DONGARGAON_110	15:40	15:45	00:05	LINE FAULT
87	10-May-22	GULBARGA	110	AURAD-DONGARGAON	DONGARGAON_110	15:50	16:05	00:15	LINE FAULT
88	10-May-22	GULBARGA	110	AURAD-DONGARGAON	DONGARGAON_110	16:10	16:25	00:15	LINE FAULT
89	10-May-22	GULBARGA	110	GALAG-MALLAT	GALAG_110	17:35	17:50	00:15	MAIN SUPPLY FAILURE
90	10-May-22	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE_110	00:00	08:00	08:00	MAIN SUPPLY FAILURE
91	10-May-22	GULBARGA	110	HALBARGA-HUMNABAD	HALBARGA_220	16:57	17:02	00:05	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
92	10-May-22	GULBARGA	110	HV1	GOOGLE_110	15:20	22:20	07:00	LINE CLEAR AVAILED
93	10-May-22	GULBARGA	110	HV1	MATAMARI_110	09:45	09:50	00:05	TRANSFORMER FAULT
94	10-May-22	GULBARGA	110	HV2	KUSTAGI_220	15:55	16:15	00:20	TRANSFORMER FAULT
95	10-May-22	GULBARGA	110	HV2	KUSTAGI_220	16:20	16:30	00:10	TRANSFORMER FAULT
96	10-May-22	GULBARGA	110	HV2	NIRNA_110	17:30	17:35	00:05	TRANSFORMER FAULT
97	10-May-22	GULBARGA	110	HV2	YAKATPUR_110	13:35	13:40	00:05	TRANSFORMER FAULT
98	10-May-22	GULBARGA	110	HV3	KUSTAGI_220	10:00	10:10	00:10	TRANSFORMER FAULT
99	10-May-22	GULBARGA	110	HV3	LADHA_110	12:27	12:58	00:31	LINE CLEAR AVAILED
100	10-May-22	GULBARGA	110	KADAGANCHI-KBSSOLAR_IPP	KADAGANCHI_110	18:45	23:35	04:50	LINE CLEAR AVAILED
101	10-May-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	21:00	21:08	00:08	LINE FAULT
102	10-May-22	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDINNI_110	19:10	19:20	00:10	LINE FAULT
103	10-May-22	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110,A DAVI AMARESHWAR_110	09:45	17:04	07:19	LINE CLEAR AVAILED
104	10-May-22	GULBARGA	110	MUNIRABAD-DONIMALAI_2	STAR METALLIC_IPP, JINDAL PUMP HOUSE,DONIMALAI_110,NMDC FACTORY	17:33	17:46	00:13	LINE FAULT
105	10-May-22	GULBARGA	110	MUNIRABAD-HAGRI	HAGRI_110,SANKLAPUR_110,RB SNS,KAMALAPUR_110	16:50	17:10	00:20	LINE CLEAR AVAILED
106	10-May-22	GULBARGA	110	NALWAR-SHAHAPUR1	NALWAR_110	10:00	15:40	05:40	NFBC ISSUED
107	10-May-22	GULBARGA	110	NALWAR-SHAHAPUR2	NALWAR_110	10:00(09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
108	10-May-22	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	11:20	11:40	00:20	LINE CLEAR AVAILED
109	10-May-22	GULBARGA	110	SEDAM-ULTRATECH_IPP	SEDAM_220	19:17	19:25	00:08	LINE FAULT
110	10-May-22	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	09:55	16:31	06:36	LINE CLEAR AVAILED
111	10-May-22	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	09:55	16:31	06:36	LINE CLEAR AVAILED
112	10-May-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	09:55	16:33	06:38	LINE CLEAR AVAILED
113	10-May-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	09:55	16:33	06:38	LINE CLEAR AVAILED
114	10-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
115	10-May-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	23:07 (10.05.2022)			LINE OPEN:LINE FAULT
116	10-May-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	23:57 (9.05.2022)	00:05 (10.05.2022)	00:08 HRS	LINE CHARGED
117	10-May-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	15:48	16:05	00:17	LINE FAULT
118	10-May-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	23:07 (10.05.2022)			LINE OPEN:LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
119	10-May-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	23:57 (9.05.2022)	00:05 (10.05.2022)	00:08 HRS	LINE CHARGED
120	10-May-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	15:48	16:05	00:17	LINE FAULT
121	10-May-22	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	16:43	16:50	00:07	LINE CLEAR AVAILED
122	10-May-22	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	02:15	02:30	00:15	LINE FAULT
123	10-May-22	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	04:20	04:30	00:10	LINE FAULT
124	10-May-22	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	21:30	21:40	00:10	LINE FAULT
125	10-May-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	17:41	17:52	00:11	LINE FAULT
126	10-May-22	GULBARGA	220	HV1	KAPNOOR_220	11:20	13:46	02:26	LINE CLEAR AVAILED
127	10-May-22	GULBARGA	220	HV1 & HV2	ITTAGI_220	18:10	18:20	00:10	TRANSFORMER FAULT
128	10-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
129	10-May-22	GULBARGA	220	ITTAGI-BMMISPAT	BMMISPAT_220	18:00	19:47	01:47	LINE FAULT
130	10-May-22	GULBARGA	220	KUDLIGI-HIREMALLANAHALLI 1&2	KUDLIGI_220	17:25(08.05.2022)			LINE OPEN:LINE FAULT
131	10-May-22	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	15:50	16:50	01:00	LINE FAULT
132	10-May-22	GULBARGA	220	RAICHUR-JURALA_1_IPP	RAICHUR_220	10:58	15:05	04:07	LINE CLEAR AVAILED
133	10-May-22	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	10:23	16:23	06:00	LINE FAULT
134	10-May-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN:LINE FAULT
135	10-May-22	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	11:30	12:35	01:05	LINE CLEAR AVAILED
136	10-May-22	HASSAN	66	HV1	RAMESHWARNAGAR_66	09:30	10:30	01:00	TRANSFORMER FAULT
137	10-May-22	HASSAN	66	HV1	RAMESHWARNAGAR_66	15:20	15:32	00:12	TRANSFORMER FAULT
138	10-May-22	HASSAN	66	HV2	SAKALESHPURA_66	10:15	16:45	06:30	LINE CLEAR AVAILED
139	10-May-22	HASSAN	66	HV4	BALEHONNUR_66	12:06	12:26	00:20	HAND TRIPPED
140	10-May-22	HASSAN	66	LV1	MRSMSG_220	14:12	14:23	00:11	TRANSFORMER FAULT
141	10-May-22	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	14:14	14:24	00:10	HAND TRIPPED
142	10-May-22	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	14:14	14:25	00:11	HAND TRIPPED
143	10-May-22	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	14:12	14:23	00:11	LINE FAULT
144	10-May-22	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	14:12	14:23	00:11	LINE FAULT
145	10-May-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
146	10-May-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	9:54 (9.05.2022)			LINE OPEN:LINE CLEAR AVAILED
147	10-May-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	13:00 (10.05.2022)			LINE OPEN:LINE CLEAR AVAILED
148	10-May-22	HASSAN	110	ARSK2-ARSKR	ARSIKERE_220	12:05	16:18	04:13	LINE CLEAR AVAILED
149	10-May-22	HASSAN	110	ARSK2-BANAVARA	ARSIKERE_220	12:10	12:13	00:03	HAND TRIPPED
150	10-May-22	HASSAN	110	ARSK2-BANAVARA	ARSIKERE_220	16:10	16:18	00:08	HAND TRIPPED
151	10-May-22	HASSAN	110	BARANG-SHR220	BARANGI_110	15:10	15:30	00:20	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
152	10-May-22	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	12:26	13:48	01:22	LINE CLEAR AVAILED
153	10-May-22	HASSAN	110	HV1	GANDASI_66	10:20	17:00	06:40	LINE CLEAR AVAILED
154	10-May-22	HASSAN	110	HV1	KADUR_220	11:15	11:50	00:35	TRANSFORMER FAULT
155	10-May-22	HASSAN	110	HV2	GANDASI_66	10:20	17:00	06:40	LINE CLEAR AVAILED
156	10-May-22	HASSAN	110	HV3	BADRAVATHI_110	12:00	16:25	04:25	LINE CLEAR AVAILED
157	10-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
158	10-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
159	10-May-22	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	12:04	12:30	00:26	LINE FAULT
160	10-May-22	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	12:30	17:30	05:00	LINE CLEAR AVAILED
161	10-May-22	HASSAN	110	LV3	MRSMG_220	14:12	14:21	00:09	TRANSFORMER FAULT
162	10-May-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	09:04	16:20	07:16	LINE CLEAR AVAILED
163	10-May-22	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	09:04	16:20	07:16	LINE CLEAR AVAILED
164	10-May-22	HASSAN	110	MRSSHM-BADRAVATY2	MRSMG_220	19:22	22:26	03:04	LINE FAULT
165	10-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
166	10-May-22	HASSAN	220	HV3	MRSMG_220	14:12	14:21	00:09	TRANSFORMER FAULT
167	10-May-22	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	10:35	13:58	03:23	NFBC ISSUED
168	10-May-22	HASSAN	220	KEMAR-VARAH12	KEMAR_220	14:05	15:52	01:47	LINE CLEAR AVAILED
169	10-May-22	HASSAN	220	MRSSHM-VARAH13	MRSMG_220	13:08	16:26	03:18	LINE FAULT
170	10-May-22	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	10:35	13:50	03:15	LINE CLEAR AVAILED
171	10-May-22	HASSAN	220	SHRAVITY-TALAGUPPA 2	gen_sharavathy	09:07	11:50	02:43	HAND TRIPPED
172	10-May-22	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	09:07	11:49	02:42	HAND TRIPPED
173	10-May-22	HASSAN	220	VARAH1-KEMAR2	gen_varahi	14:05	15:52	01:47	LINE CLEAR AVAILED
174	10-May-22	HASSAN	220	VARAH1-SHMG3	gen_varahi	13:07	16:26	03:19	LINE FAULT
175	10-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
176	10-May-22	MYSURU	66	BGNAGAR-NAGMAGALA	BG NAGAR_66 ADICHUNCHANGIRI_66 VADERAHALLI_66 KADABALLI_66	05:27	05:44	00:16	LINE FAULT
177	10-May-22	MYSURU	66	CRNAGAR-HONGANUR	HONGANUR_66	19:03	19:26	00:22	LINE FAULT
178	10-May-22	MYSURU	66	DEVNUR(N'GUD)-HV2	DEVNUR(N'GUD)_66	13:28	14:58	01:29	LINE CLEAR AVAILED
179	10-May-22	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
180	10-May-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
181	10-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
182	10-May-22	MYSURU	66	HOOTAGALLYBARC 2	NO STATIONS EFFECTED	23:36	09:51	10:15:00	LINE FAULT
183	10-May-22	MYSURU	66	HOOTAGALLY-BARC 2	NO STATIONS EFFECTED	23:22	23:31	00:09	LINE FAULT
184	10-May-22	MYSURU	66	HOSURGATE-BANNIKUPPE	HOSURGATE_66	11:50	12:20	00:30	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
185	10-May-22	MYSURU	66	HV1	COWDALLI_66	11:15	16:00	04:44	LINE CLEAR AVAILED
186	10-May-22	MYSURU	66	HV1	COWDALLI_66	18:17	18:32	00:15	TRANSFORMER FAULT
187	10-May-22	MYSURU	66	HV1	DEVNUR(N'GUD)_66	15:01	15:55	00:54	LINE CLEAR AVAILED
188	10-May-22	MYSURU	66	HV1	HALAGURU_66	04:31	04:36	00:05	TRANSFORMER FAULT
189	10-May-22	MYSURU	66	HV1	HOSURGATE_66	12:29	14:48	02:18	LINE CLEAR AVAILED
190	10-May-22	MYSURU	66	HV1	JAIPUR_66	11:18	11:59	00:41	LINE CLEAR AVAILED
191	10-May-22	MYSURU	66	HV1	KIADBMANDYA_66,MADDUR_6 6 SOMANAHALLI_66 TUMBEKERE_66	17:32	17:47	00:14	HAND TRIPPED
192	10-May-22	MYSURU	66	HV1	NAGAMANGALA_220	02:58	03:28	00:30	TRANSFORMER FAULT
193	10-May-22	MYSURU	66	HV1	NAGAMANGALA_220	04:00	04:18	00:18	TRANSFORMER FAULT
194	10-May-22	MYSURU	66	HV2	BGNAGAR_66	10:57	16:11	05:13	LINE CLEAR AVAILED
195	10-May-22	MYSURU	66	HV2	COWDALLI_66	15:14	16:07	00:52	LINE CLEAR AVAILED
196	10-May-22	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57:05 (4/5/2022)			LINE OPEN:LINE CLEAR AVAILED
197	10-May-22	MYSURU	66	KM DODDI-MANDYA	KOLKARANADODDI_66	17:31	17:46	00:14	LINE FAULT
198	10-May-22	MYSURU	66	KOLLEGALA-CHNAGARA	NO STATIONS EFFECTED	00:11	00:13	00:01	LINE FAULT
199	10-May-22	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66 YELANDUR_66	19:03	19:11	00:07	LINE FAULT
200	10-May-22	MYSURU	66	MADIKERI-SUNTHIKOPA	SUNTIKOPPA_66	07:15	07:33	00:17	LINE FAULT
201	10-May-22	MYSURU	66	VAJMANGALA-KADKOLA1	AYRAHALLI_66 MARADIHUNDI_66	18:00	18:18	00:18	LINE FAULT
202	10-May-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
203	10-May-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
204	10-May-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	09:55	10:00	00:05	LINE FAULT
205	10-May-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:10	11:10	01:00	LINE FAULT
206	10-May-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	10:30	11:35	01:05	MAIN SUPPLY FAILURE
207	10-May-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	10:55	11:35	00:40	LINE CLEAR AVAILED
208	10-May-22	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE66	NAYAKANHATTI_66, HIREMALLANAHOLE_66	08:50	09:00	00:10	LINE FAULT
209	10-May-22	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE66	NAYAKANHATTI_66, HIREMALLANAHOLE_66	19:05	19:20	00:15	LINE FAULT
210	10-May-22	TUMKUR	66	TR1	HONNALLI_66	16:50	17:00	00:10	MAIN SUPPLY FAILURE
211	10-May-22	TUMKUR	66	TR2	HULIYURDURGA_66	20:12	20:26	00:14	TRANSFORMER FAULT
212	10-May-22	TUMKUR	66	TR3	HOLALKERE_66	09:55	15:00	05:05	TRANSFORMER FAULT
213	10-May-22	TUMKUR	220	ANCHEPALYA 220kV-KUNIGAL66	KUNIGAL	09:06	09:13	00:07	HAND TRIPPED
214	10-May-22	TUMKUR	220	ANCHEPALYA 220kV-NELMANGALA-1	ANCHEPALYA_220	00:00	13:20	13:20	NFBC ISSUED
215	10-May-22	TUMKUR	220	BENKIKERE-HOSADURGA LINE-1	BENKIKERE_220	01:11	01:33	00:22	LINE FAULT
216	10-May-22	TUMKUR	220	BENKIKERE-HOSADURGA LINE-1	BENKIKERE_220	01:37	01:42	00:05	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
217	10-May-22	TUMKUR	220	BENKIKERE-HOSADURGA LINE-1	BENKIKERE_220	01:44	01:49	00:05	LINE FAULT
218	10-May-22	TUMKUR	220	CHITRADURGA 220kV-SUZLON 1 &2	SUZLON2_IPP_66	23:10	23:24	00:14	LINE FAULT
219	10-May-22	TUMKUR	220	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	08:05	08:25	00:20	LINE FAULT
220	10-May-22	TUMKUR	220	HIRIYUR220-BEVINAHALLI66	BEVINAHALLI_66, JAVAGONDANAHALLI_66,DASU DI_66	08:10	08:20	00:10	LINE FAULT
221	10-May-22	TUMKUR	220	HIRIYUR220-BEVINAHALLI66	BEVINAHALLI_66, JAVAGONDANAHALLI_66,DASU DI_66	15:47	15:53	00:06	LINE FAULT
222	10-May-22	TUMKUR	220	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEI DIAMOND SOLAR_IPP_66	18:06	21:46	03:40	LINE CLEAR AVAILED
223	10-May-22	TUMKUR	220	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	18:07	21:47	03:40	LINE CLEAR AVAILED
224	10-May-22	TUMKUR	220	TR1	PAVAGADA_220	03:50	04:10	00:20	TRANSFORMER FAULT
225	10-May-22	TUMKUR	220	TR1-66KV	HIRIYUR_220	12:29	12:30	00:01	TRANSFORMER FAULT
226	10-May-22	TUMKUR	220	TR2	PAVAGADA_220	03:50	04:10	00:20	TRANSFORMER FAULT
227	11-May-22	BAGALKOT	110	110/11KV, HV1	NAVALAGI_110	10:47	10:53	00:06	TRANSFORMER FAULT
228	11-May-22	BAGALKOT	110	110/11KV, HV2	SHIROL_110	06:00	08:00	02:00	LINE CLEAR AVAILED
229	11-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED GIRISAGAR_110	9:40 (05.05.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
230	11-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KUDACHI_110	14:00	14:15	0:15	TRANSFORMER FAULT
231	11-May-22	BAGALKOT	110	110/11KV, HV3	RATTIHALLI_110	08:40	08:43	00:03	TRANSFORMER FAULT
232	11-May-22	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	13:43	13:48	0:05	TRANSFORMER FAULT
233	11-May-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	07:07	7:10	0:03	TRANSFORMER FAULT
234	11-May-22	BAGALKOT	110	110/11KV,HV2	MUKARTHIHAL_110	11:06	11:11	0:05	TRANSFORMER FAULT
235	11-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
236	11-May-22	BAGALKOT	110	AMBEWADI- NK1 (KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	9:30 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
237	11-May-22	BAGALKOT	110	AMBEWADI- NK2 (HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	9:33 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
238	11-May-22	BAGALKOT	110	ANKOLA-KUMATA(L2)	KUMATA_110	10:00	13:49	3:49	LINE CLEAR AVAILED
239	11-May-22	BAGALKOT	110	ATHANI220- AIGALI	STATION NOT AFFECTED ATHANI_220	9:24	09:30	00:06	LINE FAULT
240	11-May-22	BAGALKOT	110	HAVERI220- KNNL	STATION NOT AFFECTED HAVERI_220	14:55	16:16	01:21	LINE CLEAR AVAILED
241	11-May-22	BAGALKOT	110	HAVERI220- SAVANUR	STATION NOT AFFECTED HAVERI_220	15:49	17:19	01:30	LINE CLEAR AVAILED
242	11-May-22	BAGALKOT	110	HAVERI220- TILUVALLI	STATION NOT AFFECTED HAVERI_220	16:15	16:39	00:24	LINE CLEAR AVAILED
243	11-May-22	BAGALKOT	110	ITANAL-HIDIKAL2 (KABBUR)	KABBUR_110	21:55	22:03	0:08	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
244	11-May-22	BAGALKOT	110	KALGHATGI-KAVALWAD-HUBLI	KALAGHATGI_110	18:34	18:39	0:05	HAND TRIPPED
245	11-May-22	BAGALKOT	110	KAMBAGI-TODALBAGI	STATION NOT AFFECTED KAMBAGI_110	13:21	13:37	0:16	HAND TRIPPED
246	11-May-22	BAGALKOT	110	KIADB BIJAPUR-BHUTANAL	BHUTANAL_110	02:36	02:38	0:02	LINE FAULT
247	11-May-22	BAGALKOT	110	KIADB BIJAPUR-BHUTANAL	BHUTANAL_110	13:47	13:52	0:05	LINE FAULT
248	11-May-22	BAGALKOT	110	KIADB BIJAPUR-BHUTANAL	BHUTANAL_110	14:52	14:54	0:02	LINE FAULT
249	11-May-22	BAGALKOT	110	KUMTA-KRCL(RAILWAY)	KRCL(RAILWAY)_110 STATION NOT AFFECTED KUMTA_110	13:59	14:54	0:55	HAND TRIPPED
250	11-May-22	BAGALKOT	110	MUGALKHOD- ITANAL2	STATION NOT AFFECTED MUGALKHOD_220	21:55	22:00	00:05	LINE FAULT
251	11-May-22	BAGALKOT	110	MUNDARGI- VIJAYANAGAR SUGARS	MUNDARGI_110	20:24 (10.05.2022)	19:11 (11.05.2022)	22:47	LINE CHARGED
252	11-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
253	11-May-22	BAGALKOT	110	RANEBENNUR- HIREKERUR	STATION NOT AFFECTED RANEBENNUR_220	23:35	23:42	00:07	LINE FAULT
254	11-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
255	11-May-22	BAGALKOT	110	SIRSI220- SIRSI1	STATION NOT AFFECTED SIRSI_220	12:34	13:35	01:01	LINE CLEAR AVAILED
256	11-May-22	BAGALKOT	110	SIRSI220- SIRSI2	STATION NOT AFFECTED SIRSI_220	13:36	14:04	00:28	LINE CLEAR AVAILED
257	11-May-22	BAGALKOT	110	SIRSI220- UMACHAGI	STATION NOT AFFECTED SIRSI_220	16:13	16:36	00:23	LINE CLEAR AVAILED
258	11-May-22	BAGALKOT	110	SIRSI-HUBLI1(SIRSI1)	STATION NOT AFFECTED SIRSI_110	12:35	13:36	1:01	LINE CLEAR AVAILED
259	11-May-22	BAGALKOT	110	SIRSI-HUBLI1(SIRSI2)	STATION NOT AFFECTED SIRSI_110	13:37	14:04	0:27	LINE CLEAR AVAILED
260	11-May-22	BAGALKOT	110	SIRSI-KUMTA1&2	STATION NOT AFFECTED KUMTA_110	10:07	13:51	3:44	NFBC ISSUED
261	11-May-22	BAGALKOT	110	SOUDATTI220- BENAKATTI	BENAKATTI_110	10:53	11:14	00:21	MAIN SUPPLY FAILURE
262	11-May-22	BAGALKOT	110	SOUDATTI220- BENAKATTI	SOUDATTI_220	10:53	11:14	00:20	LINE FAULT
263	11-May-22	BAGALKOT	110	SOUDATTI220- KATAKOL	KATAKOL_110	10:53	11:17	00:24	MAIN SUPPLY FAILURE
264	11-May-22	BAGALKOT	110	SOUDATTI220- YARAGATTI	YARAGATTI_110	10:53	11:18	00:25	MAIN SUPPLY FAILURE
265	11-May-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED MUGALKHOD_220	13:22	14:16	00:54	LINE CLEAR AVAILED
266	11-May-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED SIRSI_220	15:23	16:00	00:37	LINE CLEAR AVAILED
267	11-May-22	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED BELGAUM_220	10:34 (24.04.2022)	17:10 (11.05.2022)	414:36 hrs	TRANSFORMER CHARGED
268	11-May-22	BAGALKOT	220	220/110KV, HV3	HUBLI_220	17:01	18:10	01:09	LINE CLEAR AVAILED
269	11-May-22	BAGALKOT	220	AMBEWADI- PONDA2	STATION NOT AFFECTED AMBEWADI_220	21:40 (11.05.2022)			LINE OPEN:LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
270	11-May-22	BAGALKOT	220	ATHANI220-KAKMARI-2	STATION NOT AFFECTED ATHANI_220	15:50	16:58	01:08	LINE FAULT
271	11-May-22	BAGALKOT	220	ATHANI220-KAKMARI-2	STATION NOT AFFECTED ATHANI_220	17:20	20:25	03:05	HAND TRIPPED
272	11-May-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	9:18 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
273	11-May-22	BAGALKOT	220	BELGAUM- KANABARGI1 (NARENDRA1)	STATION NOT AFFECTED BELGAUM_220	11:09	13:11	02:10	NFBC ISSUED
274	11-May-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
275	11-May-22	BAGALKOT	220	NARENDRA- BELGAUM1	STATION NOT AFFECTED NARENDRA_220	11:08	13:10	02:02	LINE CLEAR AVAILED
276	11-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVAILED
277	11-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVAILED
278	11-May-22	BAGALKOT	220	VAJRAMATTI- MAHALINGPUR1	STATION NOT AFFECTED VAJRAMATTI_220	10:44	18:38	07:54	LINE CLEAR AVAILED
279	11-May-22	BAGALKOT	220	VAJRAMATTI- MAHALINGPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:45	18:39	07:54	LINE CLEAR AVAILED
280	11-May-22	BENGALURU	66	DABUSPET 220 - AVERAHALLI	AVERAHALLI	15:10	15:35	00:25	MAIN SUPPLY FAILURE
281	11-May-22	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	15:10	15:32	00:22	MAIN SUPPLY FAILURE
282	11-May-22	BENGALURU	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	15:10	15:27	00:17	MAIN SUPPLY FAILURE
283	11-May-22	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	15:10	15:29	00:19	MAIN SUPPLY FAILURE
284	11-May-22	BENGALURU	66	DABUSPET 220 - SK STEEL (EHT)	SK STEEL (EHT)	15:10	15:34	00:24	MAIN SUPPLY FAILURE
285	11-May-22	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	15:10	15:28	00:18	MAIN SUPPLY FAILURE
286	11-May-22	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	11:32	13:05	01:33	LINE CLEAR AVAILED
287	11-May-22	BENGALURU	66	HV1	AMAR JYOTHI	12:19	12:33	00:14	HAND TRIPPED
288	11-May-22	BENGALURU	66	HV1	ANEKAL	11:50	13:57	02:07	LINE CLEAR AVAILED
289	11-May-22	BENGALURU	66	HV1	BIDADI 220	13:05	14:01	00:56	LINE CLEAR AVAILED
290	11-May-22	BENGALURU	66	HV1	DABUSPETE 220	15:10	15:27	00:17	MAIN SUPPLY FAILURE
291	11-May-22	BENGALURU	66	HV1	DODDALAHALLI	20:08	20:34	00:26	TRANSFORMER FAULT
292	11-May-22	BENGALURU	66	HV1	GOLF LINK	10:07	10:10	00:03	LINE CLEAR AVAILED
293	11-May-22	BENGALURU	66	HV1	GOWRIBIDANUR 220	11:35	11:45	00:10	TRANSFORMER FAULT
294	11-May-22	BENGALURU	66	HV1	HOSUR RAMAPURA	12:10	15:07	02:57	LINE CLEAR AVAILED
295	11-May-22	BENGALURU	66	HV1	HUKUNDA	11:53	12:12	00:19	TRANSFORMER FAULT
296	11-May-22	BENGALURU	66	HV1	IISc	12:43	12:48	00:05	LINE CLEAR AVAILED
297	11-May-22	BENGALURU	66	HV1	IISc	16:30	16:34	00:04	HAND TRIPPED
298	11-May-22	BENGALURU	66	HV1	KOTIPURA 220	09:59	10:02	00:03	TRANSFORMER FAULT
299	11-May-22	BENGALURU	66	HV1	NANDINI LAYOUT	11:25	11:30	00:05	TRANSFORMER FAULT
300	11-May-22	BENGALURU	66	HV1	NANDINI LAYOUT	17:16	17:21	00:05	TRANSFORMER FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
301	11-May-22	BENGALURU	66	HV1	SM MANGALA	12:05	12:22	00:17	LINE CLEAR AVAILED
302	11-May-22	BENGALURU	66	HV2	DABUSPETE 220	15:10	15:27	00:17	MAIN SUPPLY FAILURE
303	11-May-22	BENGALURU	66	HV2	DEVARABISANAHALLI	13:09	13:12	00:03	LINE CLEAR AVAILED
304	11-May-22	BENGALURU	66	HV2	GOLF LINK	12:13	12:15	00:02	LINE CLEAR AVAILED
305	11-May-22	BENGALURU	66	HV2	HAL 220	11:51	11:53	00:02	LINE CLEAR AVAILED
306	11-May-22	BENGALURU	66	HV2	MALLASANDRA	13:00	13:39	00:39	LINE CLEAR AVAILED
307	11-May-22	BENGALURU	66	HV2	NELAKADRENAHALLI	15:02	15:15	00:13	TRANSFORMER FAULT
308	11-May-22	BENGALURU	66	HV2	NELAKADRENAHALLI	18:35	18:50	00:15	HAND TRIPPED
309	11-May-22	BENGALURU	66	HV2	TYAMAGONDLU	13:12	13:20	00:07	TRANSFORMER FAULT
310	11-May-22	BENGALURU	66	HV2	YEDUMADU	15:02	15:05	00:02	LINE CLEAR AVAILED
311	11-May-22	BENGALURU	66	ISKON - SOMANAHALLI 220	ISKON	14:15	15:10	00:55	MAIN SUPPLY FAILURE
312	11-May-22	BENGALURU	66	ISKON - SUBRAMANYAPURA 220	ISKON	16:36	16:37	00:01	HAND TRIPPED
313	11-May-22	BENGALURU	66	JAKKASANDRA - ADUGODI	JAKKASANDRA	19:18	19:26	00:08	LINE FAULT
314	11-May-22	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	NO STATION AFFECTED	19:18	19:26	00:08	LINE FAULT
315	11-May-22	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	20:43	20:48	00:05	LINE CLEAR AVAILED
316	11-May-22	BENGALURU	66	TELECOM LAYOUT - NRS 2 220	TELECOM LAYOUT	11:38	11:41	00:03	HAND TRIPPED
317	11-May-22	BENGALURU	220	HV1	DABUSPETE 220	15:10	15:26	00:16	TRANSFORMER FAULT
318	11-May-22	BENGALURU	220	HV2	DABUSPETE 220	15:10	15:26	00:16	TRANSFORMER FAULT
319	11-May-22	BENGALURU	220	LV1	DABUSPETE 220	15:10	15:26	00:16	MAIN SUPPLY FAILURE
320	11-May-22	BENGALURU	220	LV2	DABUSPETE 220	15:10	15:30	00:20	MAIN SUPPLY FAILURE
321	11-May-22	BENGALURU	220	MAGADI 220 - ANCHEPALYA 220	NO STATION AFFECTED	14:52	16:37	01:45	LINE CLEAR AVAILED
322	11-May-22	BENGALURU	220	MAGADI 220 - NELAMANGALA 400	NO STATION AFFECTED	12:04	14:30	02:26	LINE CLEAR AVAILED
323	11-May-22	GULBARGA	66	HV1	KUDLIGI_220	09:15	09:25	00:10	TRANSFORMER FAULT
324	11-May-22	GULBARGA	66	HV1	TELAGI_66	14:10	14:25	00:15	LINE CLEAR AVAILED
325	11-May-22	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP	05:58	06:34	00:36	LINE FAULT
326	11-May-22	GULBARGA	66	ITTAGI-KUDLIGI_2	CHORNOOR_66,BANVIKAL_66,KUDLIGI_220	18:00 (10.05.2022)	7:28 (11.05.2022)	13:28 HRS	LINE CHARGED
327	11-May-22	GULBARGA	66	ITTAGI-KUDLIGI_2	CHORNOOR_66,BANVIKAL_66,KUDLIGI_220	07:42	08:00	00:18	LINE CLEAR AVAILED
328	11-May-22	GULBARGA	66	KUDLIGI_220-KUDLIGI_66	KUDLIGI_220,KUDLIGI_66,HANSI_66,CHORNOOR_66,BANVIKAL_66	07:05	08:05	01:00	LINE CLEAR AVAILED
329	11-May-22	GULBARGA	66	KUDLIGI220 -BENAVEKAL	BENAVEKAL_66	10:15	13:50	03:35	LINE CLEAR AVAILED
330	11-May-22	GULBARGA	66	NEELAGUNDA-HALAVAGALU	HALAVAGALU_66	14:49	14:59	00:10	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
331	11-May-22	GULBARGA	110	ALLIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANA KI_IPP,BASAI STEELS_IPP	20:13	20:23	00:10	LINE FAULT
332	11-May-22	GULBARGA	110	DEODURGA-SHAHPUR	DEODURGA_110	12:20	12:25	00:05	MAIN SUPPLY FAILURE
333	11-May-22	GULBARGA	110	DEODURGA-SHAHPUR	DEODURGA_110	12:25	13:00	00:35	MAIN SUPPLY FAILURE
334	11-May-22	GULBARGA	110	DEODURGA-SHAHPUR	DEODURGA_110	13:05	14:10	01:05	MAIN SUPPLY FAILURE
335	11-May-22	GULBARGA	110	GURUMITKAL-GAMESHAWIND_IPP	GURUMITKAL_110	09:50	14:00	04:10	LINE CLEAR AVAILED
336	11-May-22	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	17:05	19:45	02:40	NFBC ISSUED
337	11-May-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADGANCHI_110	16:42	17:27	00:45	LINE FAULT
338	11-May-22	GULBARGA	110	HV1	MATAMARI_110	11:20(08.05.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
339	11-May-22	GULBARGA	110	HV2	CHOWDAPUR_110	10:43	10:48	00:05	TRANSFORMER FAULT
340	11-May-22	GULBARGA	110	HV3	HATTI_110	15:44	15:51	00:07	TRANSFORMER FAULT
341	11-May-22	GULBARGA	110	MUNIRABAD-HAGRI	HAGRI_110,SANKLAPUR_110,RB SNS,KAMALAPUR_110	17:35	17:54	00:19	LINE FAULT
342	11-May-22	GULBARGA	110	NALWAR-SHAHPUR2	NALWAR_110	10:00(09.05.2022)	16:20(11.05.2022)	54:20HRS	LINE CHARGED
343	11-May-22	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110	05:54	06:25	00:31	LINE CLEAR AVAILED
344	11-May-22	GULBARGA	110	RAICHUR-SHAHPUR1&2	GABBUR_110,GOOGLE_110	00:02	00:10	00:08	HAND TRIPPED
345	11-May-22	GULBARGA	110	RAICHUR-SHAHPUR1&2	GABBUR_110,GOOGLE_110	14:06	14:11	00:05	LINE CLEAR AVAILED
346	11-May-22	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	05:54	05:59	00:05	HAND TRIPPED
347	11-May-22	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	06:05	06:25	00:20	LINE CLEAR AVAILED
348	11-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110 ,WADAGERA_110,SANNATHI_IP P,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
349	11-May-22	GULBARGA	110	SHAHAPUR-RAICHUR,2	DEODURGA_110	12:21	12:55	00:34	LINE FAULT
350	11-May-22	GULBARGA	110	SHAHAPUR-RAICHUR,2	DEODURGA_110	13:02	16:35	03:33	LINE CLEAR AVAILED
351	11-May-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	12:21(11.05.2022)			LINE OPEN:LINE FAULT
352	11-May-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	23:07 (10.05.2022)	6:12 (11.05.2022)	7:05 HRS	LINE CHARGED
353	11-May-22	GULBARGA	110	SHAHAPUR-RAICHUR1,2	DEODURGA_110	20:11(11.05.2022)			LINE OPEN:LINE CLEAR AVAILED
354	11-May-22	GULBARGA	110	SHAHAPUR-RAICHUR1,2	DEODURGA_110	12:16	12:21	00:05	LINE FAULT
355	11-May-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	23:07 (10.05.2022)	6:12 (11.05.2022)	7:05 HRS	LINE CHARGED
356	11-May-22	GULBARGA	220	HV1,LV1	KAPNOOR_220	16:20	22:37	06:17	LINE CLEAR AVAILED
357	11-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
358	11-May-22	GULBARGA	220	KUDLIGI-HIREMALLANAHALLI 1&2	KUDLIGI_220	17:25(08.05.2022)			LINE OPEN:LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
359	11-May-22	GULBARGA	220	LINGAPUR-GANGAVATHI1	LINGAPUR_220	08:16	15:13	06:57	LINE CLEAR AVAILED
360	11-May-22	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	09:16	13:05	03:49	LINE CLEAR AVAILED
361	11-May-22	GULBARGA	220	SEDAM-TANDUR	TANDUR_220	08:20	13:30	05:10	LINE CLEAR AVAILED
362	11-May-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN:LINE FAULT
363	11-May-22	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	04:30	05:00	00:30	MAIN SUPPLY FAILURE
364	11-May-22	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	05:05	05:20	00:15	MAIN SUPPLY FAILURE
365	11-May-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	04:30	05:00	00:30	MAIN SUPPLY FAILURE
366	11-May-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	05:05	06:15	01:10	LINE FAULT
367	11-May-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:20	11:00	00:40	LINE FAULT
368	11-May-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	12:35	13:35	01:00	LINE CLEAR AVAILED
369	11-May-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	13:50	14:05	00:15	LINE FAULT
370	11-May-22	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	04:30	05:00	00:30	MAIN SUPPLY FAILURE
371	11-May-22	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	05:05	05:20	00:15	MAIN SUPPLY FAILURE
372	11-May-22	HASSAN	66	HV1	DUDDA_66	22:40	22:50	00:10	TRANSFORMER FAULT
373	11-May-22	HASSAN	66	HV1	MOSALEHOSAHALLI_66	11:35	11:45	00:10	HAND TRIPPED
374	11-May-22	HASSAN	66	HV2	CHANNARAYAPATNA_66	11:45	13:35	01:50	LINE CLEAR AVAILED
375	11-May-22	HASSAN	66	HV2	SAKALESH PURA_66	09:05	17:45	08:40	LINE CLEAR AVAILED
376	11-May-22	HASSAN	66	KANDLI-SAKLESH PUR	KANDLI_66	12:35	13:45	01:10	LINE CLEAR AVAILED
377	11-May-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATH PURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
378	11-May-22	HASSAN	66	SAKALE-HASSAN	SAKALESH PURA_66	12:35	13:45	01:10	NFBC ISSUED
379	11-May-22	HASSAN	66	SAKALE-IPCL1	SAKALESH PURA_66	9:54 (9.05.2022)			LINE OPEN:LINE CLEAR AVAILED
380	11-May-22	HASSAN	66	SAKALE-IPCL2	SAKALESH PURA_66	13:00 (10.05.2022)			LINE OPEN:LINE CLEAR AVAILED
381	11-May-22	HASSAN	110	GURUPUR-MDBDRE	GURUPURA_110	11:49	12:05	00:16	HAND TRIPPED
382	11-May-22	HASSAN	110	HV1	BIRUR_110	03:00	03:05	00:05	TRANSFORMER FAULT
383	11-May-22	HASSAN	110	HV1	KEMAR_220	10:28	11:11	00:43	LINE CLEAR AVAILED
384	11-May-22	HASSAN	110	HV1	MADHUVANA_110	12:56	17:58	05:02	LINE CLEAR AVAILED
385	11-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
386	11-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
387	11-May-22	HASSAN	110	KADUR-AJAMPURA	KADUR_220	16:56	18:43	01:47	HAND TRIPPED
388	11-May-22	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:16	13:04	02:48	LINE CLEAR AVAILED
389	11-May-22	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	15:13	15:20	00:07	LINE FAULT
390	11-May-22	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	15:20	17:37	02:17	NFBC ISSUED
391	11-May-22	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	18:55	22:41	03:46	LINE CLEAR AVAILED
392	11-May-22	HASSAN	110	LV1	PUTTUR_220	09:15	10:42	01:27	LINE CLEAR AVAILED
393	11-May-22	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	11:49	12:05	00:16	LINE CLEAR AVAILED
394	11-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
395	11-May-22	HASSAN	220	MRSSH-M-VARAH1	MRSMSG_220	13:08	18:27	05:19	LINE FAULT
396	11-May-22	HASSAN	220	VARAH-SHIMOGA1	gen_varahi	13:08	18:27	05:19	LINE FAULT
397	11-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
398	11-May-22	MYSURU	66	BANNIMANTAP-FTS	BANNIMANTAP_66	16:27	16:40	00:13	LINE CLEAR AVAILED
399	11-May-22	MYSURU	66	BANNIMANTAP- VIJAYNAGAR	BANNIMANTAP_66	16:27	16:40	00:13	LINE CLEAR AVAILED
400	11-May-22	MYSURU	66	DODDARAYAPETE- KUNTHUR	SANTHEMARAHALLI_66 JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66	18:43	18:47	00:04	LINE FAULT
401	11-May-22	MYSURU	66	DUNDANAHALLY- HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
402	11-May-22	MYSURU	66	HAMPAPURA(K)-KADAKOLA	HAMPAPURA(K)_66	01:30	02:10	00:40	LINE FAULT
403	11-May-22	MYSURU	66	HAMPAPURA(K)-KADAKOLA	HAMPAPURA(K)_66	03:00	03:15	00:15	LINE FAULT
404	11-May-22	MYSURU	66	HAMPAPURA(K)-KADAKOLA	HAMPAPURA(K)_66	04:35	04:45	00:10	LINE FAULT
405	11-May-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
406	11-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
407	11-May-22	MYSURU	66	HOOTAGALLI-BARC 2	NO STATIONS EFFECTED	20:20	20:27	00:07	LINE FAULT
408	11-May-22	MYSURU	66	HOOTAGALLI-BARC1	NO STATIONS EFFECTED	11:23	13:45	02:22	LINE CLEAR AVAILED
409	11-May-22	MYSURU	66	HV1	BANNIMANTAP_66	16:25	16:41	00:16	LINE CLEAR AVAILED
410	11-May-22	MYSURU	66	HV1	COWDALLI_66	08:12	09:00	00:48	LINE CLEAR AVAILED
411	11-May-22	MYSURU	66	HV2	BANNIMANTAP_66	16:26	16:42	00:16	LINE CLEAR AVAILED
412	11-May-22	MYSURU	66	HV2	BESAGARAHALLI_66	10:15	10:20	00:05	TRANSFORMER FAULT
413	11-May-22	MYSURU	66	HV2	DATTAGALLY_66	16:37	20:22	03:44	TRANSFORMER FAULT
414	11-May-22	MYSURU	66	HV2	THANDYA_66	13:25	13:31	00:06	TRANSFORMER FAULT
415	11-May-22	MYSURU	66	HV2	TUBINAKERE_220	12:30	12:42	00:12	TRANSFORMER FAULT
416	11-May-22	MYSURU	66	HV3	TUBINAKERE_220	12:30	12:35	00:05	TRANSFORMER FAULT
417	11-May-22	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57:05 (4/5/2022)			LINE OPEN:LINE CLEAR AVAILED
418	11-May-22	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66 SOMANAHALLI KIADB_66	16:13	17:42	01:29	LINE FAULT
419	11-May-22	MYSURU	66	KUNTHUR-BANNARIIPP	NO STATIONS EFFECTED	18:43	18:49	00:06	LINE FAULT
420	11-May-22	MYSURU	66	KUNTHUR- DODDARAYAPETE	SANTHEMARAHALLI_66 JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66	18:43	18:47	00:04	LINE FAULT
421	11-May-22	MYSURU	66	KUSHALANAGARA- MADIKERI	MADIKERI_66	10:36	12:10	01:34	LINE CLEAR AVAILED
422	11-May-22	MYSURU	66	MADDUR-K.HONALGERE	NO STATIONS EFFECTED	17:42	17:59	00:17	HAND TRIPPED
423	11-May-22	MYSURU	66	MADDUR-KIADB MANDYA	MADDUR_66 SOMANAHALLI KIADB_66	16:36	17:42	01:05	NFBC ISSUED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
424	11-May-22	MYSURU	66	MADHUVANAHALLY-KOLLEGALA	NO STATIONS EFFECTED	08:19	08:26	00:07	LINE FAULT
425	11-May-22	MYSURU	66	MADIKERI-KUSHALANAGARA	MADIKERI_66	10:30	12:15	01:45	LINE CLEAR AVAILED
426	11-May-22	MYSURU	66	MADIKERI-SUNTHIKOPA	MADIKERI_66	10:30	12:16	01:46	LINE CLEAR AVAILED
427	11-May-22	MYSURU	66	MALLAVALLI-TKHALLI	MALAVALLI_66	15:19	17:11	01:52	LINE FAULT
428	11-May-22	MYSURU	66	NAGAMANGALA-NAGAMANGALA 220	NAGAMANGALA_66	11:52	12:20	00:27	LINE CLEAR AVAILED
429	11-May-22	MYSURU	66	NAGAMANGALA-TUBINAKERE	NAGAMANGALA_66	11:52	12:20	00:27	LINE CLEAR AVAILED
430	11-May-22	MYSURU	66	SFCSIVA-PGL	NO STATIONS EFFECTED	12:06	12:46	00:39	HAND TRIPPED
431	11-May-22	MYSURU	66	SUNTIKOPPA-MADIKERI	NO STATIONS EFFECTED	10:25	12:44	02:19	LINE CLEAR AVAILED
432	11-May-22	MYSURU	66	TARIPUR-MHS	NO STATIONS EFFECTED	11:38	12:03	00:25	LINE CLEAR AVAILED
433	11-May-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
434	11-May-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
435	11-May-22	MYSURU	220	VAJAMANGALA-T K HALLI	NO STATIONS EFFECTED	14:45	15:19	00:34	LINE FAULT
436	11-May-22	TUMKUR	66	CHANNAGIRI-HONNALLI220	CHANNAGIRI_66	15:34	15:39	00:05	MAIN SUPPLY FAILURE
437	11-May-22	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	13:20	14:27	01:07	LINE FAULT
438	11-May-22	TUMKUR	66	SIRA66-BUKKAPATNA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	12:00	13:45	01:45	MAIN SUPPLY FAILURE
439	11-May-22	TUMKUR	66	TR1	BUKKAPATNA_66	14:00	15:00	01:00	LINE CLEAR AVAILED
440	11-May-22	TUMKUR	66	TR1	JAVAGONDANAHALLI_66	15:50	16:40	00:50	LINE CLEAR AVAILED
441	11-May-22	TUMKUR	66	TR1	KEREBILACHI_66	19:40	19:45	00:05	TRANSFORMER FAULT
442	11-May-22	TUMKUR	66	TR2	BUKKAPATNA_66	14:35	15:00	00:25	LINE CLEAR AVAILED
443	11-May-22	TUMKUR	66	TR2	KORATAGERE_66	10:00	10:50	00:50	TRANSFORMER FAULT
444	11-May-22	TUMKUR	220	ANCHEPALYA 220kV-MAGADI_220	ANCHEPALYA_220	14:52	16:35	01:43	NFBC ISSUED
445	11-May-22	TUMKUR	220	BENKIKERE_220-GOPPENAHALLI_66	BENKIKERE_220	12:09	12:22	00:13	LINE FAULT
446	11-May-22	TUMKUR	220	BENKIKERE-HOSADURGA LINE-1	HOSADURGA_220	05:20	23:59	18:40	LINE FAULT
447	11-May-22	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	14:46	19:05	04:19	LINE FAULT
448	11-May-22	TUMKUR	220	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	00:06	00:15	00:09	LINE FAULT
449	11-May-22	TUMKUR	220	HIRIYUR_220-PR PURA	HIRIYUR_220	07:58	08:16	00:18	LINE FAULT
450	11-May-22	TUMKUR	220	HIRIYUR_220-PR PURA	HIRIYUR_220	08:16	23:59	15:44	LINE FAULT
451	11-May-22	TUMKUR	220	HIRIYUR_220-THALLAK	HIRIYUR_220	15:00	15:43	00:43	LINE FAULT
452	11-May-22	TUMKUR	220	HONNALLI 220kV-BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	14:42	14:53	00:11	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
453	11-May-22	TUMKUR	220	HONNALLI 220kV- KUNDUR66	KUNDUR,_66,MALEBENNUR_66 ,DEVARABELKERE_66	15:45	15:54	00:09	LINE FAULT
454	11-May-22	TUMKUR	220	PAVAGADA220- NAGALAMADIKE66	PAVAGADA_220	00:00	15:05	15:05	LINE FAULT
455	11-May-22	TUMKUR	220	PAVAGADA220- SHYLAPURA_66	SHYLAPURA_66	06:45	06:50	00:05	LINE FAULT
456	11-May-22	TUMKUR	220	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEI DIAMOND SOLAR_IPP_66	18:10	20:01	01:51	LINE CLEAR AVAILED
457	11-May-22	TUMKUR	220	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	18:09	20:00	01:51	LINE CLEAR AVAILED
458	11-May-22	TUMKUR	220	TR1	DAVANGERE_SRS_220	14:46	16:05	01:19	TRANSFORMER FAULT
459	11-May-22	TUMKUR	220	TR1	HOSADURGA_220	05:20	07:30	02:10	TRANSFORMER FAULT
460	11-May-22	TUMKUR	220	TR2	HOSADURGA_220	05:20	07:36	02:16	TRANSFORMER FAULT
461	11-May-22	TUMKUR	220	TR2	SIRA_220	12:02	12:47	00:45	LINE CLEAR AVAILED
462	11-May-22	TUMKUR	220	TR3	DAVANGERE_SRS_220	14:46	15:59	01:13	TRANSFORMER FAULT
463	11-May-22	TUMKUR	220	TR3	HIRIYUR_220	15:00	15:35	00:35	TRANSFORMER FAULT
464	11-May-22	TUMKUR	400	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	14:47	19:10	04:23	LINE FAULT
465	11-May-22	TUMKUR	400	TR2	GUTTURU-400	22:45	23:59	01:15	TRANSFORMER FAULT
466	12-May-22	BENGALURU	66	BOODIGERE - BIAL BEGUR 220	BOODIGERE	12:58	13:24	00:26	LINE FAULT
467	12-May-22	BENGALURU	66	ELITA PROMENENDE - KHODAYS 220	ELITA PROMENENDE	16:35	16:52	00:17	MAIN SUPPLY FAILURE
468	12-May-22	BENGALURU	66	HV1	KADUBISANAHALLI	10:53	10:56	00:03	LINE CLEAR AVAILED
469	12-May-22	BENGALURU	66	HV2	KADUBISANAHALLI	12:50	12:52	00:02	LINE CLEAR AVAILED
470	12-May-22	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	16:35	17:03	00:28	LINE FAULT
471	12-May-22	BENGALURU	220	MYLSANDRA 400 - SOMANAHALLI 2 220	NO STATION AFFECTED	14:20	15:40	01:20	LINE FAULT
472	12-May-22	BENGALURU	66	HV1	NANDINI LAYOUT	14:23	14:26	00:03	HAND TRIPPED
473	12-May-22	BENGALURU	66	HV1	NIMHANS 220	03:03	03:30	00:27	TRANSFORMER FAULT
474	12-May-22	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	15:20	15:24	00:04	HAND TRIPPED
475	12-May-22	BENGALURU	220	SOMANAHALLI 220 - MYLSANDRA 2 400	NO STATION AFFECTED	14:20	17:16	02:56	LINE FAULT
476	12-May-22	BENGALURU	66	VR DODDI - ORCHID LAMINATE 2	VR DODDI, GURUVINAPURA, BV HALLI, KENCHANAHALLI, AO SMITH	12:50	13:20	00:30	LINE FAULT
477	12-May-22	BENGALURU	66	HV3	YARANDANAHALLI 220	03:21	03:27	00:06	TRANSFORMER FAULT
478	12-May-22	BENGALURU	66	HV3	YARANDANAHALLI 220	04:01	04:07	00:06	TRANSFORMER FAULT
479	12-May-22	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	CHANDRAPPA CIRCLE	08:55	10:52	01:57	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
480	12-May-22	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU CROSS, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	18:38	18:49	00:11	LINE FAULT
481	12-May-22	BENGALURU	66	HV1	DALASNUR	14:37	15:00	00:23	LINE CLEAR AVAILED
482	12-May-22	BENGALURU	66	HOSKOTE 220 - BIAL BEGUR	NO STATION AFFECTED	09:14	09:26	00:12	LINE FAULT
483	12-May-22	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	10:45	12:48	02:03	LINE CLEAR AVAILED
484	12-May-22	BENGALURU	66	HV2	VOLVO	15:05	15:08	00:03	LINE CLEAR AVAILED
485	12-May-22	BENGALURU	66	HV1	DASHAVARA	11:10	11:15	00:05	TRANSFORMER FAULT
486	13-May-22	BENGALURU	220	A STATION 220 - NRS 220	A STATION 220	11:33	11:46	00:13	MAIN SUPPLY FAILURE
487	13-May-22	BENGALURU	66	A STATION 220 - A STATION 2 66	A STATION 66	11:33	11:46	00:13	MAIN SUPPLY FAILURE
488	13-May-22	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	11:33	11:52	00:19	MAIN SUPPLY FAILURE
489	13-May-22	BENGALURU	66	HV2	HSR LAYOUT 220	11:25	11:27	00:02	LINE CLEAR AVAILED
490	13-May-22	BENGALURU	66	JAKKASANDRA - ADUGODI	JAKKASANDRA	03:56	04:06	00:10	LINE FAULT
491	13-May-22	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	03:56	04:06	00:10	LINE FAULT
492	13-May-22	BENGALURU	66	HV1	KADUGODI	15:10	15:15	00:05	TRANSFORMER FAULT
493	13-May-22	BENGALURU	66	KADUGODI - ARMY WELFARE ORGANISATION	ARMY WELFARE ORGANISATION	14:00	14:22	00:22	LINE FAULT
494	13-May-22	BENGALURU	220	NRS 220 - SRS PEENYA 220	NRS 220	11:30	12:15	00:45	LINE FAULT
495	13-May-22	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	11:30	12:18	00:48	MAIN SUPPLY FAILURE
496	13-May-22	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	NO STATION AFFECTED	11:30	12:18	00:48	MAIN SUPPLY FAILURE
497	13-May-22	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	11:30	12:20	00:50	MAIN SUPPLY FAILURE
498	13-May-22	BENGALURU	66	HV1	NRS 220	11:30	12:25	00:55	MAIN SUPPLY FAILURE
499	13-May-22	BENGALURU	66	HV2	NRS 220	11:30	12:25	00:55	MAIN SUPPLY FAILURE
500	13-May-22	BENGALURU	66	HV3	NRS 220	11:30	12:25	00:55	MAIN SUPPLY FAILURE
501	13-May-22	BENGALURU	66	HV4	NRS 220	11:30	12:25	00:55	MAIN SUPPLY FAILURE
502	13-May-22	BENGALURU	66	HV5	NRS 220	11:30	12:25	00:55	MAIN SUPPLY FAILURE
503	13-May-22	BENGALURU	66	HV2	VIJAYANAGARA	11:30	12:20	00:50	MAIN SUPPLY FAILURE
504	13-May-22	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD, KIRLOSKAR(EHT)	04:14	04:37	00:23	LINE FAULT
505	13-May-22	BENGALURU	66	TADIGOLU CROSS - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	00:30	00:45	00:15	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
506	13-May-22	BENGALURU	66	TADIGOLU CROSS - CHINTAMANI 220	TADIGOLU CROSS	00:30	00:43	00:13	LINE FAULT
507	13-May-22	BENGALURU	66	HV2	YEDUMADU	08:15	08:21	00:06	TRANSFORMER FAULT
508	13-May-22	BENGALURU	66	HV2	TYAMAGONDLU	10:08	10:20	00:11	TRANSFORMER FAULT
509	13-May-22	BENGALURU	66	HV2	TYAMAGONDLU	00:55	01:05	00:10	TRANSFORMER FAULT
510	13-May-22	BENGALURU	66	HV2	TYAMAGONDLU	10:53	11:03	00:10	TRANSFORMER FAULT
511	13-May-22	BENGALURU	66	HV1	MITTEMARI 220	14:00	14:05	00:05	LINE CLEAR AVAILED
512	13-May-22	BENGALURU	66	ARMY WELFARE ORGANISATION - KONDASPURA	ARMY WELFARE ORGANISATION	16:03	16:10	00:07	HAND TRIPPED
513	13-May-22	BENGALURU	66	HV2	NELAMANGALA 66	16:42	16:48	00:05	TRANSFORMER FAULT
514	14-May-22	BENGALURU	66	EXORA - CESSNA	EXORA	14:00	14:11	00:11	MAIN SUPPLY FAILURE
515	14-May-22	BENGALURU	66	EXORA - CESSNA	EXORA	15:25	15:35	00:10	MAIN SUPPLY FAILURE
516	14-May-22	BENGALURU	66	C STATION 1 & 2 - HEBBALA 220	C STATION 1 & 2	09:30	09:38	00:08	HAND TRIPPED
517	14-May-22	BENGALURU	66	C STATION 1 & 2 - A STATION 220	C STATION 1 & 2	16:29	16:33	00:04	HAND TRIPPED
518	14-May-22	BENGALURU	66	HENNUR CROSS - HBR LAYOUT 220	HENNUR CROSS	08:55	08:58	00:03	HAND TRIPPED
519	14-May-22	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	15:03	15:06	00:03	HAND TRIPPED
520	14-May-22	BENGALURU	66	CESSNA - VIKAS TECH PARK 220	CESSNA	14:00	14:05	00:05	MAIN SUPPLY FAILURE
521	14-May-22	BENGALURU	66	CESSNA - KADUBISANAHALLI	CESSNA	15:25	15:30	00:05	HAND TRIPPED
522	14-May-22	BENGALURU	66	IISc - HEBBALA 220	IISc	10:07	10:12	00:05	HAND TRIPPED
523	14-May-22	BENGALURU	66	IISc - NRS 220	IISc	16:23	16:29	00:06	HAND TRIPPED
524	14-May-22	BENGALURU	66	HV1	KHODAYS 220	09:19	09:30	00:11	TRANSFORMER FAULT
525	14-May-22	BENGALURU	66	HV2	KUMBALAGODU	23:25	23:27	00:02	LINE CLEAR AVAILED
526	14-May-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	14:00	14:08	00:08	MAIN SUPPLY FAILURE
527	14-May-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	15:15	15:29	00:14	MAIN SUPPLY FAILURE
528	14-May-22	BENGALURU	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT), VR DODDI, GURUVINAPURA	10:20	10:40	00:20	LINE FAULT
529	14-May-22	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	15:05	15:45	00:40	LINE FAULT
530	14-May-22	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	14:00	15:25	01:25	MAIN SUPPLY FAILURE
531	14-May-22	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	14:00	15:25	01:25	MAIN SUPPLY FAILURE
532	14-May-22	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	14:00	15:25	01:25	MAIN SUPPLY FAILURE
533	14-May-22	BENGALURU	66	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	11:48	12:01	00:13	LINE FAULT
534	14-May-22	BENGALURU	66	T G HALLI - BYDARAHALLI	TAVAREKERE	17:33	17:34	00:01	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
535	14-May-22	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	14:00	14:54	00:54	LINE CLEAR AVAILED
536	14-May-22	BENGALURU	220	MALUR 220 - HOODY 220	SARJAPURA 220, VIKAS TECH PARK 220	14:00	14:56	00:56	LINE CLEAR AVAILED
537	14-May-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1	SARJAPURA 220, VIKAS TECH PARK 220	14:00	15:07	01:07	LINE CLEAR AVAILED
538	14-May-22	BENGALURU	220	MALUR 220 - KOLAR 3	NO STATION AFFECTED	14:00	15:14	01:14	LINE CLEAR AVAILED
539	14-May-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	14:00	15:02	01:02	LINE CLEAR AVAILED
540	14-May-22	BENGALURU	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	14:00	15:02	01:02	LINE CLEAR AVAILED
541	14-May-22	BENGALURU	66	MALUR 220 - KGF 2	BANGARPETE	14:00	14:15	00:15	LINE CLEAR AVAILED
542	14-May-22	BENGALURU	66	BANGARPETE - KOLAR 220	BANGARPETE	15:20	15:25	00:05	HAND TRIPPED
543	14-May-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	14:00	15:11	01:11	LINE CLEAR AVAILED
544	14-May-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	14:00	14:32	00:32	LINE CLEAR AVAILED
545	14-May-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	14:00	15:02	01:02	LINE CLEAR AVAILED
546	14-May-22	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	14:00	15:02	01:02	LINE CLEAR AVAILED
547	14-May-22	BENGALURU	66	MALUR 220 - KGF 2	BANGARPETE	20:43	20:58	00:15	LINE FAULT
548	14-May-22	BENGALURU	66	MALUR 220 - KGF 2	BANGARPETE	22:31	23:33	01:02	LINE FAULT
549	14-May-22	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	01:45	02:00	00:15	LINE FAULT
550	14-May-22	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPETE	23:21	23:28	00:06	HAND TRIPPED
551	14-May-22	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	02:18	02:26	00:08	LINE FAULT
552	14-May-22	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	14:00	14:03	00:03	MAIN SUPPLY FAILURE
553	14-May-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:00	14:11	00:11	MAIN SUPPLY FAILURE
554	14-May-22	BENGALURU	66	HV2	ATTIBELE	14:00	14:20	00:20	MAIN SUPPLY FAILURE
555	14-May-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	15:09	15:38	00:29	HAND TRIPPED
556	14-May-22	BENGALURU	66	KONDASPURA - HBR LAYOUT 220	KONDASPURA	09:08	09:13	00:05	HAND TRIPPED
557	14-May-22	BENGALURU	66	KONDASPURA - EPIP 220	KONDASPURA	14:38	14:43	00:05	HAND TRIPPED
558	14-May-22	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	17:30	17:34	00:04	HAND TRIPPED
559	14-May-22	BENGALURU	66	HV2	ATTIBELE	15:50	15:55	00:05	HAND TRIPPED
560	14-May-22	BENGALURU	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	22:31(14-5-2022)			LINE OPEN:LINE FAULT
561	14-May-22	BENGALURU	220	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	22:31(14-5-2022)	5:30(15-5-2022)	06:58	MAIN SUPPLY FAILURE
562	14-May-22	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	22:31(14-5-2022)			LINE OPEN:MAIN SUPPLY FAILURE
563	14-May-22	BENGALURU	220	HV1	MALUR 220	22:31(14-5-2022)			TRANSFORMER OPEN:MAIN SUPPLY FAILURE

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
564	14-May-22	BENGALURU	220	LV1	MALUR 220	22:31(14-5-2022)			TRANSFORMER OPEN:MAIN SUPPLY FAILURE
565	14-May-22	BENGALURU	220	HV2	MALUR 220	22:31(14-5-2022)			TRANSFORMER OPEN:MAIN SUPPLY FAILURE
566	14-May-22	BENGALURU	220	LV2	MALUR 220	22:31(14-5-2022)			TRANSFORMER OPEN:MAIN SUPPLY FAILURE
567	14-May-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	22:31(14-5-2022)			LINE OPEN:MAIN SUPPLY FAILURE
568	14-May-22	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	22:31(14-5-2022)			LINE OPEN:MAIN SUPPLY FAILURE
569	14-May-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	22:31(14-5-2022)			LINE OPEN:MAIN SUPPLY FAILURE
570	14-May-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	22:31(14-5-2022)			LINE OPEN:MAIN SUPPLY FAILURE
571	15-May-22	BENGALURU	66	HV1	AMAR JYOTHI	01:23	01:29	00:06	TRANSFORMER FAULT
572	15-May-22	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	08:48	08:58	00:10	HAND TRIPPED
573	15-May-22	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 220	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	16:30	16:39	00:09	HAND TRIPPED
574	15-May-22	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION	14:26	14:33	00:07	LINE FAULT
575	15-May-22	BENGALURU	66	JAKKASANDRA - ADUGODI	JAKKASANDRA	16:17	16:25	00:08	LINE FAULT
576	15-May-22	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	16:17	16:25	00:08	LINE FAULT
577	15-May-22	BENGALURU	220	HV2	NAGANATHPURA 220	13:46	14:00	00:14	TRANSFORMER FAULT
578	15-May-22	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA, HUSKUR	13:46	13:53	00:07	MAIN SUPPLY FAILURE
579	15-May-22	BENGALURU	220	HV1	NAGANATHPURA 220	13:55	14:47	00:52	TRANSFORMER FAULT
580	15-May-22	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA, HUSKUR	13:55	14:04	00:09	MAIN SUPPLY FAILURE
581	15-May-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	07:14	07:29	00:15	HAND TRIPPED
582	15-May-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	16:49	16:57	00:08	HAND TRIPPED
583	15-May-22	BENGALURU	66	YARANDANAHALLI 220 - JIGANI 66	NO STATION AFFECTED	13:57	14:32	00:35	LINE FAULT
584	15-May-22	BENGALURU	66	HV3	YARANDANAHALLI 220	16:50	17:01	00:11	TRANSFORMER FAULT
585	15-May-22	BENGALURU	66	HV3	YARANDANAHALLI 220	19:08	19:18	00:10	TRANSFORMER FAULT
586	15-May-22	BENGALURU	66	HV1	MALLASANDRA	09:02	09:17	00:15	TRANSFORMER FAULT
587	15-May-22	BENGALURU	66	HV1	MALLASANDRA	23:07	23:25	00:18	TRANSFORMER FAULT
588	15-May-22	BENGALURU	220	LV2	MALUR 220	04:08	05:06	00:58	LINE CLEAR AVAILED
589	15-May-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	04:08	05:07	00:59	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
590	15-May-22	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	04:08	05:07	00:59	LINE CLEAR AVAILED
591	15-May-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	04:08	05:07	00:59	LINE CLEAR AVAILED
592	15-May-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	04:08	05:07	00:59	LINE CLEAR AVAILED
593	15-May-22	BENGALURU	66	HV2	TYAMAGONDLU	01:57	02:06	00:09	TRANSFORMER FAULT
594	15-May-22	BENGALURU	66	HV1	MULABAGALU	02:13	02:42	00:28	TRANSFORMER FAULT
595	15-May-22	BENGALURU	66	HV1	MULABAGALU	17:53	18:38	00:44	TRANSFORMER FAULT
596	15-May-22	BENGALURU	66	HV1	KYALANUR	01:55	02:05	00:09	TRANSFORMER FAULT
597	15-May-22	BENGALURU	66	HV2	KOLAR 220	01:06	01:57	00:51	TRANSFORMER FAULT
598	15-May-22	BENGALURU	66	HV1	CHINTAMANI 66	03:58	04:13	00:15	TRANSFORMER FAULT
599	15-May-22	BENGALURU	66	HV2	CHAKAVELU	17:40	18:00	00:20	LINE CLEAR AVAILED
600	15-May-22	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPETE	01:29	01:36	00:07	LINE FAULT
601	15-May-22	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	06:08	06:16	00:08	LINE FAULT
602	15-May-22	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	00:16	01:39	01:22	LINE FAULT
603	15-May-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	00:14	00:25	00:11	LINE FAULT
604	15-May-22	BENGALURU	66	HV1	ATTIBELE	07:05	07:10	00:05	HAND TRIPPED
605	15-May-22	BENGALURU	66	HV1	ATTIBELE	22:15	22:20	00:05	HAND TRIPPED
606	15-May-22	BENGALURU	66	ARMY WELFARE ORGANISATION - EPIP 220	ARMY WELFARE ORGANISATION	14:33	14:55	00:22	MAIN SUPPLY FAILURE
607	15-May-22	BENGALURU	66	ARMY WELFARE ORGANISATION - KONDASPURA	ARMY WELFARE ORGANISATION	15:27	15:32	00:05	HAND TRIPPED
608	15-May-22	BENGALURU	66	HV3	NELAMANGALA 66	08:03	08:13	00:09	TRANSFORMER FAULT
609	15-May-22	BENGALURU	220	LV1	MALUR 220	4:08(15-5-2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
610	15-May-22	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	22:31(14-5-2022)	4:01(15-5-2022)	05:29	MAIN SUPPLY FAILURE
611	15-May-22	BENGALURU	220	HV1	MALUR 220	22:31(14-5-2022)	4:03(15-5-2022)	05:31	MAIN SUPPLY FAILURE
612	15-May-22	BENGALURU	220	LV1	MALUR 220	22:31(14-5-2022)	4:05(15-5-2022)	05:33	MAIN SUPPLY FAILURE
613	15-May-22	BENGALURU	220	HV2	MALUR 220	22:31(14-5-2022)	4:03(15-5-2022)	05:31	MAIN SUPPLY FAILURE
614	15-May-22	BENGALURU	220	LV2	MALUR 220	22:31(14-5-2022)	4:05(15-5-2022)	05:33	MAIN SUPPLY FAILURE
615	15-May-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	22:31(14-5-2022)	4:06(15-5-2022)	05:34	MAIN SUPPLY FAILURE
616	15-May-22	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	22:31(14-5-2022)	4:06(15-5-2022)	05:34	MAIN SUPPLY FAILURE
617	15-May-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	22:31(14-5-2022)	4:06(15-5-2022)	05:34	MAIN SUPPLY FAILURE
618	15-May-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	22:31(14-5-2022)	4:06(15-5-2022)	05:34	MAIN SUPPLY FAILURE
619	16-May-22	BENGALURU	66	HV2	APPAREL PARK	17:55	17:59	00:04	TRANSFORMER FAULT
620	16-May-22	BENGALURU	66	HV3	B STATION	21:50	22:00	00:10	TRANSFORMER FAULT
621	16-May-22	BENGALURU	220	HOODY 220 - RAILWAYS 1 (EHT)	NO STATION AFFECTED	22:50	23:24	00:34	LINE FAULT
622	16-May-22	BENGALURU	66	HV1	NIMHANS 220	14:53	14:56	00:03	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
623	16-May-22	BENGALURU	66	HV1	NIMHANS 220	15:32	15:34	00:02	HAND TRIPPED
624	16-May-22	BENGALURU	220	TK HALLI 220 - VAJAMANGALA 220	TK HALLI 220	12:18	12:27	00:09	LINE FAULT
625	16-May-22	BENGALURU	220	TK HALLI 220 - VAJAMANGALA 220	TK HALLI 220	12:27	12:38	00:11	LINE FAULT
626	16-May-22	BENGALURU	220	HV1	TK HALLI 220	12:18	12:38	00:20	MAIN SUPPLY FAILURE
627	16-May-22	BENGALURU	220	HV2	TK HALLI 220	12:18	12:42	00:24	MAIN SUPPLY FAILURE
628	16-May-22	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	12:18	12:44	00:26	MAIN SUPPLY FAILURE
629	16-May-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR,K HONALGERE, YATHAMBADI	12:18	12:44	00:26	MAIN SUPPLY FAILURE
630	16-May-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	12:18	12:44	00:26	MAIN SUPPLY FAILURE
631	16-May-22	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	12:18	12:44	00:26	MAIN SUPPLY FAILURE
632	16-May-22	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	12:18	12:44	00:26	MAIN SUPPLY FAILURE
633	16-May-22	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	HALAGUR, HONNIGANAHALLI, DODDALAHALLI, SATHNUR (ACHLU)	12:18	12:44	00:26	MAIN SUPPLY FAILURE
634	16-May-22	BENGALURU	66	TK HALLI 220 - BWSSB 1 (EHT)	BWSSB 1 (EHT)	12:18	12:44	00:26	MAIN SUPPLY FAILURE
635	16-May-22	BENGALURU	66	TK HALLI 220 - BWSSB 2 (EHT)	BWSSB 2 (EHT)	12:18	12:44	00:26	MAIN SUPPLY FAILURE
636	16-May-22	BENGALURU	66	TK HALLI 220 - BWSSB 3 (EHT)	BWSSB 3 (EHT)	12:18	12:44	00:26	MAIN SUPPLY FAILURE
637	16-May-22	BENGALURU	66	TK HALLI 220 - BWSSB 4 (EHT)	BWSSB 4 (EHT)	12:18	12:44	00:26	MAIN SUPPLY FAILURE
638	16-May-22	BENGALURU	66	HV1	AMAR JYOTHI	16:39	16:53	00:14	TRANSFORMER FAULT
639	16-May-22	BENGALURU	66	HV1	AMAR JYOTHI	17:33	17:40	00:07	HAND TRIPPED
640	16-May-22	BENGALURU	66	HV2	THAYALUR	12:25	12:42	00:17	TRANSFORMER FAULT
641	16-May-22	BENGALURU	66	HV2	SARJAPURA 220	23:54	23:59	00:04	TRANSFORMER FAULT
642	16-May-22	BENGALURU	66	HV3	NELAMANGALA 66	12:30	12:44	00:14	TRANSFORMER FAULT
643	16-May-22	BENGALURU	66	HV1	MULABAGALU	13:22	14:10	00:47	LINE CLEAR AVAILED
644	16-May-22	BENGALURU	66	HV2	KIADB DB PURA 220	17:12	17:45	00:33	TRANSFORMER FAULT
645	16-May-22	BENGALURU	66	HV3	CB PURA I/A	18:06	18:36	00:30	TRANSFORMER FAULT
646	16-May-22	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	08:26	08:39	00:13	LINE FAULT
647	16-May-22	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	17:20	18:05	00:45	LINE FAULT
648	16-May-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	05:56	06:18	00:22	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
649	16-May-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 1	MANCHENAHALLI, GUNDAMGERE	19:04	19:12	00:08	LINE FAULT
650	16-May-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	10:23	10:24	00:01	LINE CLEAR AVAILED
651	16-May-22	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	17:23	17:32	00:09	LINE FAULT
652	16-May-22	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU CROSS, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	21:05	21:11	00:05	LINE FAULT
653	16-May-22	BENGALURU	220	HV2	MALUR 220	15:29	15:43	00:14	TRANSFORMER FAULT
654	16-May-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	15:29	15:44	00:15	MAIN SUPPLY FAILURE
655	16-May-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	15:29	15:44	00:15	MAIN SUPPLY FAILURE
656	16-May-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	15:29	15:44	00:15	MAIN SUPPLY FAILURE
657	16-May-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	15:29	15:44	00:15	MAIN SUPPLY FAILURE
658	16-May-22	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	15:29	15:53	00:24	MAIN SUPPLY FAILURE
659	16-May-22	BENGALURU	220	LV1	MALUR 220	4:08(15-5-2022)	18:37(16-5-2022)	38:28 hrs	TRANSFORMER CHARGED
660	12-May-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN:LINE FAULT
661	12-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
662	12-May-22	GULBARGA	220	KUDLIGI-HIREMALLANAHALLI 1&2	KUDLIGI_220	17:25(08.05.2022)			LINE OPEN:LINE FAULT
663	12-May-22	GULBARGA	220	LINGASUGUR-BAGEWADI2	BAGEWADI_220	17:38(12.05.2022)			LINE OPEN:LINE CLEAR AVAILED
664	12-May-22	GULBARGA	220	HV1,LV1	KAPNOOR_220	16:02	18:56	02:54	LINE CLEAR AVAILED
665	12-May-22	GULBARGA	220	SEDAM-TANDUR	TANDUR_220	15:20	16:25	01:05	NFBC ISSUED
666	12-May-22	GULBARGA	220	KUSTAGI-SUZLON LINE_IPP2	KUSTAGI_220	08:13	08:52	00:39	LINE CLEAR AVAILED
667	12-May-22	GULBARGA	220	KUSTAGI-SUZLON LINE_IPP2	KUSTAGI_220	08:13	08:52	00:39	LINE CLEAR AVAILED
668	12-May-22	GULBARGA	110	HV2	GULBARGAWEST_110	08:13	08:22	00:09	TRANSFORMER FAULT
669	12-May-22	GULBARGA	110	HV2	LADHA_110	13:35	14:50	01:15	TRANSFORMER FAULT
670	12-May-22	GULBARGA	110	HV2	GULBARGAWEST_110	16:45	17:20	00:35	TRANSFORMER FAULT
671	12-May-22	GULBARGA	110	HV1	GULBARGAWEST_110	14:15	14:26	00:11	TRANSFORMER FAULT
672	12-May-22	GULBARGA	110	HV1	MATAMARI_110	11:20(08.05.2022)	14:55(12.05.2022)	75:35 hrs	TRANSFORMER CHARGED
673	12-May-22	GULBARGA	110	HV3	TEKKALKOTE_110	20:43	21:08	00:25	TRANSFORMER FAULT
674	12-May-22	GULBARGA	110	HV2	ALIPUR_220	16:09	19:14	03:05	TRANSFORMER FAULT
675	12-May-22	GULBARGA	110	SHAHAPUR-RAICHUR1,2	DEODURGA_110	20:11(11.05.2022)	12:40(12.05.2022)	16:29HRS	LINE CHARGED
676	12-May-22	GULBARGA	110	SHAHAPUR-RAICHUR1,2	DEODURGA_110	09:51	12:40	02:49	LINE CLEAR AVAILED
677	12-May-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	12:21(11.05.2022)	12:40(12.05.2022)	24:19HRS	LINE CHARGED
678	12-May-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	20:21	20:27	00:06	LINE FAULT
679	12-May-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	19:48	19:59	00:11	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
680	12-May-22	GULBARGA	110	GHATTARGA-AFZALPUR	AFZALPUR_110	14:39	14:50	00:11	LINE FAULT
681	12-May-22	GULBARGA	110	NANDUR-GULBARGAUNIVERSITY	NANDUR_110	07:00	07:06	00:06	LINE FAULT
682	12-May-22	GULBARGA	110	AURAD-DONGARGAON	DONGARGAON_110	20:15	20:20	00:05	LINE FAULT
683	12-May-22	GULBARGA	110	AURAD-DONGARGAON	DONGARGAON_110	20:20	20:25	00:05	LINE FAULT
684	12-May-22	GULBARGA	110	AURAD-DONGARGAON	DONGARGAON_110	20:30	20:40	00:10	LINE FAULT
685	12-May-22	GULBARGA	110	HUNSIGI-KEMBHAVI	KEMBHAVI_110	20:35	20:45	00:10	MAIN SUPPLY FAILURE
686	12-May-22	GULBARGA	110	PDHALLI-CLNMAX	PD_HALLI_110	19:40(12.05.2022)			LINE OPEN:LINE CLEAR AVAILED
687	12-May-22	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	14:40	14:50	00:10	MAIN SUPPLY FAILURE
688	12-May-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	20:21	20:27	00:06	LINE FAULT
689	12-May-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	19:48	19:59	00:11	LINE FAULT
690	12-May-22	GULBARGA	110	LINGASUGUR-KAREPOWER	CHAYADEVI_IPP,KAREPOWER_I PP	03:36	04:25	00:49	LINE FAULT
691	12-May-22	GULBARGA	110	LINGASUGUR-KAREPOWER	CHAYADEVI_IPP,KAREPOWER_I PP	17:28	19:10	01:42	LINE FAULT
692	12-May-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNASAGI_110	20:35	20:43	00:08	LINE FAULT
693	12-May-22	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	08:40	08:50	00:10	LINE CLEAR AVAILED
694	12-May-22	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PDHALI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELS ACC	14:13	14:46	00:33	LINE FAULT
695	12-May-22	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PDHALI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELS ACC	21:01	21:16	00:15	LINE FAULT
696	12-May-22	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP	23:15	23:25	00:10	LINE FAULT
697	12-May-22	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGUTTI_110	06:59	07:28	00:29	LINE FAULT
698	12-May-22	GULBARGA	66	HV2	TAMBRAHALI_66	11:09	11:43	00:34	TRANSFORMER FAULT
699	12-May-22	GULBARGA	66	HV2	TAMBRAHALI_66	11:45	12:05	00:20	TRANSFORMER FAULT
700	12-May-22	GULBARGA	66	HV2	TAMBRAHALI_66	19:45	19:48	00:03	TRANSFORMER FAULT
701	12-May-22	GULBARGA	66	HV2	HALVAGALU_66	13:10	13:15	00:05	TRANSFORMER FAULT
702	12-May-22	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJAINI_66,BENNEHALI_66	05:00	05:10	00:10	LINE FAULT
703	12-May-22	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJAINI_66,BENNEHALI_66	11:50	12:03	00:13	LINE FAULT
704	12-May-22	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJAINI_66,BENNEHALI_66	11:50	12:03	00:13	LINE FAULT
705	13-May-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN:LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
706	13-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
707	13-May-22	GULBARGA	220	KUDLIGI- HIREMALLANAHALLI 1&2	KUDLIGI_220	17:25(08.05.2022)			LINE OPEN:LINE FAULT
708	13-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
709	13-May-22	GULBARGA	220	KUDLIGI- HIREMALLANAHALLI 1&2	KUDLIGI_220	17:25(08.05.2022)			LINE OPEN:LINE FAULT
710	13-May-22	GULBARGA	220	LINGASUGUR-BAGEWADI2	BAGEWADI_220	17:38(12.05.2022)			LINE OPEN:LINE CLEAR AVAILED
711	13-May-22	GULBARGA	220	LINGASUGUR-KUSTAGI	KUSTAGI_220	14:35	18:47	04:12	LINE CLEAR AVAILED
712	13-May-22	GULBARGA	220	RAICHUR-RTPS1	RAICHUR_220	09:25	14:50	05:25	NFBC ISSUED
713	13-May-22	GULBARGA	220	MALLAT-RTPS	MALLAT_220	04:47	06:14	01:27	LINE FAULT
714	13-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110 ,WADAGERA_110,SANNATHI_IP P,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
715	13-May-22	GULBARGA	110	STARMETALLICS- MUNIRABAD	MUNIRABAD_220	23:54(13.05.2022)			LINE OPEN:LINE FAULT
716	13-May-22	GULBARGA	110	HV3	VALKAMDINNI_110	17:18	17:22	00:04	TRANSFORMER FAULT
717	13-May-22	GULBARGA	110	HV1	NIRNA_110	01:35	01:40	00:05	TRANSFORMER FAULT
718	13-May-22	GULBARGA	110	HV1	YAKATPUR_110	12:45	12:50	00:05	TRANSFORMER FAULT
719	13-May-22	GULBARGA	110	HV2	NANDUR_110	10:49	13:12	02:23	LINE CLEAR AVAILED
720	13-May-22	GULBARGA	110	HV2	NANDUR_110	16:15	19:15	03:00	LINE CLEAR AVAILED
721	13-May-22	GULBARGA	110	HV1	LADHA_110	09:35	09:50	00:15	TRANSFORMER FAULT
722	13-May-22	GULBARGA	110	HV2	DEODURGA_110	19:30	19:40	00:10	TRANSFORMER FAULT
723	13-May-22	GULBARGA	110	PDHALLI-CLNMAX	PD_HALLI_110	19:40(12.05.2022)	03:40(13.05.2022)	8:00 hrs	LINE CHARGED
724	13-May-22	GULBARGA	110	NIRNA-CHITGUPPA	NIRNA_110	11:05	11:15	00:10	MAIN SUPPLY FAILURE
725	13-May-22	GULBARGA	110	AURAD-SANTHPUR	AURAD_110,DONAGARGAON_1 10	03:45	03:55	00:10	LINE FAULT
726	13-May-22	GULBARGA	110	KURKUNTA-BETEGERA	KURKUNTA_110	18:05	18:15	00:10	MAIN SUPPLY FAILURE
727	13-May-22	GULBARGA	110	CHITGUPPA-HUMNABAD	CHITGUPPA_110	11:00	11:10	00:10	MAIN SUPPLY FAILURE
728	13-May-22	GULBARGA	110	SHAHABAD-CHITAPUR	KORWAR TEMPLE_110	20:35	21:55	01:20	LINE FAULT
729	13-May-22	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_ 110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	15:45	15:55	00:10	LINE FAULT
730	13-May-22	GULBARGA	110	SINDHANOOR-NIRLOTI_IPP	SINDHANOOR_220	15:30	15:35	00:05	LINE FAULT
731	13-May-22	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110,KONKAL_110	17:15	17:22	00:07	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
732	13-May-22	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORWAR TEMPLE_110	18:13	18:18	00:05	LINE FAULT
733	13-May-22	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	18:13	18:19	00:06	LINE FAULT
734	13-May-22	GULBARGA	110	SEDAM-VICAT SAGR_IPP	SEDAM_220	18:19	18:24	00:05	LINE FAULT
735	13-May-22	GULBARGA	66	MUNIRABAD-MHD	VENKATAPUR_66,UPANAYAKAN AHALLI_66,HAGARIBOMMANAH ALLI_66,RR STEELS_IPP	23:57(13.05.2022)			LINE OPEN:LINE FAULT
736	13-May-22	GULBARGA	66	ITTAGI-KUDLIGI1	KOGALI_66,KUDLIGI_66,HANSI_66	13:20	13:30	00:10	LINE CLEAR AVAILED
737	14-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
738	14-May-22	GULBARGA	220	KUDLIGI- HIREMALLANAHALLI 1&2	KUDLIGI_220	17:25(08.05.2022)			LINE OPEN:LINE FAULT
739	14-May-22	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	20:07	22:40	02:33	LINE FAULT
740	14-May-22	GULBARGA	220	LINGASUGUR-BAGEWADI2	BAGEWADI_220	17:38(12.05.2022)	03:36(14.05.2022)	33:58HRS	LINE CHARGED
741	14-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110 ,WADAGERA_110,SANNATHI_IP P,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
742	14-May-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLR_110	21:15(14.05.2022)			LINE OPEN:LINE FAULT
743	14-May-22	GULBARGA	110	HV3	TEKKALKOTE_110	07:45	11:24	03:39	TRANSFORMER FAULT
744	14-May-22	GULBARGA	110	HV3	TEKKALKOTE_110	13:40	14:03	00:23	TRANSFORMER FAULT
745	14-May-22	GULBARGA	110	HV3	TEKKALKOTE_110	14:05	14:24	00:19	TRANSFORMER FAULT
746	14-May-22	GULBARGA	110	HV3	TEKKALKOTE_110	14:29	14:57	00:28	TRANSFORMER FAULT
747	14-May-22	GULBARGA	110	HV3	TEKKALKOTE_110	16:12	16:27	00:15	TRANSFORMER FAULT
748	14-May-22	GULBARGA	110	HV1	MARGUTTI_110	18:23	21:10	02:47	TRANSFORMER FAULT
749	14-May-22	GULBARGA	110	HV1	YAKATPUR_110	15:15	15:20	00:05	TRANSFORMER FAULT
750	14-May-22	GULBARGA	110	HV2	DEODURGA_110	07:00	07:10	00:10	TRANSFORMER FAULT
751	14-May-22	GULBARGA	110	HV2	DEODURGA_110	19:35	19:45	00:10	TRANSFORMER FAULT
752	14-May-22	GULBARGA	110	HV2	SHAHAPUR_220	19:05	19:20	00:15	TRANSFORMER FAULT
753	14-May-22	GULBARGA	110	PDHALLI-CLN MAX	PD_HALLI_110	18:58	22:44	03:46	LINE CLEAR AVAILED
754	14-May-22	GULBARGA	110	NIRNA-CHITGUPPA	NIRNA_110	16:10	16:50	00:40	MAIN SUPPLY FAILURE
755	14-May-22	GULBARGA	110	MARGUTTI-KAPNOOR	MARGUTTI_110	17:31	17:50	00:19	LINE CLEAR AVAILED
756	14-May-22	GULBARGA	110	MARGUTTI-KAPNOOR	MARGUTTI_110	17:50	18:20	00:30	LINE CLEAR AVAILED
757	14-May-22	GULBARGA	110	STARMETALLICS- MUNIRABAD	MUNIRABAD_220	23:54(13.05.2022)	00:06(14.05.2022)	00:10HRS	LINE CHARGED
758	14-May-22	GULBARGA	110	AURAD-DONAGARGAON	DONAGARGAON_110	00:25	00:35	00:10	LINE FAULT
759	14-May-22	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE_110	20:50	21:15	00:25	MAIN SUPPLY FAILURE
760	14-May-22	GULBARGA	110	GULBARGAWEST- GULBARGA-SOUTH	GULBARGAWEST_110	05:49	12:37	06:48	LINE FAULT
761	14-May-22	GULBARGA	110	GABBUR-DEODURGA	GABBUR_110	21:05	21:10	00:05	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
762	14-May-22	GULBARGA	110	CHITGUPPA_HUMNABAD	CHITGUPPA_110	16:15	16:35	00:20	MAIN SUPPLY FAILURE
763	14-May-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	12:06	12:26	00:20	LINE FAULT
764	14-May-22	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	16:10	16:38	00:28	LINE FAULT
765	14-May-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLR_110	20:50	21:15	00:25	LINE FAULT
766	14-May-22	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	21:50	22:20	00:30	LINE FAULT
767	14-May-22	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	23:01	23:05	00:04	LOAD CURTAILMENT
768	14-May-22	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,K EREHALLI_110,MALLAPUR_110	16:07	18:03	01:56	LINE CLEAR AVAILED
769	14-May-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,Y ERDONA_110,SRNAGAR_110,M ALLAPURA_110	01:35	01:45	00:10	LINE FAULT
770	14-May-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,Y ERDONA_110,SRNAGAR_110,M ALLAPURA_110	14:40	14:45	00:05	LINE CLEAR AVAILED
771	14-May-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,Y ERDONA_110,SRNAGAR_110,M ALLAPURA_110	18:15	18:23	00:08	LINE CLEAR AVAILED
772	14-May-22	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORWAR TEMPLE_110	11:55	12:25	00:30	LINE FAULT
773	14-May-22	GULBARGA	110	SEDAM-VASAVADATTA CEMENT_IPP	VASAVADATTA CEMENT_IPP	11:55	12:10	00:15	LINE FAULT
774	14-May-22	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	12:10	13:40	01:30	LINE CLEAR AVAILED
775	14-May-22	GULBARGA	110	SEDAM-VASAVADATTA CEMENT_IPP	VASAVADATTA CEMENT_IPP	12:13	12:28	00:15	LINE FAULT
776	14-May-22	GULBARGA	110	SEDAM-VASAVADATTA CEMENT_IPP	VASAVADATTA CEMENT_IPP	12:30	13:35	01:05	LINE FAULT
777	14-May-22	GULBARGA	66	HV2	HARAPANAHALLI_66	01:10	01:20	00:10	TRANSFORMER FAULT
778	14-May-22	GULBARGA	66	HV2	HALVAGALU_66	18:35	18:45	00:10	TRANSFORMER FAULT
779	14-May-22	GULBARGA	66	TELAGI-KURUBARAHALLI	KURUBARAHALLI_66	09:20	09:40	00:20	LINE FAULT
780	14-May-22	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJAINI_66,BENNE HALLI_66	20:24	20:29	00:05	LINE CLEAR AVAILED
781	14-May-22	GULBARGA	66	NEELGUNDA-TELAGI	TELAGI_66,KURBHALLI_66,YE REGUNTA_66	09:23	09:37	00:14	LINE FAULT
782	14-May-22	GULBARGA	66	MUNIRABAD-MHD	VENKATAPUR_66,UPANAYAKAN AHALLI_66,HAGARIBOMMANAH ALLI_66,RR STEELS_IPP	23:57(13.05.2022)	00:13(14.05.2022)	00:16HRS	LINE CHARGED
783	15-May-22	GULBARGA	220	KUDLIGI-HIREMALLANAHALLI 1&2	KUDLIGI_220	17:25(08.05.2022)			LINE OPEN:LINE FAULT
784	15-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
785	15-May-22	GULBARGA	110	PDHALLI-CLN MAX	PD_HALLI_110	20:34(15.05.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
786	15-May-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	21:15(14.05.2022)			LINE OPEN:LINE FAULT
787	15-May-22	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGUTTI_110	23:33 (15.05.2022)			LINE OPEN:LINE CLEAR AVAILED
788	15-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110 ,WADAGERA_110,SANNATHI_IP P,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
789	15-May-22	GULBARGA	110	HV4	YELBURGA_110	20:17	20:40	00:23	TRANSFORMER FAULT
790	15-May-22	GULBARGA	110	HV2	YAKATPUR_110	13:50	14:05	00:15	TRANSFORMER FAULT
791	15-May-22	GULBARGA	110	HV2	CHOWDAPUR_110	22:04	22:13	00:09	TRANSFORMER FAULT
792	15-May-22	GULBARGA	110	HV2	CHOWDAPUR_110	22:16	22:18	00:02	TRANSFORMER FAULT
793	15-May-22	GULBARGA	110	HV1	HALAKUNDI_110	12:52	13:12	00:20	TRANSFORMER FAULT
794	15-May-22	GULBARGA	110	HV2	HALAKUNDI_110	13:35	15:05	01:30	LINE CLEAR AVAILED
795	15-May-22	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	17:50	17:55	00:05	LINE FAULT
796	15-May-22	GULBARGA	110	RAJESHWAR-SASTHAPUR	SASTHAPUR_110	17:55(15.05.2022)			LINE OPEN:LINE FAULT
797	15-May-22	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	18:00	18:05	00:05	LINE FAULT
798	15-May-22	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	19:15	19:20	00:05	LINE FAULT
799	15-May-22	GULBARGA	110	CHINCHOLI-MANEKHALI	CHINCHOLI_110	18:30	19:03	00:33	LINE FAULT
800	15-May-22	GULBARGA	110	CHINCHOLI-CHETTINAD_IPP	CHINCHOLI_110	18:37	19:13	00:36	LINE CLEAR AVAILED
801	15-May-22	GULBARGA	110	CHINCHOLI-RENEWSOLAR_IPP	CHINCHOLI_110	18:37	20:24	01:47	LINE FAULT
802	15-May-22	GULBARGA	110	HALBARGA-ACMESOLAR	HALBARGA_220	22:04	22:13	00:09	LINE FAULT
803	15-May-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	11:44	11:48	00:04	LINE FAULT
804	15-May-22	GULBARGA	110	HUMNABAD-MANEIKHELLI	MANAIKHELLI_110	17:30	17:35	00:05	LINE FAULT
805	15-May-22	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	01:45	01:50	00:05	LOAD CURTAILMENT
806	15-May-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,Y ERDONA_110,SRNAGAR_110,M ALLAPURA_110	14:05	14:15	00:10	LINE FAULT
807	15-May-22	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGUTTI_110	19:48	20:37	00:49	LINE CLEAR AVAILED
808	15-May-22	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	18:35	19:05	00:30	LINE FAULT
809	16-May-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN:LINE FAULT
810	16-May-22	GULBARGA	400	RTPS-MEHOBUBNAGAR	MEHOBUBNAGAR_400	18:16	20:41	02:25	LINE FAULT
811	16-May-22	GULBARGA	220	KUDLIGI-HIREMALLANAHALLI 1&2	KUDLIGI_220	17:25(08.05.2022)			LINE OPEN:LINE FAULT
812	16-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
813	16-May-22	GULBARGA	220	ITTAGI-BMM ISPAT_IPP	BMM ISPAT_IPP	18:50 (16.05.2022)			LINE OPEN:LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
814	16-May-22	GULBARGA	220	HV2	ITTAGI_220	18:50	19:18	00:28	TRANSFORMER FAULT
815	16-May-22	GULBARGA	220	HV1,HV2	MUNIRABAD_220	18:50	19:20	00:30	TRANSFORMER FAULT
816	16-May-22	GULBARGA	220	HV1,HV2	ALIPUR_220	17:38	18:23	00:45	HAND TRIPPED
817	16-May-22	GULBARGA	220	HV1	HALAWARTHI_220	17:48	18:20	00:32	TRANSFORMER FAULT
818	16-May-22	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	17:38	18:00	00:22	LINE FAULT
819	16-May-22	GULBARGA	220	ALIPUR-RAGALPADU	RAGALPADU_220	17:38	24:00:00	06:22	LINE FAULT
820	16-May-22	GULBARGA	220	LINGAPUR-GANGAVATHI2	LINGAPUR_220	11:43	12:17	00:34	LINE FAULT
821	16-May-22	GULBARGA	220	LINGAPUR-GANGAVATHI2	LINGAPUR_220	12:38	15:18	02:40	LINE FAULT
822	16-May-22	GULBARGA	220	LINGAPUR-MUNIRABAD1	MUNIRABAD_220	18:23	19:02	00:39	LINE FAULT
823	16-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110 ,WADAGERA_110,SANNATHI_IP P,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
824	16-May-22	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	18:16 (16.05.2022)			LINE OPEN:LINE FAULT
825	16-May-22	GULBARGA	110	HV1	CHINCHOLI_110	12:52	12:58	00:06	TRANSFORMER FAULT
826	16-May-22	GULBARGA	110	HV2	GHATTARGA_110	08:10	11:10	03:00	LINE CLEAR AVAILED
827	16-May-22	GULBARGA	110	HV1	GHATTARGA_110	10:30	14:20	03:50	LINE CLEAR AVAILED
828	16-May-22	GULBARGA	110	HV2	GHATTARGA_110	11:05	11:15	00:10	TRANSFORMER FAULT
829	16-May-22	GULBARGA	110	HV1	HUNSIGI_110	10:55	11:05	00:10	LINE CLEAR AVAILED
830	16-May-22	GULBARGA	110	HV2	YAKATPUR_110	05:15	05:30	00:15	TRANSFORMER FAULT
831	16-May-22	GULBARGA	110	HV2	YAKATPUR_110	11:10	11:30	00:20	TRANSFORMER FAULT
832	16-May-22	GULBARGA	110	HV1	CHICKSUGUR_110	19:10	19:26	00:16	TRANSFORMER FAULT
833	16-May-22	GULBARGA	110	HV1	KURKUNTA_110	13:15	13:35	00:20	TRANSFORMER FAULT
834	16-May-22	GULBARGA	110	HV2	ALIPUR_220	17:17	17:27	00:10	TRANSFORMER FAULT
835	16-May-22	GULBARGA	110	HV3	ALIPUR_220	17:39	18:11	00:32	TRANSFORMER FAULT
836	16-May-22	GULBARGA	110	HV2	RAICHUR_220	18:19	18:38	00:19	TRANSFORMER FAULT
837	16-May-22	GULBARGA	110	HV2	SHAHAPUR_220	16:43	17:10	00:27	TRANSFORMER FAULT
838	16-May-22	GULBARGA	110	RAJESHWAR-SASTHAPUR	SASTHAPUR_110	17:55(15.05.2022)	11:56(16.05.2022)	18:01:00	LINE CHARGED
839	16-May-22	GULBARGA	110	PDHALLI-CLN MAX	PD_HALLI_110	20:34(15.05.2022)	2:54(16.05.2022)	6:20:00	LINE CHARGED
840	16-May-22	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGUTTI_110	23:33 (15.05.2022)	1:48 (16.05.2022)	2:15 HRS	LINE CHARGED
841	16-May-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	12:39	12:47	00:08	LINE FAULT
842	16-May-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	18:14	19:30	01:16	LINE FAULT
843	16-May-22	GULBARGA	110	MUNIRABAD-HAGRI	SANKLAPUR_110,RBNS FACTORY,KAMALAPUR_110,TO RANGALLU_110,KUDITINI_110	11:55	12:05	00:10	LINE FAULT
844	16-May-22	GULBARGA	110	AURAD-DONGARGAON	DONGARGAON_110	00:25	00:35	00:10	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
845	16-May-22	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGUTTI_110	01:43	01:48	00:05	LINE CLEAR AVAILED
846	16-May-22	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGUTTI_110	14:20	20:50	06:30	LINE CLEAR AVAILED
847	16-May-22	GULBARGA	110	HUMNABAD-DUBALGUNDI	DUBALGUNDI_110	14:05	14:15	00:10	LINE CLEAR AVAILED
848	16-May-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	21:15(14.05.2022)	10:55 (16.05.2022)	37:40 HRS	LINE CHARGED
849	16-May-22	GULBARGA	66	KUDLIGI-BANVIKAL	BANVIKAL_66	14:55	15:15	00:20	LINE FAULT
850	16-May-22	GULBARGA	66	KUDLIGI-BANVIKAL	BANVIKAL_66	16:15	16:46	00:31	LINE FAULT
851	16-May-22	GULBARGA	66	KUDLIGI-BADELADUKU	BADELADUKU_220,BANVIKAL_66,CHORNOOR_66	17:35	18:20	00:45	MAIN SUPPLY FAILURE
852	16-May-22	GULBARGA	66	ITTAGI-KUDLIGI_2	KUDLIGI_66,CHORNOOR_66,BANVIKAL_66,BADELADUKU_220	17:10 (16.05.2022)			LINE OPEN:LINE CLEAR AVAILED
853	16-May-22	GULBARGA	66	HV2	PUNABGHATA_66	05:10	05:15	00:05	TRANSFORMER FAULT
854	16-May-22	GULBARGA	66	HV2	PUNABGHATA_66	06:35	12:35	06:00	LINE CLEAR AVAILED
855	16-May-22	GULBARGA	66	HV2	HALVAGALU_66	17:40	17:50	00:10	TRANSFORMER FAULT
856	16-May-22	GULBARGA	66	HV2	HARAPANAHALLI_66	02:20	02:25	00:05	TRANSFORMER FAULT
857	16-May-22	GULBARGA	66	HV2	TAMBRAHALLI_66	03:01	03:06	00:05	TRANSFORMER FAULT
858	16-May-22	GULBARGA	66	ITTAGI-HIREHADAGALI_2	HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP	20:44	21:10	00:26	LINE FAULT
859	16-May-22	GULBARGA	66	ITTAGI-HIREHADAGALI_2	HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP	21:25	22:15	00:50	LINE FAULT
860	16-May-22	GULBARGA	66	HOSAHALLI-SML_WND	HOSAHALLI_66	16:15	21:45	05:30	LINE FAULT
861	16-May-22	GULBARGA	66	PUNABGHATA-NEELAGUNDA	PUNABGHATA_66,UCHCHANGI DURGA_66,BILCHOD_66	05:10	05:15	00:05	LINE FAULT
862	12-May-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
863	12-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
864	12-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
865	12-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVAILED
866	12-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVAILED
867	12-May-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	9:18 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
868	12-May-22	BAGALKOT	110	AMBEWADI- NK1 (KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	9:30 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
869	12-May-22	BAGALKOT	110	AMBEWADI- NK2 (HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	9:33 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
870	12-May-22	BAGALKOT	220	AMBEWADI- PONDA2	STATION NOT AFFECTED AMBEWADI_220	21:40 (11.05.2022)	15:10 (12.05.2022)	17:30	LINE CHARGED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
871	12-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED BABLESHWAR_110	21:55	23:57	2:02	TRANSFORMER FAULT
872	12-May-22	BAGALKOT	110	BABLESHWAR- MAMADAPURA	BABLESHWAR_110	21:44 (12.05.2022)			LINE OPEN:LINE CLEAR AVAILED
873	12-May-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED BILAGI_110	19:41	21:37	1:56	TRANSFORMER FAULT
874	12-May-22	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110, KARICHI_33,KERUR_33	13:53	14:38	0:45	HAND TRIPPED
875	12-May-22	BAGALKOT	110	110/11KV, HV3	HIDIKAL_110, KOLIGUDDA_33, MYTRA SOLAR_33	21:15	21:30	0:15	TRANSFORMER FAULT
876	12-May-22	BAGALKOT	110	110/11KV,HV1	KADANKOPPA_110	11:29	13:09	1:40	LINE CLEAR AVAILED
877	12-May-22	BAGALKOT	110	BAGEWADI220-UKKALI	UKKALI_110	21:35 (12.05.2022)			LINE OPEN:LINE CLEAR AVAILED
878	12-May-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TODALBAGI_110	16:50	17:00	0:10	TRANSFORMER FAULT
879	12-May-22	BAGALKOT	110	110/33KV, HV3	TODALBAGI_33, BIDARI_33 JRK SOLAR_33 STATION NOT AFFECTED TODALABAGI_110	20:00	21:02	1:02	TRANSFORMER FAULT
880	12-May-22	BAGALKOT	110	110/33KV, HV3	TODALBAGI_33, BIDARI_33 JRK SOLAR_33 STATION NOT AFFECTED TODALABAGI_110	21:02	21:15	0:13	TRANSFORMER FAULT
881	12-May-22	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED SADALAGA_110	19:08	19:19	0:11	TRANSFORMER FAULT
882	12-May-22	BAGALKOT	110	RAMANAKOPPA- MUNDAGOD(SAVANUR)	MUNDAGOD_110	13:47	13:56	0:09	HAND TRIPPED
883	12-May-22	BAGALKOT	110	MUGALKHOD220(ITNAL)- RAIBAG1	STATION NOT AFFECTED RAIBAG_110	12:44	12:48	0:04	HAND TRIPPED
884	12-May-22	BAGALKOT	110	MUGALKHOD220(ITNAL)- RAIBAG1	STATION NOT AFFECTED RAIBAG_110	12:03	12:10	0:07	HAND TRIPPED
885	12-May-22	BAGALKOT	110	MUGALKHOD220(ITNAL)- RAIBAG1	STATION NOT AFFECTED RAIBAG_110	11:35	11:58	0:23	HAND TRIPPED
886	12-May-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED RATTIHALLI_110	12:55	12:58	0:03	TRANSFORMER FAULT
887	12-May-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUDDEBIHAL_110	13:08	13:51	0:43:00	LINE CLEAR AVAILED
888	12-May-22	BAGALKOT	110	MAMADAPUR- BABALESWAR	STATION NOT AFFECTED MAMADAPUR(B)_110	19:50	21:06	1:16:00	LINE FAULT
889	12-May-22	BAGALKOT	110	MAMADAPUR- BABALESWAR	STATION NOT AFFECTED MAMADAPUR(B)_110	21:06 (12.05.2022)			LINE OPEN:LINE FAULT
890	12-May-22	BAGALKOT	110	KONNUR-ANANTAPUR SOLAR	ANANTAPUR SOLAR_110 STATION NOT AFFECTED KONNUR_110	03:37	03:50	0:13:00	LINE FAULT
891	12-May-22	BAGALKOT	220	BAGEWADI- ALAMATTI2	STATION NOT AFFECTED BAGEWADI_220	19:10 (12.05.2022)			LINE OPEN:LINE FAULT
892	12-May-22	BAGALKOT	110	BAGALKOT220- BAGALKOT2	BAGALKOT_220	19:10	20:42	1:32	LINE FAULT
893	12-May-22	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED GHATAPRABHA_220	22:49	23:06	0:17	TRANSFORMER FAULT
894	12-May-22	BAGALKOT	110	110/11KV, HV2	ALMEL_110	6:38	6:45	00:07	TRANSFORMER FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
895	12-May-22	BAGALKOT	110	110/11KV, HV2	ALMEL_110	18:41	18:50	00:09	TRANSFORMER FAULT
896	12-May-22	BAGALKOT	110	ALMEL- KPR SUGARS	ALMEL_110	17:11	18:40	01:29	LINE CLEAR AVAILED
897	12-May-22	BAGALKOT	110	GHATAPRABHA220- GOKAK	GHATAPRABHA_220	22:49	23:13	0:24	LINE FAULT
898	12-May-22	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED MAHALINGAPUR_220	21:17 (12.05.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
899	12-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
900	12-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED GIRISAGAR_110	9:40 (05.05.2022)	15:00 (12.05.2022)	173:20:00	TRANSFORMER CHARGED
901	12-May-22	BAGALKOT	110	11011KV, HV1	CHIKKODI_110	15:55	16:00	0:05	HAND TRIPPED
902	12-May-22	BAGALKOT	110	110/11KV, HV2	MANTUR(B)_110	13:58	14:08	0:10	TRANSFORMER FAULT
903	12-May-22	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	21:15 (12.05.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
904	12-May-22	BAGALKOT	220	KARWAR- KADRA1	STATION NOT AFFECTED KARWAR_220	09:20	10:53	1:33	HAND TRIPPED
905	12-May-22	BAGALKOT	110	110/11KV, HV2	SADALAGA_110	19:10	19:20	0:10	TRANSFORMER FAULT
906	12-May-22	BAGALKOT	110	SOUDATTI220- UDAKERI	SOUDATTI_220	15:05	16:46	1:41	LINE CLEAR AVAILED
907	12-May-22	BAGALKOT	110	SOUDATTI220- UDAKERI	UDAKERI_110	15:05	16:50	1:45	LINE CLEAR AVAILED
908	12-May-22	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED BELGAUM_220	11:45	17:05	5:20	LINE CLEAR AVAILED
909	13-May-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
910	13-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
911	13-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED LAXMESHVAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
912	13-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)	7:32 (13.05.2022)	210:12:00	LINE CHARGED
913	13-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)	7:32 (13.05.2022)	210:12:00	LINE CHARGED
914	13-May-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	9:18 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
915	13-May-22	BAGALKOT	110	AMBEWADI- NK1 (KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	9:30 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
916	13-May-22	BAGALKOT	110	AMBEWADI- NK2 (HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	9:33 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
917	13-May-22	BAGALKOT	110	BABLESHWAR- MAMADAPURA	BABLESHWAR_110	21:44 (12.05.2022)	14:25 (13.05.2022)	16:41	LINE CHARGED
918	13-May-22	BAGALKOT	110	BAGEWADI220-UKKALI	UKKALI_110	21:35 (12.05.2022)	13:15 (13.05.2022)	15:40	LINE CHARGED
919	13-May-22	BAGALKOT	110	MAMADAPUR- BABALESWAR	STATION NOT AFFECTED MAMADAPUR(B)_110	21:06 (12.05.2022)	14:05 (13.05.2022)	16:59:00	LINE CHARGED
920	13-May-22	BAGALKOT	220	BAGEWADI- ALAMATTI2	STATION NOT AFFECTED BAGEWADI_220	19:10 (12.05.2022)	8:27 (13.05.2022)	13:17	LINE CHARGED
921	13-May-22	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED MAHALINGAPUR_220	21:17 (12.05.2022)	7:29 (13.05.2022)	10:12	TRANSFORMER CHARGED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
922	13-May-22	BAGALKOT	110	ANKOLA- ARGA	ANKOLA_110	09:54	16:28	6:34	NFBC ISSUED
923	13-May-22	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110, KAROCHI_33,KERUR_33	12:02	13:23	1:21	LINE CLEAR AVAILED
924	13-May-22	BAGALKOT	110	HIREMASALI- KABBUR	HIREMASALI_110	15:15	15:19	0:04	LINE FAULT
925	13-May-22	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	17:09	17:14	0:05	TRANSFORMER FAULT
926	13-May-22	BAGALKOT	110	HUDALI-ANAKALAGI	HUDALI_110	10:00	16:32	6:32	LINE CLEAR AVAILED
927	13-May-22	BAGALKOT	110	BELGAUM220- HUDALI	HUDALI_110	10:00	16:28	6:28	LINE CLEAR AVAILED
928	13-May-22	BAGALKOT	110	HUDALI- BSPL	HUDALI_110	10:00	16:30	6:30	LINE CLEAR AVAILED
929	13-May-22	BAGALKOT	110	110/11KV, HV1(HV2)	STATION NOT AFFECTED ZALKI_110	11:04	11:19	0:15	HAND TRIPPED
930	13-May-22	BAGALKOT	110	YELLAMMANAWADI- SAVALAGI	STATION NOT AFFECTED YELLAMMANAWADI_110	09:46	17:43	7:57	LINE CLEAR AVAILED
931	13-May-22	BAGALKOT	110	110/33KV, HV3	TODALBAGI_33, BIDARI_33 JRK SOLAR_33 STATION NOT AFFECTED TODALBAGI_110	07:21	07:22	0:01	TRANSFORMER FAULT
932	13-May-22	BAGALKOT	110	110/33KV, HV3	TODALBAGI_33, BIDARI_33 JRK SOLAR_33 STATION NOT AFFECTED TODALBAGI_110	12:02	12:07	0:05	TRANSFORMER FAULT
933	13-May-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TOLAMATTI	08:40	09:10	0:30	LINE CLEAR AVAILED
934	13-May-22	BAGALKOT	110	TARIHAL- NAVANAGAR(H)(SRS HUBLI2)	STATION NOT AFFECTED TARIHAL_110	11:28	11:45	0:17	LINE FAULT
935	13-May-22	BAGALKOT	110	SAMBAPURROAD-RVNL RAILWAY(GADAG)	RAILWAY_110 STATION NOT AFFECTED SAMBAPURROAD_110	21:36	21:40	0:04	LINE FAULT
936	13-May-22	BAGALKOT	110	SALAHALLI-GMNAVAR	GMNAVAR_110 SALAHALLI_110	17:15	17:20	0:05	LINE FAULT
937	13-May-22	BAGALKOT	110	110/11KV, HV1	SALAHALLI_110	17:15	17:43	0:28	TRANSFORMER FAULT
938	13-May-22	BAGALKOT	110	SALAHALLI-GMNAVAR	GMNAVAR_110 SALAHALLI_110	18:53	18:58	0:05	HAND TRIPPED
939	13-May-22	BAGALKOT	110	110/11KV, HV1	SALAHALLI_110	18:53	18:59	0:06	HAND TRIPPED
940	13-May-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED PH COMPOUND_110	11:49	13:12	01:23	LINE CLEAR AVAILED
941	13-May-22	BAGALKOT	110	BIDNAL220-NAVALAGUND	STATION NOT AFFECTED NAVALAGUND_110	10:15	17:54	07:39	NFBC ISSUED
942	13-May-22	BAGALKOT	110	MURDESHWAR-KRCL RAILWAY (HONNAVAR)	KRCL RAILWAY_110 STATION NOT AFFECTED MURDESHWAR_110	21:36	21:45	00:09	LINE FAULT
943	13-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MALAGHAN(S)_110	11:53	13:34	01:41	LINE CLEAR AVAILED
944	13-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MALAGHAN(S)_110	19:00	19:15	00:15	LINE CLEAR AVAILED
945	13-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MALAGHAN(S)_110	20:15	20:26	00:11	LINE CLEAR AVAILED
946	13-May-22	BAGALKOT	110	BAGEWADI- MAMADAPUR1&2	MAMADAPUR(B)_110	13:40	14:08	00:28	HAND TRIPPED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
947	13-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MALAGHAN(B)_110	19:45	19:58	00:13	TRANSFORMER FAULT
948	13-May-22	BAGALKOT	110	KUMTA-KRCL RAILWAY(SIRSI)	KRCL RAILWAY_110 STATION NOT AFFECTED KUMTA_110	22:29	22:37	00:08	LINE FAULT
949	13-May-22	BAGALKOT	110	KUMTA-KRCL RAILWAY(SIRSI)	KRCL RAILWAY_110 STATION NOT AFFECTED KUMTA_110	22:55	23:03	00:08	LINE FAULT
950	13-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KUD DHARWAD_110	17:22	18:24	01:02	LINE CLEAR AVAILED
951	13-May-22	BAGALKOT	110	KONNUR-NAVALAGUND	KONNUR_110	10:02	10:08	00:06	HAND TRIPPED
952	13-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KAMBAGI_110	23:19	23:29	00:10	TRANSFORMER FAULT
953	13-May-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED CHIKKODI_220	14:03	14:50	00:47	LINE CLEAR AVAILED
954	13-May-22	BAGALKOT	110	110/11KV, HV2	ALMEL_110	10:52	15:13	04:21	LINE CLEAR AVAILED
955	13-May-22	BAGALKOT	110	HAVERI220- SAVANUR	HAVERI_220	05:43	05:58	00:15	LINE FAULT
956	13-May-22	BAGALKOT	400	400/220KV, ICT1	STATION NOT AFFECTED DHONI_400	10:30	21:20	10:50	LINE CLEAR AVAILED
957	13-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
958	13-May-22	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	21:15 (12.05.2022)	19:33 (13.05.2022)	22:18	TRANSFORMER CHARGED
959	13-May-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED BILAGI_110	10:20	10:40	00:20	LINE CLEAR AVAILED
960	13-May-22	BAGALKOT	110	110/11KV HV2	GULEDGUDDA_110	13:00	16:05	03:05	TRANSFORMER FAULT
961	13-May-22	BAGALKOT	110	BELGAUM220- HUDALI	HUDALI_110	10:27	16:29	06:02	LINE CLEAR AVAILED
962	13-May-22	BAGALKOT	220	CHIKKODI- MUDASHINGI	STATION NOT AFFECTED CHIKKODI_220	06:59	15:57	08:58	NFBC ISSUED
963	13-May-22	BAGALKOT	110	110/11KV, HV2	CHIKKODI_220	12:00	13:25	01:25	LINE CLEAR AVAILED
964	13-May-22	BAGALKOT	110	NAVANAGAR(H)- TARIHAL	STATION NOT AFFECTED NAVANAGAR(H)_110	11:27	15:29	04:02	LINE FAULT
965	13-May-22	BAGALKOT	110	110/11KV, HV2	KUD DHARWAD_110	17:20	18:25	01:05	LINE CLEAR AVAILED
966	13-May-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	07:25	15:20	07:55	HAND TRIPPED
967	13-May-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	07:25	15:27	08:02	HAND TRIPPED
968	13-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
969	13-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
970	13-May-22	BAGALKOT	110	SIRSI220- SIRSI1	SIRSI_220	07:25	07:41	00:16	HAND TRIPPED
971	13-May-22	BAGALKOT	110	SIRSI220- SIRSI2	SIRSI_220	07:25	07:41	00:16	HAND TRIPPED
972	13-May-22	BAGALKOT	110	SIRSI220- UMMACHAGI	SIRSI_220	07:25	07:37	00:12	HAND TRIPPED
973	13-May-22	BAGALKOT	110	110/11KV, HV1	AMBEWADI_220	10:45	12:57	02:12	LINE CLEAR AVAILED
974	14-May-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
975	14-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
976	14-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
977	14-May-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	9:18 (09.05.2022)	13:30 (14.05.2022)	124:12 hrs	LINE CHARGED
978	14-May-22	BAGALKOT	110	AMBEWADI- NK1 (KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	9:30 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
979	14-May-22	BAGALKOT	110	AMBEWADI- NK2 (HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	9:33 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
980	14-May-22	BAGALKOT	110	BJCTY(THORVI)-BHUTANAL	THORVI_110	05:45	06:00	0:15	MAIN SUPPLY FAILURE
981	14-May-22	BAGALKOT	110	BASAVANKATTI- F2(GUTTAL)	BASAVANKATTI_110	16:15	17:25	01:10	LINE CLEAR AVAILED
982	14-May-22	BAGALKOT	110	TODALABAGI-JAMAKHANDI SUGARS	JAMAKHANDI SUGARS_110 STATION NOT AFFECTED TODALABAGI_110	01:50	02:15	0:25	LINE FAULT
983	14-May-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED RATTIHALLI_110	11:35	15:33	3:58	LINE CLEAR AVAILED
984	14-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
985	14-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
986	14-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
987	14-May-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED THORVI_110	13:00	13:45	0:45	LINE CLEAR AVAILED
988	14-May-22	BAGALKOT	110	BJCTY(THORVI)-BHUTANAL	THORVI_110	11:45	11:55	0:10	MAIN SUPPLY FAILURE
989	14-May-22	BAGALKOT	110	BJCTY(THORVI)-BHUTANAL	THORVI_110	05:45	11:35	5:50	NFBC ISSUED
990	14-May-22	BAGALKOT	220	NARENDRA- BELGAUM1	STATION NOT AFFECTED NARENDRA_220	9:01 (14.05.2022)			LINE OPEN:LINE CLEAR AVAILED
991	14-May-22	BAGALKOT	220	NARENDRA- KANABARGI2 (BELGAUM2)	STATION NOT AFFECTED NARENDRA_220	13:33	19:47	06:14	NFBC ISSUED
992	14-May-22	BAGALKOT	110	110/11KV, HV1	MAREGUDDI_110	09:55	10:30	00:35	LINE CLEAR AVAILED
993	14-May-22	BAGALKOT	110	110/11KV, HV2	HALIYAL_110	17:00	17:15	00:15	TRANSFORMER FAULT
994	14-May-22	BAGALKOT	220	BELGAUM- NARENDRA1	STATION NOT AFFECTED BELGAUM_220	9:01 (14.05.2022)			LINE OPEN:LINE CLEAR AVAILED
995	14-May-22	BAGALKOT	220	BELGAUM- NARENDRA2	STATION NOT AFFECTED BELGAUM_220	13:33	14:12	00:39	HAND TRIPPED
996	14-May-22	BAGALKOT	220	BELGAUM- NARENDRA2	STATION NOT AFFECTED BELGAUM_220	19:15	19:47	00:32	HAND TRIPPED
997	15-May-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
998	15-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
999	15-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
1000	15-May-22	BAGALKOT	110	AMBEWADI- NK1 (KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	9:30 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1001	15-May-22	BAGALKOT	110	AMBEWADI- NK2 (HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	9:33 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1002	15-May-22	BAGALKOT	110	BELGAUM220-BLG110	BELGAUM_110	10:01	18:10	8:09	LINE CLEAR AVALIED
1003	15-May-22	BAGALKOT	110	110/11KV,HV1	BELGAUM_110	10:03	18:14	8:11	LINE CLEAR AVALIED
1004	15-May-22	BAGALKOT	110	110/11KV,HV2	BELGAUM_110	10:03	18:14	8:11	LINE CLEAR AVALIED
1005	15-May-22	BAGALKOT	110	110/33KV,HV4	BELGAUM_110	10:04	18:14	8:10	LINE CLEAR AVALIED
1006	15-May-22	BAGALKOT	110	110/11KV,HV1	CHIKKODI_110	10:08	18:30	8:22	LINE CLEAR AVALIED
1007	15-May-22	BAGALKOT	110	CHIKKODI220-CHIKKODI	CHIKKODI_110	12:06	18:32	6:26	LINE CLEAR AVALIED
1008	15-May-22	BAGALKOT	110	DAMBAL-ASE (SOLAR)	DAMBAL_110	18:07	18:23	0:16	LINE FAULT
1009	15-May-22	BAGALKOT	110	110/11KV, HV1	ITANAL_110	23:50 (15.05.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
1010	15-May-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TODALBAGI_110	17:53	18:03	0:10	TRANSFORMER FAULT
1011	15-May-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUDDEBIHAL_110	23:49	23:55	0:06:00	TRANSFORMER FAULT
1012	15-May-22	BAGALKOT	110	CHIKKODI220- SANKESHWAR	CHIKKODI_220	03:03	03:13	0:10	LINE FAULT
1013	15-May-22	BAGALKOT	110	110/33KV, HV1	CHIKKODI_220	10:10	18:25	8:15	LINE CLEAR AVALIED
1014	15-May-22	BAGALKOT	220	BELGAUM- NARENDRA2	STATION NOT AFFECTED BELGAUM_220	19:54	20:22	0:28	HAND TRIPPED
1015	15-May-22	BAGALKOT	110	HAVERI220- TILUVALLI	HAVERI_220	20:49	21:13	0:24	LINE FAULT
1016	15-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
1017	15-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVALIED
1018	15-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVALIED
1019	15-May-22	BAGALKOT	220	NARENDRA- BELGAUM1	STATION NOT AFFECTED NARENDRA_220	9:01 (14.05.2022)			LINE OPEN:LINE CLEAR AVALIED
1020	15-May-22	BAGALKOT	220	BELGAUM- NARENDRA1	STATION NOT AFFECTED BELGAUM_220	9:01 (14.05.2022)			LINE OPEN:LINE CLEAR AVALIED
1021	15-May-22	BAGALKOT	110	CHIKKODI220- CHIKKODI	CHIKKODI_220	12:05	18:25	06:20	LINE CLEAR AVALIED
1022	15-May-22	BAGALKOT	110	110/33KV, HV2	CHIKKODI_220	10:10	18:25	08:15	LINE CLEAR AVALIED
1023	15-May-22	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	12:24	15:59	03:35	LINE FAULT
1024	15-May-22	BAGALKOT	220	BELGAUM- NARENDRA2	STATION NOT AFFECTED BELGAUM_220	06:50	07:18	00:28	HAND TRIPPED
1025	15-May-22	BAGALKOT	220	BELGAUM- NARENDRA2	STATION NOT AFFECTED BELGAUM_220	19:54	20:22	00:28	HAND TRIPPED
1026	15-May-22	BAGALKOT	110	BELGAUM220- NEHRU NAGAR	NEHRU NAGAR_110	10:02	18:12	08:10	NFBC ISSUED
1027	15-May-22	BAGALKOT	220	MUGALKHOD- ITNAL	STATION NOT AFFECTED MUGALKHOD_220	22:06	22:12	00:06	LINE FAULT
1028	15-May-22	BAGALKOT	110	MUDHOL- KD JAMBAGI	MUDHOL_110	09:45	18:48	09:03	LINE CLEAR AVALIED
1029	16-May-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVALIED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1030	16-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1031	16-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHVAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
1032	16-May-22	BAGALKOT	110	AMBEWADI- NK1 (KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	9:30 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1033	16-May-22	BAGALKOT	110	AMBEWADI- NK2 (HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	9:33 (09.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1034	16-May-22	BAGALKOT	110	110/11KV, HV1	ITANAL_110	23:50 (15.05.2022)	00:00 (16.05.2022)	0:10	TRANSFORMER CHARGED
1035	16-May-22	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	17:28	18:36	1:08	TRANSFORMER FAULT
1036	16-May-22	BAGALKOT	110	BASAVANAKATTI-GUTTAL	STATION NOT AFFECTED BASAVANAKATTI_110	16:57 (16.05.2022)			LINE OPEN:LINE FAULT
1037	16-May-22	BAGALKOT	110	110/11KV,HV4(HV2)	CHIKKODI_110	17:25	18:30	1:05	LINE CLEAR AVALIED
1038	16-May-22	BAGALKOT	110	DAMBAL-MUNDARAGI	STATION NOT AFFECTED_ DAMBAL_110	17:08	18:13	1:05	LINE FAULT
1039	16-May-22	BAGALKOT	110	110/33KV,HV1	GADAG_110	11:12	12:30	1:18	LINE CLEAR AVALIED
1040	16-May-22	BAGALKOT	110	110/11KV,HV1	GULEDAGUDDA_110	10:15	10:20	0:05	HAND TRIPPED
1041	16-May-22	BAGALKOT	110	SIRSI1-KUMTA	STATION NOT AFFECTED KUMTA_110	22:08 (16.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1042	16-May-22	BAGALKOT	110	SIRSI2-KUMTA	STATION NOT AFFECTED KUMTA_110	21:18 (16.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1043	16-May-22	BAGALKOT	110	110/11KV,HV1	MUDDEBIHAL_110	12:34	14:30	1:56	LINE CLEAR AVALIED
1044	16-May-22	BAGALKOT	110	110/11KV,HV1	MALGHAN(S)_110	07:45	08:30	00:45	LINE CLEAR AVALIED
1045	16-May-22	BAGALKOT	110	KUDCHI220-TERDAL(MORAB)	MORAB_110	04:22	04:52	00:30	LINE FAULT
1046	16-May-22	BAGALKOT	110	110/11KV, HV3(HV4)	STATION NOT AFFECTED TODALABAGI_110	11:31	13:36	02:05	HAND TRIPPED
1047	16-May-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TODALABAGI_110	17:30	18:11	00:41	LINE CLEAR AVALIED
1048	16-May-22	BAGALKOT	110	TIKOTA-BHUTNAL(TAKKALAKI)	STATION NOT AFFECTED TIKOTA_110	06:00	08:34	02:34	NFBC ISSUED
1049	16-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TERADAL_110	18:51	18:55	00:04	HAND TRIPPED
1050	16-May-22	BAGALKOT	110	SIRSI-KUMTA2	STATION NOT AFFECTED SIRSI_110	21:19			LINE OPEN:LINE FAULT
1051	16-May-22	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	18:00	18:04	00:04	LINE FAULT
1052	16-May-22	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	18:13	18:28	00:15	LINE FAULT
1053	16-May-22	BAGALKOT	110	MUNDARGI-VIJAYA SUGARS	VIJAYA SUGARS_110 STATION NOT AFFECTED MUNDARGI_110	17:05	18:36	01:31	LINE FAULT
1054	16-May-22	BAGALKOT	220	BELGAUM- AEQUS1	STATION NOT AFFECTED BELGAUM_220	10:39 (16.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1055	16-May-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	07:44	21:42	13:58	HAND TRIPPED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1056	16-May-22	BAGALKOT	220	HUBLI- SIRSI1	STATION NOT AFFECTED HUBLI_220	12:49	17:50	5:01	LINE FAULT
1057	16-May-22	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	10:36	17:48	7:12	NFBC ISSUED
1058	16-May-22	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTED NARENDRA_220	17:18	19:19	2:01	LINE CLEAR AVAILED
1059	16-May-22	BAGALKOT	110	110/11KV, HV1	YARAGATTI_110	14:09	15:04	00:55	TRANSFORMER FAULT
1060	16-May-22	BAGALKOT	220	AEQUS- CHIKKODI	STATION NOT AFFECTED AEQUS_220	9:24	10:36	01:12	HAND TRIPPED
1061	16-May-22	BAGALKOT	220	BIDNAL- HUBLI1	STATION NOT AFFECTED BIDNAL_220	16:28	16:43	00:15	HAND TRIPPED
1062	16-May-22	BAGALKOT	220	220/110KV, HV3 & LV3	STATION NOT AFFECTED CHIKKODI_220	15:20	18:30	03:10	LINE CLEAR AVAILED
1063	16-May-22	BAGALKOT	220	HAVERI- GUTTUR1	STATION NOT AFFECTED HAVERI_220	17:56	23:18	05:22	LINE FAULT
1064	16-May-22	BAGALKOT	220	HAVERI- GUTTUR2	STATION NOT AFFECTED HAVERI_220	17:56 (16.05.2022)			LINE OPEN:LINE FAULT
1065	16-May-22	BAGALKOT	110	HAVERI220- TILUVALLI (HANGAL)	STATION NOT AFFECTED HAVERI_220	18:53	19:17	00:24	LINE FAULT
1066	16-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
1067	16-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1068	16-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1069	16-May-22	BAGALKOT	220	NARENDRA- BELGAUM1	STATION NOT AFFECTED NARENDRA_220	9:01 (14.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1070	16-May-22	BAGALKOT	220	BELGAUM- NARENDRA1	STATION NOT AFFECTED BELGAUM_220	9:01 (14.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1071	16-May-22	BAGALKOT	110	BELGAUM220- VADAGOAN	VADAGOAN_110	11:42	11:47	0:05	MAIN SUPPLY FAILURE
1072	16-May-22	BAGALKOT	110	BELGAUM220- MACHE	MACHE_110	11:42	11:47	0:05	MAIN SUPPLY FAILURE
1073	16-May-22	BAGALKOT	220	SIRSI-SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	14:01	14:47	0:46	LINE FAULT
1074	16-May-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED SIRSI_220	14:31	14:35	0:04	TRANSFORMER FAULT
1075	16-May-22	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED SIRSI_220	14:01	16:02	2:01	TRANSFORMER FAULT
1076	16-May-22	BAGALKOT	110	SOUDATTI220- BENAKATTI	SOUDATTI_220	14:09	14:22	00:13	LINE FAULT
1077	16-May-22	BAGALKOT	110	SOUDATTI220- UDAKERI	SOUDATTI_220	16:02	17:27	01:25	LINE CLEAR AVAILED
1078	16-May-22	BAGALKOT	110	BENAKATTI - YARGATTI	YARAGATTI_110	14:09	14:42	00:33	MAIN SUPPLY FAILURE
1079	16-May-22	BAGALKOT	110	BENAKATTI- KATAKOL	KATAKOL_110	14:05	14:43	00:38	MAIN SUPPLY FAILURE
1080	12-May-22	MYSURU	66	TUBINAKERE- NAGAMANGALA 1	NO STATIONS EFFECTED	16:20	16:25	00:05	LINE FAULT
1081	12-May-22	MYSURU	66	C R NAGARA-HONGANURU	YELANDUR_66 HONGANUR_66	20:05	20:12	00:07	LINE FAULT
1082	12-May-22	MYSURU	66	HV1	CHUNCHUNKATTE_66	10:10	15:45	05:35	TRANSFORMER FAULT
1083	12-May-22	MYSURU	66	HARVEY-THAMADALLI LIS	NO STATIONS EFFECTED	10:15	10:30	00:15	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1084	12-May-22	MYSURU	66	PARINAMIPURA-THALAKADU	THALAKADU_66 CHANDALLI_66	18:19	18:24	00:05	LINE FAULT
1085	12-May-22	MYSURU	66	MAMBALLI-YELANDUR	NO STATIONS EFFECTED	20:05	20:10	00:05	LINE FAULT
1086	12-May-22	MYSURU	66	HV2	NAGAMANGALA_66	10:50	11:47	00:57	LINE CLEAR AVAILED
1087	12-May-22	MYSURU	66	MALAVALLI-SHIMSHA	MALAVALLI_66	10:09	10:44	00:35	LINE CLEAR AVAILED
1088	12-May-22	MYSURU	66	HV2	JAIPUR_66	07:50	08:53	01:03	LINE CLEAR AVAILED
1089	12-May-22	MYSURU	66	HV2	DATTAGALLY_66	09:10	10:20	01:10	LINE CLEAR AVAILED
1090	12-May-22	MYSURU	66	HV1	FTS_66	16:13	16:36	00:22	LINE CLEAR AVAILED
1091	12-May-22	MYSURU	220	HOOTAGALLY-KADAKOLA	NO STATIONS EFFECTED	11:32:00 (12/5/2022)			LINE OPEN:LINE CLEAR AVAILED
1092	12-May-22	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57:05 (4/5/2022)			LINE OPEN:LINE CLEAR AVAILED
1093	12-May-22	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1094	12-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1095	12-May-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1096	12-May-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
1097	12-May-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
1098	12-May-22	MYSURU	220	HOOTAGALLI-BARC2	NO STATIONS EFFECTED	20:30:00 (11/5/2022)	11:38:00 (12/5/2022)	15:08:00	LINE CHARGED
1099	12-May-22	MYSURU	66	SFC-5MW	NO STATIONS EFFECTED	22:12:00 (11/5/2022)	6:12:00 (12/5/2022)	08:00:00	HAND TRIPPED
1100	13-May-22	MYSURU	66	HV2	ADDIHALLI_66	17:41	17:46	00:04	LOAD CURTAILMENT
1101	13-May-22	MYSURU	66	HV1	BGNAGARA_66	17:41	17:51	00:09	LOAD CURTAILMENT
1102	13-May-22	MYSURU	66	HV1	BGPURA_66	17:41	18:17	00:35	LOAD CURTAILMENT
1103	13-May-22	MYSURU	66	HV1	DEVANOORNGUDU_66	15:44	17:15	01:30	LINE CLEAR AVAILED
1104	13-May-22	MYSURU	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR STATION INTERRUPTED.	16:52	17:00	00:08	HAND TRIPPED
1105	13-May-22	MYSURU	66	HV1	DODDINADUVADI_66	17:42	17:53	00:11	LOAD CURTAILMENT
1106	13-May-22	MYSURU	66	HV2	DODDARAYAPET_66	17:42	18:00	00:17	LOAD CURTAILMENT
1107	13-May-22	MYSURU	66	HAMPAPURA-BASARALU	NO STATIONS INTERRUPTED.	11:14	14:09	02:54	LINE CLEAR AVAILED
1108	13-May-22	MYSURU	66	HV1	HAMPAPURA_66	13:00	14:03	01:03	LINE CLEAR AVAILED
1109	13-May-22	MYSURU	66	HAMPAPURA-CHIKKAMANDYA	NO STATIONS INTERRUPTED.	14:10	14:56	00:46	NFBC ISSUED
1110	13-May-22	MYSURU	66	HARADANAHALLI(JAK)-LAXJEET	NO STATIONS EFFECTED	16:50	17:00	00:10	LINE FAULT
1111	13-May-22	MYSURU	66	HV2	HDKOTE_66	17:42	17:50	00:07	LOAD CURTAILMENT
1112	13-May-22	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66, SUTTUR_66	09:22	09:35	00:12	LINE FAULT
1113	13-May-22	MYSURU	66	HV1	KIKKERI_66	17:40	17:42	00:02	LOAD CURTAILMENT
1114	13-May-22	MYSURU	66	HV2	KIKKERI_66	17:41	17:43	00:01	LOAD CURTAILMENT
1115	13-May-22	MYSURU	66	HV2	KMDODDI_66	17:43	17:51	00:08	LOAD CURTAILMENT
1116	13-May-22	MYSURU	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	06:20	06:22	00:02	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1117	13-May-22	MYSURU	66	HV2	KOLLEGALA_66	17:43	17:44	00:01	LOAD CURTAILMENT
1118	13-May-22	MYSURU	66	HV1	KUSHALANAGARA_66	17:41	17:46	00:04	LOAD CURTAILMENT
1119	13-May-22	MYSURU	66	MADUHVANAHALLIHANNU R 1	NO STATIONS EFFECTED	10:36	10:41	00:05	LINE FAULT
1120	13-May-22	MYSURU	66	MADUHVANAHALLI- LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	11:07	11:12	00:05	LINE FAULT
1121	13-May-22	MYSURU	66	HV1	MALAVALLI_66	12:38	13:02	00:23	LINE CLEAR AVAILED
1122	13-May-22	MYSURU	66	HV1	NAGAMANGALA_66	17:43	17:49	00:05	LOAD CURTAILMENT
1123	13-May-22	MYSURU	66	HV2	SANTHESARAGUR_66	17:43	17:48	00:05	LOAD CURTAILMENT
1124	13-May-22	MYSURU	66	HV2	SANTHEMARAHALLI_66	17:43	17:48	00:04	LOAD CURTAILMENT
1125	13-May-22	MYSURU	66	HV1	SANIVARASANTHE_66	10:00	15:27	05:27	MAIN SUPPLY FAILURE
1126	13-May-22	MYSURU	66	HV2	SANIVARASANTHE_66	10:00	14:55	04:55	MAIN SUPPLY FAILURE
1127	13-May-22	MYSURU	66	HV5	SFCSHIVA_66	02:42	04:01	01:19	HAND TRIPPED
1128	13-May-22	MYSURU	66	SFC SIVA-5 MW	NO STATIONS EFFECTED	11:01	11:05	00:04	LINE FAULT
1129	13-May-22	MYSURU	66	SFC SIVA-10 MW	NO STATIONS EFFECTED	11:01	11:03	00:02	LINE FAULT
1130	13-May-22	MYSURU	66	VADKEPURA-KIRUGAVLU	MALIYURU_66 KIRUGAVALU_66	11:00	11:11	00:11	LINE FAULT
1131	13-May-22	MYSURU	66	HV1	YERALLI HAND POST_66	18:20	18:30	00:10	TRANSFORMER FAULT
1132	13-May-22	MYSURU	220	HOOTAGALLY-KADAKOLA	NO STATIONS EFFECTED	11:32:00 (12/5/2022)			LINE OPEN:LINE CLEAR AVAILED
1133	13-May-22	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57:05 (4/5/2022)			LINE OPEN:LINE CLEAR AVAILED
1134	13-May-22	MYSURU	66	DUNDANAHALLY- HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1135	13-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1136	13-May-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1137	13-May-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
1138	13-May-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
1139	14-May-22	MYSURU	220	CR NAGAR- MADHUVANAHALLI2	NO STATIONS EFFECTED	13:53	14:36	00:42	LINE FAULT
1140	14-May-22	MYSURU	66	D R PETE-KUNTHUR	SANTHEMARALLI_66	18:34	18:39	00:05	LINE FAULT
1141	14-May-22	MYSURU	66	HV1	HARADANAHALLI(JAK)_66	09:24	12:33	03:09	TRANSFORMER FAULT
1142	14-May-22	MYSURU	66	HV1	K_HONNALGERE_66	12:26	12:55	00:29	LINE CLEAR AVAILED
1143	14-May-22	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	00:13	00:18	00:04	LINE FAULT
1144	14-May-22	MYSURU	66	MANDYA-TUBINAKERE	NO STATIONS EFFECTED	12:16	12:22	00:05	HAND TRIPPED
1145	14-May-22	MYSURU	66	HV2	NAGAMANGALA_66	09:27	12:12	02:45	LINE CLEAR AVAILED
1146	14-May-22	MYSURU	66	HV2	NAGAMANGALA_66	12:12	17:28	05:15	LINE CLEAR AVAILED
1147	14-May-22	MYSURU	66	VAJMANGALA-KADKOLA2	NO STATIONS EFFECTED	05:16	05:24	00:08	LINE FAULT
1148	14-May-22	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	12:03:00 (14.5.2022)			LINE OPEN:LINE FAULT
1149	14-May-22	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57:05 (4/5/2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1150	14-May-22	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1151	14-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1152	14-May-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1153	14-May-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
1154	14-May-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
1155	15-May-22	MYSURU	66	GUNDALPETE-KABBALLI	NO STATIONS EFFECTED	07:28	07:37	00:08	LINE FAULT
1156	15-May-22	MYSURU	66	PERIAPATNA-HANGUDU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	03:37	03:45	00:08	LINE FAULT
1157	15-May-22	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	HARADANAHALLI(JAK)_66 SHIVALLY_66	06:05	19:11	13:05	LINE CLEAR AVAILED
1158	15-May-22	MYSURU	66	HV2	ANEGOLAL_66	14:19	14:36	00:17	TRANSFORMER FAULT
1159	15-May-22	MYSURU	66	HV2	SHEELUNERE_66	13:20	13:30	00:10	TRANSFORMER FAULT
1160	15-May-22	MYSURU	66	PARINAMIPURA-THALAKADU	CHANDALLI_66 THALAKADU_66	21:37	21:42	00:05	LINE FAULT
1161	15-May-22	MYSURU	66	G UKKADA- S R PATNA	SRIRANGAPATNA_66	17:42	17:47	00:05	LINE FAULT
1162	15-May-22	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	6:10:00 AM (15/05/2022)			LINE OPEN:LINE CLEAR AVAILED
1163	15-May-22	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	12:03:00 (14.5.2022)			LINE OPEN:LINE FAULT
1164	15-May-22	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57:05 (4/5/2022)			LINE OPEN:LINE CLEAR AVAILED
1165	15-May-22	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1166	15-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1167	15-May-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1168	15-May-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
1169	15-May-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
1170	16-May-22	MYSURU	66	CRNAGARA-HONNALLY	ATTIGULIPURA_66 ARAKALAVADI_66 HONNALLY_MYS_66	10:32	10:49	00:17	LINE FAULT
1171	16-May-22	MYSURU	66	HV1	HEBBAL_66	03:04	03:19	00:15	TRANSFORMER FAULT
1172	16-May-22	MYSURU	66	K R PETE 220-SANTHEBACHALLI 2	NO STATIONS EFFECTED	22:04	22:11	00:07	LINE FAULT
1173	16-May-22	MYSURU	220	HV2	NAGAMANGALA_220	16:44	17:34	00:50	TRANSFORMER FAULT
1174	16-May-22	MYSURU	66	MADHUVANAHALI-KOLLEGALA	NO STATIONS EFFECTED	08:14	08:19	00:05	LINE FAULT
1175	16-May-22	MYSURU	66	MADHUVANAHALI-KOLLEGALA	NO STATIONS EFFECTED	15:57	16:02	00:05	LINE FAULT
1176	16-May-22	MYSURU	220	VAJAMANGALA-TKHALLI	NO STATIONS EFFECTED	12:17	18:55	06:38	LINE FAULT
1177	16-May-22	MYSURU	66	VAJAMANGALA-DEVANUR	NO STATIONS EFFECTED	13:18	14:35	01:17	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1178	16-May-22	MYSURU	66	HUNSUR-ILAWALA	NO STATIONS EFFECTED	08:30	08:45	00:15	LINE FAULT
1179	16-May-22	MYSURU	66	MALAVALLI-SHIMSHA	MALAVALLI_66	12:18	12:48	00:30	LINE FAULT
1180	16-May-22	MYSURU	66	K M DODDI-T K HALLI	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 KHONNALAGERE_66 SOMANAHALLI_66 TUMBEKERE _66 TALAGAVADI_66	12:16	12:43	00:27	MAIN SUPPLY FAILURE
1181	16-May-22	MYSURU	66	MUGUR-THAYUR	THAYURU_66 TNARASIPURA_66	09:55	10:00	00:05	LINE FAULT
1182	16-May-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20/03/2022)	12:39:00 (16/05/2022)	0:20 hrs	HAND TRIPPED
1183	16-May-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20/03/2022)	12:35:00 (16/05/2022)	0:50 hrs	HAND TRIPPED
1184	16-May-22	MYSURU	66	BGNAGARA-HV2	BGNAGARA_66	10:40:00 PM (16/05/2022)			LINE OPEN:LINE CLEAR AVAILED
1185	16-May-22	MYSURU	66	MALAVALLI-K K HALLI	NO STATIONS EFFECTED	12:18:00 PM (16/05/2022)			LINE OPEN:LINE FAULT
1186	16-May-22	MYSURU	66	TUBINAKERE- NAGAMANGALA 1	NO STATIONS EFFECTED	6:10:00 AM (15/05/2022)			LINE OPEN:LINE CLEAR AVAILED
1187	16-May-22	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	12:03:00 (14.5.2022)			LINE OPEN:LINE FAULT
1188	16-May-22	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57:05 (4/5/2022)			LINE OPEN:LINE CLEAR AVAILED
1189	16-May-22	MYSURU	66	DUNDANAHALLY- HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1190	16-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1191	16-May-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1192	12-May-22	TUMKUR	220	TR-1(HV SIDE)	PAVAGADA_220	20:25	20:45	00:20	TRANSFORMER FAULT
1193	12-May-22	TUMKUR	220	TR-2(HV SIDE)	PAVAGADA_220	20:25	20:45	00:20	TRANSFORMER FAULT
1194	12-May-22	TUMKUR	220	THALLAK 220kV- CHITRADURGA_220	THALLAK_220	08:04	11:08		LINE OPEN:LINE CLEAR AVAILED
1195	12-May-22	TUMKUR	220	TR-2	KBCROSS_220	21:04	22:20	01:16	TRANSFORMER FAULT
1196	12-May-22	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	06:05	06:25	00:20	LINE CLEAR AVAILED
1197	12-May-22	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	06:05	18:25	12:20	LINE FAULT
1198	12-May-22	TUMKUR	110	KB CROSS 220kV- GUNGURUMALE 110	GUNGURUMALE_110	14:15	14:48	00:33	LINE CLEAR AVAILED
1199	12-May-22	TUMKUR	110	TR-1	NITTUR_220	15:39	15:57	00:18	LINE CLEAR AVAILED
1200	12-May-22	TUMKUR	110	TR-2	NITTUR_220	15:39	15:57	00:18	LINE CLEAR AVAILED
1201	12-May-22	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	ANCHEPALYA_220	11:02	13:32	02:30	LINE CLEAR AVAILED
1202	12-May-22	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,YEDAVAN I_66	06:37	06:51	00:14	LINE FAULT
1203	12-May-22	TUMKUR	66	BENKIKERE220- HOSADURGA66 1	HOSADURGA_66	17:20	18:23	01:03	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1204	12-May-22	TUMKUR	66	BENKIKERE220-HOSADURGA66 2	HOSADURGA_66	17:20	18:23	01:03	LINE CLEAR AVAILED
1205	12-May-22	TUMKUR	66	PAVAGADA220-SHYLAPURA_66	SHYLAPURA_66	20:25	20:45	00:20	LINE FAULT
1206	12-May-22	TUMKUR	66	PAVAGADA220-NAGALAMADIKE66	PAVAGADA_220	20:25	20:45	00:20	LINE FAULT
1207	12-May-22	TUMKUR	66	PAVAGADA220-MEDEGESHI66	MEDIGESHI_66,I D HALLI_66,HOSKERE_66	20:25	20:45	00:20	LINE FAULT
1208	12-May-22	TUMKUR	66	PAVAGADA220-PAVAGADA2	PAVAGADA_220	20:25	20:45	00:20	LINE FAULT
1209	12-May-22	TUMKUR	66	PAVAGADA220-Y N HOSAKOTE_66	HOSAKOTE_66	20:25	20:45	00:20	LINE FAULT
1210	13-May-22	TUMKUR	220	KB CROSS 220kV-SHIMOGA1	KBCROSS_220	07:25	17:16	09:51	MAIN SUPPLY FAILURE
1211	13-May-22	TUMKUR	66	ANCHEPALYA 220kV-VIJAYA STEEL	VIJAYA STEEL	12:45	16:16	03:31	LINE CLEAR AVAILED
1212	13-May-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	20:51	20:56	00:05	LINE FAULT
1213	13-May-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	22:10	22:21	00:11	LINE FAULT
1214	13-May-22	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	11:30	19:45	08:15	LINE FAULT
1215	13-May-22	TUMKUR	66	MADHUGIRI 220kV-MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	19:04	19:43	00:39	HAND TRIPPED
1216	13-May-22	TUMKUR	66	PAVAGADA220-MIDIGESHI	MIDIGESHI_66	23:13	23:25	00:12	LINE FAULT
1217	14-May-22	TUMKUR	220	TR-2	KBCROSS_220	20:22	22:04	01:42	TRANSFORMER FAULT
1218	14-May-22	TUMKUR	220	TR-2	KIADB_220	13:29	15:24	01:55	TRANSFORMER FAULT
1219	14-May-22	TUMKUR	66	ANCHEPALYA 220kV-VIJAYA STEEL	VIJAYA STEEL	11:36	12:38	01:02	LINE CLEAR AVAILED
1220	14-May-22	TUMKUR	66	CHITRADURGA 220kV-SUZLON 2	SUZLON2_IPP_66	00:30	01:26	00:56	LINE FAULT
1221	14-May-22	TUMKUR	66	CHITRADURGA 220kV-SUZLON 2	SUZLON2_IPP_66	16:25	16:35	00:10	LINE FAULT
1222	14-May-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	05:01	05:11	00:10	LINE FAULT
1223	14-May-22	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	11:00	16:48	05:48	LINE CLEAR AVAILED
1224	14-May-22	TUMKUR	66	KDBVNP- TMTP	TMTP_66	12:15	12:50	00:35	LINE CLEAR AVAILED
1225	14-May-22	TUMKUR	66	SIRA220 - BUKKAPATNA	BUKKAPATNA_66	01:14	01:40	00:26	LINE FAULT
1226	14-May-22	TUMKUR	66	SIRA220-PATNAYAKANAHALLI 2	PATNAYAKANAHALLI LINE2	05:35	05:45	00:10	LINE FAULT
1227	15-May-22	TUMKUR	66	ANTHRASANAHALLI 220KV-KORA	KORA_66, THOVINAKERE_66	14:45	15:03	00:18	LINE CLEAR AVAILED
1228	15-May-22	TUMKUR	66	GUTTUR220-HALASABALU	HALASABALU_66	05:36	05:45	00:09	LINE FAULT
1229	15-May-22	TUMKUR	66	MADHUGIRI 220kV-NITRAHALLI	NITRAHALLI_66	17:27	17:40	00:13	LINE FAULT
1230	16-May-22	TUMKUR	220	TR-1	DAVANGERE_220	17:19	17:56	00:37	TRANSFORMER FAULT
1231	16-May-22	TUMKUR	220	TR-2(HV-2)	DAVANGERE_220	17:20	17:30	00:10	TRANSFORMER FAULT
1232	16-May-22	TUMKUR	220	TR-2(LV-2)	DAVANGERE_220	17:20	17:30	00:10	TRANSFORMER FAULT
1233	16-May-22	TUMKUR	220	TR-1(HV-1)	GUTTUR_220	11:47	16:17	04:30	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1234	16-May-22	TUMKUR	220	TR-1(HV-1)	THALLAK_220	17:24	18:12	00:48	TRANSFORMER FAULT
1235	16-May-22	TUMKUR	220	TR-1(LV-1)	THALLAK_220	17:24	18:13	00:49	TRANSFORMER FAULT
1236	16-May-22	TUMKUR	220	TR-2	K B CROSS	11:04	14:35	03:31	LINE CLEAR AVAILED
1237	16-May-22	TUMKUR	220	TR-2	K B CROSS	23:41(16.5.22)	0:23(17.5.22)	00:42	TRANSFORMER CHARGED
1238	16-May-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	17:01	17:40	00:39	LINE FAULT
1239	16-May-22	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJHALLI_66	17:20	17:32	00:12	HAND TRIPPED
1240	16-May-22	TUMKUR	66	DAVANGERE220kV- DAVANGERE	DAVANAGERE_66	17:20	17:31	00:11	HAND TRIPPED
1241	16-May-22	TUMKUR	66	DAVANGERE SRS- HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	17:20	17:33	00:13	HAND TRIPPED
1242	16-May-22	TUMKUR	66	GUTTUR220-HALASABALU	HALASABALU_66	17:35	17:50	00:15	LINE FAULT
1243	16-May-22	TUMKUR	66	GUTTUR220-HALASABALU	HALASABALU_66	17:50	22:13	04:23	LINE FAULT
1244	16-May-22	TUMKUR	66	THALLAK 220kV- CHALLAKERE1	CHALLAKERE_66, SANIKERE_66	17:24	18:14	00:50	LINE FAULT
1245	16-May-22	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66	17:24	18:16	00:52	LINE FAULT
1246	16-May-22	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	18:38	19:06	00:28	LINE FAULT
1247	16-May-22	TUMKUR	66	CHITRADURGA 220kV- HGML(HIRIYUR)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	11:40	14:03	02:23	HAND TRIPPED
1248	16-May-22	TUMKUR	66	CHITRADURGA 220kV- SUZLON 2	SUZLON2_IPP_66	10:56	11:03	00:07	LINE FAULT
1249	16-May-22	TUMKUR	66	CHITRADURGA 220kV- SUZLON 2	SUZLON2_IPP_66	19:15	19:47	00:32	LINE FAULT
1250	16-May-22	TUMKUR	66	DAVANGERE SRS- HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	17:35(16.5.22)			LINE OPEN:LINE CLEAR AVALIED
1251	12-May-22	HASSAN	66	RAMNAT- KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVALIED
1252	12-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVALIED
1253	12-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVALIED
1254	12-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVALIED
1255	12-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVALIED
1256	12-May-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	9:54 (9.05.2022)			LINE OPEN:LINE CLEAR AVALIED
1257	12-May-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	13:00 (10.05.2022)			LINE OPEN:LINE CLEAR AVALIED
1258	12-May-22	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	10:59	13:56	02:57	LINE CLEAR AVALIED
1259	12-May-22	HASSAN	110	HV2	ANAVATTI_110	13:05	13:25	00:20	TRANSFORMER FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1260	12-May-22	HASSAN	110	HV2	ARASIKERE_110	20:44	21:33	00:49	TRANSFORMER FAULT
1261	12-May-22	HASSAN	110	HV1	BELAGUMBA_110	10:20	15:20	05:00	LINE CLEAR AVAILED
1262	12-May-22	HASSAN	110	HV2	BELAGUMBA_110	10:20	15:20	05:00	LINE CLEAR AVAILED
1263	12-May-22	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	23:24	23:54	00:30	MAIN SUPPLY FAILURE
1264	12-May-22	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	23:24	23:54	00:30	MAIN SUPPLY FAILURE
1265	12-May-22	HASSAN	110	GURUVA-SLVPWR	GURUVAYANKERE_110	23:24	23:54	00:30	MAIN SUPPLY FAILURE
1266	12-May-22	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	23:23	23:53	00:30	LINE FAULT
1267	12-May-22	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	23:23	23:52	00:29	LINE FAULT
1268	12-May-22	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	06:04	06:42	00:38	LINE FAULT
1269	12-May-22	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:29	13:25	02:56	LINE CLEAR AVAILED
1270	12-May-22	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	13:32	16:18	02:46	LINE CLEAR AVAILED
1271	12-May-22	HASSAN	110	HV1	MADHUVANA_110	12:32	13:45	01:13	LINE CLEAR AVAILED
1272	12-May-22	HASSAN	66	HV1	BASAVAGHATTA_66	15:30	16:03	00:33	LINE CLEAR AVAILED
1273	12-May-22	HASSAN	66	HASSN22-BELUR	HASSAN_220	11:25	13:06	01:41	LINE CLEAR AVAILED
1274	12-May-22	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	11:33	13:06	01:33	HAND TRIPPED
1275	12-May-22	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	11:47	11:51	00:04	HAND TRIPPED
1276	12-May-22	HASSAN	66	HV2	HOLALUR_66	09:20	10:10	00:50	LINE CLEAR AVAILED
1277	12-May-22	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	15:05	15:24	00:19	LINE FAULT
1278	12-May-22	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPPLU_66	11:33	13:00	01:27	HAND TRIPPED
1279	12-May-22	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPPLU_66	13:02	13:07	00:05	MAIN SUPPLY FAILURE
1280	13-May-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1281	13-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1282	13-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1283	13-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1284	13-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1285	13-May-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	9:54 (9.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1286	13-May-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	13:00 (10.05.2022)	0:23 (13.05.2022)	59:23 hrs	LINE CHARGED
1287	13-May-22	HASSAN	400	HASSAN4-TLGP400	HASSAN_400	07:24	10:38	03:14	LINE FAULT
1288	13-May-22	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	07:24	10:38	03:14	LINE FAULT
1289	13-May-22	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	07:24	09:57	02:33	MAIN SUPPLY FAILURE
1290	13-May-22	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	07:24	10:14	02:50	MAIN SUPPLY FAILURE
1291	13-May-22	HASSAN	220	TALAGU-STRP1	TALAGUPPA_400	07:24	10:34	03:10	MAIN SUPPLY FAILURE
1292	13-May-22	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	07:24	14:04	06:40	MAIN SUPPLY FAILURE
1293	13-May-22	HASSAN	220	KEMAR-Kavoor3	KEMAR_220	10:06	15:35	05:29	NFBC ISSUED
1294	13-May-22	HASSAN	220	GERSOPA-TALGUPA1	gen_gerusoppa	07:33	08:06	00:33	LINE FAULT
1295	13-May-22	HASSAN	220	HV1	HASSAN_220	10:33	13:10	02:37	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1296	13-May-22	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	10:00	14:48	04:48	LINE CLEAR AVAILED
1297	13-May-22	HASSAN	66	HASSN22-HN PURA	HASSAN_220	10:27	13:20	02:53	HAND TRIPPED
1298	13-May-22	HASSAN	66	LV1	HASSAN_220	10:33	13:10	02:37	LINE CLEAR AVAILED
1299	13-May-22	HASSAN	66	HASSN22-MALLALI	HASSAN_220	10:26	13:20	02:54	HAND TRIPPED
1300	13-May-22	HASSAN	66	HASSN22-SKPURA	HASSAN_220	10:33	10:45	00:12	HAND TRIPPED
1301	13-May-22	HASSAN	66	HASSN22-SKPURA	HASSAN_220	13:13	13:19	00:06	HAND TRIPPED
1302	13-May-22	HASSAN	220	KAVOOR--KEMAR3	KAVOOR_220	10:07	15:35	05:28	LINE CLEAR AVAILED
1303	13-May-22	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	07:24	07:47	00:23	LINE FAULT
1304	13-May-22	HASSAN	220	MRSSHM-CHMLR	MRSMG_220	07:24	07:53	00:29	LINE FAULT
1305	13-May-22	HASSAN	220	MRSSHM-HASSAN	MRSMG_220	07:24	08:47	01:23	LINE FAULT
1306	13-May-22	HASSAN	220	MRSSHM-HONNALLI	MRSMG_220	07:24	08:48	01:24	LINE FAULT
1307	13-May-22	HASSAN	220	MRSSHM-HSN4001	MRSMG_220	07:24	08:21	00:57	LINE FAULT
1308	13-May-22	HASSAN	220	HV1	MRSMG_220	07:24	07:59	00:35	TRANSFORMER FAULT
1309	13-May-22	HASSAN	220	HV2	MRSMG_220	07:24	08:02	00:38	TRANSFORMER FAULT
1310	13-May-22	HASSAN	220	HV3	MRSMG_220	07:24	08:03	00:39	TRANSFORMER FAULT
1311	13-May-22	HASSAN	220	MRSSHM-KADUR	MRSMG_220	07:24	08:48	01:24	LINE FAULT
1312	13-May-22	HASSAN	220	MRSSHM-KBCRS	MRSMG_220	07:24	07:53	00:29	LINE FAULT
1313	13-May-22	HASSAN	220	MRSSHM-KBCRS	MRSMG_220	07:24	08:06	00:42	LINE FAULT
1314	13-May-22	HASSAN	220	MRSSHM-STRP1	MRSMG_220	07:24	08:06	00:42	LINE FAULT
1315	13-May-22	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMG_220	07:24	08:28	01:04	LINE FAULT
1316	13-May-22	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	07:24	19:17	11:53	LINE FAULT
1317	13-May-22	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	07:24	09:25	02:01	LINE FAULT
1318	13-May-22	HASSAN	220	MRSSHM-VARAH1	MRSMG_220	07:24	07:49	00:25	LINE FAULT
1319	13-May-22	HASSAN	220	MRSSHM-VARAH12	MRSMG_220	07:24	07:50	00:26	LINE FAULT
1320	13-May-22	HASSAN	220	MRSSHM-VARAH13	MRSMG_220	07:24	07:50	00:26	LINE FAULT
1321	13-May-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMG_220	07:24	08:30	01:06	LINE FAULT
1322	13-May-22	HASSAN	110	MRSSHM-BADRAVATY2	MRSMG_220	07:24	08:30	01:06	LINE FAULT
1323	13-May-22	HASSAN	110	MRSSHM-BADRAVATY3	MRSMG_220	07:24	07:56	00:32	LINE FAULT
1324	13-May-22	HASSAN	110	MRSSHM-GAJNUR	MRSMG_220	07:24	08:29	01:05	LINE FAULT
1325	13-May-22	HASSAN	110	LV1	MRSMG_220	07:24	08:00	00:36	TRANSFORMER FAULT
1326	13-May-22	HASSAN	110	LV2	MRSMG_220	07:24	07:55	00:31	TRANSFORMER FAULT
1327	13-May-22	HASSAN	110	LV3	MRSMG_220	07:24	08:04	00:40	TRANSFORMER FAULT
1328	13-May-22	HASSAN	110	MRSSHM-MPM	MRSMG_220	07:24	08:41	01:17	LINE FAULT
1329	13-May-22	HASSAN	110	MRSSHM-MYSORE	MRSMG_220	07:24	08:27	01:03	LINE FAULT
1330	13-May-22	HASSAN	110	MRSSHM-SS1	MRSMG_220	07:24	08:17	00:53	LINE FAULT
1331	13-May-22	HASSAN	110	MRSSHM-SS2	MRSMG_220	07:24	08:17	00:53	LINE FAULT
1332	13-May-22	HASSAN	66	MRSSHM-BD-1	MRSMG_220	07:24	08:19	00:55	LINE FAULT
1333	13-May-22	HASSAN	66	MRSSHM-BD-2	MRSMG_220	07:24	08:19	00:55	LINE FAULT
1334	13-May-22	HASSAN	66	MRSSHM-DVG2	MRSMG_220	07:24	08:25	01:01	LINE FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1335	13-May-22	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	07:24	08:25	01:01	LINE FAULT
1336	13-May-22	HASSAN	220	SHRAVTY-SHIMOGA 2	gen_sharavathy	07:24	19:17	11:53	LINE FAULT
1337	13-May-22	HASSAN	220	SHRAVTY-SHIMOGA1	gen_sharavathy	07:24	19:17	11:53	LINE FAULT
1338	13-May-22	HASSAN	220	SHRAVTY-SHIMOGA3	gen_sharavathy	07:24	19:17	11:53	LINE FAULT
1339	13-May-22	HASSAN	220	SHRAVTY-SHIRALKOPPA	gen_sharavathy	07:24	10:02	02:38	LINE FAULT
1340	13-May-22	HASSAN	220	SHRAVTY-SHIMOGA4	gen_sharavathy	07:24	10:02	02:38	LINE FAULT
1341	13-May-22	HASSAN	220	SHRAVTY-SIRISI 1	gen_sharavathy	07:24	15:28	08:04	HAND TRIPPED
1342	13-May-22	HASSAN	220	SHRAVTY-SIRISI 2	gen_sharavathy	07:24	15:28	08:04	HAND TRIPPED
1343	13-May-22	HASSAN	220	SHRAVTY-TALAGUPPA 2	gen_sharavathy	07:24	09:58	02:34	HAND TRIPPED
1344	13-May-22	HASSAN	220	SHRAVTY-TALAGUPPA1	gen_sharavathy	07:24	10:14	02:50	HAND TRIPPED
1345	13-May-22	HASSAN	220	SHRAVTY-SGS	SHIRALKOPPA_220	07:24	10:02	02:38	LINE FAULT
1346	13-May-22	HASSAN	220	VARAHI-KEMAR3	gen_varahi	13:50	14:40	00:50	LINE FAULT
1347	13-May-22	HASSAN	220	VARAHI-SHIMOGA1	gen_varahi	07:24	07:52	00:28	LINE FAULT
1348	13-May-22	HASSAN	220	VARAHI-SHIMOGA2	gen_varahi	07:24	07:53	00:29	LINE FAULT
1349	13-May-22	HASSAN	220	VARAHI-SHMG3	gen_varahi	07:24	07:53	00:29	LINE FAULT
1350	13-May-22	HASSAN	110	HV2	BANAVARA_110	14:30	15:40	01:10	LINE CLEAR AVAILED
1351	13-May-22	HASSAN	110	HV2	BADRAVATHY_110	15:35	16:35	01:00	LINE CLEAR AVAILED
1352	13-May-22	HASSAN	110	HV2	GERUMARA_110	17:42	18:02	00:20	LOAD CURTAILMENT
1353	13-May-22	HASSAN	110	HV2	HOSANGADI_110	11:51	17:08	05:17	LINE CLEAR AVAILED
1354	13-May-22	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	11:46	12:02	00:16	MAIN SUPPLY FAILURE
1355	13-May-22	HASSAN	110	HV4	MANIPAL_110	09:29	09:50	00:21	LINE CLEAR AVAILED
1356	13-May-22	HASSAN	110	HV2	NAVUNDA_110	14:17	14:30	00:13	TRANSFORMER FAULT
1357	13-May-22	HASSAN	110	SAGARA-JST2	SAGARA_110	07:20	08:25	01:05	MAIN SUPPLY FAILURE
1358	13-May-22	HASSAN	110	HV1	TOGARSI_110	14:01	15:13	01:12	TRANSFORMER FAULT
1359	13-May-22	HASSAN	110	HV2	VITTALA_110	10:50	14:55	04:05	LINE CLEAR AVAILED
1360	13-May-22	HASSAN	110	HV2	VITTALA_110	11:45	11:53	00:08	HAND TRIPPED
1361	13-May-22	HASSAN	110	HV2	VITTALA_110	12:46	13:04	00:18	HAND TRIPPED
1362	13-May-22	HASSAN	110	VITTAL-PUTR_SLTUR	VITTALA_110	11:45	11:53	00:08	HAND TRIPPED
1363	13-May-22	HASSAN	66	HV1	HANGARAHALLI_66	17:42	17:50	00:08	LOAD CURTAILMENT
1364	13-May-22	HASSAN	66	HV1	MALLIPATNA_66	10:00	14:50	04:50	MAIN SUPPLY FAILURE
1365	13-May-22	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	10:00	14:50	04:50	MAIN SUPPLY FAILURE
1366	13-May-22	HASSAN	66	HV1	MOSALEHOSAHALLI_66	09:40	09:45	00:05	HAND TRIPPED
1367	13-May-22	HASSAN	66	HV2	RAMESHWARNAGAR_66	17:41	18:01	00:20	LOAD CURTAILMENT
1368	13-May-22	HASSAN	66	HV1	SAKALESHPURA_66	15:55	16:36	00:41	LINE CLEAR AVAILED
1369	13-May-22	HASSAN	66	HV2	SAKALESHPURA_66	15:55	16:12	00:17	LINE CLEAR AVAILED
1370	13-May-22	HASSAN	66	HV2	SALAGAME_66	17:41	17:55	00:14	LOAD CURTAILMENT
1371	13-May-22	HASSAN	66	TAVAREC-HONNALI	TAVARECHATNAHALLI_66	07:25	08:56	01:31	MAIN SUPPLY FAILURE
1372	13-May-22	HASSAN	66	HV1	YESLUR_66	10:00	14:55	04:55	MAIN SUPPLY FAILURE
1373	13-May-22	HASSAN	66	YESLUR-SNVRSNT	YESLUR_66	10:00	13:50	03:50	MAIN SUPPLY FAILURE

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1374	14-May-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1375	14-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1376	14-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1377	14-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1378	14-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1379	14-May-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	9:54 (9.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1380	14-May-22	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	12:59	13:28	00:29	LINE FAULT
1381	14-May-22	HASSAN	220	GERSOPA-TALGUPA1	gen_gerusoppa	12:59	13:28	00:29	LINE FAULT
1382	14-May-22	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	09:29	13:05	03:36	LINE FAULT
1383	14-May-22	HASSAN	220	KEMAR-Varahi1	KEMAR_220	09:21	11:30	02:09	NFBC ISSUED
1384	14-May-22	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	09:29	13:05	03:36	LINE FAULT
1385	14-May-22	HASSAN	220	VARAHI-KEMAR1	gen_varahi	09:21	11:30	02:09	LINE CLEAR AVAILED
1386	14-May-22	HASSAN	220	VARAHI-KEMAR2	gen_varahi	16:20	17:13	00:53	LINE FAULT
1387	14-May-22	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	10:35	13:52	03:17	NFBC ISSUED
1388	14-May-22	HASSAN	66	HV2	HOLALUR_66	11:47	12:30	00:43	LINE CLEAR AVAILED
1389	14-May-22	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	15:05	15:10	00:05	HAND TRIPPED
1390	15-May-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1391	15-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1392	15-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1393	15-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1394	15-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1395	15-May-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	9:54 (9.05.2022)	19:20(15.05.2022)	153:25 hrs	LINE CHARGED
1396	15-May-22	HASSAN	110	KADUR-TNGL	KADUR_220	10:13	10:27	00:14	LINE FAULT
1397	15-May-22	HASSAN	66	HV1	HIREMANGALUR_66	17:16	17:44	00:28	LINE CLEAR AVAILED
1398	15-May-22	HASSAN	66	HV1	SAKALESHPURA_66	16:23	16:44	00:21	TRANSFORMER FAULT
1399	15-May-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	09:32	19:20	09:48	LINE CLEAR AVAILED
1400	16-May-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1401	16-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1402	16-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1403	16-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1404	16-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1405	16-May-22	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	19:49(16.05.2022)			LINE OPEN:LINE FAULT
1406	16-May-22	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	20:14(16.05.2022)			LINE OPEN:LINE FAULT
1407	16-May-22	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	19:50(16.05.2022)			LINE OPEN:LINE FAULT
1408	16-May-22	HASSAN	220	SHRAVTY-TALAGUPPA1	sharavathy_gen	20:17 (16.05.2022)			LINE OPEN:LINE FAULT
1409	16-May-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	17:02(16.05.2022)			LINE OPEN:LINE FAULT
1410	16-May-22	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	17:05(16.05.2022)			LINE OPEN:LINE FAULT
1411	16-May-22	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_110	22:50(16.05.2022)			LINE OPEN:LINE FAULT
1412	16-May-22	HASSAN	66	HV1	HOLEHONNUR_66	21:15 (16.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1413	16-May-22	HASSAN	220	HGUNJE-KMR	HEGGUNJE_220	11:18	13:35	02:17	LINE FAULT
1414	16-May-22	HASSAN	110	HGUNJE-LN1	HEGGUNJE_220	11:18	11:29	00:11	LINE FAULT
1415	16-May-22	HASSAN	110	HGUNJE-LN2	HEGGUNJE_220	11:17	11:31	00:14	LINE FAULT
1416	16-May-22	HASSAN	110	HV1	HEGGUNJE_220	12:20	12:26	00:06	TRANSFORMER FAULT
1417	16-May-22	HASSAN	110	LV2	HEGGUNJE_220	11:16	11:30	00:14	TRANSFORMER FAULT
1418	16-May-22	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	17:26	18:00	00:34	LINE FAULT
1419	16-May-22	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	17:32	17:45	00:13	HAND TRIPPED
1420	16-May-22	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	17:52	18:10	00:18	LINE FAULT
1421	16-May-22	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	17:27	17:56	00:29	LINE FAULT
1422	16-May-22	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	17:25	17:55	00:30	LINE FAULT
1423	16-May-22	HASSAN	220	KEMAR-Varahi2	KEMAR_220	19:10	19:18	00:08	LINE FAULT
1424	16-May-22	HASSAN	220	KEMAR-Varahi3	KEMAR_220	11:10	13:34	02:24	LINE FAULT
1425	16-May-22	HASSAN	110	HV2	KEMAR_220	22:31	22:52	00:21	TRANSFORMER FAULT
1426	16-May-22	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	10:23	11:53	01:30	LINE CLEAR AVAILED
1427	16-May-22	HASSAN	110	KEMAR-MOODABIDRI	KEMAR_220	17:06	17:31	00:25	LINE FAULT
1428	16-May-22	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	10:08	17:48	07:40	HAND TRIPPED
1429	16-May-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	18:35	20:44	02:09	LINE FAULT
1430	16-May-22	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	18:15	20:44	02:29	LINE FAULT
1431	16-May-22	HASSAN	110	MRSSHM-MPM	MRSMSG_220	18:22	20:42	02:20	LINE FAULT
1432	16-May-22	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	17:32	18:01	00:29	LINE FAULT
1433	16-May-22	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	17:32	17:46	00:14	LINE FAULT
1434	16-May-22	HASSAN	110	MSEZ-BAIKAMPADY	MSEZ_220	17:32	18:26	00:54	LINE FAULT
1435	16-May-22	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	17:42	18:14	00:32	LINE FAULT
1436	16-May-22	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	10:08	17:48	07:40	LINE CLEAR AVAILED
1437	16-May-22	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	18:01	19:12	01:11	HAND TRIPPED
1438	16-May-22	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	14:01	14:48	00:47	LINE FAULT
1439	16-May-22	HASSAN	220	HV2	SHIRALKOPPA_220	11:15	17:13	05:58	LINE CLEAR AVAILED
1440	16-May-22	HASSAN	110	LV2	SHIRALKOPPA_220	11:15	17:13	05:58	LINE CLEAR AVAILED
1441	16-May-22	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	19:07	19:31	00:24	LINE FAULT
1442	16-May-22	HASSAN	110	ALKOLA-SAGAR	ALKOLA_110	19:47	20:00	00:13	LINE FAULT
1443	16-May-22	HASSAN	110	HV2	ANANDPURA_110	11:22	14:22	03:00	TRANSFORMER FAULT

SL NO	Date	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1444	16-May-22	HASSAN	110	HV2	ANANDPURA_110	14:32	18:09	03:37	LINE CLEAR AVAILED
1445	16-May-22	HASSAN	110	ANANDA-LPH(LST-4)	ANANDPURA_110	19:43	20:02	00:19	LINE FAULT
1446	16-May-22	HASSAN	110	HV2	BAIKAMPADY_110	20:08	21:02	00:54	LINE CLEAR AVAILED
1447	16-May-22	HASSAN	110	HV2	BAIKAMPADY_110	21:15	22:18	01:03	LINE CLEAR AVAILED
1448	16-May-22	HASSAN	110	BAIKAM-KAVOOR	BAIKAMPADY_110	17:30	18:10	00:40	MAIN SUPPLY FAILURE
1449	16-May-22	HASSAN	110	HV1	BARANGI_110	07:28	07:33	00:05	HAND TRIPPED
1450	16-May-22	HASSAN	110	HV1	BARANGI_110	15:08	15:38	00:30	HAND TRIPPED
1451	16-May-22	HASSAN	110	HV2	BARANGI_110	07:28	07:33	00:05	HAND TRIPPED
1452	16-May-22	HASSAN	110	HV2	BARANGI_110	16:04	16:08	00:04	HAND TRIPPED
1453	16-May-22	HASSAN	110	HV1	BRAHMAVARA_110	23:33	23:39	00:06	TRANSFORMER FAULT
1454	16-May-22	HASSAN	110	GURUPUR-MDBDRE	GURUPURA_110	17:50	18:19	00:29	MAIN SUPPLY FAILURE
1455	16-May-22	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	11:18	11:35	00:17	MAIN SUPPLY FAILURE
1456	16-May-22	HASSAN	110	HV2	HOSANGADI_110	12:31	16:17	03:46	LINE CLEAR AVAILED
1457	16-May-22	HASSAN	110	SAGARA-SS2	SAGARA_110	19:40	20:00	00:20	LINE FAULT
1458	16-May-22	HASSAN	110	SAGARA-SS1	SAGARA_110	19:40	20:00	00:20	LINE FAULT
1459	16-May-22	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:38	10:42	00:04	LINE CLEAR AVAILED
1460	16-May-22	HASSAN	66	ALDUR-MUGLUR	ALDUR_66	11:03	11:08	00:05	NFBC ISSUED
1461	16-May-22	HASSAN	66	HV1	RAMPURA_66	18:20	18:50	00:30	TRANSFORMER FAULT
1462	16-May-22	HASSAN	66	HV2	RAMPURA_66	18:20	18:50	00:30	TRANSFORMER FAULT
1463	16-May-22	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	14:40	14:55	00:15	LINE FAULT
1464	16-May-22	HASSAN	66	HV1	SINGAPURA_66	07:15	08:10	00:55	LINE CLEAR AVAILED