

400/220/110/66 kV TRANSMISSION OUTAGES: 01.09.2020 to 07.09.2020

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
1	1-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
2	1-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
3	1-Sep-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
4	1-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
5	1-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
6	1-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN, LINE CLEAR AVAILED
7	1-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
8	1-Sep-2020	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN, LINE CLEAR AVAILED
9	1-Sep-2020	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
10	1-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26 (17.08.2020)	9:20 (01.09.2020)	481:46hrs	LINE CHARGED
11	1-Sep-2020	BAGALKOT	220	GADAG-HARTHI1	STATION NOT AFFECTED GADAG_220	12:19 (17.08.2020)	16:09 (01.09.2020)	364:28hrs	LINE CHARGED
12	1-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
13	1-Sep-2020	BAGALKOT	110	220/110KV,LV 1	STATION NOT AFFECTED BAGALKOT_220	13:05 (27.08.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
14	1-Sep-2020	BAGALKOT	220	BIDNAL-TADAS2 (HIREBENDIGERI2)	STATION NOT AFFECTED BIDNAL_220	11:42 (29.08.2020)	18:05 (01.09.2020)	77:47hrs	LINE CHARGED
15	1-Sep-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1&2(NANDIHAL1&2)	STATION NOT AFFECTED BAGEWADI_220	13:20 (29.08.2020)			LOAD CURTAILMENT
16	1-Sep-2020	BAGALKOT	220	AMBEWADI-NAGJHARI 2	STATION NOT AFFECTED AMBEWADI_220	17:16 (31.08.2020)	7:45 (01.09.2020)	33:31hrs	LINE CHARGED
17	1-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
18	1-Sep-2020	BAGALKOT	110	BIDNAL-NAVALGUND	NO STATION AFFECTED NAVLGUND_110	18:19 (31.08.2020)	12:52 (01.09.2020)	18:33hrs	LINE CHARGED
19	1-Sep-2020	BAGALKOT	110	AMBEWADI(KAVALWADA)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	13:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
20	1-Sep-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
21	1-Sep-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
22	1-Sep-2020	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	9:33	18:49	9:16	LINE CLEAR AVAILED
23	1-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	17:20 (01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
24	1-Sep-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	22:03 (01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
25	1-Sep-2020	BAGALKOT	110	BELGAUM-ANKALAGI	ANKALAGI_110	15:19	16:43	1:24	LINE CLEAR AVAILED
26	1-Sep-2020	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	16:07	16:13	0:06	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
27	1-Sep-2020	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110	16:04	16:07	0:03	LINE FAULT
28	1-Sep-2020	BAGALKOT	110	SUZLON-BYDAGI	BYADAGI_110	16:07	16:26	0:19	LINE FAULT
29	1-Sep-2020	BAGALKOT	220	220/110KV,HV 2 & LV 2	GHATAPRABHA_220	10:41	11:04	0:23	TRANSFORMER FAULT
30	1-Sep-2020	BAGALKOT	110	110/11KV,HV2	HIDIKAL DAM_110	16:49	17:31	0:42	LINE CLEAR AVAILED
31	1-Sep-2020	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	10:07	10:23	0:16	TRANSFORMER FAULT
32	1-Sep-2020	BAGALKOT	110	SHIRAGIPPI SUGARS-KAGAWAD	KAGAWAD_110	14:44	16:35	1:51	LINE CLEAR AVAILED
33	1-Sep-2020	BAGALKOT	110	SHIRAGIPPI SUGARS-KAGAWAD	KAGAWAD_110	21:15	21:25	0:10	LINE FAULT
34	1-Sep-2020	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51 (01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
35	1-Sep-2020	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	2:04	6:55	4:51	LINE CLEAR AVAILED
36	1-Sep-2020	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	2:04	7:18	5:14	LINE CLEAR AVAILED
37	1-Sep-2020	BAGALKOT	110	RANEENNUR-GUTTAL	STATION NOT AFFECTED GUTTAL_110	8:55	11:04	2:09	LINE CLEAR AVAILED
38	1-Sep-2020	BAGALKOT	110	SIRSI220-SIRSI2	STATION NOT AFFECTED SIRSI_110	15:31	15:32	0:01	HAND TRIPPED
39	1-Sep-2020	BAGALKOT	110	TUMMINAKATTI-RATTIHALLI	STATION NOT AFFECTED RATTIHALLI_110	8:35	9:54	1:19	LINE CLEAR AVAILED
40	1-Sep-2020	BAGALKOT	110	110/33KV,HV1	TIKOTA_110,BIJJARGI_33	8:54	9:02	0:08	TRANSFORMER FAULT
41	1-Sep-2020	BAGALKOT	110	110/11KV,HV2	TODALBAGI_110	9:04	11:34	2:30	TRANSFORMER FAULT
42	1-Sep-2020	BAGALKOT	220	NARENDRA-AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	9:33	18:49	9:16	LINE CLEAR AVAILED
43	1-Sep-2020	BAGALKOT	220	NARENDRA-HUBLI1	STATION NOT AFFECTED NARENDRA_220	11:52	14:57	3:05	LINE FAULT
44	1-Sep-2020	BAGALKOT	220	NARENDRA-HUBLI2	STATION NOT AFFECTED NARENDRA_220	15:02	16:03	1:01	LINE CLEAR AVAILED
45	1-Sep-2020	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_110	11:34	16:37	5:03	LINE FAULT
46	1-Sep-2020	BENGALURU	220	DB PURA 220 - NELAMANGALA 1	NO STATION AFFECTED	06:23	10:45	04:21	LINE FAULT
47	1-Sep-2020	BENGALURU	220	NELMANGALA 400 - DB PURA 1	NO STATION AFFECTED	06:23	10:45	04:21	LINE FAULT
48	1-Sep-2020	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPAHALLI	03:47	05:25	01:38	LINE FAULT
49	1-Sep-2020	BENGALURU	66	BIDADI 220 - COCO COLA (EHT)	COCO COLA (EHT)	03:47	05:35	01:48	MAIN SUPPLY FAILURE
50	1-Sep-2020	BENGALURU	66	BIDADI 220 - BOSCH (EHT)	BOSCH (EHT)	03:47	05:10	01:23	MAIN SUPPLY FAILURE
51	1-Sep-2020	BENGALURU	66	BIDADI 220 - EPIPL (EHT)	EPIPL (EHT)	03:47	05:38	01:51	MAIN SUPPLY FAILURE
52	1-Sep-2020	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	03:47	05:12	01:25	MAIN SUPPLY FAILURE
53	1-Sep-2020	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	06:27	06:43	00:16	LINE FAULT
54	1-Sep-2020	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	06:45	07:08	00:23	LINE FAULT
55	1-Sep-2020	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	08:06	08:12	00:06	LINE FAULT
56	1-Sep-2020	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	08:17	08:19	00:02	LINE FAULT
57	1-Sep-2020	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	08:21	08:42	00:21	LINE FAULT
58	1-Sep-2020	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	08:58	09:02	00:04	LINE FAULT
59	1-Sep-2020	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	09:45	10:18	00:33	LINE FAULT
60	1-Sep-2020	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	10:50	10:58	00:08	LINE FAULT
61	1-Sep-2020	BENGALURU	66	HV2	CHATRA	14:30	15:24	00:54	LINE CLEAR AVAILED
62	1-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
63	1-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
64	1-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
65	1-Sep-2020	GULBARGA	220	HUMNABAD-SEDAM2	SEDAM_220	12:14	12:30	00:16	LINE FAULT
66	1-Sep-2020	GULBARGA	110	RAJESHWAR-SASTHAPUR	SASTHAPUR_110	20:00(31.08.2020)	14:55(01.09.2020)	18:55 HRS	LINE CHARGED
67	1-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	22:08	22:17	00:09	LINE FAULT
68	1-Sep-2020	GULBARGA	110	HV1	SHAHAPUR_220	14:46	16:48	02:02	TRANSFORMER FAULT
69	1-Sep-2020	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGSARFACTORY_I PP,CHOWDAPUR_110	05:12	05:18	00:06	LINE FAULT
70	1-Sep-2020	GULBARGA	110	MASKI- SINDHANOOR	MASKI_110	19:50	20:03	00:13	LINE FAULT
71	1-Sep-2020	GULBARGA	110	MASKI-RENEWSOALR_IPP	MASKI_110	18:30	22:04	03:34	LINE CLEAR AVAILED
72	1-Sep-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPSW ATERWORKS	03:25	13:25	10:00	LINE FAULT
73	1-Sep-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPSW ATERWORKS	14:45	14:55	00:10	LINE FAULT
74	1-Sep-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPSW ATERWORKS	15:00	15:45	00:45	LINE FAULT
75	1-Sep-2020	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	15:29	15:50	00:21	LINE FAULT
76	1-Sep-2020	GULBARGA	110	RAJESHWAR-SASTHAPUR	SASTHAPUR_110	11:10	14:54	03:44	LINE CLEAR AVAILED
77	1-Sep-2020	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN, LINE CLEAR AVAILED
78	1-Sep-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	9:11 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
79	1-Sep-2020	HASSAN	220	VARAHI-KEMAR3	varahi_gen	9:11 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
80	1-Sep-2020	HASSAN	110	HALADY11-HIRIYADKA	HALADY_110	9:27 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
81	1-Sep-2020	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	9:27 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
82	1-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:11 (31.08.2020)	7:26 (1.09.2020)	8:15hrs	LINE CHARGED
83	1-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:54 (30.08.2020)	9:55 (1.09.2020)	35:01hrs	LINE CHARGED
84	1-Sep-2020	HASSAN	220	TALAGU-NELAMANGALA#2	TALAGUPPA_400	18:14 (1.09.2020)			LINE OPEN, LINE CLEAR AVAILED
85	1-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:47 (1.09.2020)			LINE OPEN, LINE CLEAR AVAILED
86	1-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	17:20 (1.09.2020)			LINE OPEN, LINE CLEAR AVAILED
87	1-Sep-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	7:40 (1.09.2020)			LINE OPEN, LINE CLEAR AVAILED
88	1-Sep-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	7:40 (1.09.2020)			LINE OPEN, LINE CLEAR AVAILED
89	1-Sep-2020	HASSAN	66	HV2	UDAYAPURA_66	23:38 (1.09.2020)			LINE OPEN, LINE CLEAR AVAILED
90	1-Sep-2020	HASSAN	400	TSALGU-NELAMANGALA#2	TALAGUPPA_400	02:02	16:43	14:41	LINE CLEAR AVAILED
91	1-Sep-2020	HASSAN	220	UPCL-KEMAR2	upcl_gen	12:27	15:48	03:21	LINE CLEAR AVAILED
92	1-Sep-2020	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	12:43	13:17	00:34	LINE FAULT
93	1-Sep-2020	HASSAN	220	KEMAR-UPCL2	KEMAR_220	12:26	15:47	03:21	LINE CLEAR AVAILED
94	1-Sep-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	12:43	13:41	00:58	LINE FAULT
95	1-Sep-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	13:47	15:35	01:48	LINE CLEAR AVAILED
96	1-Sep-2020	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	12:44	15:37	02:53	LINE FAULT
97	1-Sep-2020	HASSAN	110	HV3	BHADRAVATHI_110	20:45	20:50	00:05	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
98	1-Sep-2020	HASSAN	110	HV2	HALADY_110	19:07	20:05	00:58	TRANSFORMER FAULT
99	1-Sep-2020	HASSAN	110	HV2	HALADY_110	20:09	20:10	00:01	HAND TRIPPED
100	1-Sep-2020	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	10:25	16:30	06:05	LINE CLEAR AVAILED
101	1-Sep-2020	HASSAN	66	HV1	AREHALLI_HSN_66	10:20	11:25	01:05	LINE CLEAR AVAILED
102	1-Sep-2020	HASSAN	66	HV1	AREHALLI_HSN_66	11:30	11:35	00:05	TRANSFORMER FAULT
103	1-Sep-2020	HASSAN	66	HV1	AREHALLI_HSN_66	11:45	12:00	00:15	TRANSFORMER FAULT
104	1-Sep-2020	HASSAN	66	HV1	AREHALLI_HSN_66	12:05	12:25	00:20	TRANSFORMER FAULT
105	1-Sep-2020	HASSAN	66	HV1	AREHALLI_HSN_66	15:45	16:55	01:10	LINE CLEAR AVAILED
106	1-Sep-2020	HASSAN	66	HV1	AREHALLI_HSN_66	17:35	17:45	00:10	TRANSFORMER FAULT
107	1-Sep-2020	HASSAN	66	HV2	CHIKMAGALUR_66	11:41	12:01	00:20	LINE CLEAR AVAILED
108	1-Sep-2020	HASSAN	66	HV1	DUDDA_66	15:07	15:23	00:16	TRANSFORMER FAULT
109	1-Sep-2020	HASSAN	66	HV1	DUDDA_66	16:50	17:05	00:15	TRANSFORMER FAULT
110	1-Sep-2020	HASSAN	66	HV1	DUDDA_66	17:47	18:00	00:13	TRANSFORMER FAULT
111	1-Sep-2020	HASSAN	66	HASSN220-ARAKALGUD	HASSAN_220	05:37	05:53	00:16	LINE FAULT
112	1-Sep-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	19:33	19:55	00:22	LINE FAULT
113	1-Sep-2020	HASSAN	66	HV1	MAGGE_66	19:33	20:01	00:28	MAIN SUPPLY FAILURE
114	1-Sep-2020	HASSAN	66	HV2	MAGGE_66	19:33	20:01	00:28	MAIN SUPPLY FAILURE
115	1-Sep-2020	HASSAN	66	SAKALE-HASSAN	SAKALESHPURA_66	19:35	20:15	00:40	LINE FAULT
116	1-Sep-2020	MYSORE	66	HV1	AKKIHEBBAL_66	18:33	19:10	0:36	LINE CLEAR AVAILED
117	1-Sep-2020	MYSORE	66	HV1	AKKIHEBBAL_66	19:10	19:50	0:40	TRANSFORMER FAULT
118	1-Sep-2020	MYSORE	66	FTS-HOOTAGALLY 1	NO STATIONS EFFECTED	15:31	17:15	1:43	LINE CLEAR AVAILED
119	1-Sep-2020	MYSORE	66	KUSHALNAGARA-BYLUKUPPE	BYLUKUPPE_66	14:01	14:11	0:10	LINE FAULT
120	1-Sep-2020	MYSORE	66	HOOTAGALLI-MCF	BELAGOLA_66	8:00 (01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
121	1-Sep-2020	MYSORE	66	TUBINKERE-NAGMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	18:47	18:55	0:08	LINE FAULT
122	1-Sep-2020	MYSORE	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	13:55	14:32	0:37	LINE FAULT
123	1-Sep-2020	MYSORE	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
124	1-Sep-2020	MYSORE	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	11:10 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
125	1-Sep-2020	MYSORE	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	10:12 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
126	1-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN , TRANSFORMER FAULT
127	1-Sep-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
128	1-Sep-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	5:38:51 (01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
129	1-Sep-2020	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	5:46:08 (01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
130	1-Sep-2020	TUMKUR	110	HONNAVALI 110-DMKURKE	DMKURKE_110	23:50:28(31.08.2020)	00:58:47 (01.09.2020)	1:08:00	LINE CHARGED
131	1-Sep-2020	TUMKUR	220	CHITRADURGA 220kV- THALLAK 220	CHITRADURGA_220	6:09	19:22	13:13	LINE CLEAR AVAILED
132	1-Sep-2020	TUMKUR	220	THALLAK 220kV-CHITRADURGA	THALLAKK_220	6:12	19:13	13:01	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
133	1-Sep-2020	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	6:24	6:26	0:01	HAND TRIPPED
134	1-Sep-2020	TUMKUR	66	TR-2(HV SIDE)	CHITRADURGA_220	6:09	19:23	13:14	LINE CLEAR AVAILED
135	1-Sep-2020	TUMKUR	66	TR-1LV SIDE)	CHITRADURGA_220	6:15	19:23	13:07	LINE CLEAR AVAILED
136	1-Sep-2020	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	6:19	19:23	13:04	LINE CLEAR AVAILED
137	1-Sep-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	19:45	21:32	1:47	TRANSFORMER FAULT
138	1-Sep-2020	TUMKUR	66	TR-1	HANAGAL_66	7:56	9:22	1:26	LINE CLEAR AVAILED
139	1-Sep-2020	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	9:49	9:53	0:04	HAND TRIPPED
140	1-Sep-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	12:59	13:58	0:59	LINE FAULT
141	1-Sep-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	18:18	18:27	0:09	LINE FAULT
142	1-Sep-2020	TUMKUR	66	TR-2	MANGALWADA_66	18:51	18:56	0:04	TRANSFORMER FAULT
143	1-Sep-2020	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	13:36	13:53	0:17	TRANSFORMER FAULT
144	1-Sep-2020	TUMKUR	66	TR-1	VENKATAPURA_66	6:05	6:18	0:13	TRANSFORMER FAULT
145	1-Sep-2020	TUMKUR	66	TR-2	MATHOD_66	10:39	10:42	0:03	TRANSFORMER FAULT
146	1-Sep-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	19:22	19:26	0:04	TRANSFORMER FAULT
147	1-Sep-2020	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	8:48	8:55	0:06	LINE FAULT
148	1-Sep-2020	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	19:50	20:02	0:12	LINE FAULT
149	2-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020			LINE OPEN, LINE CLEAR AVAILED
150	2-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020			LINE OPEN, LINE CLEAR AVAILED
151	2-Sep-2020	BAGALKOT	110	110/11KV, HV2	VAJRAMATTI_110	15:44	17:10	01:26	TRANSFORMER FAULT
152	2-Sep-2020	BAGALKOT	110	110/11KV, HV2	VAJRAMATTI_110	15:44	17:10	01:26	TRANSFORMER FAULT
153	2-Sep-2020	BAGALKOT	110	110/11KV, HV3	SAVALGI_110	15:30	15:50	00:20	LINE CLEAR AVAILED
154	2-Sep-2020	BAGALKOT	110	110/11KV, HV3	SAVALGI_110	15:30	15:50	00:20	LINE CLEAR AVAILED
155	2-Sep-2020	BAGALKOT	110	110/33KV HV2	ANKOLA_110 ,SEABIRD_33,MASTIKATTA_33	16:58	17:24	00:26	TRANSFORMER FAULT
156	2-Sep-2020	BAGALKOT	110	110/33KV HV2	ANKOLA_110 ,SEABIRD_33,MASTIKATTA_33	16:58	17:24	00:26	TRANSFORMER FAULT
157	2-Sep-2020	BAGALKOT	110	110/33KV HV3	GADAG_110, LAKKUNDI_33, HULAKOTI_33, KHB_33, TDPL1&2_IPP, PIONEER_IPP, NAGAVI_IPP, KPCL_IPP, & MALSAMUDRA_IPP	10:34	10:43	00:09	HAND TRIPPED
158	2-Sep-2020	BAGALKOT	110	110/33KV HV3	GADAG_110, LAKKUNDI_33, HULAKOTI_33, KHB_33, TDPL1&2_IPP, PIONEER_IPP, NAGAVI_IPP, KPCL_IPP, & MALSAMUDRA_IPP	10:34	10:43	00:09	HAND TRIPPED
159	2-Sep-2020	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
160	2-Sep-2020	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
161	2-Sep-2020	BAGALKOT	110	220/110KV,LV 1	STATION NOT AFFECTED BAGALKOT_220	13:05 (27.08.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
162	2-Sep-2020	BAGALKOT	110	220/110KV,LV 1	STATION NOT AFFECTED BAGALKOT_220	13:05 (27.08.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
163	2-Sep-2020	BAGALKOT	110	AMBEWADI(KAVALWADA)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	13:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
164	2-Sep-2020	BAGALKOT	110	AMBEWADI(KAVALWADA)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	13:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
165	2-Sep-2020	BAGALKOT	110	ANNIGERI-GADAG	GADAG_110	05:55	15:06	09:11	LINE FAULT
166	2-Sep-2020	BAGALKOT	110	ANNIGERI-GADAG	GADAG_110	05:55	15:06	09:11	LINE FAULT
167	2-Sep-2020	BAGALKOT	110	BAGALKOT220-KALADAGI	KALADAGI_110	09:00	12:23	03:23	LINE CLEAR AVAILED
168	2-Sep-2020	BAGALKOT	110	BAGALKOT220-KALADAGI	KALADAGI_110	09:00	12:23	03:23	LINE CLEAR AVAILED
169	2-Sep-2020	BAGALKOT	110	BELGAUM220- VADAGOAN	VADAGOAN_110	06:15	12:15	06:00	LINE FAULT
170	2-Sep-2020	BAGALKOT	110	BELGAUM220- VADAGOAN	VADAGOAN_110	06:15	12:15	06:00	LINE FAULT
171	2-Sep-2020	BAGALKOT	110	BELGAUM220-ANKALAGI	STATION NOT EFFECTED BELGAUM_220	11:34 (02.09.2020)			LINE OPEN, LINE CLEAR AVAILED
172	2-Sep-2020	BAGALKOT	110	BELGAUM220-ANKALAGI	STATION NOT EFFECTED BELGAUM_220	11:34 (02.09.2020)			LINE OPEN, LINE CLEAR AVAILED
173	2-Sep-2020	BAGALKOT	110	BELGAUM220-VADAGOAN	VADAGAON_110	05:56	06:11	00:15	LINE FAULT
174	2-Sep-2020	BAGALKOT	110	BELGAUM220-VADAGOAN	STATION NOT EFFECTED BELGAUM_220	6:39 (02.09.2020)			LINE OPEN, LINE FAULT
175	2-Sep-2020	BAGALKOT	110	BELGAUM220-VADAGOAN	VADAGAON_110	05:56	06:11	00:15	LINE FAULT
176	2-Sep-2020	BAGALKOT	110	BELGAUM220-VADAGOAN	STATION NOT EFFECTED BELGAUM_220	6:39 (02.09.2020)			LINE OPEN, LINE FAULT
177	2-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
178	2-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
179	2-Sep-2020	BAGALKOT	110	GADAG220-LAXMESHWAR	STATION NOT EFFECTED LAXMESHWAR_110	19:25 (02.09.2020)			LINE OPEN, LINE FAULT
180	2-Sep-2020	BAGALKOT	110	GADAG220-LAXMESHWAR	STATION NOT EFFECTED LAXMESHWAR_110	19:25 (02.09.2020)			LINE OPEN, LINE FAULT
181	2-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
182	2-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
183	2-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
184	2-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
185	2-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
186	2-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
187	2-Sep-2020	BAGALKOT	110	HAVERI220- HANGAL	HANGAL_110	18:48	19:03	00:15	LINE FAULT
188	2-Sep-2020	BAGALKOT	110	HAVERI220- HANGAL	HANGAL_110	22:05	22:32	00:27	LINE FAULT
189	2-Sep-2020	BAGALKOT	110	HAVERI220- HANGAL	HANGAL_110	18:48	19:03	00:15	LINE FAULT
190	2-Sep-2020	BAGALKOT	110	HAVERI220- HANGAL	HANGAL_110	22:05	22:32	00:27	LINE FAULT
191	2-Sep-2020	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED HIDIKAL_110	15:47 (02.09.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
192	2-Sep-2020	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED HIDIKAL_110	15:47 (02.09.2020)			LINE OPEN, LINE CLEAR AVAILED
193	2-Sep-2020	BAGALKOT	110	JOG- SIRSI	SIRSI_110	10:26	14:26	04:00	LINE CLEAR AVAILED
194	2-Sep-2020	BAGALKOT	110	JOG- SIRSI	SIRSI_110	10:26	14:26	04:00	LINE CLEAR AVAILED
195	2-Sep-2020	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51 (01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
196	2-Sep-2020	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51 (01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
197	2-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
198	2-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
199	2-Sep-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
200	2-Sep-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
201	2-Sep-2020	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN, LINE CLEAR AVAILED
202	2-Sep-2020	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN, LINE CLEAR AVAILED
203	2-Sep-2020	BAGALKOT	110	SIRSI2-KUMTA	KUMTA_110	15:06	15:21	00:15	HAND TRIPPED
204	2-Sep-2020	BAGALKOT	110	SIRSI2-KUMTA	KUMTA_110	15:06	15:21	00:15	HAND TRIPPED
205	2-Sep-2020	BAGALKOT	110	SUPA2-AMBEWADI	AMBEWADI_220	18:22			LINE OPEN, LINE FAULT
206	2-Sep-2020	BAGALKOT	110	SUPA2-AMBEWADI	AMBEWADI_220	18:22			LINE OPEN, LINE FAULT
207	2-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
208	2-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
209	2-Sep-2020	BAGALKOT	220	220/110KV,HV1,LV1	NO STATION AFFECTED BIJAPUR_220	10:58	19:12	08:14	LINE CLEAR AVAILED
210	2-Sep-2020	BAGALKOT	220	220/110KV,HV1,LV1	NO STATION AFFECTED BIJAPUR_220	19:42	21:47	02:05	LINE CLEAR AVAILED
211	2-Sep-2020	BAGALKOT	220	220/110KV,HV1,LV1	NO STATION AFFECTED BIJAPUR_220	10:58	19:12	08:14	LINE CLEAR AVAILED
212	2-Sep-2020	BAGALKOT	220	220/110KV,HV1,LV1	NO STATION AFFECTED BIJAPUR_220	19:42	21:47	02:05	LINE CLEAR AVAILED
213	2-Sep-2020	BAGALKOT	220	AMBEWADI-NARENDRA 1&2	AMBEWADI_220	10:25	18:04	07:39	LINE CLEAR AVAILED
214	2-Sep-2020	BAGALKOT	220	AMBEWADI-NARENDRA 1&2	AMBEWADI_220	10:25	18:04	07:39	LINE CLEAR AVAILED
215	2-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
216	2-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
217	2-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	17:20 (01.09.2020)	12:01 (02.09.2020)	18:40	LINE CHARGED
218	2-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	17:20 (01.09.2020)	12:01 (02.09.2020)	18:40	LINE CHARGED
219	2-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	BAGEWADI_220	12:19 (02.09.2020)			LINE OPEN, LINE CLEAR AVAILED
220	2-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	BAGEWADI_220	12:19 (02.09.2020)			LINE OPEN, LINE CLEAR AVAILED
221	2-Sep-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1&2(NANDIHAL1&2)	STATION NOT AFFECTED BAGEWADI_220	13:20 (29.08.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
222	2-Sep-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1&2(NANDIHAL1&2)	STATION NOT AFFECTED BAGEWADI_220	13:20 (29.08.2020)			LOAD CURTAILMENT
223	2-Sep-2020	BAGALKOT	220	BELGAUM220-CHIKKODI1	STATION NOT EFFECTED BELGAUM_220	20:43 (02.09.2020)			LINE OPEN, LINE FAULT
224	2-Sep-2020	BAGALKOT	220	BELGAUM220-CHIKKODI1	STATION NOT EFFECTED BELGAUM_220	20:43 (02.09.2020)			LINE OPEN, LINE FAULT
225	2-Sep-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	22:03 (01.09.2020)	7:39 (02.09.2020)	09:36	LINE CHARGED
226	2-Sep-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	22:03 (01.09.2020)	7:39 (02.09.2020)	09:36	LINE CHARGED
227	2-Sep-2020	BAGALKOT	220	BIDNAL-NAGJHARI2	BIDNAL_220	09:16	10:36	01:20	LINE FAULT
228	2-Sep-2020	BAGALKOT	220	BIDNAL-NAGJHARI2	BIDNAL_220	09:16	10:36	01:20	LINE FAULT
229	2-Sep-2020	BAGALKOT	220	GHATAPRABHA220- PG HUNSHYAL	PG HUSHYAL_110, NAGNUR_110	12:28	12:40	00:12	LINE FAULT
230	2-Sep-2020	BAGALKOT	220	GHATAPRABHA220- PG HUNSHYAL	PG HUSHYAL_110, NAGNUR_110	12:28	12:40	00:12	LINE FAULT
231	2-Sep-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
232	2-Sep-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
233	2-Sep-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
234	2-Sep-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
235	2-Sep-2020	BAGALKOT	220	KADRA1- KARWAR220	KARWAR_220	12:18	17:46	05:28	LINE FAULT
236	2-Sep-2020	BAGALKOT	220	KADRA1- KARWAR220	KARWAR_220	12:18	17:46	05:28	LINE FAULT
237	2-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
238	2-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
239	2-Sep-2020	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 2	BAGEPALLI	15:00	15:08	00:08	LOAD CHANGE OVER
240	2-Sep-2020	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 2	BAGEPALLI	15:00	15:08	00:08	LOAD CHANGE OVER
241	2-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
242	2-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
243	2-Sep-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	15:14	15:15	00:01	LOAD CHANGE OVER
244	2-Sep-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	16:05	16:07	00:02	LOAD CHANGE OVER
245	2-Sep-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	15:14	15:15	00:01	LOAD CHANGE OVER
246	2-Sep-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	16:05	16:07	00:02	LOAD CHANGE OVER
247	2-Sep-2020	BENGALURU	66	HV1	BANGARPETE	12:11	12:18	00:07	LINE CLEAR AVOIDED
248	2-Sep-2020	BENGALURU	66	HV1	D CROSS	11:32	11:55	00:23	TRANSFORMER FAULT
249	2-Sep-2020	BENGALURU	66	HV1	SADLI	15:15	16:50	01:34	LINE CLEAR AVOIDED
250	2-Sep-2020	BENGALURU	66	HV1	SM MANGALA	14:43	14:50	00:06	LINE CLEAR AVOIDED
251	2-Sep-2020	BENGALURU	66	HV1	KYALANUR	11:41	11:48	00:07	TRANSFORMER FAULT
252	2-Sep-2020	BENGALURU	66	HV1	BANGARPETE	12:11	12:18	00:07	LINE CLEAR AVOIDED
253	2-Sep-2020	BENGALURU	66	HV1	D CROSS	11:32	11:55	00:23	TRANSFORMER FAULT
254	2-Sep-2020	BENGALURU	66	HV1	SADLI	15:15	16:50	01:34	LINE CLEAR AVOIDED
255	2-Sep-2020	BENGALURU	66	HV1	SM MANGALA	14:43	14:50	00:06	LINE CLEAR AVOIDED
256	2-Sep-2020	BENGALURU	66	HV1	KYALANUR	11:41	11:48	00:07	TRANSFORMER FAULT
257	2-Sep-2020	BENGALURU	66	HV2	NRS	11:52	11:55	00:03	LINE CLEAR AVOIDED
258	2-Sep-2020	BENGALURU	66	HV2	DODDALAHALLI	03:18	03:24	00:06	TRANSFORMER FAULT
259	2-Sep-2020	BENGALURU	66	HV2	HOSUR RAMAPURA	14:06	14:30	00:24	TRANSFORMER FAULT
260	2-Sep-2020	BENGALURU	66	HV2	THAYALUR	15:49	15:55	00:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
261	2-Sep-2020	BENGALURU	66	HV2	Y HUNSENHALLI	14:09	14:35	00:25	LINE CLEAR AVAILED
262	2-Sep-2020	BENGALURU	66	HV2	NRS	11:52	11:55	00:03	LINE CLEAR AVAILED
263	2-Sep-2020	BENGALURU	66	HV2	DODDALAHALLI	03:18	03:24	00:06	TRANSFORMER FAULT
264	2-Sep-2020	BENGALURU	66	HV2	HOSUR RAMAPURA	14:06	14:30	00:24	TRANSFORMER FAULT
265	2-Sep-2020	BENGALURU	66	HV2	THAYALUR	15:49	15:55	00:05	TRANSFORMER FAULT
266	2-Sep-2020	BENGALURU	66	HV2	Y HUNSENHALLI	14:09	14:35	00:25	LINE CLEAR AVAILED
267	2-Sep-2020	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	05:30	05:48	00:18	LINE FAULT
268	2-Sep-2020	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	05:30	05:48	00:18	LINE FAULT
269	2-Sep-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	17:51	18:00	00:09	LINE FAULT
270	2-Sep-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	17:51	18:00	00:09	LINE FAULT
271	2-Sep-2020	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	NO STATION AFFECTED	11:05	11:18	00:13	LINE FAULT
272	2-Sep-2020	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	18:29	18:35	00:06	LINE FAULT
273	2-Sep-2020	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	NO STATION AFFECTED	11:05	11:18	00:13	LINE FAULT
274	2-Sep-2020	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	18:29	18:35	00:06	LINE FAULT
275	2-Sep-2020	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	21:42	21:44	00:02	MAIN SUPPLY FAILURE
276	2-Sep-2020	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	21:42	21:44	00:02	MAIN SUPPLY FAILURE
277	2-Sep-2020	GULBARGA	110	HV1	MADIYAL_110,	16:50	17:00	00:10	TRANSFORMER FAULT
278	2-Sep-2020	GULBARGA	110	HV1	MADIYAL_110,	16:50	17:00	00:10	TRANSFORMER FAULT
279	2-Sep-2020	GULBARGA	110	HV3	YELBURGA_110	22:37	23:42	01:05	TRANSFORMER FAULT
280	2-Sep-2020	GULBARGA	110	HV3	SHAHAPUR_110	20:55	21:45	00:50	TRANSFORMER FAULT
281	2-Sep-2020	GULBARGA	110	HV3	YELBURGA_110	22:37	23:42	01:05	TRANSFORMER FAULT
282	2-Sep-2020	GULBARGA	110	HV3	SHAHAPUR_110	20:55	21:45	00:50	TRANSFORMER FAULT
283	2-Sep-2020	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGSARFACTORY_I PP,CHOWDAPUR_110	05:12	05:18	00:06	LINE FAULT
284	2-Sep-2020	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGSARFACTORY_I PP,CHOWDAPUR_110	05:12	05:18	00:06	LINE FAULT
285	2-Sep-2020	GULBARGA	110	LINGASUGUR-CHAYADEVI_IPP	LINGASUGUR_220	21:43	22:17	00:34	LINE FAULT
286	2-Sep-2020	GULBARGA	110	LINGASUGUR-CHAYADEVI_IPP	LINGASUGUR_220	21:43	22:17	00:34	LINE FAULT
287	2-Sep-2020	GULBARGA	110	LINGASUGUR-KAREPOWER_IPP	LINGASUGUR_220	21:43	22:03	00:20	LINE FAULT
288	2-Sep-2020	GULBARGA	110	LINGASUGUR-KAREPOWER_IPP	LINGASUGUR_220	21:43	22:03	00:20	LINE FAULT
289	2-Sep-2020	GULBARGA	110	LINGASUGUR-MUDGAL	MMUDGAL_110	21:43	21:56	00:13	LINE FAULT
290	2-Sep-2020	GULBARGA	110	LINGASUGUR-MUDGAL	MMUDGAL_110	21:43	21:56	00:13	LINE FAULT
291	2-Sep-2020	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPURA_110,MANVI_110	19:12	19:23	00:11	LINE FAULT
292	2-Sep-2020	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPURA_110,MANVI_110	19:12	19:23	00:11	LINE FAULT
293	2-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
294	3-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
295	2-Sep-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR-110	03:40	03:45	00:05	LINE FAULT
296	2-Sep-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR-110	03:40	03:45	00:05	LINE FAULT
297	2-Sep-2020	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	23:17	23:27	00:10	LINE FAULT
298	2-Sep-2020	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	23:17	23:27	00:10	LINE FAULT
299	2-Sep-2020	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	11:42	12:02	00:20	MAIN SUPPLY FAILURE
300	2-Sep-2020	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	11:42	12:02	00:20	MAIN SUPPLY FAILURE
301	2-Sep-2020	GULBARGA	110	YELBURGA-PRPJ_SLR	YELBURGA_110	22:40(2.9.2020)			LINE OPEN, LINE FAULT
302	2-Sep-2020	GULBARGA	220	HV1	LINGASUGUR_220	21:43	21:52	00:09	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
303	2-Sep-2020	GULBARGA	220	HV1	LINGASUGUR_220	21:43	21:52	00:09	TRANSFORMER FAULT
304	2-Sep-2020	GULBARGA	220	HV2	LINGASUGUR_220	21:43	22:00	00:17	TRANSFORMER FAULT
305	2-Sep-2020	GULBARGA	220	HV2	LINGASUGUR_220	21:43	22:00	00:17	TRANSFORMER FAULT
306	2-Sep-2020	GULBARGA	220	KAPNOOR-SHAHAPUR1	NO STATION AFFECTED	16:10	22:11	06:01	LINE CHARGED
307	2-Sep-2020	GULBARGA	220	KAPNOOR-SHAHAPUR1	NO STATION AFFECTED	16:10	22:11	06:01	LINE CHARGED
308	2-Sep-2020	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220,MALLAT_220	18:35	19:30	00:55	LINE FAULT
309	2-Sep-2020	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220,MALLAT_220	18:35	19:30	00:55	LINE FAULT
310	2-Sep-2020	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	16:02	19:12	03:10	LINE CLEAR AVOIDED
311	2-Sep-2020	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	16:02	19:12	03:10	LINE CLEAR AVOIDED
312	2-Sep-2020	GULBARGA	400	BTPS-JINDAL	BTPS_400	12:09	14:13	02:04	LINE CLEAR AVOIDED
313	2-Sep-2020	GULBARGA	400	BTPS-JINDAL	BTPS_400	12:09	14:13	02:04	LINE CLEAR AVOIDED
314	2-Sep-2020	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	13:20	13:30	00:10	LINE FAULT
315	2-Sep-2020	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	15:40	16:07	00:27	LINE FAULT
316	2-Sep-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:42	16:07	00:25	MAIN SUPPLY FAILURE
317	2-Sep-2020	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	15:42	16:10	00:28	MAIN SUPPLY FAILURE
318	2-Sep-2020	HASSAN	110	HALADY11-HIRIYADKA	HALADY_110	9:27 (31.08.2020)			LINE OPEN, LINE CLEAR AVOIDED
319	2-Sep-2020	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	9:27 (31.08.2020)			LINE OPEN, LINE CLEAR AVOIDED
320	2-Sep-2020	HASSAN	110	HV1	PUTTUR_110	09:13	09:39	00:26	LINE CLEAR AVOIDED
321	2-Sep-2020	HASSAN	110	HV1	KONAJE_110	10:43	10:48	00:05	HAND TRIPPED
322	2-Sep-2020	HASSAN	110	HV1	KONAJE_110	13:34	13:38	00:04	HAND TRIPPED
323	2-Sep-2020	HASSAN	110	HV1	SHIRALKOPPA_220	15:00	16:09	01:09	LINE CLEAR AVOIDED
324	2-Sep-2020	HASSAN	110	HV2	KONAJE_110	10:43	10:49	00:06	HAND TRIPPED
325	2-Sep-2020	HASSAN	110	HV2	KONAJE_110	13:34	13:39	00:05	HAND TRIPPED
326	2-Sep-2020	HASSAN	110	HV3	KONAJE_110	10:43	10:48	00:05	HAND TRIPPED
327	2-Sep-2020	HASSAN	110	HV3	KONAJE_110	13:34	13:38	00:04	HAND TRIPPED
328	2-Sep-2020	HASSAN	110	JOG-JST1	mghejog_gen	10:39	10:47	00:08	LINE FAULT
329	2-Sep-2020	HASSAN	110	JOG-NK1	mghejog_gen	10:55	14:30	03:35	NFBC ISSUED
330	2-Sep-2020	HASSAN	110	JOG-NK2	mghejog_gen	23:36 (7.08.2020)	14:30 (2.09.2020)	614:54hrs	LINE CHARGED
331	2-Sep-2020	HASSAN	110	KAVOOR-MRPL	KAVOOR_220	09:29	13:25	03:56	LINE CLEAR AVOIDED
332	2-Sep-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:41	16:04	00:23	LINE FAULT
333	2-Sep-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:41	16:06	00:25	LINE FAULT
334	2-Sep-2020	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	14:50	16:44	01:54	LINE CLEAR AVOIDED
335	2-Sep-2020	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	16:10	16:44	00:34	LINE FAULT
336	2-Sep-2020	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	16:24	16:48	00:24	LINE FAULT
337	2-Sep-2020	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:50	10:54	00:04	HAND TRIPPED
338	2-Sep-2020	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	12:20	13:30	01:10	NFBC ISSUED
339	2-Sep-2020	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	15:18	16:10	00:52	LINE FAULT
340	2-Sep-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	9:11 (31.08.2020)			LINE OPEN, LINE CLEAR AVOIDED
341	2-Sep-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	7:40 (1.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
342	2-Sep-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	7:40 (1.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
343	2-Sep-2020	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	17:45	21:43	03:58	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
344	2-Sep-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	13:13	16:43	03:30	LINE CLEAR AVAILED
345	2-Sep-2020	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	15:16	16:10	00:54	LINE FAULT
346	2-Sep-2020	HASSAN	220	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:45 (2.09.2020)			LINE OPEN, LINE CLEAR AVAILED
347	2-Sep-2020	HASSAN	220	VARAH1-KEMAR3	varahi_gen	9:11 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
348	2-Sep-2020	HASSAN	220	VARAH1-SHMG3	varahi_gen	13:13	16:43	03:30	LINE FAULT
349	2-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	18:14 (1.09.2020)	6:22 (2.09.2020)	12:08hrs	LINE CHARGED
350	2-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:11 (31.08.2020)	7:26 (1.09.2020)	8:15hrs	LINE CHARGED
351	2-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:47 (1.09.2020)			LINE OPEN, LINE CLEAR AVAILED
352	2-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:54 (30.08.2020)	9:55 (1.09.2020)	35:01hrs	LINE CHARGED
353	2-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	17:20(1.09.2020)	6:00 (2.09.2020)	12:40hrs	LINE CHARGED
354	2-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:36 (2.09.2020)			LINE OPEN, LINE CLEAR AVAILED
355	2-Sep-2020	HASSAN	66	HV1	HARIHARPURA_66	23:25 (2.09.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
356	2-Sep-2020	HASSAN	66	HV1	MATTANAVILE_66	21:55 (2.09.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
357	2-Sep-2020	HASSAN	66	HV1	MOSALEHOSAHALLY_66	23:13	23:22	00:09	TRANSFORMER FAULT
358	2-Sep-2020	HASSAN	66	HV2	UDAYAPURA_66	23:38 (1.09.2020)	6:55(2.09.2020)	7:15hrs	LINE CHARGED
359	2-Sep-2020	HASSAN	66	HV2	MATTANAVILE_66	12:00	12:30	00:30	LINE CLEAR AVAILED
360	2-Sep-2020	HASSAN	66	HV2	HOLALUR_66	17:11	17:21	00:10	TRANSFORMER FAULT
361	2-Sep-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	23:21 (2.09.2020)			LINE OPEN, LINE FAULT
362	2-Sep-2020	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	23:21 (2.09.2020)			LINE OPEN, LINE FAULT
363	2-Sep-2020	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	17:14	17:19	00:05	LINE FAULT
364	2-Sep-2020	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	06:51	14:00	07:09	LINE CLEAR AVAILED
365	2-Sep-2020	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	17:01	17:10	00:09	HAND TRIPPED
366	2-Sep-2020	MYSORE	220	HOOTAGALLI-HV3	NO STATIONS EFFECTED	09:20	12:34	03:14	LINE CLEAR AVAILED
367	2-Sep-2020	MYSORE	220	VAJMANGALA-TK HALLI	NO STATIONS EFFECTED	13:33	19:33	06:00	LINE FAULT
368	2-Sep-2020	MYSORE	66	COWDALLI-MARTALLI	RAMAPURA_MYS_66 MARTAHALLI_66	16:46	16:54	00:07	LINE FAULT
369	2-Sep-2020	MYSORE	66	HOOTAGALLI-BOGADHI	NO STATIONS EFFECTED	10:39	13:43	03:04	LOAD CHANGE OVER
370	2-Sep-2020	MYSORE	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	09:10	13:15	04:05	LOAD CHANGE OVER
371	2-Sep-2020	MYSORE	66	HOOTAGALLI-HUNSUR	NO STATIONS EFFECTED	09:08	13:09	04:01	LOAD CHANGE OVER
372	2-Sep-2020	MYSORE	66	HOOTAGALLI-MCF	BELAGOLA_66	8:00 (01.09.2020)	13:34 (02.09.2020)	29:34HRS	LINE CHARGED
373	2-Sep-2020	MYSORE	66	HV1	KIADBMANDYA_66	11:04	11:26	00:21	LINE CLEAR AVAILED
374	2-Sep-2020	MYSORE	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
375	2-Sep-2020	MYSORE	66	KADAKOLA-SARGUR 2	HURA_66, HULLAHALLI_66, DOORA_66 CHANDRAVADI_66	18:39	18:44	00:05	LINE FAULT
376	2-Sep-2020	MYSORE	66	KHB STATION-HOOTAGALLI	NO STATIONS EFFECTED	09:16	13:05	03:49	LOAD CHANGE OVER
377	2-Sep-2020	MYSORE	66	KR PETE 220-SANTHEBACHALLI	SANTHEBACHALLI_66 HARIYALDAMMATEMPLE_66	23:58 (02/09/2020)			LINE OPEN, LINE FAULT
378	2-Sep-2020	MYSORE	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	10:12 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
379	2-Sep-2020	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	07:09	07:15	00:05	LINE FAULT
380	2-Sep-2020	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	11:34	11:40	00:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
381	2-Sep-2020	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	13:08	13:14	00:05	LINE FAULT
382	2-Sep-2020	MYSORE	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	11:10 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
383	2-Sep-2020	MYSORE	66	MEGALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66 VYASRAJPURA_66 GARGESHWARI_66 THUMBLA_66	07:05	07:17	00:12	LINE FAULT
384	2-Sep-2020	MYSORE	66	MEGALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66 VYASRAJPURA_66 GARGESHWARI_66 THUMBLA_66	18:06	18:20	00:13	LINE FAULT
385	2-Sep-2020	MYSORE	66	VAJMANGALA-KADKOLA 1	AYRALLI_66 MARADIHUNDI_66	06:02	06:18	00:16	LINE FAULT
386	2-Sep-2020	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	ANCHEPALYA_220	13:18	16:09	02:50	LINE CLEAR AVAILED
387	2-Sep-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	06:16	06:29	00:13	LINE FAULT
388	2-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	13:45	13:54	00:08	LINE FAULT
389	2-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-2	INFOSYS-1	13:01	13:10	00:08	HAND TRIPPED
390	2-Sep-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:11	12:20	00:08	LINE FAULT
391	2-Sep-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:00	13:12	00:12	LINE FAULT
392	2-Sep-2020	TUMKUR	66	KUNDUR- RSOLAR	RENEW WIND ENERGY_IPP_66	10:02	12:41	02:39	LINE CLEAR AVAILED
393	2-Sep-2020	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	18:43	19:18	00:35	LINE FAULT
394	2-Sep-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	09:39	11:47	02:07	LINE CLEAR AVAILED
395	2-Sep-2020	TUMKUR	66	TR-1	HARIHAR_66	15:25	17:26	02:01	TRANSFORMER FAULT
396	2-Sep-2020	TUMKUR	66	TR-1	HDPURA_66	12:14	12:52	00:38	HAND TRIPPED
397	2-Sep-2020	TUMKUR	66	TR-1	HDPURA_66	16:48	16:55	00:06	HAND TRIPPED
398	2-Sep-2020	TUMKUR	66	TR-1	HDPURA_66	17:40	17:56	00:15	HAND TRIPPED
399	2-Sep-2020	TUMKUR	66	TR-1	HDPURA_66	18:24	18:29	00:05	HAND TRIPPED
400	2-Sep-2020	TUMKUR	66	TR-1	HDPURA_66	20:12	20:16	00:03	HAND TRIPPED
401	2-Sep-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	13:29	14:58	01:29	LINE CLEAR AVAILED
402	2-Sep-2020	TUMKUR	66	TR-1	PAVAGADA_220	16:54	16:56	00:01	TRANSFORMER FAULT
403	2-Sep-2020	TUMKUR	66	TR-1	RANGANATHAPURA_66	07:41	08:01	00:19	LINE CLEAR AVAILED
404	2-Sep-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
405	2-Sep-2020	TUMKUR	66	TR-2	BEVINAHALLI_66	21:36	21:47	00:10	TRANSFORMER FAULT
406	2-Sep-2020	TUMKUR	66	TR-2	HARIYABBE_66	12:07	12:12	00:05	HAND TRIPPED
407	2-Sep-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	15:43	15:48	00:04	TRANSFORMER FAULT
408	2-Sep-2020	TUMKUR	66	TR-2(HV SIDE)	HONNALLI_220	12:04	13:09	01:05	LINE CLEAR AVAILED
409	2-Sep-2020	TUMKUR	66	TR-2(LV SIDE)	HONNALLI_220	13:07	14:08	01:00	LINE CLEAR AVAILED
410	2-Sep-2020	TUMKUR	66	TR-3	HARIYABBE_66	11:50	11:58	00:07	HAND TRIPPED
411	2-Sep-2020	TUMKUR	110	KALLUR- NITTUR	KALLUR_110	10:43	17:26	06:42	LINE CLEAR AVAILED
412	2-Sep-2020	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	10:41	17:23	06:42	LINE CLEAR AVAILED
413	2-Sep-2020	TUMKUR	110	TR-1	KALLUR_110	10:41	17:28	06:46	LINE CLEAR AVAILED
414	2-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN , TRANSFORMER FAULT
415	2-Sep-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	5:38:51 AM(01.09.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
416	2-Sep-2020	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	5:46:08 AM(01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
417	3-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	18:46 (19.07.0.2020)			LINE OPEN, LINE CLEAR AVAILED
418	3-Sep-2020	BAGALKOT	110	110/11KV, HV1	TIKOTA_110	14:25	15:07	00:42	LINE CLEAR AVOIDED
419	3-Sep-2020	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	10:43	16:26	05:43	LINE CLEAR AVOIDED
420	3-Sep-2020	BAGALKOT	110	110/11KV, HV1	KUDUCHI_220	14:24	14:37	00:13	TRANSFORMER FAULT
421	3-Sep-2020	BAGALKOT	110	110/11KV, HV2	KANABARGA_110	12:26	14:15	01:49	LINE CLEAR AVOIDED
422	3-Sep-2020	BAGALKOT	110	110/11KV, HV2	NAVALGUND_110	14:30	16:21	01:51	LINE CLEAR AVOIDED
423	3-Sep-2020	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(B)_110	15:57	17:18	01:21	LINE CLEAR AVOIDED
424	3-Sep-2020	BAGALKOT	110	110/11KV,HV3	KIADB BIJAPUR_110	14:04	14:44	00:40	TRANSFORMER FAULT
425	3-Sep-2020	BAGALKOT	110	110/33KV, HV3	HUNAGUND_110, AMINAGAD_33, KARADI 33 & MYTRA IPP	08:23	08:37	00:14	TRANSFORMER FAULT
426	3-Sep-2020	BAGALKOT	110	110/33KV, HV3	HUNAGUND_110, AMINAGAD_33, KARADI 33 & MYTRA IPP	08:49	08:55	00:06	TRANSFORMER FAULT
427	3-Sep-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALASANGI 33, NEVARGI 33	11:44	11:50	00:06	TRANSFORMER FAULT
428	3-Sep-2020	BAGALKOT	110	110/33KV,HV3	LAXMESHWAR_110,MMCL_33,SSM_3 3	01:21	02:58	01:37	TRANSFORMER FAULT
429	3-Sep-2020	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG 110	15:54 (04.08.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
430	3-Sep-2020	BAGALKOT	110	220/110KV, LV1	NARENDRA_220	02:15	06:41	04:26	LOAD CURTAILMENT
431	3-Sep-2020	BAGALKOT	110	220/110KV, LV2	HAVERI_220	02:27	06:27	04:00	LINE CLEAR AVOIDED
432	3-Sep-2020	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	7:20 (03.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVOIDED
433	3-Sep-2020	BAGALKOT	110	220/110KV,LV 1	STATION NOT AFFECTED BAGALKOT_220	13:05 (27.08.2020)			TRANSFORMER OPEN, LINE CLEAR AVOIDED
434	3-Sep-2020	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110	07:10	08:37	01:27	LINE FAULT
435	3-Sep-2020	BAGALKOT	110	AMBEWADI(KAVALWADA)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	13:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
436	3-Sep-2020	BAGALKOT	110	AMBEWADI-NK2	KAVALAWAD_110	11:06	11:15	00:09	HAND TRIPPED
437	3-Sep-2020	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	10:30	10:59	00:29	LINE FAULT
438	3-Sep-2020	BAGALKOT	110	BELGAUM220-ANKALAGI	STATION NOT EFFECTED BELGAUM_220	11:34 (02.09.2020)	13:36 (03.09.2020)	03:10	LINE CHARGED
439	3-Sep-2020	BAGALKOT	110	BELGAUM220-VADAGOAN	STATION NOT EFFECTED BELGAUM_220	6:39 (02.09.2020)	12:08 (02.09.2020)	05:29	LINE FAULT
440	3-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
441	3-Sep-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	02:20	13:09	10:49	LINE FAULT
442	3-Sep-2020	BAGALKOT	110	GADAG220-LAXMESHWAR	STATION NOT EFFECTED LAXMESHWAR_110	19:25 (02.09.2020)	15:05 (3.9.20)	19:40	LINE FAULT
443	3-Sep-2020	BAGALKOT	110	GHATAPRABHA220-KABBUR	KABBUR_110	08:04	08:13	00:09	LINE FAULT
444	3-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
445	3-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
446	3-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
447	3-Sep-2020	BAGALKOT	110	HIDAKA- RAIBAG (ITANAL)	RAIBAG (ITANAL)_110	6:41 (03.09.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
448	3-Sep-2020	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED HIDIKAL_110	15:47 (02.09.2020)	2:05 (03.09.2020)	10:18	LINE CHARGED
449	3-Sep-2020	BAGALKOT	110	HUNAGUND-ILAKAL 1&2	HUNAGUND_110	05:45	06:00	00:15	LINE FAULT
450	3-Sep-2020	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51 (01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
451	3-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
452	3-Sep-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
453	3-Sep-2020	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)	14:21 (03.09.2020)	19:51	LINE CHARGED
454	3-Sep-2020	BAGALKOT	110	SUPA2-AMBEWADI	AMBEWADI_220	6:22 (02.09.2020)	18:39 (03.09.2020)	11:17	LINE FAULT
455	3-Sep-2020	BAGALKOT	110	VAJRAMATTI220- MANTUR1	STATION NOT AFFECTED MANTUR_110	10:15	10:54	00:39	LINE FAULT
456	3-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
457	3-Sep-2020	BAGALKOT	220	220/110KV,HV2 LV2	KUDUCHI_220,AINAPUR_110	06:28	06:34	00:06	TRANSFORMER FAULT
458	3-Sep-2020	BAGALKOT	220	220/110KV,HV2&LV2	NO STATION AFFECTED BIJAPUR_220	10:33	16:40	06:07	LINE CLEAR AVOIDED
459	3-Sep-2020	BAGALKOT	220	220/110KV,HV2&LV2	BELGAUM_220	07:28	08:25	00:57	LINE CLEAR AVOIDED
460	3-Sep-2020	BAGALKOT	220	BAGALKOT-GADAG 1	STATION NOT EFFECTED BAGALKOT_220	01:19	11:16	09:57	LOAD CURTAILMENT
461	3-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
462	3-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	BAGEWADI_220	12:19 (02.09.2020)			LINE OPEN, LINE CLEAR AVAILED
463	3-Sep-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1&2(NANDIHAL1&2)	STATION NOT AFFECTED BAGEWADI_220	13:20 (29.08.2020)			LOAD CURTAILMENT
464	3-Sep-2020	BAGALKOT	220	BELGAUM220-CHIKKODI1	STATION NOT EFFECTED BELGAUM_220	20:43 (02.09.2020)	11:47 (03.09.2020)	15:04	LINE FAULT
465	3-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	02:04	08:35	06:31	LOAD CURTAILMENT
466	3-Sep-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
467	3-Sep-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
468	3-Sep-2020	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	12:22	19:49	07:27	LINE FAULT
469	3-Sep-2020	BAGALKOT	220	KUDUCHI-GHATAPRABHA	STATION NOT AFFECTED KUDUCHI_220	02:35	09:54	07:19	LOAD CURTAILMENT
470	3-Sep-2020	BAGALKOT	220	NAGJHARI 1- AMBEWADI	AMBEWADI_220	15:36	15:58	00:22	LINE FAULT
471	3-Sep-2020	BAGALKOT	220	NAGJHARI1- HUBLI	STATION NOT AFFECTED HUBLI_220	13:48 (03.09.2020)			LINE OPEN, LINE FAULT
472	3-Sep-2020	BAGALKOT	220	NAGJHARI2- HUBLI	STATION NOT AFFECTED HUBLI_220	13:58	17:46	03:48	LINE FAULT
473	3-Sep-2020	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	02:20	10:42	08:22	LOAD CURTAILMENT
474	3-Sep-2020	BAGALKOT	220	NARENDRA- AMBEWADI2	NARENDRA_220	06:40	10:42	04:02	LOAD CURTAILMENT
475	3-Sep-2020	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	02:25	06:22	03:57	LOAD CURTAILMENT
476	3-Sep-2020	BAGALKOT	220	NARENDRA- HUBLI2	NARENDRA_220	15:34	18:24	02:50	LINE CLEAR AVOIDED
477	3-Sep-2020	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI_220	03:00	03:27	00:27	LINE FAULT
478	3-Sep-2020	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	MITTEMARI_220	03:00	03:27	00:27	LINE FAULT
479	3-Sep-2020	BENGALURU	220	HV1	SARIJAPURA_220	00:25	01:12	00:47	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
480	3-Sep-2020	BENGALURU	220	HV1	SARJAPURA 220	00:25	01:12	00:47	MAIN SUPPLY FAILURE
481	3-Sep-2020	BENGALURU	220	HV2	CHINTAMANI 220	13:11	13:30	00:19	TRANSFORMER FAULT
482	3-Sep-2020	BENGALURU	220	HV2	SARJAPURA 220	01:17	01:33	00:16	MAIN SUPPLY FAILURE
483	3-Sep-2020	BENGALURU	220	HV2	SARJAPURA 220	01:17	01:33	00:16	MAIN SUPPLY FAILURE
484	3-Sep-2020	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	00:25	01:12	00:47	MAIN SUPPLY FAILURE
485	3-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
486	3-Sep-2020	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	00:25	01:12	00:47	MAIN SUPPLY FAILURE
487	3-Sep-2020	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	01:17	01:33	00:16	MAIN SUPPLY FAILURE
488	3-Sep-2020	BENGALURU	220	VIKAS TECH PARK 220 - DEVARABISANHALLI	VIKAS TECH PARK	14:05	14:20	00:15	LOAD CHANGE OVER
489	3-Sep-2020	BENGALURU	220	VIKAS TECH PARK 220 - SARJAPURA 220	VIKAS TECH PARK	00:02	00:28	00:26	MAIN SUPPLY FAILURE
490	3-Sep-2020	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 220	BAGEPALLI	12:20	12:25	00:05	LINE CLEAR AVOIDED
491	3-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
492	3-Sep-2020	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	00:25	00:47	00:22	MAIN SUPPLY FAILURE
493	3-Sep-2020	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	14:52	14:56	00:04	LOAD CHANGE OVER
494	3-Sep-2020	BENGALURU	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	20:38	21:17	00:39	LINE FAULT
495	3-Sep-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	13:11	13:30	00:19	LINE CLEAR AVOIDED
496	3-Sep-2020	BENGALURU	66	CHINTAMANI 220 - SRINIVASAPURA	SRINIVASAPURA, KODIHALLI	13:11	13:30	00:19	LINE CLEAR AVOIDED
497	3-Sep-2020	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	13:11	13:40	00:29	LINE FAULT
498	3-Sep-2020	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	13:11	13:30	00:19	LINE CLEAR AVOIDED
499	3-Sep-2020	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	20:47	21:05	00:18	LINE FAULT
500	3-Sep-2020	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	21:22	22:23	01:01	LINE FAULT
501	3-Sep-2020	BENGALURU	66	DOMMASANDRA - KACHMARANAHALLI	DOMMASANDRA	14:30	14:45	00:15	LOAD CHANGE OVER
502	3-Sep-2020	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	00:05	01:15	01:10	MAIN SUPPLY FAILURE
503	3-Sep-2020	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	01:20	01:40	00:20	MAIN SUPPLY FAILURE
504	3-Sep-2020	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	06:53	07:03	00:10	MAIN SUPPLY FAILURE
505	3-Sep-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	06:00	06:16	00:16	LINE FAULT
506	3-Sep-2020	BENGALURU	66	HV1	ATTIBELE	00:05	01:00	00:55	MAIN SUPPLY FAILURE
507	3-Sep-2020	BENGALURU	66	HV1	KOLAR 220	15:12	15:30	00:18	LINE CLEAR AVOIDED
508	3-Sep-2020	BENGALURU	66	HV1	YARANDANAHALLI 220	19:45	19:53	00:08	TRANSFORMER FAULT
509	3-Sep-2020	BENGALURU	66	HV1	SADLI	10:14	10:45	00:30	LINE CLEAR AVOIDED
510	3-Sep-2020	BENGALURU	66	HV2	ATTIBELE	14:30	14:35	00:05	LOAD CHANGE OVER
511	3-Sep-2020	BENGALURU	66	HV2	ATTIBELE	00:25	01:00	00:35	MAIN SUPPLY FAILURE
512	3-Sep-2020	BENGALURU	66	HV2	DODDALAHALLI	12:00	12:13	00:13	TRANSFORMER FAULT
513	3-Sep-2020	BENGALURU	66	HV2	HOSKOTE	13:10	13:28	00:18	LINE CLEAR AVOIDED
514	3-Sep-2020	BENGALURU	66	HV2	MULBAGLU	13:03	13:42	00:39	LINE CLEAR AVOIDED
515	3-Sep-2020	BENGALURU	66	HV2	SOMAYAJANAHALLI	10:30	10:55	00:25	LINE CLEAR AVOIDED
516	3-Sep-2020	BENGALURU	66	HV2	SARJAPURA 220	01:18	01:34	00:15	MAIN SUPPLY FAILURE
517	3-Sep-2020	BENGALURU	66	HV2	SARJAPURA 220	14:23	14:25	00:02	LINE CLEAR AVOIDED
518	3-Sep-2020	BENGALURU	66	HV3	AUSTIN TOWN	12:24	13:23	00:59	LINE CLEAR AVOIDED
519	3-Sep-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	19:45	20:00	00:15	LOAD CURTAILMENT
520	3-Sep-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	19:10	19:30	00:20	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
521	3-Sep-2020	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	19:10	19:30	00:20	LOAD CURTAILMENT
522	3-Sep-2020	BENGALURU	66	KOLAR 220 - NARASAPURA	NARASAPURA	06:47	06:55	00:08	LINE FAULT
523	3-Sep-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	19:30	19:45	00:15	LOAD CURTAILMENT
524	3-Sep-2020	BENGALURU	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	19:30	19:45	00:15	LOAD CURTAILMENT
525	3-Sep-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	19:45	20:00	00:15	LOAD CURTAILMENT
526	3-Sep-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT), JADIGENAHALLI	16:05	16:56	00:51	LINE CLEAR AVAILED
527	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	03:00	03:27	00:27	MAIN SUPPLY FAILURE
528	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	03:45	04:18	00:33	MAIN SUPPLY FAILURE
529	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	04:18	07:10	02:52	LINE FAULT
530	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	03:00	03:20	00:20	MAIN SUPPLY FAILURE
531	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	03:00	03:30	00:30	MAIN SUPPLY FAILURE
532	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	03:45	04:07	00:22	MAIN SUPPLY FAILURE
533	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	04:18	04:31	00:13	MAIN SUPPLY FAILURE
534	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	08:35	08:39	00:04	LINE CLEAR AVAILED
535	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	03:00	03:29	00:29	MAIN SUPPLY FAILURE
536	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	03:45	04:07	00:22	MAIN SUPPLY FAILURE
537	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	04:18	04:31	00:13	MAIN SUPPLY FAILURE
538	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	08:35	08:39	00:04	LINE CLEAR AVAILED
539	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	03:00	03:30	00:30	MAIN SUPPLY FAILURE
540	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	03:45	04:07	00:22	MAIN SUPPLY FAILURE
541	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	04:18	04:31	00:13	MAIN SUPPLY FAILURE
542	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA	03:00	03:30	00:30	MAIN SUPPLY FAILURE
543	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA	03:45	04:07	00:22	MAIN SUPPLY FAILURE
544	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA	08:35	08:39	00:04	LINE CLEAR AVAILED
545	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	03:00	03:30	00:30	MAIN SUPPLY FAILURE
546	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI	03:45	04:03	00:18	MAIN SUPPLY FAILURE
547	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI	04:18	04:26	00:08	LINE FAULT
548	3-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI	08:35	08:40	00:05	LOAD CHANGE OVER
549	3-Sep-2020	BENGALURU	66	PATHPALYA - SOMANATHPURA	THIMMAMPALLI	17:14	17:25	00:10	LINE FAULT
550	3-Sep-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:45	14:48	00:02	LINE CLEAR AVAILED
551	3-Sep-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	00:25	01:13	00:48	MAIN SUPPLY FAILURE
552	3-Sep-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	01:17	01:37	00:20	MAIN SUPPLY FAILURE
553	3-Sep-2020	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	00:02	00:28	00:26	MAIN SUPPLY FAILURE
554	3-Sep-2020	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	14:05	14:20	00:15	LOAD CHANGE OVER
555	3-Sep-2020	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	00:02	00:28	00:26	MAIN SUPPLY FAILURE
556	3-Sep-2020	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	14:05	14:20	00:15	LOAD CHANGE OVER
557	3-Sep-2020	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	00:02	00:28	00:26	MAIN SUPPLY FAILURE
558	3-Sep-2020	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	14:05	14:20	00:15	LOAD CHANGE OVER
559	3-Sep-2020	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	00:03	00:30	00:27	LINE FAULT
560	3-Sep-2020	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL,ATTIBELE	00:03	00:35	00:32	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
561	3-Sep-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	07:03	07:09	00:06	LINE CLEAR AVAILED
562	3-Sep-2020	GULBARGA	66	ITTAGGI-HBHALLI	HAGARIBOMMANAHALLI_66,UPNAYA KANAHALLI_66	10:10	17:35	07:25	LINE CLEAR AVAILED
563	3-Sep-2020	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENAHALLI_66 ,GIRIYAPURA_66,MAGALA_66	10:20	17:42	07:22	LINE CLEAR AVAILED
564	3-Sep-2020	GULBARGA	66	ITTAGGI-HUVINA_HADAGALLI	HUVINA_HADAGALLI_66	10:20	17:35	07:15	LINE CLEAR AVAILED
565	3-Sep-2020	GULBARGA	66	ITTAGGI-KUDLIGI1,2	KOGALI_66,KUDLIGI_66,HANASI_66,B ANAVEKAL_66,CHORNOOR_66,GUDE KOTE_66,CJHALLI_66,HOSAHALLI_66	10:00	18:25	08:25	LINE CLEAR AVAILED
566	3-Sep-2020	GULBARGA	66	ITTAGGI-RENEWSLR1,2	ITTAGGI_220	10:35	13:45	03:10	LINE CLEAR AVAILED
567	3-Sep-2020	GULBARGA	66	ITTAGGI-SUZLON1,2	ITTAGGI_220	10:45	17:45	07:00	LINE CLEAR AVAILED
568	3-Sep-2020	GULBARGA	110	HV1	KURKUNTA_110	18:50	19:05	00:15	LOAD CURTAILMENT
569	3-Sep-2020	GULBARGA	110	HV2	DEODURGA_110	15:10	15:25	00:15	TRANSFORMER FAULT
570	3-Sep-2020	GULBARGA	110	HV2	JEWARGI_110	18:50	19:10	00:20	LOAD CURTAILMENT
571	3-Sep-2020	GULBARGA	110	HV3	YELBURGA_110	00:25	00:55	00:30	LINE CLEAR AVAILED
572	3-Sep-2020	GULBARGA	110	HV4	DEODURGA_110	15:05	15:30	00:25	TRANSFORMER FAULT
573	3-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,HUNSAGI_110,ASKI_110,UGAR SUGAR IPP	18:54	19:03	00:09	LINE FAULT
574	3-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,HUNSAGI_110,ASKI_110,UGAR SUGAR IPP	21:35	21:45	00:10	LINE FAULT
575	3-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,HUNSAGI_110,ASKI_110,UGAR SUGAR IPP	19:39	19:45	00:06	LINE FAULT
576	3-Sep-2020	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	00:03	00:19	00:16	LINE FAULT
577	3-Sep-2020	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	01:49	02:15	00:26	LINE FAULT
578	3-Sep-2020	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	05:48	06:08	00:20	LINE FAULT
579	3-Sep-2020	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	03:17	03:32	00:15	LINE FAULT
580	3-Sep-2020	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	13:14	13:36	00:22	LINE CLEAR AVAILED
581	3-Sep-2020	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	21:39	21:49	00:10	LINE FAULT
582	3-Sep-2020	GULBARGA	110	YELBURGA-PRPJ_SLR	YELBURGA_110	22:40(2.9.2020)	1:50(3.9.2020)	3:10HRS	LINE CHARGED
583	3-Sep-2020	GULBARGA	220	HV1	KUSHTAGI_220	11:04	11:13	00:09	TRANSFORMER FAULT
584	3-Sep-2020	GULBARGA	220	HV1	ITTAGGI_220	09:30	17:32	08:02	LOAD CURTAILMENT
585	3-Sep-2020	GULBARGA	220	HV2	ITTAGGI_220	09:30	17:42	08:12	LOAD CURTAILMENT
586	3-Sep-2020	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	13:28	13:49	00:21	LINE FAULT
587	3-Sep-2020	GULBARGA	220	LINGASUGUR-SHAHABAD	SHAHABAD_220	17:14	17:16	00:02	LINE FAULT
588	3-Sep-2020	GULBARGA	220	LINGASUGUR-SHAHAPUR	LINGASUGUR_220	04:12	04:32	00:20	LINE FAULT
589	3-Sep-2020	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	04:26	04:38	00:12	MAIN SUPPLY FAILURE
590	3-Sep-2020	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	04:26	04:38	00:12	MAIN SUPPLY FAILURE
591	3-Sep-2020	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	10:33	13:40	03:07	LINE CLEAR AVAILED
592	3-Sep-2020	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	09:15	10:02	00:47	MAIN SUPPLY FAILURE
593	3-Sep-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	09:15	10:53	01:38	MAIN SUPPLY FAILURE
594	3-Sep-2020	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	09:15	10:02	00:47	MAIN SUPPLY FAILURE
595	3-Sep-2020	HASSAN	110	HALADY11-HIRIYADKA	HALADY_110	9:27 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
596	3-Sep-2020	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	9:27 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
597	3-Sep-2020	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	09:15	10:02	00:47	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
598	3-Sep-2020	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	09:15	10:03	00:48	MAIN SUPPLY FAILURE
599	3-Sep-2020	HASSAN	110	HV	PUTTUR_220	09:12	09:50	00:38	MAIN SUPPLY FAILURE
600	3-Sep-2020	HASSAN	110	HV1	NITTUR_110	14:01	17:34	03:33	TRANSFORMER FAULT
601	3-Sep-2020	HASSAN	110	HV1	JAVAGAL_110	18:53	19:01	00:08	TRANSFORMER FAULT
602	3-Sep-2020	HASSAN	110	HV1	KONDENALU_110	18:55	19:15	00:20	LOAD CURTAILMENT
603	3-Sep-2020	HASSAN	110	HV2	KAVOOR_220	09:12	09:26	00:14	MAIN SUPPLY FAILURE
604	3-Sep-2020	HASSAN	110	HV2	KEMAR_220	09:12	09:55	00:43	MAIN SUPPLY FAILURE
605	3-Sep-2020	HASSAN	110	HV2	NITTUR_110	14:01	17:34	03:33	LINE CLEAR AVAILED
606	3-Sep-2020	HASSAN	110	HV2	GANDASI_110	18:55	19:10	00:15	TRANSFORMER FAULT
607	3-Sep-2020	HASSAN	110	HV2	GERUMARA_110	18:52	19:18	00:26	TRANSFORMER FAULT
608	3-Sep-2020	HASSAN	110	HV2	KONAJE_110	04:26	04:40	00:14	MAIN SUPPLY FAILURE
609	3-Sep-2020	HASSAN	110	HV2	KONAJE_110	09:47	09:55	00:08	MAIN SUPPLY FAILURE
610	3-Sep-2020	HASSAN	110	HV3	KAVOOR_220	09:12	09:26	00:14	MAIN SUPPLY FAILURE
611	3-Sep-2020	HASSAN	110	HV3	PUTTUR_110	09:12	11:24	02:12	MAIN SUPPLY FAILURE
612	3-Sep-2020	HASSAN	110	HV3	GURUVAYANAKERE_110	10:50	13:03	02:13	LINE CLEAR AVAILED
613	3-Sep-2020	HASSAN	110	KAVOOR-MRPL	KAVOOR_220	10:40	16:51	06:11	LINE CLEAR AVAILED
614	3-Sep-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	09:12	09:59	00:47	MAIN SUPPLY FAILURE
615	3-Sep-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	09:12	10:51	01:39	MAIN SUPPLY FAILURE
616	3-Sep-2020	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	09:12	10:01	00:49	MAIN SUPPLY FAILURE
617	3-Sep-2020	HASSAN	110	KEMAR-Manipal1	KEMAR_220	09:12	09:54	00:42	MAIN SUPPLY FAILURE
618	3-Sep-2020	HASSAN	110	KEMAR-Manipal2	KEMAR_220	09:12	11:21	02:09	MAIN SUPPLY FAILURE
619	3-Sep-2020	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	09:12	10:01	00:49	MAIN SUPPLY FAILURE
620	3-Sep-2020	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	09:12	10:01	00:49	MAIN SUPPLY FAILURE
621	3-Sep-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	09:12	10:28	01:16	MAIN SUPPLY FAILURE
622	3-Sep-2020	HASSAN	110	LV1	KEMAR_220	09:12	09:53	00:41	MAIN SUPPLY FAILURE
623	3-Sep-2020	HASSAN	110	LV2	KEMAR_220	09:12	10:11	00:59	MAIN SUPPLY FAILURE
624	3-Sep-2020	HASSAN	110	LV3	KEMAR_220	09:12	10:05	00:53	MAIN SUPPLY FAILURE
625	3-Sep-2020	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	09:15	09:58	00:43	MAIN SUPPLY FAILURE
626	3-Sep-2020	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	13:34	13:41	00:07	HAND TRIPPED
627	3-Sep-2020	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	14:01	14:25	00:24	HAND TRIPPED
628	3-Sep-2020	HASSAN	110	MANIPALHIRIYADKA	MANIPAL_110	09:15	09:58	00:43	MAIN SUPPLY FAILURE
629	3-Sep-2020	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	14:01	14:25	00:24	HAND TRIPPED
630	3-Sep-2020	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	09:15	09:58	00:43	MAIN SUPPLY FAILURE
631	3-Sep-2020	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	14:01	14:17	00:16	LINE FAULT
632	3-Sep-2020	HASSAN	110	MANIPAL-KEMAR2	MANIPAL_110	09:15	11:25	02:10	MAIN SUPPLY FAILURE
633	3-Sep-2020	HASSAN	110	MANIPAL-KEMAR2	MANIPAL_110	14:01	14:25	00:24	LINE FAULT
634	3-Sep-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	09:13	10:05	00:52	MAIN SUPPLY FAILURE
635	3-Sep-2020	HASSAN	110	MOODAB-IKEMAR1	NANDIKUR_110	09:15	10:10	00:55	MAIN SUPPLY FAILURE
636	3-Sep-2020	HASSAN	110	MOODAB-INDKR-SUZLON	NANDIKUR_110	09:15	10:10	00:55	MAIN SUPPLY FAILURE
637	3-Sep-2020	HASSAN	110	MOODAB-ISTR	MOODABIDRE_110	09:15	10:10	00:55	MAIN SUPPLY FAILURE
638	3-Sep-2020	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	09:13	10:05	00:52	MAIN SUPPLY FAILURE
639	3-Sep-2020	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	09:13	10:05	00:52	MAIN SUPPLY FAILURE
640	3-Sep-2020	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	09:28	12:27	02:59	LINE CLEAR AVAILED
641	3-Sep-2020	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	09:13	10:00	00:47	MAIN SUPPLY FAILURE
642	3-Sep-2020	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	14:01	14:20	00:19	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
643	3-Sep-2020	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	17:20	17:22	00:02	HAND TRIPPED
644	3-Sep-2020	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	09:12	10:00	00:48	MAIN SUPPLY FAILURE
645	3-Sep-2020	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	09:12	09:54	00:42	MAIN SUPPLY FAILURE
646	3-Sep-2020	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	09:12	09:58	00:46	MAIN SUPPLY FAILURE
647	3-Sep-2020	HASSAN	110	SAGARA-SORABA	SAGARA_110	10:26	15:46	05:20	LINE CLEAR AVAILED
648	3-Sep-2020	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	10:36	10:49	00:13	HAND TRIPPED
649	3-Sep-2020	HASSAN	220	HV1	KEMAR_220	09:12	09:52	00:40	MAIN SUPPLY FAILURE
650	3-Sep-2020	HASSAN	220	HV2	KEMAR_220	09:12	10:06	00:54	MAIN SUPPLY FAILURE
651	3-Sep-2020	HASSAN	220	HV3	KEMAR_220	09:12	10:05	00:53	MAIN SUPPLY FAILURE
652	3-Sep-2020	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	09:12	09:46	00:34	MAIN SUPPLY FAILURE
653	3-Sep-2020	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	09:12	09:54	00:42	MAIN SUPPLY FAILURE
654	3-Sep-2020	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	09:12	09:54	00:42	MAIN SUPPLY FAILURE
655	3-Sep-2020	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	09:12	09:41	00:29	MAIN SUPPLY FAILURE
656	3-Sep-2020	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	09:12	09:42	00:30	MAIN SUPPLY FAILURE
657	3-Sep-2020	HASSAN	220	KEMAR-Kavoor3	KEMAR_220	09:12	09:43	00:31	MAIN SUPPLY FAILURE
658	3-Sep-2020	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	09:12	09:48	00:36	MAIN SUPPLY FAILURE
659	3-Sep-2020	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	09:12	10:48	01:36	MAIN SUPPLY FAILURE
660	3-Sep-2020	HASSAN	220	KEMAR-UPCL1	KEMAR_220	09:12	09:38	00:26	MAIN SUPPLY FAILURE
661	3-Sep-2020	HASSAN	220	KEMAR-UPCL2	KEMAR_220	09:12	09:38	00:26	MAIN SUPPLY FAILURE
662	3-Sep-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	09:12	10:32	01:20	LINE FAULT
663	3-Sep-2020	HASSAN	220	KEMAR-Varahi2	KEMAR_220	09:12	10:28	01:16	LINE FAULT
664	3-Sep-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	9:11 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
665	3-Sep-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	7:40 (1.09.2020)			LINE OPEN, LINE CLEAR AVAILED
666	3-Sep-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	7:40 (1.09.2020)			LINE OPEN, LINE CLEAR AVAILED
667	3-Sep-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG-220	11:43	13:51	02:08	LINE FAULT
668	3-Sep-2020	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	09:11	09:53	00:42	MAIN SUPPLY FAILURE
669	3-Sep-2020	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	09:11	09:53	00:42	MAIN SUPPLY FAILURE
670	3-Sep-2020	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	09:11	09:43	00:32	MAIN SUPPLY FAILURE
671	3-Sep-2020	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	09:11	09:44	00:33	MAIN SUPPLY FAILURE
672	3-Sep-2020	HASSAN	220	PUTTUR-KEMAR1	PUTTUR_220	09:12	09:48	00:36	MAIN SUPPLY FAILURE
673	3-Sep-2020	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	09:12	10:48	01:36	MAIN SUPPLY FAILURE
674	3-Sep-2020	HASSAN	220	UPCL-KEMAR1	upcl_gen	09:12	09:38	00:26	MAIN SUPPLY FAILURE
675	3-Sep-2020	HASSAN	220	UPCL-KEMAR2	upcl_gen	09:12	09:39	00:27	MAIN SUPPLY FAILURE
676	3-Sep-2020	HASSAN	220	UPCL-STNAUX1	upcl_gen	09:23	09:29	00:06	HAND TRIPPED
677	3-Sep-2020	HASSAN	220	VARAHI-KEMAR1	varahi_gen	09:12	10:36	01:24	LINE FAULT
678	3-Sep-2020	HASSAN	220	VARAHI-KEMAR2	varahi_gen	09:12	10:34	01:22	MAIN SUPPLY FAILURE
679	3-Sep-2020	HASSAN	220	VARAHI-KEMAR3	varahi_gen	9:11 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
680	3-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:45 (2.09.2020)	17:55 (3.09.2020)	19:10hrs	LINE CHARGED
681	3-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:03 (3.09.2020)			LINE OPEN, LINE CLEAR AVAILED
682	3-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:47 (1.09.2020)	9:27 (3.09.2020)	33:40hrs	LINE CHARGED
683	3-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:36 (2.09.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
684	3-Sep-2020	HASSAN	66	CRPATNA-HNPURA	CRPATNA_220	09:08	09:16	00:08	LINE FAULT
685	3-Sep-2020	HASSAN	66	HV1	HARIHARPURA_66	23:25 (2.09.2020)	12:52 (3.09.2020)	13:27hrs	LINE CHARGED
686	3-Sep-2020	HASSAN	66	HV1	MATTANAVILE_66	21:55 (2.09.2020)	10:52 (3.09.2020)	12:57hrs	LINE CHARGED
687	3-Sep-2020	HASSAN	66	HV1	DIDIGA_66	16:01 (3.09.2020)			LINE OPEN, LINE CLEAR AVAILED
688	3-Sep-2020	HASSAN	66	HV1	JUTTANAHALLY_66	15:24	15:42	00:18	LINE CLEAR AVAILED
689	3-Sep-2020	HASSAN	66	HV1	KUDLIGERE_66	11:20	12:00	00:40	LINE CLEAR AVAILED
690	3-Sep-2020	HASSAN	66	HV1	DIDIGA_66	11:00	11:59	00:59	LINE CLEAR AVAILED
691	3-Sep-2020	HASSAN	66	HV1	HALLYMYSORE_66	18:55	19:05	00:10	LOAD CURTAILMENT
692	3-Sep-2020	HASSAN	66	HV1	HANGRANAHALLY_66	18:55	19:05	00:10	LOAD CURTAILMENT
693	3-Sep-2020	HASSAN	66	HV1	MOSALEHOSAHALLY_66	11:37	14:01	02:24	LINE CLEAR AVAILED
694	3-Sep-2020	HASSAN	66	HV1	SINGAPURA_66	09:09	09:18	00:09	MAIN SUPPLY FAILURE
695	3-Sep-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	18:52	18:54	00:02	TRANSFORMER FAULT
696	3-Sep-2020	HASSAN	66	HV2	RAMESHWARNAGARA_66	18:55	19:22	00:27	LOAD CURTAILMENT
697	3-Sep-2020	HASSAN	66	HV2	SALAGAME_66	18:53	19:08	00:15	LOAD CURTAILMENT
698	3-Sep-2020	HASSAN	66	HV2	S,BELAGOLA_66	12:20	12:40	00:20	HAND TRIPPED
699	3-Sep-2020	HASSAN	66	HV2	SINGAPURA_66	09:09	09:18	00:09	MAIN SUPPLY FAILURE
700	3-Sep-2020	HASSAN	66	HV2	BASAVAGHATTA_66	18:52	19:05	00:13	LOAD CURTAILMENT
701	3-Sep-2020	HASSAN	66	MRSSHM-BD-1	MRSMG_220	23:21 (2.09.2020)	0:03 (3.09.2020)	0:42hrs	LINE CHARGED
702	3-Sep-2020	HASSAN	66	MRSSHM-BD-2	MRSMG_220	23:21 (2.09.2020)	14:19 (3.09.2020)	14:58hrs	LINE CHARGED
703	3-Sep-2020	MYSORE	220	HV1	CRNAGAR_220	15:34	16:04	00:30	HAND TRIPPED
704	3-Sep-2020	MYSORE	220	MADHUVANAHALLI-CR NAGARA 1	NO STATIONS EFFECTED	10:02	10:15	00:13	LINE FAULT
705	3-Sep-2020	MYSORE	220	MADHUVANAHALLI-HEBBANI 1	NO STATIONS EFFECTED	9:06(03.09.20)			LINE OPEN, LINE CLEAR AVAILED
706	3-Sep-2020	MYSORE	66	BANNANGADI-CHINKURALI	CHINAKURALI_66	08:00	17:00	09:00	LINE CLEAR AVAILED
707	3-Sep-2020	MYSORE	66	CR NAGARA-DR PETE 1	NO STATIONS EFFECTED	11:48	12:55	01:07	NFBC ISSUED
708	3-Sep-2020	MYSORE	66	CR NAGARA-DR PETE 2	NO STATIONS EFFECTED	14:20	15:03	00:43	NFBC ISSUED
709	3-Sep-2020	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	15:43 (02/09/2020)			LINE OPEN, LINE FAULT
710	3-Sep-2020	MYSORE	66	FTS-HOOTAGALLI 1	NO STATIONS EFFECTED	08:45	18:14	09:28	NFBC ISSUED
711	3-Sep-2020	MYSORE	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	09:10	17:38	08:28	NFBC ISSUED
712	3-Sep-2020	MYSORE	66	FTS-RAJEEV NAGARA	FTS_66	10:06	17:40	07:33	NFBC ISSUED
713	3-Sep-2020	MYSORE	66	HV1	BGPURA_66	07:30	16:09	08:38	LINE CLEAR AVAILED
714	3-Sep-2020	MYSORE	66	HV1	BGPURA_66	18:55	19:14	00:19	LOAD CURTAILMENT
715	3-Sep-2020	MYSORE	66	HV1	COWDALLI_66	12:05	12:28	00:23	LINE CLEAR AVAILED
716	3-Sep-2020	MYSORE	66	HV1	HONNALLY_MYS_66	17:50	18:05	00:15	TRANSFORMER FAULT
717	3-Sep-2020	MYSORE	66	HV1	MALAVALLI_66	20:29	20:35	00:05	TRANSFORMER FAULT
718	3-Sep-2020	MYSORE	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
719	3-Sep-2020	MYSORE	66	HV2	BGPURA_66	07:31	16:02	08:31	LINE CLEAR AVAILED
720	3-Sep-2020	MYSORE	66	HV2	CHINAKURALI_66	18:52	19:17	00:25	LOAD CURTAILMENT
721	3-Sep-2020	MYSORE	66	HV2	ELAVALA_66	18:55	19:05	00:10	LOAD CURTAILMENT
722	3-Sep-2020	MYSORE	66	HV2	HOOTAGALLY_220	12:26	13:30	01:04	LINE CLEAR AVAILED
723	3-Sep-2020	MYSORE	66	HV2	JAIPUR_66	18:55	19:09	00:14	LOAD CURTAILMENT
724	3-Sep-2020	MYSORE	66	HV2	KMDODDI_66	18:52	19:08	00:16	TRANSFORMER FAULT
725	3-Sep-2020	MYSORE	66	HV2	SANTHEMARAHALLI_66	18:55	19:25	00:30	LOAD CURTAILMENT
726	3-Sep-2020	MYSORE	66	K HONNALGERE-MADDUR	SOMANAHALLI_66 MADDUR_66	11:00	11:05	00:05	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
727	3-Sep-2020	MYSORE	66	KR PETE 220-SANTHEBACHALLI	SANTHEBACHALLI_66 HARIYALDAMMATEMPLE 66	23:58 (02/09/2020)	0:07(03.9.20)	0:09 HRS	LINE CHARGED
728	3-Sep-2020	MYSORE	66	MADDUR-KIADB MANDYA	NO STATIONS EFFECTED	10:58	12:43	01:44	NFBC ISSUED
729	3-Sep-2020	MYSORE	66	MADHUVANAHALLI-HANNUR1	NO STATIONS EFFECTED	17:39	18:30	00:51	HAND TRIPPED
730	3-Sep-2020	MYSORE	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	10:12 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
731	3-Sep-2020	MYSORE	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	11:10 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
732	3-Sep-2020	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	13:29	17:08	03:39	LINE CLEAR AVAILED
733	3-Sep-2020	MYSORE	66	MEGALAPURA-SFC	THUMBLA_66 GARGESHWARI_66 VYASRAJPURA_66 CHIDRAVALI_66 BGPURA_66	13:30	13:41	00:11	LINE FAULT
734	3-Sep-2020	MYSORE	66	SB HALLI-KR PETE 220KV	SANTHEBACHALLI_66 HARIYALDAMMATEMPLE 66	17:05	17:45	00:40	LINE CLEAR AVAILED
735	3-Sep-2020	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	20:48	20:57	00:09	MAIN SUPPLY FAILURE
736	3-Sep-2020	TUMKUR	66	HIREGUNTANUR- CHITRADURGA	HIREGUNTANUR_66	13:03	13:59	00:56	LINE CLEAR AVAILED
737	3-Sep-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	09:44	09:54	00:09	LINE FAULT
738	3-Sep-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:51	12:56	00:04	LINE CLEAR AVAILED
739	3-Sep-2020	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	17:57	18:00	00:02	HAND TRIPPED
740	3-Sep-2020	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	17:57	18:00	00:03	HAND TRIPPED
741	3-Sep-2020	TUMKUR	66	TR-1	AMRUTHUR_66	12:02	13:24	01:21	LINE CLEAR AVAILED
742	3-Sep-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	10:56	12:05	01:08	LINE CLEAR AVAILED
743	3-Sep-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
744	3-Sep-2020	TUMKUR	66	TR-2	HARIYABBE_66	20:34	20:57	00:23	MAIN SUPPLY FAILURE
745	3-Sep-2020	TUMKUR	66	TR-2	HOSADURGA_66	12:16	12:31	00:15	LINE CLEAR AVAILED
746	3-Sep-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	18:05	19:55	01:49	LINE CLEAR AVAILED
747	3-Sep-2020	TUMKUR	66	TR-2	KOLALA_66	11:32	12:33	01:01	LINE CLEAR AVAILED
748	3-Sep-2020	TUMKUR	66	TR-3	HARIYABBE_66	20:34	20:57	00:23	MAIN SUPPLY FAILURE
749	3-Sep-2020	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	11:12	12:20	01:08	LINE CLEAR AVAILED
750	3-Sep-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	10:46	10:52	00:05	TRANSFORMER FAULT
751	3-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN , TRANSFORMER FAULT
752	3-Sep-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	5:38:51 AM(01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
753	3-Sep-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	01:16	06:42	05:26	LINE CLEAR AVAILED
754	3-Sep-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	16:41	17:17	00:35	HAND TRIPPED
755	3-Sep-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	15:52	16:26	00:34	HAND TRIPPED
756	3-Sep-2020	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	5:46:08 AM(01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
757	3-Sep-2020	TUMKUR	220	PAVAGADA66-MADHUGIRI	PAVAGADA_66	01:05	06:44	05:39	LINE FAULT
758	3-Sep-2020	TUMKUR	220	TR-1	CHIKKANAYAKANAHALLI_110	06:02	06:16	00:14	TRANSFORMER FAULT
759	3-Sep-2020	TUMKUR	220	TR-2	MADHUGIRI_220	17:13	17:57	00:43	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
760	4-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
761	4-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
762	4-Sep-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
763	4-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
764	4-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
765	4-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)	12:40 (04.09.2020)	1104hrs	LINE CHARGED
766	4-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
767	4-Sep-2020	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
768	4-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
769	4-Sep-2020	BAGALKOT	110	220/110KV, LV 1	STATION NOT AFFECTED BAGALKOT_220	13:05 (27.08.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
770	4-Sep-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1&2(NANDIHAL1&2)	STATION NOT AFFECTED BAGEWADI_220	13:20 (29.08.2020)			LOAD CURTAILMENT
771	4-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
772	4-Sep-2020	BAGALKOT	110	AMBEWADI(KAVALWADA)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	13:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
773	4-Sep-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
774	4-Sep-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
775	4-Sep-2020	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51 (01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
776	4-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	BAGEWADI_220	12:19 (02.09.2020)			LINE OPEN, LINE CLEAR AVAILED
777	4-Sep-2020	BAGALKOT	220	NAGJHARI1- HUBLI	STATION NOT AFFECTED HUBLI_220	13:48 (03.09.2020)	16:24 (04.09.2020)	26:36hrs	LINE CHARGED
778	4-Sep-2020	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	7:20 (03.09.2020)	8:51 (04.09.2020)	1:31HRS	TRANSFORMER CHARGED
779	4-Sep-2020	BAGALKOT	220	NAGJHARI 1-AMBEWADI	STATION NOT AFFECTED AMBEWADI_220	14:39	16:31	1:52	LINE FAULT
780	4-Sep-2020	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110 & LIS,W/S_33	15:04	17:06	2:02	LINE CLEAR AVAILED
781	4-Sep-2020	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	11:01	14:39	3:38	LINE CLEAR AVAILED
782	4-Sep-2020	BAGALKOT	110	110/11KV,HV2	HATTARGI_110	9:33	10:24	0:51	LINE CLEAR AVAILED
783	4-Sep-2020	BAGALKOT	110	SUZLON1(3)	DAMBAL_110	6:19	6:54	0:35	HAND TRIPPED
784	4-Sep-2020	BAGALKOT	110	110/11KV,HV1	HIDIKAL DAM_110	11:09	15:51	4:42	LINE CLEAR AVAILED
785	4-Sep-2020	BAGALKOT	110	110/33KV,HV3	GOKAK_110,RIDDI SIDDI_33,KOLAVI SUGARS_110	11:12	14:43	3:31	LINE CLEAR AVAILED
786	4-Sep-2020	BAGALKOT	110	110/11KV,HV4	KERUR_110	12:43	14:02	1:19	LINE CLEAR AVAILED
787	4-Sep-2020	BAGALKOT	110	110/11KV,HV1	KHANAPUR_110	18:07	18:28	0:21	LINE CLEAR AVAILED
788	4-Sep-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	10:50	11:20	0:30	LINE CLEAR AVAILED
789	4-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	14:47	15:24	0:37	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
790	4-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM_220	15:55	19:05	3:10	LINE FAULT
791	4-Sep-2020	BAGALKOT	110	GADAG220-DAMBAL	DAMBAL_110	4:32	5:00	0:28	LINE FAULT
792	4-Sep-2020	BAGALKOT	110	HAVERI220-HANAGAL	HANAGAL_110	0:24	0:37	0:13	LINE FAULT
793	4-Sep-2020	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	RABAKAVI_110	13:02	13:11	0:09	HAND TRIPPED
794	4-Sep-2020	BAGALKOT	110	MK HUBLI220-HIREBAGEWADI	HIREBAGEWADI_110	13:09	13:20	0:11	LINE FAULT
795	4-Sep-2020	BAGALKOT	110	110/11KV,HV1	MUNDGOD_110	11:28	13:20	1:52	LINE CLEAR AVOIDED
796	4-Sep-2020	BAGALKOT	66	66/11KV,HV2	HARIHAR-HOSPET_33	12:48	14:17	1:29	LINE CLEAR AVOIDED
797	4-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
798	4-Sep-2020	BAGALKOT	220	HUBLI- SIRSI1	STATION NOT AFFECTED HUBLI_220	6:11	12:51	6:40	LINE FAULT
799	4-Sep-2020	BAGALKOT	220	NAGJHARI2- HUBLI	STATION NOT AFFECTED HUBLI_220	10:27	16:28	6:01	LINE CLEAR AVOIDED
800	4-Sep-2020	BAGALKOT	110	HUBLI- TARIHAL2	STATION NOT AFFECTED TARIHAL_110	6:11	11:51	5:40	LINE FAULT
801	4-Sep-2020	BAGALKOT	110	110/11KV, HV2	SAVALAGI_110, KALABILAGI_33, TUNGAL & HIREPADASALAGI-LIS_33	14:26	14:31	0:05	HAND TRIPPED
802	4-Sep-2020	BAGALKOT	110	RANEBENNUR220-HIREKERUR	HIREKERUR_110	8:08	14:28	6:20	LINE CLEAR AVOIDED
803	4-Sep-2020	BAGALKOT	110	110/11KV, HV1	NAVANAGAR(B)_110	10:02	10:36	0:34	LINE CLEAR AVOIDED
804	4-Sep-2020	BENGALURU	66	SRS PEENYA - T G HALLI	BYADRAHALLI, TAVAREKERE, KODIGENAHALLI	12:53	13:12	00:19	LINE FAULT
805	4-Sep-2020	BENGALURU	66	BYADRAHALLI - KODIGENAHALLI	KODIGENAHALLI	12:53	14:24	01:31	LINE CLEAR AVOIDED
806	4-Sep-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	19:15	19:45	00:30	LOAD CURTAILMENT
807	4-Sep-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	19:15	19:45	00:30	LOAD CURTAILMENT
808	4-Sep-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	19:45	20:01	00:16	LOAD CURTAILMENT
809	4-Sep-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	19:45	20:01	00:16	LOAD CURTAILMENT
810	4-Sep-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	20:01	20:21	00:20	LOAD CURTAILMENT
811	4-Sep-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	20:01	20:21	00:20	LOAD CURTAILMENT
812	4-Sep-2020	BENGALURU	66	HV1	NANGALI	11:30	12:35	01:05	LINE CLEAR AVOIDED
813	4-Sep-2020	BENGALURU	66	HV1	HOSKOTE 66	13:20	17:20	04:00	LINE CLEAR AVOIDED
814	4-Sep-2020	BENGALURU	66	HV1	HOSKOTE 66	17:35	17:45	00:10	LINE CLEAR AVOIDED
815	4-Sep-2020	BENGALURU	66	HV1	HAROBEL	12:32	13:40	01:07	LINE CLEAR AVOIDED
816	4-Sep-2020	BENGALURU	66	HV1	HAROBEL	14:05	14:10	00:05	LINE CLEAR AVOIDED
817	4-Sep-2020	BENGALURU	66	HV2	DOMMASANDRA	16:22	16:34	00:11	LINE CLEAR AVOIDED
818	4-Sep-2020	BENGALURU	66	HV1	RAJANKUNTE	10:46	11:00	00:13	TRANSFORMER FAULT
819	4-Sep-2020	BENGALURU	66	HV2	RAJANKUNTE	10:37	10:45	00:07	LINE CLEAR AVOIDED
820	4-Sep-2020	BENGALURU	66	MALLASANDRA - KOLAR 220	DALASANUR, MALLASANDRA	12:30	12:45	00:15	MAIN SUPPLY FAILURE
821	4-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
822	4-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
823	4-Sep-2020	GULBARGA	220	RTPS-SEDAM1	SEDAM_220	00:58	01:14	00:16	LINE FAULT
824	4-Sep-2020	GULBARGA	220	SHAHAPUR-KAPNOOR1	KAPNOOR_400	00:05	01:52	01:47	LINE CLEAR AVOIDED
825	4-Sep-2020	GULBARGA	220	HV1	LINGASUGUR_220	07:56	08:11	00:15	TRANSFORMER FAULT
826	4-Sep-2020	GULBARGA	220	HV2	LINGASUGUR_220	07:56	08:24	00:28	TRANSFORMER FAULT
827	4-Sep-2020	GULBARGA	220	HV1	LINGASUGUR_220	08:37	09:21	00:44	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
828	4-Sep-2020	GULBARGA	220	HV2	LINGASUGUR_220	08:37	08:56	00:19	TRANSFORMER FAULT
829	4-Sep-2020	GULBARGA	110	HV1	KOLHAR_110	11:35	12:44	01:09	LINE CLEAR AVAILED
830	4-Sep-2020	GULBARGA	110	HV1	KOLHAR_110	13:20	13:25	00:05	LINE CLEAR AVAILED
831	4-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, HUNSAGI_110, ASKI_110, UGAR SUGAR IPP	00:51	01:00	00:09	LINE FAULT
832	4-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, HUNSAGI_110, ASKI_110, UGAR SUGAR IPP	01:28	01:31	00:03	LINE FAULT
833	4-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, HUNSAGI_110, ASKI_110, UGAR SUGAR IPP	02:15	02:21	00:06	LINE FAULT
834	4-Sep-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110, SAIDAPUR_110, WADAGERA_110, NALWAR_110, SANNATI_110, COREGREEN IPP	14:07	14:42	00:35	LINE FAULT
835	4-Sep-2020	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110, NSLSUGSARFACTORY_I PP, CHOWDAPUR_110	05:48	05:55	00:07	LINE FAULT
836	4-Sep-2020	GULBARGA	110	HV3	KAMPLI_110	18:55	19:31	00:36	LOAD CURTAILMENT
837	4-Sep-2020	GULBARGA	110	HV1, HV2	RAJESHWAR_110	18:53	19:05	00:12	LOAD CURTAILMENT
838	4-Sep-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110, SAIDAPUR_110, WADAGERA_110, NALWAR_110, SANNATI_110, COREGREEN IPP	18:05	18:28	00:23	LINE FAULT
839	4-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, HUNSAGI_110, ASKI_110, UGAR SUGAR IPP	21:52	21:59	00:07	LINE FAULT
840	4-Sep-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	23:38	23:44	00:06	LINE FAULT
841	4-Sep-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	DEODURGA_110, GABUR_110	09:44	13:44	04:00	LINE CLEAR AVAILED
842	4-Sep-2020	GULBARGA	110	RAICHUR-SHAHAPUR1	GOOGLE_110	14:08	14:48	00:40	LINE CLEAR AVAILED
843	4-Sep-2020	GULBARGA	110	RAICHUR-APMC2	APMC_110, CHICKSUGUR_110, SHAKTI NAGAR_110	16:48	17:03	00:15	LINE CLEAR AVAILED
844	4-Sep-2020	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	19:26	20:23	00:57	LINE CLEAR AVAILED
845	4-Sep-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	DEODURGA_110, GABUR_110	19:26	21:00	01:34	LINE CLEAR AVAILED
846	4-Sep-2020	GULBARGA	66	HV1	HANASI_66	07:12	08:05	00:53	LINE CLEAR AVAILED
847	4-Sep-2020	GULBARGA	110	LINGASUGUR-MUDGAL	MUDGAL_110	08:37	23:59	15:22	LINE CLEAR AVAILED
848	4-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:03 (3.09.2020)	7:28(04.09.2020)	8:25hrs	LINE CHARGED
849	4-Sep-2020	HASSAN	220	MRSSHM-ANTRSNH	MRS MG_220	7:40 (1.09.2020)	13:16(04.09.2020)	5:36hrs	LINE CHARGED
850	4-Sep-2020	HASSAN	66	HV1	DIDIGA_66	16:01 (3.09.2020)	19:12 (4.09.2020)	27:11hrs	LINE CHARGED
851	4-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	14:43(04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
852	4-Sep-2020	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	20:33(04.09.2020)			LINE OPEN, LINE FAULT
853	4-Sep-2020	HASSAN	220	MRSSHM-ANTRSNH	MRS MG_220	13:27(04.09.2020)			LINE OPEN, LINE FAULT
854	4-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:36 (2.09.2020)			LINE OPEN, LINE CLEAR AVAILED
855	4-Sep-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	9:11 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
856	4-Sep-2020	HASSAN	220	VARAHI-KEMAR3	varahi_gen	9:11 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
857	4-Sep-2020	HASSAN	220	MRSSHM-KBCRS	MRS MG_220	7:40 (1.09.2020)			LINE OPEN, LINE CLEAR AVAILED
858	4-Sep-2020	HASSAN	110	HALADY11-HIRIYADKA	HALADY_110	9:27 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
859	4-Sep-2020	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	9:27 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
860	4-Sep-2020	HASSAN	66	HV2	CHANNARAYAPATTANA_66	11:55(04.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
861	4-Sep-2020	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	14:58	15:46	00:48	LINE FAULT
862	4-Sep-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	09:50	13:47	03:57	LINE CLEAR AVAILED
863	4-Sep-2020	HASSAN	220	VARAH1-SHIMOGA1	gen_varahi	09:50	13:47	03:57	LINE CLEAR AVAILED
864	4-Sep-2020	HASSAN	110	HV1	GANDASI_110	12:58	13:30	00:32	LINE CLEAR AVAILED
865	4-Sep-2020	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	10:33	11:39	01:06	LINE CLEAR AVAILED
866	4-Sep-2020	HASSAN	110	KEMAR-BELMAN	KEMAR_220	16:15	18:48	02:33	LINE CLEAR AVAILED
867	4-Sep-2020	HASSAN	110	HV2	NERALAKERE_110	12:12	12:57	00:45	LINE CLEAR AVAILED
868	4-Sep-2020	HASSAN	110	SAGARA-SORABA	SAGARA_110	11:50	14:53	03:03	LINE CLEAR AVAILED
869	4-Sep-2020	HASSAN	66	CHANNARA-UDAYAPURA	CHANNARAYAPATTANA_66	11:06	17:15	06:09	NFBC ISSUED
870	4-Sep-2020	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	19:30	19:36	00:06	LINE FAULT
871	4-Sep-2020	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	12:00	12:10	00:10	HAND TRIPPED
872	4-Sep-2020	HASSAN	66	HV1	MALALI_66	19:30	19:40	00:10	MAIN SUPPLY FAILURE
873	4-Sep-2020	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	12:10	12:25	00:15	HAND TRIPPED
874	4-Sep-2020	MYSORE	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	10:49	13:55	3:05	NFBC ISSUED
875	4-Sep-2020	MYSORE	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	17:27	17:48	0:21	HAND TRIPPED
876	4-Sep-2020	MYSORE	66	MADHUVANAHALLI-HANNUR 1	NO STATIONS EFFECTED	17:03	17:25	0:22	HAND TRIPPED
877	4-Sep-2020	MYSORE	220	MADHUVANAHALLI-HV1	NO STATIONS EFFECTED	15:20	15:36	0:16	HAND TRIPPED
878	4-Sep-2020	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	18:06	18:51	0:45	LINE CLEAR AVAILED
879	4-Sep-2020	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	14:11	14:16	0:05	LINE FAULT
880	4-Sep-2020	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	17:41	18:00	0:19	HAND TRIPPED
881	4-Sep-2020	MYSORE	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	6:45	6:55	0:10	LINE FAULT
882	4-Sep-2020	MYSORE	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	17:55	18:14	0:19	HAND TRIPPED
883	4-Sep-2020	MYSORE	66	MADHUVANAHALLI-DODDINADUVADI	NO STATIONS EFFECTED	18:05	18:25	0:20	HAND TRIPPED
884	4-Sep-2020	MYSORE	66	HV2	RKNAGARA_66	13:10	14:30	1:20	LINE CLEAR AVAILED
885	4-Sep-2020	MYSORE	66	HV1	RKNAGARA_66	11:06	13:04	1:58	LINE CLEAR AVAILED
886	4-Sep-2020	MYSORE	220	HOOTAGALLI-HV3	BELAGOLA_66 ELAVALA_66 GAVADAGERE_66 HUNSUR_66 BANNIKUPPE_66 HOSURGATE_66	13:34	14:03	0:29	LINE FAULT
887	4-Sep-2020	MYSORE	66	HOOTAGALLI-KHB	KHBCOLONY_66	13:34	17:40	4:06	LINE FAULT
888	4-Sep-2020	MYSORE	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)	11:38(01/9/2020)	1461:05 HRS	TRANSFORMER CHARGED
889	4-Sep-2020	MYSORE	220	MADHUVANAHALLI-HEBBANI 1	NO STATIONS EFFECTED	9:06:00 AM (03/09/2020)	7:15(4/9/2020)	32:09 HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
890	4-Sep-2020	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	15:43 (02/09/2020)	13:38(4/9/2020)	45:55 HRS	LINE IS CHARGED ON 04.09.2020 @ 13:38 HRS . TRIPPED ON DPR, OCR & EFR. TEST CHARGED THE LINE BREAKER BUT AGAIN LINE TRIPPED. THE SAME HAS BEEN INFORMED TO TLI STAFF AND KEPT OPEN.(WATER ACCUMILATED DUE TO HEAVY RAIN). NFBC ISSUED TO JE(S) IN ORDER TO ISSUE LC TO TLI JE FOR D CAP REPLACEMENT OF INSULATOR @ TOWER 4. (AS
891	4-Sep-2020	MYSORE	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	11:10 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
892	4-Sep-2020	MYSORE	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	10:12 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
893	4-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN , TRANSFORMER FAULT
894	4-Sep-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
895	4-Sep-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	5:38(01.09.2020)	19:18(04.09.2020)	85:38hrs	LINE CHARGED
896	4-Sep-2020	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	5:46(01.09.2020)	18:55(04.09.2020)	85:08hrs	LINE CHARGED
897	4-Sep-2020	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	0:50	6:53	6:02	LINE CLEAR AVAILED
898	4-Sep-2020	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	12:53	13:47	0:53	LINE CLEAR AVAILED
899	4-Sep-2020	TUMKUR	220	TR-1(HV SIDE)	CHITRADURGA_220	11:51	19:22	7:31	LINE CLEAR AVAILED
900	4-Sep-2020	TUMKUR	220	TR-2(HV SIDE)	CHITRADURGA_220	11:51	19:25	7:33	LINE CLEAR AVAILED
901	4-Sep-2020	TUMKUR	220	CHITRADURGA 220kv- THALLAK 220	CHITRADURGA_220	7:20	19:27	12:06	LINE CLEAR AVAILED
902	4-Sep-2020	TUMKUR	220	THALLAK 220kv-CHITRADURGA	THALLAKK_220	7:21	18:48	11:26	LINE CLEAR AVAILED
903	4-Sep-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	15:35	18:57	3:22	LINE CLEAR AVAILED
904	4-Sep-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	10:49	12:24	1:35	LINE CLEAR AVAILED
905	4-Sep-2020	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	11:30	19:17	7:47	LINE CLEAR AVAILED
906	4-Sep-2020	TUMKUR	110	TR-1	KGTEMPLE_110	16:46	17:56	1:09	LINE CLEAR AVAILED
907	4-Sep-2020	TUMKUR	110	NITTUR 220kv- KADABA	KADABA_110	19:23	19:37	0:14	LOAD CURTAILMENT
908	4-Sep-2020	TUMKUR	110	NITTUR 220kv- KALLUR	KALLUR_110	19:23	19:35	0:11	LOAD CURTAILMENT
909	4-Sep-2020	TUMKUR	110	NITTUR 220kv- KG TEMPLE	KGTEMPLE_110, UNGRA_110	19:23	19:38	0:14	LOAD CURTAILMENT
910	4-Sep-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	19:02	20:01	0:59	LOAD CURTAILMENT
911	4-Sep-2020	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	7:36	7:38	0:01	HAND TRIPPED
912	4-Sep-2020	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	11:55	12:44	0:49	HAND TRIPPED
913	4-Sep-2020	TUMKUR	66	TR-1	BALENAHALLI_66	15:00	15:09	0:08	TRANSFORMER FAULT
914	4-Sep-2020	TUMKUR	66	TR-2	BALENAHALLI_66	15:03	15:09	0:06	HAND TRIPPED
915	4-Sep-2020	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	14:28	14:39	0:10	LINE FAULT
916	4-Sep-2020	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	18:41	18:48	0:07	LINE FAULT
917	4-Sep-2020	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	19:30	19:36	0:05	LINE FAULT
918	4-Sep-2020	TUMKUR	66	CHITRADURGA 220kv-CHITRADURGA2	CHITRADURGA_66	19:21	20:07	0:46	LINE CLEAR AVAILED
919	4-Sep-2020	TUMKUR	66	TR-2	CHITRADURGA_220	7:20	7:44	0:23	LINE CLEAR AVAILED
920	4-Sep-2020	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	7:26	19:24	11:58	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
921	4-Sep-2020	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	7:29	19:25	11:56	LINE CLEAR AVAILED
922	4-Sep-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66, CHITRA HALLI_66	17:44	19:34	1:49	LINE CLEAR AVAILED
923	4-Sep-2020	TUMKUR	66	CHITRADURGA 220kV- SUZLON 2	SUZLON1_IPP_66	17:50	19:37	1:47	LINE CLEAR AVAILED
924	4-Sep-2020	TUMKUR	66	TR-2(LV SIDE)	DAVANGERE_SRS_220	16:29	17:41	1:12	LINE CLEAR AVAILED
925	4-Sep-2020	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 1	CHITRADURGA_66	17:44	19:06	1:22	MAIN SUPPLY FAILURE
926	4-Sep-2020	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA2	CHITRADURGA_66	17:42	19:05	1:23	MAIN SUPPLY FAILURE
927	4-Sep-2020	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	11:51	12:23	0:31	MAIN SUPPLY FAILURE
928	4-Sep-2020	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	0:54	1:28	0:33	LINE FAULT
929	4-Sep-2020	TUMKUR	66	H D PURA- CHITRADURGA220	HDPURA_66	11:03	13:30	2:26	MAIN SUPPLY FAILURE
930	4-Sep-2020	TUMKUR	66	TR-1	HDPURA_66	14:07	14:11	0:04	LINE CLEAR AVAILED
931	4-Sep-2020	TUMKUR	66	HEGGERE- MALLASANDRA2	MALLASANDRA_66	9:56	10:20	0:23	LINE FAULT
932	4-Sep-2020	TUMKUR	66	HEGGERE- MALLASANDRA2	MALLASANDRA_66	14:36	14:59	0:22	LINE CLEAR AVAILED
933	4-Sep-2020	TUMKUR	66	HEGGERE- MALLASANDRA2	MALLASANDRA_66	19:45	20:15	0:29	MAIN SUPPLY FAILURE
934	4-Sep-2020	TUMKUR	66	HIRIYUR 220KV- CHITRADURGA(SIRA)	HIRIYUR_220	0:04	0:17	0:12	LINE FAULT
935	4-Sep-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	12:54	13:03	0:09	LINE FAULT
936	4-Sep-2020	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	6:12	6:23	0:11	LINE FAULT
937	4-Sep-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66, BAGUR_66, NEELAGUNDA_66	8:02	8:10	0:08	LINE FAULT
938	4-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	10:51	11:36	0:45	LINE FAULT
939	4-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-2	INFOSYS-2	15:57	16:06	0:08	HAND TRIPPED
940	4-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	11:27	11:52	0:25	LINE FAULT
941	4-Sep-2020	TUMKUR	66	TR-1	KATTIGE_66	15:28	17:18	1:49	LINE CLEAR AVAILED
942	4-Sep-2020	TUMKUR	66	TR-2	KOLALA_66	11:20	14:57	3:36	LINE CLEAR AVAILED
943	4-Sep-2020	TUMKUR	66	TR-2	KOLALA_66	17:33	17:47	0:14	LINE CLEAR AVAILED
944	5-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
945	5-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
946	5-Sep-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
947	5-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
948	5-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
949	5-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
950	5-Sep-2020	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
951	5-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
952	5-Sep-2020	BAGALKOT	110	220/110KV,LV 1	STATION NOT AFFECTED BAGALKOT_220	13:05 (27.08.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
953	5-Sep-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1&2(NANDIHAL1&2)	STATION NOT AFFECTED BAGEWADI_220	13:20 (29.08.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
954	5-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
955	5-Sep-2020	BAGALKOT	110	AMBEWADI(KAVALWADA)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	13:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
956	5-Sep-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
957	5-Sep-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
958	5-Sep-2020	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51 (01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
959	5-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	12:19 (02.09.2020)			LINE OPEN, LINE CLEAR AVAILED
960	5-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
961	5-Sep-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	11:37	11:46	0:09	TRANSFORMER FAULT
962	5-Sep-2020	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	VAJRAMATTI_220	13:02	13:28	0:26	LINE FAULT
963	5-Sep-2020	BAGALKOT	110	110/11KV, HV1	SIRSI_220	11:56	12:15	0:19	LINE CLEAR AVOID
964	5-Sep-2020	BAGALKOT	110	110/11KV, HV2	RON_110	16:19	16:35	0:16	LINE CLEAR AVOID
965	5-Sep-2020	BAGALKOT	110	110/11KV, HV1	RATTIHALI_110	15:53	16:45	0:52	LINE CLEAR AVOID
966	5-Sep-2020	BAGALKOT	110	110/11KV, HV2	RATTIHALI_110	10:02	18:36	8:34	LINE CLEAR AVOID
967	5-Sep-2020	BAGALKOT	110	110/11KV, HV2	NAVANAGAR(B)_110	15:32	15:51	0:19	LINE CLEAR AVOID
968	5-Sep-2020	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	10:02	21:00	10:58	NFBC ISSUED
969	5-Sep-2020	BAGALKOT	220	AMBEWADI-PONDA1	AMBEWADI_220	14:02	14:48	0:46	LINE FAULT
970	5-Sep-2020	BAGALKOT	110	110/11KV,HV1	KANABARGI LAY OUT_110	0:55	10:23	9:28	TRANSFORMER FAULT
971	5-Sep-2020	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	16:35	17:08	00:33	LINE CLEAR AVOID
972	5-Sep-2020	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	08:02	19:35	11:33	LINE CLEAR AVOID
973	5-Sep-2020	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPAHALLI	10:22	13:03	02:41	LINE CLEAR AVOID
974	5-Sep-2020	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	10:20	10:27	00:07	LINE CLEAR AVOID
975	5-Sep-2020	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	14:43	14:48	00:05	LINE CLEAR AVOID
976	5-Sep-2020	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	14:43	14:48	00:05	LINE CLEAR AVOID
977	5-Sep-2020	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	10:20	10:27	00:07	LINE CLEAR AVOID
978	5-Sep-2020	BENGALURU	66	HV2	R R NAGAR	16:20	16:36	00:16	TRANSFORMER FAULT
979	5-Sep-2020	BENGALURU	66	HV2	REMCO	06:47	06:48	00:01	LOAD CHANGE OVER
980	5-Sep-2020	BENGALURU	66	KOLAR 220 - NARASAPURA	NARASAPURA	17:25	18:04	00:39	LINE FAULT
981	5-Sep-2020	BENGALURU	220	HV3	KOLAR 220	21:18	22:34	01:16	LINE CLEAR AVOID
982	5-Sep-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	20:37	22:39	02:02	LINE CLEAR AVOID
983	5-Sep-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	20:37	20:46	00:09	LINE CLEAR AVOID
984	5-Sep-2020	BENGALURU	66	KOLAR 220 - NARASAPURA	NARASAPURA	20:37	20:48	00:11	LINE CLEAR AVOID
985	5-Sep-2020	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	08:50	16:22	07:32	LINE CLEAR AVOID
986	5-Sep-2020	BENGALURU	66	HV2	MELLAHALLI	17:45	18:07	00:22	TRANSFORMER FAULT
987	5-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
988	5-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
989	5-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
990	5-Sep-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	23:25(5.9.2020)			LINE OPEN, LINE FAULT
991	5-Sep-2020	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	12:23	12:38	00:15	LINE FAULT
992	5-Sep-2020	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	00:04	00:30	00:26	LINE FAULT
993	5-Sep-2020	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	12:08	12:34	00:26	LINE FAULT
994	5-Sep-2020	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220,MALLAT_220	19:51	20:14	00:23	LINE FAULT
995	5-Sep-2020	GULBARGA	110	LINGASUGUR-MUDGAL	MUDGAL_110	8:37(4.9.2020)	0:06(05.09.2020)	15:29 HRS	LINE CHARGED
996	5-Sep-2020	GULBARGA	110	HV1	PDHALLI_110	06:30	11:04	04:34	LINE CLEAR AVAILED
997	5-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, HUNSAGI_110, ASKI_110, UGAR SUGAR IPP	00:08	00:12	00:04	LINE FAULT
998	5-Sep-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	19:36	19:42	00:06	LINE FAULT
999	5-Sep-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	20:09	20:17	00:08	LINE FAULT
1000	5-Sep-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	20:45	20:56	00:11	LINE FAULT
1001	5-Sep-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	22:56	23:08	00:12	LINE FAULT
1002	5-Sep-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	04:29	04:35	00:06	LINE FAULT
1003	5-Sep-2020	GULBARGA	66	HV1	ITTAGGI_220	12:39	12:51	00:12	TRANSFORMER FAULT
1004	5-Sep-2020	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66	22:16	22:40	00:24	LINE FAULT
1005	5-Sep-2020	GULBARGA	66	HV2	TAMBRAHALLI_66	12:27	13:15	00:48	LINE CLEAR AVAILED
1006	5-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:36 (2.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1007	5-Sep-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	9:11 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
1008	5-Sep-2020	HASSAN	220	VARAHI-KEMAR3	varahi_gen	9:11 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
1009	5-Sep-2020	HASSAN	110	HALADY11-HIRIYADKA	HALADY_110	9:27 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
1010	5-Sep-2020	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	9:27 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
1011	5-Sep-2020	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	20:33(04.09.2020)	12:45 (5.09.2020)	16:12hrs	LINE CHARGED
1012	5-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	14:43(04.09.2020)	6:42 (5.09.2020)	14:59hrs	LINE CHARGED
1013	5-Sep-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	13:27(04.09.2020)	11:46 (05.09.2020)	22:19hrs	LINE CHARGED
1014	5-Sep-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	7:40 (1.09.2020)	12:00 (05.09.2020)	9:20hrs	LINE CHARGED
1015	5-Sep-2020	HASSAN	66	HV2	CHANNARYAPATNA_66	11:55(04.09.2020)	18:59(05.09.2020)	31:04hrs	LINE CHARGED
1016	5-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	18:23 (5.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1017	5-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:42(05.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1018	5-Sep-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	14:00 (5.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1019	5-Sep-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	14:00(05.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1020	5-Sep-2020	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	10:32	18:41	08:09	LINE CLEAR AVAILED
1021	5-Sep-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	12:52	16:37	03:45	LINE FAULT
1022	5-Sep-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	12:03	16:40	04:37	LINE FAULT
1023	5-Sep-2020	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	22:08	22:30	00:22	LINE FAULT
1024	5-Sep-2020	HASSAN	110	HV1	NITTUR_110	20:25	21:52	01:27	MAIN SUPPLY FAILURE
1025	5-Sep-2020	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	20:25	21:50	01:25	MAIN SUPPLY FAILURE
1026	5-Sep-2020	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	10:15	14:34	04:19	LINE CLEAR AVAILED
1027	5-Sep-2020	HASSAN	110	HV2	ARASIKERE_110	13:30	13:35	00:05	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
1028	5-Sep-2020	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	10:18	13:21	03:03	LINE CLEAR AVAILED
1029	5-Sep-2020	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	20:31	21:47	01:16	MAIN SUPPLY FAILURE
1030	5-Sep-2020	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	20:31	21:52	01:21	MAIN SUPPLY FAILURE
1031	5-Sep-2020	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	20:31	21:43	01:12	LINE FAULT
1032	5-Sep-2020	HASSAN	110	HV2	MOODABIDRE_110	19:07	19:50	00:43	MAIN SUPPLY FAILURE
1033	5-Sep-2020	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	10:25	10:59	00:34	LINE FAULT
1034	5-Sep-2020	HASSAN	66	HASSN22-ARAKALGUD2	HASSAN_220	00:55	01:09	00:14	LINE FAULT
1035	5-Sep-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	13:30	14:06	00:36	LINE CLEAR AVAILED
1036	5-Sep-2020	HASSAN	66	HV1	BALEHONNUR_66	17:46	18:03	00:17	LINE CLEAR AVAILED
1037	5-Sep-2020	HASSAN	66	HV4	BALEHONNUR_66	17:30	17:44	00:14	LINE CLEAR AVAILED
1038	5-Sep-2020	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	03:12	03:17	00:05	HAND TRIPPED
1039	5-Sep-2020	MYSORE	66	KR PETE 220-MADESHWARAPURA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 MADESWARAPURA_66 NAGAMANGALA_66	9:27	14:19	4:52	LINE CLEAR AVAILED
1040	5-Sep-2020	MYSORE	66	KR PETE 220-SB HALLY	SANTHEBACHALLI_66 HARIYALDAMMATHEMPLE_66	9:27	13:44	4:17	LINE CLEAR AVAILED
1041	5-Sep-2020	MYSORE	66	KR PETE 220-BOOKANKERE	SHEELUNERE_66 GANJIGERE_66 BOOKANAKERE_66 BANANGADI_66 CHINAKURALI_66	9:27	14:24	4:57	LINE CLEAR AVAILED
1042	5-Sep-2020	MYSORE	66	KR PETE 220-CR PATNA	KRISHNAPURA_66 ANEGOLAL_66	9:27	13:54	4:27	LINE CLEAR AVAILED
1043	5-Sep-2020	MYSORE	66	KR PETE 220-KR PETE 1	AKKIHEBBAL_66 KIKKERI_66 KRPET_66	9:27	14:14	4:47	LINE CLEAR AVAILED
1044	5-Sep-2020	MYSORE	66	KR PETE 220-KRPETE 2	AKKIHEBBAL_66 KIKKERI_66 KRPET_66	9:27	14:14	4:47	LINE CLEAR AVAILED
1045	5-Sep-2020	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	10:47	14:43	3:56	LINE CLEAR AVAILED
1046	5-Sep-2020	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	17:03	17:19	0:16	HAND TRIPPED
1047	5-Sep-2020	MYSORE	220	HV1	MADHUVANAHALLI_220	15:27	16:17	0:50	HAND TRIPPED
1048	5-Sep-2020	MYSORE	66	TUBINKERE-ARAKERE	GAMANAHALLY_66 TARIPURA_66 ARAKERE_66	10:20	13:55	3:35	LINE CLEAR AVAILED
1049	5-Sep-2020	MYSORE	66	TUBINKERE-ARAKERE	GAMANAHALLY_66 TARIPURA_66 ARAKERE_66	17:48	18:15	0:27	LINE CLEAR AVAILED
1050	5-Sep-2020	MYSORE	66	KUSHALNAGARA-PERİYAPATNA 1	PERIYAPATNA_66 HANAGODU_66 PONNAMPET_66 VIRAJPET_66	15:58	16:07	0:09	LINE FAULT
1051	5-Sep-2020	MYSORE	66	KUSHALNAGARA-BYLUKUPPE	BYLUKUPPE_66	15:58	16:07	0:09	LINE FAULT
1052	5-Sep-2020	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	12:02	12:08	0:06	LINE FAULT
1053	5-Sep-2020	MYSORE	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	11:10 (27.08.2020)	16:49 (05/09/2020)	221:39 HRS	LINE CHARGED
1054	5-Sep-2020	MYSORE	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	10:12 (27.08.2020)	16:42 (05/09/2020)	222:30 HRS	LINE CHARGED
1055	5-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN , TRANSFORMER FAULT
1056	5-Sep-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020			TRANSFORMER OPEN , TRANSFORMER FAULT
1057	5-Sep-2020	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	1:25	7:15	5:49	LINE CLEAR AVAILED
1058	5-Sep-2020	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	11:17	11:35	0:18	LINE FAULT
1059	5-Sep-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	16:19	17:29	1:09	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
1060	5-Sep-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	11:17	11:36	0:19	LINE FAULT
1061	5-Sep-2020	TUMKUR	220	TR-1	PAVAGADA_220	13:03	14:03	1:00	LINE CLEAR AVAILED
1062	5-Sep-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	6:36	6:44	0:08	TRANSFORMER FAULT
1063	5-Sep-2020	TUMKUR	110	TR-1	KGTEMPLE_110	15:15	22:00	6:44	LINE CLEAR AVAILED
1064	5-Sep-2020	TUMKUR	66	TR-1	AMRUTHUR_66	16:44	17:08	0:24	LINE CLEAR AVAILED
1065	5-Sep-2020	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	11:03	11:11	0:07	LINE FAULT
1066	5-Sep-2020	TUMKUR	66	CHAWDANKUPPE-ESENGY_SLR	ESENGY_SLR	18:59	21:59	2:59	LINE CLEAR AVAILED
1067	5-Sep-2020	TUMKUR	66	TR-1 & 2	CHITRADURGA_220	12:22	12:43	0:21	HAND TRIPPED
1068	5-Sep-2020	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	6:06	6:13	0:07	HAND TRIPPED
1069	5-Sep-2020	TUMKUR	66	TR-2	GULIGENAHALLI_66	15:18	15:34	0:15	LINE CLEAR AVAILED
1070	5-Sep-2020	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	12:20	12:31	0:10	HAND TRIPPED
1071	5-Sep-2020	TUMKUR	66	TR-1	HDPURA_66	12:00	12:12	0:12	LINE CLEAR AVAILED
1072	5-Sep-2020	TUMKUR	66	TR-1	HDPURA_66	13:42	14:10	0:27	LINE CLEAR AVAILED
1073	5-Sep-2020	TUMKUR	66	TR-1	HDPURA_66	14:36	14:49	0:13	LINE CLEAR AVAILED
1074	5-Sep-2020	TUMKUR	66	TR-1	HIRIYUR_66	10:33	11:43	1:09	LINE CLEAR AVAILED
1075	5-Sep-2020	TUMKUR	66	HIRIYUR 220KV-MATHOD2	MATHOD2	10:20	10:27	0:06	LINE FAULT
1076	5-Sep-2020	TUMKUR	66	HIRIYUR 220KV-MATHOD2	MATHOD2	11:08	11:25	0:16	LINE FAULT
1077	5-Sep-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66, BASAVAPATNA_66	13:29	13:42	0:12	LINE FAULT
1078	5-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	INFOSYS-1	12:46	13:06	0:20	LINE FAULT
1079	6-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
1080	6-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
1081	6-Sep-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
1082	6-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
1083	6-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
1084	6-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
1085	6-Sep-2020	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
1086	6-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
1087	6-Sep-2020	BAGALKOT	110	220/110KV,LV 1	STATION NOT AFFECTED BAGALKOT_220	13:05 (27.08.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1088	6-Sep-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1&2(NANDIHAL1&2)	STATION NOT AFFECTED BAGEWADI_220	13:20 (29.08.2020)			LOAD CURTAILMENT
1089	6-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
1090	6-Sep-2020	BAGALKOT	110	AMBEWADI(KAVALWADA)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	13:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
1091	6-Sep-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
1092	6-Sep-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
1093	6-Sep-2020	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51 (01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1094	6-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	12:19 (02.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1095	6-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1096	6-Sep-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	10:49	10:53	0:04	TRANSFORMER FAULT
1097	6-Sep-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	11:20	11:33	0:13	TRANSFORMER FAULT
1098	6-Sep-2020	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	10:18	17:23	7:05	LINE CLEAR AVOIDED
1099	6-Sep-2020	BAGALKOT	110	SOUDATTI220- SOUDATTI1&2	SOUDATTI_110	10:05	16:43	6:38	LINE CLEAR AVOIDED
1100	6-Sep-2020	BAGALKOT	110	SOUDATTI- ENERCON1&2	SOUDATTI_110	16:23	16:49	0:26	LINE CLEAR AVOIDED
1101	6-Sep-2020	BAGALKOT	220	220/110KV, HV1&LV1	SOUDATTI_220	13:07	15:17	2:10	LINE CLEAR AVOIDED
1102	6-Sep-2020	BAGALKOT	220	220/110KV, HV2&LV2	SOUDATTI_220	16:45	19:04	2:19	LINE CLEAR AVOIDED
1103	6-Sep-2020	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	11:05	17:34	6:29	LINE FAULT
1104	6-Sep-2020	BAGALKOT	220	SHARAVATHY1- SIRSI	SIRSI_220	11:57	17:03	5:06	LINE FAULT
1105	6-Sep-2020	BAGALKOT	220	220/110KV, HV1&LV1	SIRSI_220	12:37	14:00	1:23	LINE CLEAR AVOIDED
1106	6-Sep-2020	BAGALKOT	110	110/11KV, HV3	SAVALAGI_110	6:37	12:57	6:20	TRANSFORMER FAULT
1107	6-Sep-2020	BAGALKOT	110	RANNABELAGALI- UTTUR	UTTUR_110	7:35	7:45	0:10	LINE FAULT
1108	6-Sep-2020	BAGALKOT	110	110/11KV, HV2	NIDAGUNDI_110	15:13	16:12	0:59	TRANSFORMER FAULT
1109	6-Sep-2020	BAGALKOT	110	110/11KV, HV2	NAVANAGAR(B)_110	9:28	9:49	0:21	LINE CLEAR AVOIDED
1110	6-Sep-2020	BAGALKOT	110	110/11KV, HV1	NAVANAGAR(B)_110	8:31	9:32	1:01	LINE CLEAR AVOIDED
1111	6-Sep-2020	BAGALKOT	110	110/33KV,HV3	MUNAVALLI_110, MUNAVALLI_33, MALLUR_33	10:36	15:17	4:41	LINE CLEAR AVOIDED
1112	6-Sep-2020	BAGALKOT	110	MK HUBLI-220- HIREBAGEWADI	HIREBAGEWADI_110	9:57	17:00	7:03	LINE CLEAR AVOIDED
1113	6-Sep-2020	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	10:02(06.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVOIDED
1114	6-Sep-2020	BAGALKOT	220	220/110KV, HV1&LV1	NARENDRA_220	11:19	16:24	5:05	LINE CLEAR AVOIDED
1115	6-Sep-2020	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	16:36	17:33	0:57	LINE CLEAR AVOIDED
1116	6-Sep-2020	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	13:06	18:34	5:28	LINE FAULT
1117	6-Sep-2020	BAGALKOT	110	BAGALKOT-NAVANGAR 2	NAVANAGAR(B)_110	8:17	9:29	1:12	LINE CLEAR AVOIDED
1118	6-Sep-2020	BAGALKOT	110	BAGALKOT-NAVANGAR 1	NAVANAGAR(B)_110	9:34	10:25	0:51	LINE CLEAR AVOIDED
1119	6-Sep-2020	BAGALKOT	110	110/11KV,HV3	BIJAPUR_110	22:22	23:58	1:36	TRANSFORMER FAULT
1120	6-Sep-2020	BAGALKOT	220	NANDIHAL2-BIJAPUR	BIJAPUR_220	14:49	15:11	0:22	LINE FAULT
1121	6-Sep-2020	BAGALKOT	110	110/33KV,HV3	KIADB BIJAPUR_110 &NAGATHAN&HONNUTAGI_33	8:42	9:02	0:20	TRANSFORMER FAULT
1122	6-Sep-2020	BAGALKOT	110	ATHANI-AIGALI	AIGALI_110	16:27	17:16	0:49	LINE FAULT
1123	6-Sep-2020	BAGALKOT	110	110/11KV,HV1	BYADAGI_110	11:29	12:17	0:48	LINE CLEAR AVOIDED
1124	6-Sep-2020	BAGALKOT	110	110/11KV,HV1	MACHE_110	10:35	12:35	2:00	LINE CLEAR AVOIDED
1125	6-Sep-2020	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	15:31	18:34	3:03	LINE FAULT
1126	6-Sep-2020	BENGALURU	66	HV2	BANASHANKARI	08:00	08:05	00:05	TRANSFORMER FAULT
1127	6-Sep-2020	BENGALURU	66	HV1	BYADRAHALI	11:01	12:40	01:39	LINE CLEAR AVOIDED
1128	6-Sep-2020	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	15:40	15:45	00:05	LOAD CHANGE OVER
1129	6-Sep-2020	BENGALURU	220	EPIP 220 - HSR LAYOUT 220	NIMHANS 220,HSR LAYOUT 220,KORAMANGALA 220	14:06	15:03	00:57	LINE FAULT
1130	6-Sep-2020	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	JAKKASANDRA,ADUGODI, BOSCH (EHT)	14:06	14:24	00:18	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
1131	6-Sep-2020	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	14:06	14:24	00:18	MAIN SUPPLY FAILURE
1132	6-Sep-2020	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	14:06	14:24	00:18	MAIN SUPPLY FAILURE
1133	6-Sep-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:12	11:22	01:10	LINE CLEAR AVAILED
1134	6-Sep-2020	BENGALURU	220	HV3	KOLAR 220	10:12	11:03	00:51	LINE CLEAR AVAILED
1135	6-Sep-2020	BENGALURU	66	KOLAR 220 - NARASAPURA	NARASAPURA	11:18	11:22	00:04	LINE CLEAR AVAILED
1136	6-Sep-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	16:57	17:05	00:08	LINE CLEAR AVAILED
1137	6-Sep-2020	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	11:01	15:52	04:51	LINE CLEAR AVAILED
1138	6-Sep-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT), JADIGENAHALLI	05:58	06:06	00:08	LINE FAULT
1139	6-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
1140	6-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
1141	6-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
1142	6-Sep-2020	GULBARGA	400	BTPS-RTPS	BTPS_400	11:34	12:54	01:20	LINE FAULT
1143	6-Sep-2020	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	05:54	06:21	00:27	LINE FAULT
1144	6-Sep-2020	GULBARGA	220	RAICHUR-RTPS1	RAICHUR_220	11:05	15:19	04:14	NFBC ISSUED
1145	6-Sep-2020	GULBARGA	220	HV1	RAICHUR_220	11:05	15:19	04:14	LINE CLEAR AVAILED
1146	6-Sep-2020	GULBARGA	220	HV2	RAICHUR_220	11:05	15:50	04:45	LINE CLEAR AVAILED
1147	6-Sep-2020	GULBARGA	220	HV1	SHAHAPUR_220	02:38	02:47	00:09	TRANSFORMER FAULT
1148	6-Sep-2020	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	05:53	08:18	02:25	LINE FAULT
1149	6-Sep-2020	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	11:50	12:07	00:17	LINE CLEAR AVAILED
1150	6-Sep-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR-110	23:25(5.9.2020)	0:01(06.09.2020)	0:36 MINS	LINE CHARGED
1151	6-Sep-2020	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	17:12	17:24	00:12	LINE FAULT
1152	6-Sep-2020	GULBARGA	110	HV2	MANVI_110	13:21	18:28	05:07	LINE CLEAR AVAILED
1153	6-Sep-2020	GULBARGA	110	RAICHUR-SHAHAPUR1	DEODURGA_110,GABUR_110	06:16	06:24	00:08	LINE FAULT
1154	6-Sep-2020	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI_110	07:42	07:49	00:07	LINE FAULT
1155	6-Sep-2020	GULBARGA	110	RAICHUR-SHAHAPUR1	DEODURGA_110,GABUR_110	21:02	21:08	00:06	LINE FAULT
1156	6-Sep-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	21:02	21:09	00:07	LINE FAULT
1157	6-Sep-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110, SAIDAPUR_110, WADAGERA_110, NALWAR_110, SANNATI_110,COREGREEN IPP	00:37	01:08	00:31	LINE FAULT
1158	6-Sep-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110, SAIDAPUR_110, WADAGERA_110, NALWAR_110, SANNATI_110,COREGREEN IPP	02:08	02:22	00:14	LINE FAULT
1159	6-Sep-2020	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	15:45	16:45	01:00	NFBC ISSUED
1160	6-Sep-2020	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	20:20	20:30	00:10	LINE FAULT
1161	6-Sep-2020	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	20:55	21:10	00:15	LINE FAULT
1162	6-Sep-2020	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	21:55	22:10	00:15	LINE FAULT
1163	6-Sep-2020	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66	04:14	04:25	00:11	LINE FAULT
1164	6-Sep-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	9:11 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
1165	6-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:36 (2.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1166	6-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	18:23 (5.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1167	6-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:42(05.09.2020)	6:20(06.09.2020)	6:38hrs	LINE CHARGED
1168	6-Sep-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	14:00 (5.09.2020)	18:43 (6.09.2020)	28:43hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
1169	6-Sep-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	14:00(05.09.2020)	18:44(06.09.2020)	28:44hrs	LINE CHARGED
1170	6-Sep-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	9:11 (31.08.2020)	20:19 (6.09.2020)	155:08hrs	LINE CHARGED
1171	6-Sep-2020	HASSAN	220	VARAHI-KEMAR3	varahi_gen	9:11 (31.08.2020)	20:19 (6.09.2020)	155:08hrs	LINE CHARGED
1172	6-Sep-2020	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	16:13(6.09.2020)			LINE OPEN, LINE FAULT
1173	6-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:34(06.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1174	6-Sep-2020	HASSAN	220	MRSSH-M-KADUR	MRSMSG_220	20:59 (6.09.2020)			LINE OPEN, LINE FAULT
1175	6-Sep-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	18:17(06.09.2020)			LINE OPEN, LINE FAULT
1176	6-Sep-2020	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	17:17 (6.09.2020)			LINE OPEN, LINE FAULT
1177	6-Sep-2020	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	19:07 (6.09.2020)			MAIN SUPPLY FAILURE
1178	6-Sep-2020	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	11:57	17:04	05:07	LINE FAULT
1179	6-Sep-2020	HASSAN	220	HV1	CRPATNA_220	22:12	23:18	01:06	LINE CLEAR AVAILED
1180	6-Sep-2020	HASSAN	220	HV2	CRPATNA_220	22:12	23:18	01:06	LINE CLEAR AVAILED
1181	6-Sep-2020	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	19:07	19:42	00:35	LINE FAULT
1182	6-Sep-2020	HASSAN	220	KAVOOR-BAIPE1	KAVOOR_220	19:13	19:40	00:27	HAND TRIPPED
1183	6-Sep-2020	HASSAN	220	KAVOOR-BAIPE2	KAVOOR_220	19:13	19:40	00:27	HAND TRIPPED
1184	6-Sep-2020	HASSAN	220	KEMAR-BAIPE1	KEMAR_220	18:59	19:49	00:50	LINE FAULT
1185	6-Sep-2020	HASSAN	220	KEMAR-BAIPE2	KEMAR_220	17:16	18:15	00:59	LINE FAULT
1186	6-Sep-2020	HASSAN	220	KEMAR-BAIPE2	KEMAR_220	18:59	19:37	00:38	LINE FAULT
1187	6-Sep-2020	HASSAN	220	MRSSH-M-ANTRSNH	MRSMSG_220	13:36	14:44	01:08	LINE FAULT
1188	6-Sep-2020	HASSAN	220	MRSSH-M-SHARAVATHY3	MRSMSG_220	17:40	18:47	01:07	LINE FAULT
1189	6-Sep-2020	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	19:26	19:39	00:13	HAND TRIPPED
1190	6-Sep-2020	HASSAN	220	MSEZ-KAVOOR2	MSEZ	19:26	19:40	00:14	HAND TRIPPED
1191	6-Sep-2020	HASSAN	220	MSEZ-KEMAR1	MSEZ	18:59	19:49	00:50	LINE FAULT
1192	6-Sep-2020	HASSAN	220	MSEZ-KEMAR2	MSEZ	17:16	18:59	01:43	LINE FAULT
1193	6-Sep-2020	HASSAN	220	MSEZ-KEMAR2	MSEZ	18:59	19:37	00:38	LINE FAULT
1194	6-Sep-2020	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	17:40	18:47	01:07	LINE FAULT
1195	6-Sep-2020	HASSAN	110	MRSSH-M-BADRAVATY3	MRSMSG_220	15:04	19:15	04:11	LINE FAULT
1196	6-Sep-2020	HASSAN	110	HV2	KAVOOR_220	19:07	19:24	00:17	HAND TRIPPED
1197	6-Sep-2020	HASSAN	110	HV3	KAVOOR_220	19:07	19:24	00:17	HAND TRIPPED
1198	6-Sep-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	17:17	18:17	01:00	LINE FAULT
1199	6-Sep-2020	HASSAN	110	HV2	KEMAR_220	18:59	19:27	00:28	TRANSFORMER FAULT
1200	6-Sep-2020	HASSAN	110	KEMAR-Manipal1	KEMAR_220	17:15	18:20	01:05	LINE FAULT
1201	6-Sep-2020	HASSAN	110	KEMAR-Manipal2	KEMAR_220	17:15	18:20	01:05	LINE FAULT
1202	6-Sep-2020	HASSAN	110	MSEZ-GSS31	MSEZ	19:10	19:59	00:49	MAIN SUPPLY FAILURE
1203	6-Sep-2020	HASSAN	110	HV1	MSEZ	19:11	20:05	00:54	MAIN SUPPLY FAILURE
1204	6-Sep-2020	HASSAN	110	HV2	MSEZ	19:12	19:50	00:38	MAIN SUPPLY FAILURE
1205	6-Sep-2020	HASSAN	110	MSEZ-KAVOOR	MSEZ	19:09	20:03	00:54	MAIN SUPPLY FAILURE
1206	6-Sep-2020	HASSAN	110	HV1	NITTUR_110	10:39	12:05	01:26	MAIN SUPPLY FAILURE
1207	6-Sep-2020	HASSAN	110	HV1	NITTUR_110	12:19	12:22	00:03	MAIN SUPPLY FAILURE
1208	6-Sep-2020	HASSAN	110	HV1	NITTUR_110	17:16	18:23	01:07	MAIN SUPPLY FAILURE
1209	6-Sep-2020	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	10:39	12:05	01:26	LINE CLEAR AVAILED
1210	6-Sep-2020	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	12:19	12:21	00:02	HAND TRIPPED
1211	6-Sep-2020	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	17:16	18:23	01:07	MAIN SUPPLY FAILURE
1212	6-Sep-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	17:17	17:50	00:33	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
1213	6-Sep-2020	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	17:17	17:52	00:35	MAIN SUPPLY FAILURE
1214	6-Sep-2020	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	01:09	01:22	00:13	LINE FAULT
1215	6-Sep-2020	HASSAN	110	HV2	KONAJE_110	19:08	19:45	00:37	MAIN SUPPLY FAILURE
1216	6-Sep-2020	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	13:16	18:25	05:09	MAIN SUPPLY FAILURE
1217	6-Sep-2020	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	13:16	18:25	05:09	MAIN SUPPLY FAILURE
1218	6-Sep-2020	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	13:16	18:25	05:09	MAIN SUPPLY FAILURE
1219	6-Sep-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	19:07	19:50	00:43	MAIN SUPPLY FAILURE
1220	6-Sep-2020	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	19:07	19:50	00:43	LINE FAULT
1221	6-Sep-2020	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	19:07	19:58	00:51	MAIN SUPPLY FAILURE
1222	6-Sep-2020	HASSAN	110	NDKR-SUZLON	NANDIKUR_110	02:22	03:06	00:44	LINE FAULT
1223	6-Sep-2020	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	01:25	01:55	00:30	LINE FAULT
1224	6-Sep-2020	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	13:40	13:54	00:14	LINE FAULT
1225	6-Sep-2020	HASSAN	66	CRPATNA-CRPTNA1	CRPATNA_220	23:12	23:19	00:07	LINE CLEAR AVAILED
1226	6-Sep-2020	HASSAN	66	CRPATNA-CRPTNA2	CRPATNA_220	23:12	23:19	00:07	LINE CLEAR AVAILED
1227	6-Sep-2020	HASSAN	66	CRPATNA-HNPURA	CRPATNA_220	23:12	23:23	00:11	LINE CLEAR AVAILED
1228	6-Sep-2020	HASSAN	66	HV1	CRPATNA_220	22:34	23:59	01:25	LINE CLEAR AVAILED
1229	6-Sep-2020	HASSAN	66	LV2	CRPATNA_220	22:12	23:19	01:07	LINE CLEAR AVAILED
1230	6-Sep-2020	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	23:12	23:23	00:11	LINE CLEAR AVAILED
1231	6-Sep-2020	HASSAN	66	CRPATNA-SBELAGOLA	CRPATNA_220	23:12	23:21	00:09	LINE CLEAR AVAILED
1232	6-Sep-2020	HASSAN	66	HV1	CHANNARYAPATNA_66	16:28	18:59	02:31	LINE CLEAR AVAILED
1233	6-Sep-2020	HASSAN	66	HV2	CHANNARYAPATNA_66	09:46	14:28	04:42	LINE CLEAR AVAILED
1234	6-Sep-2020	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARYAPATNA_66	23:26	23:36	00:10	HAND TRIPPED
1235	6-Sep-2020	HASSAN	66	HASSN22-BELUR	HASSAN_220	06:10	06:18	00:08	LINE FAULT
1236	6-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	11:41	11:48	00:07	LINE FAULT
1237	6-Sep-2020	HASSAN	66	HNPR2-BANDISHETTIHALLI	HOLENARASIPURA_220	06:50	06:55	00:05	LINE FAULT
1238	6-Sep-2020	HASSAN	66	HV2	HNPURA_66	11:23	13:24	02:01	LINE CLEAR AVAILED
1239	6-Sep-2020	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	15:10	16:25	01:15	LINE CLEAR AVAILED
1240	6-Sep-2020	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	15:05	16:25	01:20	LINE CLEAR AVAILED
1241	6-Sep-2020	HASSAN	66	HV1	SINGAPURA_66	22:13	23:23	01:10	MAIN SUPPLY FAILURE
1242	6-Sep-2020	HASSAN	66	HV2	SINGAPURA_66	22:13	23:23	01:10	MAIN SUPPLY FAILURE
1243	6-Sep-2020	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	22:13	23:40	01:27	MAIN SUPPLY FAILURE
1244	6-Sep-2020	MYSORE	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	7:52	7:58	0:06	LINE FAULT
1245	6-Sep-2020	MYSORE	66	GUNDLUPETE-BEGUR 2	NO STATIONS EFFECTED	7:52	7:58	0:06	LINE FAULT
1246	6-Sep-2020	MYSORE	66	METAGALLY-HEBBAL	METAGALLY_66 HEBBAL_66	9:55	17:21	7:26	LINE CLEAR AVAILED
1247	6-Sep-2020	MYSORE	66	METAGALLY-G UKKADA	METAGALLY_66	9:55	17:21	7:26	LINE CLEAR AVAILED
1248	6-Sep-2020	MYSORE	66	METAGALLY-VIKRANTH	NO STATIONS EFFECTED	9:55	17:45	7:50	LINE CLEAR AVAILED
1249	6-Sep-2020	MYSORE	66	TUBINKERE-ARAKERE	GAMANAHALLY_66 TARIPURA_66 ARAKERE_66	20:52	20:59	0:06	LINE FAULT
1250	6-Sep-2020	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	17:40	18:20	0:40	LINE FAULT
1251	6-Sep-2020	MYSORE	66	MADHUVANAHALLI-HANNUR 1	NO STATIONS EFFECTED	18:23	18:29	0:06	LINE FAULT
1252	6-Sep-2020	MYSORE	66	MADHUVANAHALLI-KOLLEGALA	NO STATIONS EFFECTED	18:41	18:55	0:14	LINE FAULT
1253	6-Sep-2020	MYSORE	66	HOOTAGALLI-RBI	NO STATIONS EFFECTED	8:45	17:40	8:55	LINE CLEAR AVAILED
1254	6-Sep-2020	MYSORE	66	HOOTAGALLI-BEML	NO STATIONS EFFECTED	10:00	13:10	3:10	LINE CLEAR AVAILED
1255	6-Sep-2020	MYSORE	220	KUSHALNAGARA-BASTIPURA 1	NO STATIONS EFFECTED	4:06	13:38	9:32	LINE CLEAR AVAILED
1256	6-Sep-2020	MYSORE	66	CR NAGARA-YELANDUR	YELANDUR_66	9:55	16:24	6:29	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
1257	6-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN , TRANSFORMER FAULT
1258	6-Sep-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020			TRANSFORMER OPEN , TRANSFORMER FAULT
1259	6-Sep-2020	TUMKUR	66	GULIGENAHALLI- SIRA	GULIGENAHALLI_66	2:06	2:39	0:32	LINE FAULT
1260	6-Sep-2020	TUMKUR	66	GULIGENAHALLI- SIRA	GULIGENAHALLI_66	6:04	6:25	0:21	LINE FAULT
1261	6-Sep-2020	TUMKUR	66	TR-1	HDPURA_66	6:40	6:42	0:02	HAND TRIPPED
1262	6-Sep-2020	TUMKUR	66	TR-1	HDPURA_66	14:51	14:55	0:03	HAND TRIPPED
1263	6-Sep-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	11:26	11:35	0:09	LINE FAULT
1264	6-Sep-2020	TUMKUR	66	TR-2	HOLALKERE_66	23:54	23:57	0:02	TRANSFORMER FAULT
1265	6-Sep-2020	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	6:41	6:49	0:08	LINE FAULT
1266	6-Sep-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUN DA_66	11:53	11:59	0:06	LINE FAULT
1267	6-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	10:27	10:37	0:10	LINE FAULT
1268	6-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	14:11	14:24	0:12	LINE FAULT
1269	6-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	17:48	17:53	0:04	LINE FAULT
1270	6-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	17:39	19:01	1:21	LINE FAULT
1271	6-Sep-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:23	16:32	0:09	LINE FAULT
1272	6-Sep-2020	TUMKUR	66	TR-1	KUNDUR_66	11:13	14:25	3:12	LINE CLEAR AVAILED
1273	6-Sep-2020	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 1	HOLAVINAHALLY_66	23:50	23:51	0:01	HAND TRIPPED
1274	7-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
1275	7-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
1276	7-Sep-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
1277	7-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
1278	7-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
1279	7-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
1280	7-Sep-2020	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
1281	7-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
1282	7-Sep-2020	BAGALKOT	110	220/110KV,LV 1	STATION NOT AFFECTED BAGALKOT_220	13:05 (27.08.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1283	7-Sep-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1&2(NANDIHAL1&2)	STATION NOT AFFECTED BAGEWADI_220	13:20 (29.08.2020)	13:19 (07.09.2020)	239:59hrs	LINE CHARGED
1284	7-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
1285	7-Sep-2020	BAGALKOT	110	AMBEWADI(KAVALWADA)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	13:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
1286	7-Sep-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
1287	7-Sep-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	18:48 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
1288	7-Sep-2020	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	12:51 (01.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1289	7-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	12:19 (02.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1290	7-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1291	7-Sep-2020	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI_220	10:02 (06.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1292	7-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM_220	21:38 (06.09.2020)	7:44 (07.09.2020)	10:06hrs	LINE CHARGED
1293	7-Sep-2020	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	12:16	12:39	0:23	LINE CLEAR AVAILED
1294	7-Sep-2020	BAGALKOT	110	AMBEWADI-NK2	KAVALWADA_110	12:16	12:39	0:23	LINE CLEAR AVAILED
1295	7-Sep-2020	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	12:57	14:35	1:38	LINE CLEAR AVAILED
1296	7-Sep-2020	BAGALKOT	110	BAGEWADI-SINDAGI	SINDAGI_110	0:05	8:40	8:35	LINE FAULT
1297	7-Sep-2020	BAGALKOT	110	BAGEWADI-CHIMMALAGI LIS	CHIMMALAGI LIS_110	5:40	6:38	0:58	LINE FAULT
1298	7-Sep-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	10:16	12:49	2:33	NFBC ISSUED
1299	7-Sep-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	16:07	16:41	0:34	NFBC ISSUED
1300	7-Sep-2020	BAGALKOT	220	220/110KV,HV 2	GADAG_220	11:54	14:12	2:18	LINE CLEAR AVAILED
1301	7-Sep-2020	BAGALKOT	110	220/110KV,LV 2	GADAG_220	11:54	17:20	5:26	LINE CLEAR AVAILED
1302	7-Sep-2020	BAGALKOT	110	110/11KV,HV4	GHATAPRABHA_110	10:50	11:22	0:32	LINE CLEAR AVAILED
1303	7-Sep-2020	BAGALKOT	110	HATTARGI-DADDI	DADDI_110	16:28	16:40	0:12	LINE FAULT
1304	7-Sep-2020	BAGALKOT	110	HAVERI-HANAGALL	HANAGALL_110	11:08	12:35	1:27	LINE CLEAR AVAILED
1305	7-Sep-2020	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	5:25	12:03	6:38	LINE FAULT
1306	7-Sep-2020	BAGALKOT	110	110/33KVKV,HV 2	HUNGUND_110 &KARADI,AMINAGAD_33	10:34	11:24	0:50	TRANSFORMER FAULT
1307	7-Sep-2020	BAGALKOT	110	110/33KVKV,HV 2	HUNGUND_110 &KARADI,AMINAGAD_33	11:38	11:45	0:07	TRANSFORMER FAULT
1308	7-Sep-2020	BAGALKOT	110	110/33KV, HV1	HUBLI_220	9:58	17:58	8:00	LINE CLEAR AVAILED
1309	7-Sep-2020	BAGALKOT	220	SHARAVATHY1- SIRSI	SIRSI_220	14:27	16:22	1:55	LINE CLEAR AVAILED
1310	7-Sep-2020	BAGALKOT	110	110/11KV, HV3	SAVALAGI_110	18:05	19:50	1:45	LINE CLEAR AVAILED
1311	7-Sep-2020	BAGALKOT	220	220/110KV, HV2&LV2	NARENDRA_220	11:41	16:34	4:53	LINE CLEAR AVAILED
1312	7-Sep-2020	BAGALKOT	110	BPCL- NARAGUND	NARAGUND_110	13:28	14:31	1:03	LINE CLEAR AVAILED
1313	7-Sep-2020	BAGALKOT	110	MUNDARGI- VIJAYANAGAR SUGARS	MUNDARGI_110	15:41	16:11	0:30	LINE FAULT
1314	7-Sep-2020	BAGALKOT	110	MUNDARGI- VIJAYANAGAR SUGARS	MUNDARGI_110	17:13	17:40	0:27	LINE FAULT
1315	7-Sep-2020	BAGALKOT	220	220/110KV, HV3& LV3	MAHALINGAPUR_220, HIDIKAL_110, ITANAL_110	5:25	5:55	0:30	TRANSFORMER FAULT
1316	7-Sep-2020	BAGALKOT	110	110/11KV, HV4	KULIGOD_110	12:32	14:05	1:33	LINE CLEAR AVAILED
1317	7-Sep-2020	BAGALKOT	110	SHIRGUPPI SUGARS- KAGAWADA	KAGAWADA_110	10:57	11:07	0:10	LINE FAULT
1318	7-Sep-2020	BAGALKOT	110	SHIRGUPPI SUGARS- KAGAWADA	KAGAWADA_110	11:13	12:08	0:55	LINE FAULT
1319	7-Sep-2020	BAGALKOT	110	SHIRGUPPI SUGARS- KAGAWADA	KAGAWADA_110	14:15	14:22	0:07	LINE FAULT
1320	7-Sep-2020	BAGALKOT	110	KUDACHI220- AINAPUR	AINAPUR_110	10:57	19:04	8:07	LINE FAULT
1321	7-Sep-2020	BAGALKOT	220	KUDACHI- ATHANI	KUDACHI_220	11:35	13:58	2:23	LINE CLEAR AVAILED
1322	7-Sep-2020	BAGALKOT	220	KUDACHI- MAHALINGAPUR	KUDACHI_220	13:30	13:53	0:23	LINE FAULT
1323	7-Sep-2020	BAGALKOT	220	220/110KV, HV1& LV1	KUDACHI_220	14:38	16:39	2:01	LINE CLEAR AVAILED
1324	7-Sep-2020	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	22:20	22:25	00:05	LOAD CHANGE OVER
1325	7-Sep-2020	BENGALURU	66	HV1	ITI	10:10	17:31	07:21	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
1326	7-Sep-2020	BENGALURU	66	HV1	JAKKASANDRA	12:44	12:57	00:13	LINE CLEAR AVAILED
1327	7-Sep-2020	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	12:46	12:49	00:03	LINE CLEAR AVAILED
1328	7-Sep-2020	BENGALURU	66	KODIGENAHALLI - T G HALLI	TAVAREKERE	11:31	12:15	00:44	LINE CLEAR AVAILED
1329	7-Sep-2020	BENGALURU	66	KUMBALAGODU - KENGERI SATELLITE TOWN	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	19:30	19:33	00:03	LOAD CHANGE OVER
1330	7-Sep-2020	BENGALURU	66	HV1	MEI LAYOUT	00:31	00:45	00:14	TRANSFORMER FAULT
1331	7-Sep-2020	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	05:25	05:30	00:05	LOAD CHANGE OVER
1332	7-Sep-2020	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	22:15	22:20	00:05	LOAD CHANGE OVER
1333	7-Sep-2020	BENGALURU	66	HV2	REMCO	22:29	22:32	00:03	LOAD CHANGE OVER
1334	7-Sep-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD	11:00	11:24	00:24	LINE FAULT
1335	7-Sep-2020	BENGALURU	66	VIDHURASHWATHA - GOWRIBIDANUR 220	BAGEPALLI, GUNDLU KOTTUR, VIDHURASHWATHA	18:10	18:20	00:10	LINE FAULT
1336	7-Sep-2020	BENGALURU	66	CHELUR - YENNIGADALE	CHELUR	17:48	18:14	00:26	LINE FAULT
1337	7-Sep-2020	BENGALURU	66	CHIKKABALLAPURA I/A - NALLIMARADANAHALLI	NALLIMARADANAHALLI	12:10	12:19	00:09	LINE FAULT
1338	7-Sep-2020	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	17:48	17:57	00:09	LINE FAULT
1339	7-Sep-2020	BENGALURU	66	HV1	DEVANAHALLI	11:05	11:15	00:10	LINE CLEAR AVAILED
1340	7-Sep-2020	BENGALURU	66	HV2	DEVANAHALLI	12:50	13:00	00:10	LINE CLEAR AVAILED
1341	7-Sep-2020	BENGALURU	66	HOSKOTE 220 - BUDIGERE	NO STATION AFFECTED	10:55	11:55	01:00	LINE FAULT
1342	7-Sep-2020	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 220 1	MITTEMARI 220	13:50	14:29	00:39	LINE FAULT
1343	7-Sep-2020	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 220 2	MITTEMARI 220	13:50	14:45	00:55	LINE CLEAR AVAILED
1344	7-Sep-2020	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	13:50	14:45	00:55	LINE CLEAR AVAILED
1345	7-Sep-2020	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	13:50	14:45	00:55	LINE CLEAR AVAILED
1346	7-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	13:50	14:45	00:55	LINE CLEAR AVAILED
1347	7-Sep-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	13:50	14:45	00:55	LINE CLEAR AVAILED
1348	7-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA	13:50	14:45	00:55	LINE CLEAR AVAILED
1349	7-Sep-2020	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 220 1	MITTEMARI 220	13:50	14:27	00:37	LINE CLEAR AVAILED
1350	7-Sep-2020	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 220 2	MITTEMARI 220	13:50	14:45	00:55	LINE CLEAR AVAILED
1351	7-Sep-2020	BENGALURU	66	HV1	KUMBALAGODU	21:05(07/09/2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
1352	7-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
1353	7-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
1354	7-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
1355	7-Sep-2020	GULBARGA	400	BTPS-RTPS	RTPS_400	10:35	18:59	08:24	LINE FAULT
1356	7-Sep-2020	GULBARGA	220	LINGAPUR-KUSTAGI	KUSTAGI_220	12:40	17:20	04:40	NFBC ISSUED
1357	7-Sep-2020	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	05:13	05:33	00:20	LINE FAULT
1358	7-Sep-2020	GULBARGA	220	LINGASUGUR-KUSTAGI	KUSTAGI_220	10:39	11:03	00:24	LINE FAULT
1359	7-Sep-2020	GULBARGA	220	LINGASUGUR-KUSTAGI	KUSTAGI_220	13:04	13:38	00:34	LINE FAULT
1360	7-Sep-2020	GULBARGA	220	HV2	SIDHANOOR_220	13:28	13:51	00:23	TRANSFORMER FAULT
1361	7-Sep-2020	GULBARGA	220	SINDHANOOR-LINGASUGUR	SIDHANOOR_220	13:28	14:35	01:07	LINE FAULT
1362	7-Sep-2020	GULBARGA	220	SINDHANOOR-LINGAPUR	SINDHANOOR_220	19:36	20:22	00:46	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
1363	7-Sep-2020	GULBARGA	220	HV2	SINDHANOOR_220	19:36	19:48	00:12	TRANSFORMER FAULT
1364	7-Sep-2020	GULBARGA	220	LINGAPUR-LINGASUGUR	LINGASUGUR_220	09:32	17:20	07:48	LINE CLEAR AVAILED
1365	7-Sep-2020	GULBARGA	220	SHAHPUR-SEDAM	SHAHPUR_220	13:08	13:34	00:26	LINE FAULT
1366	7-Sep-2020	GULBARGA	220	SHAHPUR-LINGASUGUR	SEDAM_220	13:34	14:29	00:55	LINE FAULT
1367	7-Sep-2020	GULBARGA	110	HANUMANAL-HIREGONNAGAR	HANUMANAL_110	13:20	14:10	00:50	MAIN SUPPLY FAILURE
1368	7-Sep-2020	GULBARGA	110	SINDHANOOR-SIRUGUPPA	DHADESUGUR_110, SIRUGUPPA_110, TEKKALKOTE_110, NSLSUGARS_IPP	14:43	14:54	00:11	LINE FAULT
1369	7-Sep-2020	GULBARGA	110	HV1	JEWARGI_110	11:42	14:15	02:33	LINE CLEAR AVAILED
1370	7-Sep-2020	GULBARGA	110	HV3	KOLHAR_110	13:52	14:01	00:09	LINE CLEAR AVAILED
1371	7-Sep-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI-SINDHANOOR	13:13	13:19	00:06	LINE FAULT
1372	7-Sep-2020	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110, SAIDAPUR_110, WADAGERA_110, NALWAR_110, SANNATI_110, COREGREEN IPP	00:40	00:52	00:12	LINE FAULT
1373	7-Sep-2020	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	01:45	01:59	00:14	LINE FAULT
1374	7-Sep-2020	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	19:57	20:12	00:15	LINE FAULT
1375	7-Sep-2020	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	21:39	22:06	00:27	LINE FAULT
1376	7-Sep-2020	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	23:43	23:56	00:13	LINE FAULT
1377	7-Sep-2020	GULBARGA	110	HV1	VALKAMDINNI_110	13:35	14:10	00:35	TRANSFORMER FAULT
1378	7-Sep-2020	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	13:03	15:03	02:00	MAIN SUPPLY FAILURE
1379	7-Sep-2020	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110, NSLSUGSARFACTORY_IPP, CHOWDAPUR_110	18:55	18:58	00:03	LINE FAULT
1380	7-Sep-2020	GULBARGA	110	GULBARGA SOUTH-SHAHABAD	GULBARGA SOUTH_110	17:22	17:36	00:14	MAIN SUPPLY FAILURE
1381	7-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:36 (2.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1382	7-Sep-2020	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	19:07 (6.09.2020)			MAIN SUPPLY FAILURE
1383	7-Sep-2020	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	16:13(6.09.2020)	14:49 (7.09.2020)	22:36hrs	LINE CHARGED
1384	7-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	18:23 (5.09.2020)	6:30 (7.09.2020)	36:07hrs	LINE CHARGED
1385	7-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:34(06.09.2020)	6:43 (7.09.2020)	8:09hrs	LINE CHARGED
1386	7-Sep-2020	HASSAN	220	MRSSHM-KADUR	MRSMG_220	20:59 (6.09.2020)	10:42 (7.09.2020)	13:43hrs	LINE CHARGED
1387	7-Sep-2020	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	17:17 (6.09.2020)	11:01 (7.09.2020)	17:44hrs	LINE CHARGED
1388	7-Sep-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	18:17(06.09.2020)	11:01 (7.09.2020)	16:44hrs	LINE CHARGED
1389	7-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:50 (7.09.2020)			LINE OPEN, LINE CLEAR AVAILED
1390	7-Sep-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	17:23 (7.09.2020)			LINE OPEN, LINE FAULT
1391	7-Sep-2020	HASSAN	220	VARAHI-KEMAR3	varahi_gen	17:23 (7.09.2020)			LINE OPEN, LINE FAULT
1392	7-Sep-2020	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	12:44	15:10	02:26	NFBC ISSUED
1393	7-Sep-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	09:56	15:47	05:51	NFBC ISSUED
1394	7-Sep-2020	HASSAN	220	MRSSHM-VARAH3	MRSMG_220	17:23	17:53	00:30	LINE FAULT
1395	7-Sep-2020	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	14:27	17:36	03:09	LINE CLEAR AVAILED
1396	7-Sep-2020	HASSAN	220	VARAHI-KEMAR3	varahi_gen	09:56	15:47	05:51	NFBC ISSUED
1397	7-Sep-2020	HASSAN	220	VARAHI-SHMG3	varahi_gen	17:23	17:53	00:30	MAIN SUPPLY FAILURE
1398	7-Sep-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	05:25	05:45	00:20	LINE FAULT
1399	7-Sep-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	05:50	06:18	00:28	LINE FAULT
1400	7-Sep-2020	HASSAN	110	HV3	ALKOLA_110	15:28	15:40	00:12	LINE CLEAR AVAILED
1401	7-Sep-2020	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	06:28	06:32	00:04	LINE FAULT
1402	7-Sep-2020	HASSAN	110	GURUPUR-MDBDRE	GURUPURA_110	06:29	06:30	00:01	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
1403	7-Sep-2020	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	05:25	05:45	00:20	MAIN SUPPLY FAILURE
1404	7-Sep-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	05:50	06:30	00:40	MAIN SUPPLY FAILURE
1405	7-Sep-2020	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	05:25	05:45	00:20	MAIN SUPPLY FAILURE
1406	7-Sep-2020	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	05:50	06:30	00:40	MAIN SUPPLY FAILURE
1407	7-Sep-2020	HASSAN	110	HV1	JAVAGAL_66	16:20	17:15	00:55	LINE CLEAR AVAILED
1408	7-Sep-2020	HASSAN	110	HV2	KUNDAPURA_110	13:30	14:00	00:30	LINE CLEAR AVAILED
1409	7-Sep-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	05:25	05:48	00:23	MAIN SUPPLY FAILURE
1410	7-Sep-2020	HASSAN	110	HV2	MOODABIDRE_110	05:25	05:48	00:23	MAIN SUPPLY FAILURE
1411	7-Sep-2020	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	05:25	05:48	00:23	MAIN SUPPLY FAILURE
1412	7-Sep-2020	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	05:25	05:48	00:23	MAIN SUPPLY FAILURE
1413	7-Sep-2020	HASSAN	110	HV1	BHADRAVATHI_110	11:31	12:57	01:26	LINE CLEAR AVAILED
1414	7-Sep-2020	HASSAN	110	HV1	GANDASI_110	09:28	17:40	08:12	TRANSFORMER FAULT
1415	7-Sep-2020	HASSAN	66	HV1	CRPATNA_220	10:53	16:10	05:17	LINE CLEAR AVAILED
1416	7-Sep-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	19:46	20:15	00:29	LINE FAULT
1417	7-Sep-2020	HASSAN	66	HV2	HOLALUR_66	17:40	18:00	00:20	LINE CLEAR AVAILED
1418	7-Sep-2020	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	06:13	06:35	00:22	LINE FAULT
1419	7-Sep-2020	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	06:13	06:39	00:26	LINE FAULT
1420	7-Sep-2020	MYSORE	66	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	11:07	14:09	3:02	LINE CLEAR AVAILED
1421	7-Sep-2020	MYSORE	66	HV1	FTS_66	11:25	11:47	0:22	LINE CLEAR AVAILED
1422	7-Sep-2020	MYSORE	66	HV2	FTS_66	12:52	13:53	1:00	LINE CLEAR AVAILED
1423	7-Sep-2020	MYSORE	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	11:07	14:08	3:01	LINE CLEAR AVAILED
1424	7-Sep-2020	MYSORE	66	HV1	JAIPUR_66	12:14	13:45	1:30	LINE CLEAR AVAILED
1425	7-Sep-2020	MYSORE	220	KADAKOLA-BASTIPURA1	NO STATIONS EFFECTED	9:45	16:58	7:13	LINE CLEAR AVAILED
1426	7-Sep-2020	MYSORE	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	8:14	8:21	0:07	LINE FAULT
1427	7-Sep-2020	MYSORE	66	KUSHALNAGARA-RAMANATHPURA 1	ALUR SIDDAPURA_66 KANAGAL_66	6:00	6:10	0:10	LINE FAULT
1428	7-Sep-2020	MYSORE	66	HV1	KIADBMANDYA_66	12:52	12:57	0:05	TRANSFORMER FAULT
1429	7-Sep-2020	MYSORE	66	HV2	TUBINAKERE_220	16:01	16:36	0:34	LINE CLEAR AVAILED
1430	7-Sep-2020	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	9:47	9:52	0:05	LINE FAULT
1431	7-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN , TRANSFORMER FAULT
1432	7-Sep-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
1433	7-Sep-2020	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 1	ANCHEPALYA_220	12:11	14:07	1:55	LINE CLEAR AVAILED
1434	7-Sep-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	15:37	18:28	2:51	LINE CLEAR AVAILED
1435	7-Sep-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	12:36	15:25	2:48	LINE CLEAR AVAILED
1436	7-Sep-2020	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	17:10	17:19	0:08	LINE CLEAR AVAILED
1437	7-Sep-2020	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	15:38	18:22	2:44	LINE CLEAR AVAILED
1438	7-Sep-2020	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	12:35	15:23	2:47	LINE CLEAR AVAILED
1439	7-Sep-2020	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	12:22	18:19	5:57	LINE CLEAR AVAILED
1440	7-Sep-2020	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	22:10	22:29	0:18	LINE FAULT
1441	7-Sep-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	12:52	13:15	0:22	LINE CLEAR AVAILED
1442	7-Sep-2020	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	12:02	12:47	0:45	LINE CLEAR AVAILED
1443	7-Sep-2020	TUMKUR	110	TR-2	KADEHALLI_110	16:52	17:54	1:02	TRANSFORMER FAULT
1444	7-Sep-2020	TUMKUR	66	TR-1	CHAWANAKUPPE_66	18:24	19:07	0:43	LINE CLEAR AVAILED
1445	7-Sep-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	13:08	13:44	0:36	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
1446	7-Sep-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:08	13:40	0:32	LINE FAULT
1447	7-Sep-2020	TUMKUR	66	TR-1	HALURAMESHWARA_66	11:54	12:04	0:09	TRANSFORMER FAULT
1448	7-Sep-2020	TUMKUR	66	TR-1	HALURAMESHWARA_66	13:36	13:50	0:14	TRANSFORMER FAULT
1449	7-Sep-2020	TUMKUR	66	HONNALLI_220-LINGADAHALLI	LINGDHALLI_66	16:11	16:22	0:11	LINE FAULT
1450	7-Sep-2020	TUMKUR	66	TR-2	HOSADURGA_66	14:26	18:37	4:10	LINE CLEAR AVAILED
1451	7-Sep-2020	TUMKUR	66	TR-1	LINGDHALLI_66	15:08	15:10	0:01	TRANSFORMER FAULT
1452	7-Sep-2020	TUMKUR	66	MEDIGESHI- CLEANSOLAR IPP	CLEANSOLAR_IPP_66	13:35	18:40	5:04	LINE CLEAR AVAILED
1453	7-Sep-2020	TUMKUR	66	MIDIGESHI-IDHALLI	IDHALLY_66,KODIGENAHALLI_6	13:35	18:32	4:56	LINE CLEAR AVAILED
1454	7-Sep-2020	TUMKUR	66	MEDIGESHI- MADHUGIRI	MEDIGESHI_66	13:35	18:27	4:52	LINE CLEAR AVAILED
1455	7-Sep-2020	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	13:38	18:13	4:35	LINE CLEAR AVAILED
1456	7-Sep-2020	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN SOLAR_IPP_66	18:35	19:45	1:10	LINE FAULT
1457	7-Sep-2020	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN SOLAR_IPP_66	18:35	19:41	1:06	LINE FAULT
1458	7-Sep-2020	TUMKUR	66	SASALUHALLA-CKJRKUTT	SASALUHALLA_66	12:03	14:27	2:24	LINE CLEAR AVAILED