

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 10.12.2019 TO 16.12.2019**

| SL no | DATE      | Tr_ZONE   | Voltage | Line/Transformer                   | NAME OF THE STATION                                | open_at | Closed_At | Duration | REASON             |
|-------|-----------|-----------|---------|------------------------------------|--|---------|-----------|----------|--------------------|
| 1     | 10-Dec-19 | BAGALKOT  | 110     | 110/33 KV,HV 2                     | ANKOLA_110&33KV SEA BIRD &ANKOLA                   | 15:54   | 19:05     | 3:11     | LINE CLEAR AVAILED |
| 2     | 10-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV 1                      | ATHARGA_110  | 7:07    | 7:15      | 0:08     | LOAD CURTAILMENT   |
| 3     | 10-Dec-19 | BAGALKOT  | 220     | BAGALKOT-GADAG 1                   | BAGALKOT_220                                       | 12:03   | 16:43     | 4:40     | LINE CLEAR AVAILED |
| 4     | 10-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV 4                      | GAJENDRAGAD_110                                    | 6:49    | 7:05      | 0:16     | LOAD CURTAILMENT   |
| 5     | 10-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV 4                      | GAJENDRAGAD_110                                    | 7:12    | 7:41      | 0:29     | LOAD CURTAILMENT   |
| 6     | 10-Dec-19 | BAGALKOT  | 220     | GHATAPRABHA-NARENDRA 1             | GHATAPRABHA_220                                    | 12:51   | 17:28     | 4:37     | LINE CLEAR AVAILED |
| 7     | 10-Dec-19 | BAGALKOT  | 220     | GHATAPRABHA-KUDACHI                | GHATAPRABHA_220                                    | 21:56   | 23:59     | 2:03     | LINE CLEAR AVAILED |
| 8     | 10-Dec-19 | BAGALKOT  | 110     | 110/11KV HV1                       | HANAGAL_110  | 7:07    | 7:14      | 0:07     | LOAD CURTAILMENT   |
| 9     | 10-Dec-19 | BAGALKOT  | 110     | 110/33KV,HV3                       | HIDIKAL_110 &33KV KOLIGUDD&ALAGAWADI               | 7:07    | 7:27      | 0:20     | LOAD CURTAILMENT   |
| 10    | 10-Dec-19 | BAGALKOT  | 220     | HAVERI-GUTTUR 1&2                  | HAVERI_220   | 10:32   | 19:36     | 9:04     | NFBC ISSUED        |
| 11    | 10-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV4                       | KERUR_110  | 15:51   | 17:55     | 2:04     | LINE CLEAR AVAILED |
| 12    | 10-Dec-19 | BAGALKOT  | 66      | 110/33KV,HV4                       | HARIHAR HOSPET_66                                  | 7:07    | 7:22      | 0:15     | LOAD CURTAILMENT   |
| 13    | 10-Dec-19 | BAGALKOT  | 110     | 110/11KV, HV1                      | TODALBAGI_110                                      | 7:07    | 8:03      | 0:56     | LOAD CURTAILMENT   |
| 14    | 10-Dec-19 | BAGALKOT  | 110     | 110/33KV, HV2                      | SAVALGI_110, HIREPADASALGI_33                      | 7:07    | 7:14      | 0:07     | LOAD CURTAILMENT   |
| 15    | 10-Dec-19 | BAGALKOT  | 110     | 110/11KV, HV1                      | MUNDUGANUR_110                                     | 7:07    | 7:12      | 0:05     | LOAD CURTAILMENT   |
| 16    | 10-Dec-19 | BAGALKOT  | 220     | KADRA2-KARWAR                      | KARWAR_220   | 11:38   | 17:58     | 6:20     | LINE CLEAR AVAILED |
| 17    | 10-Dec-19 | BENGALURU | 66      | HBR LAYOUT - HOSKOTE 220           | HBR LAYOUT, BELL CERAMICS (EHT)                    | 14:26   | 14:33     | 0:07     | LOAD CHANGE OVER   |
| 18    | 10-Dec-19 | BENGALURU | 66      | HBR LAYOUT - L R BANDE             | HBR LAYOUT, BELL CERAMICS (EHT)                    | 15:24   | 15:33     | 0:09     | LOAD CHANGE OVER   |
| 19    | 10-Dec-19 | BENGALURU | 66      | HOSKOTE 220 - HOSKOTE 2            | HBR LAYOUT, BELL CERAMICS (EHT)                    | 6:56    | 7:12      | 0:16     | LINE FAULT         |
| 20    | 10-Dec-19 | BENGALURU | 66      | HV3                                | KGF  | 14:24   | 15:33     | 1:09     | LINE CLEAR AVAILED |
| 21    | 10-Dec-19 | BENGALURU | 66      | HV2                                | KGF  | 13:45   | 15:30     | 1:45     | LINE CLEAR AVAILED |
| 22    | 10-Dec-19 | BENGALURU | 66      | KOLAR 220 - NANGLI                 | KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI | 18:20   | 18:30     | 0:10     | LOAD CURTAILMENT   |
| 23    | 10-Dec-19 | BENGALURU | 66      | NALLIMARADANAHALLI - D B PURA 220  | NALLIMARADANAHALLI                                 | 10:38   | 14:55     | 4:17     | LINE CLEAR AVAILED |
| 24    | 10-Dec-19 | BENGALURU | 66      | HV2                                | RANGANADODDI                                       | 15:05   | 15:43     | 0:38     | LINE CLEAR AVAILED |
| 25    | 10-Dec-19 | BENGALURU | 66      | YELAHANKA 220 - LINE 6             | SOLADEVANAHALLI                                    | 6:36    | 7:05      | 0:29     | LINE FAULT         |
| 26    | 10-Dec-19 | BENGALURU | 66      | JAYADEVA - NIMHAS 220              | JAYADEVA   | 13:01   | 13:08     | 0:06     | LINE CLEAR AVAILED |
| 27    | 10-Dec-19 | BENGALURU | 66      | JAYADEVA - SARAKI                  | JAYADEVA   | 14:11   | 14:23     | 0:12     | LINE CLEAR AVAILED |
| 28    | 10-Dec-19 | BENGALURU | 66      | DODDABALLAPURA 220 - DEVANAHALLI 1 | KUNDANA  | 8:01    | 8:17      | 0:15     | LINE FAULT         |

| SL no | DATE      | Tr_ZONE   | Voltage | Line/Transformer                       | NAME OF THE STATION  | open_at | Closed_At | Duration | REASON              |
|-------|-----------|-----------|---------|--|--|---------|-----------|----------|---------------------|
| 29    | 10-Dec-19 | BENGALURU | 66      | DODDABALLAPURA 220 - DEVANAHALLI 2     | DEVANAHALLI  | 8:01    | 8:17      | 0:15     | LINE FAULT          |
| 30    | 10-Dec-19 | BENGALURU | 66      | DODDABALLAPURA 220 - DEVANAHALLI 1     | KUNDANA  | 12:45   | 13:10     | 0:25     | LINE CLEAR AVAILED  |
| 31    | 10-Dec-19 | BENGALURU | 66      | DODDABALLAPURA 220 - DEVANAHALLI 2     | DEVANAHALLI  | 12:45   | 13:10     | 0:25     | LINE CLEAR AVAILED  |
| 32    | 10-Dec-19 | BENGALURU | 66      | DODDABALLAPURA 220 - CHIKKABALLAPURA 1 | CHIKKABALLAPURA I/A,<br>CHIKKABALLAPURA URBAN,<br>NALLIMARADANAHALLI | 12:45   | 13:05     | 0:20     | LINE CLEAR AVAILED  |
| 33    | 10-Dec-19 | BENGALURU | 66      | DODDABALLAPURA 220 - CHIKKABALLAPURA 2 | TUBUGERE   | 12:45   | 13:05     | 0:20     | LINE CLEAR AVAILED  |
| 34    | 10-Dec-19 | BENGALURU | 66      | HV3                                    | ADUGODI  | 13:02   | 13:10     | 0:08     | MAIN SUPPLY FAILURE |
| 35    | 10-Dec-19 | BENGALURU | 66      | HV3                                    | ADUGODI  | 14:13   | 14:23     | 0:09     | MAIN SUPPLY FAILURE |
| 36    | 10-Dec-19 | BENGALURU | 66      | BAGEPALLI - GOWRIBIDANUR 2             | SOMANATHPURA   | 13:50   | 14:00     | 0:10     | MAIN SUPPLY FAILURE |
| 37    | 10-Dec-19 | GULBARGA  | 110     | HV3                                    | KAMPLI_110   | 6:45    | 6:55      | 0:10     | LOAD CURTAILMENT    |
| 38    | 10-Dec-19 | GULBARGA  | 110     | HV1                                    | PDHALLI_110  | 6:48    | 7:00      | 0:12     | LOAD CURTAILMENT    |
| 39    | 10-Dec-19 | GULBARGA  | 110     | SHAKTINAGAR_RAICHURBIO_IPP             | SHAKTINAGAR_110  | 6:37    | 7:14      | 0:37     | LINE FAULT          |
| 40    | 10-Dec-19 | GULBARGA  | 110     | RAICHUR-MALIYABAD                      | MALIYABAD_110,VADAVATTI_110  | 6:36    | 6:47      | 0:11     | LINE FAULT          |
| 41    | 10-Dec-19 | GULBARGA  | 110     | SHAHAPUR-YADGIR                        | YADGIR_110   | 3:00    | 3:05      | 0:05     | LINE FAULT          |
| 42    | 10-Dec-19 | GULBARGA  | 110     | RAICHUR-MALIYABAD                      | MALIYABAD_110, VADAVATTI_110   | 6:36    | 6:47      | 0:11     | LINE FAULT          |
| 43    | 10-Dec-19 | GULBARGA  | 110     | HV3                                    | BEVOOR_110   | 21:47   | 21:52     | 0:05     | TRANSFORMER FAULT   |
| 44    | 10-Dec-19 | GULBARGA  | 110     | HV2                                    | CHINCHOLI_110(IDLE)  | 6:47    | 7:14      | 0:27     | LOAD CURTAILMENT    |
| 45    | 10-Dec-19 | GULBARGA  | 110     | HV2                                    | CHINCHOLI_110(IDLE)  | 8:10    | 21:08     | 12:58    | LINE CLEAR AVAILED  |
| 46    | 10-Dec-19 | GULBARGA  | 110     | KOLHAR-HALBARGA,HUMNABAD               | KOLHAR_110,JANAWADA_110  | 11:30   | 12:25     | 0:55     | LINE FAULT          |
| 47    | 10-Dec-19 | GULBARGA  | 110     | KOLHAR-HALBARGA,HUMNABAD               | KOLHAR_110,JANAWADA_110  | 16:35   | 18:40     | 2:05     | LINE CLEAR AVAILED  |
| 48    | 10-Dec-19 | GULBARGA  | 110     | KOLHAR-NSSK                            | JANAWADA_110   | 12:35   | 12:40     | 0:05     | LINE FAULT          |
| 49    | 10-Dec-19 | GULBARGA  | 110     | KOLHAR-NSSK                            | JANAWADA_110   | 12:50   | 13:10     | 0:20     | LINE FAULT          |
| 50    | 10-Dec-19 | GULBARGA  | 110     | KOLHAR-NSSK                            | JANAWADA_110   | 13:25   | 13:30     | 0:05     | LINE FAULT          |
| 51    | 10-Dec-19 | GULBARGA  | 110     | KOLHAR-NSSK                            | JANAWADA_110   | 13:30   | 15:30     | 2:00     | LINE CLEAR AVAILED  |
| 52    | 10-Dec-19 | GULBARGA  | 110     | KOLHAR-NSSK                            | JANAWADA_110   | 18:40   | 19:05     | 0:25     | LINE CLEAR AVAILED  |
| 53    | 10-Dec-19 | GULBARGA  | 110     | KOLHAR-SHAHI_SLR                       | KOLHAR_110   | 12:25   | 12:40     | 0:15     | LINE CLEAR AVAILED  |
| 54    | 10-Dec-19 | GULBARGA  | 110     | KOLHAR-SHAHI_SLR                       | KOLHAR_110   | 13:25   | 16:35     | 3:10     | LINE CLEAR AVAILED  |
| 55    | 10-Dec-19 | GULBARGA  | 110     | HV2                                    | KOLHAR_110   | 12:15   | 13:10     | 0:55     | LINE CLEAR AVAILED  |
| 56    | 10-Dec-19 | GULBARGA  | 110     | HV2                                    | KOLHAR_110   | 13:30   | 15:30     | 2:00     | LINE CLEAR AVAILED  |
| 57    | 10-Dec-19 | GULBARGA  | 110     | HV3                                    | KOLHAR_110   | 18:45   | 20:00     | 1:15     | LINE CLEAR AVAILED  |
| 58    | 10-Dec-19 | GULBARGA  | 110     | SHAHABAD-YEDRAMI                       | YEDRAMI_110  | 7:30    | 18:30     | 11:00    | MAIN SUPPLY FAILURE |
| 59    | 10-Dec-19 | GULBARGA  | 110     | HV3                                    | VALKAMDINNI_110  | 14:16   | 17:04     | 2:48     | LINE CLEAR AVAILED  |

| SL no | DATE      | Tr_ZONE  | Voltage | Line/Transformer      | NAME OF THE STATION                      | open_at | Closed_At | Duration | REASON              |
|-------|-----------|----------|---------|-----------------------|--|---------|-----------|----------|---------------------|
| 60    | 10-Dec-19 | GULBARGA | 110     | HV3                   | VALKAMDINNI_110                          | 17:06   | 17:45     | 0:39     | LINE CLEAR AVAILED  |
| 61    | 10-Dec-19 | GULBARGA | 110     | HUMNABAD-BHALKI1      | BHALKI_110,LADHA_110                     | 17:50   | 18:17     | 0:27     | LINE FAULT          |
| 62    | 10-Dec-19 | GULBARGA | 66      | ITTAGI-SUZLON1&2_IPP  | ITTAGI_220                               | 12:00   | 13:59     | 1:59     | LINE CLEAR AVAILED  |
| 63    | 10-Dec-19 | GULBARGA | 66      | ITTAGI-HUVINAHADAGALI | HUVINAHADAGALI_66,HOLAGUNDI_66           | 12:05   | 13:59     | 1:54     | LINE CLEAR AVAILED  |
| 64    | 10-Dec-19 | GULBARGA | 66      | ITTAGI-TAMBRAHALLI    | HAMPASAGAR_66,MOREGERE_66,TAMBRAHALLI_66 | 12:05   | 13:59     | 1:54     | LINE CLEAR AVAILED  |
| 65    | 10-Dec-19 | GULBARGA | 66      | ITTAGI-HIREHADAGALI   | HIREHADAGALI_66                          | 12:10   | 13:55     | 1:45     | LINE CLEAR AVAILED  |
| 66    | 10-Dec-19 | GULBARGA | 66      | ITTAGI-CLNMAX2_IPP    | ITTAGI_220                               | 12:05   | 12:40     | 0:35     | LINE CLEAR AVAILED  |
| 67    | 10-Dec-19 | GULBARGA | 66      | ITTAGI-CLNMAX1_IPP    | ITTAGI_220                               | 12:05   | 14:04     | 1:59     | LINE CLEAR AVAILED  |
| 68    | 10-Dec-19 | GULBARGA | 66      | HV1                   | ITTAGI_220                               | 14:13   | 14:15     | 0:02     | LINE CLEAR AVAILED  |
| 69    | 10-Dec-19 | GULBARGA | 66      | ITTAGGI-CLN MAX2      | ITTAGI_220                               | 19:05   | 19:10     | 0:05     | LINE CLEAR AVAILED  |
| 70    | 10-Dec-19 | HASSAN   | 66      | HNPR2-HASS2           | HOLENARASIPURA_220                       | 13:07   | 14:57     | 1:50     | LINE CLEAR AVAILED  |
| 71    | 10-Dec-19 | HASSAN   | 400     | UPCL-HASSAN1          | upcl_gen                                 | 0:00    | 7:02      | 7:02     | LINE CLEAR AVAILED  |
| 72    | 10-Dec-19 | HASSAN   | 400     | UPCL-HASSAN1          | upcl_gen                                 | 21:50   | 23:59     | 2:09     | LINE CLEAR AVAILED  |
| 73    | 10-Dec-19 | HASSAN   | 220     | HV2                   | KEMAR_220                                | 14:42   | 15:38     | 0:56     | LINE CLEAR AVAILED  |
| 74    | 10-Dec-19 | HASSAN   | 220     | HV3                   | KEMAR_220                                | 11:03   | 12:33     | 1:30     | LINE CLEAR AVAILED  |
| 75    | 10-Dec-19 | HASSAN   | 220     | HV3                   | KEMAR_220                                | 15:44   | 16:30     | 0:46     | LINE CLEAR AVAILED  |
| 76    | 10-Dec-19 | HASSAN   | 220     | KEMAR-Varahi1         | KEMAR_220                                | 10:51   | 12:29     | 1:38     | LINE CLEAR AVAILED  |
| 77    | 10-Dec-19 | HASSAN   | 220     | VARAHI-KEMAR1         | varahi_gen                               | 10:51   | 12:29     | 1:38     | NFBC ISSUED         |
| 78    | 10-Dec-19 | HASSAN   | 110     | LV2                   | KEMAR_220                                | 14:42   | 15:38     | 0:56     | LINE CLEAR AVAILED  |
| 79    | 10-Dec-19 | HASSAN   | 110     | LV3                   | KEMAR_220                                | 11:03   | 12:33     | 1:30     | LINE CLEAR AVAILED  |
| 80    | 10-Dec-19 | HASSAN   | 110     | HV1                   | BANTWAL_110                              | 19:23   | 20:21     | 0:58     | TRANSFORMER FAULT   |
| 81    | 10-Dec-19 | HASSAN   | 110     | HV3                   | BANTWAL_110                              | 19:23   | 20:21     | 0:58     | TRANSFORMER FAULT   |
| 82    | 10-Dec-19 | HASSAN   | 110     | BANTWA-KAVOOR         | BANTWAL_110                              | 19:23   | 20:21     | 0:58     | LINE FAULT          |
| 83    | 10-Dec-19 | HASSAN   | 110     | BANTWA-SALATTUR       | BANTWAL_110                              | 19:23   | 20:21     | 0:58     | LINE FAULT          |
| 84    | 10-Dec-19 | HASSAN   | 110     | HV2                   | BIRUR_110                                | 7:20    | 7:30      | 0:10     | LOAD CURTAILMENT    |
| 85    | 10-Dec-19 | HASSAN   | 110     | HV1                   | BRAHMAVARA_110                           | 6:48    | 7:02      | 0:14     | LOAD CURTAILMENT    |
| 86    | 10-Dec-19 | HASSAN   | 110     | HV1                   | BRAHMAVARA_110                           | 7:16    | 7:46      | 0:30     | LOAD CURTAILMENT    |
| 87    | 10-Dec-19 | HASSAN   | 110     | HV2                   | GANDASI_110                              | 7:11    | 7:30      | 0:19     | LOAD CURTAILMENT    |
| 88    | 10-Dec-19 | HASSAN   | 110     | HV1                   | HALADY_110                               | 7:13    | 7:32      | 0:19     | LOAD CURTAILMENT    |
| 89    | 10-Dec-19 | HASSAN   | 110     | HV1                   | JAVAGAL_110                              | 7:12    | 7:18      | 0:06     | LOAD CURTAILMENT    |
| 90    | 10-Dec-19 | HASSAN   | 110     | HV1                   | KONDENALU_110                            | 7:12    | 7:20      | 0:08     | LOAD CURTAILMENT    |
| 91    | 10-Dec-19 | HASSAN   | 110     | HV2                   | KUNDAPURA_110                            | 10:03   | 14:35     | 4:32     | MAIN SUPPLY FAILURE |
| 92    | 10-Dec-19 | HASSAN   | 110     | HV2                   | MOODABIDRE_110                           | 14:09   | 14:29     | 0:20     | HAND TRIPPED        |
| 93    | 10-Dec-19 | HASSAN   | 110     | MOODAB-KEMAR          | MOODABIDRE_110                           | 10:46   | 17:25     | 6:39     | LINE CLEAR AVAILED  |
| 94    | 10-Dec-19 | HASSAN   | 110     | MRSSHM-SS1            | MRSMG_220                                | 9:55    | 9:56      | 0:01     | LINE CLEAR AVAILED  |
| 95    | 10-Dec-19 | HASSAN   | 110     | MRSSHM-SS1            | MRSMG_220                                | 9:18    | 9:19      | 0:01     | LINE CLEAR AVAILED  |
| 96    | 10-Dec-19 | HASSAN   | 110     | MRSSHM-SS2            | MRSMG_220                                | 9:21    | 9:22      | 0:01     | LINE CLEAR AVAILED  |

| SL no | DATE      | Tr_ZONE | Voltage | Line/Transformer            | NAME OF THE STATION              | open_at | Closed_At | Duration | REASON              |
|-------|-----------|---------|---------|-----------------------------|----------------------------------|---------|-----------|----------|---------------------|
| 97    | 10-Dec-19 | HASSAN  | 110     | MRSSHM-SS2                  | MRSMSG_220                       | 9:38    | 9:39      | 0:01     | LINE CLEAR AVAILED  |
| 98    | 10-Dec-19 | HASSAN  | 110     | MRSSHM-SK LINE              | MRSMSG_220                       | 16:29   | 16:32     | 0:03     | LINE CLEAR AVAILED  |
| 99    | 10-Dec-19 | HASSAN  | 110     | MRSSHM-SK LINE              | MRSMSG_220                       | 10:28   | 10:30     | 0:02     | LINE CLEAR AVAILED  |
| 100   | 10-Dec-19 | HASSAN  | 110     | HV3                         | MRSMSG_220                       | 10:32   | 16:26     | 5:54     | LINE CLEAR AVAILED  |
| 101   | 10-Dec-19 | HASSAN  | 110     | SAGARA-SORABA               | SAGARA_110                       | 10:10   | 11:25     | 1:15     | LINE CLEAR AVAILED  |
| 102   | 10-Dec-19 | HASSAN  | 66      | HV2                         | CHANNARAYAPATNA_66               | 7:11    | 7:22      | 0:11     | LOAD CURTAILMENT    |
| 103   | 10-Dec-19 | HASSAN  | 66      | HASSN220-HN PURA            | HASSAN_220                       | 9:47    | 16:42     | 6:55     | LINE CLEAR AVAILED  |
| 104   | 10-Dec-19 | HASSAN  | 66      | HASSN220-MALLALI            | HASSAN_220                       | 9:47    | 16:34     | 6:47     | LINE CLEAR AVAILED  |
| 105   | 10-Dec-19 | HASSAN  | 66      | HNPR2-HASS2                 | HOLENARASIPURA_220               | 9:35    | 15:43     | 6:08     | LINE CLEAR AVAILED  |
| 106   | 10-Dec-19 | HASSAN  | 66      | HV1                         | HOLALUR_66                       | 9:50    | 10:15     | 0:25     | LINE CLEAR AVAILED  |
| 107   | 10-Dec-19 | HASSAN  | 66      | LALALI-HASSAN               | MALALI_66                        | 12:30   | 15:50     | 3:20     | MAIN SUPPLY FAILURE |
| 108   | 10-Dec-19 | HASSAN  | 66      | HV2                         | RAMESHWARNAGAR_66                | 7:12    | 7:24      | 0:12     | LOAD CURTAILMENT    |
| 109   | 10-Dec-19 | HASSAN  | 66      | RMWNGR-SHANTI               | RAMESHWARNAGAR_66                | 15:25   | 15:40     | 0:15     | HAND TRIPPED        |
| 110   | 10-Dec-19 | HASSAN  | 66      | HV2                         | SALAGAME_66                      | 6:47    | 6:56      | 0:09     | LOAD CURTAILMENT    |
| 111   | 10-Dec-19 | HASSAN  | 66      | HV2                         | SALAGAME_66                      | 7:13    | 7:23      | 0:10     | LOAD CURTAILMENT    |
| 112   | 10-Dec-19 | HASSAN  | 66      | UDAYAP-SHANTIGRAMA          | UDAYAPURA_66                     | 12:50   | 23:59     | 11:09    | NFBC ISSUED         |
| 113   | 10-Dec-19 | MYSORE  | 66      | BILIKERE-GV GUDI            | GVGUDI_66                        | 19:33   | 19:39     | 0:06     | LINE FAULT          |
| 114   | 10-Dec-19 | MYSORE  | 66      | HV2                         | BOOKANAKERE_66                   | 7:11    | 7:21      | 0:09     | LOAD CURTAILMENT    |
| 115   | 10-Dec-19 | MYSORE  | 66      | HV1                         | CHANDAKAVADI_66                  | 10:59   | 12:23     | 1:24     | LINE CLEAR AVAILED  |
| 116   | 10-Dec-19 | MYSORE  | 66      | HV2                         | CHANDAKAVADI_66                  | 15:25   | 17:53     | 2:27     | LINE CLEAR AVAILED  |
| 117   | 10-Dec-19 | MYSORE  | 66      | HV1                         | CHUNCHUNKATTE_66                 | 4:42    | 4:50      | 0:07     | TRANSFORMER FAULT   |
| 118   | 10-Dec-19 | MYSORE  | 66      | HV1                         | CHUNCHUNKATTE_66                 | 4:50    | 4:58      | 0:07     | TRANSFORMER FAULT   |
| 119   | 10-Dec-19 | MYSORE  | 66      | HV1                         | COWDALLI_66                      | 11:38   | 12:16     | 0:38     | LINE CLEAR AVAILED  |
| 120   | 10-Dec-19 | MYSORE  | 66      | HV2                         | COWDALLI_66                      | 11:38   | 23:59     | 12:20    | LINE CLEAR AVAILED  |
| 121   | 10-Dec-19 | MYSORE  | 66      | COWDALLI-MARTALLI           | MARTAHALLI_66<br>RAMAPURA_MYS_66 | 11:18   | 17:41     | 6:22     | NFBC ISSUED         |
| 122   | 10-Dec-19 | MYSORE  | 66      | HV1                         | GUNDULPET_66                     | 10:55   | 12:01     | 1:06     | LINE CLEAR AVAILED  |
| 123   | 10-Dec-19 | MYSORE  | 66      | HV1                         | HANAGODU_66                      | 7:12    | 7:19      | 0:07     | LOAD CURTAILMENT    |
| 124   | 10-Dec-19 | MYSORE  | 66      | HV2                         | HANNUR_66                        | 7:13    | 7:44      | 0:31     | LOAD CURTAILMENT    |
| 125   | 10-Dec-19 | MYSORE  | 220     | HV3                         | HOOTAGALLY_220                   | 10:20   | 13:34     | 3:13     | LINE CLEAR AVAILED  |
| 126   | 10-Dec-19 | MYSORE  | 66      | HV1                         | K_HONNALGERE_66                  | 12:22   | 12:47     | 0:24     | LINE CLEAR AVAILED  |
| 127   | 10-Dec-19 | MYSORE  | 66      | HV2                         | KIRUGAVALU_66                    | 7:13    | 7:45      | 0:32     | LOAD CURTAILMENT    |
| 128   | 10-Dec-19 | MYSORE  | 66      | HV1                         | PANDAVAPURA_66                   | 7:13    | 7:22      | 0:08     | LOAD CURTAILMENT    |
| 129   | 10-Dec-19 | MYSORE  | 66      | HV1                         | SINDHUVALLI_66                   | 10:03   | 18:03     | 8:00     | NFBC ISSUED         |
| 130   | 10-Dec-19 | MYSORE  | 66      | HV2                         | VIRAJPET_66                      | 14:46   | 16:30     | 1:43     | LINE CLEAR AVAILED  |
| 131   | 10-Dec-19 | TUMKUR  | 220     | TR-1(HV SIDE)               | HONNALLI_220                     | 15:07   | 15:46     | 0:39     | LINE CLEAR AVAILED  |
| 132   | 10-Dec-19 | TUMKUR  | 220     | KB CROSS 220kV- NELAMANGALA | KBCROSS_220                      | 10:09   | 17:18     | 7:09     | LINE CLEAR AVAILED  |
| 133   | 10-Dec-19 | TUMKUR  | 110     | TR-1                        | TURUVEKERE_110                   | 6:20    | 6:45      | 0:24     | MAIN SUPPLY FAILURE |
| 134   | 10-Dec-19 | TUMKUR  | 110     | TR-1                        | TURUVEKERE_110                   | 15:06   | 16:47     | 1:41     | MAIN SUPPLY FAILURE |

| SL no | DATE      | Tr_ZONE  | Voltage | Line/Transformer                           | NAME OF THE STATION   | open_at | Closed_At | Duration | REASON              |
|-------|-----------|----------|---------|--|---|---------|-----------|----------|---------------------|
| 135   | 10-Dec-19 | TUMKUR   | 110     | TR-1                                       | TURUVEKERE_110  | 18:06   | 18:23     | 0:16     | MAIN SUPPLY FAILURE |
| 136   | 10-Dec-19 | TUMKUR   | 110     | TR-1                                       | CHIKKANAYAKANAHALLI_110   | 9:44    | 11:14     | 1:29     | LINE CLEAR AVAILED  |
| 137   | 10-Dec-19 | TUMKUR   | 66      | ANCHEPALYA 220kV- ANCHEPALYA1              | ANCHEPALYA_66,<br>BHAKTHARAHALLI_66,<br>THIMMASANDRA_66               | 9:54    | 10:08     | 0:14     | LINE FAULT          |
| 138   | 10-Dec-19 | TUMKUR   | 66      | ANTHRASANAHALLI 220KV- KOLALA ( dabaspete) | KOLALA_66, URDIGERE_66  | 20:41   | 22:08     | 1:27     | LINE FAULT          |
| 139   | 10-Dec-19 | TUMKUR   | 66      | TR-2                                       | BALENAHALLI_66  | 15:40   | 16:46     | 1:06     | LINE CLEAR AVAILED  |
| 140   | 10-Dec-19 | TUMKUR   | 66      | DAVANGERE SRS- GUTTUR66                    | GUTTUR_66   | 16:53   | 17:17     | 0:24     | LINE FAULT          |
| 141   | 10-Dec-19 | TUMKUR   | 66      | TR-1(LV SIDE)                              | HONNALLI_220  | 15:06   | 15:48     | 0:41     | LINE CLEAR AVAILED  |
| 142   | 10-Dec-19 | TUMKUR   | 66      | HOSADURGA-RAMAGIRI                         | RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66                                    | 16:11   | 16:41     | 0:30     | LINE CLEAR AVAILED  |
| 143   | 10-Dec-19 | TUMKUR   | 66      | TR-2                                       | HOSADURGA_66  | 17:13   | 17:25     | 0:12     | LINE CLEAR AVAILED  |
| 144   | 10-Dec-19 | TUMKUR   | 66      | TR-1                                       | IDHALLY_66  | 14:00   | 14:58     | 0:57     | LINE CLEAR AVAILED  |
| 145   | 10-Dec-19 | TUMKUR   | 66      | KUKKAWADA- LINGADAHALLI(CHANNAGIRI)        | KUKKAWADA_66, TYAVANAGI_66,<br>BASAVAPATNA_66,<br>SANTEBENNUR_66      | 15:11   | 22:05     | 6:53     | LINE FAULT          |
| 146   | 10-Dec-19 | TUMKUR   | 66      | KUKKAWADA- SRS DAVANGERE                   | KUKKAWADA_66  | 15:11   | 22:05     | 6:53     | LINE FAULT          |
| 147   | 10-Dec-19 | TUMKUR   | 66      | MATHOD- ENERCON1_IPP_66                    | ENERCON1_IPP_66   | 6:15    | 6:23      | 0:07     | LINE FAULT          |
| 148   | 10-Dec-19 | TUMKUR   | 66      | TR-1                                       | MYLANAHALLI_66  | 7:08    | 7:18      | 0:10     | TRANSFORMER FAULT   |
| 149   | 11-Dec-19 | BAGALKOT | 110     | MAMADAPUR-BABLESHWAR                       | BABALESHWAR_110   | 15:38   | 15:58     | 0:20     | LINE FAULT          |
| 150   | 11-Dec-19 | BAGALKOT | 110     | MAMADAPUR-BABLESHWAR                       | BABALESHWAR_110   | 16:20   | 16:29     | 0:09     | LINE FAULT          |
| 151   | 11-Dec-19 | BAGALKOT | 220     | BAGALKOT-GADAG2                            | BAGALKOT_220  | 10:08   | 12:32     | 2:24     | LINE CLEAR AVAILED  |
| 152   | 11-Dec-19 | BAGALKOT | 220     | BAGALKOT-GADAG2                            | BAGALKOT_220  | 12:36   | 13:15     | 0:39     | LINE CLEAR AVAILED  |
| 153   | 11-Dec-19 | BAGALKOT | 220     | BAGALKOT-GADAG2                            | BAGALKOT_220  | 13:28   | 13:32     | 0:04     | LINE CLEAR AVAILED  |
| 154   | 11-Dec-19 | BAGALKOT | 110     | BAGEWADI-MAMADAPUR 2                       | MAMADAPUR_110   | 21:05   | 21:19     | 0:14     | LINE FAULT          |
| 155   | 11-Dec-19 | BAGALKOT | 110     | BAGEWADI-MAMADAPUR 2                       | MAMADAPUR_110   | 21:05   | 21:19     | 0:14     | LINE FAULT          |
| 156   | 11-Dec-19 | BAGALKOT | 110     | B.BAGEWADI-KIADB                           | KIADB BIJAPUR_110   | 11:59   | 12:31     | 0:32     | LINE CLEAR AVAILED  |
| 157   | 11-Dec-19 | BAGALKOT | 110     | 110/33KV,HV 1&2                            | HANAGALI_110 &33KV<br>BELAGALPET,LAXMIPUR,BASAPUR,P<br>ALA&MOMMANALLI | 10:04   | 18:10     | 8:06     | LINE CLEAR AVAILED  |
| 158   | 11-Dec-19 | BAGALKOT | 220     | BELAGAUM-NARENDRA1                         | BELGAUM_220   | 12:26   | 15:01     | 2:35     | LINE CLEAR AVAILED  |
| 159   | 11-Dec-19 | BAGALKOT | 220     | GADAG-BAGALKOT 2                           | GADAG_220   | 12:08   | 12:32     | 0:24     | LINE CLEAR AVAILED  |
| 160   | 11-Dec-19 | BAGALKOT | 110     | GHATAPRABHA-HIDIKAL DAM                    | HIDIKAL DAM_110   | 11:00   | 18:58     | 7:58     | LINE CLEAR AVAILED  |
| 161   | 11-Dec-19 | BAGALKOT | 220     | GHATAPRABHA-KUDACHI                        | GHATAPRABHA_220   | 0:00    | 8:09      | 8:09     | LINE CLEAR AVAILED  |
| 162   | 11-Dec-19 | BAGALKOT | 220     | GHATAPRABHA-NARENDRA 1                     | GHATAPRABHA_220   | 9:44    | 19:31     | 9:47     | LINE CLEAR AVAILED  |
| 163   | 11-Dec-19 | BAGALKOT | 220     | HAVERI-GUTTUR1                             | HAVERI_220  | 9:39    | 14:57     | 5:18     | LINE CLEAR AVAILED  |
| 164   | 11-Dec-19 | BAGALKOT | 220     | HAVERI-GUTTUR2                             | HAVERI_220  | 11:19   | 16:17     | 4:58     | LINE CLEAR AVAILED  |

| SL no | DATE      | Tr_ZONE   | Voltage | Line/Transformer              | NAME OF THE STATION                                  | open_at | Closed_At | Duration | REASON              |
|-------|-----------|-----------|---------|-------------------------------|--|---------|-----------|----------|---------------------|
| 165   | 11-Dec-19 | BAGALKOT  | 110     | HAVERI-HANAGALL               | HANAGALL_110   | 10:13   | 18:00     | 7:47     | LINE CLEAR AVAILED  |
| 166   | 11-Dec-19 | BAGALKOT  | 110     | HAVERI-SAVANUR                | SAVANUR_110  | 11:22   | 23:59     | 12:37    | LINE CLEAR AVAILED  |
| 167   | 11-Dec-19 | BAGALKOT  | 66      | 66/33KV,HV 4                  | HARIHAR-HOSPET                                       | 6:54    | 7:10      | 0:16     | TRANSFORMER FAULT   |
| 168   | 11-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV4                  | KERUR_110  | 10:21   | 14:55     | 4:34     | LINE CLEAR AVAILED  |
| 169   | 11-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV2                  | KHANAPUR_110   | 10:05   | 16:19     | 6:14     | LINE CLEAR AVAILED  |
| 170   | 11-Dec-19 | BAGALKOT  | 220     | 220/110KV,HV1&LV1             | KARWAR_110   | 12:56   | 13:29     | 0:33     | LINE CLEAR AVAILED  |
| 171   | 11-Dec-19 | BAGALKOT  | 110     | KARWAR220-ARGA                | ARGA_110   | 11:05   | 13:00     | 1:55     | LINE CLEAR AVAILED  |
| 172   | 11-Dec-19 | BAGALKOT  | 110     | LAXMESHVAR-BELLATTI           | BELLATTI_110   | 10:07   | 14:02     | 3:55     | LINE CLEAR AVAILED  |
| 173   | 11-Dec-19 | BAGALKOT  | 110     | MAHALINGAPUR220-TERDAL        | TERDAL_110   | 12:03   | 13:09     | 1:06     | LINE CLEAR AVAILED  |
| 174   | 11-Dec-19 | BAGALKOT  | 110     | MAHALINGAPUR220-TERDAL        | TERDAL_110   | 13:29   | 14:48     | 1:19     | LINE FAULT          |
| 175   | 11-Dec-19 | BAGALKOT  | 110     | BELAGUM SUGAR-MAMADAPUR(B)    | MAMADAPUR(B)_110                                     | 21:08   | 21:24     | 0:16     | MAIN SUPPLY FAILURE |
| 176   | 11-Dec-19 | BAGALKOT  | 110     | 110/33KV,HV2                  | MATTIHAL_110,NTPC_33,WATER SUPPLY_33,KARJOL LIS_33   | 11:30   | 14:28     | 2:58     | LINE CLEAR AVAILED  |
| 177   | 11-Dec-19 | BAGALKOT  | 110     | SOUDATTI220-RAMADURGA         | RAMADURGA_110  | 10:31   | 14:40     | 4:09     | LINE CLEAR AVAILED  |
| 178   | 11-Dec-19 | BAGALKOT  | 110     | RANEBENNUR220-GUTTAL          | GUTTAL_110   | 11:00   | 11:43     | 0:43     | LINE CLEAR AVAILED  |
| 179   | 11-Dec-19 | BAGALKOT  | 110     | RANEBENNUR220-HIREKERUR       | HIREKERUR_110  | 12:17   | 12:28     | 0:11     | LINE FAULT          |
| 180   | 11-Dec-19 | BAGALKOT  | 110     | 110/33KV,HV2                  | SAVANUR_110,HULAGUR_33,HATTI MATTUR_33,BANKAPUR_33   | 13:59   | 16:13     | 2:14     | LINE CLEAR AVAILED  |
| 181   | 11-Dec-19 | BAGALKOT  | 110     | SODATTI220-SOUDATTI 2         | SOUDATTI_110   | 10:29   | 14:41     | 4:12     | LINE CLEAR AVAILED  |
| 182   | 11-Dec-19 | BENGALURU | 66      | REMCO - VIJAYANAGARA          | VIJAYANAGARA   | 8:30    | 8:40      | 0:10     | LINE FAULT          |
| 183   | 11-Dec-19 | BENGALURU | 66      | NRS 220 - VIJAYANAGARA        | VIJAYANAGARA   | 9:20    | 9:37      | 0:17     | LINE FAULT          |
| 184   | 11-Dec-19 | BENGALURU | 66      | KOLAR 220 - NANGALI           | KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI | 7:15    | 7:20      | 0:05     | LOAD CURTAILMENT    |
| 185   | 11-Dec-19 | BENGALURU | 66      | KEMBODI - NANGALI             | MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI          | 7:20    | 7:46      | 0:26     | LOAD CURTAILMENT    |
| 186   | 11-Dec-19 | BENGALURU | 66      | SOMANAHALLI 220- JIGANI 2     | BG ROAD, JIGANI 66, JIGANI LINK ROAD                 | 18:56   | 19:23     | 0:27     | LINE FAULT          |
| 187   | 11-Dec-19 | BENGALURU | 66      | SOMANAHALLI 220- JIGANI 2     | BG ROAD, JIGANI 66, JIGANI LINK ROAD                 | 19:23   | 19:35     | 0:12     | LINE FAULT          |
| 188   | 11-Dec-19 | BENGALURU | 66      | YARANDANAHALLI 220 - ANEKAL 2 | ANEKAL   | 9:19    | 9:22      | 0:03     | MAIN SUPPLY FAILURE |
| 189   | 11-Dec-19 | BENGALURU | 66      | MALUR 220 - MAASTHI           | MAASTHI, DEVANGONDHI, LAKKUR                         | 7:15    | 7:31      | 0:16     | LOAD CURTAILMENT    |
| 190   | 11-Dec-19 | BENGALURU | 66      | HV2                           | ANEKAL   | 9:03    | 9:20      | 0:17     | MAIN SUPPLY FAILURE |
| 191   | 11-Dec-19 | GULBARGA  | 220     | HV2                           | LINGAPUR_220   | 11:34   | 15:10     | 3:36     | NFBC ISSUED         |
| 192   | 11-Dec-19 | GULBARGA  | 110     | HV1                           | LINGASUGUR_220                                       | 6:55    | 7:30      | 0:35     | LOAD CURTAILMENT    |
| 193   | 11-Dec-19 | GULBARGA  | 110     | HV2                           | LINGASUGUR_220                                       | 6:55    | 7:30      | 0:35     | LOAD CURTAILMENT    |
| 194   | 11-Dec-19 | GULBARGA  | 110     | HV3                           | LINGASUGUR_220                                       | 6:55    | 7:30      | 0:35     | LOAD CURTAILMENT    |
| 195   | 11-Dec-19 | GULBARGA  | 220     | HV1                           | LINGASUGUR_220                                       | 10:50   | 13:50     | 3:00     | LINE CLEAR AVAILED  |

| SL no | DATE      | Tr_ZONE  | Voltage | Line/Transformer   | NAME OF THE STATION        | open_at | Closed_At | Duration | REASON             |
|-------|-----------|----------|---------|--------------------|----------------------------|---------|-----------|----------|--------------------|
| 196   | 11-Dec-19 | GULBARGA | 400     | YTPS-BPS2          | YTPS_400                   | 0:00    | 17:59     | 17:59    | LINE FAULT         |
| 197   | 11-Dec-19 | GULBARGA | 400     | YTPS-BPS2          | YTPS_400                   | 10:43   | 23:59     | 13:16    | LINE CLEAR AVAILED |
| 198   | 11-Dec-19 | HASSAN   | 400     | UPCL-HASSAN1       | upcl_gen                   | 0:00    | 6:44      | 6:44     | LINE CLEAR AVAILED |
| 199   | 11-Dec-19 | HASSAN   | 400     | UPCL-HASSAN1       | upcl_gen                   | 23:49   | 23:59     | 0:10     | HAND TRIPPED       |
| 200   | 11-Dec-19 | HASSAN   | 220     | GERSOPA-TALGUPA1   | gerusoppa_gen              | 22:25   | 23:11     | 0:46     | HAND TRIPPED       |
| 201   | 11-Dec-19 | HASSAN   | 220     | GERSOPA-TALGUPA2   | gerusoppa_gen              | 22:26   | 23:12     | 0:46     | HAND TRIPPED       |
| 202   | 11-Dec-19 | HASSAN   | 220     | HV1                | SHIRALKOPPA_220            | 13:41   | 14:40     | 0:59     | LINE CLEAR AVAILED |
| 203   | 11-Dec-19 | HASSAN   | 220     | HV2                | SHIRALKOPPA_220            | 15:52   | 17:42     | 1:50     | LINE CLEAR AVAILED |
| 204   | 11-Dec-19 | HASSAN   | 110     | LV2                | SHIRALKOPPA_220            | 15:52   | 17:42     | 1:50     | LINE CLEAR AVAILED |
| 205   | 11-Dec-19 | HASSAN   | 110     | HV1                | GANDASI_110                | 11:39   | 16:38     | 4:59     | LINE CLEAR AVAILED |
| 206   | 11-Dec-19 | HASSAN   | 110     | HV1                | GURUVAYANAKERE_110         | 12:57   | 13:50     | 0:53     | LINE CLEAR AVAILED |
| 207   | 11-Dec-19 | HASSAN   | 110     | HV3                | GURUVAYANAKERE_110         | 11:17   | 12:57     | 1:40     | LINE CLEAR AVAILED |
| 208   | 11-Dec-19 | HASSAN   | 110     | SAGARA-IDLE        | SAGARA_110                 | 14:41   | 14:49     | 0:08     | HAND TRIPPED       |
| 209   | 11-Dec-19 | HASSAN   | 66      | HV1                | BAGUR_66                   | 17:17   | 17:54     | 0:37     | TRANSFORMER FAULT  |
| 210   | 11-Dec-19 | HASSAN   | 66      | HV2                | BASAVAGHATTA_66            | 6:55    | 7:05      | 0:10     | TRANSFORMER FAULT  |
| 211   | 11-Dec-19 | HASSAN   | 66      | HV1                | DODDAKADANUR_66            | 18:17   | 18:19     | 0:02     | LOAD CURTAILMENT   |
| 212   | 11-Dec-19 | HASSAN   | 66      | HNPR2-MYSOR2       | HOLENARASIPURA_220         | 18:10   | 18:19     | 0:09     | LINE FAULT         |
| 213   | 11-Dec-19 | MYSORE   | 66      | HV2                | BOMMALAPURA_66             | 11:14   | 17:45     | 6:31     | LINE CLEAR AVAILED |
| 214   | 11-Dec-19 | MYSORE   | 66      | HV1                | COWDALLI_66                | 13:32   | 15:50     | 2:17     | LINE CLEAR AVAILED |
| 215   | 11-Dec-19 | MYSORE   | 66      | CR NAGARA-KABBALLI | HARVEY_66                  | 0:18    | 0:29      | 0:11     | LINE FAULT         |
| 216   | 11-Dec-19 | MYSORE   | 66      | HV1                | GUNDULPET_66               | 8:06    | 9:13      | 1:07     | LINE CLEAR AVAILED |
| 217   | 11-Dec-19 | MYSORE   | 66      | HV1                | HADLI_66                   | 10:14   | 12:16     | 2:02     | LINE CLEAR AVAILED |
| 218   | 11-Dec-19 | MYSORE   | 66      | HOOTAGALLI-BOGADHI | BOGADHI_66                 | 9:55    | 9:57      | 0:01     | HAND TRIPPED       |
| 219   | 11-Dec-19 | MYSORE   | 66      | HOOTAGALLI-BOGADHI | BOGADHI_66, KALAMANDIRA_66 | 12:32   | 12:33     | 0:00     | HAND TRIPPED       |
| 220   | 11-Dec-19 | MYSORE   | 66      | HV1                | HOOTAGALLY_220             | 10:01   | 10:04     | 0:02     | HAND TRIPPED       |
| 221   | 11-Dec-19 | MYSORE   | 66      | HV2                | HOOTAGALLY_220             | 10:01   | 10:04     | 0:02     | HAND TRIPPED       |
| 222   | 11-Dec-19 | MYSORE   | 220     | HV1                | HOOTAGALLY_220             | 10:10   | 12:28     | 2:18     | LINE CLEAR AVAILED |
| 223   | 11-Dec-19 | MYSORE   | 66      | HV2                | KADAKOLA_220               | 11:12   | 15:16     | 4:03     | LINE CLEAR AVAILED |
| 224   | 11-Dec-19 | MYSORE   | 66      | HV1                | KUSHALANAGARA_66           | 6:56    | 7:03      | 0:07     | LOAD CURTAILMENT   |
| 225   | 11-Dec-19 | MYSORE   | 66      | HV1                | MALAVALLI_66               | 10:06   | 15:30     | 5:23     | LINE CLEAR AVAILED |
| 226   | 11-Dec-19 | MYSORE   | 66      | HV2                | MALAVALLI_66               | 10:07   | 15:30     | 5:23     | LINE CLEAR AVAILED |
| 227   | 11-Dec-19 | MYSORE   | 66      | MALAVALLI-M2       | HADLI                      | 10:12   | 15:30     | 5:17     | LINE CLEAR AVAILED |
| 228   | 11-Dec-19 | MYSORE   | 66      | HV1                | RAVANDUR_66                | 13:28   | 15:35     | 2:07     | LINE CLEAR AVAILED |
| 229   | 11-Dec-19 | MYSORE   | 66      | HV2                | RAVANDUR_66                | 14:35   | 16:00     | 1:25     | LINE CLEAR AVAILED |
| 230   | 11-Dec-19 | MYSORE   | 66      | HV1                | SANTHESARAGUR_66           | 13:04   | 16:11     | 3:06     | LINE CLEAR AVAILED |
| 231   | 11-Dec-19 | MYSORE   | 66      | HV1                | TARIPURA_66                | 11:32   | 11:53     | 0:21     | LINE CLEAR AVAILED |

| SL no | DATE      | Tr_ZONE | Voltage | Line/Transformer                           | NAME OF THE STATION  | open_at | Closed_At | Duration | REASON              |
|-------|-----------|---------|---------|--|--|---------|-----------|----------|---------------------|
| 232   | 11-Dec-19 | MYSORE  | 66      | TUBINAKERE-NAGAMANGALA 1                   | ADDIHALLI_66<br>HARADANAHALLI(JAK)_66<br>BGNAGARA_66<br>ADICHUNCHANAGIRI_66 VADERALLI_66<br>BASARALU_66 KESLAGERE_66 | 6:39    | 6:48      | 0:08     | LINE FAULT          |
| 233   | 11-Dec-19 | MYSORE  | 66      | VAJAMANGALA-JYOTHINAGARA                   | JYOTHINAGARA_66  | 10:31   | 16:46     | 6:15     | NFBC ISSUED         |
| 234   | 11-Dec-19 | MYSORE  | 66      | HV1  | VIJAYANAGRAMYS_66  | 12:35   | 12:40     | 0:05     | MAIN SUPPLY FAILURE |
| 235   | 11-Dec-19 | MYSORE  | 66      | HV2  | VIJAYANAGRAMYS_66  | 12:35   | 12:41     | 0:05     | MAIN SUPPLY FAILURE |
| 236   | 11-Dec-19 | TUMKUR  | 220     | GUTUR_400-NEELAGUNDA                       | NEELAGUNDA_220   | 16:25   | 19:54     | 3:28     | LINE CLEAR AVAILED  |
| 237   | 11-Dec-19 | TUMKUR  | 110     | TR-1                                       | CHIKKANAYAKANAHALLI_110  | 8:42    | 10:35     | 1:52     | LINE CLEAR AVAILED  |
| 238   | 11-Dec-19 | TUMKUR  | 110     | TR-1                                       | GUBBI_110  | 2:15    | 2:27      | 0:12     | TRANSFORMER FAULT   |
| 239   | 11-Dec-19 | TUMKUR  | 110     | TR-1                                       | GUBBI_110  | 13:00   | 14:07     | 1:07     | LINE CLEAR AVAILED  |
| 240   | 11-Dec-19 | TUMKUR  | 66      | ANTHRASANAHALLI 220KV- KOLALA ( dabaspete) | KOLALA_66, URDIGERE_66   | 0:13    | 0:24      | 0:11     | LINE FAULT          |
| 241   | 11-Dec-19 | TUMKUR  | 66      | CHITRADURGA 220kv- HIRIYUR                 | IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66   | 7:13    | 7:45      | 0:31     | HAND TRIPPED        |
| 242   | 11-Dec-19 | TUMKUR  | 66      | CHITRADURGA 220kv- PANDARAHALLI 1          | HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66  | 7:19    | 7:45      | 0:26     | HAND TRIPPED        |
| 243   | 11-Dec-19 | TUMKUR  | 66      | CHITRADURGA 220kv- PANDARAHALLI 1          | HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66  | 11:39   | 11:58     | 0:19     | HAND TRIPPED        |
| 244   | 11-Dec-19 | TUMKUR  | 66      | TR-2                                       | GUTTUR_66  | 6:00    | 6:58      | 0:57     | TRANSFORMER FAULT   |
| 245   | 11-Dec-19 | TUMKUR  | 66      | TR-2                                       | HALUVAGALU_66  | 12:15   | 13:02     | 0:47     | LINE CLEAR AVAILED  |
| 246   | 11-Dec-19 | TUMKUR  | 66      | HONNALLI 220kv- CHANNAGIRI(NALLUR )        | DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66  | 18:04   | 18:19     | 0:15     | LINE FAULT          |
| 247   | 11-Dec-19 | TUMKUR  | 66      | TR-1                                       | KATTIGE_66   | 9:56    | 10:00     | 0:04     | TRANSFORMER FAULT   |
| 248   | 11-Dec-19 | TUMKUR  | 66      | MATHOD- ENERCON1_IPP_66                    | ENERCON1_IPP_66  | 13:38   | 15:42     | 2:04     | LINE CLEAR AVAILED  |
| 249   | 11-Dec-19 | TUMKUR  | 66      | THALLAK 220kv -BGKERE 1                    | BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66  | 12:08   | 12:14     | 0:06     | HAND TRIPPED        |
| 250   | 11-Dec-19 | TUMKUR  | 66      | THALLAK 220kv- GOWRASAMUDRA                | CHALLAKERE_66, SANIKERE_66   | 12:08   | 12:14     | 0:05     | HAND TRIPPED        |
| 251   | 11-Dec-19 | TUMKUR  | 66      | TR-2(LV SIDE)                              | THALLAKK_220   | 11:54   | 12:12     | 0:17     | TRANSFORMER FAULT   |
| 252   | 11-Dec-19 | TUMKUR  | 66      | THALLAK 220kv- NAYAKANHATTI                | NAYAKANHATTI_66, HIREMALLANAHOLE_66  | 6:02    | 11:13     | 5:11     | LINE CLEAR AVAILED  |
| 253   | 11-Dec-19 | TUMKUR  | 66      | THALLAK 220kv- WELSPUN SOLAR1              | WELSPUNSOLAR1_IPP_66   | 12:08   | 16:02     | 3:54     | LiNE CLEAR AVAILED  |
| 254   | 11-Dec-19 | TUMKUR  | 66      | THALLAK 220kv- WELSPUN SOLAR1              | WELSPUNSOLAR1_IPP_66   | 12:08   | 12:21     | 0:13     | HAND TRIPPED        |



| SL no | DATE      | Tr_ZONE   | Voltage | Line/Transformer             | NAME OF THE STATION            | open_at | Closed_At | Duration | REASON              |
|-------|-----------|-----------|---------|------------------------------|--------------------------------|---------|-----------|----------|---------------------|
| 255   | 11-Dec-19 | TUMKUR    | 66      | URDIGERE-ANTHRASANAHALI      | URDIGERE_66                    | 0:17    | 0:31      | 0:13     | MAIN SUPPLY FAILURE |
| 256   | 11-Dec-19 | TUMKUR    | 66      | URDIGERE-KOLALA              | URDIGERE_66                    | 0:18    | 0:34      | 0:16     | MAIN SUPPLY FAILURE |
| 257   | 11-Dec-19 | TUMKUR    | 66      | TR-1                         | YEDIYUR_66                     | 12:07   | 12:33     | 0:25     | LINE CLEAR AVAILED  |
| 258   | 12-Dec-19 | BAGALKOT  | 110     | 110/33KV,HV 2                | ANKOLA_110&33KV SEABIRD&ANKOLA | 10:06   | 17:39     | 7:33     | LINE CLEAR AVAILED  |
| 259   | 12-Dec-19 | BAGALKOT  | 110     | MAMDAPUR-BABALESHWAR         | BABALESHWAR_110                | 10:19   | 16:17     | 5:58     | LINE FAULT          |
| 260   | 12-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV 2                | BYADAGI_110                    | 9:15    | 19:52     | 10:37    | TRANSFORMER FAULT   |
| 261   | 12-Dec-19 | BAGALKOT  | 220     | AMBEWADI-PONDA 2             | AMBEWADI_220                   | 0:00    | 17:38     | 17:38    | LINE CLEAR AVAILED  |
| 262   | 12-Dec-19 | BAGALKOT  | 220     | BIDNAL-HARTI 1               | BIDNAL_220                     | 9:54    | 15:28     | 5:34     | LINE CLEAR AVAILED  |
| 263   | 12-Dec-19 | BAGALKOT  | 220     | GHATAPRABHA-NARENDRA 1       | GHATAPRABHA_220                | 10:31   | 17:52     | 7:21     | LINE CLEAR AVAILED  |
| 264   | 12-Dec-19 | BAGALKOT  | 110     | 110/11V,HV2                  | HIDIKAL DAM_110                | 12:01   | 16:44     | 4:43     | LINE CLEAR AVAILED  |
| 265   | 12-Dec-19 | BAGALKOT  | 110     | KADANAKOPPA-KAVALWADA        | KAVALWADA_110                  | 10:06   | 23:59     | 13:53    | LINE CLEAR AVAILED  |
| 266   | 12-Dec-19 | BAGALKOT  | 110     | 110/11V,HV2                  | KAGAWAD_110                    | 11:13   | 11:32     | 0:19     | LINE CLEAR AVAILED  |
| 267   | 12-Dec-19 | BAGALKOT  | 110     | 110/11V,HV2                  | KANABARGI LAYOUT_110           | 8:43    | 15:12     | 6:29     | LINE CLEAR AVAILED  |
| 268   | 12-Dec-19 | BAGALKOT  | 110     | 110/11V,HV2                  | KANABARGI LAYOUT_110           | 16:12   | 17:58     | 1:46     | LINE CLEAR AVAILED  |
| 269   | 12-Dec-19 | BAGALKOT  | 110     | LAXMESHWAR-BELLATTI          | BELLATTI_110                   | 17:35   | 17:52     | 0:17     | LINE CLEAR AVAILED  |
| 270   | 12-Dec-19 | BAGALKOT  | 110     | KUDUCHI-TERDAL               | TERDAL_110                     | 14:09   | 15:37     | 1:28     | LINE CLEAR AVAILED  |
| 271   | 12-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV4                 | HUBLI_220                      | 13:42   | 14:39     | 0:57     | LINE CLEAR AVAILED  |
| 272   | 12-Dec-19 | BAGALKOT  | 110     | HUBLI-KADANKOPPA             | KADANKOPPA_110                 | 11:13   | 17:43     | 6:30     | NFBC ISSUED         |
| 273   | 12-Dec-19 | BAGALKOT  | 110     | SANKESHWAR-HUKKERI           | HUKKERI_110                    | 15:52   | 15:59     | 0:07     | LINE CLEAR AVAILED  |
| 274   | 12-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV2                 | SANKESHWAR_110                 | 11:43   | 12:10     | 0:27     | LINE CLEAR AVAILED  |
| 275   | 12-Dec-19 | BAGALKOT  | 110     | BAGEWADI-HUNGUND             | HUNGUND_110                    | 10:25   | 10:35     | 0:10     | LINE FAULT          |
| 276   | 12-Dec-19 | BAGALKOT  | 110     | HUNGAND-ILKAL1&2             | ILKAL_110                      | 10:35   | 10:43     | 0:08     | HAND TRIPPED        |
| 277   | 12-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV2                 | MUKARTIHAL_110                 | 14:07   | 15:43     | 1:36     | LINE CLEAR AVAILED  |
| 278   | 12-Dec-19 | BAGALKOT  | 110     | UGAR KHUD-KAGAWAD            | KAGAWAD_110                    | 4:41    | 4:55      | 0:14     | LINE FAULT          |
| 279   | 12-Dec-19 | BAGALKOT  | 110     | UGAR SUGARS-UGAR KHUD        | UGAR KHUD_110                  | 4:42    | 4:51      | 0:09     | LINE FAULT          |
| 280   | 12-Dec-19 | BENGALURU | 66      | SOMANAHALLI 220- JIGANI 2    | BG ROAD                        | 0:00    | 0:30      | 0:30     | LINE FAULT          |
| 281   | 12-Dec-19 | BENGALURU | 66      | JIGANI 66 - JIGANI LINK ROAD | JIGANI LINK ROAD               | 0:20    | 0:30      | 0:10     | LOAD CHANGE OVER    |
| 282   | 12-Dec-19 | BENGALURU | 66      | JIGANI 66 - JIGANI 220       | JIGANI 66                      | 0:20    | 0:32      | 0:12     | LOAD CHANGE OVER    |
| 283   | 12-Dec-19 | BENGALURU | 66      | MANDIKAL - SOMENAHALLI       | SOMENAHALLI                    | 8:00    | 8:05      | 0:05     | LOAD CHANGE OVER    |
| 284   | 12-Dec-19 | BENGALURU | 66      | MITTEMARI - SOMENAHALLI      | SOMENAHALLI                    | 19:45   | 19:50     | 0:05     | LOAD CHANGE OVER    |
| 285   | 12-Dec-19 | BENGALURU | 66      | RBI - ELITA PROMENENDE       | RBI                            | 5:05    | 5:10      | 0:05     | LOAD CHANGE OVER    |
| 286   | 12-Dec-19 | BENGALURU | 66      | SOUTH CITY - KHODAYS         | SOUTH CITY                     | 6:10    | 6:20      | 0:10     | LOAD CHANGE OVER    |
| 287   | 12-Dec-19 | BENGALURU | 66      | HV2                          | MANCHENAHALLI                  | 8:11    | 8:30      | 0:18     | TRANSFORMER FAULT   |
| 288   | 12-Dec-19 | BENGALURU | 66      | MANDIKAL - SOMENAHALLI       | SOMENAHALLI                    | 8:15    | 8:20      | 0:05     | LOAD CHANGE OVER    |
| 289   | 12-Dec-19 | GULBARGA  | 400     | YTPS-BPS2                    | YTPS_400                       | 0:00    | 17:59     | 17:59    | LINE FAULT          |
| 290   | 12-Dec-19 | GULBARGA  | 400     | YTPS-BPS2                    | YTPS_400                       | 10:43   | 23:59     | 13:16    | LINE CLEAR AVAILED  |
| 291   | 12-Dec-19 | GULBARGA  | 400     | YTPS-BPS2                    | YTPS_400                       | 0:00    | 7:55      | 7:55     | LINE CLEAR AVAILED  |
| 292   | 12-Dec-19 | GULBARGA  | 400     | BPS-YTPS1                    | YTPS_400                       | 10:45   | 23:59     | 13:14    | LINE CLEAR AVAILED  |

| SL no | DATE      | Tr_ZONE  | Voltage | Line/Transformer                 | NAME OF THE STATION   | open_at | Closed_At | Duration | REASON             |
|-------|-----------|----------|---------|----------------------------------|---|---------|-----------|----------|--------------------|
| 293   | 12-Dec-19 | GULBARGA | 110     | LINGASUGUR_220                   | HV1   | 9:25    | 9:33      | 0:08     | LINE FAULT         |
| 294   | 12-Dec-19 | GULBARGA | 110     | LINGASUGUR_220                   | HV2   | 9:25    | 9:33      | 0:08     | LINE FAULT         |
| 295   | 12-Dec-19 | GULBARGA | 110     | SHAHAPUR-WARDASOLAR_IPP          | SHAHAPUR_220  | 18:21   | 20:22     | 2:01     | LINE CLEAR AVAILED |
| 296   | 12-Dec-19 | GULBARGA | 110     | HUMNABAD-DUBALGUNDI              | DUBALGUNDI_110  | 18:30   | 23:59     | 5:29     | LINE CLEAR AVAILED |
| 297   | 12-Dec-19 | HASSAN   | 400     | UPCL-HASSAN1                     | upcl_gen  | 0:00    | 6:52      | 6:52     | LINE CLEAR AVAILED |
| 298   | 12-Dec-19 | HASSAN   | 220     | GERSOPA-TALGUPA2                 | gerusoppa_gen   | 14:43   | 23:59     | 9:16     | LINE FAULT         |
| 299   | 12-Dec-19 | HASSAN   | 220     | TALAGU-STRP2                     | TALAGUPPA_400   | 14:43   | 23:59     | 9:16     | LINE FAULT         |
| 300   | 12-Dec-19 | HASSAN   | 110     | HV1                              | BANTWAL_110   | 10:18   | 17:39     | 7:21     | LINE CLEAR AVAILED |
| 301   | 12-Dec-19 | HASSAN   | 110     | HV3                              | SHIRALKOPPA_110   | 15:28   | 15:31     | 0:03     | TRANSFORMER FAULT  |
| 302   | 12-Dec-19 | HASSAN   | 66      | CHANNARA-UDAYAPURA               | CHANNARAYAPATNA_66  | 9:42    | 13:53     | 4:11     | LINE CLEAR AVAILED |
| 303   | 12-Dec-19 | HASSAN   | 66      | SAKALE-HANBAL                    | SAKLESHPURA_66  | 2:52    | 3:25      | 0:33     | LINE FAULT         |
| 304   | 12-Dec-19 | HASSAN   | 66      | SAKALE-HANBAL                    | SAKLESHPURA_66  | 4:14    | 4:25      | 0:11     | LINE FAULT         |
| 305   | 12-Dec-19 | MYSORE   | 66      | HV1                              | BOGADHI_66  | 12:07   | 13:01     | 0:54     | LINE CLEAR AVAILED |
| 306   | 12-Dec-19 | MYSORE   | 66      | HV2                              | BOMMALAPURA_66  | 12:03   | 17:09     | 5:05     | LINE CLEAR AVAILED |
| 307   | 12-Dec-19 | MYSORE   | 66      | HV1                              | CHUNCHUNKATTE_66  | 1:13    | 1:30      | 0:16     | TRANSFORMER FAULT  |
| 308   | 12-Dec-19 | MYSORE   | 66      | HUNSUR-HOOTAGALLY                | BANNIKUPPE_66 HOSURGATE_66  | 5:48    | 5:54      | 0:06     | LINE FAULT         |
| 309   | 12-Dec-19 | MYSORE   | 220     | HV2                              | KADAKOLA_220  | 12:42   | 21:58     | 9:16     | LINE CLEAR AVAILED |
| 310   | 12-Dec-19 | MYSORE   | 66      | KADAKOLA-SARGUR 2                | HULLAHALLI_66 DOORA_66<br>CHANDAKAVADI_66 HURA_66<br>SANTHESARAGUR_66     | 18:29   | 19:00     | 0:30     | HAND TRIPPED       |
| 311   | 12-Dec-19 | MYSORE   | 66      | KADAKOLA-SARGUR 1                | ANTHARSANTHE_66,<br>HAMPAPURA(K)_66, HDKOTE_66,<br>JAIPUR_66 B MATKERE_66 | 18:27   | 19:00     | 0:33     | HAND TRIPPED       |
| 312   | 12-Dec-19 | MYSORE   | 66      | KIRUGAVALU-MALIYUR               | MALIYURU_66 KIRUGAVALU_66<br>VADKEPURA_66                                 | 8:05    | 8:16      | 0:11     | LINE FAULT         |
| 313   | 12-Dec-19 | MYSORE   | 66      | KUSHALNAGARA 220-MYSORE 1        | MIRLE_66  | 6:03    | 6:10      | 0:06     | LINE FAULT         |
| 314   | 12-Dec-19 | MYSORE   | 66      | VAJAMANGALA-KADAKOLA 1           | AYRALLI_66 MARADIHUNDI_66   | 15:54   | 16:03     | 0:09     | LINE FAULT         |
| 315   | 12-Dec-19 | TUMKUR   | 220     | CHITRADURGA 220- GUTTUR 220      | CHITRADURGA_220   | 11:22   | 13:37     | 2:14     | LINE CLEAR AVAILED |
| 316   | 12-Dec-19 | TUMKUR   | 220     | DAVANGERE SRS- GUTTUR-3          | DAVANGERE_SRS_220   | 12:32   | 17:45     | 5:13     | LINE CLEAR AVAILED |
| 317   | 12-Dec-19 | TUMKUR   | 220     | GUTTUR 400- CHITRADURGA 220      | CHITRADURGA_220   | 11:17   | 13:36     | 2:19     | LINE CLEAR AVAILED |
| 318   | 12-Dec-19 | TUMKUR   | 220     | GUTUR_400-DAVANGERE SRS2         | DAVANGERE_SRS_220   | 9:19    | 13:09     | 3:49     | LINE CLEAR AVAILED |
| 319   | 12-Dec-19 | TUMKUR   | 110     | TR-1                             | TURUVEKERE_110  | 12:26   | 12:38     | 0:12     | TRANSFORMER FAULT  |
| 320   | 12-Dec-19 | TUMKUR   | 110     | SAMPIGE- RENEWIND_IPP            | RENEW_WIND_IPP_110  | 11:03   | 11:16     | 0:12     | HAND TRIPPED       |
| 321   | 12-Dec-19 | TUMKUR   | 66      | TR-2                             | CHELURU_66  | 14:14   | 14:25     | 0:11     | LINE CLEAR AVAILED |
| 322   | 12-Dec-19 | TUMKUR   | 66      | CHITRADURGA 66kV- PANDARAHALLI 2 | PANDARAHALLI_66   | 14:20   | 15:20     | 1:00     | LINE CLEAR AVAILED |
| 323   | 12-Dec-19 | TUMKUR   | 66      | DAVANGERE SRS- DAVANGERE         | DAVANAGERE_66   | 17:29   | 17:44     | 0:14     | LINE FAULT         |
| 324   | 12-Dec-19 | TUMKUR   | 66      | SIRA- KALLAMBELLA                | SIRA_66   | 10:32   | 12:41     | 2:09     | LINE CLEAR AVAILED |

| SL no | DATE      | Tr_ZONE   | Voltage | Line/Transformer               | NAME OF THE STATION  | open_at | Closed_At | Duration | REASON              |
|-------|-----------|-----------|---------|--------------------------------|--|---------|-----------|----------|---------------------|
| 325   | 12-Dec-19 | TUMKUR    | 66      | NAYAKANAHATTI66-HIREMALLANHOLE | NAYAKANAHATTI_66   | 13:56   | 14:56     | 1:00     | LINE CLEAR AVAILED  |
| 326   | 12-Dec-19 | TUMKUR    | 66      | KUKKAWADA- LINGADAHALLI        | TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66   | 11:18   | 14:59     | 3:40     | LINE CLEAR AVAILED  |
| 327   | 12-Dec-19 | TUMKUR    | 66      | TR-1                           | KATTIGE_66   | 17:07   | 17:13     | 0:06     | TRANSFORMER FAULT   |
| 328   | 13-Dec-19 | BAGALKOT  | 220     | 220/110KV, HV1&LV1             | BELGAUM_220, NEHRU NAGAR_110, KANBARGILAYOUT_110, HUDLI_110, VADAGOAN_110, UCHAGOAN_110, UDYAMBAG_110, MACHE_110 | 14:35   | 19:35     | 5:00     | TRANSFORMER FAULT   |
| 329   | 13-Dec-19 | BAGALKOT  | 220     | 220/110KV, HV1&LV1             | BELGAUM_220, NEHRU NAGAR_110, KANBARGILAYOUT_110, HUDLI_110, VADAGOAN_110, UCHAGOAN_110, UDYAMBAG_110, MACHE_110 | 14:35   | 19:32     | 4:57     | TRANSFORMER FAULT   |
| 330   | 13-Dec-19 | BAGALKOT  | 220     | BIDNAL-HAVERI                  | BIDNAL_220   | 15:47   | 23:59     | 8:12     | LINE FAULT          |
| 331   | 13-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV2                   | BYADAGI_110  | 11:46   | 13:20     | 1:34     | LINE CLEAR AVAILED  |
| 332   | 13-Dec-19 | BAGALKOT  | 220     | CHIKKODI-MUDASHINGI            | CHIKKODI_220   | 13:28   | 18:58     | 5:30     | LINE FAULT          |
| 333   | 13-Dec-19 | BAGALKOT  | 220     | DHONI-GADAG 1&2                | GADAG_220  | 11:00   | 23:59     | 12:59    | LINE CLEAR AVAILED  |
| 334   | 13-Dec-19 | BAGALKOT  | 220     | 220/110KV,HV1 &LV1             | GADAG_220  | 17:44   | 20:08     | 2:24     | LINE CLEAR AVAILED  |
| 335   | 13-Dec-19 | BAGALKOT  | 220     | GHATAPRABHA -NARENDRA 2        | GHATAPRABHA_220  | 9:52    | 17:52     | 8:00     | LINE CLEAR AVAILED  |
| 336   | 13-Dec-19 | BAGALKOT  | 220     | HAVERI-BIDNAL                  | HAVERI_220   | 15:47   | 23:59     | 8:12     | LINE FAULT          |
| 337   | 13-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV2                   | KANABARGI LAY OUT_110  | 10:37   | 11:08     | 0:31     | LINE CLEAR AVAILED  |
| 338   | 13-Dec-19 | BAGALKOT  | 220     | KADRA 1-KARAWAR                | KARAWAR_220  | 13:35   | 15:24     | 1:49     | LINE CLEAR AVAILED  |
| 339   | 13-Dec-19 | BAGALKOT  | 220     | KADRA 1-KARAWAR                | KARAWAR_220  | 15:27   | 16:49     | 1:22     | LINE CLEAR AVAILED  |
| 340   | 13-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV2                   | MUNAVALLI_110  | 13:24   | 13:33     | 0:09     | LINE CLEAR AVAILED  |
| 341   | 13-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV3                   | RATTIHALLI_110   | 10:47   | 12:23     | 1:36     | TRANSFORMER FAULT   |
| 342   | 13-Dec-19 | BAGALKOT  | 110     | HIREBEVANUR-RODAGI             | RODAGI_110   | 17:59   | 18:08     | 0:09     | LINE FAULT          |
| 343   | 13-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV1                   | TODALBAGI_110  | 10:39   | 10:46     | 0:07     | TRANSFORMER FAULT   |
| 344   | 13-Dec-19 | BENGALURU | 66      | MANDIKAL - SOMENAHALLI         | SOMENAHALLI  | 8:15    | 8:20      | 0:05     | LOAD CHANGE OVER    |
| 345   | 13-Dec-19 | BENGALURU | 66      | SOMANAHALLI 220 - KHODAYS 220  | KHODAYS 220, SUBRAMANYAPURA 220  | 12:50   | 13:10     | 0:20     | LINE FAULT          |
| 346   | 13-Dec-19 | BENGALURU | 220     | MALUR 220 - HOODY 220          | MALUR 220  | 11:43   | 11:51     | 0:08     | LINE FAULT          |
| 347   | 13-Dec-19 | BENGALURU | 220     | MALUR 220 - HOODY 220          | MALUR 220  | 11:43   | 11:51     | 0:08     | LINE FAULT          |
| 348   | 13-Dec-19 | BENGALURU | 66      | MALUR 220 - MAASTHI            | MAASTHI, DEVANGONDHI, LAKKUR   | 11:47   | 12:26     | 0:39     | MAIN SUPPLY FAILURE |

| SL no | DATE      | Tr_ZONE   | Voltage | Line/Transformer       | NAME OF THE STATION  | open_at | Closed_At | Duration | REASON              |
|-------|-----------|-----------|---------|------------------------|--|---------|-----------|----------|---------------------|
| 349   | 13-Dec-19 | BENGALURU | 66      | MALUR 220 - KGF 1      | KGF, TEKAL, BUDIKOTE, KAMASAMUDRA  | 11:47   | 12:27     | 0:40     | MAIN SUPPLY FAILURE |
| 350   | 13-Dec-19 | BENGALURU | 66      | MALUR 220 - KGF 2      | ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI                                    | 11:47   | 12:27     | 0:40     | MAIN SUPPLY FAILURE |
| 351   | 13-Dec-19 | BENGALURU | 66      | MALUR 220 - HOSKOTE 2  | JADIGENAHALLI  | 11:47   | 12:26     | 0:39     | MAIN SUPPLY FAILURE |
| 352   | 13-Dec-19 | BENGALURU | 66      | MALUR 220 - HOSKOTE 1  | MALUR I/A, STAR PANEL (EHT)  | 11:47   | 12:26     | 0:39     | MAIN SUPPLY FAILURE |
| 353   | 13-Dec-19 | BENGALURU | 66      | MALUR 220 - MALUR 66   | MALUR 66   | 11:47   | 12:26     | 0:39     | MAIN SUPPLY FAILURE |
| 354   | 13-Dec-19 | BENGALURU | 66      | MALUR 220 - KGF 1 & 2  | KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI | 11:47   | 12:26     | 0:39     | MAIN SUPPLY FAILURE |
| 355   | 13-Dec-19 | BENGALURU | 66      | HV2                    | KOLAR 220  | 13:50   | 14:00     | 0:10     | TRANSFORMER FAULT   |
| 356   | 13-Dec-19 | BENGALURU | 66      | HV2                    | KOLAR 220  | 14:00   | 20:28     | 6:28     | LINE CLEAR AVAILED  |
| 357   | 13-Dec-19 | GULBARGA  | 400     | BPS-YTPS1              | YTPS_400   | 0:00    | 8:35      | 8:35     | LINE CLEAR AVAILED  |
| 358   | 13-Dec-19 | GULBARGA  | 220     | ALIPUR-BTPS            | ALIPUR_220   | 9:28    | 15:05     | 5:37     | LINE CLEAR AVAILED  |
| 359   | 13-Dec-19 | GULBARGA  | 110     | HUMNABAD-DUBALGUNDI    | DUBALGUNDI_110   | 0:00    | 11:45     | 11:45    | LINE CLEAR AVAILED  |
| 360   | 13-Dec-19 | GULBARGA  | 110     | SINDHANOOR-MUNIRABAD2  | MUNIRABAD_220  | 11:03   | 11:15     | 0:12     | LINE FAULT          |
| 361   | 13-Dec-19 | GULBARGA  | 110     | SINDHANOOR-SINDHANOOR1 | SINDHANOOR_220   | 12:00   | 12:57     | 0:57     | LINE FAULT          |
| 362   | 13-Dec-19 | HASSAN    | 400     | UPCL-HASSAN1           | upcl_gen   | 1:34    | 5:44      | 4:10     | LINE CLEAR AVAILED  |
| 363   | 13-Dec-19 | HASSAN    | 220     | GERSOPA-TALGUPA2       | gerusoppa_gen  | 0:00    | 13:50     | 13:50    | LINE FAULT          |
| 364   | 13-Dec-19 | HASSAN    | 220     | KEMAR-PUTUR1           | KEMAR_220  | 10:37   | 13:12     | 2:35     | LINE CLEAR AVAILED  |
| 365   | 13-Dec-19 | HASSAN    | 220     | MRSSHM-SHARAVATHY3     | MRSMG_220  | 11:44   | 13:49     | 2:05     | LINE CLEAR AVAILED  |
| 366   | 13-Dec-19 | HASSAN    | 220     | SHRAVTY-SHIMOGA3       | sharavathy_gen   | 11:44   | 13:49     | 2:05     | NFBC ISSUED         |
| 367   | 13-Dec-19 | HASSAN    | 220     | TALAGU-STRP2           | TALAGUPPA_400  | 0:00    | 13:50     | 13:50    | LINE FAULT          |
| 368   | 13-Dec-19 | HASSAN    | 110     | GURUVA-SLVPWR          | GURUVAYANAKERE_110   | 14:45   | 15:35     | 0:50     | LINE CLEAR AVAILED  |
| 369   | 13-Dec-19 | HASSAN    | 110     | HV1                    | KULASHEKARA_110  | 14:30   | 16:00     | 1:30     | LINE CLEAR AVAILED  |
| 370   | 13-Dec-19 | HASSAN    | 110     | HV2                    | MOODABIDRE_110   | 12:03   | 12:28     | 0:25     | LINE CLEAR AVAILED  |
| 371   | 13-Dec-19 | HASSAN    | 110     | HV1                    | SORABA_110   | 12:50   | 14:10     | 1:20     | LINE CLEAR AVAILED  |
| 372   | 13-Dec-19 | HASSAN    | 66      | MRSSHM-DVG2            | MRSMG_220  | 14:33   | 14:39     | 0:06     | LINE FAULT          |
| 373   | 13-Dec-19 | HASSAN    | 66      | BANDISH-RAMNATHPURA    | BANDISHETTYHALLI_66  | 11:10   | 11:35     | 0:25     | LINE CLEAR AVAILED  |
| 374   | 13-Dec-19 | HASSAN    | 66      | HV1                    | HNPURA_66  | 11:15   | 11:17     | 0:02     | HAND TRIPPED        |
| 375   | 13-Dec-19 | HASSAN    | 66      | KUDLIGE-ANVRPP         | KUDLIGERE_66   | 11:58   | 12:53     | 0:55     | LINE CLEAR AVAILED  |
| 376   | 13-Dec-19 | HASSAN    | 66      | HV2                    | SALAGAME_66  | 15:23   | 15:38     | 0:15     | LINE CLEAR AVAILED  |
| 377   | 13-Dec-19 | HASSAN    | 66      | SIGEBAG-KDLGRE         | SIGEBAGI_66  | 14:39   | 14:44     | 0:05     | MAIN SUPPLY FAILURE |
| 378   | 13-Dec-19 | MYSORE    | 66      | BOMMALAPURA-GUNDLUPETE | BOMMALAPURA_66   | 12:04   | 14:19     | 2:15     | LINE CLEAR AVAILED  |
| 379   | 13-Dec-19 | MYSORE    | 66      | HV1                    | BOMMALAPURA_66   | 11:38   | 15:15     | 3:37     | LINE CLEAR AVAILED  |
| 380   | 13-Dec-19 | MYSORE    | 66      | HV2                    | BOMMALAPURA_66   | 11:38   | 15:16     | 3:38     | LINE CLEAR AVAILED  |
| 381   | 13-Dec-19 | MYSORE    | 66      | HV1                    | DKMAIDANA_66   | 10:02   | 15:23     | 5:20     | LINE CLEAR AVAILED  |
| 382   | 13-Dec-19 | MYSORE    | 66      | HV2                    | DKMAIDANA_66   | 10:02   | 15:23     | 5:20     | LINE CLEAR AVAILED  |

| SL no | DATE      | Tr_ZONE  | Voltage | Line/Transformer                    | NAME OF THE STATION  | open_at | Closed_At | Duration | REASON              |
|-------|-----------|----------|---------|-------------------------------------|--|---------|-----------|----------|---------------------|
| 383   | 13-Dec-19 | MYSORE   | 220     | HV2                                 | KADAKOLA_220   | 9:55    | 12:52     | 2:56     | LINE CLEAR AVAILED  |
| 384   | 13-Dec-19 | MYSORE   | 66      | KADAKOLA-DK MAIDANA                 | DKMAIDANA_66   | 10:15   | 15:22     | 5:07     | NFBC ISSUED         |
| 385   | 13-Dec-19 | MYSORE   | 66      | KADAKOLA-SARGURU 2                  | B MATKERE_66 HULLAHALLI_66<br>DOORA_66 CHANDAKAVADI_66<br>HURA_66 SANTHESARAGUR_66 | 13:07   | 13:14     | 0:06     | HAND TRIPPED        |
| 386   | 13-Dec-19 | MYSORE   | 66      | KADAKOLA-SARGURU 1                  | ANTHARSANTHE_66,<br>HAMPAPURA(K)_66, HDKOTE_66,<br>JAIPUR_66                       | 13:07   | 13:14     | 0:06     | HAND TRIPPED        |
| 387   | 13-Dec-19 | MYSORE   | 66      | KIRUGAVLU-VADKEPURA                 | KIRUGAVALU_66  | 11:41   | 11:55     | 0:14     | LINE FAULT          |
| 388   | 13-Dec-19 | MYSORE   | 66      | MADHUVANAHALLI-MAMBALLI             | MAMBALLI_66  | 7:37    | 7:42      | 0:05     | LINE FAULT          |
| 389   | 13-Dec-19 | MYSORE   | 66      | HV1                                 | SANTHESARAGUR_66   | 6:55    | 20:16     | 13:21    | LINE CLEAR AVAILED  |
| 390   | 13-Dec-19 | MYSORE   | 66      | HV2                                 | SANTHEMARAHALLI_66   | 11:02   | 11:35     | 0:33     | LINE CLEAR AVAILED  |
| 391   | 13-Dec-19 | MYSORE   | 66      | HV2                                 | SFCSHIVA_66  | 15:48   | 17:14     | 1:25     | LINE CLEAR AVAILED  |
| 392   | 13-Dec-19 | TUMKUR   | 110     | TR-1                                | BIDARE_110   | 14:34   | 15:42     | 1:07     | LINE CLEAR AVAILED  |
| 393   | 13-Dec-19 | TUMKUR   | 110     | TR-2                                | SAMPIGE_110  | 5:42    | 5:53      | 0:10     | TRANSFORMER FAULT   |
| 394   | 13-Dec-19 | TUMKUR   | 66      | DASUDI-M/S CLEAN SOLAR              | M/S CLEAN SOLAR_IPP_66   | 6:24    | 8:25      | 2:00     | LINE CLEAR AVAILED  |
| 395   | 13-Dec-19 | TUMKUR   | 66      | TR-2                                | HALUVAGALU_66  | 11:23   | 11:31     | 0:07     | LINE CLEAR AVAILED  |
| 396   | 13-Dec-19 | TUMKUR   | 66      | TR-1                                | KATTIGE_66   | 15:26   | 16:38     | 1:11     | LINE CLEAR AVAILED  |
| 397   | 13-Dec-19 | TUMKUR   | 66      | KATTIGE- RENEW WIND IPP             | RENEW WIND ENERGY_IPP_66   | 18:56   | 19:02     | 0:06     | LINE CLEAR AVAILED  |
| 398   | 13-Dec-19 | TUMKUR   | 66      | TR-1                                | MADHUGIRI_220  | 18:02   | 18:19     | 0:17     | TRANSFORMER FAULT   |
| 399   | 13-Dec-19 | TUMKUR   | 66      | THALLAK 220kV- NAYAKANHATTI         | NAYAKANHATTI_66,<br>HIREMALLANAHOLE_66   | 6:18    | 10:06     | 3:48     | LINE CLEAR AVAILED  |
| 400   | 13-Dec-19 | TUMKUR   | 66      | SIRA- MADHUGIRI OLD( BADAVANAHALLI) | SIRA_66  | 9:58    | 13:09     | 3:11     | LINE CLEAR AVAILED  |
| 401   | 13-Dec-19 | TUMKUR   | 66      | TR-1                                | SASALUHALLA_66   | 9:12    | 10:03     | 0:50     | LINE CLEAR AVAILED  |
| 402   | 13-Dec-19 | TUMKUR   | 66      | TR-2                                | SANIKERE_66  | 8:56    | 9:15      | 0:19     | TRANSFORMER FAULT   |
| 403   | 14-Dec-19 | BAGALKOT | 220     | NAGJHARI 1-AMBEWADI                 | AMBEWADI_220   | 10:28   | 13:25     | 2:57     | NFBC ISSUED         |
| 404   | 14-Dec-19 | BAGALKOT | 220     | PONDA1-AMBEWADI                     | AMBEWADI_220   | 0:00    | 16:53     | 16:53    | LINE CLEAR AVAILED  |
| 405   | 14-Dec-19 | BAGALKOT | 220     | NAGJHARI 2-AMBEWADI                 | AMBEWADI_220   | 10:28   | 11:17     | 0:49     | NFBC ISSUED         |
| 406   | 14-Dec-19 | BAGALKOT | 110     | 110/11KV,HV1                        | ANAND NAGAR_110  | 2:55    | 8:17      | 5:22     | TRANSFORMER FAULT   |
| 407   | 14-Dec-19 | BAGALKOT | 110     | 110/11KV,HV1 & HV2                  | ANAND NAGAR_110  | 10:53   | 11:26     | 0:33     | MAIN SUPPLY FAILURE |
| 408   | 14-Dec-19 | BAGALKOT | 110     | ANNIGERI-GADAG                      | ANNIGERI_110   | 12:30   | 12:53     | 0:23     | HAND TRIPPED        |
| 409   | 14-Dec-19 | BAGALKOT | 110     | BIDNAL 220-ANNIGERI                 | ANNIGERI_110   | 11:14   | 12:30     | 1:16     | LINE CLEAR AVAILED  |
| 410   | 14-Dec-19 | BAGALKOT | 110     | 110/11KV ,HV4                       | BAILHONGAL_110   | 12:23   | 13:21     | 0:58     | LINE CLEAR AVAILED  |
| 411   | 14-Dec-19 | BAGALKOT | 220     | BIDNAL-HAVERI                       | BIDNAL_220   | 0:00    | 16:56     | 16:56    | LINE CLEAR AVAILED  |
| 412   | 14-Dec-19 | BAGALKOT | 220     | BIDNAL-NARENDRA                     | BIDNAL_220   | 10:53   | 16:56     | 6:03     | LINE FAULT          |
| 413   | 14-Dec-19 | BAGALKOT | 220     | BIDNAL-NARENDRA                     | BIDNAL_220   | 10:53   | 16:56     | 6:03     | LINE FAULT          |
| 414   | 14-Dec-19 | BAGALKOT | 220     | BIDNAL-HARTI 2                      | BIDNAL_220   | 10:53   | 13:02     | 2:09     | LINE FAULT          |
| 415   | 14-Dec-19 | BAGALKOT | 220     | BIDNAL-HIREBENDIGERI 1& 2           | BIDNAL_220   | 11:14   | 12:03     | 0:49     | HAND TRIPPED        |

| SL no | DATE      | Tr_ZONE  | Voltage | Line/Transformer                 | NAME OF THE STATION   | open_at | Closed_At | Duration | REASON              |
|-------|-----------|----------|---------|----------------------------------|---|---------|-----------|----------|---------------------|
| 416   | 14-Dec-19 | BAGALKOT | 220     | BIDNAL-HUBLI 1&2                 | BIDNAL_220  | 11:14   | 11:42     | 0:28     | HAND TRIPPED        |
| 417   | 14-Dec-19 | BAGALKOT | 220     | BIDNAL-NAGJHARI                  | BIDNAL_220  | 11:14   | 11:53     | 0:39     | HAND TRIPPED        |
| 418   | 14-Dec-19 | BAGALKOT | 220     | BIDNAL-NAGJHARI                  | BIDNAL_220  | 11:53   | 16:45     | 4:52     | LINE FAULT          |
| 419   | 14-Dec-19 | BAGALKOT | 220     | 220/110KV,HV1                    | BIDNAL_220  | 11:14   | 11:43     | 0:29     | HAND TRIPPED        |
| 420   | 14-Dec-19 | BAGALKOT | 110     | 110/11KV ,HV1 & HV2              | BIDNAL_220  | 11:44   | 12:10     | 0:26     | HAND TRIPPED        |
| 421   | 14-Dec-19 | BAGALKOT | 220     | BIDNAL-HARTI 1                   | BIDNAL_220  | 11:14   | 13:02     | 1:48     | LINE CLEAR AVAILED  |
| 422   | 14-Dec-19 | BAGALKOT | 110     | 110/11KV,HV3                     | BIJAPURCITY_110   | 12:27   | 12:29     | 0:02     | HAND TRIPPED        |
| 423   | 14-Dec-19 | BAGALKOT | 110     | BIJAPUR220-BIJAPUR CITY          | BIJAPURCITY_110   | 10:34   | 11:39     | 1:05     | MAIN SUPPLY FAILURE |
| 424   | 14-Dec-19 | BAGALKOT | 110     | BIJAPUR220-BIJAPUR CITY          | BIJAPURCITY_110   | 0:00    | 11:39     | 11:39    | LINE CLEAR AVAILED  |
| 425   | 14-Dec-19 | BAGALKOT | 110     | BIDNAL-GADAG ROAD                | GADAG ROAD_110  | 11:35   | 12:24     | 0:49     | MAIN SUPPLY FAILURE |
| 426   | 14-Dec-19 | BAGALKOT | 220     | DHONI-GADAG 1&2                  | GADAG_220   | 0:00    | 19:54     | 19:54    | LINE CLEAR AVAILED  |
| 427   | 14-Dec-19 | BAGALKOT | 110     | BIDNAL 220-GADAGROAD             | GADAGROAD_110   | 11:14   | 12:17     | 1:03     | LINE CLEAR AVAILED  |
| 428   | 14-Dec-19 | BAGALKOT | 220     | GHATAPRABHA -KUDACHI             | GHATAPRABHA_220   | 20:35   | 23:59     | 3:24     | LINE CLEAR AVAILED  |
| 429   | 14-Dec-19 | BAGALKOT | 110     | GHATAPRABHA-GOKAK                | GOKAK_110   | 11:58   | 17:20     | 5:22     | LINE CLEAR AVAILED  |
| 430   | 14-Dec-19 | BAGALKOT | 110     | BAGALKOT220- GULEDGUDDA          | GULEDGUDDA_110  | 13:33   | 13:46     | 0:13     | LINE FAULT          |
| 431   | 14-Dec-19 | BAGALKOT | 110     | HALYAL-GMR SUGAR                 | HALYAL_110  | 11:28   | 13:47     | 2:19     | LINE CLEAR AVAILED  |
| 432   | 14-Dec-19 | BAGALKOT | 220     | HAVERI-BIDNAL                    | HAVERI_220  | 0:00    | 15:53     | 15:53    | LINE CLEAR AVAILED  |
| 433   | 14-Dec-19 | BAGALKOT | 220     | HAVERI-NARENDRA                  | HAVERI_220  | 13:20   | 14:02     | 0:42     | LINE CLEAR AVAILED  |
| 434   | 14-Dec-19 | BAGALKOT | 220     | NARENDRA2-HUBLI                  | HUBLI_220   | 10:50   | 20:38     | 9:48     | LINE FAULT          |
| 435   | 14-Dec-19 | BAGALKOT | 220     | NARENDRA1-HUBLI                  | HUBLI_220   | 10:51   | 20:39     | 9:48     | LINE FAULT          |
| 436   | 14-Dec-19 | BAGALKOT | 220     | HUBLI-BIDNAL1                    | HUBLI_220   | 11:39   | 11:42     | 0:03     | HAND TRIPPED        |
| 437   | 14-Dec-19 | BAGALKOT | 220     | HUBLI-BIDNAL2                    | HUBLI_220   | 11:39   | 11:43     | 0:04     | HAND TRIPPED        |
| 438   | 14-Dec-19 | BAGALKOT | 220     | NAGJHARI1-HUBLI                  | HUBLI_220   | 11:39   | 11:47     | 0:08     | HAND TRIPPED        |
| 439   | 14-Dec-19 | BAGALKOT | 220     | NAGJHARI2-HUBLI                  | HUBLI_220   | 11:39   | 11:48     | 0:09     | HAND TRIPPED        |
| 440   | 14-Dec-19 | BAGALKOT | 220     | NAGJHARI3-HUBLI                  | HUBLI_220   | 11:39   | 11:50     | 0:11     | HAND TRIPPED        |
| 441   | 14-Dec-19 | BAGALKOT | 220     | HUBLI-SIRSI2                     | HUBLI_220   | 0:00    | 11:39     | 11:39    | LINE CLEAR AVAILED  |
| 442   | 14-Dec-19 | BAGALKOT | 220     | HUBLI-SIRSI1                     | HUBLI_220   | 0:00    | 11:46     | 11:46    | LINE CLEAR AVAILED  |
| 443   | 14-Dec-19 | BAGALKOT | 220     | 220/110KV,HV1,LV1&HV2,LV&HV3,LV3 | HUBLI_220,SIRSI_110,PH<br>COMPOUND_110,KADANKOPPA_11<br>OTARIHAL_110,RAMANKOPPA_110 | 11:39   | 11:53     | 0:14     | HAND TRIPPED        |
| 444   | 14-Dec-19 | BAGALKOT | 110     | 110/11KV,HV2                     | KALGHATAGI_110  | 10:44   | 13:20     | 2:36     | TRANSFORMER FAULT   |
| 445   | 14-Dec-19 | BAGALKOT | 110     | KIADB BIJAPUR-B BAGEWADI 1       | KIADB BIJAPUR_110   | 10:33   | 23:59     | 13:26    | LINE CLEAR AVAILED  |
| 446   | 14-Dec-19 | BAGALKOT | 110     | MUKARTIHAL-MATRIX                | MATRIX_IPP  | 10:25   | 18:40     | 8:15     | LINE CLEAR AVAILED  |
| 447   | 14-Dec-19 | BAGALKOT | 220     | NARENDRA -BIDNAL                 | NARENDRA_220  | 10:53   | 15:18     | 4:25     | LINE FAULT          |
| 448   | 14-Dec-19 | BAGALKOT | 110     | BIDANAL-NAVAGUND                 | NAVAGUND_110  | 11:48   | 18:13     | 6:25     | LINE CLEAR AVAILED  |
| 449   | 14-Dec-19 | BAGALKOT | 110     | BIDNAL 220-NAVALGUND             | NAVALGUND_110   | 11:14   | 12:34     | 1:20     | LINE CLEAR AVAILED  |
| 450   | 14-Dec-19 | BAGALKOT | 110     | BIDNAL 220-PHCOMPOUND            | PHCOMPOUND_110  | 11:14   | 12:27     | 1:13     | LINE CLEAR AVAILED  |
| 451   | 14-Dec-19 | BAGALKOT | 110     | 110/11KV,HV3                     | RATTIHALI_110   | 10:41   | 10:58     | 0:17     | TRANSFORMER FAULT   |

| SL no | DATE      | Tr_ZONE   | Voltage | Line/Transformer            | NAME OF THE STATION   | open_at | Closed_At | Duration | REASON             |
|-------|-----------|-----------|---------|-----------------------------|---|---------|-----------|----------|--------------------|
| 452   | 14-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV3                | RATTIHALLI_110  | 13:02   | 13:14     | 0:12     | TRANSFORMER FAULT  |
| 453   | 14-Dec-19 | BAGALKOT  | 110     | 110/33KV,HV2                | SAVANUR_110,HULAGUR_33KV,BA<br>NKAPUR_33KV,HATTIMATTUR_33K<br>V | 10:35   | 10:43     | 0:08     | TRANSFORMER FAULT  |
| 454   | 14-Dec-19 | BAGALKOT  | 110     | SIRSI220-SIRSI2             | SIRSI_110   | 19:47   | 23:59     | 4:12     | LINE FAULT         |
| 455   | 14-Dec-19 | BAGALKOT  | 220     | SIRSI220-HUBLI1&2           | SIRSI_220   | 20:44   | 23:59     | 3:15     | LINE CLEAR AVAILED |
| 456   | 14-Dec-19 | BAGALKOT  | 220     | 220/110KC,HV1,LV1           | SIRSI_220   | 19:25   | 19:45     | 0:20     | TRANSFORMER FAULT  |
| 457   | 14-Dec-19 | BAGALKOT  | 110     | 110/11KV,HV1                | SOUDATTI_220  | 8:38    | 12:28     | 3:50     | LINE CLEAR AVAILED |
| 458   | 14-Dec-19 | BENGALURU | 220     | HV1                         | NAGNATHPURA 220   | 16:20   | 16:55     | 0:35     | TRANSFORMER FAULT  |
| 459   | 14-Dec-19 | BENGALURU | 220     | HV2                         | NAGNATHPURA 220   | 16:20   | 17:05     | 0:45     | TRANSFORMER FAULT  |
| 460   | 14-Dec-19 | BENGALURU | 66      | HV1                         | NAGNATHPURA 220   | 16:20   | 16:58     | 0:38     | TRANSFORMER FAULT  |
| 461   | 14-Dec-19 | BENGALURU | 66      | HV2                         | ATTUR YELAHANKA   | 5:37    | 5:44      | 0:07     | LOAD CHANGE OVER   |
| 462   | 14-Dec-19 | BENGALURU | 66      | CHIKKENAHALLI - CHANNAPATNA | CHANNAPATNA, SHIVANAHALLI,<br>DASHAWARA, SANKALGERE,<br>BEVOOR  | 14:15   | 14:19     | 0:04     | LINE FAULT         |
| 463   | 14-Dec-19 | BENGALURU | 66      | CHIKKENAHALLI - CHANNAPATNA | CHANNAPATNA, SHIVANAHALLI,<br>DASHAWARA, SANKALGERE,<br>BEVOOR  | 7:02    | 7:07      | 0:05     | LINE FAULT         |
| 464   | 14-Dec-19 | BENGALURU | 66      | SOMANAHALLI 220 - JIGANI 2  | BG ROAD, JIGANI 66, JIGANI LINK<br>ROAD                         | 23:12   | 23:35     | 0:23     | LINE FAULT         |
| 465   | 14-Dec-19 | BENGALURU | 66      | SOMANAHALLI 220 - JIGANI 2  | BG ROAD, JIGANI 66, JIGANI LINK<br>ROAD                         | 23:10   | 23:59     | 0:49     | LINE FAULT         |
| 466   | 14-Dec-19 | BENGALURU | 66      | HBR LAYOUT - DG4            | HBR LAYOUT, BELL CERAMICS (EHT)                                 | 7:20    | 7:25      | 0:05     | LOAD CHANGE OVER   |
| 467   | 14-Dec-19 | BENGALURU | 66      | HOSKOTE 220 - HOSKOTE 2     | HBR LAYOUT, BELL CERAMICS (EHT)                                 | 6:48    | 7:15      | 0:27     | LINE FAULT         |
| 468   | 14-Dec-19 | BENGALURU | 66      | JIGANI 66 - SOMANAHALLI 220 | JIGANI 66   | 23:10   | 23:50     | 0:40     | LINE FAULT         |
| 469   | 14-Dec-19 | GULBARGA  | 220     | LINGAPUR-GADAG2             | LINGAPUR_220  | 10:28   | 15:39     | 5:11     | LINE CLEAR AVAILED |
| 470   | 14-Dec-19 | GULBARGA  | 220     | LINGAPUR-ARRESSSTEEL_IPP    | LINGAPUR_220  | 10:59   | 14:58     | 3:59     | LINE CLEAR AVAILED |
| 471   | 14-Dec-19 | GULBARGA  | 220     | LINGAPUR-GUDADAHALLI1       | LINGAPUR_220  | 11:19   | 19:24     | 8:05     | LINE CLEAR AVAILED |
| 472   | 14-Dec-19 | GULBARGA  | 220     | LINGAPUR-GUDADAHALLI2       | LINGAPUR_220  | 11:20   | 20:18     | 8:58     | LINE CLEAR AVAILED |
| 473   | 14-Dec-19 | GULBARGA  | 110     | HV1                         | CHINCHOLI_110   | 7:50    | 8:32      | 0:42     | LINE CLEAR AVAILED |
| 474   | 14-Dec-19 | GULBARGA  | 110     | HV1                         | SHAHAPUR_220  | 13:05   | 13:38     | 0:33     | TRANSFORMER FAULT  |
| 475   | 14-Dec-19 | GULBARGA  | 66      | ITTAGI-HIREHADAGALI         | HIREHADAGALI_66   | 6:11    | 6:24      | 0:13     | LINE FAULT         |
| 476   | 14-Dec-19 | HASSAN    | 400     | UPCL-HASSAN1                | upcl_gen  | 1:37    | 6:26      | 4:49     | LINE CLEAR AVAILED |
| 477   | 14-Dec-19 | HASSAN    | 400     | UPCL-HASSAN2                | upcl_gen  | 21:25   | 23:59     | 2:34     | LINE CLEAR AVAILED |
| 478   | 14-Dec-19 | HASSAN    | 220     | MRSSHM-VARAH1               | MRSMG_220   | 13:30   | 18:37     | 5:07     | LINE FAULT         |
| 479   | 14-Dec-19 | HASSAN    | 220     | VARAHI-SHIMOGA1             | varahi_gen  | 13:30   | 18:38     | 5:08     | LINE FAULT         |
| 480   | 14-Dec-19 | HASSAN    | 110     | HV2                         | KULASHEKARA_110   | 9:05    | 11:55     | 2:50     | LINE CLEAR AVAILED |

| SL no | DATE      | Tr_ZONE | Voltage | Line/Transformer                              | NAME OF THE STATION  | open_at | Closed_At | Duration | REASON              |
|-------|-----------|---------|---------|---|--|---------|-----------|----------|---------------------|
| 481   | 14-Dec-19 | HASSAN  | 110     | HV1   | MRSMSG_220   | 9:05    | 9:09      | 0:04     | TRANSFORMER FAULT   |
| 482   | 14-Dec-19 | HASSAN  | 110     | HV2   | MRSMSG_220   | 9:04    | 9:09      | 0:05     | TRANSFORMER FAULT   |
| 483   | 14-Dec-19 | HASSAN  | 110     | HV3   | MRSMSG_220   | 9:00    | 9:10      | 0:10     | TRANSFORMER FAULT   |
| 484   | 14-Dec-19 | HASSAN  | 110     | HV4   | MRSMSG_220   | 9:04    | 9:10      | 0:06     | TRANSFORMER FAULT   |
| 485   | 14-Dec-19 | HASSAN  | 66      | MRSSHM-BD-1                                   | MRSMSG_220   | 9:08    | 9:14      | 0:06     | LINE FAULT          |
| 486   | 14-Dec-19 | HASSAN  | 66      | MRSSHM-BD-2                                   | MRSMSG_220   | 9:08    | 9:14      | 0:06     | LINE FAULT          |
| 487   | 14-Dec-19 | HASSAN  | 66      | MRSSHM-DVG2                                   | MRSMSG_220   | 9:07    | 9:12      | 0:05     | LINE FAULT          |
| 488   | 14-Dec-19 | HASSAN  | 66      | MRSSHM-HOLUR                                  | MRSMSG_220   | 9:07    | 9:12      | 0:05     | LINE FAULT          |
| 489   | 14-Dec-19 | HASSAN  | 66      | LV1   | MRSMSG_220   | 9:05    | 9:09      | 0:04     | TRANSFORMER FAULT   |
| 490   | 14-Dec-19 | HASSAN  | 66      | LV2   | MRSMSG_220   | 9:05    | 9:10      | 0:05     | TRANSFORMER FAULT   |
| 491   | 14-Dec-19 | HASSAN  | 66      | LV3   | MRSMSG_220   | 9:04    | 9:10      | 0:06     | TRANSFORMER FAULT   |
| 492   | 14-Dec-19 | HASSAN  | 66      | LV4   | MRSMSG_220   | 9:04    | 9:11      | 0:07     | TRANSFORMER FAULT   |
| 493   | 14-Dec-19 | HASSAN  | 66      | HASSN22-CHIKAMAGLUR2                          | HASSAN_220   | 11:25   | 11:38     | 0:13     | LINE FAULT          |
| 494   | 14-Dec-19 | HASSAN  | 66      | HV1   | DODDAKADANUR_66  | 17:12   | 17:18     | 0:06     | MAIN SUPPLY FAILURE |
| 495   | 14-Dec-19 | HASSAN  | 66      | HNPR2-MYSOR2                                  | HOLENARASIPURA_220   | 17:09   | 17:14     | 0:05     | LINE FAULT          |
| 496   | 14-Dec-19 | HASSAN  | 66      | SAKALE-HANBAL                                 | SAKLESH PURA_66  | 10:13   | 10:28     | 0:15     | LINE FAULT          |
| 497   | 14-Dec-19 | MYSORE  | 66      | HV1   | HDKOTE_66  | 8:51    | 9:24      | 0:33     | LINE CLEAR AVAILED  |
| 498   | 14-Dec-19 | MYSORE  | 66      | KADAKOLA-SARGURU 1                            | ANTHARSANTHE_66,<br>HAMPAPURA(K)_66, HDKOTE_66,<br>JAIPUR_66 | 8:02    | 8:09      | 0:06     | LINE FAULT          |
| 499   | 14-Dec-19 | MYSORE  | 66      | KADAKOLA-MYSORE SOUTH                         | MYSORESOUTH_66   | 18:50   | 23:59     | 5:09     | LINE FAULT          |
| 500   | 14-Dec-19 | MYSORE  | 66      | HV1   | SANTHESARAGUR_66   | 11:52   | 13:27     | 1:34     | LINE CLEAR AVAILED  |
| 501   | 14-Dec-19 | MYSORE  | 66      | HV1   | SANTHESARAGUR_66   | 16:25   | 16:51     | 0:26     | TRANSFORMER FAULT   |
| 502   | 14-Dec-19 | MYSORE  | 66      | HV1   | SFCSHIVA_66  | 9:17    | 10:58     | 1:40     | LINE CLEAR AVAILED  |
| 503   | 14-Dec-19 | MYSORE  | 66      | HV1   | SFCSHIVA_66  | 14:22   | 15:31     | 1:08     | TRANSFORMER FAULT   |
| 504   | 14-Dec-19 | MYSORE  | 66      | TUBINAKERE-G UKKADA                           | GARUDANAUKADDA_66<br>SRIRANGAPATNA_66                        | 2:20    | 2:34      | 0:13     | LINE FAULT          |
| 505   | 14-Dec-19 | TUMKUR  | 110     | TR-1  | TURUVEKERE_110   | 7:28    | 7:45      | 0:17     | MAIN SUPPLY FAILURE |
| 506   | 14-Dec-19 | TUMKUR  | 66      | ANCHEPALYA 220kV- HULIYURDURGA                | HULIYURDURGA_66,<br>CHAWANAKUPPE_66                          | 6:35    | 6:45      | 0:10     | LINE FAULT          |
| 507   | 14-Dec-19 | TUMKUR  | 66      | HONNALLI 220KV- SASUVEHALLI                   | SASUVEHALLI_66,CHANNAGIRI_66                                 | 4:33    | 4:44      | 0:11     | LINE FAULT          |
| 508   | 14-Dec-19 | TUMKUR  | 66      | HONNALLI 220KV- SASUVEHALLI                   | SASUVEHALLI_66,CHANNAGIRI_66                                 | 8:12    | 9:32      | 1:20     | LINE CLEAR AVAILED  |
| 509   | 14-Dec-19 | TUMKUR  | 66      | TR-2  | SAMPIGE_110  | 20:18   | 20:34     | 0:16     | TRANSFORMER FAULT   |
| 510   | 14-Dec-19 | TUMKUR  | 66      | ANTHRASANAHALLI 220KV- KOLALA<br>( dabaspete) | KOLALA_66, URDIGERE_66                                       | 2:40    | 3:37      | 0:56     | LINE FAULT          |
| 511   | 14-Dec-19 | TUMKUR  | 66      | TR-2  | HOSADURGA_66   | 10:13   | 16:51     | 6:38     | LINE CLEAR AVAILED  |
| 512   | 14-Dec-19 | TUMKUR  | 66      | TR-1  | KALAMARANAHALLI_66   | 11:27   | 11:59     | 0:31     | LINE CLEAR AVAILED  |



| SL no | DATE      | Tr_ZONE   | Voltage | Line/Transformer                       | NAME OF THE STATION   | open_at | Closed_At | Duration | REASON              |
|-------|-----------|-----------|---------|--|---|---------|-----------|----------|---------------------|
| 513   | 14-Dec-19 | TUMKUR    | 66      | TR-1                                   | KUNIGAL_66  | 7:57    | 8:06      | 0:09     | TRANSFORMER FAULT   |
| 514   | 14-Dec-19 | TUMKUR    | 66      | THALLAK 220kv- NAYAKANHATTI            | NAYAKANHATTI_66,<br>HIREMALLANAHOLE_66  | 5:50    | 10:07     | 4:17     | LINE CLEAR AVAILED  |
| 515   | 15-Dec-19 | BAGALKOT  | 220     | BELGAUM-NARENDRA1&2                    | BELGAUM_220   | 9:33    | 16:10     | 6:37     | LINE CLEAR AVAILED  |
| 516   | 15-Dec-19 | BAGALKOT  | 220     | 220/110KV, HV2&LV2                     | BELGAUM_220   | 10:52   | 13:44     | 2:52     | LINE CLEAR AVAILED  |
| 517   | 15-Dec-19 | BAGALKOT  | 220     | 220/110KV, HV1&LV1                     | BELGAUM_220, NEHRU<br>NAGAR_110,<br>KANBARGILAYOUT_110,<br>HUDLI_110, VADAGOAN_110,<br>UCHAGOAN_110, UDYAMBAG_110,<br>MACHE_110 | 12:33   | 13:46     | 1:13     | LINE CLEAR AVAILED  |
| 518   | 15-Dec-19 | BAGALKOT  | 220     | GHATAPRABHA -KUDACHI                   | GHATAPRABHA_220   | 0:00    | 8:16      | 8:16     | LINE CLEAR AVAILED  |
| 519   | 15-Dec-19 | BAGALKOT  | 110     | MK HUBLI 220-HIREBAGEWADI              | HIREBAGEWADI_110  | 14:39   | 17:39     | 3:00     | LINE CLEAR AVAILED  |
| 520   | 15-Dec-19 | BAGALKOT  | 110     | KAGAWAD-SHIRAGUPPI SUGARS              | KAGAWAD_110   | 5:26    | 5:32      | 0:06     | LINE FAULT          |
| 521   | 15-Dec-19 | BAGALKOT  | 110     | UGARKHUD-KAGWAD                        | KAGWAD_110  | 5:00    | 5:20      | 0:20     | LINE FAULT          |
| 522   | 15-Dec-19 | BAGALKOT  | 110     | 110/33KV,HV4                           | KANABARGI LAY OUT_110& 33KV<br>KAKATI & SUZLON  | 11:56   | 13:51     | 1:55     | LINE CLEAR AVAILED  |
| 523   | 15-Dec-19 | BAGALKOT  | 110     | KULIGOD-GAMESH                         | KULIGOD_110   | 16:23   | 16:26     | 0:03     | MAIN SUPPLY FAILURE |
| 524   | 15-Dec-19 | BAGALKOT  | 110     | MK HUBLI 220-MK HUBLI 110              | MK HUBLI_110 & KITTUR_33  | 9:06    | 17:31     | 8:25     | LINE CLEAR AVAILED  |
| 525   | 15-Dec-19 | BAGALKOT  | 110     | 220/110KV,LV 2                         | MK HUBLI_220  | 14:42   | 19:13     | 4:31     | LINE CLEAR AVAILED  |
| 526   | 15-Dec-19 | BAGALKOT  | 110     | PGHUNSYAL-NAGANUR,SATTISUGARS          | NAGANUR_110,SATTI SUGAR_IPP   | 16:10   | 16:16     | 0:06     | LINE FAULT          |
| 527   | 15-Dec-19 | BAGALKOT  | 220     | NARENDRA -BELGAUM 1& 2                 | NARENDRA_220  | 9:33    | 16:10     | 6:37     | NFBC ISSUED         |
| 528   | 15-Dec-19 | BAGALKOT  | 110     | SIRSI220-SIRSI2                        | SIRSI_110   | 0:00    | 14:50     | 14:50    | LINE CLEAR AVAILED  |
| 529   | 15-Dec-19 | BAGALKOT  | 110     | UGAR SUGARS-UGARKHUD                   | UGARKHUD_110  | 5:00    | 5:25      | 0:25     | LINE FAULT          |
| 530   | 15-Dec-19 | BAGALKOT  | 110     | BELGAUM220-VADAGOAN                    | VADAGOAN_110  | 11:59   | 14:08     | 2:09     | LINE CLEAR AVAILED  |
| 531   | 15-Dec-19 | BENGALURU | 66      | HV1                                    | CHANDAPURA  | 19:24   | 19:30     | 0:05     | LOAD CHANGE OVER    |
| 532   | 15-Dec-19 | BENGALURU | 66      | HV2                                    | CHANDAPURA  | 19:24   | 19:30     | 0:05     | LOAD CHANGE OVER    |
| 533   | 15-Dec-19 | BENGALURU | 66      | SOMANAHALLI 220 - JIGANI 2             | BG ROAD   | 0:00    | 8:25      | 8:25     | LINE FAULT          |
| 534   | 15-Dec-19 | BENGALURU | 66      | ANEKAL - YERANDANAHALLI 2              | ANEKAL  | 6:50    | 7:01      | 0:11     | LOAD CHANGE OVER    |
| 535   | 15-Dec-19 | BENGALURU | 66      | ANEKAL - ATTIBELE                      | ANEKAL, SURYANAGAR  | 10:06   | 11:35     | 1:29     | MAIN SUPPLY FAILURE |
| 536   | 15-Dec-19 | BENGALURU | 66      | ANEKAL - YERANDANAHALLI 2              | ANEKAL  | 13:22   | 13:47     | 0:25     | LOAD CHANGE OVER    |
| 537   | 15-Dec-19 | BENGALURU | 66      | SURYANAGAR - YERANDANAHALLI 220        | SURYANAGAR  | 6:50    | 7:01      | 0:11     | LOAD CHANGE OVER    |
| 538   | 15-Dec-19 | BENGALURU | 66      | ANEKAL - SURYANAGAR                    | SURYANAGAR  | 13:22   | 13:47     | 0:25     | LOAD CHANGE OVER    |
| 539   | 15-Dec-19 | BENGALURU | 66      | YARANDANAHALLI 220 - ELECTRONIC CITY 2 | BIOCON (EHT), BOMMASANDRA I/A   | 7:05    | 7:15      | 0:10     | LOAD CHANGE OVER    |
| 540   | 15-Dec-19 | BENGALURU | 66      | HV1                                    | YERANDANAHALLI 220  | 7:09    | 8:23      | 1:14     | LINE CLEAR AVAILED  |
| 541   | 15-Dec-19 | BENGALURU | 66      | HV2                                    | YERANDANAHALLI 220  | 7:09    | 8:23      | 1:14     | LINE CLEAR AVAILED  |
| 542   | 15-Dec-19 | BENGALURU | 66      | HV3                                    | YERANDANAHALLI 220  | 7:09    | 8:23      | 1:14     | LINE CLEAR AVAILED  |

| SL no | DATE      | Tr_ZONE   | Voltage | Line/Transformer                     | NAME OF THE STATION                                   | open_at | Closed_At | Duration | REASON              |
|-------|-----------|-----------|---------|--------------------------------------|---|---------|-----------|----------|---------------------|
| 543   | 15-Dec-19 | BENGALURU | 220     | YARANDANAHALLI 220 - SOMANAHALLI 220 | YERANDANAHALLI 220                                    | 7:23    | 8:23      | 1:00     | LINE CLEAR AVAILED  |
| 544   | 15-Dec-19 | BENGALURU | 220     | HV2                                  | YERANDANAHALLI 220                                    | 13:48   | 13:50     | 0:02     | TRANSFORMER FAULT   |
| 545   | 15-Dec-19 | BENGALURU | 220     | SARJAPURA 220 - MALUR 220            | SARJAPURA 220   | 10:03   | 10:22     | 0:19     | MAIN SUPPLY FAILURE |
| 546   | 15-Dec-19 | BENGALURU | 220     | SARJAPURA 220 - MALUR 220            | SARJAPURA 220   | 17:37   | 18:10     | 0:33     | MAIN SUPPLY FAILURE |
| 547   | 15-Dec-19 | BENGALURU | 66      | HOSKOTE 220 - VOLVO                  | VOLVO, NANDAGUDI                                      | 11:00   | 11:58     | 0:58     | LINE CLEAR AVAILED  |
| 548   | 15-Dec-19 | BENGALURU | 66      | HOSKOTE 220 - SULIBELE               | SULIBELE  | 12:54   | 13:08     | 0:14     | LINE FAULT          |
| 549   | 15-Dec-19 | BENGALURU | 66      | JIGANI 220 - JIGANI 66               | JIGANI 66,JIGANI LINK ROAD                            | 5:54    | 6:10      | 0:16     | LINE FAULT          |
| 550   | 15-Dec-19 | BENGALURU | 66      | JIGANI 220 - JIGANI 66               | JIGANI 66,JIGANI LINK ROAD                            | 7:15    | 8:06      | 0:51     | LINE CLEAR AVAILED  |
| 551   | 15-Dec-19 | BENGALURU | 66      | JIGANI 220 - JIGANI 66               | JIGANI 66   | 11:40   | 13:15     | 1:35     | LINE CLEAR AVAILED  |
| 552   | 15-Dec-19 | BENGALURU | 66      | JIGANI LINK ROAD - SOMANAHALLI 220   | JIGANI LINK ROAD                                      | 11:40   | 12:25     | 0:45     | LOAD CHANGE OVER    |
| 553   | 15-Dec-19 | BENGALURU | 66      | KANAKAPURA 220 - SOMANAHALLI 1       | CHATRA, MARALWADI,<br>HANUMANTHNAGAR, YEDUMADU        | 8:54    | 9:12      | 0:18     | LINE FAULT          |
| 554   | 15-Dec-19 | BENGALURU | 66      | KANAKAPURA 220 - SOMANAHALLI 1       | CHATRA, MARALWADI,<br>HANUMANTHNAGAR, YEDUMADU        | 9:41    | 9:54      | 0:13     | LINE FAULT          |
| 555   | 15-Dec-19 | BENGALURU | 220     | KOLAR 220 - PGCIL 1                  | KOLAR 220   | 10:39   | 17:22     | 6:43     | LINE CLEAR AVAILED  |
| 556   | 15-Dec-19 | BENGALURU | 220     | KOLAR 220 - PGCIL 2                  | KOLAR 220   | 10:39   | 17:22     | 6:43     | LINE CLEAR AVAILED  |
| 557   | 15-Dec-19 | BENGALURU | 66      | KOLAR 220 - NANGLI                   | KEMBODI, MUDIYANUR, H<br>GOLLAHALLI, BAIRAKUR, NANGLI | 9:44    | 18:15     | 8:31     | LINE CLEAR AVAILED  |
| 558   | 15-Dec-19 | BENGALURU | 66      | KOLAR 220 - VOKKALERI                | VOKKALERI   | 9:44    | 18:15     | 8:31     | LINE CLEAR AVAILED  |
| 559   | 15-Dec-19 | BENGALURU | 66      | KOLAR 220 - SRINIVASPURA             | DRDO(EHT), MALLASANDRA,<br>DALASANUR, YELDUR          | 9:44    | 18:15     | 8:31     | LINE CLEAR AVAILED  |
| 560   | 15-Dec-19 | BENGALURU | 66      | KOLAR 220 - PGCIL                    | PGCIL, SUGATUR, SM MANGALA                            | 9:44    | 18:15     | 8:31     | LINE CLEAR AVAILED  |
| 561   | 15-Dec-19 | BENGALURU | 66      | KOLAR 220 - NARASAPURA 1             | NARASAPURA  | 9:44    | 18:15     | 8:31     | LINE CLEAR AVAILED  |
| 562   | 15-Dec-19 | BENGALURU | 66      | KOLAR 220 - BANGARPET 1              | BANGARPET   | 9:44    | 18:15     | 8:31     | LINE CLEAR AVAILED  |
| 563   | 15-Dec-19 | BENGALURU | 66      | KOLAR 220 - THAYLUR                  | THAYALUR, TAMAKA, NG HULKUR,<br>MALLANAYAKANAHALLI    | 9:44    | 18:15     | 8:31     | LINE CLEAR AVAILED  |
| 564   | 15-Dec-19 | BENGALURU | 66      | KOLAR 220 - MULBAGAL                 | AVANI, MULBAGAL                                       | 9:44    | 18:15     | 8:31     | LINE CLEAR AVAILED  |
| 565   | 15-Dec-19 | BENGALURU | 66      | KOLAR 220 - VEMGAL                   | VEMGAL, KYALANUR                                      | 9:44    | 18:15     | 8:31     | LINE CLEAR AVAILED  |
| 566   | 15-Dec-19 | GULBARGA  | 220     | LINGAPUR-GUDADAHALLI2                | LINGAPUR_220  | 11:03   | 12:02     | 0:59     | LINE CLEAR AVAILED  |
| 567   | 15-Dec-19 | GULBARGA  | 110     | HV2                                  | BELLARYSOUTH_110                                      | 9:24    | 17:47     | 8:23     | LINE CLEAR AVAILED  |
| 568   | 15-Dec-19 | GULBARGA  | 110     | ALIPUR-BELLARYSOUTH                  | BELLARYSOUTH_110,HALKUNDI_110                         | 11:05   | 11:52     | 0:47     | LINE CLEAR AVAILED  |
| 569   | 15-Dec-19 | GULBARGA  | 110     | GADAG-BETAGERA                       | BETAGERA_110  | 6:25    | 6:31      | 0:06     | LINE FAULT          |
| 570   | 15-Dec-19 | GULBARGA  | 110     | HUMNABAD-DUBALGUNDI                  | DUBALGUNDI_110  | 15:30   | 16:15     | 0:45     | LINE FAULT          |

| SL no | DATE      | Tr_ZONE  | Voltage | Line/Transformer              | NAME OF THE STATION  | open_at | Closed_At | Duration | REASON              |
|-------|-----------|----------|---------|-------------------------------|--|---------|-----------|----------|---------------------|
| 571   | 15-Dec-19 | HASSAN   | 400     | UPCL-HASSAN2                  | upcl_gen   | 0:00    | 7:08      | 7:08     | LINE CLEAR AVAILED  |
| 572   | 15-Dec-19 | HASSAN   | 400     | UPCL-HASSAN2                  | upcl_gen   | 21:11   | 23:59     | 2:48     | LINE CLEAR AVAILED  |
| 573   | 15-Dec-19 | HASSAN   | 110     | HV1                           | BAIKAMPADI_110   | 6:30    | 16:58     | 10:28    | MAIN SUPPLY FAILURE |
| 574   | 15-Dec-19 | HASSAN   | 110     | HV2                           | BAIKAMPADI_110   | 6:30    | 16:58     | 10:28    | MAIN SUPPLY FAILURE |
| 575   | 15-Dec-19 | HASSAN   | 110     | HV3                           | BAIKAMPADI_110   | 6:30    | 16:58     | 10:28    | MAIN SUPPLY FAILURE |
| 576   | 15-Dec-19 | HASSAN   | 110     | HV4                           | BAIKAMPADI_110   | 6:30    | 16:58     | 10:28    | MAIN SUPPLY FAILURE |
| 577   | 15-Dec-19 | HASSAN   | 110     | BANTWA-SALATTUR               | BANTWAL_110  | 1:38    | 6:27      | 4:49     | LINE FAULT          |
| 578   | 15-Dec-19 | HASSAN   | 110     | KAVOOR-MCFLine                | KAVOOR_220   | 6:29    | 16:55     | 10:26    | LINE CLEAR AVAILED  |
| 579   | 15-Dec-19 | HASSAN   | 110     | NERALA-TEREKERE               | NERALAKERE_110   | 14:53   | 16:44     | 1:51     | LINE FAULT          |
| 580   | 15-Dec-19 | HASSAN   | 110     | SHIVAPU-NERALEKERE            | SHIVPURA_110   | 14:33   | 14:51     | 0:18     | LINE FAULT          |
| 581   | 15-Dec-19 | HASSAN   | 66      | MRSSHM-DVG2                   | MRSMG_220  | 11:29   | 12:11     | 0:42     | LINE FAULT          |
| 582   | 15-Dec-19 | HASSAN   | 66      | HASSN22-SAKLESH PURA2         | HASSAN_220   | 6:28    | 6:44      | 0:16     | LINE FAULT          |
| 583   | 15-Dec-19 | HASSAN   | 66      | HV2                           | HNPURA_66  | 13:34   | 16:32     | 2:58     | LINE CLEAR AVAILED  |
| 584   | 15-Dec-19 | HASSAN   | 66      | HV2                           | HNPURA_66  | 16:32   | 17:00     | 0:28     | LINE CLEAR AVAILED  |
| 585   | 15-Dec-19 | HASSAN   | 66      | SIGEBAG-KDLGRE                | SIGEBAGI_66  | 12:10   | 12:15     | 0:05     | MAIN SUPPLY FAILURE |
| 586   | 15-Dec-19 | MYSORE   | 66      | CR NAGARA-YELANDUR            | YELANDUR_66  | 6:28    | 0:00      | 17:31    | LINE FAULT          |
| 587   | 15-Dec-19 | MYSORE   | 66      | KADAKOLA-SARGURU 2            | B MATKERE_66 HULLAHALLI_66<br>DOORA_66 CHANDAKAVADI_66<br>HURA_66 SANTHESARAGUR_66                                     | 6:07    | 6:12      | 0:04     | LINE FAULT          |
| 588   | 15-Dec-19 | MYSORE   | 66      | HV1                           | KIADBMANDYA_66   | 9:44    | 17:37     | 7:52     | LINE CLEAR AVAILED  |
| 589   | 15-Dec-19 | MYSORE   | 66      | HV2                           | KIADBMANDYA_66   | 9:44    | 17:37     | 7:52     | LINE CLEAR AVAILED  |
| 590   | 15-Dec-19 | MYSORE   | 66      | KIADB MANDYA-TUMBEKERE        | TUMBEKERE_66   | 9:33    | 17:51     | 8:18     | NFBC ISSUED         |
| 591   | 15-Dec-19 | MYSORE   | 66      | TUBINAKERE-NAGAMANGALA 1      | ADDIHALI_66<br>ADICHUNCHANAGIRI_66<br>BASARALU_66<br>HARADANAHALLI(JAK)_66<br>BGNAGARA_66 KESLAGERE_66<br>VADERALLI_66 | 18:15   | 18:21     | 0:05     | LINE FAULT          |
| 592   | 15-Dec-19 | TUMKUR   | 66      | ANTHRASANAHALLI 220KV- CHELUR | CHELURU_66, HOSAKERE_66,<br>ANKASANDRA_66  | 6:53    | 7:05      | 0:12     | LINE FAULT          |
| 593   | 15-Dec-19 | TUMKUR   | 66      | TR-1                          | CHANNAGIRI_66  | 7:50    | 7:57      | 0:07     | TRANSFORMER FAULT   |
| 594   | 15-Dec-19 | TUMKUR   | 66      | CHELLUR-ANTHRASANAHALLI       | CHELURU_66   | 6:56    | 7:06      | 0:10     | LINE FAULT          |
| 595   | 15-Dec-19 | TUMKUR   | 66      | HONNALLI 220KV- KUNDUR        | KUNDUR_66,MALEBENNUR_66  | 10:59   | 11:08     | 0:09     | LINE FAULT          |
| 596   | 15-Dec-19 | TUMKUR   | 66      | MADHUGIRI 220KV- KORATAGERE 2 | KORATAGERE_66,<br>CHIKKATOTLUKERE_66,<br>BELADARA_66   | 6:30    | 6:44      | 0:14     | LINE FAULT          |
| 597   | 15-Dec-19 | TUMKUR   | 66      | THALLAK 220kv- NAYAKANHATTI   | NAYAKANHATTI_66,<br>HIREMALLANAHOLE_66   | 5:50    | 9:35      | 3:45     | LINE CLEAR AVAILED  |
| 598   | 16-Dec-19 | BAGALKOT | 110     | TADASINAKOPPA-TARIHAL         | TARIHAL_110  | 12:45   | 12:58     | 0:13     | HAND TRIPPED        |

| SL no | DATE      | Tr_ZONE  | Voltage | Line/Transformer          | NAME OF THE STATION          | open_at | Closed_At | Duration | REASON             |
|-------|-----------|----------|---------|---------------------------|------------------------------|---------|-----------|----------|--------------------|
| 599   | 16-Dec-19 | BAGALKOT | 110     | TADASINKOPPA-TARIHAL      | TARIHAL_110                  | 17:17   | 17:19     | 0:02     | HAND TRIPPED       |
| 600   | 16-Dec-19 | BAGALKOT | 110     | SOUDATTI220-UDIKERI       | UDIKERI_110                  | 12:34   | 18:27     | 5:53     | LINE CLEAR AVAILED |
| 601   | 16-Dec-19 | BAGALKOT | 110     | MMCL-SOUDATTI             | SOUDATTI_220                 | 15:08   | 15:29     | 0:21     | LINE FAULT         |
| 602   | 16-Dec-19 | BAGALKOT | 110     | 110/11KV,HV4              | SADALAGA_110                 | 12:34   | 17:47     | 5:13     | TRANSFORMER FAULT  |
| 603   | 16-Dec-19 | BAGALKOT | 110     | 110/11KV,HV2              | MUKARTHAL_110                | 18:11   | 23:59     | 5:48     | LINE CLEAR AVAILED |
| 604   | 16-Dec-19 | BAGALKOT | 110     | 110/11KV,HV1              | LAKAMANAHALLI_110            | 10:24   | 15:05     | 4:41     | LINE CLEAR AVAILED |
| 605   | 16-Dec-19 | BAGALKOT | 110     | 110/11KV,HV2              | LAKAMANAHALLI_110            | 10:24   | 16:15     | 5:51     | LINE CLEAR AVAILED |
| 606   | 16-Dec-19 | BAGALKOT | 110     | 110/33KV,HV4              | LAKAMANAHALLI_110,ALNAVAR_33 | 11:14   | 18:14     | 7:00     | LINE CLEAR AVAILED |
| 607   | 16-Dec-19 | BAGALKOT | 110     | KUD DHARWAD-LAKAMANAHALLI | LAKAMANAHALLI_110            | 13:15   | 13:58     | 0:43     | LINE CLEAR AVAILED |
| 608   | 16-Dec-19 | BAGALKOT | 220     | NAGJHARI1-AMBEWADI        | AMBEWADI_220                 | 10:24   | 13:26     | 3:02     | LINE CLEAR AVAILED |
| 609   | 16-Dec-19 | BAGALKOT | 220     | NAGJHARI2-AMBEWADI        | AMBEWADI_220                 | 10:23   | 13:29     | 3:06     | LINE CLEAR AVAILED |
| 610   | 16-Dec-19 | BAGALKOT | 220     | 220/110KV, HV1 & LV1      | BELGAUM_220                  | 10:00   | 23:59     | 13:59    | LINE CLEAR AVAILED |
| 611   | 16-Dec-19 | BAGALKOT | 110     | GADAG220-DAMBAL           | DAMBAL_110                   | 15:07   | 15:40     | 0:33     | LINE FAULT         |
| 612   | 16-Dec-19 | BAGALKOT | 110     | GADAG220-SAMBAPUR ROAD    | SAMBAPUR ROAD_110            | 15:07   | 15:46     | 0:39     | LINE FAULT         |
| 613   | 16-Dec-19 | BAGALKOT | 110     | 110/11KV, HV2             | GOPPANAKOPPA_110             | 11:10   | 18:51     | 7:41     | LINE CLEAR AVAILED |
| 614   | 16-Dec-19 | BAGALKOT | 110     | SUZLON1&2-DAMBAL          | DAMBAL_110                   | 16:06   | 16:13     | 0:07     | HAND TRIPPED       |
| 615   | 16-Dec-19 | BAGALKOT | 110     | DAMBAL-EILS               | DAMBAL_110                   | 16:06   | 16:14     | 0:08     | HAND TRIPPED       |
| 616   | 16-Dec-19 | GULBARGA | 220     | LINGASUGUR-SINDHANOOR     | SINDHANOOR_220               | 12:25   | 16:42     | 4:17     | LINE CLEAR AVAILED |
| 617   | 16-Dec-19 | GULBARGA | 110     | HV1                       | HUMNABAD_220                 | 14:58   | 17:45     | 2:47     | LINE CLEAR AVAILED |
| 618   | 16-Dec-19 | GULBARGA | 110     | HV2                       | BEVOOR_110                   | 16:05   | 16:35     | 0:30     | LINE CLEAR AVAILED |
| 619   | 16-Dec-19 | GULBARGA | 110     | SINDHANOOR-MUNIRABAD2     | MUNIRABAD_220                | 0:35    | 0:47      | 0:12     | LINE FAULT         |
| 620   | 16-Dec-19 | GULBARGA | 110     | HALBARGA-ACME SOLAR       | HALBARGA_220                 | 18:08   | 19:22     | 1:14     | LINE CLEAR AVAILED |
| 621   | 16-Dec-19 | GULBARGA | 220     | LINGASUGUR-SINDHANOOR     | SINDHANOOR_220               | 12:25   | 16:42     | 4:17     | LINE CLEAR AVAILED |
| 622   | 16-Dec-19 | GULBARGA | 110     | HV1                       | HUMNABAD_220                 | 14:58   | 17:45     | 2:47     | LINE CLEAR AVAILED |
| 623   | 16-Dec-19 | GULBARGA | 110     | HV2                       | BEVOOR_110                   | 16:05   | 16:35     | 0:30     | LINE CLEAR AVAILED |
| 624   | 16-Dec-19 | GULBARGA | 110     | SINDHANOOR-MUNIRABAD2     | MUNIRABAD_220                | 0:35    | 0:47      | 0:12     | LINE FAULT         |
| 625   | 16-Dec-19 | GULBARGA | 110     | HALBARGA-ACME SOLAR       | HALBARGA_220                 | 18:08   | 19:22     | 1:14     | LINE CLEAR AVAILED |
| 626   | 16-Dec-19 | HASSAN   | 400     | UPCL-HASSAN2              | upcl_gen                     | 0:00    | 6:13      | 6:13     | LINE CLEAR AVAILED |
| 627   | 16-Dec-19 | HASSAN   | 220     | MRSSHM-VARAH13            | MRSMG_220                    | 9:30    | 12:29     | 2:59     | LINE CLEAR AVAILED |
| 628   | 16-Dec-19 | HASSAN   | 220     | VARAHI-SHMG3              | varahi_gen                   | 9:30    | 12:29     | 2:59     | LINE CLEAR AVAILED |
| 629   | 16-Dec-19 | HASSAN   | 110     | HV4                       | BAIKAMPADI_110               | 2:15    | 3:55      | 1:40     | TRANSFORMER FAULT  |
| 630   | 16-Dec-19 | HASSAN   | 110     | BANTWA-SALATTUR           | BANTWAL_110                  | 15:26   | 17:13     | 1:47     | LINE CLEAR AVAILED |
| 631   | 16-Dec-19 | HASSAN   | 110     | MANIPAL-BRAMVR            | MANIPAL_110                  | 8:04    | 8:35      | 0:31     | HAND TRIPPED       |
| 632   | 16-Dec-19 | HASSAN   | 110     | MANIPAL-BRAMVR            | MANIPAL_110                  | 9:07    | 9:09      | 0:02     | HAND TRIPPED       |
| 633   | 16-Dec-19 | HASSAN   | 110     | HV2                       | SORABA_110                   | 15:50   | 16:25     | 0:35     | LINE CLEAR AVAILED |
| 634   | 16-Dec-19 | HASSAN   | 110     | HV2                       | BRAHMAVARA_110               | 3:41    | 8:40      | 4:59     | TRANSFORMER FAULT  |
| 635   | 16-Dec-19 | HASSAN   | 110     | HV2                       | BRAHMAVARA_110               | 8:59    | 9:07      | 0:08     | TRANSFORMER FAULT  |
| 636   | 16-Dec-19 | HASSAN   | 66      | HV2                       | HOLALUR_66                   | 10:52   | 10:59     | 0:07     | HAND TRIPPED       |

| SL no | DATE      | Tr_ZONE | Voltage | Line/Transformer           | NAME OF THE STATION | open_at | Closed_At | Duration | REASON             |
|-------|-----------|---------|---------|----------------------------|---------------------|---------|-----------|----------|--------------------|
| 637   | 16-Dec-19 | HASSAN  | 66      | SAKALE-HANBAL              | SAKLESH PURA_66     | 22:27   | 22:38     | 0:11     | LINE FAULT         |
| 638   | 16-Dec-19 | MYSORE  | 66      | HV2                        | CHANDAKAVADI_66     | 14:38   | 14:54     | 0:15     | TRANSFORMER FAULT  |
| 639   | 16-Dec-19 | MYSORE  | 66      | HV1                        | DUNDANAHALLI_66     | 15:36   | 15:45     | 0:09     | TRANSFORMER FAULT  |
| 640   | 16-Dec-19 | MYSORE  | 220     | HV2                        | HOOTAGALLY_220      | 9:58    | 12:53     | 2:55     | LINE CLEAR AVAILED |
| 641   | 16-Dec-19 | MYSORE  | 66      | HV1                        | MADDUR_66           | 15:00   | 16:07     | 1:07     | LINE CLEAR AVAILED |
| 642   | 16-Dec-19 | MYSORE  | 66      | MADHUVANAHALLI-PG PALYA    | PGPALYA_66          | 14:04   | 15:30     | 1:26     | LINE CLEAR AVAILED |
| 643   | 16-Dec-19 | MYSORE  | 66      | SANTHE SARAGURU-B MATTGERE | B MATKERE_66        | 10:16   | 18:29     | 8:13     | NFBC ISSUED        |
| 644   | 16-Dec-19 | MYSORE  | 66      | HV1                        | SANTHESARAGUR_66    | 12:35   | 12:45     | 0:10     | TRANSFORMER FAULT  |
| 645   | 16-Dec-19 | MYSORE  | 66      | HV1                        | SANTHESARAGUR_66    | 12:58   | 13:44     | 0:46     | TRANSFORMER FAULT  |
| 646   | 16-Dec-19 | MYSORE  | 66      | HV1                        | SANTHESARAGUR_66    | 13:55   | 14:00     | 0:05     | TRANSFORMER FAULT  |