

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM:24.03.2020 TO 30.03.2020**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
1	24-Mar-20	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110	14:13	14:40	0:27	LINE FAULT
2	24-Mar-20	BAGALKOT	110	110/11KV,HV1	ANANDNAGAR_110	16:05	16:43	0:38	TRANSFORMER FAULT
3	24-Mar-20	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	0:00	13:46	13:46	LINE CLEAR AVAILED
4	24-Mar-20	BAGALKOT	110	BIDNAL-GADAG	GADAG_110	0:00	14:43	14:43	LINE CLEAR AVAILED
5	24-Mar-20	BAGALKOT	110	110/33KV,HV 2	HUNGUND_110 &33KV AMINAGAD,KARADI	12:25	12:29	0:04	TRANSFORMER FAULT
6	24-Mar-20	BAGALKOT	110	110/11KV,HV2	ITANAL_110	19:20	19:35	0:15	TRANSFORMER FAULT
7	24-Mar-20	BAGALKOT	110	110/11KV,HV 2	ITANAL_110	22:13	22:22	0:09	TRANSFORMER FAULT
8	24-Mar-20	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	16:08	16:29	0:21	LINE FAULT
9	24-Mar-20	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	16:17	19:56	3:39	LINE FAULT
10	24-Mar-20	BAGALKOT	220	BELGAUM-KANABARGI 1	BELGAUM_220	16:36	18:48	2:12	LINE FAULT
11	24-Mar-20	BAGALKOT	110	110/33KV,HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	8:10	8:41	0:31	TRANSFORMER FAULT
12	24-Mar-20	BAGALKOT	110	GAMESH-RON	RON_110	21:45	22:08	0:23	HAND TRIPPED
13	24-Mar-20	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	21:47	23:59	2:12	LINE FAULT
14	24-Mar-20	BAGALKOT	110	NAREGAL-RON	RON_110	21:53	22:15	0:22	LINE CLEAR AVAILED
15	24-Mar-20	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	21:47	22:15	0:28	TRANSFORMER FAULT
16	24-Mar-20	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	11:44	11:52	0:08	TRANSFORMER FAULT
17	24-Mar-20	BAGALKOT	220	220/110KV, HV1&LV1	KUDACHI_220, UGARKHUD_110	14:31	14:49	0:18	TRANSFORMER FAULT
18	24-Mar-20	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	0:00	11:38	11:38	LINE CLEAR AVAILED
19	24-Mar-20	BENGALURU	66	HV2	BTM 4TH PHASE	18:42	18:49	0:07	TRANSFORMER FAULT
20	24-Mar-20	BENGALURU	66	BANGARPETE - KOLAR 220	BANGARPETE	10:35	12:30	1:55	LINE CLEAR AVAILED
21	24-Mar-20	BENGALURU	66	CHINTAMANI 66 - CHINTAMANI 220	CHINTAMANI 66	11:24	11:32	0:08	LINE CLEAR AVAILED
22	24-Mar-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	11:36	13:04	1:28	LINE CLEAR AVAILED
23	24-Mar-20	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	18:21	18:30	0:09	LINE FAULT
24	24-Mar-20	BENGALURU	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	18:21	18:38	0:17	LINE FAULT
25	24-Mar-20	BENGALURU	66	HV1	MUDIYANUR	18:55	19:10	0:15	TRANSFORMER FAULT
26	24-Mar-20	BENGALURU	66	HV1	MUDIYANUR	19:10	19:20	0:10	TRANSFORMER FAULT
27	24-Mar-20	BENGALURU	66	HV2	TEKAL	11:15	11:31	0:16	LINE CLEAR AVAILED
28	24-Mar-20	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	11:18	13:01	1:43	LINE CLEAR AVAILED
29	24-Mar-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110 ,SAIDAPUR_110,CORE GREEN SUGAR_IPP,SANNATHI_IPP	3:31	3:42	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
30	24-Mar-20	GULBARGA	110	SHAHAPUR-KEMBHANI	KEMBHAVI_110,UGARSUGAR_IPP	6:48	6:52	0:04	LINE FAULT
31	24-Mar-20	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110,GANGAVATHI_110,V ENKATAGIRI_110	9:38	9:55	0:17	LINE FAULT
32	24-Mar-20	HASSAN	220	ARSK2-NITTUR	ARASIKERE_220	15:30	17:19	1:49	LINE FAULT
33	24-Mar-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:27	11:39	1:12	LINE CLEAR AVAILED
34	24-Mar-20	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	19:45	23:59	4:14	LINE CLEAR AVAILED
35	24-Mar-20	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	0:00	9:53	9:53	LINE CLEAR AVAILED
36	24-Mar-20	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:28	11:40	1:12	LINE CLEAR AVAILED
37	24-Mar-20	HASSAN	220	VARAHI-SHMG3	varahi_gen	19:08	23:22	4:14	LINE FAULT
38	24-Mar-20	HASSAN	110	MRSSHM-VARAH13	MRSMSG_220	19:07	23:23	4:16	LINE FAULT
39	24-Mar-20	HASSAN	110	HV1	KULASHEKARA_110	4:24	4:35	0:11	TRANSFORMER FAULT
40	24-Mar-20	HASSAN	66	HASSN22-ARAKALGUD1	HASSAN_220	17:49	18:00	0:11	LINE FAULT
41	24-Mar-20	HASSAN	66	HASSN22-HSN66	HASSAN_220	7:28	8:33	1:05	LINE CLEAR AVAILED
42	24-Mar-20	HASSAN	66	HASSN22-SKPURA	HASSAN_220	7:29	7:58	0:29	LINE CLEAR AVAILED
43	24-Mar-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	13:04	13:11	0:07	LINE FAULT
44	24-Mar-20	HASSAN	66	HV1	DUDDA_66	15:10	15:32	0:22	TRANSFORMER FAULT
45	24-Mar-20	HASSAN	66	HV1	MAGGE_66	9:00	9:10	0:10	TRANSFORMER FAULT
46	24-Mar-20	HASSAN	66	HV1	MAGGE_66	16:13	16:26	0:13	TRANSFORMER FAULT
47	24-Mar-20	HASSAN	66	SAKALE-HASSAN1	SAKLESH PURA_66	7:53	8:07	0:14	HAND TRIPPED
48	24-Mar-20	MYSORE	66	HV 2	KRPET_220	9:50	10:00	0:10	TRANSFORMER FAULT
49	24-Mar-20	MYSORE	66	HV 2	KRPET_220	10:52	11:03	0:11	TRANSFORMER FAULT
50	24-Mar-20	MYSORE	66	HV 2	KRPET_220	11:03	11:10	0:07	TRANSFORMER FAULT
51	24-Mar-20	MYSORE	66	HV 2	KRPET_220	11:52	12:00	0:07	TRANSFORMER FAULT
52	24-Mar-20	MYSORE	66	HUNSUR-HOOTAGALLI	HOSURGATE_66 BANNIKUPPE_66	7:35	7:51	0:16	LINE FAULT
53	24-Mar-20	MYSORE	66	KUSHAL22-RAMANTHAPURA1	ALUR SIDDAPUR_66	17:59	18:11	0:12	LINE FAULT
54	24-Mar-20	MYSORE	66	HV1	NANJANGUDU_66	12:14	12:29	0:15	TRANSFORMER FAULT
55	24-Mar-20	MYSORE	66	HV1	TARIPURA_66	12:27	13:25	0:57	TRANSFORMER FAULT
56	24-Mar-20	MYSORE	66	HV1	TARIPURA_66	15:07	15:35	0:28	LINE CLEAR AVAILED
57	24-Mar-20	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	6:40	6:52	0:12	LINE FAULT
58	24-Mar-20	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	14:58	15:09	0:10	MAIN SUPPLY FAILURE
59	24-Mar-20	TUMKUR	66	TR-1	HIRIYUR_66	10:46	10:54	0:07	LINE CLEAR AVAILED
60	24-Mar-20	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	6:26	6:52	0:25	LINE FAULT
61	24-Mar-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	19:25	19:37	0:11	LINE FAULT
62	24-Mar-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	14:58	15:09	0:11	LINE FAULT
63	24-Mar-20	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	11:59	12:10	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
64	24-Mar-20	TUMKUR	66	KUKKAWADA-LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	4:54	5:08	0:14	LINE FAULT
65	24-Mar-20	TUMKUR	66	TR-2	LINGDHALLI_66	8:03	8:10	0:06	TRANSFORMER FAULT
66	24-Mar-20	TUMKUR	66	MADHUGIRI 220-KALLAMBELLA	KALLAMBELLA_66, SIRA_66	16:16	16:39	0:22	MAIN SUPPLY FAILURE
67	24-Mar-20	TUMKUR	66	MADHUGIRI 220kV-PULAMAGATTA	PULAMG_66	16:16	16:26	0:09	MAIN SUPPLY FAILURE
68	24-Mar-20	TUMKUR	66	NAGASAMUDRA-RAMPURA	NAGASAMUDRA_66, RAMPURA_66	6:51	7:22	0:30	HAND TRIPPED
69	24-Mar-20	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	18:39	18:46	0:07	LINE FAULT
70	24-Mar-20	TUMKUR	66	PAVAGADA 220-MEDIGESHI	HOSAKERE_66 , MEDIGESHI_66	10:34	16:24	5:50	LINE CLEAR AVOIDED
71	24-Mar-20	TUMKUR	66	TR-1	THIMMASANDRA_66	10:25	10:27	0:01	TRANSFORMER FAULT
72	24-Mar-20	TUMKUR	110	TR-1	NITTUR_220	18:51	23:59	5:07	LINE CLEAR AVOIDED
73	24-Mar-20	TUMKUR	220	HIRIYUR 220KV- ENERCON	ENERCON_IPP_220	13:44	14:21	0:37	LINE FAULT
74	24-Mar-20	TUMKUR	220	TR-1(220kV)	MADHUGIRI_220	13:56	15:20	1:23	TRANSFORMER FAULT
75	25-Mar-20	BAGALKOT	110	110/11KV,HV1	ANNIGERI_110	12:25	13:40	1:15	LINE CLEAR AVOIDED
76	25-Mar-20	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	5:50	6:09	0:19	LINE FAULT
77	25-Mar-20	BAGALKOT	110	BAGALKOT-NEERBUDIHAL	NEERBUDIHAL_110	19:21	22:36	3:15	LINE FAULT
78	25-Mar-20	BAGALKOT	110	110/33KV,HV4	ZALKI_110	12:00	12:19	0:19	TRANSFORMER FAULT
79	25-Mar-20	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	18:03	18:39	0:36	TRANSFORMER FAULT
80	25-Mar-20	BAGALKOT	110	NAREGAL-RON	NAREGAL_110	7:44	8:05	0:21	LINE CLEAR AVOIDED
81	25-Mar-20	BAGALKOT	110	110/11KV,HV1	MUKARTIHAL_110	18:12	18:40	0:28	LINE CLEAR AVOIDED
82	25-Mar-20	BAGALKOT	110	MKHUBLI220-BEDI	BEDI_110	16:55	17:56	1:01	LINE FAULT
83	25-Mar-20	BAGALKOT	110	110/11KV,HV1	MKHUBLI_110	16:48	17:56	1:08	TRANSFORMER FAULT
84	25-Mar-20	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	0:00	1:56	1:56	LINE CLEAR AVOIDED
85	25-Mar-20	BAGALKOT	110	KERUR-BADAMI	BADAMI_110	5:51	10:35	4:44	LINE FAULT
86	25-Mar-20	BAGALKOT	110	110/11KV,HV1	SIRSI_110	15:50	16:16	0:26	TRANSFORMER FAULT
87	25-Mar-20	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-2	8:23	8:33	0:10	TRANSFORMER FAULT
88	25-Mar-20	BENGALURU	66	HV2	EPIP 220	23:37	23:58	0:21	TRANSFORMER FAULT
89	25-Mar-20	BENGALURU	66	HV2	KADUBISANAHALLI	8:00	8:25	0:25	TRANSFORMER FAULT
90	25-Mar-20	BENGALURU	66	HV1	KADUBISANAHALLI	7:35	8:00	0:25	TRANSFORMER FAULT
91	25-Mar-20	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	17:54	18:09	0:15	LINE FAULT
92	25-Mar-20	BENGALURU	66	HV1	VOLVO	16:09	16:47	0:38	TRANSFORMER FAULT
93	25-Mar-20	GULBARGA	220	LINGAPUR-BTPS	BTPS_220,ALIPUR_220	13:53	14:32	0:39	LINE FAULT
94	25-Mar-20	GULBARGA	110	GULBARGA UNIVERSITY-SHAHABAD	GULBARGAUNIVERSITY_110	10:35	23:59	13:24	NFBC ISSUED
95	25-Mar-20	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110	12:12	13:10	0:58	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
96	25-Mar-20	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110,GANGAVATHI_110,VENKATAGIRI_110	9:38	9:55	0:17	LINE FAULT
97	25-Mar-20	GULBARGA	66	HV1	TAMBRAHALLI_66	11:15	11:35	0:20	TRANSFORMER FAULT
98	25-Mar-20	GULBARGA	66	HV2	TAMBRAHALLI_66	18:25	18:35	0:10	TRANSFORMER FAULT
99	25-Mar-20	GULBARGA	66	KOGALI-ASTRO_SOLAR_IPP	KOGALI_66	11:16	11:39	0:23	LINE CLEAR AVAILED
100	25-Mar-20	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	16:36	17:17	0:41	LINE FAULT
101	25-Mar-20	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	16:36	17:25	0:49	LINE FAULT
102	25-Mar-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	16:36	17:29	0:53	LINE FAULT
103	25-Mar-20	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	12:13	13:48	1:35	MAIN SUPPLY FAILURE
104	25-Mar-20	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	16:36	17:25	0:49	MAIN SUPPLY FAILURE
105	25-Mar-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	16:36	17:30	0:54	MAIN SUPPLY FAILURE
106	25-Mar-20	HASSAN	110	GURUVA-SLPWR	GURUVAYANAKERE_110	16:36	17:28	0:52	MAIN SUPPLY FAILURE
107	25-Mar-20	HASSAN	110	HV2	NAVUNDA_110	18:39	23:59	5:20	TRANSFORMER FAULT
108	25-Mar-20	HASSAN	110	NAVUNDA-MADHUVANA	NAVUNDA_110	18:38	19:00	0:22	LINE FAULT
109	25-Mar-20	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	12:25	13:35	1:10	LINE CLEAR AVAILED
110	25-Mar-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	13:24	13:30	0:06	LINE FAULT
111	25-Mar-20	MYSORE	66	HV1	BANNUR_66	11:35	11:37	0:01	TRANSFORMER FAULT
112	25-Mar-20	MYSORE	66	HV1	HDKOTE_66	15:03	15:51	0:47	LINE CLEAR AVAILED
113	25-Mar-20	MYSORE	66	HV2	HDKOTE_66	15:51	16:14	0:22	TRANSFORMER FAULT
114	25-Mar-20	MYSORE	66	KOLLEGALA-TALAKADU	PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	1:29	1:38	0:08	LINE FAULT
115	25-Mar-20	MYSORE	66	HV1	SATHEGALA_66	7:36	8:00	0:23	LINE CLEAR AVAILED
116	25-Mar-20	MYSORE	66	TARIPURA-TUBINAKERE	TARIPURA_66	6:04	6:13	0:08	LINE FAULT
117	25-Mar-20	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	12:32	12:43	0:10	LINE FAULT
118	25-Mar-20	TUMKUR	66	TR-1	NEELAGUNDA_220	1:24	1:33	0:09	TRANSFORMER FAULT
119	25-Mar-20	TUMKUR	66	TR-2	LINGDHALLI_66	16:04	16:09	0:05	TRANSFORMER FAULT
120	25-Mar-20	TUMKUR	66	TR-1	NITTUR_220	2:17	3:21	1:04	LINE CLEAR AVAILED
121	26-Mar-20	BAGALKOT	110	110/11KV,HV2	AIGALI_110	7:40	7:56	0:16	TRANSFORMER FAULT
122	26-Mar-20	BAGALKOT	110	110/11KV,HV2	AIGALI_110	10:22	11:39	1:17	TRANSFORMER FAULT
123	26-Mar-20	BAGALKOT	110	ANKALAGI-ISLAMPUR (HIDIKAL)	ISLAMPUR_110	3:08	3:40	0:32	LINE FAULT
124	26-Mar-20	BAGALKOT	110	KUMATA (L2)-ANKOLA	ANKOLA_110	12:20	12:45	0:25	MAIN SUPPLY FAILURE
125	26-Mar-20	BAGALKOT	110	KUMATA (L2)-ANKOLA	ANKOLA_110	12:43	12:53	0:10	LINE CLEAR AVAILED
126	26-Mar-20	BAGALKOT	110	110/33KV,HV2&HV3	HANAGAL_110,BELGALPET,AKKIALUR_33,BOMMANHALLI_33,LAXMIPURA_33	5:54	6:00	0:06	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
127	26-Mar-20	BAGALKOT	110	110/33KV,HV2&HV3	HANAGAL_110,BELGALPET,AKKIALUR_33,BOMMANHALLI_33,LAXMIPURA_33	10:10	10:15	0:05	TRANSFORMER FAULT
128	26-Mar-20	BAGALKOT	110	RON 1&2-GAJENDRAGAD	GAJENDRAGAD_110	23:20	23:43	0:23	LOAD CHANGE OVER
129	26-Mar-20	BAGALKOT	110	KUSHTAGI-GAJENDRAGAD	GAJENDRAGAD_110	23:27	23:41	0:14	LOAD CHANGE OVER
130	26-Mar-20	BAGALKOT	110	110/11KV,HV 2	HIDIKAL_110	6:54	7:08	0:14	TRANSFORMER FAULT
131	26-Mar-20	BAGALKOT	220	RANEBENNUR-SHIRALKOPPA	RANEBENNUR_220	0:00	10:35	10:35	LINE CLEAR AVAILED
132	26-Mar-20	BAGALKOT	220	RANEBENNUR-SHIRALKOPPA	RANEBENNUR_220	14:05	23:59	9:54	LINE CLEAR AVAILED
133	26-Mar-20	BAGALKOT	110	KARAWAR-SOLARIS(BINAGA)	BINAGA_110	0:15	13:08	12:53	LINE FAULT
134	26-Mar-20	BAGALKOT	110	KARAWAR-ARGA	ARGA_110	9:56	12:48	2:52	LINE CLEAR AVAILED
135	26-Mar-20	BAGALKOT	220	220/110KV, HV2&LV2	VAJRAMATTTI_220	16:50	17:56	1:06	LINE CLEAR AVAILED
136	26-Mar-20	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, HALSANGI_33	11:00	11:22	0:22	TRANSFORMER FAULT
137	26-Mar-20	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, HALSANGI_33	12:23	12:25	0:02	TRANSFORMER FAULT
138	26-Mar-20	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, HALSANGI_33	12:30	12:34	0:04	TRANSFORMER FAULT
139	26-Mar-20	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, HALSANGI_33	14:40	14:47	0:07	TRANSFORMER FAULT
140	26-Mar-20	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, HALSANGI_33	15:21	15:28	0:07	TRANSFORMER FAULT
141	26-Mar-20	BAGALKOT	110	110/11KV, HV1	YELPARAHATTI_110	16:26	16:37	0:11	LINE CLEAR AVAILED
142	26-Mar-20	BAGALKOT	110	RANNABELAGALI-UTTUR	UTTUR_110	7:07	7:27	0:20	LINE FAULT
143	26-Mar-20	BAGALKOT	110	SIRSI-KUMATA2	KUMATA_110	12:00	17:31	5:31	LINE FAULT
144	26-Mar-20	BAGALKOT	110	SIRSI-KUMATA1	KUMATA_110	12:10	23:59	11:49	LINE FAULT
145	26-Mar-20	BAGALKOT	110	ESALE1(SIRSI220)-SIRSI	SIRSI_110	14:52	16:50	1:58	LINE CLEAR AVAILED
146	26-Mar-20	BAGALKOT	110	ESALE2(SIRSI220)-SIRSI	SIRSI_110	18:19	18:59	0:40	LINE CLEAR AVAILED
147	26-Mar-20	BAGALKOT	110	SIRSI110-SIDDAPUR	SIDDAPUR_110	18:19	18:43	0:24	LINE CLEAR AVAILED
148	26-Mar-20	BAGALKOT	110	JOG-SIRSI	SIRSI_110	18:19	18:50	0:31	LINE CLEAR AVAILED
149	26-Mar-20	BAGALKOT	110	ESALE1(SIRSI220)-SIRSI	SIRSI_110	18:19	18:38	0:19	LINE CLEAR AVAILED
150	26-Mar-20	BAGALKOT	110	110/11KV, HV2	SIRSI_110	17:55	18:38	0:43	LINE CLEAR AVAILED
151	26-Mar-20	BAGALKOT	110	110/11KV, HV1	SIRSI_110	18:13	18:38	0:25	LINE CLEAR AVAILED
152	26-Mar-20	BAGALKOT	110	110/11KV, HV1	SHIROL_110	19:37	19:39	0:02	TRANSFORMER FAULT
153	26-Mar-20	BAGALKOT	110	GAMESHA-RON	RON_110	23:05	23:50	0:45	HAND TRIPPED
154	26-Mar-20	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	0:00	11:07	11:07	LINE CLEAR AVAILED
155	26-Mar-20	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	14:57	23:59	9:02	LINE CLEAR AVAILED
156	26-Mar-20	BAGALKOT	110	NAREGAL- RON	NAREGAL_110	10:59	14:57	3:58	LINE CLEAR AVAILED
157	26-Mar-20	BAGALKOT	110	110/11KV, HV2	MUDEDEBIHAL_110	7:16	7:30	0:14	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
158	26-Mar-20	BAGALKOT	110	MAMADAPUR(B)-TODALBAGI	TODALBAGI_220	13:15	15:03	1:48	LINE CLEAR AVOIDED
159	26-Mar-20	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	14:45	14:47	0:02	TRANSFORMER FAULT
160	26-Mar-20	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	15:03	15:07	0:04	TRANSFORMER FAULT
161	26-Mar-20	BAGALKOT	110	KUMATA-SIRSI1	KUMATA_110	12:59	23:59	11:00	LINE CLEAR AVOIDED
162	26-Mar-20	BAGALKOT	220	220/110KV,HV1&LV1	SIRSI_220, SIRSI_110	17:50	18:04	0:14	TRANSFORMER FAULT
163	26-Mar-20	BENGALURU	66	YEDUMADU - KANAKPURA 220	YEDUMADU	15:33	15:37	0:04	LOAD CHANGE OVER
164	26-Mar-20	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	9:33	9:38	0:05	LOAD CHANGE OVER
165	26-Mar-20	BENGALURU	66	HV1	SULIBELE	15:46	16:42	0:56	LINE CLEAR AVOIDED
166	26-Mar-20	BENGALURU	66	HV1	MULBAGALU	11:54	12:41	0:47	LINE CLEAR AVOIDED
167	26-Mar-20	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, NANGLI, H GOLAHALLI, BAIRAKURU	22:07	22:11	0:03	LINE FAULT
168	26-Mar-20	BENGALURU	66	DODDABALLAPURA 220 - DEVANAHALLI 1	KUNDANA	17:46	17:52	0:05	LINE FAULT
169	26-Mar-20	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1	THIMMAPALLI, PATHPALYA, SOMANTHPURA	8:00	8:06	0:05	LOAD CHANGE OVER
170	26-Mar-20	BENGALURU	220	LV3	SOMANAHALLI 220	11:46	17:55	6:09	LINE CLEAR AVOIDED
171	26-Mar-20	BENGALURU	66	HV2	KUMBALGODU	13:00	13:11	0:10	LINE CLEAR AVOIDED
172	26-Mar-20	BENGALURU	66	HV2	HAL 220	23:01	23:58	0:56	TRANSFORMER FAULT
173	26-Mar-20	BENGALURU	66	HV1	DEVARBEESANAHALLI	6:23	8:20	1:56	TRANSFORMER FAULT
174	26-Mar-20	BENGALURU	66	HV2	DEVARBEESANAHALLI	8:04	8:18	0:14	LINE CLEAR AVOIDED
175	26-Mar-20	BENGALURU	66	HV2	DEVARBEESANAHALLI	8:20	8:23	0:03	TRANSFORMER FAULT
176	26-Mar-20	HASSAN	220	HV1	HASSAN_220	17:07	17:57	0:50	LINE CLEAR AVOIDED
177	26-Mar-20	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	10:35	13:58	3:23	LINE CLEAR AVOIDED
178	26-Mar-20	HASSAN	220	VARAHI-SHMG3	varahi_gen	12:20	13:53	1:33	LINE FAULT
179	26-Mar-20	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	10:32	13:57	3:25	LINE CLEAR AVOIDED
180	26-Mar-20	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	14:18	14:20	0:02	LINE FAULT
181	26-Mar-20	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	12:20	12:41	0:21	LINE FAULT
182	26-Mar-20	HASSAN	110	JOG-NK1	mghejog_gen	17:52	18:04	0:12	LINE FAULT
183	26-Mar-20	HASSAN	110	JOG-NK2	mghejog_gen	17:52	18:04	0:12	LINE FAULT
184	26-Mar-20	HASSAN	110	MRSSHM-GAJNUR	MRSMG_220	8:40	11:54	3:14	LINE FAULT
185	26-Mar-20	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:21	12:03	0:42	HAND TRIPPED
186	26-Mar-20	HASSAN	66	LV1	HASSAN_220	17:07	17:58	0:51	LINE CLEAR AVOIDED
187	26-Mar-20	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	17:06	18:00	0:54	HAND TRIPPED
188	26-Mar-20	HASSAN	66	HASSN22-CHIKAMAGLUR2	HASSAN_220	17:04	18:15	1:11	LINE CLEAR AVOIDED
189	26-Mar-20	HASSAN	66	HASSN22-HN PURA	HASSAN_220	17:07	18:06	0:59	HAND TRIPPED
190	26-Mar-20	HASSAN	66	HASSN22-MALLALI	HASSAN_220	17:07	18:05	0:58	HAND TRIPPED
191	26-Mar-20	HASSAN	66	HASSN22-SKPURA	HASSAN_220	17:07	18:03	0:56	HAND TRIPPED
192	26-Mar-20	HASSAN	66	HV1	DODDAKADANUR_66	13:10	13:46	0:36	LINE CLEAR AVOIDED
193	26-Mar-20	HASSAN	66	HV1	MAGGE_66	17:07	18:04	0:57	MAIN SUPPLY FAILURE
194	26-Mar-20	HASSAN	66	HV2	MAGGE_66	17:06	18:04	0:58	MAIN SUPPLY FAILURE
195	26-Mar-20	HASSAN	66	HV1	S.BELAGOLA_66	11:04	11:11	0:07	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
196	26-Mar-20	HASSAN	66	SOMNHL-GDNEHALI	SOMANAHALLY_66	17:00	17:10	0:10	MAIN SUPPLY FAILURE
197	26-Mar-20	MYSORE	66	KUSHALANAGARA-RAMANATHAPURA	ALUR SIDDAPUR_66	11:36	12:24	0:48	LINE CLEAR AVAILED
198	26-Mar-20	MYSORE	66	HV2	AKKIHEBBAL_66	13:11	13:55	0:44	TRANSFORMER FAULT
199	26-Mar-20	MYSORE	66	KIRUGAVALU-SFC	VADKEPURA_66 KIRUGAVALU_66	21:55	22:12	0:16	LINE FAULT
200	26-Mar-20	MYSORE	66	HV2	NAGAMANGALA_66	10:03	10:12	0:09	TRANSFORMER FAULT
201	26-Mar-20	MYSORE	66	HV5	SFCSHIVA_66	12:44	23:59	11:14	LINE CLEAR AVAILED
202	26-Mar-20	TUMKUR	400	GUTTUR 400KV-KAIGA400KV	GUTUR_400	12:33	15:29	2:56	LINE CLEAR AVAILED
203	26-Mar-20	TUMKUR	110	TR-2	KBCROSS_220	11:53	18:38	6:44	LINE CLEAR AVAILED
204	26-Mar-20	TUMKUR	66	DAVANGERE SRS-KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:12	14:21	0:09	LINE FAULT
205	26-Mar-20	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66	14:33	14:41	0:07	LINE FAULT
206	26-Mar-20	TUMKUR	66	TR-1	PANDARAHALLI_66	15:41	16:05	0:24	HAND TRIPPED
207	26-Mar-20	TUMKUR	66	TR-1	YEDIYUR_66	12:02	12:32	0:30	LINE CLEAR AVAILED
208	26-Mar-20	TUMKUR	66	CHITRADURGA 66kV-PANDARAHALLI 2	CHITRADURGA_66	9:15	9:45	0:30	LINE FAULT
209	27-Mar-2020	BAGALKOT	220	BELGAUM-NARENDRA1&2	BELGAUM_220	8:47	9:01	0:14	HAND TRIPPED
210	27-Mar-2020	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	8:47	9:02	0:15	HAND TRIPPED
211	27-Mar-2020	BAGALKOT	110	CHIKKODI-NIPPANI	NIPPANI_110	21:20	21:51	0:31	LINE FAULT
212	27-Mar-2020	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	22:46	23:59	1:13	LINE CLEAR AVAILED
213	27-Mar-2020	BAGALKOT	110	GAJENDRAGAD-RON 1&2	GAJENDRAGAD_110	1:55	23:59	22:04	LINE CLEAR AVAILED
214	27-Mar-2020	BAGALKOT	110	KUSHTAGI-GAJENDRAGAD	GAJENDRAGAD_110	1:55	2:14	0:19	HAND TRIPPED
215	27-Mar-2020	BAGALKOT	110	110/33KV, HV 2	HANAGALL_110 & 33KV BOMMANALLI, BELGALPET, LAXMIPUR & AKKIALUR	5:12	5:41	0:29	HAND TRIPPED
216	27-Mar-2020	BAGALKOT	110	110/33KV, HV 2	HANAGALL_110 & 33KV BOMMANALLI, BELGALPET, LAXMIPUR & AKKIALUR	6:16	6:23	0:07	TRANSFORMER FAULT
217	27-Mar-2020	BAGALKOT	110	110/33KV, HV 2	HANAGALL_110 & 33KV BOMMANALLI, BELGALPET, LAXMIPUR & AKKIALUR	7:44	7:55	0:11	TRANSFORMER FAULT
218	27-Mar-2020	BAGALKOT	110	110/33KV, HV 2	HANAGALL_110 & 33KV BOMMANALLI, BELGALPET, LAXMIPUR & AKKIALUR	5:07	5:17	0:10	TRANSFORMER FAULT
219	27-Mar-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, HALSANGI_33	7:49	8:12	0:23	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
220	27-Mar-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, HALSANGI_33	11:45	11:51	0:06	TRANSFORMER FAULT
221	27-Mar-2020	BAGALKOT	110	110/11KV, HV1	ZALKI_110	11:45	11:49	0:04	LINE CLEAR AVOID
222	27-Mar-2020	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	20:00	23:59	3:59	TRANSFORMER FAULT
223	27-Mar-2020	BAGALKOT	110	110/33KV, HV3	RON_110, MUSHIGERI_33	1:55	7:28	5:33	TRANSFORMER FAULT
224	27-Mar-2020	BAGALKOT	110	GAMESHA-RON	RON_110	1:55	3:15	1:20	LINE CLEAR AVOID
225	27-Mar-2020	BAGALKOT	110	CHIKKODI2-RAIBAG	RAIBAG_110	22:09	22:52	0:43	LINE FAULT
226	27-Mar-2020	BAGALKOT	110	CHIKKODI1-RAIBAG	RAIBAG_110	22:44	22:51	0:07	HAND TRIPPED
227	27-Mar-2020	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	1:55	3:21	1:26	TRANSFORMER FAULT
228	27-Mar-2020	BAGALKOT	110	110/33KV, HV3	SANKESHWAR_110, HEBBAL_33, KANAGAL_33	12:32	12:34	0:02	LINE CLEAR AVOID
229	27-Mar-2020	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	23:01	23:25	0:24	HAND TRIPPED
230	27-Mar-2020	BAGALKOT	220	HARTI1&2-GADAG	GADAG_220	10:59	23:59	13:00	LINE CLEAR AVOID
231	27-Mar-2020	BAGALKOT	110	HAVERI220-HANAGAL(TILUVAALI)	HANAGAL_110	5:12	5:40	0:28	LINE FAULT
232	27-Mar-2020	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	5:39	12:44	7:05	LINE FAULT
233	27-Mar-2020	BAGALKOT	220	GUTTUR1-HAVERI	HAVERI_220	10:04	11:48	1:44	LINE CLEAR AVOID
234	27-Mar-2020	BAGALKOT	110	SIRSI1-KUMTA	KUMTA_110	0:00	10:25	10:25	LINE CLEAR AVOID
235	27-Mar-2020	BAGALKOT	110	SIRSI1-KUMTA	KUMTA_110	10:37	23:59	13:22	LINE CLEAR AVOID
236	27-Mar-2020	BAGALKOT	110	110/11KV, HV1	KONNUR_110	2:00	9:25	7:25	TRANSFORMER FAULT
237	27-Mar-2020	BAGALKOT	110	110/33KV, HV2	KONNUR_110, SUREBAN_33, WIND WORLD_33	2:00	9:25	7:25	TRANSFORMER FAULT
238	27-Mar-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	SOUTH CITY	12:42	13:00	0:18	LINE FAULT
239	27-Mar-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:55	12:10	0:14	LINE FAULT
240	27-Mar-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	17:51	18:14	0:22	LINE FAULT
241	27-Mar-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	4:32	4:48	0:16	LINE FAULT
242	27-Mar-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	17:37	17:52	0:14	LINE FAULT
243	27-Mar-2020	BENGALURU	66	HV2	AREHALLI	12:15	12:18	0:03	LINE CLEAR AVOID
244	27-Mar-2020	BENGALURU	66	HV5	NRS 220	16:20	16:40	0:20	TRANSFORMER FAULT
245	27-Mar-2020	BENGALURU	66	NRS 220 - MYSORE ROAD 2	VIJAYANAGARA	7:58	8:05	0:07	LINE FAULT
246	27-Mar-2020	GULBARGA	400	JSWVL-GUTTUR	GUTTUR_400	13:12	19:04	5:52	LINE FAULT
247	27-Mar-2020	GULBARGA	220	HV1, HV2	ITTAGI_220	14:25	14:40	0:15	TRANSFORMER FAULT
248	27-Mar-2020	GULBARGA	220	HV1, HV2	ITTAGI_220	18:25	18:38	0:13	TRANSFORMER FAULT
249	27-Mar-2020	GULBARGA	220	HV2	ITTAGI_220	21:13	22:40	1:27	TRANSFORMER FAULT
250	27-Mar-2020	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITAGUPPA_110	12:10	12:15	0:05	LINE FAULT
251	27-Mar-2020	GULBARGA	110	HV1	CHINCHOLI_110	21:20	22:05	0:45	LINE CLEAR AVOID
252	27-Mar-2020	GULBARGA	110	HV1	CHINCHOLI_110	8:22	9:43	1:21	LINE CLEAR AVOID
253	27-Mar-2020	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110, MANVI_110	5:29	5:40	0:11	LINE FAULT
254	27-Mar-2020	GULBARGA	110	MALLAT-BYAGWAT1	BYAGAWAT_110	23:41	23:51	0:10	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
255	27-Mar-2020	GULBARGA	110	MALLAT-BYAGWAT1	BYAGAWAT_110	1:06	1:16	0:10	LINE FAULT
256	27-Mar-2020	GULBARGA	110	MALLAT-BYAGWAT1	BYAGAWAT_110	20:38	20:50	0:12	LINE FAULT
257	27-Mar-2020	GULBARGA	110	HV1	SHAHPUR_220	10:25	10:52	0:27	TRANSFORMER FAULT
258	27-Mar-2020	GULBARGA	110	SHAHPUR-SHAHPUR1	SHAHPUR_110	10:40	11:59	1:19	LINE CLEAR AVAILED
259	27-Mar-2020	GULBARGA	110	HV3	KEMBHAVI_110	11:35	11:40	0:05	TRANSFORMER FAULT
260	27-Mar-2020	HASSAN	110	HV1	ARASIKERE_110	6:45	6:50	0:05	TRANSFORMER FAULT
261	27-Mar-2020	HASSAN	110	HV1	SHIKARIPURA_110	13:03	13:11	0:08	TRANSFORMER FAULT
262	27-Mar-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	13:08	13:12	0:04	LINE FAULT
263	27-Mar-2020	MYSORE	66	KUSHALANAGARA-MYSORE-2	BETTADHAPURA_66, KITTUR_66, KRNAGARA_66, BHERYA_66, BILIKERE_66, GVGUDI_66 & DMG_HALLI_66, RAVANDUR_66 & CHUNCHUNKATTE_66.	16:03	16:18	0:15	LINE FAULT
264	27-Mar-2020	MYSORE	66	KUSHALANAGARA-MYSORE-1	MIRLE_66	15:23	15:37	0:14	LINE FAULT
265	27-Mar-2020	MYSORE	66	KUSHALANAGARA-MYSORE-1	KRNAGARA_66, BHERYA_66, BILIKERE_66, GVGUDI_66 & DMG_HALLI_66	15:50	16:00	0:10	LINE FAULT
266	27-Mar-2020	MYSORE	66	KUSHALANAGARA-MYSORE-1	MIRLE_66	16:02	16:32	0:30	LINE FAULT
267	27-Mar-2020	MYSORE	66	BOGADHI-GIS	GIS	20:25	20:43	0:17	LINE FAULT
268	27-Mar-2020	MYSORE	66	HV2	HDKOTE_66	19:24	20:07	0:42	LINE CLEAR AVAILED
269	27-Mar-2020	MYSORE	66	HV2	KMDODDI_66	18:56	19:14	0:18	TRANSFORMER FAULT
270	27-Mar-2020	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	MADESWARAPURA_66, JAKKANAHALLY_66, G MALLIGERE_66, GUDDENAHALLI_66, BOGADHI MANDYA_66 & NAGAMANGALA_66	16:50	16:56	0:06	LINE FAULT
271	27-Mar-2020	MYSORE	66	HV4	SFCSHIVA_66	14:25	20:32	6:07	TRANSFORMER FAULT
272	27-Mar-2020	TUMKUR	220	ANTHRASANAHALLI 220KV-VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	12:05	16:40	4:35	LINE CLEAR AVAILED
273	27-Mar-2020	TUMKUR	110	KB CROSS 220kv-CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	10:44	10:57	0:13	LINE CLEAR AVAILED
274	27-Mar-2020	TUMKUR	66	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	17:40	17:56	0:16	HAND TRIPPED
275	27-Mar-2020	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	11:59	12:02	0:02	LINE FAULT
276	27-Mar-2020	TUMKUR	66	TR-1	BELADARA_66	11:59	12:02	0:02	LINE CLEAR AVAILED
277	27-Mar-2020	TUMKUR	66	TR-2	BELADARA_66	11:59	12:02	0:02	LINE CLEAR AVAILED
278	27-Mar-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	17:31	17:35	0:04	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
279	27-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:40	16:42	0:01	HAND TRIPPED
280	27-Mar-2020	TUMKUR	66	TR-1	TAVAREKERE(C)_66	21:23	21:25	0:01	MAIN SUPPLY FAILURE
281	28-Mar-2020	BAGALKOT	110	BAGALKOT220-BAGALKOT110	BAGALKOT_110	14:56	15:10	0:14	LINE FAULT
282	28-Mar-2020	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	19:25	23:59	4:34	LINE CLEAR AVAILED
283	28-Mar-2020	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	0:00	0:08	0:08	LINE CLEAR AVAILED
284	28-Mar-2020	BAGALKOT	110	GAJENDRAGAD-RON 1&2	GAJENDRAGAD_110	0:00	13:37	13:37	LINE CLEAR AVAILED
285	28-Mar-2020	BAGALKOT	110	GAJENDRAGAD-RON 1	GAJENDRAGAD_110	18:13	23:59	5:46	LINE FAULT
286	28-Mar-2020	BAGALKOT	110	GAJENDRAGAD-RON 2	GAJENDRAGAD_110	18:13	23:59	5:46	LINE CLEAR AVAILED
287	28-Mar-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, HALSANGI_33	22:05	22:07	0:02	TRANSFORMER FAULT
288	28-Mar-2020	BAGALKOT	110	110/33KV, HV3	ZALKI_110, HORTI_33	9:21	12:42	3:21	LINE CLEAR AVAILED
289	28-Mar-2020	BAGALKOT	110	110/33KV, HV2	UTTUR_110, YADAWAD_33, VANTAGOD_33	15:15	15:21	0:06	TRANSFORMER FAULT
290	28-Mar-2020	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	0:00	16:00	16:00	LINE CLEAR AVAILED
291	28-Mar-2020	BAGALKOT	110	SAVANUR-RAMANKOPPA (SHIGGOAN)	SHIGGOAN_110	6:11	6:32	0:21	LINE FAULT
292	28-Mar-2020	BAGALKOT	110	SAVANUR-RAMANKOPPA (SHIGGOAN)	SHIGGOAN_110	6:41	6:55	0:14	LINE FAULT
293	28-Mar-2020	BAGALKOT	110	RANEBENNUR220-HIREKERUR	HIREKERUR_110	4:31	4:43	0:12	LINE FAULT
294	28-Mar-2020	BAGALKOT	110	RANEBENNUR220-HIREKERUR	HIREKERUR_110	5:25	5:35	0:10	LINE FAULT
295	28-Mar-2020	BAGALKOT	110	RANEBENNUR220-HIREKERUR	HIREKERUR_110	7:01	8:23	1:22	LINE FAULT
296	28-Mar-2020	BAGALKOT	110	RANEBENNUR220-AREMALLAPUR(HONNATTI)	HONNATTI_110	4:47	4:58	0:11	LINE FAULT
297	28-Mar-2020	BAGALKOT	110	RANEBENNUR220-AREMALLAPUR(HONNATTI)	HONNATTI_110	6:32	6:45	0:13	LINE FAULT
298	28-Mar-2020	BAGALKOT	110	RANEBENNUR- RATTIHALI	RATTIHALI_110, TUMMINKATTI_110	7:26	7:39	0:13	LINE FAULT
299	28-Mar-2020	BAGALKOT	110	RON-NAREGAL	NAREGAL_110	18:08	18:21	0:13	HAND TRIPPED
300	28-Mar-2020	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	0:00	18:14	18:14	LINE CLEAR AVAILED
301	28-Mar-2020	BAGALKOT	110	110/11KV,HV2	KHANAPUR_110	11:15	12:37	1:22	LINE CLEAR AVAILED
302	28-Mar-2020	BAGALKOT	110	110/33KV,HV2	HUNAGUND_110,AMINAGAD_33, KARADI_33	15:44	15:48	0:04	TRANSFORMER FAULT
303	28-Mar-2020	BAGALKOT	110	BALAJI SUGAR-MUDDEBIHAL	MUDDEBIHAL_110	6:19	6:32	0:13	LINE FAULT
304	28-Mar-2020	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	7:40	7:50	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
305	28-Mar-2020	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	18:07	18:28	0:20	LINE FAULT
306	28-Mar-2020	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	18:07	18:31	0:23	LINE FAULT
307	28-Mar-2020	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	6:42	7:01	0:18	LINE FAULT
308	28-Mar-2020	BENGALURU	66	GOKULA - BEL (EH)	BEL (EHT)	18:07	18:31	0:23	MAIN SUPPLY FAILURE
309	28-Mar-2020	BENGALURU	66	HV1	BIDADI 220	8:11	8:18	0:07	TRANSFORMER FAULT
310	28-Mar-2020	BENGALURU	66	HV1	BIDADI 220	8:21	8:35	0:14	TRANSFORMER FAULT
311	28-Mar-2020	BENGALURU	66	HV2	BYADRAHALLI	14:43	15:15	0:31	TRANSFORMER FAULT
312	28-Mar-2020	BENGALURU	66	HV1	KODIHALLI	7:45	7:50	0:04	TRANSFORMER FAULT
313	28-Mar-2020	BENGALURU	66	HV1	MUDIYANUR	14:09	14:16	0:07	TRANSFORMER FAULT
314	28-Mar-2020	GULBARGA	220	HV1	HALBARGA_220	14:32	18:40	4:08	TRANSFORMER FAULT
315	28-Mar-2020	GULBARGA	110	HV2	SHAHPUR_220	1:41	1:52	0:11	TRANSFORMER FAULT
316	28-Mar-2020	GULBARGA	110	HV2	DEODURGA_110	17:05	17:10	0:05	TRANSFORMER FAULT
317	28-Mar-2020	GULBARGA	110	HV1	KEMBHAVI_110	14:05	14:10	0:05	TRANSFORMER FAULT
318	28-Mar-2020	GULBARGA	110	HV1	KEMBHAVI_110	15:15	15:20	0:05	TRANSFORMER FAULT
319	28-Mar-2020	GULBARGA	110	HV1	KEMBHAVI_110	16:10	16:15	0:05	TRANSFORMER FAULT
320	28-Mar-2020	GULBARGA	110	HV1	KEMBHAVI_110	17:40	17:45	0:05	TRANSFORMER FAULT
321	28-Mar-2020	GULBARGA	110	GURGUNTA-KHEL_IPP, LJV_L_IPP	GURUNTA_110,KHEL_IPP, LJV_L_IPP	17:45	18:00	0:15	LINE CLEAR AVAILED
322	28-Mar-2020	GULBARGA	110	GURGUNTA-LINGASUGUR	GURUNTA_110,KHEL_IPP, LJV_L_IPP	23:30	23:35	0:05	LINE FAULT
323	28-Mar-2020	GULBARGA	110	GURGUNTA-KHEL_IPP, LJV_L_IPP	KHEL_IPP, LJV_L_IPP	23:30	23:50	0:20	LINE FAULT
324	28-Mar-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	7:01	11:52	4:51	LINE FAULT
325	28-Mar-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	4:23	14:36	10:13	LINE FAULT
326	28-Mar-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	12:02	12:37	0:35	HAND TRIPPED
327	28-Mar-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	21:22	23:59	2:37	LINE FAULT
328	28-Mar-2020	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	4:22	14:36	10:14	LINE FAULT
329	28-Mar-2020	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	12:02	12:37	0:35	HAND TRIPPED
330	28-Mar-2020	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	21:22	23:59	2:37	LINE FAULT
331	28-Mar-2020	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	11:15	11:21	0:06	HAND TRIPPED
332	28-Mar-2020	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	12:30	12:33	0:03	HAND TRIPPED
333	28-Mar-2020	HASSAN	110	HV1	JOG_110	15:43	17:03	1:20	LINE CLEAR AVAILED
334	28-Mar-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	10:34	10:39	0:05	LINE FAULT
335	28-Mar-2020	HASSAN	66	BHARA-LINGADAHALLI	bhadra_gen	12:28	12:35	0:07	LINE FAULT
336	28-Mar-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	9:58	10:06	0:08	HAND TRIPPED
337	28-Mar-2020	HASSAN	66	HV1	KANDLI_66	10:49	10:53	0:04	TRANSFORMER FAULT
338	28-Mar-2020	MYSORE	66	HOOTAGALLY-ELWALA	ELAVALA_66 & GAVADAGERE_66	12:46	13:07	0:21	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
339	28-Mar-2020	MYSORE	66	HOOTAGALLY-HUNSUR	HUNSUR_66, HANAGODU_66, HOSURGATE_66 & BANNIKUPPE_66	12:46	13:07	0:21	LINE FAULT
340	28-Mar-2020	MYSORE	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 & DODDABYADARAHALLI_66	9:02	9:08	0:06	LINE FAULT
341	28-Mar-2020	MYSORE	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 & DODDABYADARAHALLI_66	20:09	20:14	0:05	LINE FAULT
342	28-Mar-2020	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	13:21	13:28	0:07	LINE FAULT
343	28-Mar-2020	MYSORE	66	HV 1	CHINAKURALI_66	13:00	13:36	0:36	LINE CLEAR AVAILED
344	28-Mar-2020	MYSORE	66	HV3	SFCSHIVA_66	9:58	14:25	4:26	LINE CLEAR AVAILED
345	28-Mar-2020	MYSORE	66	HV2	BILIKERE_66	11:36	11:41	0:04	TRANSFORMER FAULT
346	28-Mar-2020	MYSORE	66	HV1	HULLAHALLI_66	11:18	12:24	1:05	LINE CLEAR AVAILED
347	28-Mar-2020	MYSORE	66	KADAKOLA-SARGUR 2	HULLAHALLI_66, DOORA_66, HURA_66, SANTHESARAGUR_66, B MATKERE_66 & CHANDRAVADI_66 STATIONS INTERRUPTED.	12:50	12:52	0:02	LINE FAULT
348	28-Mar-2020	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66	5:48	5:58	0:10	LINE FAULT
349	28-Mar-2020	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66	12:50	12:53	0:02	LINE FAULT
350	28-Mar-2020	MYSORE	66	HV2	PANDAVAPURA	9:15	13:07	3:52	LINE CLEAR AVAILED
351	28-Mar-2020	TUMKUR	220	TR-1	ANTHRASANAHALLI_220	12:08	15:23	3:14	LINE CLEAR AVAILED
352	28-Mar-2020	TUMKUR	220	TR-2	ANTHRASANAHALLI_220	12:09	13:51	1:42	LINE CLEAR AVAILED
353	28-Mar-2020	TUMKUR	66	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	11:53	13:52	1:59	LINE CLEAR AVAILED
354	28-Mar-2020	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	11:37	15:58	4:21	LINE CLEAR AVAILED
355	28-Mar-2020	TUMKUR	66	ANTHRASANAHALLI 220kv-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	11:53	13:52	1:59	LINE CLEAR AVAILED
356	28-Mar-2020	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	12:08	15:24	3:15	LINE CLEAR AVAILED
357	28-Mar-2020	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	12:09	13:51	1:42	LINE CLEAR AVAILED
358	28-Mar-2020	TUMKUR	66	ANTHRASANAHALLI 220KV-MELEKOTE	MELKOTE_66, BADDIHALI_66	11:53	15:00	3:07	LINE CLEAR AVAILED
359	28-Mar-2020	TUMKUR	66	ANTHRASANAHALLI 220KV-TUMKUR	TUMKUR_66	12:08	15:41	3:32	LINE CLEAR AVAILED
360	28-Mar-2020	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	13:57	14:00	0:02	LINE CLEAR AVAILED
361	28-Mar-2020	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	15:05	15:07	0:02	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
362	28-Mar-2020	TUMKUR	66	TR-1	BELADARA_66	13:57	14:01	0:03	LINE CLEAR AVAILED
363	28-Mar-2020	TUMKUR	66	TR2	BELADARA_66	13:57	14:01	0:03	LINE CLEAR AVAILED
364	28-Mar-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	3:54	12:22	8:28	TRANSFORMER FAULT
365	28-Mar-2020	TUMKUR	66	DODDASARANGI-ANCHEPALYA	DODDASARANGI_66	11:33	15:32	3:58	LINE CLEAR AVAILED
366	28-Mar-2020	TUMKUR	66	DAVANGERE SRS-KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	4:04	4:12	0:08	LINE FAULT
367	28-Mar-2020	TUMKUR	66	DAVANGERE SRS-DAVANGERE	DAVANAGERE_66	12:56	13:12	0:15	LINE FAULT
368	28-Mar-2020	TUMKUR	66	HONNALLI 220kV-BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	13:11	13:38	0:26	LINE CLEAR AVAILED
369	28-Mar-2020	TUMKUR	66	TR-1	NEELAGUNDA_220	13:02	13:12	0:09	TRANSFORMER FAULT
370	28-Mar-2020	TUMKUR	66	TR-1	TUMKUR_66	12:10	12:19	0:09	HAND TRIPPED
371	28-Mar-2020	TUMKUR	66	TR-1	TUMKUR_66	15:48	15:58	0:10	HAND TRIPPED
372	28-Mar-2020	TUMKUR	66	TR-2	TUMKUR_66	12:10	12:19	0:08	HAND TRIPPED
373	28-Mar-2020	TUMKUR	66	TR-2	TUMKUR_66	15:48	16:23	0:35	HAND TRIPPED
374	29-Mar-2020	BAGALKOT	110	BAGEWDAI-MAMADAPUR1&2	MAMADAPUR_110	6:00	6:24	0:24	LINE FAULT
375	29-Mar-2020	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	0:00	13:26	13:26	LINE CLEAR AVAILED
376	29-Mar-2020	BAGALKOT	110	110/11KV,HV 3	MAMADAPUR(B)_110	6:31	6:32	0:01	TRANSFORMER FAULT
377	29-Mar-2020	BAGALKOT	110	MAMADAPUR-TODALABAGI	TODALABAGI_110	11:27	13:40	2:13	LINE CLEAR AVAILED
378	29-Mar-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, HALSANGI_33	6:54	7:07	0:13	TRANSFORMER FAULT
379	29-Mar-2020	BAGALKOT	110	110/11KV, HV2	YARGATTI_110	6:02	6:12	0:10	TRANSFORMER FAULT
380	29-Mar-2020	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	11:18	11:57	0:39	LINE CLEAR AVAILED
381	29-Mar-2020	BAGALKOT	110	110/11KV, HV2	SHIROL_110	19:01	19:06	0:05	TRANSFORMER FAULT
382	29-Mar-2020	BAGALKOT	110	RON-GAJENDRAGAD1&2	RON_110	15:40	16:44	1:04	LINE CLEAR AVAILED
383	29-Mar-2020	BAGALKOT	110	HIREHAL-RON	RON_110	15:40	16:44	1:04	LINE CLEAR AVAILED
384	29-Mar-2020	BAGALKOT	110	GAMESHA-RON	RON_110	15:40	16:44	1:04	LINE CLEAR AVAILED
385	29-Mar-2020	BAGALKOT	110	NAREGAL-RON	RON_110	15:41	16:07	0:26	HAND TRIPPED
386	29-Mar-2020	BAGALKOT	220	MAHALINGAPUR-NARENDRA2	MAHALINGAPUR_220	14:42	20:09	5:27	LINE FAULT
387	29-Mar-2020	BENGALURU	66	TADIGODU CROSS - LAKSHMIPURA	LAKSHMIPURA, SOMAJAYANAHALLI, ADGAL	6:45	8:05	1:20	LINE FAULT
388	29-Mar-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	6:31	6:48	0:16	LINE FAULT
389	29-Mar-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	8:23	8:30	0:06	LINE FAULT
390	29-Mar-2020	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	3:11	3:32	0:21	LINE FAULT
391	29-Mar-2020	BENGALURU	66	HV1	BIDADI 220	14:36	17:07	2:30	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
392	29-Mar-2020	BENGALURU	66	HV2	SHAMRAJ TECH PARK	6:42	7:01	0:19	TRANSFORMER FAULT
393	29-Mar-2020	BENGALURU	66	HV1	ATTUR YELAHANKA	3:34	4:40	1:05	TRANSFORMER FAULT
394	29-Mar-2020	GULBARGA	110	SHAHPUR-KEMBHAVI2	KEMBHAVI_110, UGARSUGAR_IPP, HUNSAGI_110	4:09	4:40	0:31	LINE FAULT
395	29-Mar-2020	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	21:22	21:48	0:26	LINE FAULT
396	29-Mar-2020	GULBARGA	110	HV3	KEMBHAVI_110	15:30	15:35	0:05	TRANSFORMER FAULT
397	29-Mar-2020	GULBARGA	110	KEMBHAVI-HUNSAGI	HUNSAGI_110	4:05	4:20	0:15	LINE FAULT
398	29-Mar-2020	GULBARGA	110	HV1	PD_HALLI_110	17:50	17:55	0:05	LINE CLEAR AVAILED
399	29-Mar-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	0:00	9:52	9:52	LINE FAULT
400	29-Mar-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	17:20	23:59	6:39	LINE FAULT
401	29-Mar-2020	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	0:00	9:52	9:52	LINE FAULT
402	29-Mar-2020	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	17:20	23:59	6:39	LINE FAULT
403	29-Mar-2020	HASSAN	110	HV1	KULASHEKARA_110	14:11	14:18	0:07	TRANSFORMER FAULT
404	29-Mar-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:06	23:59	5:53	LINE CLEAR AVAILED
405	29-Mar-2020	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	8:32	8:47	0:15	LINE FAULT
406	29-Mar-2020	HASSAN	66	HASSN22-BELUR	HASSAN_220	6:02	13:30	7:28	LINE CLEAR AVAILED
407	29-Mar-2020	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	4:08	4:30	0:22	LINE FAULT
408	29-Mar-2020	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	6:02	13:30	7:28	LINE CLEAR AVAILED
409	29-Mar-2020	HASSAN	66	HASSN22-SUZLON	HASSAN_220	6:02	13:30	7:28	LINE CLEAR AVAILED
410	29-Mar-2020	HASSAN	66	BHARA-LINGADAHALLI	bhadra_gen	13:15	13:29	0:14	LINE FAULT
411	29-Mar-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	9:15	9:28	0:13	HAND TRIPPED
412	29-Mar-2020	HASSAN	66	DUDDA-CKNDGL	DUDDA_66	13:51	14:09	0:18	HAND TRIPPED
413	29-Mar-2020	HASSAN	66	HV1	KUDLIGERE_66	8:28	11:11	2:43	LINE CLEAR AVAILED
414	29-Mar-2020	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	6:05	13:30	7:25	MAIN SUPPLY FAILURE
415	29-Mar-2020	HASSAN	66	HV2	SHANTHIGRAMMA_66	11:16	11:23	0:07	TRANSFORMER FAULT
416	29-Mar-2020	HASSAN	66	HV2	UDAYAPURA_66	11:24	11:26	0:02	TRANSFORMER FAULT
417	29-Mar-2020	HASSAN	66	HV2	UDAYAPURA_66	18:02	18:14	0:12	TRANSFORMER FAULT
418	29-Mar-2020	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	6:00	8:22	2:22	MAIN SUPPLY FAILURE
419	29-Mar-2020	HASSAN	66	UDDURKO-CKNDGL	UDDURKOPLU_66	5:01	5:05	0:04	LINE FAULT
420	29-Mar-2020	HASSAN	66	UDDURKO-CKNDGL	UDDURKOPLU_66	6:00	8:25	2:25	MAIN SUPPLY FAILURE
421	29-Mar-2020	HASSAN	66	UDDUEKO-HASSAN1	UDDURKOPLU_66	4:27	4:33	0:06	HAND TRIPPED
422	29-Mar-2020	HASSAN	66	UDDUEKO-HASSAN1	UDDURKOPLU_66	6:00	13:31	7:31	MAIN SUPPLY FAILURE
423	29-Mar-2020	HASSAN	66	UDDUEKO-HASSAN2	UDDURKOPLU_66	4:12	4:33	0:21	LINE FAULT
424	29-Mar-2020	HASSAN	66	UDDUEKO-HASSAN2	UDDURKOPLU_66	6:00	13:31	7:31	MAIN SUPPLY FAILURE
425	29-Mar-2020	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	5:42	5:57	0:15	LINE FAULT
426	29-Mar-2020	MYSORE	66	KUSHALANAGARA-MYSORE-1	MIRLE_66, KRNAGARA_66, BILIKERE_66, BHERYA_66, GVGUDI_66 & DMG_HALLI_66	17:44	17:49	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
427	29-Mar-2020	MYSORE	66	KUSHALANAGARA-MYSORE-2	BETTADHAPURA_66, KITTUR_66, RAVANDUR_66 & CHUNCHUNKATTE_66( UPTO 17:55:00).	17:44	19:05	1:21	LINE FAULT
428	29-Mar-2020	MYSORE	220	KUSHALANAGARA-BASTIPURA-1	ALL DOWN STREAM STATIONS.	10:32	11:15	0:43	LINE FAULT
429	29-Mar-2020	MYSORE	220	KUSHALANAGARA-BASTIPURA-2	ALL DOWN STREAM STATIONS.	10:32	11:15	0:43	LINE FAULT
430	29-Mar-2020	MYSORE	66	TUBINKERE-MC-2	MANDYA_66, CHIKKA_MANDYA_66, KADKOTHANAHALLI_66,HAMPAP URA_66, KOPPA_66, BASARALU_66, BESAGARAHALLI_66,MALAVALLI_66 & HADLI_66	4:29	4:39	0:09	LINE FAULT
431	29-Mar-2020	MYSORE	66	TUBINKERE-NAGAMANGALA-1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	16:57	17:04	0:07	LINE FAULT
432	29-Mar-2020	MYSORE	66	TUBINKERE-NAGAMANGALA-1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	17:10	17:27	0:16	LINE FAULT
433	29-Mar-2020	MYSORE	66	MANDYA-M2	KADKOTHANAHALLI_66, MALAVALLI_66 & HADLI_66	8:10	8:15	0:05	LINE FAULT
434	29-Mar-2020	MYSORE	66	MANDYA-M2	KADKOTHANAHALLI_66, MALAVALLI_66 & HADLI_66	8:30	8:55	0:25	LINE FAULT
435	29-Mar-2020	MYSORE	66	HV2	BILIKERE_66	14:03	14:08	0:05	TRANSFORMER FAULT
436	29-Mar-2020	MYSORE	66	HV2	DUNDANAHALLI_66	10:02	10:56	0:54	LINE CLEAR AVAILED
437	29-Mar-2020	MYSORE	66	HV1	HANAGODU_66	7:23	7:34	0:11	TRANSFORMER FAULT
438	29-Mar-2020	MYSORE	66	HV2	HUNSUR_66	4:39	7:16	2:37	TRANSFORMER FAULT
439	29-Mar-2020	MYSORE	66	HV2	HUNSUR_66	7:20	14:20	6:59	LINE CLEAR AVAILED
440	29-Mar-2020	TUMKUR	110	TR-1	SAMPIGE_110	12:06	12:39	0:33	TRANSFORMER FAULT
441	29-Mar-2020	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	9:24	9:38	0:14	LINE FAULT
442	29-Mar-2020	TUMKUR	66	CHITRADURGA 220kV-HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	6:13	6:37	0:23	LINE FAULT
443	29-Mar-2020	TUMKUR	66	H D PURA- SUZLON	SUZLON	20:29	20:39	0:09	HAND TRIPPED
444	29-Mar-2020	TUMKUR	66	H D PURA-MMCLWINDMILL	MMCLWINDMILL_IPP_66	20:29	20:38	0:09	HAND TRIPPED
445	29-Mar-2020	TUMKUR	66	TR-2	HIREGUNTANUR_66	19:10	19:26	0:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
446	29-Mar-2020	TUMKUR	66	HONNALLI 220kV-BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	12:06	14:23	2:16	MAIN SUPPLY FAILURE
447	29-Mar-2020	TUMKUR	66	HONNALLI 220kV-BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	18:26	18:45	0:18	LINE FAULT
448	29-Mar-2020	TUMKUR	66	HONNALLI 220KV-KUNDUR	KUNDUR_66,MALEBENNUR_66	12:06	14:25	2:18	MAIN SUPPLY FAILURE
449	29-Mar-2020	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	13:17	13:30	0:13	MAIN SUPPLY FAILURE
450	29-Mar-2020	TUMKUR	66	TR-2(LV SIDE)	HONNALLI_220	12:06	14:19	2:13	LINE CLEAR AVAILED
451	29-Mar-2020	TUMKUR	66	TR-1	NEELAGUNDA_220	4:28	4:37	0:08	TRANSFORMER FAULT
452	29-Mar-2020	TUMKUR	66	PANDARAHALLI-HOLALKERE	HOLALKERE_66,HDPURA_66,	4:11	4:21	0:09	LINE FAULT
453	29-Mar-2020	TUMKUR	66	PANDARAHALLI-HOLALKERE	HOLALKERE_66,HDPURA_66,	8:08	8:18	0:09	LINE FAULT
454	29-Mar-2020	TUMKUR	66	PANDARAHALLI-HOLALKERE	HOLALKERE_66,HDPURA_66,	15:22	15:33	0:11	LINE FAULT
455	29-Mar-2020	TUMKUR	66	TR-1	TAVAREKERE(C)_66	12:05	13:32	1:26	MAIN SUPPLY FAILURE
456	29-Mar-2020	TUMKUR	66	TR-2	TAVAREKERE(C)_66	12:05	14:39	2:34	MAIN SUPPLY FAILURE
457	30-Mar-2020	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	4:55	5:06	0:11	LINE FAULT
458	30-Mar-2020	BAGALKOT	220	BELGAUM-CHIKKODI	BELGAUM_220	14:53	18:32	3:39	LINE FAULT
459	30-Mar-2020	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	22:16	22:18	0:02	TRANSFORMER FAULT
460	30-Mar-2020	BAGALKOT	220	NAGJHARI1-HUBLI	HUBLI_220	12:05	16:19	4:14	LINE FAULT
461	30-Mar-2020	BAGALKOT	110	MAMDAPUR(G)-TODALBAGI	TODALBAGI_110	9:17	11:14	1:57	LINE CLEAR AVAILED
462	30-Mar-2020	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110	3:53	3:55	0:02	LINE FAULT
463	30-Mar-2020	BAGALKOT	110	VAJRAMATTI220-SHIRAGUPPI(BILAGI)	SHIRAGUPPI_110	3:53	3:55	0:02	LINE FAULT
464	30-Mar-2020	BAGALKOT	110	110/11KV,HV2	SHIROL_110	12:18	14:04	1:46	LINE CLEAR AVAILED
465	30-Mar-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,NIVAR GI_33,DULKHED_33	22:03	22:13	0:10	TRANSFORMER FAULT
466	30-Mar-2020	BENGALURU	66	HV2	JIGANI LINK ROAD	11:45	11:55	0:10	LINE CLEAR AVAILED
467	30-Mar-2020	BENGALURU	66	HV2	JIGANI LINK ROAD	15:03	15:10	0:06	LINE CLEAR AVAILED
468	30-Mar-2020	BENGALURU	66	HV1	SURYANAGAR	8:20	8:39	0:18	LINE CLEAR AVAILED
469	30-Mar-2020	BENGALURU	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSUR RAMAPURA, NITRALLI	13:27	13:40	0:13	LINE FAULT
470	30-Mar-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	13:30	13:35	0:05	LINE FAULT
471	30-Mar-2020	BENGALURU	66	KGF - KYASAMBALLI	KYASAMBALLI	12:26	13:22	0:56	LINE CLEAR AVAILED
472	30-Mar-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	9:03	9:19	0:16	LINE FAULT
473	30-Mar-2020	BENGALURU	66	HV2	HAL 220	9:17	11:51	2:34	LINE CLEAR AVAILED
474	30-Mar-2020	BENGALURU	66	HEBBALA 220 - BANASAWADI	BANASAWADI	18:22	18:58	0:36	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
475	30-Mar-2020	BENGALURU	66	HV2	VIJAYANAGARA	18:45	18:48	0:03	TRANSFORMER FAULT
476	30-Mar-2020	GULBARGA	220	HV1, HV2	ITTAGI_220	5:55	6:05	0:10	TRANSFORMER FAULT
477	30-Mar-2020	GULBARGA	220	SHAHPUR-LINGASUGUR	LINGASUGUR_220	11:12	15:26	4:14	NFBC ISSUED
478	30-Mar-2020	GULBARGA	110	HALBURGA-KAMTHANA	KAMTHANA_110	18:04	18:10	0:06	LINE FAULT
479	30-Mar-2020	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110, DONGRAGOAN_110, KAMALNAGAR_110	18:20	18:25	0:05	LINE FAULT
480	30-Mar-2020	GULBARGA	110	SHAHPUR220-SHAHPUR	SHAHPUR_110	2:11	2:26	0:15	LINE FAULT
481	30-Mar-2020	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL_IPP	23:14	23:43	0:29	LINE FAULT
482	30-Mar-2020	GULBARGA	110	HV2	YEDRAMI_110	10:00	10:20	0:20	TRANSFORMER FAULT
483	30-Mar-2020	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALLI_66	5:55	6:36	0:41	LINE FAULT
484	30-Mar-2020	GULBARGA	66	ITTAGIHUVINAHADAGALI1	HUVINAHADAGALLI_66, HOLAGUNDI_66	12:16	12:37	0:21	LINE CLEAR AVAILED
485	30-Mar-2020	HASSAN	66	HV1	SHRAVANABELAGOLA_66	6:46	6:54	0:08	TRANSFORMER FAULT
486	30-Mar-2020	MYSORE	66	KADAKOLA-SARAGUR 2	B MATKERE_66, CHANDRAVADI_66, DOORA_66 , HURA_66, HULLAHALLI_66, SANTHESARAGUR_66	12:05	12:13	0:07	LINE FAULT
487	30-Mar-2020	MYSORE	66	KADAKOLA-SARAGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	12:05	12:12	0:06	LINE FAULT
488	30-Mar-2020	MYSORE	66	KADAKOLA-SARAGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	12:44	12:52	0:07	LINE FAULT
489	30-Mar-2020	MYSORE	66	KUSHALANAGARA 220-MYSORE-2	BETTADHAPURA_66, KITTUR_66, RAVANDUR_66 CHUNCHUNKATTE_66	17:48	18:57	1:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
490	30-Mar-2020	MYSORE	66	KUSHALANAGARA 220-MYSORE-1	BILIKERE_66, GVGUDI_66 DMG_HALLI_66, MIRLE_66, KRNAGARA_66	17:48	18:04	0:16	LINE FAULT
491	30-Mar-2020	MYSORE	66	HV1	KMDODDI_66	3:15	3:25	0:10	TRANSFORMER FAULT
492	30-Mar-2020	MYSORE	66	HV1	KADKOTHANAHALLI_66	12:15	13:05	0:50	HAND TRIPPED
493	30-Mar-2020	MYSORE	66	MADHUVANAHALLY-MAMBALLY	MAMBALLI_66	12:59	13:06	0:06	LINE FAULT
494	30-Mar-2020	MYSORE	66	HV4	SFCSHIVA_66	8:42	8:56	0:13	HAND TRIPPED
495	30-Mar-2020	MYSORE	66	HV4	SFCSHIVA_66	10:30	12:54	2:24	LINE CLEAR AVAILED
496	30-Mar-2020	MYSORE	66	HV5	SFCSHIVA_66	4:26	7:18	2:51	LINE CLEAR AVAILED
497	30-Mar-2020	MYSORE	66	HV1	SHIVALLY_66	9:27	10:17	0:49	LINE CLEAR AVAILED
498	30-Mar-2020	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	16:48	16:54	0:05	LINE FAULT
499	30-Mar-2020	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	17:43	17:50	0:06	LINE FAULT
500	30-Mar-2020	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66	10:16	10:23	0:06	LINE FAULT
501	30-Mar-2020	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	4:57	5:09	0:11	LINE FAULT
502	30-Mar-2020	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	10:48	10:58	0:10	LINE FAULT
503	30-Mar-2020	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66	4:56	5:08	0:11	LINE FAULT
504	30-Mar-2020	TUMKUR	66	MADHUGIRI 220kv-KORATAGERE 1	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	12:29	15:57	3:27	LINE CLEAR AVAILED
505	30-Mar-2020	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	11:08	15:57	4:49	LINE CLEAR AVAILED
506	30-Mar-2020	TUMKUR	66	MADHUGIRI 220kv-KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	11:28	12:24	0:55	LINE CLEAR AVAILED
507	30-Mar-2020	TUMKUR	66	MADHUGIRI 220kv-MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	12:29	15:57	3:27	LINE CLEAR AVAILED
508	30-Mar-2020	TUMKUR	66	MADHUGIRI 220kv- SIRA 1	SIRA_66,GULIGENAHALLI_66,	12:31	15:57	3:26	LINE CLEAR AVAILED
509	30-Mar-2020	TUMKUR	66	NEELAGUNDA-HARPANAHALLI-1	HARAPPANAHALLI_66	1:03	1:15	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	STN NAME	Open_at	Closed_At	Duration	REASON
510	30-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	10:23	10:34	0:11	LINE FAULT
511	30-Mar-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	13:41	14:13	0:31	LINE CLEAR AVAILED