

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 22.02.22 to 28.02.2022

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	22-Feb-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
2	22-Feb-2022	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVOIDED
3	22-Feb-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVOIDED
4	22-Feb-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN,LINE FAULT
5	22-Feb-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVOIDED
6	22-Feb-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVOIDED
7	22-Feb-2022	BAGALKOT	220	HAVERI- GUTTUR1	STATION NOT AFFECTED HAVERI_220	20:31 (21.02.2022)			LINE OPEN,LINE CLEAR AVOIDED
8	22-Feb-2022	BAGALKOT	110	AIGALI-SAVALAGI	SAVALAGI_110	4:00	4:10	0:10	LINE FAULT
9	22-Feb-2022	BAGALKOT	110	110/11KV,HV2	BABALESHWAR_110	14:45	15:22	0:37	LINE CLEAR AVOIDED
10	22-Feb-2022	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110 (STATION NOT AFFECTED)	18:37	20:08	1:31	LINE CLEAR AVOIDED
11	22-Feb-2022	BAGALKOT	110	110/11KV,HV2	CHANDKAVATE_110	15:27	15:43	0:16	HAND TRIPPED
12	22-Feb-2022	BAGALKOT	110	110/11KV,HV1	HEBBALLI_110	13:59	14:17	0:18	TRANSFORMER FAULT
13	22-Feb-2022	BAGALKOT	110	HOSA HONNATTI-GUTTAL	GUTTAL_110	0:02	0:23	0:21	LINE FAULT
14	22-Feb-2022	BAGALKOT	110	HOSA HONNATTI-GUTTAL	GUTTAL_110	1:07	7:30	6:23	LINE FAULT
15	22-Feb-2022	BAGALKOT	110	HOSA HONNATTI-GUTTAL	GUTTAL_110	11:46	12:57	1:11	LINE CLEAR AVOIDED
16	22-Feb-2022	BAGALKOT	110	110/11KV,HV1	MAMADAPUR_110	17:15	17:32	0:17	HAND TRIPPED
17	22-Feb-2022	BAGALKOT	110	110/33KV,HV4	HALASANGI_33,NEVARGI_33,DH ULKHED_33 ZALKI_110	9:05	9:10	0:05	TRANSFORMER FAULT
18	22-Feb-2022	BAGALKOT	110	SAVALAGI-YELLANAWADI	SAVALAGI_110	3:59	4:26	0:27	LINE FAULT
19	22-Feb-2022	BAGALKOT	110	AIGALI-YELLAMANAWADI	YELLAMANAWADI_110	4:00	4:10	0:10	LINE FAULT
20	22-Feb-2022	BAGALKOT	110	110/11KV,HV1	TOLAMATTI_110	3:36	5:38	2:02	LINE CLEAR AVOIDED
21	22-Feb-2022	BAGALKOT	110	110/33KV,HV2	TOLAMATTI_110, HERAKAL JACK WELL_33,	8:28	10:21	1:53	LINE CLEAR AVOIDED
22	22-Feb-2022	BAGALKOT	110	110/11KV,HV1	TOLAMATTI_110	8:28	10:20	1:52	LINE CLEAR AVOIDED
23	22-Feb-2022	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	11:30	14:20	2:50	NFBC ISSUED
24	22-Feb-2022	BAGALKOT	110	SHIRAGUPPI - BILAGI	BILAGI_110,BISNAL_110, GIRISAGAR_110, TOLAMATTI_110	8:20	10:20	2:00	MAIN SUPPLY FAILURE
25	22-Feb-2022	BAGALKOT	110	VAJRAMATTI220- SHIRAGUPPI	SHIRAGUPPI_110	8:20	9:50	1:30	LINE CLEAR AVOIDED
26	22-Feb-2022	BAGALKOT	110	SHIRAGUPPI - BILAGI LINE	SHIRAGUPPI_110	8:20	10:20	2:00	LINE CLEAR AVOIDED
27	22-Feb-2022	BAGALKOT	110	VAJRAMATTI220 -MANTUR2	MANTUR(B)_110	5:55	6:00	0:05	LINE FAULT
28	22-Feb-2022	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	13:59	17:40	3:41	LINE FAULT
29	22-Feb-2022	BAGALKOT	110	220/110KV,LV1	STATION NOT AFFECTED BIJAPUR_220	11:00	11:12	0:12	LINE CLEAR AVOIDED
30	22-Feb-2022	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED BIJAPUR_220	12:07	15:10	3:03	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
31	22-Feb-2022	BAGALKOT	110	BIJAPUR-(BAGEWADI)ENERCON	STATION NOT AFFECTED BIJAPUR_220	14:20	14:24	0:04	LINE FAULT
32	22-Feb-2022	BAGALKOT	400	DHONI- GUTTUR	STATION NOT AFFECTED DHONI_400	15:15	19:07	3:52	LINE FAULT
33	22-Feb-2022	BAGALKOT	110	MUDEDEBIHAL- KN SOLAR	STATION NOT AFFECTED MUDEDEBIHAL_110	7:00	17:00	10:00	LINE CLEAR AVOIDED
34	22-Feb-2022	BAGALKOT	110	MURDESHWAR- HONNAVAR (KRCL RAILWAY TRACTION)	STATION NOT AFFECTED MURDESHWAR_110	16:12	16:19	0:07	LINE FAULT
35	22-Feb-2022	BAGALKOT	110	RANEENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			LINE OPEN,LINE CLEAR AVOIDED
36	22-Feb-2022	BAGALKOT	110	MANTUR - NIRANI SUGARS	MANTUR(B)_110	5:55	6:10	0:15	LINE FAULT
37	22-Feb-2022	BAGALKOT	110	RANEENNUR- HOSAHONNATTI	RANEENNUR_220	0:02	0:12	0:10	LINE FAULT
38	22-Feb-2022	BAGALKOT	110	RANEENNUR- HOSAHONNATTI	RANEENNUR_220	1:06	1:16	0:10	LINE FAULT
39	22-Feb-2022	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED RANEENNUR_220	18:39	20:01	1:22	LINE CLEAR AVOIDED
40	22-Feb-2022	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	16:04	16:06	0:02	LINE FAULT
41	22-Feb-2022	BENGALURU	66	EXORA - CESSNA	EXORA	9:55	13:28	3:33	LINE CLEAR AVOIDED
42	22-Feb-2022	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	14:02	14:38	0:36	LINE CLEAR AVOIDED
43	22-Feb-2022	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	14:04	14:36	0:32	LINE CLEAR AVOIDED
44	22-Feb-2022	BENGALURU	66	HV2	ATTIBELE	9:30	9:35	0:05	LOAD CHANGE OVER
45	22-Feb-2022	BENGALURU	66	MELUR - VIJAYPURA	MELUR, JAGAMKOTE	19:15	19:30	0:15	LOAD CHANGE OVER
46	22-Feb-2022	BENGALURU	66	MELUR - SIDDLAGHATTA	MELUR, JAGAMKOTE	15:56	17:00	1:03	MAIN SUPPLY FAILURE
47	22-Feb-2022	BENGALURU	66	SIDLAGATTA - CHINTAMANI 220	SIDLAGATTA	15:56	18:24	2:28	LINE FAULT
48	22-Feb-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:39	11:44	0:04	LINE CLEAR AVOIDED
49	22-Feb-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	16:25	16:35	0:10	LINE CLEAR AVOIDED
50	22-Feb-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	17:45	17:51	0:06	LINE CLEAR AVOIDED
51	22-Feb-2022	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	16:14	17:50	1:36	LINE CLEAR AVOIDED
52	22-Feb-2022	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA	16:00	18:18	2:17	LINE CLEAR AVOIDED
53	22-Feb-2022	BENGALURU	66	HV2	N G HULKUR	17:18	17:45	0:26	LINE CLEAR AVOIDED
54	22-Feb-2022	BENGALURU	66	HV1	DOMMASANDRA	16:23	16:30	0:06	LINE CLEAR AVOIDED
55	22-Feb-2022	BENGALURU	66	HV1	CB PURA URBAN	16:05	17:13	1:08	TRANSFORMER FAULT
56	22-Feb-2022	BENGALURU	66	HV1	BANGARPET	16:00	16:15	0:15	LINE CLEAR AVOIDED
57	22-Feb-2022	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	17:40	18:20	0:40	LINE CLEAR AVOIDED
58	22-Feb-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
59	22-Feb-2022	GULBARGA	220	HV2	SINDHANOUR_220	12:37	12:47	0:10	TRANSFORMER FAULT
60	22-Feb-2022	GULBARGA	220	BTPSG-ALIPUR	ALIPUR_220	8:16	8:55	0:39	LINE FAULT
61	22-Feb-2022	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	11:07	12:35	1:28	NFBC ISSUED
62	22-Feb-2022	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	8:40	19:09	10:29	LINE CLEAR AVOIDED
63	22-Feb-2022	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	16:08	16:35	0:27	LINE CLEAR AVOIDED
64	22-Feb-2022	GULBARGA	220	SHAHABAD-KAPANOOR	KAPNOOR_220	16:08	16:35	0:27	LINE CLEAR AVOIDED
65	22-Feb-2022	GULBARGA	220	LINGASUGUR-MALLAT	MALLAT_220	12:08	15:07	2:59	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
66	22-Feb-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
67	22-Feb-2022	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110 ,DEVANGAON_110,RENUKA_IPP ,AFZALPUR_110,KARAJAGI_110	16:08(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
68	22-Feb-2022	GULBARGA	110	HV3	VALKAMDINNI_110	9:17	9:22	0:05	TRANSFORMER FAULT
69	22-Feb-2022	GULBARGA	110	HV1	TEKKALKOTE_110	10:17	19:53	9:36	LINE CLEAR AVAILED
70	22-Feb-2022	GULBARGA	110	HV2	HATTI_110	11:39	13:08	1:29	LINE CLEAR AVAILED
71	22-Feb-2022	GULBARGA	110	LV1	HUMNABAD_220	9:30	16:15	6:45	LINE CLEAR AVAILED
72	22-Feb-2022	GULBARGA	110	HV2	BISILAHALLI_110	8:17	8:33	0:16	TRANSFORMER FAULT
73	22-Feb-2022	GULBARGA	110	HV2	BISILAHALLI_110	13:25	13:50	0:25	TRANSFORMER FAULT
74	22-Feb-2022	GULBARGA	110	HV2	CHOWDAPUR_110	13:20	15:05	1:45	LINE CLEAR AVAILED
75	22-Feb-2022	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	21:57	22:05	0:08	LINE FAULT
76	22-Feb-2022	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	5:57	6:07	0:10	LINE FAULT
77	22-Feb-2022	GULBARGA	110	STARMETALLIC-MUNIRABAD	MUNIRABAD_220	1:09	1:17	0:08	LINE FAULT
78	22-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	0:33	0:40	0:07	LINE FAULT
79	22-Feb-2022	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHIKKASUGUR_110, SHAKTHINAGA_110	11:34	14:30	2:56	NFBC ISSUED
80	22-Feb-2022	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110, SHAKTHINAGA_110	11:35	11:40	0:05	LINE FAULT
81	22-Feb-2022	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110, SHAKTHINAGA_110	12:14	12:21	0:07	LINE FAULT
82	22-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:04	20:07	0:03	LINE FAULT
83	22-Feb-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	16:08	16:35	0:27	LINE CLEAR AVAILED
84	22-Feb-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YE RDONA_110,SRNAGAR_110,MA LLAPURA_110	1:49	1:59	0:10	LINE FAULT
85	22-Feb-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YE RDONA_110,SRNAGAR_110,MA LLAPURA_110	11:10	11:20	0:10	LINE FAULT
86	22-Feb-2022	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110,GANDHINAGAR _110	12:37	12:50	0:13	LINE FAULT
87	22-Feb-2022	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KE REHALLI_110,MALLAPUR_110	11:13	11:27	0:14	LINE FAULT
88	22-Feb-2022	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KE REHALLI_110,MALLAPUR_110	22:05	22:15	0:10	LINE FAULT
89	22-Feb-2022	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVATH I_110,DR NAGAR_110,KARATAGI_110	6:00	6:31	0:31	LINE FAULT
90	22-Feb-2022	GULBARGA	110	KAVITAL-GAMESHA	KAVITAL_110	18:44	19:29	0:45	LINE CLEAR AVAILED
91	22-Feb-2022	GULBARGA	110	ALIPUR-RVNL	RVNL_110	8:26	9:12	0:46	LINE FAULT
92	22-Feb-2022	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	13:56	14:04	0:08	LINE FAULT
93	22-Feb-2022	GULBARGA	110	CHINCHOLI-RENEW_SLR	CHINCHOLI_110	19:35	19:40	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
94	22-Feb-2022	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,UPANAYAKAN AHALLI_66,HAGARIBOMMANAH ALLI_66,RR STEELS IPP	1:05	1:15	0:10	LINE FAULT
95	22-Feb-2022	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINAHADGALI_66,HOLAGUNDI_66	8:45	9:20	0:35	LINE CLEAR AVAILED
96	22-Feb-2022	GULBARGA	66	ITTAGI-HIREHADGALI2	HIREHADGALI_66,GIRIYAPUR_66,MAGALA_66,SOVENHALLI_66,TUNGA BHADRA IPP	6:50	7:02	0:12	LINE FAULT
97	22-Feb-2022	HASSAN	110	HULICA-KVR	HULICAL_110	10:40 (21.02.2022)	8:39 (22.02.2022)	21:58 hrs	LINE CHARGED
98	22-Feb-2022	HASSAN	66	HV2	KANDLI_66	9:55 (21.02.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
99	22-Feb-2022	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
100	22-Feb-2022	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
101	22-Feb-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
102	22-Feb-2022	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
103	22-Feb-2022	HASSAN	220	UPCL-KEMAR1	upcl_gen	10:45	15:07	4:22	LINE CLEAR AVAILED
104	22-Feb-2022	HASSAN	400	TALAGU-NELAMANG2	TALAGUPPA_400	9:12	12:57	3:45	LINE CLEAR AVAILED
105	22-Feb-2022	HASSAN	66	HASSN22-BELUR	HASSAN_220	16:11	16:23	0:12	HAND TRIPPED
106	22-Feb-2022	HASSAN	66	HASSN22-SUZLON	HASSAN_220	16:11	16:26	0:15	HAND TRIPPED
107	22-Feb-2022	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	9:18	18:32	9:14	LINE CLEAR AVAILED
108	22-Feb-2022	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	9:10	18:41	9:31	LINE CLEAR AVAILED
109	22-Feb-2022	HASSAN	110	HV1	HALADY_110	9:03	18:33	9:30	LINE CLEAR AVAILED
110	22-Feb-2022	HASSAN	110	HV2	HALADY_110	9:29	18:36	9:07	LINE CLEAR AVAILED
111	22-Feb-2022	HASSAN	110	HV2	ESSUR_110	16:24	17:12	0:48	LINE CLEAR AVAILED
112	22-Feb-2022	HASSAN	110	LINE2	HEGGUNJE_220	9:19	18:28	9:09	NFBC ISSUED
113	22-Feb-2022	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	8:59	22:02	13:03	LINE CLEAR AVAILED
114	22-Feb-2022	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	8:39	18:32	9:53	NFBC ISSUED
115	22-Feb-2022	HASSAN	110	KADUR-NERELEKERE	KADUR_220	11:58	12:09	0:11	HAND TRIPPED
116	22-Feb-2022	HASSAN	110	HV1	KARKALA_110	10:28	13:00	2:32	LINE CLEAR AVAILED
117	22-Feb-2022	HASSAN	110	KMS110-MRS-ANDPR	KUMSI_110	10:00	18:00	8:00	LINE CLEAR AVAILED
118	22-Feb-2022	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	22:07	22:15	0:08	NFBC ISSUED
119	22-Feb-2022	HASSAN	110	HV2	MRSMG_220	9:12	12:55	3:43	LINE CLEAR AVAILED
120	22-Feb-2022	HASSAN	66	CRPATNA-HNPURA	CHANNARAYPATTANA_220	10:15	17:35	7:20	LINE CLEAR AVAILED
121	22-Feb-2022	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYPATTANA_220	12:02	15:52	3:50	LINE CLEAR AVAILED
122	22-Feb-2022	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYPATTANA_220	17:30	17:40	0:10	LINE FAULT
123	22-Feb-2022	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYPATTANA_220	17:45	20:40	2:55	LINE CLEAR AVAILED
124	22-Feb-2022	HASSAN	66	HV1	DODDAKADANUR_66	16:00	18:44	2:44	LINE CLEAR AVAILED
125	22-Feb-2022	HASSAN	66	HV1	HIRESAVE_66	10:44	18:57	8:13	LINE CLEAR AVAILED
126	22-Feb-2022	HASSAN	66	HV2	HIRESAVE_66	10:44	18:57	8:13	LINE CLEAR AVAILED
127	22-Feb-2022	HASSAN	66	MATTNAV-CRPATNA	MATTANAVILE_66	11:50	15:55	4:05	LINE CLEAR AVAILED
128	22-Feb-2022	HASSAN	66	MATTNAV-CRPATNA	MATTANAVILE_66	17:30	17:40	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
129	22-Feb-2022	HASSAN	66	MATTNAV-CRPATNA	MATTANAVILE_66	17:45	18:25	0:40	MAIN SUPPLY FAILURE
130	22-Feb-2022	HASSAN	66	MATTNAV-CRPATNA	MATTANAVILE_66	19:30	20:45	1:15	NFBC ISSUED
131	22-Feb-2022	HASSAN	66	HV2	SAKALAESHPUA_66	5:05	7:00	1:55	TRANSFORMER FAULT
132	22-Feb-2022	HASSAN	66	SAKALE-IPCL1	SAKALAESHPUA_66	9:30	17:15	7:45	LINE CLEAR AVAILED
133	22-Feb-2022	HASSAN	66	SAKALE-IPCL1	SAKALAESHPUA_66	9:30	17:15	7:45	LINE CLEAR AVAILED
134	22-Feb-2022	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	10:15	17:38	7:23	NFBC ISSUED
135	22-Feb-2022	HASSAN	66	HV1	SINGAPURA_66	12:30	14:30	2:00	LINE CLEAR AVAILED
136	22-Feb-2022	HASSAN	66	HV1	YESLUR_66	16:10	18:40	2:30	MAIN SUPPLY FAILURE
137	22-Feb-2022	MYSURU	66	HV1	ADICHUNCHANAGIRI_66	9:06	11:32	2:26	LINE CLEAR AVAILED
138	22-Feb-2022	MYSURU	66	HV1	AKKIHEBBAL_66	13:00	16:20	3:20	LINE CLEAR AVAILED
139	22-Feb-2022	MYSURU	66	HV2	AKKIHEBBAL_66	10:05	17:59	7:54	LINE CLEAR AVAILED
140	22-Feb-2022	MYSURU	66	AKKIHEBBAL-KR PETE1	AKKIHEBBAL_66	13:35	15:35	2:00	LINE CLEAR AVAILED
141	22-Feb-2022	MYSURU	66	AKKIHEBBAL-KR PETE2	NO STATIONS EFFECTED	13:35	15:35	2:00	LINE CLEAR AVAILED
142	22-Feb-2022	MYSURU	66	AKKIHEBBAL-KAVERI HYDRO	NO STATIONS EFFECTED	13:36	15:37	2:00	LINE CLEAR AVAILED
143	22-Feb-2022	MYSURU	66	BG NAGARA-HIRISAVE	KADABALLY_66	18:24	18:26	0:02	HAND TRIPPED
144	22-Feb-2022	MYSURU	66	BG NAGARA-HIRISAVE	KADABALLY_66	20:36	20:42	0:05	HAND TRIPPED
145	22-Feb-2022	MYSURU	66	DUNDANAHALLI-HULIYURDURGA	DUNDANAHALLI_66	9:50	18:20	8:30	LINE CLEAR AVAILED
146	22-Feb-2022	MYSURU	66	HV1	DEVANOORMYS_66	11:40	13:04	1:23	LINE CLEAR AVAILED
147	22-Feb-2022	MYSURU	66	GARUDANA UKKADA-SR PATNA	SRIRANGAPATNA_66	10:07	17:11	7:03	NFBC ISSUED
148	22-Feb-2022	MYSURU	66	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PG PALYA_66	10:17	16:00	5:42	NFBC ISSUED
149	22-Feb-2022	MYSURU	66	MALLAVALLI-TK HALLI	MALAVALLI_66	9:10	18:04	8:54	LINE CLEAR AVAILED
150	22-Feb-2022	MYSURU	66	NAGAMANGALA-JAKKANAHALLI	NO STATIONS EFFECTED	7:00	7:15	0:14	LINE FAULT
151	22-Feb-2022	MYSURU	220	KR PETE 220-HV 1	NO STATIONS EFFECTED	8:04	8:21	0:17	LINE FAULT
152	22-Feb-2022	MYSURU	220	KR PETE 220-HV 2	NO STATIONS EFFECTED	8:04	8:32	0:28	LINE FAULT
153	22-Feb-2022	MYSURU	66	KR PETE 220-SB HALLI 1	SANTHEBACHALLI_66 BGNAGARA_66 ADDIHALLI_66ADICHUNCHANA GIRI_66VADERALLI _66HARIYALDAMMATEMPLE_66	8:04	8:45	0:41	HAND TRIPPED
154	22-Feb-2022	MYSURU	66	KR PETE 220-SB HALLI 2	NO STATIONS EFFECTED	8:04	8:45	0:41	HAND TRIPPED
155	22-Feb-2022	MYSURU	66	KR PETE 220-BUKANAKERE	GANJIGERE_66SHEELUNERE_66 BOOKANAKERE_66CHINAKURALI 66	8:04	11:34	3:30	LINE FAULT
156	22-Feb-2022	MYSURU	66	KR PETE 220-MADESHWARAPURA	JAKKANAHALLY_66MADESWAR APURA_66	8:04	9:54	1:50	LINE FAULT
157	22-Feb-2022	MYSURU	66	KR PETE 220-K R PETE 1	KIKKERI_66AKKIHEBBAL_66KRPE T_66	8:04	8:45	0:41	HAND TRIPPED
158	22-Feb-2022	MYSURU	66	KR PETE 220-K R PETE 2	NO STATIONS EFFECTED	8:04	14:29	6:25	LINE CLEAR AVAILED
159	22-Feb-2022	MYSURU	66	KR PETE 220-C R PATNA	KRISHNAPURA_66ANEGOLAL_66	8:04	8:21	0:17	HAND TRIPPED
160	22-Feb-2022	MYSURU	66	VAJAMANGALA-HEBBANI	NO STATIONS EFFECTED	10:44	10:49	0:05	LINE FAULT
161	22-Feb-2022	MYSURU	66	VAJAMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	18:11	18:17	0:06	LINE FAULT
162	22-Feb-2022	MYSURU	66	VAJAMANGALA-HEBBANI	NO STATIONS EFFECTED	18:25	18:37	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
163	22-Feb-2022	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY _66NAGAMANGALA_66HARADA NAHALLI(JAK)_66KESLAGERE_66 BASARALU 66	6:59	7:06	0:07	LINE FAULT
164	22-Feb-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
165	22-Feb-2022	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
166	22-Feb-2022	MYSURU	66	HEBBANI-SFC 2	NO STATIONS EFFECTED	13:05:00 (21.02.2022)	16:23:00 (22.02.2022)	27:18HRS	LINE CHARGED
167	22-Feb-2022	TUMKUR	66	TR-1	MADHUGIRI_66	10:42:53 (21.2.22)			TRANSFORMER OPEN,LINE CLEAR AVAILED
168	22-Feb-2022	TUMKUR	220	THALLAK 220kV -HIRIYUR	SANEKERE_66, THALLAKK_220	17:21	18:14	0:52	LINE FAULT
169	22-Feb-2022	TUMKUR	220	TR-3	THALLAK_220	17:21	18:16	0:54	TRANSFORMER FAULT
170	22-Feb-2022	TUMKUR	220	THALLAK 220kV-CHITRADURGA	CHITRADURGA_220	17:21	17:59	0:37	LINE FAULT
171	22-Feb-2022	TUMKUR	110	CHIKKANAYAKANAHALLI- HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	21:44	21:47	0:03	LINE FAULT
172	22-Feb-2022	TUMKUR	110	TR-1	THIMMASANDRA_66	10:30	21:05	10:35	LINE CLEAR AVAILED
173	22-Feb-2022	TUMKUR	66	TR-1	BHARAMAGIRI_66	11:55	12:05	0:10	TRANSFORMER FAULT
174	22-Feb-2022	TUMKUR	66	TR-2	BHARAMAGIRI_66	14:30	14:40	0:10	TRANSFORMER FAULT
175	22-Feb-2022	TUMKUR	66	TR-1	CHALLAKERE_66	7:35	9:29	1:54	TRANSFORMER FAULT
176	22-Feb-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	8:07	8:21	0:14	LINE FAULT
177	22-Feb-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	8:21	8:22	0:01	LINE FAULT
178	22-Feb-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	8:42	8:52	0:10	LINE FAULT
179	22-Feb-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:32	10:44	0:12	LINE FAULT
180	22-Feb-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:17	18:38	0:21	LINE FAULT
181	22-Feb-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:38	18:40	0:01	LINE FAULT
182	22-Feb-2022	TUMKUR	66	TR-1	RAMAPURA_66	18:45	18:50	0:04	TRANSFORMER FAULT
183	22-Feb-2022	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	THALLAK 220kV	11:15	11:23	0:07	LINE FAULT
184	22-Feb-2022	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	THALLAK 220kV	12:59	13:11	0:12	LINE FAULT
185	22-Feb-2022	TUMKUR	66	TR-1(HV &LV)	THALLAK 220kV	12:59	13:10	0:10	TRANSFORMER FAULT
186	22-Feb-2022	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR IPP_66	MYLANAHALLI_66, DYAVARANAHALLI_66	12:59	13:12	0:13	LINE FAULT
187	22-Feb-2022	TUMKUR	66	THALLAK 220kV- NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLANAHOLE_66	12:59	13:31	0:32	LINE FAULT
188	22-Feb-2022	TUMKUR	66	THALLAK 220kV - BGKERE 1	BGKERE 1	12:59	13:13	0:13	LINE FAULT
189	22-Feb-2022	TUMKUR	66	THALLAK 220kV - BGKERE 2	BGKERE 2	12:59	13:13	0:13	LINE FAULT
190	22-Feb-2022	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	CHALLAKERE_66, SANIKERE_66	12:59	13:13	0:13	LINE FAULT
191	22-Feb-2022	TUMKUR	66	THALLAK 220kV- THALLAK	SEI VENUS DIAMOND_ IPP_66	12:59	13:10	0:10	LINE FAULT
192	22-Feb-2022	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	THALLAK 220kV	12:59	13:11	0:11	LINE FAULT
193	22-Feb-2022	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	14:54	16:22	1:28	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
194	23-Feb-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
195	23-Feb-2022	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
196	23-Feb-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
197	23-Feb-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN,LINE FAULT
198	23-Feb-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
199	23-Feb-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
200	23-Feb-2022	BAGALKOT	220	HAVERI- GUTTUR1	STATION NOT AFFECTED HAVERI_220	20:31 (21.02.2022)			LINE OPEN,LINE CLEAR AVAILED
201	23-Feb-2022	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			LINE OPEN,LINE CLEAR AVAILED
202	23-Feb-2022	BAGALKOT	110	110/11KV,HV2	ALMEL_110	9:00	9:23	0:23	LINE CLEAR AVAILED
203	23-Feb-2022	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	10:33	12:19	1:46	LINE CLEAR AVAILED
204	23-Feb-2022	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	13:11 (23.02.2022)			LINE OPEN,LINE CLEAR AVAILED
205	23-Feb-2022	BAGALKOT	110	BIDNAL(GOPANAKOPPA)-GADAG ROAD	GADAG ROAD_110	14:21	14:46	0:25	HAND TRIPPED
206	23-Feb-2022	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110 (STATION NOT AFFECTED)	10:36	16:05	5:29	LINE CLEAR AVAILED
207	23-Feb-2022	BAGALKOT	110	HUBLI-KALAGHATGI	KALGHATGI_110 (STATION NOT AFFECTED)	10:29	15:54	5:25	LINE CLEAR AVAILED
208	23-Feb-2022	BAGALKOT	110	110/33KV,HV3	MUNAVALLI_110 &MUNAVALLI,MALLUR_33	17:50	18:28	0:38	LINE CLEAR AVAILED
209	23-Feb-2022	BAGALKOT	110	HUBLI-TARIHAL1	STATION NOT AFFECTED HUBLI_220	10:55	15:53	4:58	LINE CLEAR AVAILED
210	23-Feb-2022	BAGALKOT	110	HUBLI-PH COMPOUND	STATION NOT AFFECTED HUBLI_220	10:55	15:02	4:07	LINE CLEAR AVAILED
211	23-Feb-2022	BAGALKOT	110	HUBLI-SIRSI(KALAGATAGI)	STATION NOT AFFECTED HUBLI_220	10:55	15:50	4:55	LINE CLEAR AVAILED
212	23-Feb-2022	BAGALKOT	110	HUBLI-KADANAKOPPA	STATION NOT AFFECTED HUBLI_220	10:55	15:59	5:04	LINE CLEAR AVAILED
213	23-Feb-2022	BAGALKOT	110	HUBLI-RAMANAKOPPA	STATION NOT AFFECTED HUBLI_220	15:36	21:59	6:23	LINE CLEAR AVAILED
214	23-Feb-2022	BAGALKOT	110	220/110KV,HV3,LV3	STATION NOT AFFECTED HUBLI_220	15:55	21:47	5:52	LINE CLEAR AVAILED
215	23-Feb-2022	BAGALKOT	110	HUBLI-TARIHAL2	STATION NOT AFFECTED HUBLI_220	16:18	21:57	5:39	LINE CLEAR AVAILED
216	23-Feb-2022	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUNDATTI_220	13:04	16:54	3:50	LINE FAULT
217	23-Feb-2022	BAGALKOT	110	110/33KV,HV4	DULKHED_33,HALASANGI_33,N EVARGI_33 ZALKI_110	7:05	7:13	0:08	TRANSFORMER FAULT
218	23-Feb-2022	BAGALKOT	110	TAKKALAKI-WARADA SOLAR	STATION NOT AFFECTED TAKKALAKI_110	19:30	22:56	3:26	LINE CLEAR AVAILED
219	23-Feb-2022	BAGALKOT	110	SANKESHWAR-HSFCG(HIRA SUGAR 1)	STATION NOT AFFECTED SANKESHWAR_110	16:20 (23.02.2022)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
220	23-Feb-2022	BAGALKOT	110	HUBLI-RAMANAKOPPA	STATION NOT AFFECTED RAMANAKOPPA_110	15:28	22:02	6:34	NFBC ISSUED
221	23-Feb-2022	BAGALKOT	110	HUBLI-PH COMPOUND	STATION NOT AFFECTED PH COMPOUND_110	8:37	15:02	6:25	NFBC ISSUED
222	23-Feb-2022	BAGALKOT	110	NAVALGUND-KONNUR	STATION NOT AFFECTED NAVALGUND_110	9:20	11:37	2:17	LINE CLEAR AVAILED
223	23-Feb-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED NAVALGUND_110	10:50	11:16	0:26	LINE CLEAR AVAILED
224	23-Feb-2022	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	14:16	19:08	4:52	LINE FAULT
225	23-Feb-2022	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:09	21:57	5:48	NFBC ISSUED
226	23-Feb-2022	BAGALKOT	110	RANEBENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEBENNUR_220	18:42 (14.02.2022)			LINE OPEN,LINE CLEAR AVAILED
227	23-Feb-2022	BAGALKOT	110	110/11KV,HV2	UDIKERI_110	18:15	18:45	0:30	LINE CLEAR AVAILED
228	23-Feb-2022	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED NAVALGUND_110	11:37	12:19	0:42	LINE CLEAR AVAILED
229	23-Feb-2022	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	9:43	10:15	0:32	MAIN SUPPLY FAILURE
230	23-Feb-2022	BENGALURU	66	SHOBHA CITY - MANYATHA TECH PARK 220	SHOBHA CITY	8:59	9:23	0:24	MAIN SUPPLY FAILURE
231	23-Feb-2022	BENGALURU	66	SHOBHA CITY - HENNUR CROSS	SHOBHA CITY	9:43	11:17	1:34	MAIN SUPPLY FAILURE
232	23-Feb-2022	BENGALURU	66	MANYATHA TECH PARK 220 - HOSKOTE 2	SHOBHA CITY	8:59	9:23	0:24	LINE FAULT
233	23-Feb-2022	BENGALURU	220	HV2	MANYATHA TECH PARK 220	8:59	9:24	0:25	TRANSFORMER FAULT
234	23-Feb-2022	BENGALURU	66	HV3	MANYATHA TECH PARK 220	8:59	9:24	0:25	LINE CLEAR AVAILED
235	23-Feb-2022	BENGALURU	66	HV1	SURANAGARA	12:04	18:18	6:14	LINE CLEAR AVAILED
236	23-Feb-2022	BENGALURU	66	SURANAGARA - YARANDANAHALLI 220	SURANAGARA	12:04	17:07	5:03	LINE CLEAR AVAILED
237	23-Feb-2022	BENGALURU	66	TK HALLI 220 - MANDYA 1	NO STATION AFFECTED	11:38	17:16	5:38	LINE CLEAR AVAILED
238	23-Feb-2022	BENGALURU	66	HV1	MANCHENAHALLI	10:23	10:30	0:06	LINE CLEAR AVAILED
239	23-Feb-2022	BENGALURU	66	HV2	MAASTHI	9:10	9:23	0:13	TRANSFORMER FAULT
240	23-Feb-2022	BENGALURU	66	HV1	MAASTHI	11:12	11:30	0:18	TRANSFORMER FAULT
241	23-Feb-2022	BENGALURU	66	VIDYANAGAR -HENNUR CROSS	HENNUR CROSS	9:40	10:15	0:34	LINE FAULT
242	23-Feb-2022	BENGALURU	66	TEKAL - MALUR	TEKAL, BUDIKOTE, TORALAKKI	9:38	9:50	0:11	LINE FAULT
243	23-Feb-2022	GULBARGA	400	RTPS-RAICHUR1	RTPS_400	9:42	10:39	0:57	LINE FAULT
244	23-Feb-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
245	23-Feb-2022	GULBARGA	220	HUMNABAD -HALBARGA 1	HALBARGA_220	16:50	17:20	0:30	LINE CLEAR AVAILED
246	23-Feb-2022	GULBARGA	220	HUMNABAD-KAPNOOR 1	HUMNABAD_220	17:35	17:40	0:05	LINE CLEAR AVAILED
247	23-Feb-2022	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	9:00	19:18	10:18	LINE CLEAR AVAILED
248	23-Feb-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
249	23-Feb-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	23:14 (23.02.2022)			LINE OPEN,LINE CLEAR AVAILED
250	23-Feb-2022	GULBARGA	110	HV2	HATTI_110	8:36	9:54	1:18	LINE CLEAR AVAILED
251	23-Feb-2022	GULBARGA	110	LV1	HUMNABAD_220	10:25	15:45	5:20	LINE CLEAR AVAILED
252	23-Feb-2022	GULBARGA	110	HV1	HUNSAGI_110	19:05	19:30	0:25	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
253	23-Feb-2022	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	16:08(22.02.2022)	11:13(23.02.2022)	19:05HRS	LINE CHARGED
254	23-Feb-2022	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDIN NI_110	5:52	6:05	0:13	LINE FAULT
255	23-Feb-2022	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDIN NI_110	21:09	21:21	0:12	LINE FAULT
256	23-Feb-2022	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDIN NI_110	21:43	22:00	0:17	LINE FAULT
257	23-Feb-2022	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KE REHALLI_110,MALLAPUR_110	4:20	4:30	0:10	LINE FAULT
258	23-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	10:16	10:27	0:11	LINE FAULT
259	23-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	10:16	10:27	0:11	LINE FAULT
260	23-Feb-2022	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	12:36	12:46	0:10	LINE CLEAR AVAILED
261	23-Feb-2022	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	17:14	17:24	0:10	LINE CLEAR AVAILED
262	23-Feb-2022	GULBARGA	110	UCHCHANGI DURGA-BILCHOD	BILCHOD_66	0:20	0:30	0:10	LINE FAULT
263	23-Feb-2022	GULBARGA	110	YERADONA-BENUR	BENUR_110	5:05	5:10	0:05	LINE FAULT
264	23-Feb-2022	GULBARGA	110	JAWALGERA-ADAVIAMARESHWAR	ADAVI AMARESHWAR_110	20:50	20:55	0:05	LINE FAULT
265	23-Feb-2022	GULBARGA	110	JAWALGERA-ADAVIAMARESHWAR	ADAVI AMARESHWAR_110	21:55	22:00	0:05	LINE FAULT
266	23-Feb-2022	GULBARGA	110	LADHA-RENEW SLR	LADHA_110	18:30	23:56	5:26	LINE CLEAR AVAILED
267	23-Feb-2022	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	10:35	10:40	0:05	MAIN SUPPLY FAILURE
268	23-Feb-2022	GULBARGA	66	HV1	BENNEHALLI_66	11:40	11:50	0:10	TRANSFORMER FAULT
269	23-Feb-2022	GULBARGA	66	HV1	KUDLIGI_220	13:25	13:45	0:20	TRANSFORMER FAULT
270	23-Feb-2022	GULBARGA	66	HOSALLI-SML_WND	HOSAHALLI_66	6:25	6:35	0:10	LINE FAULT
271	23-Feb-2022	GULBARGA	66	UCHCHANGIDURGA-BILCHOD	BILCHOD_66	0:20	0:30	0:10	LINE FAULT
272	23-Feb-2022	HASSAN	66	HV2	KANDLI_66	9:55 (21.02.2022)	18:55(23.02.2022)	56:59 hrs	TRANSFORMER CHARGED
273	23-Feb-2022	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
274	23-Feb-2022	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
275	23-Feb-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
276	23-Feb-2022	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
277	23-Feb-2022	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	9:33	9:47	0:14	LINE FAULT
278	23-Feb-2022	HASSAN	220	HV2	PUTTUR_220	9:34	15:18	5:44	LINE CLEAR AVAILED
279	23-Feb-2022	HASSAN	110	LV2	PUTTUR_220	9:34	15:18	5:44	LINE CLEAR AVAILED
280	23-Feb-2022	HASSAN	110	KADUR-NGNHL	KADUR_220	11:01	13:10	2:09	LINE CLEAR AVAILED
281	23-Feb-2022	HASSAN	110	HV1	MRSMSG_220	9:03	13:41	4:38	LINE CLEAR AVAILED
282	23-Feb-2022	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	9:46	10:54	1:08	LINE CLEAR AVAILED
283	23-Feb-2022	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	11:19	11:25	0:06	LINE FAULT
284	23-Feb-2022	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	11:52	11:58	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
285	23-Feb-2022	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	16:55	17:06	0:11	LINE FAULT
286	23-Feb-2022	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	9:46	10:54	1:08	NFBC ISSUED
287	23-Feb-2022	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	16:55	17:06	0:11	LINE FAULT
288	23-Feb-2022	HASSAN	66	HV1	SAKALAESH PURA_66	5:05	7:00	1:55	TRANSFORMER FAULT
289	23-Feb-2022	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	9:40	18:10	8:30	NFBC ISSUED
290	23-Feb-2022	MYSURU	66	KADAKOLA-THANDYA	NO STATIONS EFFECTED	13:19	15:53	2:34	LINE FAULT
291	23-Feb-2022	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	NO STATIONS EFFECTED	11:15	11:59	0:44	LINE CLEAR AVAILED
292	23-Feb-2022	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	NO STATIONS EFFECTED	7:45	9:05	1:20	LINE CLEAR AVAILED
293	23-Feb-2022	MYSURU	66	TUBINAKERE-ARAKERE	ARKERE_66 TARIPURA_66 GAMANALLY_66	10:40	12:20	1:40	LINE CLEAR AVAILED
294	23-Feb-2022	MYSURU	220	C R NAGARA- MADHUVANAHALLI 1	NO STATIONS EFFECTED	10:46	12:48	2:02	LINE CLEAR AVAILED
295	23-Feb-2022	MYSURU	220	C R NAGARA- MADHUVANAHALLI 2	NO STATIONS EFFECTED	13:14	14:56	1:42	LINE CLEAR AVAILED
296	23-Feb-2022	MYSURU	66	HV4	KUSHALANAGARA_66	22:11	22:30	0:19	TRANSFORMER FAULT
297	23-Feb-2022	MYSURU	66	HV4	KUSHALANAGARA_66	22:42	22:45	0:03	HAND TRIPPED
298	23-Feb-2022	MYSURU	66	THANDYA-NANJANGUDU	THANDYA_66	8:09	9:25	1:16	LINE FAULT
299	23-Feb-2022	MYSURU	66	THANDYA-ITC	NO STATIONS EFFECTED	8:09	9:30	1:21	MAIN SUPPLY FAILURE
300	23-Feb-2022	MYSURU	66	THANDYA-ITC	NO STATIONS EFFECTED	9:45	9:47	0:02	LINE FAULT
301	23-Feb-2022	MYSURU	66	THANDYA-KADAKOLA	NO STATIONS EFFECTED	8:09	15:53	7:44	LINE FAULT
302	23-Feb-2022	MYSURU	66	KIADB MANDYA-TK HALLI	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66TUMBEKERE _66 MADDUR_66SOMANAHALLI_66	11:23	11:38	0:15	HAND TRIPPED
303	23-Feb-2022	MYSURU	66	GAMANAHALLI-TUBINKERE	GAMANAHALLY_66	9:00	17:30	8:30	LINE CLEAR AVAILED
304	23-Feb-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
305	23-Feb-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
306	23-Feb-2022	TUMKUR	66	TR-1	MADHUGIRI_66	10:42:53 (21.2.22)			TRANSFORMER OPEN,LINE CLEAR AVAILED
307	23-Feb-2022	TUMKUR	400	GUTTUR 400kv-Beeranahalli1	GUTUR_400	9:44	16:40	6:55	LINE CLEAR AVAILED
308	23-Feb-2022	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	9:13	20:49	11:35	LINE CLEAR AVAILED
309	23-Feb-2022	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	10:05	14:27	4:22	LINE CLEAR AVAILED
310	23-Feb-2022	TUMKUR	220	TR-1(HV SIDE)	HIRIYUR_220	14:32	18:38	4:06	LINE CLEAR AVAILED
311	23-Feb-2022	TUMKUR	220	GUTTUR 400kv-DAVANAGERE3	DAVANGERE_SRS_220	9:13	20:50	11:37	LINE CLEAR AVAILED
312	23-Feb-2022	TUMKUR	220	TR-1	KIADB V N PURA_220	15:31	15:38	0:06	LINE CLEAR AVAILED
313	23-Feb-2022	TUMKUR	220	TR-2	KIADB V N PURA_220	16:50	20:33	3:43	LINE CLEAR AVAILED
314	23-Feb-2022	TUMKUR	110	TR-1	MAYASANDRA_110	11:13	11:18	0:05	TRANSFORMER FAULT
315	23-Feb-2022	TUMKUR	66	TR-2	BHARAMAGIRI_66	14:35	14:40	0:05	TRANSFORMER FAULT
316	23-Feb-2022	TUMKUR	66	TR-2	BHARAMAGIRI_66	22:04	22:10	0:05	TRANSFORMER FAULT
317	23-Feb-2022	TUMKUR	66	TR-2	BHARAMAGIRI_66	10:30	10:50	0:20	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
318	23-Feb-2022	TUMKUR	66	TR-1	BRAMASANDRA_66	8:10	17:17	9:06	LINE CLEAR AVAILED
319	23-Feb-2022	TUMKUR	66	TR-2	BRAMASANDRA_66	9:54	10:06	0:11	TRANSFORMER FAULT
320	23-Feb-2022	TUMKUR	66	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	6:35	6:50	0:15	LINE FAULT
321	23-Feb-2022	TUMKUR	66	DEVARAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66	13:22	13:25	0:03	LINE FAULT
322	23-Feb-2022	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	11:41	11:46	0:04	HAND TRIPPED
323	23-Feb-2022	TUMKUR	66	TR-3(LV SIDE)	HIRIYUR_220	10:03	14:27	4:24	LINE CLEAR AVAILED
324	23-Feb-2022	TUMKUR	66	TR-1(LV SIDE)	HIRIYUR_220	14:35	18:40	4:05	LINE CLEAR AVAILED
325	23-Feb-2022	TUMKUR	66	HIRIYUR220-MATHOD 1	MATHOD_66,HINDASGHATTA_6 6,KANCHIPURA_66,GARAGA_66, PANCHANAHALLI_66,HOSADUR GA_66	10:25	10:50	0:25	HAND TRIPPED
326	23-Feb-2022	TUMKUR	66	HIRIYUR220-MATHOD 2	MATHOD_66,HINDASGHATTA_6 6,KANCHIPURA_66,GARAGA_66, PANCHANAHALLI_66,HOSADUR GA_66	10:25	10:50	0:25	HAND TRIPPED
327	23-Feb-2022	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELA GUNDA_66	11:02	11:44	0:41	LINE CLEAR AVAILED
328	23-Feb-2022	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	13:01	13:06	0:04	LINE FAULT
329	23-Feb-2022	TUMKUR	66	TR-2	KOLALA_66	16:33	17:57	1:23	LINE CLEAR AVAILED
330	23-Feb-2022	TUMKUR	66	TR-2	KOLALA_66	9:32	10:11	0:39	LINE CLEAR AVAILED
331	23-Feb-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	6:01	7:01	1:00	LINE CLEAR AVAILED
332	23-Feb-2022	TUMKUR	66	TR-1	PDKOTE_66	14:06	14:18	0:12	TRANSFORMER FAULT
333	23-Feb-2022	TUMKUR	66	PAVAGADA220-SHYLAPURA_66	SHYLAPURA_66	14:13	14:22	0:08	LINE FAULT
334	23-Feb-2022	TUMKUR	66	PAVAGADA220-NAGALAMADIKE66	NAGALAMADIKE_66	18:35	18:42	0:07	LINE FAULT
335	23-Feb-2022	TUMKUR	66	SAILAPURA66-PR PURA66	PR PURA_66,LINGADHALLI_66	14:31	18:46	4:14	MAIN SUPPLY FAILURE
336	23-Feb-2022	TUMKUR	66	SASALUHALLA66-CHIKKAJAJUR66(SRS DAVANAGERE)	SASALUHALLA_66	13:42	15:02	1:20	LINE CLEAR AVAILED
337	24-Feb-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
338	24-Feb-2022	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
339	24-Feb-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
340	24-Feb-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN,LINE FAULT
341	24-Feb-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
342	24-Feb-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
343	24-Feb-2022	BAGALKOT	220	HAVERI- GUTTUR1	STATION NOT AFFECTED HAVERI_220	20:31 (21.02.2022)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
344	24-Feb-2022	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	13:11 (23.02.2022)			LINE OPEN,LINE CLEAR AVAILED
345	24-Feb-2022	BAGALKOT	110	RANEENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			LINE OPEN,LINE CLEAR AVAILED
346	24-Feb-2022	BAGALKOT	110	SANKESHWAR-HSFCG(HIRA SUGAR 1)	STATION NOT AFFECTED SANKESHWAR_110	16:20 (23.02.2022)	15:59 (24.02.2022)	23:39HRS	LINE CHARGED
347	24-Feb-2022	BAGALKOT	110	110/11KV,HV2	ALMEL_110	15:02	16:11	1:09	LINE CLEAR AVAILED
348	24-Feb-2022	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110 &(KOLIWAD_33)	8:44	9:08	0:24	HAND TRIPPED
349	24-Feb-2022	BAGALKOT	110	HUBLI-KADANAKOPPA_110	KADANAKOPPA_110 (STATION NOT AFFECTED)	10:53	17:34	6:41	NFBC ISSUED
350	24-Feb-2022	BAGALKOT	110	110/11KV,HV1	KALAGHTGI_110	8:23	12:36	4:13	TRANSFORMER FAULT
351	24-Feb-2022	BAGALKOT	110	KANABARGI LAY OUT- NEHRU NAGAR	STATION NOT AFFECTED KANABARGI LAY OUT_110	9:58	13:44	3:46	NFBC ISSUED
352	24-Feb-2022	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	11:33	20:05	8:32	LINE CLEAR AVAILED
353	24-Feb-2022	BAGALKOT	110	YADAWAD-ISEL(IZARA)	STATION NOT AFFECTED YADAWAD_110	6:38	6:51	0:13	LINE FAULT
354	24-Feb-2022	BAGALKOT	110	110/11KV,HV2	TIKOTA_110	4:39	4:43	0:04	TRANSFORMER FAULT
355	24-Feb-2022	BAGALKOT	110	TAKKALAKI-KN SOLAR	STATION NOT AFFECTED TAKKALAKI_110	18:41	23:16	4:35	LINE CLEAR AVAILED
356	24-Feb-2022	BAGALKOT	110	SIRSI-KUMTA2	STATION NOT AFFECTED SIRSI_110	12:43	15:32	2:49	LINE FAULT
357	24-Feb-2022	BAGALKOT	110	110/11KV,HV2	SIRSI_110	12:43	14:46	2:03	LINE CLEAR AVAILED
358	24-Feb-2022	BAGALKOT	110	110/11KV,HV1	SIRSI_110	14:46	17:57	3:11	LINE CLEAR AVAILED
359	24-Feb-2022	BAGALKOT	110	SALAHALLI-GMNAVAR	STATION NOT AFFECTED SALAHALLI_110	7:47	8:26	0:39	LINE FAULT
360	24-Feb-2022	BAGALKOT	110	110/11KV, HV1	UMMACHAGI_110	16:13	18:34	2:21	LINE CLEAR AVAILED
361	24-Feb-2022	BAGALKOT	110	BAGALKOT220- KALADAGI	KALADAGI_110	6:26	6:57	0:31	HAND TRIPPED
362	24-Feb-2022	BAGALKOT	220	220/110KV,HV1	STATION NOT AFFECTED BAGALKOT_220	6:26	6:41	0:15	TRANSFORMER FAULT
363	24-Feb-2022	BAGALKOT	110	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	6:26	6:45	0:19	TRANSFORMER FAULT
364	24-Feb-2022	BAGALKOT	220	AMBEWADI-NAGJHARI2	STATION NOT AFFECTED AMBEWADI_220	11:11	14:48	3:37	LINE CLEAR AVAILED
365	24-Feb-2022	BAGALKOT	110	MUGALKOD- SULTANPUR	STATION NOT AFFECTED MUGALKOD_220	16:05	17:00	0:55	NFBC ISSUED
366	24-Feb-2022	BAGALKOT	220	MAHALINGAPUR- MUGALKOD	STATION NOT AFFECTED MUGALKOD_220	16:06	17:05	0:59	NFBC ISSUED
367	24-Feb-2022	BAGALKOT	220	HUBLI- SIRSI1	STATION NOT AFFECTED HUBLI_220	10:33	18:17	7:44	LINE CLEAR AVAILED
368	24-Feb-2022	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	10:34	18:17	7:43	LINE CLEAR AVAILED
369	24-Feb-2022	BAGALKOT	110	HUBLI- KADANKOPPA	STATION NOT AFFECTED HUBLI_220	11:06	17:33	6:27	LINE CLEAR AVAILED
370	24-Feb-2022	BAGALKOT	220	220/110KV, HV1& LV1	STATION NOT AFFECTED HUBLI_220	9:12	13:48	4:36	LINE CLEAR AVAILED
371	24-Feb-2022	BAGALKOT	110	CHIKKODI220- CHIKKODI	CHIKKODI_110	9:40	10:25	0:45	LINE FAULT
372	24-Feb-2022	BAGALKOT	110	BAGALKOT220-NEERABUDIHAL	NEERABUDIHAL_110	6:26	6:55	0:29	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
373	24-Feb-2022	BAGALKOT	220	AMBEWADI-NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	11:37	14:48	3:11	LINE CLEAR AVOIDED
374	24-Feb-2022	BAGALKOT	110	110/11KV, HV1	UDIKERI_110	18:15	18:30	0:15	LINE CLEAR AVOIDED
375	24-Feb-2022	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	18:06	18:11	0:05	LOAD CHANGE OVER
376	24-Feb-2022	BENGALURU	66	HV1	GLOBAL TECH PARK	10:23	10:38	0:15	LOAD CHANGE OVER
377	24-Feb-2022	BENGALURU	66	GLOBAL TECH PARK - DEVARABISANAHALLI	GLOBAL TECH PARK	12:33	14:53	2:20	LINE CLEAR AVOIDED
378	24-Feb-2022	BENGALURU	66	HV1	KHB	13:25	13:35	0:10	LINE CLEAR AVOIDED
379	24-Feb-2022	BENGALURU	66	HV2	ATTUR YELAHANKA	10:52	10:56	0:04	LINE CLEAR AVOIDED
380	24-Feb-2022	BENGALURU	66	HV1	ATTUR YELAHANKA	12:19	12:22	0:03	LINE CLEAR AVOIDED
381	24-Feb-2022	BENGALURU	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	18:35	18:45	0:10	LINE FAULT
382	24-Feb-2022	BENGALURU	66	HV2	BAIRAKURU	14:25	18:24	3:59	LINE CLEAR AVOIDED
383	24-Feb-2022	BENGALURU	66	HV1	CHAKAVELU	13:20	13:34	0:13	TRANSFORMER FAULT
384	24-Feb-2022	BENGALURU	66	HV2	DOMMASANDRA	16:22	17:50	1:28	LINE CLEAR AVOIDED
385	24-Feb-2022	BENGALURU	66	HV2	HUKUNDA	19:25	19:35	0:09	TRANSFORMER FAULT
386	24-Feb-2022	BENGALURU	66	HV2	HUKUNDA	9:40	10:30	0:50	LINE CLEAR AVOIDED
387	24-Feb-2022	BENGALURU	66	HV1	HUKUNDA	9:00	9:40	0:40	LINE CLEAR AVOIDED
388	24-Feb-2022	BENGALURU	66	HV2	JULLUPALYA	15:30	16:00	0:30	LINE CLEAR AVOIDED
389	24-Feb-2022	BENGALURU	66	HV1	JULLUPALYA	12:15	12:20	0:05	LINE CLEAR AVOIDED
390	24-Feb-2022	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	9:36	17:49	8:12	LOAD CURTAILMENT
391	24-Feb-2022	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	BELL CERAMICS (EHT)	8:14	8:57	0:43	LINE FAULT
392	24-Feb-2022	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), KGF, KAMASAMUDRA	4:25	4:36	0:11	LINE FAULT
393	24-Feb-2022	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), KGF, KAMASAMUDRA	4:43	4:53	0:10	LINE FAULT
394	24-Feb-2022	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), KGF, KAMASAMUDRA	8:45	8:52	0:06	LINE FAULT
395	24-Feb-2022	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), KGF, KAMASAMUDRA	13:16	13:34	0:18	LINE FAULT
396	24-Feb-2022	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NO STATION AFFECTED	21:14	21:24	0:10	MAIN SUPPLY FAILURE
397	24-Feb-2022	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	19:58	20:14	0:16	LINE FAULT
398	24-Feb-2022	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	21:27	22:00	0:33	LINE FAULT
399	24-Feb-2022	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	21:14	21:25	0:11	MAIN SUPPLY FAILURE
400	24-Feb-2022	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	21:53	22:00	0:07	MAIN SUPPLY FAILURE
401	24-Feb-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
402	24-Feb-2022	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	9:00	19:00	10:00	LINE CLEAR AVOIDED
403	24-Feb-2022	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	21:09	21:35	0:26	LINE FAULT
404	24-Feb-2022	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	15:14	18:18	3:04	LINE CLEAR AVOIDED
405	24-Feb-2022	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	21:09	21:32	0:23	LINE FAULT
406	24-Feb-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVOIDED
407	24-Feb-2022	GULBARGA	110	LV1	HUMNABAD_220	9:25	17:15	7:50	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
408	24-Feb-2022	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110 ,DEVANGAON_110,RENUKA_IPP ,AFZALPUR_110,KARAJAGI_110	16:08(22.02.2022)	11:13(23.0 2.2022)	19:05HRS	LINE CHARGED
409	24-Feb-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	23:14 (23.02.2022)	7:14 (24.02.202 2)	8:00 HRS	LINE CHARGED
410	24-Feb-2022	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	0:09	0:12	0:03	LINE FAULT
411	24-Feb-2022	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	1:50	1:57	0:07	LINE FAULT
412	24-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	21:25	21:34	0:09	LINE FAULT
413	24-Feb-2022	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	1:40	1:50	0:10	LINE FAULT
414	24-Feb-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YE RDONA_110,SRNAGAR_110,MA LLAPURA_110	3:45	3:55	0:10	LINE FAULT
415	24-Feb-2022	GULBARGA	110	MUNIRABAD-HAGRI	HAGRI_110,SANKLAPUR_110,RB SNS,KAMALAPUR_110	16:25	16:34	0:09	LINE FAULT
416	24-Feb-2022	GULBARGA	110	YELBURGA-PRPJSLR	YELBURGA_110	14:20	14:41	0:21	LINE CLEAR AVAILED
417	24-Feb-2022	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	22:42	22:50	0:08	LINE FAULT
418	24-Feb-2022	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	23:44	23:51	0:07	LINE FAULT
419	24-Feb-2022	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	17:31	17:35	0:04	MAIN SUPPLY FAILURE
420	24-Feb-2022	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	11:30	11:40	0:10	MAIN SUPPLY FAILURE
421	24-Feb-2022	GULBARGA	110	JAWALGERA-ADAVI AMARESHWAR	ADAVI AMARESHWAR_110	2:25	2:30	0:05	LINE FAULT
422	24-Feb-2022	GULBARGA	110	KEMBHAVI-HUNSAGI	HUNSAGI_110	20:55	21:05	0:10	LINE FAULT
423	24-Feb-2022	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	16:25	16:38	0:13	LINE FAULT
424	24-Feb-2022	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	20:49	21:00	0:11	LINE FAULT
425	24-Feb-2022	GULBARGA	110	HALBARGA-HUMNABAD	HALBARGA_220	15:52	16:08	0:16	LINE FAULT
426	24-Feb-2022	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSL SUGARS FACTORY,CHOWDAPUR_110	11:32	11:40	0:08	LINE FAULT
427	24-Feb-2022	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,UPANAYAKAN AHALLI_66,HAGARIBOMMANAH ALLI_66,RR STEELS IPP	20:48	20:56	0:08	LINE FAULT
428	24-Feb-2022	GULBARGA	66	BANVEKAL-SLRYS_IPP	BANVEKAL_110	16:15	17:15	1:00	LINE CLEAR AVAILED
429	24-Feb-2022	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
430	24-Feb-2022	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
431	24-Feb-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
432	24-Feb-2022	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
433	24-Feb-2022	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	11:27	11:28	0:01	HAND TRIPPED
434	24-Feb-2022	HASSAN	110	HV1	BAIKAMPADY_110	10:26	12:31	2:05	LINE CLEAR AVAILED
435	24-Feb-2022	HASSAN	110	BARANG-SHR220	BARANGI_110	6:35	10:45	4:10	NFBC ISSUED
436	24-Feb-2022	HASSAN	110	HV3	BEJAI_110	9:54	17:16	7:22	LINE CLEAR AVAILED
437	24-Feb-2022	HASSAN	110	HV2	GURUVAYANAKERE_110	10:46	11:41	0:55	LINE CLEAR AVAILED
438	24-Feb-2022	HASSAN	110	HV1	HOSANGADI_110	13:36	18:01	4:25	LINE CLEAR AVAILED
439	24-Feb-2022	HASSAN	110	HV2	HOSANGADI_110	11:18	16:40	5:22	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
440	24-Feb-2022	HASSAN	110	MANIPAL-KEMAR2	MANIPAL_110	12:41	14:43	2:02	LINE CLEAR AVAILED
441	24-Feb-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	10:04	10:14	0:10	HAND TRIPPED
442	24-Feb-2022	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	6:26	6:45	0:19	LINE FAULT
443	24-Feb-2022	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	12:33	14:30	1:57	LINE CLEAR AVAILED
444	24-Feb-2022	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	6:35	10:45	4:10	LINE CLEAR AVAILED
445	24-Feb-2022	HASSAN	66	CRPATNA-HNPURA	CRPATNA_220	9:01	18:44	9:43	LINE CLEAR AVAILED
446	24-Feb-2022	HASSAN	66	GANGUR-HASSAN	GANGUR_66	1:15	1:35	0:20	MAIN SUPPLY FAILURE
447	24-Feb-2022	HASSAN	66	GANGUR-HASSAN	GANGUR_66	3:45	3:55	0:10	MAIN SUPPLY FAILURE
448	24-Feb-2022	HASSAN	66	GANGUR-HASSAN	GANGUR_66	6:10	10:35	4:25	MAIN SUPPLY FAILURE
449	24-Feb-2022	HASSAN	66	HAGARE-HASSAN	HAGARE_66	1:15	1:35	0:20	MAIN SUPPLY FAILURE
450	24-Feb-2022	HASSAN	66	HAGARE-HASSAN	HAGARE_66	3:45	3:55	0:10	MAIN SUPPLY FAILURE
451	24-Feb-2022	HASSAN	66	HAGARE-HASSAN	HAGARE_66	6:10	10:30	4:20	MAIN SUPPLY FAILURE
452	24-Feb-2022	HASSAN	66	HV1	HANGRANAHALLY_66	12:53	13:05	0:12	TRANSFORMER FAULT
453	24-Feb-2022	HASSAN	66	HV2	KANDLI_66	12:37	13:18	0:41	HAND TRIPPED
454	24-Feb-2022	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	9:29	17:54	8:25	LINE CLEAR AVAILED
455	24-Feb-2022	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	9:29	17:54	8:25	LINE CLEAR AVAILED
456	24-Feb-2022	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	9:03	18:45	9:42	NFBC ISSUED
457	24-Feb-2022	MYSURU	66	VAJAMANGALA-HEBBANI	NO STATIONS EFFECTED	10:14	10:20	0:06	LINE FAULT
458	24-Feb-2022	MYSURU	66	HV2	ARAKERE_66	10:26	10:31	0:04	TRANSFORMER FAULT
459	24-Feb-2022	MYSURU	66	HV1	CHUNCHUNKATTE_66	10:19	16:40	6:20	LINE CLEAR AVAILED
460	24-Feb-2022	MYSURU	66	HV2	CHUNCHUNKATTE_66	10:15	16:40	6:25	LINE CLEAR AVAILED
461	24-Feb-2022	MYSURU	66	HV1	DEVANOORNGUDU_66	17:03	18:19	1:16	LINE CLEAR AVAILED
462	24-Feb-2022	MYSURU	66	HV2	SATHEGALA_66	11:02	11:39	0:36	LINE CLEAR AVAILED
463	24-Feb-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
464	24-Feb-2022	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
465	24-Feb-2022	TUMKUR	66	TR-1	MADHUGIRI_66	10:42:53 (21.2.22)			TRANSFORMER OPEN,LINE CLEAR AVAILED
466	24-Feb-2022	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	10:44	16:10	5:26	LINE CLEAR AVAILED
467	24-Feb-2022	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	9:44	19:28	9:43	LINE CLEAR AVAILED
468	24-Feb-2022	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	10:35	10:50	0:15	MAIN SUPPLY FAILURE
469	24-Feb-2022	TUMKUR	220	GUTTUR 400KV-DAVANAGERE2	DAVANGERE_SRS_220	10:21	10:39	0:18	LINE FAULT
470	24-Feb-2022	TUMKUR	220	TR-2	KIADB V N PURA_220	14:15	16:21	2:06	LINE CLEAR AVAILED
471	24-Feb-2022	TUMKUR	220	TR-2	KIADB V N PURA_220	14:15	17:03	2:48	LINE CLEAR AVAILED
472	24-Feb-2022	TUMKUR	220	NITTUR 220-ARASIKERE	NITTUR_220	0:11	6:40	6:29	LOAD CURTAILMENT
473	24-Feb-2022	TUMKUR	220	TR-2	NITTUR_220	19:30	20:01	0:31	TRANSFORMER FAULT
474	24-Feb-2022	TUMKUR	220	PAVAGADA220-MADHUGIRI 1	PAVAGADA_220	14:22	15:19	0:57	LINE CLEAR AVAILED
475	24-Feb-2022	TUMKUR	110	TR-2	HULIYAR_110	16:02	16:26	0:24	LINE CLEAR AVAILED
476	24-Feb-2022	TUMKUR	110	TR-2	NITTUR_220	19:30	20:01	0:31	TRANSFORMER FAULT
477	24-Feb-2022	TUMKUR	110	TR-1	SHETTYKERE_110	16:19	17:23	1:03	LINE CLEAR AVAILED
478	24-Feb-2022	TUMKUR	66	TR-2	BADAVANAHALLI_66	11:34	13:54	2:20	LINE CLEAR AVAILED
479	24-Feb-2022	TUMKUR	66	TR-2	BRAMASANDRA_66	11:20	11:35	0:14	TRANSFORMER FAULT
480	24-Feb-2022	TUMKUR	66	TR-2	CHANNAGIRI_66	9:46	9:52	0:06	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
481	24-Feb-2022	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66,KADAJJI_66,M ELEKATTE 66	10:23	10:41	0:18	MAIN SUPPLY FAILURE
482	24-Feb-2022	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:23	10:41	0:17	MAIN SUPPLY FAILURE
483	24-Feb-2022	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI 66	10:23	10:41	0:18	MAIN SUPPLY FAILURE
484	24-Feb-2022	TUMKUR	66	TR-1	DAVANGERE_SRS_220	10:23	10:41	0:18	MAIN SUPPLY FAILURE
485	24-Feb-2022	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR 66	10:23	10:41	0:18	MAIN SUPPLY FAILURE
486	24-Feb-2022	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR 66	13:23	13:30	0:06	MAIN SUPPLY FAILURE
487	24-Feb-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:23	10:41	0:17	MAIN SUPPLY FAILURE
488	24-Feb-2022	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI 66	10:23	10:41	0:18	MAIN SUPPLY FAILURE
489	24-Feb-2022	TUMKUR	66	TR-1	HONNALLI_220	10:27	11:02	0:34	MAIN SUPPLY FAILURE
490	24-Feb-2022	TUMKUR	66	TR-2	HONNALLI_220	10:27	11:03	0:35	MAIN SUPPLY FAILURE
491	24-Feb-2022	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	10:28	11:22	0:54	MAIN SUPPLY FAILURE
492	24-Feb-2022	TUMKUR	66	HONNALLI 220kv- KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	10:28	11:04	0:36	MAIN SUPPLY FAILURE
493	24-Feb-2022	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:28	11:06	0:38	MAIN SUPPLY FAILURE
494	24-Feb-2022	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	10:21	10:27	0:06	MAIN SUPPLY FAILURE
495	24-Feb-2022	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	11:02	11:08	0:05	MAIN SUPPLY FAILURE
496	24-Feb-2022	TUMKUR	66	TR-2	KADAJJI_66	9:39	9:47	0:07	TRANSFORMER FAULT
497	24-Feb-2022	TUMKUR	66	TR-2	KADAJJI_66	15:30	15:36	0:05	TRANSFORMER FAULT
498	24-Feb-2022	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR 66	13:33	13:35	0:02	LINE FAULT
499	24-Feb-2022	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR 66	13:50	13:55	0:05	LINE FAULT
500	24-Feb-2022	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	13:39	13:50	0:10	MAIN SUPPLY FAILURE
501	24-Feb-2022	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	18:43	18:51	0:07	LINE FAULT
502	24-Feb-2022	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI66	MADHUGIRI_66, BADAVANAHALLI_66	11:41	13:47	2:05	LINE CLEAR AVAIED
503	24-Feb-2022	TUMKUR	66	NAGALAMADIKE- SUNDER RAJU SOLAR IPP_66	SUNDER RAJU SOLAR_IPP_66	11:10	11:18	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
504	24-Feb-2022	TUMKUR	66	SASALUHALLA66-CHIKKAJAJUR66(SRS DAVANAGERE)	SASALUHALLA_66	17:50	18:39	0:49	HAND TRIPPED
505	24-Feb-2022	TUMKUR	66	TR-1	SASALUHALLA_66	17:54	18:39	0:44	HAND TRIPPED
506	25-Feb-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
507	25-Feb-2022	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
508	25-Feb-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
509	25-Feb-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN,LINE FAULT
510	25-Feb-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
511	25-Feb-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
512	25-Feb-2022	BAGALKOT	220	HAVERI- GUTTUR1	STATION NOT AFFECTED HAVERI_220	20:31 (21.02.2022)	14:34 (25.02.2022)	90:03HRS	LINE CHARGED
513	25-Feb-2022	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	13:11 (23.02.2022)			LINE OPEN,LINE CLEAR AVAILED
514	25-Feb-2022	BAGALKOT	110	THORVI(BJCTY)-TAKKALAKI(TIKOTA)	TAKKALAKI_110	6:16	6:30	0:14	LINE FAULT
515	25-Feb-2022	BAGALKOT	110	BIJAPUR220-KIADB 1&2	KIADB BIJAPUR_110	6:16	6:24	0:08	LINE FAULT
516	25-Feb-2022	BAGALKOT	110	110/11KV,HV2	DHAVALSHWAR_110	14:27	14:41	0:14	TRANSFORMER FAULT
517	25-Feb-2022	BAGALKOT	110	110/11KV,HV1	GOKAK_110	13:36	14:14	0:38	LINE CLEAR AVAILED
518	25-Feb-2022	BAGALKOT	110	HOSAHONNATTI-GUTTAL	GUTTAL_110	17:04	17:20	0:16	LINE CLEAR AVAILED
519	25-Feb-2022	BAGALKOT	110	TAKKALAKI-THORVI	TAKKALAKI_110	6:16	6:30	0:14	LINE FAULT
520	25-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED RAMADURG_110	13:37	14:14	0:37	LINE CLEAR AVAILED
521	25-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NAGANUR_110	5:25	10:03	4:38	TRANSFORMER FAULT
522	25-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NAGANUR_110	10:06	11:15	1:09	TRANSFORMER FAULT
523	25-Feb-2022	BAGALKOT	110	KANABARGI-BELAGAUM(NEHRUNAGAR)	BELAGAVI_110	9:31	14:06	4:35	NFBC ISSUED
524	25-Feb-2022	BAGALKOT	110	KALAGHATAGI-HUBLI220	STATION NOT AFFECTED KALAGHATAGI_110	16:22	16:41	0:19	NFBC ISSUED
525	25-Feb-2022	BAGALKOT	220	220/110KV,HV1	STATION NOT AFFECTED CHIKKODI_220	19:57	20:22	0:25	TRANSFORMER FAULT
526	25-Feb-2022	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	10:49	14:54	4:05	NFBC ISSUED
527	25-Feb-2022	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	14:11	17:17	3:06	LINE FAULT
528	25-Feb-2022	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED HUBLI_220	9:33	15:04	5:31	LINE CLEAR AVAILED
529	25-Feb-2022	BAGALKOT	110	HUBLI- KALGHATAGI	STATION NOT AFFECTED HUBLI_220	11:32	16:37	5:05	LINE CLEAR AVAILED
530	25-Feb-2022	BAGALKOT	110	AMBEWADI- NK1	STATION NOT AFFECTED AMBEWADI_220	8:18	19:14	10:56	LINE CLEAR AVAILED
531	25-Feb-2022	BAGALKOT	110	AMBEWADI- NK2	STATION NOT AFFECTED AMBEWADI_220	8:18	19:13	10:55	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
532	25-Feb-2022	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED HUBLI_220	9:33	15:04	5:31	LINE CLEAR AVAILED
533	25-Feb-2022	BAGALKOT	110	RANEENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			LINE OPEN,LINE CLEAR AVAILED
534	25-Feb-2022	BAGALKOT	110	220/110KV, LV2	ATHANI_220	16:12	16:14	0:02	HAND TRIPPED
535	25-Feb-2022	BAGALKOT	110	SOUDATTI220- RAMDURG1	RAMDURG_110	13:35	14:15	0:40	LINE CLEAR AVAILED
536	25-Feb-2022	BAGALKOT	110	CHIKKODI220- RAIBAG2	CHIKKODI_220	20:00 (25.02.2022)			LINE OPEN,LINE FAULT
537	25-Feb-2022	BAGALKOT	220	220/110KV, HV1&LV1	INDI_220, DEVAR HIPPARAGI_110, INDI_110, LACHYAN_110, ZALKI_110, ATHARGA_110, HIREMASALI_110, HIREBEVNUR_110, ZALKI_110, CHADCHAN_110, INCHARGERI_110	9:52	10:15	0:23	TRANSFORMER FAULT
538	25-Feb-2022	BAGALKOT	220	220/110KV, HV2&LV2	INDI_220, DEVAR HIPPARAGI_110, INDI_110, LACHYAN_110, ZALKI_110, ATHARGA_110, HIREMASALI_110, HIREBEVNUR_110, ZALKI_110, CHADCHAN_110, INCHARGERI_110	9:52	10:15	0:23	TRANSFORMER FAULT
539	25-Feb-2022	BAGALKOT	110	110/11KV, HV1	MANTUR(B)_110	16:10	16:20	0:10	TRANSFORMER FAULT
540	25-Feb-2022	BAGALKOT	110	110/11KV, HV2	HUBLI_220	15:12	16:41	1:29	LINE CLEAR AVAILED
541	25-Feb-2022	BENGALURU	66	HV2	ABBIGERE	17:35	18:33	0:58	LINE CLEAR AVAILED
542	25-Feb-2022	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	15:50	16:30	0:40	MAIN SUPPLY FAILURE
543	25-Feb-2022	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	16:43	16:50	0:07	MAIN SUPPLY FAILURE
544	25-Feb-2022	BENGALURU	66	HV2	CHATRA	11:30	12:00	0:30	LINE CLEAR AVAILED
545	25-Feb-2022	BENGALURU	66	HV1	ELECTRONIC CITY	11:59	12:02	0:03	LINE CLEAR AVAILED
546	25-Feb-2022	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	15:50	16:30	0:40	MAIN SUPPLY FAILURE
547	25-Feb-2022	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	16:43	16:52	0:09	MAIN SUPPLY FAILURE
548	25-Feb-2022	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	20:30	20:35	0:05	LOAD CHANGE OVER
549	25-Feb-2022	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	14:30	15:21	0:51	LINE FAULT
550	25-Feb-2022	BENGALURU	220	KOTIPURA 220 - TUBINAKERE 220	KOTIPURA 220	13:58	14:51	0:53	MAIN SUPPLY FAILURE
551	25-Feb-2022	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	13:58	14:51	0:53	LINE CLEAR AVAILED
552	25-Feb-2022	BENGALURU	66	MELLAHALLI - KEMPAHALLI	MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	10:00	13:21	3:21	LINE CLEAR AVAILED
553	25-Feb-2022	BENGALURU	66	MELLAHALLI - KOTIPURA 220	MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	13:58	15:03	1:05	MAIN SUPPLY FAILURE
554	25-Feb-2022	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	17:35	17:44	0:09	LINE FAULT
555	25-Feb-2022	BENGALURU	220	HV2	TK HALLI 220	6:26	6:44	0:18	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
556	25-Feb-2022	BENGALURU	220	LV2	TK HALLI 220	6:26	6:44	0:18	TRANSFORMER FAULT
557	25-Feb-2022	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	6:26	6:50	0:24	LINE CLEAR AVAILED
558	25-Feb-2022	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR,K HONALGERE	6:26	6:51	0:25	LINE CLEAR AVAILED
559	25-Feb-2022	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	6:26	7:31	1:05	LINE CLEAR AVAILED
560	25-Feb-2022	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	6:26	7:49	1:23	LINE CLEAR AVAILED
561	25-Feb-2022	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	6:26	7:49	1:23	LINE CLEAR AVAILED
562	25-Feb-2022	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	9:44	11:03	1:19	LINE CLEAR AVAILED
563	25-Feb-2022	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	9:44	11:04	1:20	LINE CLEAR AVAILED
564	25-Feb-2022	BENGALURU	66	HV2	VIDHURASHWATHA	14:53	15:05	0:11	LINE CLEAR AVAILED
565	25-Feb-2022	BENGALURU	66	HV1	N G HULKUR	16:57	17:30	0:32	LINE CLEAR AVAILED
566	25-Feb-2022	BENGALURU	66	HV2	MAASTHI	6:37	6:42	0:05	TRANSFORMER FAULT
567	25-Feb-2022	BENGALURU	66	HV1	KONDASPURA	12:33	12:42	0:08	TRANSFORMER FAULT
568	25-Feb-2022	BENGALURU	66	HV1	DODDABELAVANGALA	22:13	22:21	0:07	TRANSFORMER FAULT
569	25-Feb-2022	BENGALURU	66	HV1	CHELUR	17:40	18:22	0:42	LINE CLEAR AVAILED
570	25-Feb-2022	BENGALURU	66	HV2	BAIRAKURU	5:47	6:03	0:15	TRANSFORMER FAULT
571	25-Feb-2022	BENGALURU	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	12:16	12:30	0:14	LINE CLEAR AVAILED
572	25-Feb-2022	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	12:29	12:37	0:08	LINE CLEAR AVAILED
573	25-Feb-2022	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	11:33	12:34	1:01	LINE CLEAR AVAILED
574	25-Feb-2022	BENGALURU	66	KOLAR 220 - MULBAGAL	NO STATION AFFECTED	14:40	14:53	0:12	LINE FAULT
575	25-Feb-2022	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	14:06	17:53	3:47	LOAD CURTAILMENT
576	25-Feb-2022	BENGALURU	220	HV1	BEGUR 220	15:51	16:19	0:28	TRANSFORMER FAULT
577	25-Feb-2022	BENGALURU	220	HV2	BEGUR 220	15:51	16:19	0:28	TRANSFORMER FAULT
578	25-Feb-2022	BENGALURU	220	HV1	BEGUR 220	16:43	17:18	0:35	TRANSFORMER FAULT
579	25-Feb-2022	BENGALURU	220	HV2	BEGUR 220	16:43	17:18	0:35	TRANSFORMER FAULT
580	25-Feb-2022	BENGALURU	220	HV1	BEGUR 220	17:30	17:43	0:13	TRANSFORMER FAULT
581	25-Feb-2022	BENGALURU	220	HV2	BEGUR 220	17:30	17:43	0:13	TRANSFORMER FAULT
582	25-Feb-2022	BENGALURU	66	BEGUR 220 - VIDYANAGAR	VIDYANAGAR, HENNUR CROSS	15:51	16:25	0:34	MAIN SUPPLY FAILURE
583	25-Feb-2022	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	15:51	16:30	0:39	MAIN SUPPLY FAILURE
584	25-Feb-2022	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	15:51	16:34	0:43	MAIN SUPPLY FAILURE
585	25-Feb-2022	BENGALURU	66	HV2	BEGUR 220	15:51	16:35	0:44	MAIN SUPPLY FAILURE
586	25-Feb-2022	BENGALURU	66	BEGUR 220 - BIAL 2	NO STATION AFFECTED	16:43	17:20	0:37	MAIN SUPPLY FAILURE
587	25-Feb-2022	BENGALURU	66	HV2	BEGUR 220	16:43	17:20	0:37	MAIN SUPPLY FAILURE
588	25-Feb-2022	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	16:43	17:22	0:39	MAIN SUPPLY FAILURE
589	25-Feb-2022	BENGALURU	66	BEGUR 220 - BIAL 2	NO STATION AFFECTED	17:30	17:56	0:26	MAIN SUPPLY FAILURE
590	25-Feb-2022	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	16:43	16:50	0:07	MAIN SUPPLY FAILURE
591	25-Feb-2022	BENGALURU	66	HV2	BEGUR 220	17:30	18:02	0:32	MAIN SUPPLY FAILURE
592	25-Feb-2022	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	17:30	18:22	0:52	MAIN SUPPLY FAILURE
593	25-Feb-2022	BENGALURU	66	BEGUR 220 - BIAL 1	AIRPORT	17:30	18:32	1:02	MAIN SUPPLY FAILURE
594	25-Feb-2022	BENGALURU	66	BEGUR 220 - BOODIGERE	NO STATION AFFECTED	17:30	18:54	1:24	MAIN SUPPLY FAILURE
595	25-Feb-2022	BENGALURU	66	HV1	BEGUR 220	17:30	18:46	1:16	MAIN SUPPLY FAILURE
596	25-Feb-2022	BENGALURU	66	BEGUR 220 - VIDYANAGAR	NO STATION AFFECTED	17:30	19:29	1:59	MAIN SUPPLY FAILURE
597	25-Feb-2022	BENGALURU	66	BEGUR 220 - VIDYANAGAR	VIDYANAGAR, HENNUR CROSS	16:43	18:00	1:17	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
598	25-Feb-2022	BENGALURU	66	VIDYANAGAR - HOSKOTE 220	VIDYANAGAR	20:11	20:13	0:02	LOAD CHANGE OVER
599	25-Feb-2022	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	20:11	20:35	0:24	LOAD CHANGE OVER
600	25-Feb-2022	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	13:18	14:30	1:12	LINE CLEAR AVAILED
601	25-Feb-2022	GULBARGA	400	GUTTUR-BPTS	GUTTUR_400	23:21(25.02.2022)			LINE OPEN,LINE CLEAR AVAILED
602	25-Feb-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
603	25-Feb-2022	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	8:34	19:16	10:42	LINE CLEAR AVAILED
604	25-Feb-2022	GULBARGA	220	LINGASUGUR-SHAHAPUR	LINGASUGUR_220	10:14	14:36	4:22	LINE CLEAR AVAILED
605	25-Feb-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
606	25-Feb-2022	GULBARGA	110	HV1	NIRNA_110	10:30	10:42	0:12	TRANSFORMER FAULT
607	25-Feb-2022	GULBARGA	110	HV2	HATTI_110	17:14	17:19	0:05	LINE CLEAR AVAILED
608	25-Feb-2022	GULBARGA	110	HV2	BISILAHALLI_110	13:25	13:35	0:10	TRANSFORMER FAULT
609	25-Feb-2022	GULBARGA	110	HV1	BEVOOR_110	18:05	18:20	0:15	LINE CLEAR AVAILED
610	25-Feb-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_110,SDAIDHAPUR_110,SANATHI_IPP,CORE GREEN SUGAR IPP	6:04	6:11	0:07	LINE FAULT
611	25-Feb-2022	GULBARGA	110	HOSAHALLI-SML_WIND	HOSAHALLI_66	11:35	19:10	7:35	LINE CLEAR AVAILED
612	25-Feb-2022	GULBARGA	110	GURMITKAL-KONKAL	GURMITKAL_110	14:45	15:55	1:10	LINE CLEAR AVAILED
613	25-Feb-2022	GULBARGA	110	LINGASUGUR-CHAYADEVI	CHAYADEVI_IPP,KAREPOWER_IPP	12:51(21.02.2022)	18:16(25.02.2022)	101:25HRS	LINE CHARGED
614	25-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	0:20	0:25	0:05	LINE FAULT
615	25-Feb-2022	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	8:15	11:00	2:45	LOAD CURTAILMENT
616	25-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	8:15	11:00	2:45	LOAD CURTAILMENT
617	25-Feb-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	14:00	14:15	0:15	LINE FAULT
618	25-Feb-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	8:06	13:22	5:16	LINE CLEAR AVAILED
619	25-Feb-2022	GULBARGA	110	HALBARGA-HUMNABAD	HALBARGA_220	15:58	16:17	0:19	LINE FAULT
620	25-Feb-2022	GULBARGA	110	HALBARGA-CHIDRI 2	CHIDRI_110	17:52	17:59	0:07	LINE FAULT
621	25-Feb-2022	GULBARGA	66	HV2	TAMBRAHALLI_66	0:21	0:40	0:19	TRANSFORMER FAULT
622	25-Feb-2022	GULBARGA	66	HV2	HALAVAGALU_66	8:00	8:05	0:05	TRANSFORMER FAULT
623	25-Feb-2022	GULBARGA	66	HV2	HALAVAGALU_66	10:50	10:55	0:05	TRANSFORMER FAULT
624	25-Feb-2022	GULBARGA	66	HV2	HALAVAGALU_66	10:55	11:00	0:05	TRANSFORMER FAULT
625	25-Feb-2022	GULBARGA	66	HV3	HALAVAGALU_66	22:50	22:55	0:05	TRANSFORMER FAULT
626	25-Feb-2022	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
627	25-Feb-2022	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
628	25-Feb-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
629	25-Feb-2022	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
630	25-Feb-2022	HASSAN	110	HV2	BIRUR_110	4:20	9:50	5:30	TRANSFORMER FAULT
631	25-Feb-2022	HASSAN	110	HV2	GURUPURA_110	1:13	1:20	0:07	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
632	25-Feb-2022	HASSAN	110	HOSUR-BALIGAVI	HOSUR_110	10:01	13:48	3:47	LINE CLEAR AVAILED
633	25-Feb-2022	HASSAN	110	HV1	HOSUR_110	10:01	13:53	3:52	LINE CLEAR AVAILED
634	25-Feb-2022	HASSAN	110	JOG11-LPH	JOG_110	14:34	15:19	0:45	LINE FAULT
635	25-Feb-2022	HASSAN	110	LPH-JLT3	gen_lph	14:34	16:05	1:31	LINE FAULT
636	25-Feb-2022	HASSAN	110	MOODABI-SOHAM1	MOODABIDRE_110	9:36	10:04	0:28	HAND TRIPPED
637	25-Feb-2022	HASSAN	110	MOODABI-SOHAM1	MOODABIDRE_110	10:53	13:29	2:36	LINE CLEAR AVAILED
638	25-Feb-2022	HASSAN	110	SSLI-SAGARA	SAGARA_110	14:55	15:10	0:15	HAND TRIPPED
639	25-Feb-2022	HASSAN	66	CRP2-HNPURA	CRPATNA_220	9:10	18:04	8:54	LINE CLEAR AVAILED
640	25-Feb-2022	HASSAN	66	HV1	DODDAHALLY_66	7:29	8:09	0:40	LINE CLEAR AVAILED
641	25-Feb-2022	HASSAN	66	HV1	DODDAKADNUR_66	17:16	18:24	1:08	LINE CLEAR AVAILED
642	25-Feb-2022	HASSAN	66	HV1	HOLALUR_66	17:28	18:50	1:22	LINE CLEAR AVAILED
643	25-Feb-2022	HASSAN	66	HV2	HOLALUR_66	17:31	18:50	1:19	LINE CLEAR AVAILED
644	25-Feb-2022	HASSAN	66	HV1	KANDLI_66	14:24	16:27	2:03	LINE CLEAR AVAILED
645	25-Feb-2022	HASSAN	66	HV2	KANDLI_66	14:24	16:27	2:03	LINE CLEAR AVAILED
646	25-Feb-2022	HASSAN	66	MALALI-CRPATNA	MALALI_66	12:36	14:01	1:25	LINE CLEAR AVAILED
647	25-Feb-2022	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGARA_66	12:23	12:38	0:15	MAIN SUPPLY FAILURE
648	25-Feb-2022	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGARA_66	13:55	14:05	0:10	MAIN SUPPLY FAILURE
649	25-Feb-2022	HASSAN	66	SAKALESH-IPCL1	SAKLESHPUA_66	9:30	18:11	8:41	LINE CLEAR AVAILED
650	25-Feb-2022	HASSAN	66	SAKALESH-IPCL2	SAKLESHPUA_66	9:30	18:11	8:41	LINE CLEAR AVAILED
651	25-Feb-2022	HASSAN	66	SHANTI-MALLALI	SHANTHIGRAMA_66	12:30	13:00	0:30	MAIN SUPPLY FAILURE
652	25-Feb-2022	HASSAN	66	SHANTI-RMWNGR	SHANTHIGRAMA_66	13:50	14:00	0:10	HAND TRIPPED
653	25-Feb-2022	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	9:12	18:04	8:52	NFBC ISSUED
654	25-Feb-2022	MYSURU	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	18:33	18:41	0:08	LINE FAULT
655	25-Feb-2022	MYSURU	66	KR PETE 220-SANTHEBACHALLI 2	NO STATIONS EFFECTED	1:01	1:10	0:09	LINE FAULT
656	25-Feb-2022	MYSURU	220	HV1	KRPET_220	16:21	17:51	1:30	LINE CLEAR AVAILED
657	25-Feb-2022	MYSURU	220	TUBINKERE-BASTIPURA	TARIPURA_66 GAMANAHALLY_66 DODDABYADARAHALLI_66 SRIRANGAPATNA_66 GARUDANAUKADDA_66HADLI_66 PANDAVAPURA_66TUBINAKE RE_220ARAKERE_66CHIKKA_MANDYA_66 MANDYA_66KADKOTH ANAHALLI_66 MALAVALLI_66HARADANAHALLI(JAK) HAMPAPURA_66 BASARALU_66 BESAGARAHALLI_66 KOPPA_66 KESLAGERE_66 G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66 SHIVALLY_66	14:00	14:55	0:55	LINE FAULT
658	25-Feb-2022	MYSURU	220	TUBINKERE-HUYGONAHALLI	NO STATIONS EFFECTED	14:00	14:50	0:50	LINE FAULT
659	25-Feb-2022	MYSURU	66	TUBINKERE-SR PATNA	NO STATIONS EFFECTED	11:00	12:10	1:10	LINE CLEAR AVAILED
660	25-Feb-2022	MYSURU	220	TUBINKERE-KOTTIPURA 1	NO STATIONS EFFECTED	14:00	14:55	0:55	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
661	25-Feb-2022	MYSURU	220	TUBINKERE-KOTTIPURA 2	NO STATIONS EFFECTED	14:00	14:55	0:55	HAND TRIPPED
662	25-Feb-2022	MYSURU	66	HEBBANI-SHIMSHA	NO STATIONS EFFECTED	11:00	11:19	0:19	HAND TRIPPED
663	25-Feb-2022	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	6:28	7:01	0:33	LINE FAULT
664	25-Feb-2022	MYSURU	66	HALGUR-HONNAGANAHALLI	HALAGUR_66	9:30	15:55	6:25	LINE CLEAR AVAILED
665	25-Feb-2022	MYSURU	66	HALGUR-TK HALLI	NO STATIONS EFFECTED	9:30	15:55	6:25	LINE CLEAR AVAILED
666	25-Feb-2022	MYSURU	66	PANDAVAPURA-CHINKURALI	BANANGADI_66	12:22	15:10	2:48	LINE CLEAR AVAILED
667	25-Feb-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
668	25-Feb-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
669	25-Feb-2022	TUMKUR	220	TR-1	CHITRADURGA_220	15:41	16:13	0:31	LINE CLEAR AVAILED
670	25-Feb-2022	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	9:14	20:25	11:11	LINE CLEAR AVAILED
671	25-Feb-2022	TUMKUR	220	TR-1 & 2	PAVAGADA_220	12:23	12:51	0:27	TRANSFORMER FAULT
672	25-Feb-2022	TUMKUR	220	TR-1 & 2	PAVAGADA_220	12:51	12:55	0:04	TRANSFORMER FAULT
673	25-Feb-2022	TUMKUR	220	TR-1 & 2	PAVAGADA_220	13:25	13:27	0:01	LINE CLEAR AVAILED
674	25-Feb-2022	TUMKUR	110	TR-3	AMMASANDRA_110	8:11	8:19	0:07	TRANSFORMER FAULT
675	25-Feb-2022	TUMKUR	110	TR-3	AMMASANDRA_110	15:29	15:47	0:17	HAND TRIPPED
676	25-Feb-2022	TUMKUR	110	GUBBI110-NITTUR220	GUBBI_110	13:34	14:45	1:11	LINE CLEAR AVAILED
677	25-Feb-2022	TUMKUR	110	TR-1	GUBBI_110	13:01	14:45	1:44	LINE CLEAR AVAILED
678	25-Feb-2022	TUMKUR	110	TR-2	GUBBI_110	12:20	14:47	2:27	LINE CLEAR AVAILED
679	25-Feb-2022	TUMKUR	110	TR-3	GUBBI_110	13:34	14:46	1:11	LINE CLEAR AVAILED
680	25-Feb-2022	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	10:15	10:58	0:43	LOAD CURTAILMENT
681	25-Feb-2022	TUMKUR	66	TR-1	MADHUGIRI_66	10:42:53 (21.2.22)			TRANSFORMER OPEN,LINE CLEAR AVAILED
682	25-Feb-2022	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	15:24	15:44	0:20	LINE CLEAR AVAILED
683	25-Feb-2022	TUMKUR	66	TR-1(LV-1)	CHITRADURGA_220	15:41	16:13	0:32	LINE CLEAR AVAILED
684	25-Feb-2022	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	8:39	9:02	0:23	LINE FAULT
685	25-Feb-2022	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:27	16:44	0:17	LINE FAULT
686	25-Feb-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	8:24	8:53	0:28	LOAD CURTAILMENT
687	25-Feb-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:31	18:47	0:15	LINE FAULT
688	25-Feb-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	19:14	19:26	0:11	LINE FAULT
689	25-Feb-2022	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	8:23	8:53	0:29	LOAD CURTAILMENT
690	25-Feb-2022	TUMKUR	66	HONNALLI 220kV- KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	12:38	13:01	0:23	LOAD CURTAILMENT
691	25-Feb-2022	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	6:23	8:32	2:09	LINE CLEAR AVAILED
692	25-Feb-2022	TUMKUR	66	TR-2	KADAJJI_66	13:38	13:43	0:05	TRANSFORMER FAULT
693	25-Feb-2022	TUMKUR	66	KUKKAWADA -HONNALLI	KUKKAWADA_66	16:46	16:52	0:05	HAND TRIPPED
694	25-Feb-2022	TUMKUR	66	LOKIKERE-TYAVANAGI	LOKIKERE_66	16:49	16:59	0:09	LOAD CURTAILMENT
695	25-Feb-2022	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	8:19	8:32	0:12	LOAD CURTAILMENT
696	25-Feb-2022	TUMKUR	66	NAGALAMADIKE-MADHUGIRI	NAGALMADIKE_66	11:05	13:11	2:06	LINE CLEAR AVAILED
697	25-Feb-2022	TUMKUR	66	NAGALAMADIKE- SUNDARRAISOLAR IPP 66	SUNDARRAISOLAR_IPP_66	12:40	16:21	3:41	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
698	25-Feb-2022	TUMKUR	66	NAGALAMADIKE-MADHUGIRI	NAGALMADIKE_66	13:12	13:30	0:18	LINE FAULT
699	25-Feb-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	6:34	7:24	0:50	LINE CLEAR AVAILED
700	25-Feb-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	18:26	19:15	0:48	LINE CLEAR AVAILED
701	25-Feb-2022	TUMKUR	66	TR-2	PD KOTE_66	8:50	8:59	0:09	TRANSFORMER FAULT
702	25-Feb-2022	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	10:18	10:22	0:04	LINE FAULT
703	25-Feb-2022	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	15:40	15:50	0:09	LINE FAULT
704	25-Feb-2022	TUMKUR	66	TR-1(LV-1)	PAVAGADA_220	12:24	12:55	0:31	TRANSFORMER FAULT
705	25-Feb-2022	TUMKUR	66	TR-2(LV-2)	PAVAGADA_220	12:25	12:55	0:30	TRANSFORMER FAULT
706	25-Feb-2022	TUMKUR	66	PAVAGADA220-MIDIGESHI	MIDIGESHI_66	12:26	12:55	0:29	LINE FAULT
707	25-Feb-2022	TUMKUR	66	PAVAGADA220-NAGALMADIKE	NAGALMADIKE_66	12:25	12:54	0:28	LINE FAULT
708	25-Feb-2022	TUMKUR	66	PAVAGADA220-PAVAGADA1	PAVAGADA_220	12:26	12:55	0:29	LINE FAULT
709	25-Feb-2022	TUMKUR	66	PAVAGADA 220kV- SHYLAPURA	SHYLAPURA_66	12:25	12:54	0:28	LINE FAULT
710	25-Feb-2022	TUMKUR	66	PAVAGADA 220kV- YN HOSAKETE	PAVAGADA_220	12:25	12:54	0:28	LINE FAULT
711	25-Feb-2022	TUMKUR	66	TR-1	RAMAPURA_66	6:47	6:55	0:07	TRANSFORMER FAULT
712	25-Feb-2022	TUMKUR	66	RAMPURA66-WELSPUN SOLAR	WELSPUN SOLAR_IPP_66	8:12	8:21	0:08	LINE FAULT
713	25-Feb-2022	TUMKUR	66	RAMPURA66-WELSPUN SOLAR	WELSPUN SOLAR_IPP_66	8:21	8:23	0:02	LINE FAULT
714	25-Feb-2022	TUMKUR	66	RAMPURA66-WELSPUN SOLAR	WELSPUN SOLAR_IPP_66	17:57	18:05	0:08	LINE FAULT
715	25-Feb-2022	TUMKUR	66	H D PURA- CHITRADURGA220	H D PURA_66	13:25	13:33	0:08	LINE FAULT
716	25-Feb-2022	TUMKUR	66	THERIYUR 66-GOWRIBIDANUR	THERIYUR_66	12:20	15:07	2:46	LINE CLEAR AVAILED
717	26-Feb-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
718	26-Feb-2022	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
719	26-Feb-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
720	26-Feb-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN,LINE FAULT
721	26-Feb-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
722	26-Feb-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
723	26-Feb-2022	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	13:11 (23.02.2022)			LINE OPEN,LINE CLEAR AVAILED
724	26-Feb-2022	BAGALKOT	110	110/11KV,HV2	ALMEL_110	13:30	13:34	0:04	HAND TRIPPED
725	26-Feb-2022	BAGALKOT	110	110/11KV,HV2	ALMEL_110	14:41	14:43	0:02	HAND TRIPPED
726	26-Feb-2022	BAGALKOT	110	110/11KV,HV2	ALMEL_110	15:55	16:22	0:27	HAND TRIPPED
727	26-Feb-2022	BAGALKOT	110	110/11KV,HV2	ALMEL_110	17:56	18:17	0:21	HAND TRIPPED
728	26-Feb-2022	BAGALKOT	110	BIDNAL- NAVALGUND	NAVALGUND_110	14:55	17:52	2:57	LINE CLEAR AVAILED
729	26-Feb-2022	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	14:29	17:58	3:29	LINE FAULT
730	26-Feb-2022	BAGALKOT	110	110/11KV,HV2	HANAGALL_110	9:09	9:20	0:11	TRANSFORMER FAULT
731	26-Feb-2022	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	12:45	15:59	3:14	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
732	26-Feb-2022	BAGALKOT	110	SHIGAON-AVANTI SOLAR	AVANTI SOLAR_110 STATION NOT AFFECTED SHIGAON_110	17:25 (26.02.2022)			LINE OPEN,LINE CLEAR AVAILED
733	26-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TAKKALAKI_110	11:45	11:48	0:03	TRANSFORMER FAULT
734	26-Feb-2022	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	9:35	9:40	0:05	LINE FAULT
735	26-Feb-2022	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	9:40	9:43	0:03	LINE FAULT
736	26-Feb-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED RAMADURG_110	9:51	10:32	0:41	LINE CLEAR AVAILED
737	26-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUKARTIHAL_110	16:15	16:39	0:24	LINE CLEAR AVAILED
738	26-Feb-2022	BAGALKOT	110	NAVALAGUND-BIDNAL220	STATION NOT AFFECTED NAVALAGUND_110	15:04	17:56	2:52	NFBC ISSUED
739	26-Feb-2022	BAGALKOT	110	KIRUVATTI-SIRSI(AMBEWADI)	KIRUVATTI_110	14:03	14:06	0:03	LINE FAULT
740	26-Feb-2022	BAGALKOT	110	KALAGHATAGI-HUBLI220	STATION NOT AFFECTED KALAGHATAGI_110	5:15	11:16	6:01	LINE CLEAR AVAILED
741	26-Feb-2022	BAGALKOT	110	KALAGHATAGI-HUBLI220	STATION NOT AFFECTED KALAGHATAGI_110	11:16	16:00	4:44	LINE FAULT
742	26-Feb-2022	BAGALKOT	220	KARWAR- KADRA LINE 1	KARWAR_220	13:47	14:53	1:06	LINE CLEAR AVAILED
743	26-Feb-2022	BAGALKOT	110	KARWAR-(SOLARIS)BINAGA	KARWAR_220	13:50	14:21	0:31	HAND TRIPPED
744	26-Feb-2022	BAGALKOT	220	NARENDRA-HUBLI1	STATION NOT AFFECTED NARENDRA_220	16:17	18:48	2:31	LINE CLEAR AVAILED
745	26-Feb-2022	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	13:26	14:41	1:15	LINE CLEAR AVAILED
746	26-Feb-2022	BAGALKOT	110	HUBLI- KALGHATAGI	STATION NOT AFFECTED HUBLI_220	5:00	15:43	10:43	LINE FAULT
747	26-Feb-2022	BAGALKOT	110	HUBLI- KADANKOPPA	STATION NOT AFFECTED HUBLI_220	12:40	15:50	3:10	LINE CLEAR AVAILED
748	26-Feb-2022	BAGALKOT	220	HUBLI- NAGJHARI2	STATION NOT AFFECTED HUBLI_220	14:30	17:52	3:22	LINE FAULT
749	26-Feb-2022	BAGALKOT	220	HUBLI- NAGJHARI3	STATION NOT AFFECTED HUBLI_220	14:30	17:53	3:23	LINE FAULT
750	26-Feb-2022	BAGALKOT	220	HUBLI- NAGJHARI1	STATION NOT AFFECTED HUBLI_220	14:32	17:51	3:19	LINE FAULT
751	26-Feb-2022	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	16:17	18:48	2:31	NFBC ISSUED
752	26-Feb-2022	BAGALKOT	110	MUGALKHOD- SAIDAPUR	STATION NOT AFFECTED MUGALKHOD_220	10:22	20:10	9:48	LINE CLEAR AVAILED
753	26-Feb-2022	BAGALKOT	110	MUGALKHOD- KULIGOD	STATION NOT AFFECTED MUGALKHOD_220	10:22	20:10	9:48	LINE CLEAR AVAILED
754	26-Feb-2022	BAGALKOT	110	MUGALKHOD-NAGANUR	STATION NOT AFFECTED MUGALKHOD_220	10:22	20:10	9:48	LINE CLEAR AVAILED
755	26-Feb-2022	BAGALKOT	110	MUGALKHOD- PG HUNSHYAL	STATION NOT AFFECTED MUGALKHOD_220	10:17	20:15	9:58	LINE CLEAR AVAILED
756	26-Feb-2022	BAGALKOT	110	AMBEWADI- NK-1	STATION NOT AFFECTED AMBEWADI_220	11:46	11:51	0:05	HAND TRIPPED
757	26-Feb-2022	BAGALKOT	110	AMBEWADI- NK-1	STATION NOT AFFECTED AMBEWADI_220	15:19	15:40	0:21	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
758	26-Feb-2022	BAGALKOT	110	AMBEWADI- NK-2	STATION NOT AFFECTED AMBEWADI_220	15:19	15:40	0:21	HAND TRIPPED
759	26-Feb-2022	BAGALKOT	110	KUDCHI- AINAPUR(YELPHARATTI)	YELPHARATTI_110	12:57	13:15	0:18	LINE FAULT
760	26-Feb-2022	BAGALKOT	110	KUDCHI-TERDAL(MORAB)	MORAB_110	6:17	6:35	0:18	LINE FAULT
761	26-Feb-2022	BAGALKOT	110	RANEBENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEBENNUR_220	18:42 (14.02.2022)			LINE OPEN,LINE CLEAR AVOIDED
762	26-Feb-2022	BAGALKOT	110	CHIKKODI220- RAIBAG2	CHIKKODI_220	20:00 (25.02.2022)	18:35 (26.02.2022)	22:35HRS	LINE CHARGED
763	26-Feb-2022	BAGALKOT	110	110/11KV, HV2	RAMADURGA_110	9:50	10:30	0:40	LINE CLEAR AVOIDED
764	26-Feb-2022	BAGALKOT	220	KARWAR- KADRA LINE 2	KARWAR_220	13:47	14:10	0:33	HAND TRIPPED
765	26-Feb-2022	BAGALKOT	110	110/11KV, HV2	ANKALI_110	10:05	12:30	2:25	LINE CLEAR AVOIDED
766	26-Feb-2022	BAGALKOT	110	110/11KV, HV1	HALIYAL_110	14:05	14:19	0:14	TRANSFORMER FAULT
767	26-Feb-2022	BAGALKOT	220	220/110KV, HV1&LV1	SIRSI_220	11:34	11:51	0:17	TRANSFORMER FAULT
768	26-Feb-2022	BAGALKOT	110	RANEBENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEBENNUR_220	18:42 (14.02.2022)			LINE OPEN,LINE CLEAR AVOIDED
769	26-Feb-2022	BENGALURU	66	ABBIGERE - YELAHANKA 220	ABBIGERE	9:54	9:58	0:04	LOAD CHANGE OVER
770	26-Feb-2022	BENGALURU	66	HV2	ABBIGERE	12:14	13:50	1:36	LINE CLEAR AVOIDED
771	26-Feb-2022	BENGALURU	66	HV3	ADUGODI	10:56	11:00	0:04	LINE CLEAR AVOIDED
772	26-Feb-2022	BENGALURU	66	BOODIGERE - HOSKOTE 220	BOODIGERE	9:55	10:00	0:05	LOAD CHANGE OVER
773	26-Feb-2022	BENGALURU	66	HV1	BTM 4TH PHASE	16:02	16:05	0:03	LINE CLEAR AVOIDED
774	26-Feb-2022	BENGALURU	66	HV1	ELECTRONIC CITY	12:26	14:25	1:59	LINE CLEAR AVOIDED
775	26-Feb-2022	BENGALURU	66	HV1	EPIP 220	14:01	14:26	0:25	LINE CLEAR AVOIDED
776	26-Feb-2022	BENGALURU	66	ISRO LAYOUT - SUBRAMANYAPURA 220	ISRO LAYOUT	11:10	14:50	3:40	LINE CLEAR AVOIDED
777	26-Feb-2022	BENGALURU	66	KHB - YELAHANKA 220	KHB	9:50	10:05	0:15	LOAD CHANGE OVER
778	26-Feb-2022	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	13:46	14:00	0:14	TRANSFORMER FAULT
779	26-Feb-2022	BENGALURU	220	HV2	YELAHANKA 220	10:08	19:01	8:53	LINE CLEAR AVOIDED
780	26-Feb-2022	BENGALURU	66	HV2	MAASTHI	15:44	15:52	0:08	TRANSFORMER FAULT
781	26-Feb-2022	BENGALURU	66	HV1	KOLAR 220	11:55	12:05	0:10	LINE CLEAR AVOIDED
782	26-Feb-2022	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	12:02	13:02	1:00	LINE CLEAR AVOIDED
783	26-Feb-2022	BENGALURU	66	KOLAR 220 - MULBAGAL	NO STATION AFFECTED	11:00	11:05	0:05	LINE CLEAR AVOIDED
784	26-Feb-2022	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	10:55	11:08	0:13	LINE CLEAR AVOIDED
785	26-Feb-2022	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	11:10	12:03	0:53	LINE FAULT
786	26-Feb-2022	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	8:54	18:30	9:36	LOAD CURTAILMENT
787	26-Feb-2022	BENGALURU	66	BOODIGERE - HOSKOTE 220	BOODIGERE	9:55	10:00	0:05	LOAD CHANGE OVER
788	26-Feb-2022	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	23:43	23:55	0:12	LINE FAULT
789	26-Feb-2022	GULBARGA	400	GUTTUR-BPTS	GUTTUR_400	23:21(25.02.2022)	12:05(26.02.2022)	12:44HRS	LINE CHARGED
790	26-Feb-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
791	26-Feb-2022	GULBARGA	220	HV1	SHAHABAD_220	6:27	6:35	0:08	TRANSFORMER FAULT
792	26-Feb-2022	GULBARGA	220	HV2	ALIPUR_220	12:45	13:07:00	0:22	TRANSFORMER FAULT
793	26-Feb-2022	GULBARGA	220	HV2	ALIPUR_220	13:25	13:32:00	0:07	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
794	26-Feb-2022	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	8:27	17:49	9:22	LINE CLEAR AVAIED
795	26-Feb-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAIED
796	26-Feb-2022	GULBARGA	110	HV1	PD_HALLI_110	15:52	16:05	0:13	TRANSFORMER FAULT
797	26-Feb-2022	GULBARGA	110	HV2	SREERAMANAGAR_110	9:15	18:30	9:15	TRANSFORMER FAULT
798	26-Feb-2022	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	22:10	22:25	0:15	MAIN SUPPLY FAILURE
799	26-Feb-2022	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	6:15	6:18	0:03	LINE FAULT
800	26-Feb-2022	GULBARGA	110	NANDUR-SHAHABAD	NANDUOR_110	6:25	7:15	0:50	MAIN SUPPLY FAILURE
801	26-Feb-2022	GULBARGA	110	SIRIGERICROSS-ALIPURA	SIRIGERICROSS_110	12:52	13:12	0:20	MAIN SUPPLY FAILURE
802	26-Feb-2022	GULBARGA	110	JAWALGERA-ADAVI AMARESHWAR_110	ADAVI AMARESHWAR_110	5:30	5:35:00	0:05	LINE FAULT
803	26-Feb-2022	GULBARGA	110	JEEWARGI-SHAHBAD	JEEWARGI_110	6:25	6:50:00	0:25	MAIN SUPPLY FAILURE
804	26-Feb-2022	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_11 0,KURUGOD_110,SHATAVAHAN A_IPP,AGARWAL_IPP,AGARWAL _IPP,SUZLON_IPP,KAMLAPUR_IP P,MATR_110,RBNS FACTORY	12:47	13:09:00	0:22	LINE CLEAR AVAIED
805	26-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	1:08	1:10	0:02	LINE FAULT
806	26-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:16	5:21	0:05	LINE FAULT
807	26-Feb-2022	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110 ,DEVANGAON_110,RENUKA_IPP ,AFZALPUR_110,KARAJAGI_110	6:27	6:45	0:18	LINE CLEAR AVAIED
808	26-Feb-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	6:27	6:47	0:35	LINE CLEAR AVAIED
809	26-Feb-2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110,MANVI_110	4:51	5:03	0:12	LINE FAULT
810	26-Feb-2022	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	16:08	16:20	0:12	LINE FAULT
811	26-Feb-2022	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	21:48	21:59	0:11	LINE FAULT
812	26-Feb-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YE RDONA_110,SRNAGAR_110,MA LLAPURA_110	3:59	4:09	0:10	LINE FAULT
813	26-Feb-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAISAPUR_110, WADAGERA_110,SANNATHI_IPP ,COREGREENSUGARS_IPP	3:32	3:37	0:05	LINE FAULT
814	26-Feb-2022	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IP P,HUNASIGI_110,ASKI_110	4:43	4:47	0:04	LINE FAULT
815	26-Feb-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:40	21:47	0:07	LINE FAULT
816	26-Feb-2022	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAIED
817	26-Feb-2022	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAIED
818	26-Feb-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAIED
819	26-Feb-2022	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAIED
820	26-Feb-2022	HASSAN	220	DABUS-DABUSET	KADUR_220	11:45	14:36	2:51	LINE CLEAR AVAIED
821	26-Feb-2022	HASSAN	220	GOPAL-BASTIPURA	GOPALAPURA_220	9:54	18:25	8:31	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
822	26-Feb-2022	HASSAN	110	MOODABI-SOHAM1	MOODABIDRE_110	11:08	11:23	0:15	HAND TRIPPED
823	26-Feb-2022	HASSAN	110	JOG11-AMBTR1	JOG_110	8:08(26.02.2022)			LINE OPEN,LINE CLEAR AVAILED
824	26-Feb-2022	HASSAN	110	HV3	PUTTUR_110	1:29	2:51	1:22	TRANSFORMER FAULT
825	26-Feb-2022	HASSAN	66	HV1	HIRESAVE_66	16:26	16:31	0:05	TRANSFORMER FAULT
826	26-Feb-2022	HASSAN	66	UDAYAPU-SATHENAHALLI	UDAYAPURA_66	6:48	6:52	0:04	MAIN SUPPLY FAILURE
827	26-Feb-2022	HASSAN	66	SHANTIGRAMA	UDAYAPURA_66	6:48	6:56	0:08	MAIN SUPPLY FAILURE
828	26-Feb-2022	HASSAN	66	UDAYAPU-UDAYAPURA	CHANNARAYAPATNA_66	6:25	6:45	0:20	LINE FAULT
829	26-Feb-2022	HASSAN	66	CHANNARA-MALLALI	CHANNARAYAPATNA_66	6:25	6:45	0:20	LINE FAULT
830	26-Feb-2022	MYSURU	66	HV1	CHANDRAVADI_66	14:30	14:36	0:06	TRANSFORMER FAULT
831	26-Feb-2022	MYSURU	66	BILIKERE-KHB	DMG_HALLI_66	13:10	13:33	0:23	LINE FAULT
832	26-Feb-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
833	26-Feb-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
834	26-Feb-2022	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	16:44	17:48	1:03	LINE FAULT
835	26-Feb-2022	TUMKUR	220	TR-2	MADHUGIRI_220	10:18	20:05	9:47	LINE CLEAR AVAILED
836	26-Feb-2022	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	13:20	13:32	0:12	LOAD CURTAILMENT
837	26-Feb-2022	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	12:13	12:41	0:27	LOAD CURTAILMENT
838	26-Feb-2022	TUMKUR	110	TR-2	SAMPIGE_110	11:31	12:10	0:39	LINE CLEAR AVAILED
839	26-Feb-2022	TUMKUR	66	TR-1	MADHUGIRI_66	10:42:53 (21.2.22)	17:20(26.2. 22)	126:38HR S	TRANSFORMER CHARGED
840	26-Feb-2022	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	15:02	15:52	0:50	LINE FAULT
841	26-Feb-2022	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	15:32	15:46	0:14	LINE FAULT
842	26-Feb-2022	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	16:52	17:11	0:18	LINE FAULT
843	26-Feb-2022	TUMKUR	66	TR-2	BHARAMAGIRI_66	17:05	17:10	0:05	TRANSFORMER FAULT
844	26-Feb-2022	TUMKUR	66	TR-2	BHARAMAGIRI_66	22:10	22:15	0:05	TRANSFORMER FAULT
845	26-Feb-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:20	18:36	0:15	LINE FAULT
846	26-Feb-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	6:40	18:00	11:20	LINE CLEAR AVAILED
847	26-Feb-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	18:59	20:54	1:55	LINE CLEAR AVAILED
848	26-Feb-2022	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	9:03	9:15	0:12	LINE FAULT
849	26-Feb-2022	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	16:15	16:34	0:19	LINE FAULT
850	27-Feb-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
851	27-Feb-2022	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
852	27-Feb-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
853	27-Feb-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN,LINE FAULT
854	27-Feb-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
855	27-Feb-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
856	27-Feb-2022	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	13:11 (23.02.2022)			LINE OPEN,LINE CLEAR AVAILED
857	27-Feb-2022	BAGALKOT	110	SHIGAON-AVANTI SOLAR	AVANTI SOLAR_110 STATION NOT AFFECTED SHIGAON_110	17:25 (26.02.2022)	2:58 (27.02.2022)	9:33HRS	LINE CHARGED
858	27-Feb-2022	BAGALKOT	110	110/11KV,HV2	ALMEL_110	1:37	1:44	0:07	TRANSFORMER FAULT
859	27-Feb-2022	BAGALKOT	110	110/11KV,HV2	BABALESHWAR_110	15:39	17:10	1:31	LINE CLEAR AVAILED
860	27-Feb-2022	BAGALKOT	110	110/11KV,HV2	HANAGALL_110	12:17	12:46	0:29	TRANSFORMER FAULT
861	27-Feb-2022	BAGALKOT	110	110/11KV HV1	HIEMASALI_110	6:54	6:56	0:02	TRANSFORMER FAULT
862	27-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TUMMINAKATTI_110	22:07	22:11	0:04	TRANSFORMER FAULT
863	27-Feb-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NAREGAL_110	10:27	10:52	0:25	TRANSFORMER FAULT
864	27-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUKARTIHAL_110	10:26	10:50	0:24	LINE CLEAR AVAILED
865	27-Feb-2022	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	11:49	11:58	0:09	TRANSFORMER FAULT
866	27-Feb-2022	BAGALKOT	110	KULIGERE CROSS-MRN SUGARS	STATION NOT AFFECTED KULIGERE CROSS_110	20:41	20:43	0:02	LINE FAULT
867	27-Feb-2022	BAGALKOT	110	MUGALKHOD- SAIDAPUR	STATION NOT AFFECTED MUGALKHOD_220	8:17	19:20	11:03	LINE CLEAR AVAILED
868	27-Feb-2022	BAGALKOT	110	MUGALKHOD- KULIGOD	STATION NOT AFFECTED MUGALKHOD_220	8:17	19:20	11:03	LINE CLEAR AVAILED
869	27-Feb-2022	BAGALKOT	110	MUGALKHOD-NAGANUR	STATION NOT AFFECTED MUGALKHOD_220	8:17	19:20	11:03	LINE CLEAR AVAILED
870	27-Feb-2022	BAGALKOT	110	MUGALKHOD- PG HUNSHYAL	STATION NOT AFFECTED MUGALKHOD_220	8:25	19:25	11:00	LINE CLEAR AVAILED
871	27-Feb-2022	BAGALKOT	110	SHIRAGUPPI - VAJRAMATI	SHIRAGUPPI_110	6:30	6:40	0:10	LINE FAULT
872	27-Feb-2022	BAGALKOT	110	SHIRAGUPPI - BILAGI	SHIRAGUPPI_110	6:30	6:40	0:10	LINE FAULT
873	27-Feb-2022	BAGALKOT	110	BILAGI-GIRISAGAR	GIRISAGAR_110	6:30	6:40	0:10	MAIN SUPPLY FAILURE
874	27-Feb-2022	BAGALKOT	110	SIRAGUPPI-TOLAMATTI	TOLAMATTI_110	6:30	6:40	0:10	MAIN SUPPLY FAILURE
875	27-Feb-2022	BAGALKOT	110	BILAGI - BISNAL	BISNAL_110	6:30	6:40	0:10	MAIN SUPPLY FAILURE
876	27-Feb-2022	BAGALKOT	110	BAGALKOT-RAMDURG	BAGALKOT_220	20:40	20:55	0:15	LINE FAULT
877	27-Feb-2022	BENGALURU	66	HV2	CHATRA	16:22	16:50	0:28	LINE CLEAR AVAILED
878	27-Feb-2022	BENGALURU	66	HEBBALA 220 - PEENYA 2	NO STATION AFFECTED	13:22	15:05	1:43	LINE FAULT
879	27-Feb-2022	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, PADMANABHANAGAR	10:58	11:05	0:07	LINE FAULT
880	27-Feb-2022	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	10:57	11:15	0:18	LINE FAULT
881	27-Feb-2022	BENGALURU	66	JAYADEVA - SARAKKI 1	NO STATION AFFECTED	10:57	15:25	4:28	LINE FAULT
882	27-Feb-2022	BENGALURU	66	JAYADEVA - ADUGODI 1	NO STATION AFFECTED	11:40	16:30	4:50	LINE FAULT
883	27-Feb-2022	BENGALURU	220	HV1	YELAHANKA 220	9:44	17:50	8:05	LINE CLEAR AVAILED
884	27-Feb-2022	BENGALURU	66	HV1	KUNDANA	18:24	18:36	0:12	TRANSFORMER FAULT
885	27-Feb-2022	BENGALURU	66	HV2	HUKUNDA	8:00	8:20	0:20	TRANSFORMER FAULT
886	27-Feb-2022	BENGALURU	66	HV2	GUDIBANDE	12:30	12:48	0:18	TRANSFORMER FAULT
887	27-Feb-2022	BENGALURU	66	HV2	BAIRAKURU	15:59	16:10	0:10	TRANSFORMER FAULT
888	27-Feb-2022	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	10:39	14:02	3:23	LOAD CURTAILMENT
889	27-Feb-2022	BENGALURU	220	LV1	GOWRIBIDANUR 220	6:18	6:30	0:12	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
890	27-Feb-2022	BENGALURU	220	LV2	GOWRIBIDANUR 220	6:18	6:30	0:12	TRANSFORMER FAULT
891	27-Feb-2022	BENGALURU	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	6:18	6:35	0:17	LINE FAULT
892	27-Feb-2022	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADOSANAHALLI	6:18	6:35	0:17	MAIN SUPPLY FAILURE
893	27-Feb-2022	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA, GUNDLU KOTTUR	6:18	6:35	0:17	MAIN SUPPLY FAILURE
894	27-Feb-2022	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	6:18	6:35	0:17	MAIN SUPPLY FAILURE
895	27-Feb-2022	BENGALURU	66	HV1	GOWRIBIDANUR 220	6:18	6:35	0:17	MAIN SUPPLY FAILURE
896	27-Feb-2022	BENGALURU	66	HV2	GOWRIBIDANUR 220	6:18	6:35	0:17	MAIN SUPPLY FAILURE
897	27-Feb-2022	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	6:18	6:35	0:17	MAIN SUPPLY FAILURE
898	27-Feb-2022	GULBARGA	220	HV1	SHAHAPUR_220	2:03	2:33	0:30	TRANSFORMER FAULT
899	27-Feb-2022	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	2:03	2:30	0:27	LINE FAULT
900	27-Feb-2022	GULBARGA	110	HV1	MATAMARI_110	18:45	18:55:00	0:10	TRANSFORMER FAULT
901	27-Feb-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
902	27-Feb-2022	GULBARGA	110	SHAHABAD-FARTHABAD	FARTHABAD_110,GULBARGA SOUTH_110	11:20(27.02.2022)			LINE OPEN,LINE CLEAR AVAILED
903	27-Feb-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
904	27-Feb-2022	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	4:55	5:20	0:25	LINE FAULT
905	27-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	21:10	21:15	0:05	LINE FAULT
906	27-Feb-2022	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	17:45	18:07	0:22	LINE FAULT
907	27-Feb-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YE RDONA_110,SRNAGAR_110,MALLAPURA_110	23:40	23:50	0:10	LINE FAULT
908	27-Feb-2022	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	21:22	21:47	0:25	LINE FAULT
909	27-Feb-2022	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110,KONKAL_110	5:10	5:20	0:10	LINE FAULT
910	27-Feb-2022	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	12:37	12:59	0:22	LINE FAULT
911	27-Feb-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	2:13	2:24	0:11	LINE FAULT
912	27-Feb-2022	GULBARGA	110	GURMITKAL-SEDAM	GURMITKAL_110	5:10	5:25	0:15	MAIN SUPPLY FAILURE
913	27-Feb-2022	GULBARGA	110	MARGUTTI-CLEANSLR	MARGUTTI_110	19:05	21:35	2:30	LINE CLEAR AVAILED
914	27-Feb-2022	GULBARGA	110	LINGASUGUR-KHAREPOWER	CHAYADEVI_IPP,KAREPOWER_IPP	11:01	11:48	0:47	LINE CLEAR AVAILED
915	27-Feb-2022	GULBARGA	66	HV1	ITTAGI_220	14:37	14:55	0:18	TRANSFORMER FAULT
916	27-Feb-2022	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
917	27-Feb-2022	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
918	27-Feb-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
919	27-Feb-2022	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
920	27-Feb-2022	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	13:35	14:00	0:25	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
921	27-Feb-2022	HASSAN	110	JOG11-AMBTR1	JOG_110	8:08(26.02.2022)			LINE OPEN,LINE CLEAR AVAILED
922	27-Feb-2022	HASSAN	110	JOG-JLT4	gen_mghe	15:04	17:10	2:06	LINE FAULT
923	27-Feb-2022	HASSAN	110	JOG11-LPH	JOG_110	13:34	16:49	3:15	LINE FAULT
924	27-Feb-2022	HASSAN	110	LPH-JLT3	gen_lph	13:35	17:11	3:36	LINE FAULT
925	27-Feb-2022	HASSAN	110	LPH-JLT4	gen_lph	15:18	17:12	1:54	LINE CLEAR AVAILED
926	27-Feb-2022	HASSAN	110	MRSSHM-GAJNUR	MRSMG_220	13:35	13:52	0:17	HAND TRIPPED
927	27-Feb-2022	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	9:49	13:37	3:48	LINE CLEAR AVAILED
928	27-Feb-2022	HASSAN	110	SAGARA-SORABA	SAGARA_110	13:55	14:17	0:22	LINE CLEAR AVAILED
929	27-Feb-2022	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	0:34	0:37	0:03	LINE FAULT
930	27-Feb-2022	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	2:56	3:00	0:04	LINE FAULT
931	27-Feb-2022	HASSAN	66	HV2	BALEHONNUR_66	10:00	10:15	0:15	TRANSFORMER FAULT
932	27-Feb-2022	HASSAN	66	HV1	HIRESAVE_66	7:36	7:39	0:03	TRANSFORMER FAULT
933	27-Feb-2022	HASSAN	66	HV1	HIRESAVE_66	8:35	8:39	0:04	TRANSFORMER FAULT
934	27-Feb-2022	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	6:31	6:39	0:08	LINE FAULT
935	27-Feb-2022	HASSAN	66	HV1	SAKLESH PURA_66	3:09	3:51	0:42	TRANSFORMER FAULT
936	27-Feb-2022	HASSAN	66	HV1	SAKLESH PURA_66	13:58	14:19	0:21	TRANSFORMER FAULT
937	27-Feb-2022	HASSAN	66	SIGEBBA-KDLGRE	SIGEBAG_66	10:51	11:05	0:14	LINE FAULT
938	27-Feb-2022	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	5:34	8:21	2:47	MAIN SUPPLY FAILURE
939	27-Feb-2022	HASSAN	66	CHANNARA-MALLALI	CHANNARAYAPATNA_66	5:34	5:50	0:16	LINE FAULT
940	27-Feb-2022	MYSURU	66	ARAKERE-TUBINAKERE	ARAKERE_66	12:15	12:20	0:05	LINE FAULT
941	27-Feb-2022	MYSURU	66	HV1	DEVANOORNGUDU_66	11:12	11:17	0:04	TRANSFORMER FAULT
942	27-Feb-2022	MYSURU	66	HV1	KOLLEGALA_66	6:35	9:44	3:08	TRANSFORMER FAULT
943	27-Feb-2022	MYSURU	66	KR NAGARA-MYSORE-1	MIRLE_66	6:27	6:33	0:06	LINE FAULT
944	27-Feb-2022	MYSURU	66	KUSHALANAGARA 220-MYSORE-1	MIRLE_66	6:27	6:32	0:05	LINE FAULT
945	27-Feb-2022	MYSURU	66	TALAKADU-ADANI	NO STATIONS EFFECTED	9:39	10:00	0:20	LINE FAULT
946	27-Feb-2022	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	BASARALU_66, HARADANAHALLI(JAK)_66, KESLAGERE_66,SHIVALLY_66	11:15	11:21	0:06	LINE FAULT
947	27-Feb-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
948	27-Feb-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
949	27-Feb-2022	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	8:23	20:02	11:38	LINE CLEAR AVAILED
950	27-Feb-2022	TUMKUR	220	NITTUR 220KV- ARASIKERE	NITTUR_220	11:08	14:02	2:54	LOAD CURTAILMENT
951	27-Feb-2022	TUMKUR	110	CHIKKANAYAKANAHALLI- HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	11:10	11:16	0:05	LINE FAULT
952	27-Feb-2022	TUMKUR	110	TR-1	MAYASANDRA_110	10:26	10:34	0:07	TRANSFORMER FAULT
953	27-Feb-2022	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	14:03	14:25	0:21	LINE FAULT
954	27-Feb-2022	TUMKUR	66	BRAHMASANDRA- THOVINKERE	THOVINAKERE_66, KORA_66	14:03	14:35	0:31	LINE FAULT
955	27-Feb-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	19:01	19:20	0:19	LINE FAULT
956	27-Feb-2022	TUMKUR	66	TR-1	KADAJJI_66	8:44	8:50	0:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
957	27-Feb-2022	TUMKUR	66	TR-1	KADAJJI_66	18:16	18:58	0:41	LINE CLEAR AVAILED
958	27-Feb-2022	TUMKUR	66	TR-2	KADAJJI_66	18:16	18:58	0:41	LINE CLEAR AVAILED
959	27-Feb-2022	TUMKUR	66	TR-1	KORA_66	8:50	9:07	0:17	TRANSFORMER FAULT
960	27-Feb-2022	TUMKUR	66	TR-1	KORA_66	14:03	14:10	0:07	TRANSFORMER FAULT
961	27-Feb-2022	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKWADA_66	8:08	8:24	0:15	LINE FAULT
962	27-Feb-2022	TUMKUR	66	TR-1	MAVINAKATTE_66	15:16	15:22	0:05	TRANSFORMER FAULT
963	27-Feb-2022	TUMKUR	66	TR-1	MAVINAKATTE_66	10:50	11:05	0:15	MAIN SUPPLY FAILURE
964	27-Feb-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	6:37	18:41	12:04	LINE CLEAR AVAILED
965	28-Feb-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
966	28-Feb-2022	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
967	28-Feb-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
968	28-Feb-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN,LINE FAULT
969	28-Feb-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
970	28-Feb-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
971	28-Feb-2022	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	13:11 (23.02.2022)			LINE OPEN,LINE CLEAR AVAILED
972	28-Feb-2022	BAGALKOT	110	110/11KV,HV1	ANKOLA_110	3:46	3:57	0:11	TRANSFORMER FAULT
973	28-Feb-2022	BAGALKOT	110	110/11KV,HV2	BABALESHWAR_110	12:41	13:50	1:09	LINE CLEAR AVAILED
974	28-Feb-2022	BAGALKOT	110	110/11KV,HV1	GOPANAKOPPA_110	16:34	16:52	0:18	LINE CLEAR AVAILED
975	28-Feb-2022	BAGALKOT	110	110/11KV,HV3	HANAGAL_110	14:30	21:23	6:53	LINE CLEAR AVAILED
976	28-Feb-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED VAJRAMATTI_110	6:13	6:26	0:13	TRANSFORMER FAULT
977	28-Feb-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED UKKALI_110	16:29	16:39	0:10	TRANSFORMER FAULT
978	28-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TUMMINAKATTI_110	13:00	17:45	4:45	LINE CLEAR AVAILED
979	28-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED JAMAKHANDI_110	12:41	12:50	0:09	LINE CLEAR AVAILED
980	28-Feb-2022	BAGALKOT	110	MUGALKHOD- SAIDAPUR	STATION NOT AFFECTED MUGALKHOD_220	11:14	19:45	8:31	LINE CLEAR AVAILED
981	28-Feb-2022	BAGALKOT	110	MUGALKHOD- KULIGOD	STATION NOT AFFECTED MUGALKHOD_220	11:18	19:46	8:28	LINE CLEAR AVAILED
982	28-Feb-2022	BAGALKOT	110	MUGALKHOD-NAGANUR	STATION NOT AFFECTED MUGALKHOD_220	11:20	19:47	8:27	LINE CLEAR AVAILED
983	28-Feb-2022	BAGALKOT	110	MUGALKHOD- PG HUNSHYAL	STATION NOT AFFECTED MUGALKHOD_220	11:22	19:48	8:26	LINE CLEAR AVAILED
984	28-Feb-2022	BAGALKOT	110	RANEBENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEBENNUR_220	18:42 (14.02.2022)			LINE OPEN,LINE CLEAR AVAILED
985	28-Feb-2022	BAGALKOT	110	110/11KV, HV1	VAJRAMATI_110	6:10	6:25	0:15	TRANSFORMER FAULT
986	28-Feb-2022	BAGALKOT	110	110/11KV, HV1	MELLIGERI_110	16:40	17:50	1:10	LINE CLEAR AVAILED
987	28-Feb-2022	BAGALKOT	110	110/11KV, HV1	MANTUR(B)_110	12:40	12:45	0:05	TRANSFORMER FAULT
988	28-Feb-2022	BAGALKOT	110	110/11KV, HV1	KUDACHI_110	4:30	8:30	4:00	LINE CLEAR AVAILED
989	28-Feb-2022	BAGALKOT	110	110/11KV, HV1	KUDACHI_110	10:15	10:30	0:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
990	28-Feb-2022	BAGALKOT	110	110/11KV, HV1	KUDACHI_110	12:50	12:55	0:05	TRANSFORMER FAULT
991	28-Feb-2022	BAGALKOT	110	110/11KV, HV1	KUDACHI_110	17:05	17:20	0:15	TRANSFORMER FAULT
992	28-Feb-2022	BAGALKOT	110	110/11KV, HV1	KATAKOL_110	11:35	12:50	1:15	LINE CLEAR AVAIED
993	28-Feb-2022	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	18:24	18:28	0:04	LOAD CHANGE OVER
994	28-Feb-2022	BENGALURU	66	KADUGODI - ARMY WELFARE	ARMY WELFARE ORGANISATION, KONDASPURA	7:20	8:20	1:00	LINE FAULT
995	28-Feb-2022	BENGALURU	66	KHB - SRS PEENYA 220	KHB	6:15	6:20	0:05	LOAD CHANGE OVER
996	28-Feb-2022	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	14:30	14:35	0:05	LINE CLEAR AVAIED
997	28-Feb-2022	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	15:15	15:20	0:05	LOAD CHANGE OVER
998	28-Feb-2022	BENGALURU	66	HV1	REMCO	20:26	20:50	0:24	MAIN SUPPLY FAILURE
999	28-Feb-2022	BENGALURU	66	HV1	VIJAYANAGARA	20:28	20:54	0:26	MAIN SUPPLY FAILURE
1000	28-Feb-2022	BENGALURU	220	VRISHABHAVATHI 220 - TATAGUNI 220	VRISHABHAVATHI 220	20:27	20:44	0:17	LINE FAULT
1001	28-Feb-2022	BENGALURU	66	VRISHABHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	20:27	20:50	0:23	LINE CLEAR AVAIED
1002	28-Feb-2022	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	REMCO	20:27	20:59	0:32	LINE CLEAR AVAIED
1003	28-Feb-2022	BENGALURU	66	VRISHABHAVATHI 220 - SIR MV LAYOUT	KENGERI SATELLITE TOWN, SIR MV LAYOUT	20:27	20:52	0:25	LINE CLEAR AVAIED
1004	28-Feb-2022	BENGALURU	66	VRISHABHAVATHI 220 - BANASHANKARI	BANASHANKARI	20:27	20:50	0:23	LINE CLEAR AVAIED
1005	28-Feb-2022	BENGALURU	66	ARMY WELFARE ORGANISATION - KONDASPURA	ARMY WELFARE ORGANISATION	10:20	10:35	0:15	LOAD CHANGE OVER
1006	28-Feb-2022	BENGALURU	220	HV2	GOWRIBIDANUR 220	16:10	16:40	0:30	LINE CLEAR AVAIED
1007	28-Feb-2022	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	5:20	5:32	0:12	LINE FAULT
1008	28-Feb-2022	BENGALURU	66	KONDASPURA - HOSKOTE 220	KONDASPURA	10:50	10:55	0:05	LOAD CHANGE OVER
1009	28-Feb-2022	BENGALURU	66	HV2	SIDDALAGATTA	9:55	11:06	1:11	LINE CLEAR AVAIED
1010	28-Feb-2022	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	11:48	12:01	0:13	LINE FAULT
1011	28-Feb-2022	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	17:20	17:30	0:10	LINE CLEAR AVAIED
1012	28-Feb-2022	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	17:20	17:30	0:10	LINE CLEAR AVAIED
1013	28-Feb-2022	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	17:20	17:30	0:10	LINE CLEAR AVAIED
1014	28-Feb-2022	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	4:00	4:15	0:15	MAIN SUPPLY FAILURE
1015	28-Feb-2022	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	4:00	4:15	0:15	MAIN SUPPLY FAILURE
1016	28-Feb-2022	BENGALURU	66	HV1	MITTEMARI 220	4:00	4:15	0:15	MAIN SUPPLY FAILURE
1017	28-Feb-2022	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	4:00	4:35	0:35	MAIN SUPPLY FAILURE
1018	28-Feb-2022	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	NO STATION AFFECTED	16:05	16:19	0:14	MAIN SUPPLY FAILURE
1019	28-Feb-2022	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	7:00	7:10	0:10	LOAD CHANGE OVER
1020	28-Feb-2022	BENGALURU	220	HV2	MITTEMARI 220	4:00(28-2-2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1021	28-Feb-2022	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(28.02.2022)			LINE OPEN,LINE FAULT
1022	28-Feb-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1023	28-Feb-2022	GULBARGA	220	HV1	SHAHAPUR_220	2:03	2:33	0:30	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1024	28-Feb-2022	GULBARGA	220	KUSTAGI-SULEKAL	SULEKAL_220	15:39	16:36	0:57	LINE FAULT
1025	28-Feb-2022	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	16:29	16:38	0:09	LINE FAULT
1026	28-Feb-2022	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	2:03	2:30	0:27	LINE FAULT
1027	28-Feb-2022	GULBARGA	220	KAPNOOR-SHAHAPUR	SHAHAPUR_220	2:05	2:29	0:24	LINE FAULT
1028	28-Feb-2022	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	2:02	2:10	0:08	LINE FAULT
1029	28-Feb-2022	GULBARGA	220	ITTAGI-LINGAPUR	ITTAGI_220	13:06 (28.02.2022)			LINE OPEN,LINE FAULT
1030	28-Feb-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1031	28-Feb-2022	GULBARGA	110	HV2	GHATTARGA_110	11:40(28.02.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1032	28-Feb-2022	GULBARGA	110	HV1	GHATTARGA_110	11:00:00	11:40	0:40	LINE CLEAR AVAILED
1033	28-Feb-2022	GULBARGA	110	SHAHABAD-FARTHABAD	FARTHABAD_110,GULBARGA SOUTH_110	11:20(27.02.2022)	10:05(28.0 2.2022)	22:45HRS	LINE CHARGED
1034	28-Feb-2022	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	6:03	6:14	0:11	LINE FAULT
1035	28-Feb-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YE RDONA_110,SRNAGAR_110,MA LLAPURA_110	3:55	4:15	0:20	LINE FAULT
1036	28-Feb-2022	GULBARGA	110	MUDDAPURA-MASKI	MASKI_110	0:38	0:43	0:05	LINE FAULT
1037	28-Feb-2022	GULBARGA	110	AURAD-DONGARGOAN	DONGARGOAN_110	14:50	14:55	0:05	LINE FAULT
1038	28-Feb-2022	GULBARGA	110	JAWALGERA-ADAVI AMARESHWAR_110	ADAVI AMARESHWAR_110	4:10	4:15	0:05	LINE FAULT
1039	28-Feb-2022	GULBARGA	110	VAJRABANDI-KUSHTAGI	VAJRABANDI_110	16:30	17:10	0:40	MAIN SUPPLY FAILURE
1040	28-Feb-2022	GULBARGA	110	GALAG-MALLAT	GALAG_110	6:05	6:20	0:15	MAIN SUPPLY FAILURE
1041	28-Feb-2022	GULBARGA	110	CHINCHOLI-RENEWSLR_IPP	CHINCHOLI_110	19:30	21:35	2:05	LINE CLEAR AVAILED
1042	28-Feb-2022	GULBARGA	110	CHINCHOLUI-SEDAM	CHINCHOLI_110	18:35	19:15	0:40	MAIN SUPPLY FAILURE
1043	28-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	4:20	4:25	0:05	LINE FAULT
1044	28-Feb-2022	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	6:03	6:14	0:11	LINE FAULT
1045	28-Feb-2022	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_ 110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	13:58	14:08	0:10	LINE FAULT
1046	28-Feb-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	2:13	2:24	0:11	LINE FAULT
1047	28-Feb-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110 ,WADAGERA_110,SANNATHI_IP P,COREGREENSUGARS_IPP	13:27	14:17	0:50	LINE CLEAR AVAILED
1048	28-Feb-2022	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	18:40	19:15	0:35	LINE FAULT
1049	28-Feb-2022	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110,KONKAL_110	23:35	23:45	0:10	LINE FAULT
1050	28-Feb-2022	GULBARGA	66	HV2	TAMBRAHALLI_66	7:25	7:30	0:05	TRANSFORMER FAULT
1051	28-Feb-2022	GULBARGA	66	HV1	HARVI_66	9:00	9:08	0:08	LINE CLEAR AVAILED
1052	28-Feb-2022	GULBARGA	66	HV1	HARVI_66	16:35	17:07	0:32	LINE CLEAR AVAILED
1053	28-Feb-2022	GULBARGA	66	PUNABGHATA- UCHCHANGIDURGA	UCHCHANGIDURGA_66	8:05	8:35	0:30	LINE FAULT
1054	28-Feb-2022	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCHCHANGIDURGA_66	8:07	8:28	0:21	LINE FAULT
1055	28-Feb-2022	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCHCHANGIDURGA_66	13:58	14:09	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1056	28-Feb-2022	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCHCHANGIDURGA_66	22:06	22:19	0:13	LINE FAULT
1057	28-Feb-2022	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCHCHANGIDURGA_66	22:22	22:53	0:31	LINE FAULT
1058	28-Feb-2022	GULBARGA	66	BENNEHALLI-ITTAGGI	BENNEHALLI_66	13:10	13:40	0:30	MAIN SUPPLY FAILURE
1059	28-Feb-2022	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1060	28-Feb-2022	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1061	28-Feb-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1062	28-Feb-2022	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1063	28-Feb-2022	HASSAN	220	GOPALPURA-BASTIPURA	GOPALAPURA_220	10:23	14:31	4:08	LINE FAULT
1064	28-Feb-2022	HASSAN	220	HV2	KADUR_220	9:49	10:02	0:13	TRANSFORMER FAULT
1065	28-Feb-2022	HASSAN	110	LV2	KADUR_220	9:49	10:02	0:13	TRANSFORMER FAULT
1066	28-Feb-2022	HASSAN	110	HV1	KADUR_220	9:49	10:02	0:13	TRANSFORMER FAULT
1067	28-Feb-2022	HASSAN	110	LV1	KADUR_220	9:49	10:02	0:13	TRANSFORMER FAULT
1068	28-Feb-2022	HASSAN	110	KADUR-NERELEKERE	KADUR_220	9:49	10:02	0:13	MAIN SUPPLY FAILURE
1069	28-Feb-2022	HASSAN	110	KADUR-NGNHL	KADUR_220	9:49	10:02	0:13	MAIN SUPPLY FAILURE
1070	28-Feb-2022	HASSAN	110	KADUR-TNGL	KADUR_220	9:49	10:02	0:13	MAIN SUPPLY FAILURE
1071	28-Feb-2022	HASSAN	110	KADUR-YGTI	KADUR_220	9:49	10:02	0:13	MAIN SUPPLY FAILURE
1072	28-Feb-2022	HASSAN	110	KADUR-AJAMPURA	KADUR_220	9:49	10:02	0:13	MAIN SUPPLY FAILURE
1073	28-Feb-2022	HASSAN	110	ANAVATI-BARNGI	ANAVATTI:110	18:45	18:55	0:10	LINE CLEAR AVAILED
1074	28-Feb-2022	HASSAN	110	ANAVATI-BARNGI	BARANGI_110	14:00	18:53	4:53	NFBC ISSUED
1075	28-Feb-2022	HASSAN	110	JOG-JLT4	gen_mghe	13:32	14:02	0:30	LINE FAULT
1076	28-Feb-2022	HASSAN	110	JOG110-AMBTR1	JOG_110	8:08(26.02.2022)	11:42(28.02.2022)	47:34HRS	LINE CHARGED
1077	28-Feb-2022	HASSAN	110	JOG110-LPH	JOG_110	12:40	17:34	4:54	LINE CLEAR AVAILED
1078	28-Feb-2022	HASSAN	110	LPH-MGHE 1	gen_lph	12:41	17:37	4:56	LINE FAULT
1079	28-Feb-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	16:23	16:57	0:34	LINE CLEAR AVAILED
1080	28-Feb-2022	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	12:18	12:35	0:17	LINE FAULT
1081	28-Feb-2022	HASSAN	66	HV1	CHIKKAMAGLUR_66	11:11	13:11	2:00	LINE CLEAR AVAILED
1082	28-Feb-2022	HASSAN	66	HV1	HIRESAVE_66	13:55	13:57	0:02	TRANSFORMER FAULT
1083	28-Feb-2022	HASSAN	66	HV2	HIRESAVE_66	11:15	11:17	0:02	TRANSFORMER FAULT
1084	28-Feb-2022	HASSAN	66	HV1	SAKALESHPURA_66	8:34	8:46	0:12	TRANSFORMER FAULT
1085	28-Feb-2022	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	9:30	13:50	4:20	LINE CLEAR AVAILED
1086	28-Feb-2022	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	9:30	13:50	4:20	LINE CLEAR AVAILED
1087	28-Feb-2022	MYSURU	66	HAMPAPURA-BASARALU	BESAGARAHALLI_66, KOPPA_66	19:55	20:09	0:14	LINE FAULT
1088	28-Feb-2022	MYSURU	66	HV1	HULLAHALLI_66	14:29	16:17	1:48	MAIN SUPPLY FAILURE
1089	28-Feb-2022	MYSURU	66	HV2	HULLAHALLI_66	14:29	16:17	1:48	MAIN SUPPLY FAILURE
1090	28-Feb-2022	MYSURU	66	HULLAHALLI-KADAKOLKA	HULLAHALLI_66	14:29	16:17	1:48	NFBC ISSUED
1091	28-Feb-2022	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	21:36	21:45	0:08	LINE FAULT
1092	28-Feb-2022	MYSURU	66	KADAKOLA-NANJANGUDU 1	NANJANGUDU_66	22:47(28.2.22)			LINE OPEN,LINE FAULT
1093	28-Feb-2022	MYSURU	66	KADAKOLA-NANJANGUDU 2	THANDYA_66	22:47	23:28	0:40	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1094	28-Feb-2022	MYSURU	66	KADAKOLA-SARAGURU 2	DOORA_66 HURA_66 HULLAHALLI_66	14:24	15:48	1:23	LINE CLEAR AVAILED
1095	28-Feb-2022	MYSURU	66	KR NAGARA-MYSORE 1	MIRLE_66	23:45	23:59	0:14	LINE FAULT
1096	28-Feb-2022	MYSURU	66	KUSHALANAGARA 220-MYSORE 1	BILIKERE_66 BHERYA_66 DMG_HALLI_66 GVGUDI_66 MIRLE_66 KRNAGARA_66	23:45	23:59	0:13	LINE FAULT
1097	28-Feb-2022	MYSURU	66	KUSHALANAGARA 220-MYSORE 2	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITUR_66 RAVANDUR_66	23:45	23:59	0:14	LINE FAULT
1098	28-Feb-2022	MYSURU	66	MADHUVANAHALLI-HANNUR 1	NO STATIONS EFFECTED	18:24	18:28	0:04	LINE FAULT
1099	28-Feb-2022	MYSURU	66	HV2	MADHUVANAHALLI_220	13:13	13:21	0:07	TRANSFORMER FAULT
1100	28-Feb-2022	MYSURU	66	NANJANAGUDU-SINDHUVALLI	NO STATIONS EFFECTED	22:48(28.2.22)			LINE OPEN,LINE FAULT
1101	28-Feb-2022	MYSURU	66	NANJANAGUDU-THANDYA	NANJANGUDU_66	22:48(28.2.22)			LINE OPEN,LINE FAULT
1102	28-Feb-2022	MYSURU	66	TALAKADU-ADANI	NO STATIONS EFFECTED	16:37	17:01	0:23	LINE FAULT
1103	28-Feb-2022	MYSURU	66	TALAKADU-ADANI	NO STATIONS EFFECTED	17:06	17:21	0:14	HAND TRIPPED
1104	28-Feb-2022	MYSURU	66	HV1	THALAKADU_66	14:20	14:28	0:07	TRANSFORMER FAULT
1105	28-Feb-2022	MYSURU	66	HV2	THALAKADU_66	14:20	14:28	0:07	TRANSFORMER FAULT
1106	28-Feb-2022	MYSURU	66	THANDYA-NANJANGUDU	NO STATIONS EFFECTED	23:26			LINE OPEN,LINE CLEAR AVAILED
1107	28-Feb-2022	MYSURU	66	HEBBANI-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJUPURA_66	15:36	15:52	0:16	LINE FAULT
1108	28-Feb-2022	MYSURU	66	HV4	SFCSHIVA_66	21:39(28.2.22)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1109	28-Feb-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
1110	28-Feb-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1111	28-Feb-2022	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	8:33	22:05	13:32	LINE CLEAR AVAILED
1112	28-Feb-2022	TUMKUR	220	TR-1(HV SIDE)	MADHUGIRI 220kV	11:19	11:38	0:19	HAND TRIPPED
1113	28-Feb-2022	TUMKUR	220	TR-2(HV SIDE)	MADHUGIRI 220kV	11:58	12:25	0:27	HAND TRIPPED
1114	28-Feb-2022	TUMKUR	220	TR-1(HV SIDE)	MADHUGIRI 220kV	17:38	18:01	0:23	LINE CLEAR AVAILED
1115	28-Feb-2022	TUMKUR	110	TR-2	SHETYKERE_110	18:16	18:34	0:17	LINE CLEAR AVAILED
1116	28-Feb-2022	TUMKUR	66	TR-1	BHARAMAGIRI_66	1:52	1:54	0:02	TRANSFORMER FAULT
1117	28-Feb-2022	TUMKUR	66	TR-1	BHARAMAGIRI_66	7:07	7:18	0:11	TRANSFORMER FAULT
1118	28-Feb-2022	TUMKUR	66	TR-1	BHARAMAGIRI_66	7:32	7:40	0:07	TRANSFORMER FAULT
1119	28-Feb-2022	TUMKUR	66	TR-2	BHARAMAGIRI_66	9:20	9:35	0:15	TRANSFORMER FAULT
1120	28-Feb-2022	TUMKUR	66	TR-2	CHANNAGIRI_66	10:42	10:46	0:03	TRANSFORMER FAULT
1121	28-Feb-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:28	18:44	0:16	LINE FAULT
1122	28-Feb-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	19:06	19:13	0:06	LINE FAULT
1123	28-Feb-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	21:02	21:15	0:12	LINE FAULT
1124	28-Feb-2022	TUMKUR	66	TR-2	KOLALA_66	15:19	15:34	0:14	TRANSFORMER FAULT
1125	28-Feb-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	6:27	7:52	1:25	LINE CLEAR AVAILED
1126	28-Feb-2022	TUMKUR	66	TR-2	TAVAREKERE(H)	15:44	15:56	0:12	TRANSFORMER FAULT
1127	28-Feb-2022	TUMKUR	66	TR-1	SIRA_66	9:38	11:27	1:49	TRANSFORMER FAULT
1128	28-Feb-2022	TUMKUR	66	TR-1	SIRA_66	12:55	13:51	0:56	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1129	28-Feb-2022	TUMKUR	66	TR-2	KUKKAWADA_66	15:10	16:42	1:31	LINE CLEAR AVAILED
1130	28-Feb-2022	TUMKUR	66	TR-1	KUKKAWADA_66	16:42	18:14	1:32	LINE CLEAR AVAILED
1131	28-Feb-2022	TUMKUR	66	PD KOTE 66-CLEAR SOLAR IPP_66	CLEAR SOLAR _IPP_66	9:17	9:26	0:08	LINE FAULT
1132	28-Feb-2022	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	6:22	6:36	0:13	LINE FAULT
1133	28-Feb-2022	TUMKUR	66	TR-1	LINGADAHALLY_66(NALLUR)	14:09	14:18	0:09	TRANSFORMER FAULT
1134	28-Feb-2022	TUMKUR	66	TR-1	MADHUGIRI 220kv	11:17	11:33	0:15	HAND TRIPPED
1135	28-Feb-2022	TUMKUR	66	TR-1	MADHUGIRI 220kv	12:25	12:35	0:10	HAND TRIPPED
1136	28-Feb-2022	TUMKUR	66	TR-1	MADHUGIRI 220kv	17:52	18:06	0:14	HAND TRIPPED
1137	28-Feb-2022	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	12:25	12:28	0:03	LINE CLEAR AVAILED
1138	28-Feb-2022	TUMKUR	66	TR-2	MADHUGIRI 220kv	11:58	12:27	0:29	LINE CLEAR AVAILED
1139	28-Feb-2022	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI66	MADHUGIRI_66, BADAVANAHALLI_66	11:17	11:43	0:25	HAND TRIPPED
1140	28-Feb-2022	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI66	MADHUGIRI_66, BADAVANAHALLI_66	12:25	12:28	0:02	HAND TRIPPED
1141	28-Feb-2022	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI66	MADHUGIRI_66, BADAVANAHALLI_66	12:31	12:37	0:05	HAND TRIPPED