

400/220/110/66 kV TRANSMISSION OUTAGES FROM 23.02.2021 TO 01.03.2021

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	23-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
2	23-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
3	23-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
4	23-Feb-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
5	23-Feb-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)	22:17(23.02.2021)	2133:12HRS	TRANSFORMER CHARGED
6	23-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
7	23-Feb-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
8	23-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
9	23-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
10	23-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
11	23-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN:LINE CLEAR AVAILED
12	23-Feb-21	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN:LINE CLEAR AVAILED
13	23-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN:LINE CLEAR AVAILED
14	23-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
15	23-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
16	23-Feb-21	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	00:14 (21.02.2021)			LINE OPEN:LINE FAULT
17	23-Feb-21	BAGALKOT	110	MAHALINGAPUR-JAMAKHANDI	JAMAKHANDI_110	22:54 (21.02.2021)			LINE OPEN:LINE FAULT
18	23-Feb-21	BAGALKOT	220	NARENDRA- AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	0:14 (21.02.2021)			LINE OPEN:LINE FAULT
19	23-Feb-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN:LINE CLEAR AVAILED
20	23-Feb-21	BAGALKOT	220	SHARAVATHY1- SIRSI	SIRSI_220	10:34 (22.02.2021)			LOAD CURTAILMENT
21	23-Feb-21	BAGALKOT	220	SHARAVATHY2- SIRSI	SIRSI_220	10:34 (22.02.2021)			LOAD CURTAILMENT
22	23-Feb-21	BAGALKOT	110	110/11KV, HV1	RANNABELAGALI_110	0:20 (22.02.2021)			TRANSFORMER OPEN : TRANSFORMER FAULT
23	23-Feb-21	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	10:01	10:43	0:42	HAND TRIPPED
24	23-Feb-21	BAGALKOT	220	BAGEWADI-ATRIA 2	BAGEWADI_220	14:31	15:36	1:05	HAND TRIPPED
25	23-Feb-21	BAGALKOT	110	GADAG- SHIRAHATTI	SHIRAHATTI_110	10:27	18:01	7:34	LINE CLEAR AVAILED
26	23-Feb-21	BAGALKOT	110	110/11KV,HV2	GOKAK_110	11:05	20:35	9:30	TRANSFORMER FAULT
27	23-Feb-21	BAGALKOT	110	GDAG220- SHIRAHATTI	STATION NOT AFFECTED SHIRAHATTI_110	10:30	18:03	7:33	LINE CLEAR AVAILED
28	23-Feb-21	BAGALKOT	110	GMNAVAR- SALAHALLI	SALAHALLI_110	10:05	18:03	7:58	LINE CLEAR AVAILED
29	23-Feb-21	BAGALKOT	110	MKHUBLI220- KITTUR(MK HUBLI)	MK HUBLI_110, KITTUR_110	11:30	12:56	1:26	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
30	23-Feb-21	BAGALKOT	110	110/11KV, HV4	MACHE_110	14:42	15:29	0:47	LINE CLEAR AVAILED
31	23-Feb-21	BAGALKOT	110	LOKAPUR- SALAHALLI	SALAHALLI_110	10:30	16:40	6:10	LINE CLEAR AVAILED
32	23-Feb-21	BAGALKOT	110	110/11KV, HV2	KULIGERI CROSS_110	12:05	13:35	1:30	LINE CLEAR AVAILED
33	23-Feb-21	BAGALKOT	110	110/11KV, HV1	KUDAL SANAM_110	11:37	13:21	1:44	LINE CLEAR AVAILED
34	23-Feb-21	BAGALKOT	110	220/110KV, LV1	KARAWAR_220	14:17	15:15	0:58	HAND TRIPPED
35	23-Feb-21	BAGALKOT	110	110/33KV, HV2	SAVALAGI_110, HIREPADASALAGI_33, KALABILAGI_33	13:19	14:30	1:11	LINE CLEAR AVAILED
36	23-Feb-21	BAGALKOT	110	110/11KV, HV3	SAVALAGI_110	15:05	15:59	0:54	LINE CLEAR AVAILED
37	23-Feb-21	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	20:12	20:15	00:03	LOAD CHANGE OVER
38	23-Feb-21	BENGALURU	66	BIEC - DABUSPETE 220	BIEC	14:11	15:41	01:30	LINE CLEAR AVAILED
39	23-Feb-21	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	21:35	21:47	00:12	LINE CLEAR AVAILED
40	23-Feb-21	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI	23:00	23:05	00:05	LOAD CHANGE OVER
41	23-Feb-21	BENGALURU	220	KOTIPURA 220 - TUBINAKERE 220	KOTIPURA 220	09:30	09:45	00:15	LOAD CHANGE OVER
42	23-Feb-21	BENGALURU	66	KOTHIPURA 220kv - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	09:30	16:35	07:05	LINE CLEAR AVAILED
43	23-Feb-21	BENGALURU	220	KOTIPURA 220 - BIDADI 220	KOTIPURA 220	19:52	20:02	00:10	LOAD CHANGE OVER
44	23-Feb-21	BENGALURU	66	KOTHIPURA 220kv - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	19:52	20:02	00:10	LOAD CHANGE OVER
45	23-Feb-21	BENGALURU	66	HV2	REMCO	10:16	10:18	00:02	LOAD CHANGE OVER
46	23-Feb-21	BENGALURU	66	HV1	REMCO	21:37	21:39	00:02	LOAD CHANGE OVER
47	23-Feb-21	BENGALURU	66	HV1	VIJAYANAGARA	17:49	18:12	00:23	LOAD CHANGE OVER
48	23-Feb-21	BENGALURU	66	HV1	MAASTHI	10:12	10:57	00:45	TRANSFORMER FAULT
49	23-Feb-21	BENGALURU	66	HV1	MAASTHI	11:10	13:40	02:30	TRANSFORMER FAULT
50	23-Feb-21	BENGALURU	66	HV1	CHANDAPURA	12:13	12:15	00:01	LINE CLEAR AVAILED
51	23-Feb-21	BENGALURU	66	HV2	MULBAGLU	14:20	15:21	01:01	LINE CLEAR AVAILED
52	23-Feb-21	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR, NELAMANGALA 66	14:09	15:43	01:33	LINE CLEAR AVAILED
53	23-Feb-21	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU	19:37	19:58	00:21	LINE CLEAR AVAILED
54	23-Feb-21	BENGALURU	66	KGF - KYASAMBALLI	KYASAMBALLI	12:02	12:04	00:01	LINE CLEAR AVAILED
55	23-Feb-21	BENGALURU	66	KGF - MALUR 2	ANDERSONPET, KYASAMBALLI, DODDAKARI	12:00	12:05	00:05	LINE CLEAR AVAILED
56	23-Feb-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	11:26	12:16	00:50	LINE CLEAR AVAILED
57	23-Feb-21	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	14:05	16:53	02:48	LINE CLEAR AVAILED
58	23-Feb-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	11:38	12:10	00:32	LINE CLEAR AVAILED
59	23-Feb-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	10:12	10:45	00:32	LINE FAULT
60	23-Feb-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	11:10	11:29	00:19	LINE FAULT
61	23-Feb-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	11:50	12:05	00:15	LINE FAULT
62	23-Feb-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
63	23-Feb-21	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	18:20(19.2.2021)			LINE OPEN:LINE CLEAR AVAILED
64	23-Feb-21	GULBARGA	220	HV2	KUSHTAGI_220	17:10(23.02.2021)			TRANSFORMER OPEN : TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
65	23-Feb-21	GULBARGA	220	HV2	KUSHTAGI_220	06:30	07:04	00:34	TRANSFORMER FAULT
66	23-Feb-21	GULBARGA	220	HV2	KUSHTAGI_220	11:39	16:50	05:11	LINE CLEAR AVAILED
67	23-Feb-21	GULBARGA	220	HV1	KUSHTAGI_220	06:30	07:02	00:32	TRANSFORMER FAULT
68	23-Feb-21	GULBARGA	220	HV1	SINDHANOOR_220	10:05	13:50	03:45	TRANSFORMER FAULT
69	23-Feb-21	GULBARGA	220	HV1,HV2	SINDHANOOR_220	15:15	15:30	00:15	TRANSFORMER FAULT
70	23-Feb-21	GULBARGA	220	SINDHANOOR-LINGASUGUR,LINGAPUR	SINDHANOOR_220	15:15	15:25	00:10	LINE FAULT
71	23-Feb-21	GULBARGA	220	LINGASUGUR-RTPS	LINGASUGUR_220	00:28	00:36	00:08	LINE FAULT
72	23-Feb-21	GULBARGA	110	HANUMSAGAR-KUSHTAGI	HANUMSAGAR_110,HANUMANAL_110,HIREGONNAGAR_110	06:30	07:30	01:00	MAIN SUPPLY FAILURE
73	23-Feb-21	GULBARGA	110	HANUMSAGAR-KUSHTAGI	HANUMSAGAR_110,HANUMANAL_110,HIREGONNAGAR_110	10:50	11:10	00:20	MAIN SUPPLY FAILURE
74	23-Feb-21	GULBARGA	110	HANUMSAGAR-KUSHTAGI	HANUMSAGAR_110,HANUMANAL_110,HIREGONNAGAR_110	11:45	11:55	00:10	MAIN SUPPLY FAILURE
75	23-Feb-21	GULBARGA	110	KUDITINI-TORANGALU	TORANGALLU_110	11:08	14:53	03:45	LINE CLEAR AVAILED
76	23-Feb-21	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMSAGAR_110,HANUMANAL_110,HIREGONNAGAR_110	06:30	10:45	04:15	LINE FAULT
77	23-Feb-21	GULBARGA	110	HV2	MYLAR_110	09:25	09:30	00:05	TRANSFORMER FAULT
78	23-Feb-21	GULBARGA	110	RAICHUR-SHAHAPUR2	SHAHAPUR_110	12:43	12:48	00:05	LINE FAULT
79	23-Feb-21	GULBARGA	66	MAGALA-ITTAGGI	MAGALA_66	11:50	12:20	00:30	LINE CLEAR AVAILED
80	23-Feb-21	GULBARGA	66	ITTAGI-GUDEKOTE	GUDEKOTE_66	10:15	16:05	05:50	MAIN SUPPLY FAILURE
81	23-Feb-21	GULBARGA	110	RAICHUR-VALKAMDINNI	VALKAMDINNI_110	06:30	06:40	00:10	MAIN SUPPLY FAILURE
82	23-Feb-21	GULBARGA	110	RAICHUR-VALKAMDINNI	VALKAMDINNI_110	10:05	10:20	00:15	MAIN SUPPLY FAILURE
83	23-Feb-21	GULBARGA	110	HV1	VALKAMDINNI_110	13:50	14:20	00:30	LINE CLEAR AVAILED
84	23-Feb-21	GULBARGA	110	HV1	VALKAMDINNI_110	17:40	17:45	00:05	LINE CLEAR AVAILED
85	23-Feb-21	GULBARGA	110	SHAHAPUR-WARDHASOLAR_IPP	SHAHAPUR_220	18:20	20:11	01:51	LINE FAULT
86	23-Feb-21	GULBARGA	110	LV1	SHAHAPUR_220	19:48	20:11	00:23	TRANSFORMER FAULT
87	23-Feb-21	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	21:33 (22.02.2021)	17:06 (23.02.2021)	19:32 hrs	LINE CHARGED
88	23-Feb-21	HASSAN	66	HV2	UDAYAPURA_66	20:17(22.02.2021)	7:40 (23.02.2021)	11:22 hrs	TRANSFORMER CHARGED
89	23-Feb-21	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
90	23-Feb-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
91	23-Feb-21	HASSAN	110	JOG-JST1	mghejog_gen	16:05 (23.02.2021)			LINE OPEN:LINE FAULT
92	23-Feb-21	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMG_220	15:33	16:13	00:40	HAND TRIPPED
93	23-Feb-21	HASSAN	220	MRSSSHM-VARAH12	MRSMG_220	16:14	21:28	05:14	LINE FAULT
94	23-Feb-21	HASSAN	220	HV2	SHIRALKOPPA_220	11:04	16:38	05:34	LINE CLEAR AVAILED
95	23-Feb-21	HASSAN	110	LV2	SHIRALKOPPA_220	11:04	16:38	05:34	LINE CLEAR AVAILED
96	23-Feb-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	13:21	13:44	00:23	HAND TRIPPED
97	23-Feb-21	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	16:14	21:28	05:14	LINE FAULT
98	23-Feb-21	HASSAN	110	HV2	ESSUR_110	11:35	13:55	02:20	LINE CLEAR AVAILED
99	23-Feb-21	HASSAN	110	HV1	GAJNUR_110	10:00	15:38	05:38	LINE CLEAR AVAILED
100	23-Feb-21	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	10:20	14:04	03:44	LINE CLEAR AVAILED
101	23-Feb-21	HASSAN	110	JOG110-MGHE	JOG_110	15:57	16:41	00:44	LINE FAULT
102	23-Feb-21	HASSAN	110	HV2	KONAJE_110	10:22	16:53	06:31	LINE CLEAR AVAILED
103	23-Feb-21	HASSAN	110	MADHUV-HIRIYADKA	MADHUVANA_110	10:20	14:05	03:45	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
104	23-Feb-21	HASSAN	110	NAVUNDA-MADHUVANA	NAVUNDA_110	12:48	13:30	00:42	LINE CLEAR AVAILED
105	23-Feb-21	HASSAN	110	HV1	SAGARA_110	14:17	14:25	00:08	LINE CLEAR AVAILED
106	23-Feb-21	HASSAN	110	HV1	SORABA_110	16:05	16:25	00:20	LINE CLEAR AVAILED
107	23-Feb-21	HASSAN	110	HV2	SORABA_110	16:05	16:25	00:20	LINE CLEAR AVAILED
108	23-Feb-21	HASSAN	110	SORABA-SHR220	SORABA_110	16:05	16:25	00:20	LINE CLEAR AVAILED
109	23-Feb-21	HASSAN	66	HASSN22-HN PURA	HASSAN_220	09:03	11:17	02:14	LINE FAULT
110	23-Feb-21	HASSAN	66	HASSN22-UDDUR	HASSAN_220	11:17	11:37	00:20	HAND TRIPPED
111	23-Feb-21	HASSAN	66	HASSN22-MALALI	HASSAN_220	12:02	12:46	00:44	HAND TRIPPED
112	23-Feb-21	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	11:40	12:44	01:04	LINE CLEAR AVAILED
113	23-Feb-21	HASSAN	66	CRPATNA-SBELAGOLA	CRPATNA_220	15:52	18:02	02:10	LINE CLEAR AVAILED
114	23-Feb-21	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	11:22	18:02	06:40	LINE CLEAR AVAILED
115	23-Feb-21	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	11:22	19:01	07:39	LINE CLEAR AVAILED
116	23-Feb-21	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	13:12	14:04	00:52	LINE CLEAR AVAILED
117	23-Feb-21	HASSAN	66	SAKALE-HASSAN	SAKLESHPURA_66	13:13	14:06	00:53	NFBC ISSUED
118	23-Feb-21	HASSAN	66	HV1	SAKLESHPURA_66	01:21	01:33	00:12	TRANSFORMER FAULT
119	23-Feb-21	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	11:10	13:29	02:19	LINE CLEAR AVAILED
120	23-Feb-21	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:57	19:01	08:04	LINE CLEAR AVAILED
121	23-Feb-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:46	19:00	08:14	LINE CLEAR AVAILED
122	23-Feb-21	HASSAN	66	KIADB H-HASAN I\c	KIADB_66	11:50	12:49	00:59	NFBC ISSUED
123	23-Feb-21	MYSURU	66	HV1	AKKIHEBBAL_66	9:39	14:02	4:23	LINE CLEAR AVAILED
124	23-Feb-21	MYSURU	66	HV2	AKKIHEBBAL_66	10:23	16:23	5:59	LINE CLEAR AVAILED
125	23-Feb-21	MYSURU	66	AKKIHEBBAL -KAVERI HYDRO	NO STATION EFFECTED	10:52	13:45	2:52	LINE CLEAR AVAILED
126	23-Feb-21	MYSURU	66	BANNUR-MALIYURU	MALIYURU_66	10:44	17:41	6:57	NFBC ISSUED
127	23-Feb-21	MYSURU	66	HV1	BGPURA_66	11:40	12:27	0:47	LINE CLEAR AVAILED
128	23-Feb-21	MYSURU	66	HV2	BGPURA_66	12:27	12:58	0:31	LINE CLEAR AVAILED
129	23-Feb-21	MYSURU	66	BG PURA-HEBBANI	NO STATION EFFECTED	12:27	13:47	1:20	LINE CLEAR AVAILED
130	23-Feb-21	MYSURU	66	BG PURA-CHANDALLI	NO STATION EFFECTED	10:45	12:27	1:42	LINE CLEAR AVAILED
131	23-Feb-21	MYSURU	66	BG PURA-CHANDALLI	NO STATION EFFECTED	22:16(23.02.21)			LINE OPEN:LINE CLEAR AVAILED
132	23-Feb-21	MYSURU	66	HV2	BILIKERE_66	13:26	13:51	0:25	LINE CLEAR AVAILED
133	23-Feb-21	MYSURU	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	12:40	12:46	0:05	LINE FAULT
134	23-Feb-21	MYSURU	66	G UKKADA-PANDAVAPURA	NO STATION EFFECTED	10:45	14:46	4:01	NFBC ISSUED
135	23-Feb-21	MYSURU	66	KIRUGAVLU-MALIYURU	MALIYURU_66	10:31	17:49	7:17	NFBC ISSUED
136	23-Feb-21	MYSURU	66	HV1	KMDODDI_66	10:46	14:20	3:34	LINE CLEAR AVAILED
137	23-Feb-21	MYSURU	66	HV2	KMDODDI_66	14:22	16:06	1:44	LINE CLEAR AVAILED
138	23-Feb-21	MYSURU	66	KR PETE-AKKIHEBBAL 1	AKKIHEBBAL_66	10:50	13:45	2:54	HAND TRIPPED
139	23-Feb-21	MYSURU	66	KR PETE-AKKIHEBBAL 2	AKKIHEBBAL_66	10:50	13:45	2:55	HAND TRIPPED
140	23-Feb-21	MYSURU	66	KR PETE-KIKKERI	KIKKERI_66	6:21	6:27	0:05	LINE FAULT
141	23-Feb-21	MYSURU	66	HV1	KUSHALANAGARA_66	17:30	18:10	0:40	HAND TRIPPED
142	23-Feb-21	MYSURU	66	HV3	KUSHALANAGARA_66	17:28	18:06	0:38	HAND TRIPPED
143	23-Feb-21	MYSURU	66	HV4	KUSHALANAGARA_66	17:30	18:00	0:30	HAND TRIPPED
144	23-Feb-21	MYSURU	220	HV1	KUSHALNAGARA_220	15:33	18:01	2:27	LINE CLEAR AVAILED
145	23-Feb-21	MYSURU	220	HV2	KUSHALNAGARA_220	13:12	15:09	1:57	LINE CLEAR AVAILED
146	23-Feb-21	MYSURU	220	HV2	KUSHALNAGARA_220	17:13	17:55	0:42	TRANSFORMER FAULT
147	23-Feb-21	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	7:52	7:57	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
148	23-Feb-21	MYSURU	66	MADHUVANAHALLI-KOLLEGALA 1	NO STATION EFFECTED	6:31	6:37	0:06	LINE FAULT
149	23-Feb-21	MYSURU	66	HV1	NAGAMANGALA_66	14:19	14:35	0:15	HAND TRIPPED
150	23-Feb-21	MYSURU	66	HV2	NAGAMANGALA_66	14:19	14:35	0:15	HAND TRIPPED
151	23-Feb-21	MYSURU	66	HV1	NAGAMANGALA_66	14:59	15:24	0:25	HAND TRIPPED
152	23-Feb-21	MYSURU	66	HV5	SFCSHIVA_66	2:59	7:07	4:07	HAND TRIPPED
153	23-Feb-21	MYSURU	66	HV5	SFCSHIVA_66	20:37			TRANSFORMER OPEN:LINE CLEAR AVAILED
154	23-Feb-21	MYSURU	66	HV1	THANDYA_66	16:53	16:58	0:05	TRANSFORMER FAULT
155	23-Feb-21	MYSURU	66	HV1	THANDYA_66	22:53	22:57	0:03	TRANSFORMER FAULT
156	23-Feb-21	MYSURU	66	HV2	THANDYA_66	6:12 (21/02/2021)	18:36 (23/02/2021)	60:24 HRS	TRANSFORMER CHARGED
157	23-Feb-21	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
158	23-Feb-21	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	11:19:12 AM(23.02.2021)			LINE OPEN:LINE CLEAR AVAILED
159	23-Feb-21	TUMKUR	220	HONNALLI 220kV- DAVANAGERE 220kV	HONNALLI_220	11:43:11 AM(23.02.2021)			LINE OPEN:LINE CLEAR AVAILED
160	23-Feb-21	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	10:14	10:53	0:38	LINE FAULT
161	23-Feb-21	TUMKUR	220	CHITRADURGA 220kV- THALLAK 220	CHITRADURGA_220	6:18	18:01	11:43	LINE CLEAR AVAILED
162	23-Feb-21	TUMKUR	220	THALLAK 220kV-HIRIYUR	THALLAKK_220	6:16	18:13	11:56	LINE CLEAR AVAILED
163	23-Feb-21	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	14:23	16:38	2:15	TRANSFORMER FAULT
164	23-Feb-21	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	9:43	9:53	0:10	TRANSFORMER FAULT
165	23-Feb-21	TUMKUR	110	TR-2	SAMPIGE_110	8:01	8:40	0:38	LINE CLEAR AVAILED
166	23-Feb-21	TUMKUR	110	TR-1	SHETYKERE_110	2:14	2:25	0:10	TRANSFORMER FAULT
167	23-Feb-21	TUMKUR	110	TR-1	SHETYKERE_110	7:46	8:01	0:15	TRANSFORMER FAULT
168	23-Feb-21	TUMKUR	110	TR-1	TANDAGA_110	2:58	3:24	0:26	TRANSFORMER FAULT
169	23-Feb-21	TUMKUR	66	TR-2	BALENAHALLI_66	9:06	9:27	0:20	TRANSFORMER FAULT
170	23-Feb-21	TUMKUR	66	TR-2	CHANNAGIRI_66	10:38	11:43	1:05	MAIN SUPPLY FAILURE
171	23-Feb-21	TUMKUR	66	TR-1	HEGGERE_66	12:01	15:53	3:52	LINE CLEAR AVAILED
172	23-Feb-21	TUMKUR	66	TR-1	HIREHALLY_66	16:36	17:43	1:06	LINE CLEAR AVAILED
173	23-Feb-21	TUMKUR	66	TR-2	HIREHALLY_66	17:03	17:43	0:39	LINE CLEAR AVAILED
174	23-Feb-21	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	13:49	13:56	0:06	HAND TRIPPED
175	23-Feb-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:35	15:00	0:25	LINE FAULT
176	23-Feb-21	TUMKUR	66	TR-1	HOLALKERE_66	7:10	7:35	0:25	TRANSFORMER FAULT
177	23-Feb-21	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	16:48	17:26	0:38	LINE CLEAR AVAILED
178	23-Feb-21	TUMKUR	66	TR-2	MALEBENNUR_66	11:39	12:00	0:20	LINE CLEAR AVAILED
179	23-Feb-21	TUMKUR	66	UCHANGIDURGA- PALLAGATTE	O/G PULAMGHATTA ,UCCHANGIDURGA ,BILCHODU ,PALLAGHATTA, SOKKE	9:21	9:38	0:16	LINE FAULT
180	23-Feb-21	TUMKUR	66	UCHANGIDURGA- PALLAGATTE	O/G PULAMGHATTA ,UCCHANGIDURGA ,BILCHODU ,PALLAGHATTA, SOKKE	14:58	16:36	1:38	LINE CLEAR AVAILED
181	24-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
182	24-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
183	24-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
184	24-Feb-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
185	24-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
186	24-Feb-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
187	24-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
188	24-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
189	24-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
190	24-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN:LINE CLEAR AVAILED
191	24-Feb-21	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)	17:49 (24.02.2021)	572:04HRS	LINE CHARGED
192	24-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN:LINE CLEAR AVAILED
193	24-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
194	24-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
195	24-Feb-21	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	00:14 (21.02.2021)	17:50 (24.02.2021)	89:36HRS	LINE CHARGED
196	24-Feb-21	BAGALKOT	110	MAHALINGAPUR-JAMAKHANDI	JAMAKHANDI_110	22:54 (21.02.2021)	10:50(24.02.2021)	35:56HRS	LINE CHARGED
197	24-Feb-21	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	0:14 (21.02.2021)	17:49(24.02.2021)	89:35HRS	LINE CHARGED
198	24-Feb-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN:LINE CLEAR AVAILED
199	24-Feb-21	BAGALKOT	220	SHARAVATHY1- SIRSI	SIRSI_220	10:34 (22.02.2021)			LOAD CURTAILMENT
200	24-Feb-21	BAGALKOT	220	SHARAVATHY2- SIRSI	SIRSI_220	10:34 (22.02.2021)			LOAD CURTAILMENT
201	24-Feb-21	BAGALKOT	110	110/11KV, HV1	RANNABELAGALI_110	0:20 (22.02.2021)	17:03(24.02.2021)	16:43HRS	TRANSFORMER CHARGED
202	24-Feb-21	BAGALKOT	110	ATHANI220-BALIGERI(THAVASI)	BALIGERI_110	10:40	17:44	7:04	LINE CLEAR AVAILED
203	24-Feb-21	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	15:11	16:00	0:49	LINE CLEAR AVAILED
204	24-Feb-21	BAGALKOT	110	BELGAUM220-BELGAUM(NEHARU NAGAR)	NEHARUNAGAR_110	10:10	10:15	0:05	LINE FAULT
205	24-Feb-21	BAGALKOT	110	BELGAUM220-BELGAUM(NEHARU NAGAR)	NEHARUNAGAR_110	10:20	13:01	2:41	LINE CLEAR AVAILED
206	24-Feb-21	BAGALKOT	110	GADAG220-BETAGERI	STATION NOT AFFECTED GADAG_220	10:13 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
207	24-Feb-21	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	18:15 (24.02.2021)			LINE OPEN:LINE FAULT
208	24-Feb-21	BAGALKOT	220	AMBEWADI-XELDOM(PONDA 1)	AMBEWADI_220	10:48	19:22	8:34	LINE FAULT
209	24-Feb-21	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	09:22	9:59	0:37	LINE FAULT
210	24-Feb-21	BAGALKOT	220	BAGEWADI- NANDYAL1&2(BIJAPUR1&2)	BAGEWADI_220	14:23	14:51	0:28	LINE FAULT
211	24-Feb-21	BAGALKOT	220	BAGEWADI-ATRIA2	BAGEWADI_220	14:26	14:52	0:26	LINE FAULT
212	24-Feb-21	BAGALKOT	220	BAGEWADI-FORTUNE FIVE 2	BAGEWADI_220	14:26	14:36	0:10	LINE FAULT
213	24-Feb-21	BAGALKOT	220	BAGEWADI-ATRIA1	BAGEWADI_220	14:26	14:38	0:12	LINE FAULT
214	24-Feb-21	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	14:26	15:14	0:48	LINE FAULT
215	24-Feb-21	BAGALKOT	110	BAGEWADI-MAMDAPUR1	MAMADAPUR_110	14:23	14:35	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
216	24-Feb-21	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	14:23	14:35	0:12	LINE FAULT
217	24-Feb-21	BAGALKOT	110	KUSHTAGI-GAJENDRAGAD	GAJENDTAGAD_110	9:18	9:26	0:08	HAND TRIPPED
218	24-Feb-21	BAGALKOT	110	GAJENDRAGAD-RON 1&2	GAJENDTAGAD_110	9:25	16:22	6:57	HAND TRIPPED
219	24-Feb-21	BAGALKOT	110	VAJRAMATTI-JAMBAGI	JAMBAGI_110	13:38	14:43	1:05	LINE FAULT
220	24-Feb-21	BAGALKOT	110	KERUR-KONNUR	KERUR_110	17:58	18:24	0:26	HAND TRIPPED
221	24-Feb-21	BAGALKOT	110	SIRSI-KIRUVATTI	KIRUVATTI_110	9:23	10:18	0:55	LINE FAULT
222	24-Feb-21	BAGALKOT	110	KONNUR-KULAGERI CROSS	KULAGERI CROSS_110	18:01	18:18	0:17	HAND TRIPPED
223	24-Feb-21	BAGALKOT	110	KULAGERI CROSS-MRN SUGARS	KULAGERI CROSS_110	18:01	18:23	0:22	HAND TRIPPED
224	24-Feb-21	BAGALKOT	110	110/33KV,HV1&2	BELGAUM_110 &FORT,RM2,SADASHIV NAGAR,KLE 33	10:13	13:04	2:51	HAND TRIPPED
225	24-Feb-21	BAGALKOT	110	KANABARGI-BELGAUM	BELGAUM_110	10:25	13:01	2:36	HAND TRIPPED
226	24-Feb-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	MAHALINGAPUR_220	10:07:00 AM (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
227	24-Feb-21	BAGALKOT	220	MAHALINGAPUR - SOUDATTI	MAHALINGAPUR_220	13:35	13:42	0:07	LINE FAULT
228	24-Feb-21	BAGALKOT	220	NARENDRA-KANABARGI1	NARENDRA_220	10:26	19:05	8:39	LINE CLEAR AVAILED
229	24-Feb-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	13:13	13:51	0:38	LINE FAULT
230	24-Feb-21	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR2-	VAJRAMATTI_220	10:07:00 AM (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
231	24-Feb-21	BAGALKOT	220	220/110KV,HV2	VAJRAMATTI_220	11:16	17:22	6:06	LINE CLEAR AVAILED
232	24-Feb-21	BAGALKOT	220	VAJRAMATTI-BAGALKOT 1	VAJRAMATTI_220	12:27	13:50	1:23	LINE FAULT
233	24-Feb-21	BAGALKOT	220	NAGJHARI-HUBLI	HUBLI_220	15:31	17:59	2:28	LINE FAULT
234	24-Feb-21	BAGALKOT	110	110/11KV,HV1	MURDESHWAR_110	9:33	10:44	1:11	LINE CLEAR AVAILED
235	24-Feb-21	BAGALKOT	110	NAREGAL-RON	NAREGAL_110	9:41	10:22	0:41	HAND TRIPPED
236	24-Feb-21	BAGALKOT	110	SAVANUR-ASF SOLAR	SAVANUR_110	15:32	15:38	0:06	LINE FAULT
237	24-Feb-21	BAGALKOT	110	SHIGGOAN-AVANTI SOLAR	SHIGGOAN_110	12:23	12:28	0:05	HAND TRIPPED
238	24-Feb-21	BAGALKOT	110	SHIGGOAN-AVANTI SOLAR	SHIGGOAN_110	12:40	14:10	1:30	LINE CLEAR AVAILED
239	24-Feb-21	BAGALKOT	110	110/11KV,HV2	SHIROL_110	12:03	12:30	0:27	HAND TRIPPED
240	24-Feb-21	BENGALURU	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSURU RAMAPURA, NITRALLI	02:24	02:35	00:10	LINE FAULT
241	24-Feb-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	13:31	14:17	00:46	LINE CLEAR AVAILED
242	24-Feb-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	13:05	13:42	00:37	LINE CLEAR AVAILED
243	24-Feb-21	BENGALURU	66	GUDIBANDE - GOWRIBIDANUR 220	GUDIBANDE	15:32	15:48	00:16	LINE CLEAR AVAILED
244	24-Feb-21	BENGALURU	220	DABUSPET 220 - KADUR 220	DABUSPET 220	14:33	16:56	02:22	LINE FAULT
245	24-Feb-21	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	10:13	10:18	00:05	LINE CLEAR AVAILED
246	24-Feb-21	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	14:17	14:18	00:01	LINE CLEAR AVAILED
247	24-Feb-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	10:13	10:16	00:02	LOAD CHANGE OVER
248	24-Feb-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	14:16	14:21	00:05	LOAD CHANGE OVER
249	24-Feb-21	BENGALURU	66	HV2	KOLAR 220	11:54	14:34	02:39	LINE CLEAR AVAILED
250	24-Feb-21	BENGALURU	66	HV1	MAASTHI	17:35	18:56	01:21	LINE CLEAR AVAILED
251	24-Feb-21	BENGALURU	66	HV1	MITTEMARI 220	16:49	16:59	00:10	LINE CLEAR AVAILED
252	24-Feb-21	BENGALURU	66	HV1	MUDIYANUR	13:10	13:20	00:10	LINE CLEAR AVAILED
253	24-Feb-21	BENGALURU	66	HV2	MUDIYANUR	15:50	16:05	00:15	LINE CLEAR AVAILED
254	24-Feb-21	BENGALURU	66	HV2	MUDIYANUR	16:15	17:07	00:52	LINE CLEAR AVAILED
255	24-Feb-21	BENGALURU	66	HV2	RANGANDODDI	22:59	23:30	00:30	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
256	24-Feb-21	BENGALURU	66	LINE8	YELAHANKA 220	18:02	20:48	02:46	LINE FAULT
257	24-Feb-21	BENGALURU	66	HV2	KIADB DB PURA 220	13:02	13:26	00:24	LINE CLEAR AVAILED
258	24-Feb-21	BENGALURU	66	HV1	BAGHMANE WORLD TECH PARK	10:20	10:25	00:05	LINE CLEAR AVAILED
259	24-Feb-21	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	09:52	09:55	00:03	LOAD CHANGE OVER
260	24-Feb-21	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	21:18	21:26	00:08	LOAD CHANGE OVER
261	24-Feb-21	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	18:38	18:59	00:21	LINE FAULT
262	24-Feb-21	BENGALURU	66	CHANDRA LAYOUT - VRISHBHAVATHI 220	CHANDRA LAYOUT	14:47	14:51	00:04	LOAD CHANGE OVER
263	24-Feb-21	BENGALURU	66	CHANDRA LAYOUT - NRS 220	CHANDRA LAYOUT	16:21	16:24	00:03	LOAD CHANGE OVER
264	24-Feb-21	BENGALURU	66	HV1	HANUMANTHNAGARA	12:20	13:00	00:40	LINE CLEAR AVAILED
265	24-Feb-21	BENGALURU	66	HV1	KADUBISANAHALLI	08:38	10:35	01:57	TRANSFORMER FAULT
266	24-Feb-21	BENGALURU	66	HV2	NAGANATHPURA 220	10:37	10:40	00:03	LINE CLEAR AVAILED
267	24-Feb-21	BENGALURU	66	HV1	NATIONAL COLLEGE	12:40	12:43	00:03	LINE CLEAR AVAILED
268	24-Feb-21	BENGALURU	66	RAJANKUNTE - YELAHANKA 220	RAJANKUNTE	18:05	18:30	00:25	MAIN SUPPLY FAILURE
269	24-Feb-21	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	21:05	21:10	00:05	LOAD CHANGE OVER
270	24-Feb-21	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	17:20	17:25	00:05	LOAD CHANGE OVER
271	24-Feb-21	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	21:26	21:32	00:06	LOAD CHANGE OVER
272	24-Feb-21	BENGALURU	66	HV1	REMCO	17:19	17:24	00:05	LOAD CHANGE OVER
273	24-Feb-21	BENGALURU	66	HV2	REMCO	17:19	17:24	00:05	LOAD CHANGE OVER
274	24-Feb-21	BENGALURU	66	HV1	REMCO	09:46	09:48	00:02	LOAD CHANGE OVER
275	24-Feb-21	BENGALURU	66	HV2	REMCO	22:52	22:53	00:01	LOAD CHANGE OVER
276	24-Feb-21	BENGALURU	66	VRISHBHAVATHI 220 - SIR MV LAYOUT	KNGERI SATELLITE TOWN, SIR MV LAYOUT	12:59	14:10	01:11	LINE CLEAR AVAILED
277	24-Feb-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
278	24-Feb-21	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	18:20(19.2.2021)	19:55(24.02.2021)	121:35 HRS	LINE CHARGED
279	24-Feb-21	GULBARGA	220	HV2	KUSHTAGI_220	17:10(23.02.2021)	00:14(24.02.2021)	6:58 HRS	TRANSFORMER CHARGED
280	24-Feb-21	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:28	14:50	01:22	LINE FAULT
281	24-Feb-21	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	14:50	17:28	02:38	LINE CLEAR AVAILED
282	24-Feb-21	GULBARGA	220	HV2	KUSHTAGI_220	16:33	19:07	02:34	LINE CLEAR AVAILED
283	24-Feb-21	GULBARGA	110	HV1	GURUMITAKAL_110	11:30	13:40	02:10	LINE CLEAR AVAILED
284	24-Feb-21	GULBARGA	110	HV2	GURUMITAKAL_110	12:10	14:30	02:20	LINE CLEAR AVAILED
285	24-Feb-21	GULBARGA	110	GURUMITAKAL-SEDAM,GAMESH WIND IPP	GURUMITAKAL_110	12:10	13:40	01:30	LINE CLEAR AVAILED
286	24-Feb-21	GULBARGA	110	HV3	KEREHALLI_110	11:55	12:02	00:07	TRANSFORMER FAULT
287	24-Feb-21	GULBARGA	110	MUNIRABAD-KEREHALLI	KEREHALLI_110	11:30	11:35	00:05	MAIN SUPPLY FAILURE
288	24-Feb-21	GULBARGA	110	MUNIRABAD-KEREHALLI	KEREHALLI_110	11:40	11:45	00:05	MAIN SUPPLY FAILURE
289	24-Feb-21	GULBARGA	110	HV2	MYLAR	08:25	08:30	00:05	TRANSFORMER FAULT
290	24-Feb-21	GULBARGA	110	HV2	MYLAR	15:04	15:08	00:04	TRANSFORMER FAULT
291	24-Feb-21	GULBARGA	110	ALLIPUR-MUNIRBAD	TORANGALLU_110,KUDITINI_110,K URGOD_110,SHATHAVAHANA_IPP,A GRAWAL_IPP,SUZLIN _IPP,KAMALAPUR_110,MATRI_110, RBNS FACTORY	05:33	05:44	00:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
292	24-Feb-21	GULBARGA	110	KUSTIGI-HANUMASAGAR	HANUMASAGAR_110,HANUMANAL_110,HIREGONNAGAR_110	11:15	11:32	00:17	LINE FAULT
293	24-Feb-21	GULBARGA	110	KUSTIGI-HANUMASAGAR	HANUMASAGAR_110,HANUMANAL_110,HIREGONNAGAR_110	16:03	16:14	00:11	LINE FAULT
294	24-Feb-21	GULBARGA	110	SEDAM-SHAHABAD	CHITAPUR_110,KORWARTEMPLE_110,RAJESHREECEMENT_110	14:50	14:55	00:05	LINE CLEAR AVAILED
295	24-Feb-21	GULBARGA	110	KUSHTAGI-ILKAL1	ILKAL_110	19:02	19:15	00:13	LINE CLEAR AVAILED
296	24-Feb-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	01:49	01:59	00:10	LINE FAULT
297	24-Feb-21	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	04:52	05:02	00:10	LINE FAULT
298	24-Feb-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	21:26	21:48	00:22	LINE FAULT
299	24-Feb-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	21:54	22:04	00:10	LINE FAULT
300	24-Feb-21	GULBARGA	66	HV1	HAMPASAGAR_66	12:55	13:13	00:18	TRANSFORMER FAULT
301	24-Feb-21	GULBARGA	66	HV1	HAMPASAGAR_66	14:53	14:55	00:02	TRANSFORMER FAULT
302	24-Feb-21	GULBARGA	66	HV1	KOGALI_66	10:53	13:31	02:38	LINE CLEAR AVAILED
303	24-Feb-21	GULBARGA	66	HV1	HAMPASAGAR_66	17:37	17:45	00:08	TRANSFORMER FAULT
304	24-Feb-21	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
305	24-Feb-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
306	24-Feb-21	HASSAN	110	JOG-JST1	mghejog_gen	16:05 (23.02.2021)	15:44(24.02.2021)	23:39hrs	LINE CHARGED
307	24-Feb-21	HASSAN	220	KADUR-DABUSET	KADUR_220	14:33	16:55	02:22	LINE FAULT
308	24-Feb-21	HASSAN	110	HV2	BARANGI_110	18:30	18:40	00:10	LINE CLEAR AVAILED
309	24-Feb-21	HASSAN	110	HV2	BARANGI_110	17:10	17:20	00:10	TRANSFORMER FAULT
310	24-Feb-21	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	14:24	15:29	01:05	LINE CLEAR AVAILED
311	24-Feb-21	HASSAN	110	HV1	HIRENALLUR_110	12:42	13:10	00:28	LINE CLEAR AVAILED
312	24-Feb-21	HASSAN	110	HV1	HIRENALLUR_110	17:07	18:31	01:24	LINE CLEAR AVAILED
313	24-Feb-21	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	11:21	14:08	02:47	LINE CLEAR AVAILED
314	24-Feb-21	HASSAN	110	HV3	MANIPAL_110	09:47	16:41	06:54	LINE CLEAR AVAILED
315	24-Feb-21	HASSAN	110	HV4	MANIPAL_110	09:29	16:05	06:36	LINE CLEAR AVAILED
316	24-Feb-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	10:05	13:08	03:03	LINE CLEAR AVAILED
317	24-Feb-21	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLI_66	09:10	16:54	07:44	MAIN SUPPLY FAILURE
318	24-Feb-21	HASSAN	66	HV1	ATTICHOWDENAHALLI_66	09:10	16:54	07:44	MAIN SUPPLY FAILURE
319	24-Feb-21	HASSAN	66	HV1	BALEHONNUR_66	14:28	15:20	00:52	LINE CLEAR AVAILED
320	24-Feb-21	HASSAN	66	HV4	BALEHONNUR_66	15:25	17:27	02:02	LINE CLEAR AVAILED
321	24-Feb-21	HASSAN	66	CHANNARA-MALLALI	CHANNARAYAPATNA_66	09:07	16:55	07:48	LINE CLEAR AVAILED
322	24-Feb-21	HASSAN	66	HV1	CHIKABOMMENAHALLY_66	09:50	12:50	03:00	LINE CLEAR AVAILED
323	24-Feb-21	HASSAN	66	HV1	RAMPURA_66	12:34	13:31	00:57	LINE CLEAR AVAILED
324	24-Feb-21	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	09:08	16:58	07:50	NFBC ISSUED
325	24-Feb-21	MYSURU	66	HV1	AKKIHEBBAL_66	13:16	14:59	1:43	LINE CLEAR AVAILED
326	24-Feb-21	MYSURU	66	HV2	AKKIHEBBAL_66	11:33	13:19	1:46	LINE CLEAR AVAILED
327	24-Feb-21	MYSURU	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66 AJJIPURA_66	13:40	14:22	0:42	LINE CLEAR AVAILED
328	24-Feb-21	MYSURU	66	HANNUR-MADHUVANAHALLI 1	NO STATION EFFECTED	12:19	12:33	0:14	LINE CLEAR AVAILED
329	24-Feb-21	MYSURU	66	HANNUR-MADHUVANAHALLI 2	NO STATION EFFECTED	11:08	12:18	1:09	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
330	24-Feb-21	MYSURU	66	HANNUR-KOTHNURU	NO STATION EFFECTED	13:03	13:39	0:35	LINE CLEAR AVAILED
331	24-Feb-21	MYSURU	220	HOOTAGALLI-BASTHIPURA 2	NO STATION EFFECTED	11:07	11:10	0:02	HAND TRIPPED
332	24-Feb-21	MYSURU	220	HOOTAGALLI-KADAKOLA	NO STATION EFFECTED	11:14	11:16	0:02	HAND TRIPPED
333	24-Feb-21	MYSURU	220	HOOTAGALLI-VAJAMANGALA	NO STATION EFFECTED	11:11	11:13	0:01	HAND TRIPPED
334	24-Feb-21	MYSURU	66	KIADB MANDYA-TUMBEEKERE	TUMBEEKERE_66	9:26	10:39	1:12	HAND TRIPPED
335	24-Feb-21	MYSURU	66	KM DODDI-MANDYA	KOLKARANADODDI_66	9:42	14:40	4:57	HAND TRIPPED
336	24-Feb-21	MYSURU	66	HV1	KUSHALANAGARA_66	11:35	13:10	1:35	LINE CLEAR AVAILED
337	24-Feb-21	MYSURU	66	MADDUR-SOMNAHALI	NO STATION EFFECTED	14:45	14:49	0:03	HAND TRIPPED
338	24-Feb-21	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATION EFFECTED	14:38	14:43	0:05	LINE FAULT
339	24-Feb-21	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATION EFFECTED	16:14	16:21	0:06	LINE FAULT
340	24-Feb-21	MYSURU	66	HV1	MANDGERE_66	9:56	17:08	7:12	LINE CLEAR AVAILED
341	24-Feb-21	MYSURU	66	HV1	NAGAMANGALA_66	16:28	16:53	0:24	HAND TRIPPED
342	24-Feb-21	MYSURU	66	HV2	NAGAMANGALA_66	15:52	16:24	0:31	HAND TRIPPED
343	24-Feb-21	MYSURU	66	SATHEGALA-BPCL	NO STATION EFFECTED	10:27	13:10	2:42	NFBC ISSUED
344	24-Feb-21	MYSURU	66	SATHEGALA-HEBBANI	NO STATION EFFECTED	12:16	14:31	2:14	NFBC ISSUED
345	24-Feb-21	MYSURU	66	HV5	SFCSHIVA_66	13:52	16:12	2:20	HAND TRIPPED
346	24-Feb-21	MYSURU	66	HV1	TERAKANAMBE_66	11:05	12:05	1:00	LINE CLEAR AVAILED
347	24-Feb-21	MYSURU	66	HV2	THANDYA_66	10:20	12:06	1:45	LINE CLEAR AVAILED
348	24-Feb-21	MYSURU	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	10:22	16:14	5:52	NFBC ISSUED
349	24-Feb-21	MYSURU	66	BG PURA-CHANDALLI	NO STATION EFFECTED	22:16 (23/02/2021)	8:20 (24/02/2021)	10:03 HRS	LINE CHARGED
350	24-Feb-21	MYSURU	66	HV5	SFCSHIVA_66	20:37 (23/02/2021)	0:53 (24/02/2021)	4:15 HRS	TRANSFORMER CHARGED
351	24-Feb-21	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
352	24-Feb-21	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	11:19:12 AM(23.02.2021)			LINE OPEN:LINE CLEAR AVAILED
353	24-Feb-21	TUMKUR	220	HONNALLI 220kV- DAVANAGERE 220kV	HONNALLI_220	11:43:11 AM(23.02.2021)			LINE OPEN:LINE CLEAR AVAILED
354	24-Feb-21	TUMKUR	220	CHITRADURGA 220kV- THALLAK 220	CHITRADURGA_220	6:12	18:55	12:43	LINE CLEAR AVAILED
355	24-Feb-21	TUMKUR	220	THALLAK 220kV-HIRIYUR	THALLAKK_220	6:22	18:52	12:29	LINE CLEAR AVAILED
356	24-Feb-21	TUMKUR	110	TR-2	NITTUR_220	2:48	8:56	6:08	TRANSFORMER FAULT
357	24-Feb-21	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	8:40	8:55	0:15	LINE FAULT
358	24-Feb-21	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	17:28	17:39	0:10	LINE FAULT
359	24-Feb-21	TUMKUR	66	TR-2	HONNUDIKE_66	10:15	10:23	0:07	TRANSFORMER FAULT
360	24-Feb-21	TUMKUR	66	TR-1	CHIKKATOTLUKERE_66	0:04	0:16	0:11	TRANSFORMER FAULT
361	24-Feb-21	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:09	16:53	6:43	LINE CLEAR AVAILED
362	24-Feb-21	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	8:32	8:47	0:14	LINE FAULT
363	24-Feb-21	TUMKUR	66	TR-1	HOLALKERE_66	12:15	13:09	0:54	LINE CLEAR AVAILED
364	24-Feb-21	TUMKUR	66	TR-1	HOLALKERE_66	16:52	17:01	0:09	TRANSFORMER FAULT
365	24-Feb-21	TUMKUR	66	TR-1	HOLALKERE_66	18:22	18:26	0:04	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
366	24-Feb-21	TUMKUR	66	JAVAGONDAHALLI- INFOSYS-1	INFOSYS-1	15:16	15:35	0:18	LINE FAULT
367	24-Feb-21	TUMKUR	66	TR-1	KALAMARANAHALLI_66	12:17	12:21	0:04	HAND TRIPPED
368	24-Feb-21	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	PULAMG_66	18:50	19:07	0:17	LINE FAULT
369	24-Feb-21	TUMKUR	66	TR-2	MADANAYAKANAHALLI_66	7:44	8:51	1:07	LINE CLEAR AVAILED
370	24-Feb-21	TUMKUR	66	TR-1	NYAMATHI_66	17:51	17:57	0:06	LINE CLEAR AVAILED
371	24-Feb-21	TUMKUR	66	TR-1	PAVAGADA_66	7:51	8:18	0:27	HAND TRIPPED
372	24-Feb-21	TUMKUR	66	PAVAGADA66-MADHUGIRI	PAVAGADA_66	7:35	7:49	0:13	HAND TRIPPED
373	24-Feb-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN SOLAR 1_IPP_66	8:56	9:24	0:27	HAND TRIPPED
374	24-Feb-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN SOLAR2_IPP_66	8:56	9:24	0:27	HAND TRIPPED
375	24-Feb-21	TUMKUR	66	THALLAK 220kv- NAYAKANHATTI	NAYAKANAHATTI_66	9:17	16:17	7:00	LINE CLEAR AVAILED
376	25-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
377	25-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
378	25-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
379	25-Feb-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
380	25-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
381	25-Feb-21	BAGALKOT	110	KANABARGI LAYOUT-NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
382	25-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
383	25-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
384	25-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
385	25-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN:LINE CLEAR AVAILED
386	25-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN:LINE CLEAR AVAILED
387	25-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
388	25-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
389	25-Feb-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN:LINE CLEAR AVAILED
390	25-Feb-21	BAGALKOT	220	SHARAVATHY1- SIRSI	SIRSI_220	10:34 (22.02.2021)			LOAD CURTAILMENT
391	25-Feb-21	BAGALKOT	220	SHARAVATHY2- SIRSI	SIRSI_220	10:34 (22.02.2021)			LOAD CURTAILMENT
392	25-Feb-21	BAGALKOT	110	GADAG220-BETAGERI	STATION NOT AFFECTED GADAG_220	10:13 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
393	25-Feb-21	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	18:15 (24.02.2021)	18:19(25.02.2021)	24:04HRS	LINE CHARGED
394	25-Feb-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	MAHALINGAPUR_220	10:07:00 AM (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
395	25-Feb-21	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR2-	VAJRAMATTI_220	10:07:00 AM (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
396	25-Feb-21	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR1	VAJRAMATTI_220	16:17:00 AM (23.02.2021)			LINE OPEN:LINE FAULT
397	25-Feb-21	BAGALKOT	220	AMBEWADI-XELDOM(PONDA1)	AMBEWADI_220	11:28	19:15	7:47	LINE FAULT
398	25-Feb-21	BAGALKOT	220	AMBEWADI-XELDOM(PONDA1)	AMBEWADI_220	22:49 (25.02.2021)			LINE OPEN:LINE FAULT
399	25-Feb-21	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	13:17	13:38	0:21	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
400	25-Feb-21	BAGALKOT	110	AMBEWADI-NK2	KAVALWAD_110	13:18	13:39	0:21	LINE FAULT
401	25-Feb-21	BAGALKOT	110	SUPA1&2-AMBEWADI	AMBEWADI_220	13:25	13:40	0:15	HAND TRIPPED
402	25-Feb-21	BAGALKOT	110	110/11KV,HV2	AEMALLAPUR_110	10:56	16:11	5:15	LINE CLEAR AVAILED
403	25-Feb-21	BAGALKOT	110	110/11KV,HV1	AEMALLAPUR_110	16:13	19:17	3:04	LINE CLEAR AVAILED
404	25-Feb-21	BAGALKOT	110	110/11KV,HV1	ARGA_110	10:05	11:01	0:56	HAND TRIPPED
405	25-Feb-21	BAGALKOT	110	BABALESHWAR-VSE SOLAR(MAMADAPUR)	BABALESHWAR_110	2:08 (25.02.2021)			LINE OPEN:LINE FAULT
406	25-Feb-21	BAGALKOT	110	110/11KV,HV1	BASAVANKATTE_110	11:07	11:47	0:40	HAND TRIPPED
407	25-Feb-21	BAGALKOT	110	110/11KV,HV2	GOKAK_110	8:51	10:12	1:21	LINE CLEAR AVAILED
408	25-Feb-21	BAGALKOT	110	110/11KV HV1	GULEDGUDD_110	22:28	22:35	0:07	TRANSFORMER FAULT
409	25-Feb-21	BAGALKOT	110	110/11KV HV4	HUKKERI_110	15:47	15:54	0:07	HAND TRIPPED
410	25-Feb-21	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	12:01	16:50	4:49	LINE CLEAR AVAILED
411	25-Feb-21	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	16:52 (25.02.2021)			LINE OPEN:LINE CLEAR AVAILED
412	25-Feb-21	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	13:16 (25.02.2021)			LINE OPEN:LINE CLEAR AVAILED
413	25-Feb-21	BAGALKOT	110	TADASINKOPPA- TARIHAL	TARIHAL_110	10:30	10:56	0:26	LINE FAULT
414	25-Feb-21	BAGALKOT	110	110/11KV, HV2	TARIHAL_110	09:21	14:07	4:46	LINE CLEAR AVAILED
415	25-Feb-21	BAGALKOT	110	110/11KV, HV2	TARIHAL_110	14:56	15:15	0:19	LINE CLEAR AVAILED
416	25-Feb-21	BAGALKOT	110	SUARNASOUDA- MACHE	MACHE_110	11:54	12:05	0:11	HAND TRIPPED
417	25-Feb-21	BAGALKOT	110	SUARNASOUDA- MACHE	MACHE_110	12:09	12:18	0:09	HAND TRIPPED
418	25-Feb-21	BAGALKOT	110	110/11KV,HV1	SIRSI_110	04:55	09:16	4:21	TRANSFORMER FAULT
419	25-Feb-21	BAGALKOT	110	SIRSI- JOG1(SIDDAPUR)	STATION NOT AFFECTED SIDDAPUR_110	14:03	14:50	0:47	LINE CLEAR AVAILED
420	25-Feb-21	BAGALKOT	110	SIRSI- JOG1(SIDDAPUR)	STATION NOT AFFECTED SIDDAPUR_110	17:38	18:19	0:41	LINE CLEAR AVAILED
421	25-Feb-21	BAGALKOT	110	110/33KV, HV2	RATTIHALLI_110, MASUR_33, HALLUR_33	13:48	14:03	0:15	LINE CLEAR AVAILED
422	25-Feb-21	BAGALKOT	110	110/11KV, HV1	PHCOMPOUND_110	11:32	13:53	2:21	LINE CLEAR AVAILED
423	25-Feb-21	BAGALKOT	220	HUBLI- NAGJHARI3	HUBLI_220	11:33	13:36	2:03	LINE FAULT
424	25-Feb-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	13:21 (25.02.2021)			LINE OPEN:LINE FAULT
425	25-Feb-21	BAGALKOT	110	MKHUBLI220- HIREBAGEWADI	HIREBAGEWADI_110	11:34	11:51	0:17	LINE FAULT
426	25-Feb-21	BAGALKOT	110	MKHUBLI220- HIREBAGEWADI	HIREBAGEWADI_110	12:07	17:03	4:56	LINE FAULT
427	25-Feb-21	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	8:04	18:19	10:15	LINE CLEAR AVAILED
428	25-Feb-21	BAGALKOT	220	NARENDRA- BELGAUM1	NARENDRA_220	14:52	18:28	3:36	LINE FAULT
429	25-Feb-21	BAGALKOT	220	MAHALINGAPUR- SOUDATTI	MAHALINGAPUR_220	13:19 (25.02.2021)			LINE OPEN:LINE FAULT
430	25-Feb-21	BAGALKOT	220	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	13:46	19:52	6:06	LINE FAULT
431	25-Feb-21	BAGALKOT	220	GADAG- HARTI1	GADAG_220	11:42	17:15	5:33	HAND TRIPPED
432	25-Feb-21	BAGALKOT	220	GADAG- HARTI2	GADAG_220	17:16 (25.02.2021)			LINE OPEN:LINE CLEAR AVAILED
433	25-Feb-21	BAGALKOT	220	BELGAUM- NARENDRA1	BELGAUM_220	14:52	18:11	3:19	LINE FAULT
434	25-Feb-21	BAGALKOT	220	BIJAPUR- INDI2	BIJAPUR_220	22:02 (25.02.2021)			LINE OPEN:LINE FAULT
435	25-Feb-21	BAGALKOT	220	BIJAPUR- VAISHALI2	BIJAPUR_220	22:02 (25.02.2021)			LINE OPEN:LINE FAULT
436	25-Feb-21	BAGALKOT	220	BIJAPUR- BAGEWADI2(GMR)	BIJAPUR_220	22:02 (25.02.2021)			LINE OPEN:LINE FAULT
437	25-Feb-21	BENGALURU	66	HV1	BAGHMANE WORLD TECH PARK	10:20	10:25	00:04	LINE CLEAR AVAILED
438	25-Feb-21	BENGALURU	66	HV1	DODDABELAVANGALA	07:05	07:12	00:07	TRANSFORMER FAULT
439	25-Feb-21	BENGALURU	66	HV2	M GOLLAHALLI	13:01	14:26	01:24	LINE CLEAR AVAILED
440	25-Feb-21	BENGALURU	220	HV1	MITTEMARI 220	15:35	16:07	00:32	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
441	25-Feb-21	BENGALURU	220	HV2	MITTEMARI 220	15:35	17:14	01:39	MAIN SUPPLY FAILURE
442	25-Feb-21	BENGALURU	66	HV1	RANGANDODDI	12:12	15:12	03:00	LINE CLEAR AVAILED
443	25-Feb-21	BENGALURU	66	HV2	RANGANDODDI	07:40	08:15	00:35	LINE CLEAR AVAILED
444	25-Feb-21	BENGALURU	220	HV2	SARJAPURA 220	11:28	12:20	00:52	MAIN SUPPLY FAILURE
445	25-Feb-21	BENGALURU	66	HV2	SARJAPURA 220	11:28	12:20	00:52	MAIN SUPPLY FAILURE
446	25-Feb-21	BENGALURU	66	HV1	SARJAPURA 220	11:28	12:20	00:52	MAIN SUPPLY FAILURE
447	25-Feb-21	BENGALURU	66	HV2	SM MANGALA	11:26	12:07	00:40	LINE CLEAR AVAILED
448	25-Feb-21	BENGALURU	66	HV1	MITTEMARI 220	15:35	16:10	00:35	MAIN SUPPLY FAILURE
449	25-Feb-21	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	17:29	17:54	00:25	LINE FAULT
450	25-Feb-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	11:31	11:36	00:05	LINE FAULT
451	25-Feb-21	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	MITTEMARI 220	15:38	20:03	04:25	LINE FAULT
452	25-Feb-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	14:42	14:58	00:16	LINE FAULT
453	25-Feb-21	BENGALURU	66	KODIHALLI - HUNSENAHALLI	HUNSENAHALLI, BIJJAHALLI	05:53	06:10	00:17	LINE FAULT
454	25-Feb-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	06:58	07:55	00:57	LOAD CURTAILMENT
455	25-Feb-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	09:10	09:30	00:19	LINE FAULT
456	25-Feb-21	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	11:29	12:15	00:45	LINE FAULT
457	25-Feb-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	15:35	16:12	00:37	MAIN SUPPLY FAILURE
458	25-Feb-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	15:35	16:11	00:36	MAIN SUPPLY FAILURE
459	25-Feb-21	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	15:35	16:25	00:50	MAIN SUPPLY FAILURE
460	25-Feb-21	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	18:01	18:06	00:05	LOAD CHANGE OVER
461	25-Feb-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	15:35	16:12	00:37	MAIN SUPPLY FAILURE
462	25-Feb-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	15:35	16:25	00:50	MAIN SUPPLY FAILURE
463	25-Feb-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	18:01	18:06	00:05	LOAD CHANGE OVER
464	25-Feb-21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	15:35	16:25	00:50	MAIN SUPPLY FAILURE
465	25-Feb-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	11:28	12:21	00:52	MAIN SUPPLY FAILURE
466	25-Feb-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:28	12:21	00:53	MAIN SUPPLY FAILURE
467	25-Feb-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:28	12:23	00:54	MAIN SUPPLY FAILURE
468	25-Feb-21	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	11:28	12:19	00:51	LINE FAULT
469	25-Feb-21	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI	15:36	16:35	00:58	MAIN SUPPLY FAILURE
470	25-Feb-21	BENGALURU	66	SOMENAHALLI - PATHPALYA	SOMENAHALLI	20:05	20:10	00:05	LOAD CHANGE OVER
471	25-Feb-21	BENGALURU	66	HV1	IRGAMPALLI	16:23	16:28	00:05	LINE CLEAR AVAILED
472	25-Feb-21	BENGALURU	66	HV2	IRGAMPALLI	14:02	16:16	02:13	LINE CLEAR AVAILED
473	25-Feb-21	BENGALURU	66	HV1	MAASTHI	09:50	10:58	01:08	LINE CLEAR AVAILED
474	25-Feb-21	BENGALURU	66	HV2	MAASTHI	14:20	15:55	01:34	LINE CLEAR AVAILED
475	25-Feb-21	BENGALURU	66	HV1	MAASTHI	16:30	16:50	00:20	LINE CLEAR AVAILED
476	25-Feb-21	BENGALURU	66	SADLI - MITTEMARI 220	SADLI, DIBBURAHALLI	20:57	21:08	0:10	LINE CLEAR AVAILED
477	25-Feb-21	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	14:15	14:35	00:20	MAIN SUPPLY FAILURE
478	25-Feb-21	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	15:28	15:32	00:04	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
479	25-Feb-21	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	14:40	15:02	00:22	LINE CLEAR AVAILED
480	25-Feb-21	BENGALURU	66	HANUMANTHNAGAR - SOMANAHALLI 220	HANUMANTHNAGAR	10:25	10:30	00:05	LOAD CHANGE OVER
481	25-Feb-21	BENGALURU	220	HOODY 400 - HSR LAYOUT 220	HSR LAYOUT 220	15:22	17:22	02:00	LINE FAULT
482	25-Feb-21	BENGALURU	220	HSR LAYOUT - HOODY 220	HSR LAYOUT 220	15:22	17:22	02:00	LINE FAULT
483	25-Feb-21	BENGALURU	220	HV1	HSR LAYOUT 220	15:22	17:22	02:00	LINE CLEAR AVAILED
484	25-Feb-21	BENGALURU	220	HSR LAYOUT - SOMANAHALLI 220	HSR LAYOUT 220	15:45	16:08	00:23	MAIN SUPPLY FAILURE
485	25-Feb-21	BENGALURU	220	HV2	HSR LAYOUT 220	15:45	16:08	00:23	LINE CLEAR AVAILED
486	25-Feb-21	BENGALURU	220	HV3	HSR LAYOUT 220	15:45	16:08	00:23	LINE CLEAR AVAILED
487	25-Feb-21	BENGALURU	220	HSR LAYOUT - NIMHANS 220	KORAMANGALA 220, NIMHANS 220	15:22	17:35	02:13	LINE CLEAR AVAILED
488	25-Feb-21	BENGALURU	66	HV1	HSR LAYOUT 220	15:45	16:10	00:25	LINE CLEAR AVAILED
489	25-Feb-21	BENGALURU	66	HV2	HSR LAYOUT 220	15:45	17:10	01:25	LINE CLEAR AVAILED
490	25-Feb-21	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	15:45	16:10	00:25	LINE CLEAR AVAILED
491	25-Feb-21	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	15:45	16:10	00:25	LINE CLEAR AVAILED
492	25-Feb-21	BENGALURU	66	HSR LAYOUT 220 - DEVARABISANAHALLI	DEVARABISANAHALLI	15:45	16:10	00:25	LINE CLEAR AVAILED
493	25-Feb-21	BENGALURU	66	HSR LAYOUT 220 - JAKKASANDRA	JAKKASANDRA	15:22	16:14	00:52	LINE CLEAR AVAILED
494	25-Feb-21	BENGALURU	66	HV1	ISRO LAYOUT	10:15	10:20	00:05	LINE CLEAR AVAILED
495	25-Feb-21	BENGALURU	66	HV2	ISRO LAYOUT	10:15	10:20	00:05	LINE CLEAR AVAILED
496	25-Feb-21	BENGALURU	66	HV1	ISRO LAYOUT	14:55	15:00	00:05	LINE CLEAR AVAILED
497	25-Feb-21	BENGALURU	66	HV2	ISRO LAYOUT	14:55	15:00	00:05	LINE CLEAR AVAILED
498	25-Feb-21	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	15:22	17:10	01:48	MAIN SUPPLY FAILURE
499	25-Feb-21	BENGALURU	220	KORAMANGALA 220 - HSR LAYOUT 220	KORAMANGALA 220	15:22	17:35	02:13	MAIN SUPPLY FAILURE
500	25-Feb-21	BENGALURU	66	KORAMANGALA 220 - GOLF LINK HAL 2	K & C VALLEY	15:22	17:35	02:13	LINE CLEAR AVAILED
501	25-Feb-21	BENGALURU	66	KORAMANGALA 220 - KORAMANGALA 66	KORAMANGALA 66	15:22	17:35	02:13	LINE CLEAR AVAILED
502	25-Feb-21	BENGALURU	66	NIMHANS 220 - ADUGODI	ADUGODI, BOSCH(EHT)	15:22	17:40	02:18	LINE CLEAR AVAILED
503	25-Feb-21	BENGALURU	220	HV1	NIMHANS 220	15:22	17:35	02:13	LINE CLEAR AVAILED
504	25-Feb-21	BENGALURU	220	HV2	NIMHANS 220	15:22	17:35	02:13	LINE CLEAR AVAILED
505	25-Feb-21	BENGALURU	66	NATIONAL COLLEGE - JAYANAGARA	NATIONAL COLLEGE	15:22	15:32	00:10	LINE CLEAR AVAILED
506	25-Feb-21	BENGALURU	66	JAYANAGARA - NIMHANS 220	JAYANAGARA	15:22	16:42	01:20	LINE CLEAR AVAILED
507	25-Feb-21	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	15:21	15:35	00:14	LINE CLEAR AVAILED
508	25-Feb-21	BENGALURU	220	SOMANAHALLI 220 - HSR LAYOUT 220	HSR LAYOUT 220	15:45	16:05	00:20	LINE FAULT
509	25-Feb-21	BENGALURU	66	T K HALLI 220 - SIMSHA 1	T K HALLI 220	13:28	13:41	00:13	LINE CLEAR AVAILED
510	25-Feb-21	BENGALURU	66	HV1	VIJAYANAGARA	06:24	06:41	00:17	LOAD CHANGE OVER
511	25-Feb-21	BENGALURU	66	HV1	VIJAYANAGARA	14:15	15:10	00:55	MAIN SUPPLY FAILURE
512	25-Feb-21	BENGALURU	220	VRISHABHAVATHI 220 - TATAGUNI 220 (EHT)	VRISHABHAVATHI 220	14:14	14:58	00:44	MAIN SUPPLY FAILURE
513	25-Feb-21	BENGALURU	66	VRISHABHAVATHI 220 - CHANDRA LAYOUT	CHANDRALAYOUT	14:14	15:02	00:48	LINE CLEAR AVAILED
514	25-Feb-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	REMCO	14:14	15:09	00:55	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
515	25-Feb-21	BENGALURU	66	VRISHABHAVATHI 220 - SIR MV LAYOUT	KENERI SATELLITE TOWN, SIR MV LAYOUT	14:14	15:06	00:52	LINE CLEAR AVAILED
516	25-Feb-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
517	25-Feb-21	GULBARGA	220	HV2	SINDHANOOOR_220	14:05	15:35	01:30	LINE CLEAR AVAILED
518	25-Feb-21	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	12:46	13:20	00:34	NFBC ISSUED
519	25-Feb-21	GULBARGA	110	KUSTIGI-HANUMASAGAR	HANUMASAGAR_110,HANUMANAL_110,HIREGONNAGAR_110	03:50	04:05	00:15	LINE FAULT
520	25-Feb-21	GULBARGA	110	KUSTIGI-KANAKAGIRI	KANAKAGIRI_110,GANADAL_110	07:25	07:55	00:30	LINE CLEAR AVAILED
521	25-Feb-21	GULBARGA	110	KUDITINI-BELLARY,TORANGALU	KUDITINI_110,TORANGALLU_110	05:29	05:37	00:08	LINE FAULT
522	25-Feb-21	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALKAMDINNI_110	10:21	10:31	00:10	LINE FAULT
523	25-Feb-21	GULBARGA	66	HV1	HAMPASAGAR_66	08:24	08:31	00:07	TRANSFORMER FAULT
524	25-Feb-21	GULBARGA	66	HV1	HAMPASAGAR_66	11:01	11:37	00:36	TRANSFORMER FAULT
525	25-Feb-21	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
526	25-Feb-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
527	25-Feb-21	HASSAN	110	HV2	ESSUR_110	12:45 (25.02.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
528	25-Feb-21	HASSAN	110	HV2	KARAYA_110	19:35 (25.02.2021)			TRANSFORMER OPEN : TRANSFORMER FAULT
529	25-Feb-21	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	23:59(25.02.2021)			LINE OPEN:LINE CLEAR AVAILED
530	25-Feb-21	HASSAN	66	HV1	SALAGAME_66	23:54(25.02.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
531	25-Feb-21	HASSAN	66	HV2	SALAGAME_66	23:54(25.02.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
532	25-Feb-21	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	23:54(25.02.2021)			LINE OPEN:LINE CLEAR AVAILED
533	25-Feb-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	14:05	16:38	02:33	LINE CLEAR AVAILED
534	25-Feb-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	14:05	16:38	02:33	NFBC ISSUED
535	25-Feb-21	HASSAN	110	HV2	PUTTUR_110	09:29	13:20	03:51	LINE CLEAR AVAILED
536	25-Feb-21	HASSAN	110	HV2	AJJAMPURA_110	16:23	17:28	01:05	LINE CLEAR AVAILED
537	25-Feb-21	HASSAN	110	HV2	ANANDAPURA_110	12:04	12:30	00:26	TRANSFORMER FAULT
538	25-Feb-21	HASSAN	110	HV2	BARANGI_110	12:36	13:17	00:41	LINE CLEAR AVAILED
539	25-Feb-21	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:10	11:47	01:37	LINE CLEAR AVAILED
540	25-Feb-21	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	10:11	18:20	08:09	LINE CLEAR AVAILED
541	25-Feb-21	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:11	18:20	08:09	LINE CLEAR AVAILED
542	25-Feb-21	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	02:14	02:20	00:06	LINE FAULT
543	25-Feb-21	HASSAN	66	HV1	HNPURA_66	02:14	02:23	00:09	TRANSFORMER FAULT
544	25-Feb-21	HASSAN	66	HV2	HNPURA_66	02:14	02:23	00:09	TRANSFORMER FAULT
545	25-Feb-21	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	02:14	02:25	00:11	LINE FAULT
546	25-Feb-21	HASSAN	66	HV1	RAMPURA_66	12:05	12:32	00:27	LINE CLEAR AVAILED
547	25-Feb-21	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:03	18:16	08:13	LINE CLEAR AVAILED
548	25-Feb-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	11:04	18:14	07:10	LINE CLEAR AVAILED
549	25-Feb-21	HASSAN	66	HV1	BASAVAGHATTA_66	12:20	12:34	00:14	LINE CLEAR AVAILED
550	25-Feb-21	HASSAN	66	HV2	BASAVAGHATTA_66	12:45	13:04	00:19	TRANSFORMER FAULT
551	25-Feb-21	MYSURU	66	HV1	AKKIHEBBAL_66	10:34	10:37	0:03	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
552	25-Feb-21	MYSURU	66	HV1	AKKIHEBBAL_66	11:08	11:21	0:12	LINE CLEAR AVAILED
553	25-Feb-21	MYSURU	66	HV1	AKKIHEBBAL_66	13:13	13:36	0:22	LINE CLEAR AVAILED
554	25-Feb-21	MYSURU	66	HV2	AKKIHEBBAL_66	10:18	17:10	6:51	LINE CLEAR AVAILED
555	25-Feb-21	MYSURU	66	BG PURA-CHANDALLI	CHANDALLI_66	13:16	15:38	2:22	NFBC ISSUED
556	25-Feb-21	MYSURU	66	HV1	GAMANAHALLY_66	12:21	14:51	2:30	LINE CLEAR AVAILED
557	25-Feb-21	MYSURU	66	HARADANAHALLI(JAK)-LAXJEET	NO STATION EFFECTED	17:36	18:36	0:59	LINE CLEAR AVAILED
558	25-Feb-21	MYSURU	66	HV1	HOSURGATE_66	11:31	12:06	0:35	LINE CLEAR AVAILED
559	25-Feb-21	MYSURU	66	KADAKOLA-NANJANAGUDU 2	NO STATION EFFECTED	10:29	11:49	1:20	HAND TRIPPED
560	25-Feb-21	MYSURU	66	HV1	K_HONNALGERE_66	11:17	12:02	0:45	HAND TRIPPED
561	25-Feb-21	MYSURU	66	HV2	K_HONNALGERE_66	12:03	12:30	0:26	HAND TRIPPED
562	25-Feb-21	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:01	13:30	0:28	HAND TRIPPED
563	25-Feb-21	MYSURU	66	HV1	KRPET_220	13:38	14:57	1:18	LINE CLEAR AVAILED
564	25-Feb-21	MYSURU	66	HV2	KRPET_220	12:29	14:20	1:51	LINE CLEAR AVAILED
565	25-Feb-21	MYSURU	220	HV2	KUSHALNAGARA_220	15:06	17:13	2:07	LINE CLEAR AVAILED
566	25-Feb-21	MYSURU	66	SATHEGALA-BPCL	NO STATION EFFECTED	10:19	12:19	1:59	HAND TRIPPED
567	25-Feb-21	MYSURU	66	SATHEGALA-HEBBANI	NO STATION EFFECTED	11:20	12:18	0:58	HAND TRIPPED
568	25-Feb-21	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
569	25-Feb-21	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	11:19:12 AM(23.02.2021)			LINE OPEN:LINE CLEAR AVAILED
570	25-Feb-21	TUMKUR	220	HONNALLI 220kV- DAVANAGERE 220kV	HONNALLI_220	11:43:11 AM(23.02.2021)			LINE OPEN:LINE CLEAR AVAILED
571	25-Feb-21	TUMKUR	220	CHITRADURGA 220kV- THALLAK 220	CHITRADURGA_220	4:38	19:41	15:02	LINE CLEAR AVAILED
572	25-Feb-21	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	12:05	14:44	2:38	LINE FAULT
573	25-Feb-21	TUMKUR	220	MADHUGIRI 220kV- GOWRIBIDANUR220	MADHUGIRI 220kV	15:39	16:44	1:05	LINE FAULT
574	25-Feb-21	TUMKUR	220	THALLAK 220kV-HIRIYUR	THALLAKK_220	7:35	19:59	12:23	LINE CLEAR AVAILED
575	25-Feb-21	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	6:59	8:13	1:14	LOAD CURTAILMENT
576	25-Feb-21	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	8:08	8:16	0:07	LOAD CURTAILMENT
577	25-Feb-21	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	6:59	8:10	1:10	LOAD CURTAILMENT
578	25-Feb-21	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	11:41	11:51	0:10	LINE FAULT
579	25-Feb-21	TUMKUR	66	TR-1	BELLAVI_66	13:16	14:02	0:46	LINE CLEAR AVAILED
580	25-Feb-21	TUMKUR	66	TR-1	CHANNAGIRI_66	22:33	22:40	0:07	TRANSFORMER FAULT
581	25-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:09	15:16	0:07	LINE FAULT
582	25-Feb-21	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	18:03	18:09	0:06	LINE CLEAR AVAILED
583	25-Feb-21	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	18:52	19:03	0:11	LINE CLEAR AVAILED
584	25-Feb-21	TUMKUR	66	TR-1	HIREGUNTANUR_66	12:47	13:20	0:32	HAND TRIPPED
585	25-Feb-21	TUMKUR	66	TR-2	LINGDHALLI_66	9:10	9:25	0:15	LINE CLEAR AVAILED
586	25-Feb-21	TUMKUR	66	TR-1	MYLANAHALLI_66	8:11	8:22	0:10	TRANSFORMER FAULT
587	25-Feb-21	TUMKUR	66	TR-2	SIRA_66	14:24	15:28	1:04	LINE CLEAR AVAILED
588	26-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
589	26-Feb-21	BAGALKOT	110	110/11KV,HV1	GULEDAGUDDA_110	17:28	17:48	0:20	HAND TRIPPED
590	26-Feb-21	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	12:02	12:35	0:33	TRANSFORMER FAULT
591	26-Feb-21	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	11:39	11:49	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
592	26-Feb-21	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,MASTIKATTA_33,SEAB IRD_33	10:01	16:25	6:24	LINE CLEAR AVAILED
593	26-Feb-21	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110,BELAGAUM W/S 1_33,BELAGAUM W/S 2&3_33,RUSTUMPUR LIS_33	18:41	19:05	0:24	TRANSFORMER FAULT
594	26-Feb-21	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	13:30	13:41	0:11	LINE FAULT
595	26-Feb-21	BAGALKOT	110	BABALESHWAR-VSE SOLAR(MAMADAPUR)	BABALESHWAR_110	2:08(25.02.2021)			LINE OPEN:LINE FAULT
596	26-Feb-21	BAGALKOT	110	BAGALKOT 220-BAGALKOT 1	STATION NOT AFFECTED BAGALKOT_110	4:32 (26.02.2021)			LINE OPEN:LINE CLEAR AVAILED
597	26-Feb-21	BAGALKOT	110	BAGALKOT220-BAGALKOT 2	BAGALKOT_110	00:15	00:22	0:07	LINE FAULT
598	26-Feb-21	BAGALKOT	110	BAGALKOT220-BAGALKOT 2	BAGALKOT_110	00:23	01:00	0:37	HAND TRIPPED
599	26-Feb-21	BAGALKOT	110	BAGALKOT220-BAGALKOT 2	BAGALKOT_110	03:22	03:26	0:04	HAND TRIPPED
600	26-Feb-21	BAGALKOT	110	BAGALKOT220-RAMDURGA	STATION NOT AFFECTED RAMDURGA_110	06:43	06:45	0:02	HAND TRIPPED
601	26-Feb-21	BAGALKOT	110	BAGALKOT220-RAMDURGA	STATION NOT AFFECTED BAGALKOT_220	07:40	07:41	0:01	HAND TRIPPED
602	26-Feb-21	BAGALKOT	110	BAGALKOT-RAMDURGA	STATION NOT AFFECTED RAMDURGA_110	7:40 (26.02.2021)			LINE OPEN:LINE CLEAR AVAILED
603	26-Feb-21	BAGALKOT	110	GADAG220-BETAGERI	STATION NOT AFFECTED GADAG_220	10:13 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
604	26-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
605	26-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN:LINE CLEAR AVAILED
606	26-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
607	26-Feb-21	BAGALKOT	110	HAVERI220-HAVERI	HAVERI_110	7:52	10:22	2:30	LINE FAULT
608	26-Feb-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
609	26-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
610	26-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
611	26-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
612	26-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN:LINE CLEAR AVAILED
613	26-Feb-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
614	26-Feb-21	BAGALKOT	110	SOUDATTI220-RAMDURG1	RAMDURG_110	05:58	07:46	1:48	LINE FAULT
615	26-Feb-21	BAGALKOT	110	SOUDATTI220-RAMDURG2	RAMDURG_110	05:58	07:47	1:49	LINE FAULT
616	26-Feb-21	BAGALKOT	110	SOUDATTI-RAMDURGA	STATION NOT AFFECTED RAMDURGA_110	5:55	7:46	1:51	HAND TRIPPED
617	26-Feb-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN:LINE CLEAR AVAILED
618	26-Feb-21	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE_110	17:14 (25.02.2021)	20:42 (26.02.2021)	27:28 HRS	LINE CHARGED
619	26-Feb-21	BAGALKOT	220	ADPH 2- BAGEWADI	STATION NOT AFFECTED BAGEWADI_220	12:47	13:28	0:41	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
620	26-Feb-21	BAGALKOT	220	AMBEWADI-XELDOM(PONDA1)	AMBEWADI_220	22:49(25.02.2021)	15:37 (26.02.2021)	16:48 HRS	LINE CHARGED
621	26-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
622	26-Feb-21	BAGALKOT	220	BGL220-KNBRGI I	STATION NOT AFFECTED BELGAUM_220	12:54	16:38	3:44	LINE FAULT
623	26-Feb-21	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	16:52 (25.02.2021)			LINE OPEN:LINE CLEAR AVAILED
624	26-Feb-21	BAGALKOT	220	BIDNAL-HUBLI 1	STATION NOT AFFECTED BIDNAL_220	14:08	17:56	3:48	LINE FAULT
625	26-Feb-21	BAGALKOT	220	BIJAPUR- BAGEWADI2(GMR)	BIJAPUR_220	22:02 (25.02.2021)			LINE OPEN:LINE FAULT
626	26-Feb-21	BAGALKOT	220	BIJAPUR- INDI2	BIJAPUR_220	22:02 (25.02.2021)	8:02 (26.02.2021)	10:00 HRS	LINE CHARGED
627	26-Feb-21	BAGALKOT	220	BIJAPUR- VAISHALI2	BIJAPUR_220	22:02 (25.02.2021)	8:02 (26.02.2021)	10:00 HRS	LINE CHARGED
628	26-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
629	26-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
630	26-Feb-21	BAGALKOT	220	GADAG- HARTI2	GADAG_220	17:16 (25.02.2021)			LINE OPEN:LINE CLEAR AVAILED
631	26-Feb-21	BAGALKOT	220	HUBLI-NAGAZARI3	STATION NOT AFFECTED HUBLI_220	11:33 (25.02.2021)	13:36 (26.02.2021)	26:03 HRS	LINE CHARGED
632	26-Feb-21	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	13:09	18:20	5:11	LINE FAULT
633	26-Feb-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
634	26-Feb-21	BAGALKOT	220	MAHALINGAPUR- SOUDATTI	MAHALINGAPUR_220	13:19 (25.02.2021)	15:36 (26.02.2021)	26:17 HRS	LINE CHARGED
635	26-Feb-21	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	13:16(25.02.2021)	13:42 (26.02.2021)	24:26 HRS	LINE CHARGED
636	26-Feb-21	BAGALKOT	220	NARENDRA-AMBEWADI1 &2	STATION NOT AFFECTED NARENDRA_220	14:10	18:54	4:44	LINE CLEAR AVAILED
637	26-Feb-21	BAGALKOT	220	NARENDRA-KANABARGI1	STATION NOT AFFECTED NARENDRA_220	12:54	16:38	3:44	LINE FAULT
638	26-Feb-21	BAGALKOT	220	SHARAVATHY1- SIRSI	SIRSI_220	10:34 (22.02.2021)			LOAD CURTAILMENT
639	26-Feb-21	BAGALKOT	220	SHARAVATHY2- SIRSI	SIRSI_220	10:34 (22.02.2021)			LOAD CURTAILMENT
640	26-Feb-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	13:21 (25.02.2021)			LINE OPEN:LINE FAULT
641	26-Feb-21	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	STATION NOT AFFECTED VAJRAMATTI_220	17:11	17:30	0:19	LINE FAULT
642	26-Feb-21	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR1	VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
643	26-Feb-21	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR2-	VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
644	26-Feb-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	18:36	18:57	00:20	LINE FAULT
645	26-Feb-21	BENGALURU	66	HV1	HOSOR RAMAPURA	13:36	14:45	01:08	LINE CLEAR AVAILED
646	26-Feb-21	BENGALURU	66	HV1	VIJAYAPURA	20:00	20:12	00:11	TRANSFORMER FAULT
647	26-Feb-21	BENGALURU	66	HV2	HOSOR RAMAPURA	10:02	11:59	01:57	LINE CLEAR AVAILED
648	26-Feb-21	BENGALURU	66	HV2	SADLI	13:01	13:34	00:33	LINE CLEAR AVAILED
649	26-Feb-21	BENGALURU	66	KOTHIPURA 220kv - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	08:03	08:09	00:06	LOAD CHANGE OVER
650	26-Feb-21	BENGALURU	66	KOTHIPURA 220kv - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	19:27	19:35	00:08	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
651	26-Feb-21	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	13:35	13:40	00:05	LOAD CHANGE OVER
652	26-Feb-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
653	26-Feb-21	BENGALURU	220	KOTIPURA 220 - BIDADI 220	KOTIPURA 220	19:27	19:35	00:08	LOAD CHANGE OVER
654	26-Feb-21	BENGALURU	220	KOTIPURA 220 - TUBINAKERE 220	KOTIPURA 220	08:03	08:09	00:06	LOAD CHANGE OVER
655	26-Feb-21	BENGALURU	220	SRS PEENYA 220- SUBRAMANYAPURA 220	NO STATION AFFECTED	16:20	18:08	01:48	LINE FAULT
656	26-Feb-21	GULBARGA	66	HAMPASAGAR-ITTAGGI	HAMPASAGAR_66	21:45(26.02.2021)			LINE OPEN:LINE FAULT
657	26-Feb-21	GULBARGA	66	HV1	CHORNOOR_66	10:14	10:19	00:05	TRANSFORMER FAULT
658	26-Feb-21	GULBARGA	66	KOTTUR-BENNEHALLI	KOTTUR_66	12:55	13:20	00:25	MAIN SUPPLY FAILURE
659	26-Feb-21	GULBARGA	66	KOTTUR-BENNEHALLI	KOTTUR_66	12:20	12:45	00:25	MAIN SUPPLY FAILURE
660	26-Feb-21	GULBARGA	66	KOTTUR-KUDLIGI	UJJANI_66	12:55			LINE OPEN:LINE FAULT
661	26-Feb-21	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	18:45	18:54	00:09	MAIN SUPPLY FAILURE
662	26-Feb-21	GULBARGA	110	HV2	HALIKHED_110	16:57	17:40	00:43	LINE CLEAR AVOIDED
663	26-Feb-21	GULBARGA	110	HV2	HANUMASAGAR_110	09:55	10:50	00:55	LINE CLEAR AVOIDED
664	26-Feb-21	GULBARGA	110	HV2	HATTI_110	14:00	14:05	00:05	TRANSFORMER FAULT
665	26-Feb-21	GULBARGA	110	HV3	HALIKHED_110	12:02	13:17	01:15	LINE CLEAR AVOIDED
666	26-Feb-21	GULBARGA	110	KUSTAGI-YELBURGA	YELBURGA_110	06:19	17:14	10:55	MAIN SUPPLY FAILURE
667	26-Feb-21	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	02:39	02:54	00:15	MAIN SUPPLY FAILURE
668	26-Feb-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	13:46	14:05	00:19	MAIN SUPPLY FAILURE
669	26-Feb-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	14:20	14:36	00:16	LINE CLEAR AVOIDED
670	26-Feb-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	18:00	18:45	00:45	LINE CLEAR AVOIDED
671	26-Feb-21	GULBARGA	110	SHAHAPUR-RAICHUR1	GABBUR_110,DEODURGA_110	14:30	17:25	02:55	NFBC ISSUED
672	26-Feb-21	GULBARGA	110	STAR METALLIC -MUNIRABAD	MUNIRABAD_220	06:04	06:09	00:05	LINE FAULT
673	26-Feb-21	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	06:11	17:12	11:01	MAIN SUPPLY FAILURE
674	26-Feb-21	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	10:09	12:50	02:41	LINE CLEAR AVOIDED
675	26-Feb-21	HASSAN	66	BELUR66-HASSAN	BELUR_66	11:39	13:44	02:05	LOAD CURTAILMENT
676	26-Feb-21	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	12:32	13:50	01:18	LOAD CURTAILMENT
677	26-Feb-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:00	12:54	02:54	LINE CLEAR AVOIDED
678	26-Feb-21	HASSAN	66	CRPATNA-HNPURA	CRPATNA_220	10:24	10:40	00:16	LINE FAULT
679	26-Feb-21	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	13:52	18:50	04:58	LINE CLEAR AVOIDED
680	26-Feb-21	HASSAN	66	HV1	SALAGAME_66	23:54(25.02.2021)	2:06(26.02.2021)	2:11 hrs	TRANSFORMER CHARGED
681	26-Feb-21	HASSAN	66	HV1	ALDUR_66	15:10	15:40	00:30	LINE CLEAR AVOIDED
682	26-Feb-21	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:37	12:57	02:20	LINE CLEAR AVOIDED
683	26-Feb-21	HASSAN	66	HV1	GANGUR_66	11:20	11:55	00:35	LINE CLEAR AVOIDED
684	26-Feb-21	HASSAN	66	HV1	SALAGAME_66	19:48	20:12	00:24	LOAD CURTAILMENT
685	26-Feb-21	HASSAN	66	HV1	SINGAPURA_66	10:26	10:42	00:16	LOAD CURTAILMENT
686	26-Feb-21	HASSAN	66	HV2	SALAGAME_66	23:54(25.02.2021)	2:06(26.02.2021)	2:11 hrs	TRANSFORMER CHARGED
687	26-Feb-21	HASSAN	66	HV2	SALAGAME_66	17:58	20:12	02:14	LOAD CURTAILMENT
688	26-Feb-21	HASSAN	66	HV2	SINGAPURA_66	10:26	10:42	00:16	LOAD CURTAILMENT
689	26-Feb-21	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
690	26-Feb-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
691	26-Feb-21	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	08:57	16:09	07:12	LINE CLEAR AVOIDED
692	26-Feb-21	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	08:52	16:09	07:17	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
693	26-Feb-21	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	23:59(25.02.2021)	2:05(26.02.2021)	2:05 hrs	LINE CHARGED
694	26-Feb-21	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	15:41	18:02	02:21	LOAD CURTAILMENT
695	26-Feb-21	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	19:50	20:17	00:27	LOAD CURTAILMENT
696	26-Feb-21	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	23:54(25.02.2021)	20:11(26.02.2021)	20:16 hrs	LINE CHARGED
697	26-Feb-21	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:01	12:55	02:54	LINE CLEAR AVAILED
698	26-Feb-21	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	01:12	20:07	18:55	LINE CLEAR AVAILED
699	26-Feb-21	HASSAN	110	ARSK2-GERUMARA	ARASIKERE_220	11:00	13:10	02:10	LINE CLEAR AVAILED
700	26-Feb-21	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	09:15	14:16	05:01	LINE CLEAR AVAILED
701	26-Feb-21	HASSAN	110	HV1	ESSUR_110	22:29	22:45	00:16	LINE CLEAR AVAILED
702	26-Feb-21	HASSAN	110	HV2	ESSUR_110	12:45 (25.02.2021)	23:25(26.02.2021)	34:39 hrs	TRANSFORMER CHARGED
703	26-Feb-21	HASSAN	110	HV2	KARAYA_110	19:35 (25.02.2021)	16:09 (26.02.2021)	20:33 hrs	TRANSFORMER CHARGED
704	26-Feb-21	HASSAN	110	HV2	HALADY_110	09:30	09:35	00:05	TRANSFORMER FAULT
705	26-Feb-21	HASSAN	110	KADUR-TNGL	KADUR_220	11:14	12:34	01:20	LINE CLEAR AVAILED
706	26-Feb-21	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:26(26.02.2021)			LINE OPEN:LINE CLEAR AVAILED
707	26-Feb-21	HASSAN	220	MRSSHM-HONNALLI	MRSMG_220	10:23	14:23	04:00	LINE FAULT
708	26-Feb-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	18:05 (26.02.2021)			LINE OPEN:LINE CLEAR AVAILED
709	26-Feb-21	MYSURU	66	CHIKKAMANDYA-MANDYA	NO STATION EFFECTED	12:03	12:31	0:28	LINE CLEAR AVAILED
710	26-Feb-21	MYSURU	66	GAMANAHALLI-TUBINKERE	GAMANAHALLY_66	18:28			LINE OPEN:LINE FAULT
711	26-Feb-21	MYSURU	66	HV1	CHIKKA_MANDYA_66	11:29	12:19	0:50	LINE CLEAR AVAILED
712	26-Feb-21	MYSURU	66	HV1	GUDDENAHALLI_66	7:40	8:09	0:29	LINE CLEAR AVAILED
713	26-Feb-21	MYSURU	66	HV1	GUDDENAHALLI_66	19:45	19:52	0:07	LINE CLEAR AVAILED
714	26-Feb-21	MYSURU	66	HV2	CHIKKA_MANDYA_66	10:35	11:30	0:55	LINE CLEAR AVAILED
715	26-Feb-21	MYSURU	66	HV2	GUDDENAHALLI_66	7:40	8:09	0:29	LINE CLEAR AVAILED
716	26-Feb-21	MYSURU	66	HV2	GUDDENAHALLI_66	16:50	17:25	0:35	LINE CLEAR AVAILED
717	26-Feb-21	MYSURU	66	HV2	GUDDENAHALLI_66	19:45	19:52	0:07	LINE CLEAR AVAILED
718	26-Feb-21	MYSURU	66	HV2	NAGAMANGALA_66	17:40	18:03	0:23	LINE CLEAR AVAILED
719	26-Feb-21	MYSURU	66	HV2	THANDYA_66	11:17	12:45	1:28	LINE CLEAR AVAILED
720	26-Feb-21	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	NO STATION EFFECTED	9:11	18:25	9:13	HAND TRIPPED
721	26-Feb-21	MYSURU	66	KADAKOLA-MANDAKALLI	NO STATION EFFECTED	9:28	18:25	8:57	HAND TRIPPED
722	26-Feb-21	MYSURU	66	KADAKOLA-MYSORE SOUTH	NO STATION EFFECTED	9:12	18:28	9:16	HAND TRIPPED
723	26-Feb-21	MYSURU	66	KADAKOLA-NANJANGUDU 1	NO STATION EFFECTED	9:30	18:29	8:59	HAND TRIPPED
724	26-Feb-21	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
725	26-Feb-21	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATION EFFECTED	12:20	12:53	0:33	LINE CLEAR AVAILED
726	26-Feb-21	MYSURU	66	PANDAVAPURA-ATRIA2	NO STATION EFFECTED	11:47	12:20	0:32	LINE CLEAR AVAILED
727	26-Feb-21	MYSURU	220	HV1	KUSHALNAGARA_220	15:05	16:18	1:13	LINE CLEAR AVAILED
728	26-Feb-21	MYSURU	220	KADAKOLA-HV1	NO STATION EFFECTED	12:06	18:23	6:16	LINE CLEAR AVAILED
729	26-Feb-21	MYSURU	220	KADAKOLA-KOZIKODE	NO STATION EFFECTED	10:10	17:23	7:13	NFBC ISSUED
730	26-Feb-21	MYSURU	220	KUSHALNAGARA-HV2	KUSHALNAGARA_220	16:21	17:27	1:05	LINE CLEAR AVAILED
731	26-Feb-21	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	10:29	12:48	2:18	LINE CLEAR AVAILED
732	26-Feb-21	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	12:20	12:28	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
733	26-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	0:02	0:16	0:14	LINE FAULT
734	26-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	20:48	21:00	0:11	LINE FAULT
735	26-Feb-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	18:48	18:58	0:09	LINE FAULT
736	26-Feb-21	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	18:32	18:43	0:10	LINE FAULT
737	26-Feb-21	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	19:29	19:40	0:10	LINE FAULT
738	26-Feb-21	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR IPP_66	BPCLSOLAR_IPP_66	18:08	18:25	0:17	LINE FAULT
739	26-Feb-21	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	18:08	18:12	0:04	LINE FAULT
740	26-Feb-21	TUMKUR	66	NAGASAMUDRA- RAMPURA	NAGASAMUDRA_66	9:02	9:20	0:18	LINE FAULT
741	26-Feb-21	TUMKUR	66	THALLAK 220kv -BGKERE 1	BGKERE_66	13:37	13:39	0:01	HAND TRIPPED
742	26-Feb-21	TUMKUR	66	THALLAK 220kv -BGKERE 1	BGKERE_66	14:05	14:10	0:05	HAND TRIPPED
743	26-Feb-21	TUMKUR	66	THALLAK 220kv -BGKERE 2	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	13:37	13:39	0:01	HAND TRIPPED
744	26-Feb-21	TUMKUR	66	THALLAK 220kv -BGKERE 2	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	14:05	14:10	0:05	HAND TRIPPED
745	26-Feb-21	TUMKUR	66	THALLAK 220kv- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	13:22	13:34	0:12	LINE FAULT
746	26-Feb-21	TUMKUR	66	THALLAK 220kv- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	14:05	14:20	0:14	HAND TRIPPED
747	26-Feb-21	TUMKUR	66	THALLAK 220kv- GOWRASAMUDRA	GOWRASAMUDRA_66	13:37	13:41	0:04	HAND TRIPPED
748	26-Feb-21	TUMKUR	66	THALLAK 220kv- GOWRASAMUDRA	GOWRASAMUDRA_66	14:05	14:11	0:06	HAND TRIPPED
749	26-Feb-21	TUMKUR	66	THALLAK 220kv- SEI DIAMOND SOLAR IPP_66	SEL DIAMOND SOLAR_IPP_66	13:25	13:36	0:11	HAND TRIPPED
750	26-Feb-21	TUMKUR	66	THALLAK 220kv- SEI DIAMOND SOLAR IPP_66	SEL DIAMOND SOLAR_IPP_66	16:06	16:12	0:05	HAND TRIPPED
751	26-Feb-21	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	13:37	13:41	0:04	HAND TRIPPED
752	26-Feb-21	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	14:05	14:12	0:06	HAND TRIPPED
753	26-Feb-21	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	13:37	13:40	0:03	HAND TRIPPED
754	26-Feb-21	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	14:05	14:11	0:06	HAND TRIPPED
755	26-Feb-21	TUMKUR	66	TR-1	CHALLAKERE_66	17:08	17:11	0:02	HAND TRIPPED
756	26-Feb-21	TUMKUR	66	TR-1	HIREGUNTANUR_66	19:58	20:05	0:06	HAND TRIPPED
757	26-Feb-21	TUMKUR	66	TR-1	HANAGAL_66	13:28	13:39	0:11	MAIN SUPPLY FAILURE
758	26-Feb-21	TUMKUR	66	TR-2	HIREGUNTANUR_66	19:58	20:05	0:06	HAND TRIPPED
759	26-Feb-21	TUMKUR	66	TR-2	HANAGAL_66	13:28	13:40	0:11	MAIN SUPPLY FAILURE
760	26-Feb-21	TUMKUR	66	TR-2	HINDASGHATTA_66	9:57	10:36	0:39	LINE CLEAR AVAILED
761	26-Feb-21	TUMKUR	66	TR-2(LV SIDE)	THALLAKK_220	13:22	13:37	0:14	TRANSFORMER FAULT
762	26-Feb-21	TUMKUR	66	TR-2(LV SIDE)	THALLAKK_220	14:01	14:21	0:19	TRANSFORMER FAULT
763	26-Feb-21	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	11:19:12 (23.02.2021)	10:49:58 (26.02.2021)	71:30 HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
764	26-Feb-21	TUMKUR	220	HONNALLI 220kV- DAVANAGERE 220kV	HONNALLI_220	11:43:11 (23.02.2021)	10:59:21 (26.02.2021)	71:44 HRS	LINE CHARGED
765	27-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
766	27-Feb-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YADAWAD 110	22:20	22:28	0:08	TRANSFORMER FAULT
767	27-Feb-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TIKOTA 110	04:00	04:03	0:03	TRANSFORMER FAULT
768	27-Feb-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TIKOTA 110	09:05	09:10	0:05	TRANSFORMER FAULT
769	27-Feb-21	BAGALKOT	110	BABALESHWAR-VSE SOLAR(MAMADAPUR)	BABALESHWAR_110	2:08 (25.02.2021)			LINE OPEN:LINE FAULT
770	27-Feb-21	BAGALKOT	110	BAGALKOT 220-BAGALKOT 1	STATION NOT AFFECTED BAGALKOT 110	4:32 (26.02.2021)			LINE OPEN:LINE CLEAR AVAILED
771	27-Feb-21	BAGALKOT	110	BAGALKOT220-BAGALKOT2	STATION NOT AFFECTED BAGALKOT 220	11:48	15:47	3:59	LINE FAULT
772	27-Feb-21	BAGALKOT	110	BAGALKOT-RAMDURGA	STATION NOT AFFECTED RAMDURGA 110	7:40 (26.02.2021)			LINE OPEN:LINE CLEAR AVAILED
773	27-Feb-21	BAGALKOT	110	GADAG220-BETAGERI	STATION NOT AFFECTED GADAG 220	10:13 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
774	27-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG 110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
775	27-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI 110	7:13 (07.02.2021)			LINE OPEN:LINE CLEAR AVAILED
776	27-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
777	27-Feb-21	BAGALKOT	110	HUBLI220-BIDNAL2	STATION NOT AFFECTED HUBLI 220	10:34 (26.02.2021)	19:33 (27.02.2021)	32:59 HRS	LINE CHARGED
778	27-Feb-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT 110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
779	27-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
780	27-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI 110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
781	27-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND 110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
782	27-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG 110	17:42 (04.02.2021)			LINE OPEN:LINE CLEAR AVAILED
783	27-Feb-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR 220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
784	27-Feb-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY 110	15:10 (22.02.2021)			LINE OPEN:LINE CLEAR AVAILED
785	27-Feb-21	BAGALKOT	110	TAKKALAKI-KN SOLAR	TAKKALAKI_110 KN SOLAR IPP 110	11:18	12:24	1:06	MAIN SUPPLY FAILURE
786	27-Feb-21	BAGALKOT	110	TAKKALAKI-WARADA SOLAR	TAKKALAKI_110 WARADA SOLAR IPP 110	11:17	12:24	1:07	MAIN SUPPLY FAILURE
787	27-Feb-21	BAGALKOT	110	UCHAGOAN-UDYAMBAG	UDYAMBAG_110	19:54	21:36	1:42	LINE FAULT
788	27-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
789	27-Feb-21	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	16:52 (25.02.2021)			LINE OPEN:LINE CLEAR AVAILED
790	27-Feb-21	BAGALKOT	220	BIJAPUR- BAGEWADI2(GMR)	BIJAPUR_220	22:02 (25.02.2021)			LINE OPEN:LINE FAULT
791	27-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
792	27-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
793	27-Feb-21	BAGALKOT	220	GADAG- HARTI2	GADAG_220	17:16 (25.02.2021)			LINE OPEN:LINE CLEAR AVAILED
794	27-Feb-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	MAHALINGAPUR_220	10:07:00 AM (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
795	27-Feb-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	18:44	19:13	0:29	LINE FAULT
796	27-Feb-21	BAGALKOT	220	SHARAVATHY1- SIRSI	SIRSI_220	10:34 (22.02.2021)	20:05 (27.02.2021)	129:31 HRS	LINE CHARGED
797	27-Feb-21	BAGALKOT	220	SHARAVATHY2- SIRSI	SIRSI_220	10:34 (22.02.2021)	20:05 (27.02.2021)	129:31 HRS	LINE CHARGED
798	27-Feb-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	13:21 (25.02.2021)			LINE OPEN:LINE FAULT
799	27-Feb-21	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR1	VAJRAMATTI_220	16:17:00 AM (23.02.2021)			LINE OPEN:LINE FAULT
800	27-Feb-21	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR2-	VAJRAMATTI_220	10:07:00 AM (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
801	27-Feb-21	BENGALURU	66	A STATION 66 - A STATION 2	A STATION 66	07:35	07:38	00:03	LOAD CHANGE OVER
802	27-Feb-21	BENGALURU	66	ANEKAL - ATTIBELE	ATTIBELE	13:05	13:20	00:15	LOAD CHANGE OVER
803	27-Feb-21	BENGALURU	66	ANEKAL - YERANDANAHALLI 2	ANEKAL	13:01	13:46	00:44	LINE CLEAR AVAILED
804	27-Feb-21	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	17:30	17:35	00:05	LOAD CHANGE OVER
805	27-Feb-21	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	16:37	18:53	02:15	LINE FAULT
806	27-Feb-21	BENGALURU	66	HV1	ANEKAL	11:15	16:04	04:49	LINE CLEAR AVAILED
807	27-Feb-21	BENGALURU	66	HV1	VIJAYANAGARA	17:59	20:24	02:25	LINE CLEAR AVAILED
808	27-Feb-21	BENGALURU	66	HV1	WIDIA	10:00	18:22	08:22	LINE CLEAR AVAILED
809	27-Feb-21	BENGALURU	66	HV2	ANEKAL	13:01	13:49	00:48	LINE CLEAR AVAILED
810	27-Feb-21	BENGALURU	66	HV2	ANEKAL	16:38	18:02	01:23	LINE CLEAR AVAILED
811	27-Feb-21	BENGALURU	66	HV2	MAASTHI	18:36	19:23	00:46	TRANSFORMER FAULT
812	27-Feb-21	BENGALURU	66	HV2	YEDUMADU	12:53	12:57	00:04	TRANSFORMER FAULT
813	27-Feb-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	07:14	07:59	00:45	LINE CLEAR AVAILED
814	27-Feb-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	03:15	03:57	00:41	LOAD CURTAILMENT
815	27-Feb-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	07:14	07:59	00:45	LINE CLEAR AVAILED
816	27-Feb-21	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	04:15	07:58	03:43	LINE FAULT
817	27-Feb-21	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	03:12	04:05	00:52	LINE FAULT
818	27-Feb-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	07:14	07:59	00:45	LINE CLEAR AVAILED
819	27-Feb-21	BENGALURU	66	MEI LAYOUT - WIDIA	WIDIA	10:02	13:02	03:00	LINE CLEAR AVAILED
820	27-Feb-21	BENGALURU	66	V R DODDI - SOMANAHALLI 220	V R DODDI	10:48	11:05	00:17	LOAD CHANGE OVER
821	27-Feb-21	BENGALURU	66	V R DODDI - T K HALLI 220	V R DODDI	13:55	14:20	00:25	LOAD CHANGE OVER
822	27-Feb-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
823	27-Feb-21	BENGALURU	220	LV1	KOLAR 220	03:12	03:55	00:42	TRANSFORMER FAULT
824	27-Feb-21	GULBARGA	66	HAMPASAGAR-ITTAGGI	HAMPASAGAR_66	21:45(26.02.2021)	0:35(27.02.2021)	2:50 HRS	LINE CHARGED
825	27-Feb-21	GULBARGA	66	HAMPASAGAR-ITTAGGI	HAMPASAGAR_66	11:02	13:44	02:42	NFBC ISSUED
826	27-Feb-21	GULBARGA	66	HV1	HAMPASAGAR_66	16:01	16:03	00:02	TRANSFORMER FAULT
827	27-Feb-21	GULBARGA	66	KOTTUR-KUDLIGI	UJJANI_66	12:55(26.02.2021)	1:46(27.02.2021)	12:51 HRS	LINE CHARGED
828	27-Feb-21	GULBARGA	66	UJJANI-F1(BRI IPL IPP_ WIND)	UJJANI_66	16:52	17:12	00:20	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
829	27-Feb-21	GULBARGA	66	UJJANI-SOKKE	UJJANI_66	00:10	01:30	01:20	NFBC ISSUED
830	27-Feb-21	GULBARGA	110	220HUMNABAD-110HUMNABAD2	HUMNABAD_110	18:02	18:15	00:13	MAIN SUPPLY FAILURE
831	27-Feb-21	GULBARGA	110	HV2	MYLAR_110	06:20	06:25	00:05	TRANSFORMER FAULT
832	27-Feb-21	GULBARGA	110	HV2	MYLAR_110	07:20	07:25	00:05	TRANSFORMER FAULT
833	27-Feb-21	GULBARGA	110	HV2	MYLAR_110	10:46	10:47	00:01	TRANSFORMER FAULT
834	27-Feb-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	03:31	06:55	03:24	MAIN SUPPLY FAILURE
835	27-Feb-21	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	15:59	18:27	02:28	NFBC ISSUED
836	27-Feb-21	GULBARGA	110	SHAHAPUR-RAICHUR2	GOOGLE_110	10:05	19:46	09:41	NFBC ISSUED
837	27-Feb-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERAD ONA_110,SRNAGAR_110	12:10	12:20	00:10	MAIN SUPPLY FAILURE
838	27-Feb-21	GULBARGA	220	RTPS-LINGASUGUR	LINGAPUR_220	04:01	04:29	00:28	LINE CLEAR AVAILED
839	27-Feb-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	17:42	18:38	00:56	LINE CLEAR AVAILED
840	27-Feb-21	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	10:37	17:31	06:54	LINE CLEAR AVAILED
841	27-Feb-21	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	13:35	13:44	00:09	LINE FAULT
842	27-Feb-21	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	15:24	15:36	00:12	HAND TRIPPED
843	27-Feb-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	09:59	17:23	07:24	LINE CLEAR AVAILED
844	27-Feb-21	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	17:03	17:07	00:04	HAND TRIPPED
845	27-Feb-21	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	11:22	11:51	00:29	LINE FAULT
846	27-Feb-21	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	11:21	13:15	01:54	LINE CLEAR AVAILED
847	27-Feb-21	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:37	17:31	06:54	LINE CLEAR AVAILED
848	27-Feb-21	HASSAN	66	HV1	HAGARE_66	11:13	12:55	01:42	LINE CLEAR AVAILED
849	27-Feb-21	HASSAN	66	HV1	MALALI_66	11:24	11:55	00:31	LOAD CURTAILMENT
850	27-Feb-21	HASSAN	66	HV1	SALAGAME_66	11:05	11:47	00:42	LOAD CURTAILMENT
851	27-Feb-21	HASSAN	66	HV1	SALAGAME_66	12:59	14:25	01:26	LINE CLEAR AVAILED
852	27-Feb-21	HASSAN	66	HV2	SALAGAME_66	11:05	11:47	00:42	LOAD CURTAILMENT
853	27-Feb-21	HASSAN	66	HV2	SALAGAME_66	12:59	14:25	01:26	LINE CLEAR AVAILED
854	27-Feb-21	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
855	27-Feb-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
856	27-Feb-21	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	10:52	16:39	05:47	LINE CLEAR AVAILED
857	27-Feb-21	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	10:52	16:24	05:32	LINE CLEAR AVAILED
858	27-Feb-21	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	11:05	11:47	00:42	LOAD CURTAILMENT
859	27-Feb-21	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	12:59	14:25	01:26	LINE CLEAR AVAILED
860	27-Feb-21	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	11:05	11:46	00:41	LOAD CURTAILMENT
861	27-Feb-21	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	12:59	14:25	01:26	LINE CLEAR AVAILED
862	27-Feb-21	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:31	17:30	06:59	LINE CLEAR AVAILED
863	27-Feb-21	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	14:15	14:22	00:07	HAND TRIPPED
864	27-Feb-21	HASSAN	110	HV1	HALADY_110	09:20	09:29	00:09	HAND TRIPPED
865	27-Feb-21	HASSAN	110	HV1	HALADY_110	10:28	11:42	01:14	LINE CLEAR AVAILED
866	27-Feb-21	HASSAN	110	HV2	ESSUR_110	10:19	10:52	00:33	LINE CLEAR AVAILED
867	27-Feb-21	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	10:31	15:09	04:38	NFBC ISSUED
868	27-Feb-21	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:26(26.02.2021)			LINE OPEN:LINE CLEAR AVAILED
869	27-Feb-21	HASSAN	220	MRSSH-M-HASSAN	MRSMG_220	10:31	15:09	04:38	LINE CLEAR AVAILED
870	27-Feb-21	HASSAN	220	MRSSH-M-VARAH3	MRSMG_220	04:27	07:53	03:26	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
871	27-Feb-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	18:05 (26.02.2021)	15:39 (27.02.2021)	21:30 hrs	LINE CHARGED
872	27-Feb-21	MYSURU	66	GAMANAHALLI-TUBINKERE	GAMANAHALLY_66	18:28(27.2.21)	11:23 (27/02/2021)	16:55 HRS	LINE CHARGED
873	27-Feb-21	MYSURU	66	HOOTAGALLI-ELWALA	ELAVALA_66 GAVADAGERE_66	22:26	23:28	1:01	LINE FAULT
874	27-Feb-21	MYSURU	66	HOOTAGALLI-RBI	NO STATION EFFECTED	10:04	12:56	2:51	LINE CLEAR AVAILED
875	27-Feb-21	MYSURU	66	HV1	ADDIHALLI_66	20:59	21:10	0:10	TRANSFORMER FAULT
876	27-Feb-21	MYSURU	66	HV1	ELAVALA_66	22:26 (27/02/2021)			TRANSFORMER OPEN : TRANSFORMER FAULT
877	27-Feb-21	MYSURU	66	KADAKOLA-SARGUR 2	DOORA_66 HURA_66 HULLAHALLI_66,	6:55	7:00	0:05	LINE FAULT
878	27-Feb-21	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
879	27-Feb-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	10:54	10:57	0:02	HAND TRIPPED
880	27-Feb-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	9:05	9:10	0:05	LINE FAULT
881	27-Feb-21	MYSURU	220	HV1	KUSHALNAGARA_220	10:53	12:09	1:16	LINE CLEAR AVAILED
882	27-Feb-21	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	06:24	08:21	1:57	LINE FAULT
883	27-Feb-21	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	12:02	12:16	0:14	LINE FAULT
884	27-Feb-21	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	12:56	13:05	0:08	LINE FAULT
885	27-Feb-21	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	13:09	13:15	0:05	LINE FAULT
886	27-Feb-21	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR IPP_66	BPCLSOLAR_IPP_66	18:14	19:08	0:53	LINE FAULT
887	27-Feb-21	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	PULAMG_66	18:38	18:55	0:17	LINE FAULT
888	27-Feb-21	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	06:22	06:27	0:04	LINE CLEAR AVAILED
889	27-Feb-21	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	13:31	18:09	4:38	LINE CLEAR AVAILED
890	27-Feb-21	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGID URGA_66,PALLAGATTE_66, SOKKE_66	10:10	10:19	0:08	LINE FAULT
891	27-Feb-21	TUMKUR	66	SASALUHALLA-CKJRKUTT	SASALUHALLA_66	14:10	14:32	0:21	LINE FAULT
892	27-Feb-21	TUMKUR	66	TR-1	DYAVARANAHALLI_66	13:49	13:59	0:10	TRANSFORMER FAULT
893	27-Feb-21	TUMKUR	66	TR-1	DYAVARANAHALLI_66	15:03	15:08	0:05	TRANSFORMER FAULT
894	27-Feb-21	TUMKUR	66	TR-1	HIRIYUR_66	11:18	11:49	0:31	LINE CLEAR AVAILED
895	27-Feb-21	TUMKUR	66	TR-1	SASALUHALLA_66	19:34	19:38	0:03	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
896	27-Feb-21	TUMKUR	66	TR-1	TUMKUR_66	12:41	13:43	1:01	LINE CLEAR AVAILED
897	27-Feb-21	TUMKUR	66	TR-2	CHIKKABANAGERE_66	12:58	13:29	0:30	TRANSFORMER FAULT
898	27-Feb-21	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	08:21	08:28	0:06	LINE FAULT
899	27-Feb-21	TUMKUR	110	BANDIHALLI- TIPTUR	TIPTUR_110, HONNAVALLI_110	08:21	08:31	0:09	LINE FAULT
900	28-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
901	28-Feb-21	BAGALKOT	110	110/11KV,HV1	GULEDAGUDDA_110	13:22	13:29	0:07	TRANSFORMER FAULT
902	28-Feb-21	BAGALKOT	110	BABALESHWAR-VSE SOLAR(MAMADAPUR)	BABALESHWAR_110	2:08(25.02.2021)	13:55 (28.02.2021)	83:47 HRS	LINE CHARGED
903	28-Feb-21	BAGALKOT	110	BAGALKOT 220-BAGALKOT 1	STATION NOT AFFECTED BAGALKOT_110	4:32 (26.02.2021)			LINE OPEN:LINE CLEAR AVAILED
904	28-Feb-21	BAGALKOT	110	BAGALKOT-RAMDURGA	STATION NOT AFFECTED RAMDURGA_110	7:40 (26.02.2021)			LINE OPEN:LINE CLEAR AVAILED
905	28-Feb-21	BAGALKOT	110	GADAG220-BETAGERI	STATION NOT AFFECTED GADAG_220	10:13 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
906	28-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
907	28-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN:LINE CLEAR AVAILED
908	28-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
909	28-Feb-21	BAGALKOT	110	KANABARGI LAYOUT-NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
910	28-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
911	28-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
912	28-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
913	28-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN:LINE CLEAR AVAILED
914	28-Feb-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
915	28-Feb-21	BAGALKOT	110	SOUDATTI220-MMCL IPP	SOUDATTI_220 MMCL IPP_110	21:22	22:16	0:54	HAND TRIPPED
916	28-Feb-21	BAGALKOT	110	SOUDATTI220-MUNAVALLI	MUNAVALLI_110	21:29	22:10	0:41	HAND TRIPPED
917	28-Feb-21	BAGALKOT	110	SOUDATTI220-RAMDURG1	RAMDURG_110	21:29	22:05	0:36	HAND TRIPPED
918	28-Feb-21	BAGALKOT	110	SOUDATTI220-RAMDURG1&2	RAMDURG_110	5:23	5:47	0:24	LINE FAULT
919	28-Feb-21	BAGALKOT	110	SOUDATTI220-RAMDURG2	RAMDURG_110	21:29	22:01	0:32	HAND TRIPPED
920	28-Feb-21	BAGALKOT	110	SOUDATTI220-SOUDATTI1	SOUDATTI_110	21:28	21:58	0:30	HAND TRIPPED
921	28-Feb-21	BAGALKOT	110	SOUDATTI220-SOUDATTI2	SOUDATTI_110	21:29	22:18	0:49	HAND TRIPPED
922	28-Feb-21	BAGALKOT	110	SOUDATTI220-YARAGATTI	YARAGATTI_110	21:29	22:03	0:34	HAND TRIPPED
923	28-Feb-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN:LINE CLEAR AVAILED
924	28-Feb-21	BAGALKOT	110	TAKKALAKI-KN SOLAR	TAKKALAKI_110 KN SOLAR IPP_110	10:39	15:27	4:48	HAND TRIPPED
925	28-Feb-21	BAGALKOT	110	TAKKALAKI-TORVI	TAKKALAKI_110	9:00	15:16	6:16	HAND TRIPPED
926	28-Feb-21	BAGALKOT	110	TAKKALAKI-WARADA SOLAR	TAKKALAKI_110 WARADA SOLAR IPP_110	10:39	15:36	4:57	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
927	28-Feb-21	BAGALKOT	110	THORVI-TAKKALAKI(TIKOTA)	STATION NOT AFFECTED THORVI_110	09:00	15:10	6:10	LINE CLEAR AVAILED
928	28-Feb-21	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE_110	7:05 (27.02.2021)	17:22 (28.02.2021)	10:17 HRS	LINE CHARGED
929	28-Feb-21	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE_110	17:42 (28.02.2021)			LINE OPEN:LINE CLEAR AVAILED
930	28-Feb-21	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	04:39	23:01	18:22	LINE CLEAR AVAILED
931	28-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
932	28-Feb-21	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	16:52 (25.02.2021)			LINE OPEN:LINE CLEAR AVAILED
933	28-Feb-21	BAGALKOT	220	BIDNAL-SOUDATTI	STATION NOT AFFECTED BIDNAL_220	21:23	21:56	0:33	LINE FAULT
934	28-Feb-21	BAGALKOT	220	BIJAPUR- BAGEWADI2(GMR)	BIJAPUR_220	22:02 (25.02.2021)			LINE OPEN:LINE FAULT
935	28-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
936	28-Feb-21	BAGALKOT	220	DHONI-LINGAPUR2(HALAVATTI1)	DHONI_400	08:57	12:00	3:03	NFBC ISSUED
937	28-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
938	28-Feb-21	BAGALKOT	220	GADAG- HARTI2	GADAG_220	17:16 (25.02.2021)			LINE OPEN:LINE CLEAR AVAILED
939	28-Feb-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
940	28-Feb-21	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	8:35	18:25	9:50	LINE CLEAR AVAILED
941	28-Feb-21	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	18:57 (28.02.2021)			LINE OPEN:LINE CLEAR AVAILED
942	28-Feb-21	BAGALKOT	220	NARENDRA-AMBEWADI2	NARENDRA_220	04:18	18:25	14:07	LINE FAULT
943	28-Feb-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	13:21 (25.02.2021)			LINE OPEN:LINE FAULT
944	28-Feb-21	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	21:54	21:57	0:03	LINE FAULT
945	28-Feb-21	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR1	VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
946	28-Feb-21	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR2-	VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
947	28-Feb-21	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR	19:24	19:41	00:16	LOAD CHANGE OVER
948	28-Feb-21	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	16:07	16:24	00:17	LOAD CHANGE OVER
949	28-Feb-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	12:57	13:45	00:48	LINE FAULT
950	28-Feb-21	BENGALURU	66	HV1	MUDIYANUR	18:56	19:05	00:09	TRANSFORMER FAULT
951	28-Feb-21	BENGALURU	66	HV1	HUKUNDA	13:09	13:15	00:06	TRANSFORMER FAULT
952	28-Feb-21	BENGALURU	66	HV2	ANDERSONPET	14:45	14:55	00:10	LOAD CHANGE OVER
953	28-Feb-21	BENGALURU	66	HV2	DODDABELAVANGALA	12:55	13:47	00:51	TRANSFORMER FAULT
954	28-Feb-21	BENGALURU	66	HV2	B G ROAD	15:48	16:02	00:14	TRANSFORMER FAULT
955	28-Feb-21	BENGALURU	66	JAYANAGARA - NIMHANS 220	JAYANAGARA	17:31	17:53	00:22	MAIN SUPPLY FAILURE
956	28-Feb-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	13:10	13:48	00:37	LOAD CURTAILMENT
957	28-Feb-21	BENGALURU	66	KORAMANGALA 220 - GOLF LINK HAL 1	AMAR JYOTHI	17:31	18:31	01:00	LINE CLEAR AVAILED
958	28-Feb-21	BENGALURU	66	KORAMANGALA 220 - GOLF LINK HAL 2	K & C VALLEY	17:31	18:30	00:59	LINE CLEAR AVAILED
959	28-Feb-21	BENGALURU	66	KORAMANGALA 220 - KORAMANGALA 66	KORAMANGALA 66	17:31	18:29	00:58	LINE CLEAR AVAILED
960	28-Feb-21	BENGALURU	66	KOTHIPURA 220kV - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	10:30	10:37	00:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
961	28-Feb-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	17:47	18:06	00:18	LINE FAULT
962	28-Feb-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	18:06	18:36	00:29	LINE FAULT
963	28-Feb-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	18:56	19:05	00:08	LINE CLEAR AVAILED
964	28-Feb-21	BENGALURU	66	NIMHANS 220 - ADUGODI	ADUGODI	17:31	18:31	01:00	LINE CLEAR AVAILED
965	28-Feb-21	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	17:31	18:31	01:00	LINE CLEAR AVAILED
966	28-Feb-21	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	17:31	17:52	00:21	MAIN SUPPLY FAILURE
967	28-Feb-21	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66, ISKON	04:50	05:10	00:20	LOAD CHANGE OVER
968	28-Feb-21	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66, ISKON	18:15	18:20	00:05	LOAD CHANGE OVER
969	28-Feb-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
970	28-Feb-21	BENGALURU	220	HSR LAYOUT 220 - EPIP 220	KORAMANGALA 220, NIMHANS 220	17:31	18:16	00:45	LINE FAULT
971	28-Feb-21	BENGALURU	220	HV1	KORAMANGALA 220	17:31	18:27	00:56	LINE CLEAR AVAILED
972	28-Feb-21	BENGALURU	220	HV1	NIMHANS 220	17:31	18:24	00:53	LINE CLEAR AVAILED
973	28-Feb-21	BENGALURU	220	HV2	KORAMANGALA 220	17:31	18:27	00:56	LINE CLEAR AVAILED
974	28-Feb-21	BENGALURU	220	HV2	NIMHANS 220	17:31	18:24	00:53	LINE CLEAR AVAILED
975	28-Feb-21	BENGALURU	220	KORAMANGALA 220 - HSR LAYOUT 220	KORAMANGALA 220	17:31	18:25	00:54	MAIN SUPPLY FAILURE
976	28-Feb-21	BENGALURU	220	NIMHANS 220 - HSR LAYOUT 220	NIMHANS 220	17:31	18:24	00:53	MAIN SUPPLY FAILURE
977	28-Feb-21	GULBARGA	66	HV1	HAMPASAGAR_66	16:45	16:48	00:03	TRANSFORMER FAULT
978	28-Feb-21	GULBARGA	110	220SINDHANOOR-110 SINDHANOOR1	MASKI_110,MUDDAPUR_110	08:30	13:50	05:20	LINE CLEAR AVAILED
979	28-Feb-21	GULBARGA	110	HV1	GINIGERA_110	13:01	13:23	00:22	LINE CLEAR AVAILED
980	28-Feb-21	GULBARGA	110	HV2	SINDHANOOR_110	23:53	23:58	00:05	TRANSFORMER FAULT
981	28-Feb-21	GULBARGA	110	HV2	YEDRAMI_110	13:10	13:25	00:15	LINE CLEAR AVAILED
982	28-Feb-21	GULBARGA	110	KUDITINI-IDLE(TORANGALU)	TORANGALU_110	09:31	14:02	04:31	LINE CLEAR AVAILED
983	28-Feb-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	08:15	08:22	00:07	LINE FAULT
984	28-Feb-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	06:48	06:55	00:07	LINE FAULT
985	28-Feb-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	17:29	17:35	00:06	LINE FAULT
986	28-Feb-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	01:28	01:35	00:07	LINE FAULT
987	28-Feb-21	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	08:30	21:10	12:40	LINE CLEAR AVAILED
988	28-Feb-21	GULBARGA	110	SINDHANOOR-RAICHUR1	SINDHANOOR_110	01:10	01:15	00:05	LINE FAULT
989	28-Feb-21	GULBARGA	110	SINDHANOOR-RAICHUR2(IDLE)	ADVIABRESHWARA_110(NO EFFECTED STAION)	06:05	09:50	03:45	LINE FAULT
990	28-Feb-21	GULBARGA	110	SINDHANOOR-RAICHUR2(IDLE)	ADVIABRESHWARA_110(NO EFFECTED STAION)	09:50	13:50	04:00	LINE FAULT
991	28-Feb-21	GULBARGA	110	SINDHANOOR-SIRIGUPPA	SIRIGUPPA_110	08:45	13:40	04:55	LINE CLEAR AVAILED
992	28-Feb-21	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	11:38	12:23	00:45	MAIN SUPPLY FAILURE
993	28-Feb-21	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	10:06	13:48	03:42	LINE CLEAR AVAILED
994	28-Feb-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	09:59	14:08	04:09	LINE CLEAR AVAILED
995	28-Feb-21	HASSAN	66	HASSN22-HN PURA	HASSAN_220	15:10	15:33	00:23	LINE FAULT
996	28-Feb-21	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	08:44	08:48	00:04	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
997	28-Feb-21	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:06	14:10	04:04	LINE CLEAR AVAILED
998	28-Feb-21	HASSAN	66	HV1	BALEHONNUR_66	19:36	20:10	00:34	TRANSFORMER FAULT
999	28-Feb-21	HASSAN	66	HV1	BALEHONNUR_66	20:18	20:46	00:28	TRANSFORMER FAULT
1000	28-Feb-21	HASSAN	66	HV1	HANGARANAHALLY_66	18:05	18:37	00:32	HAND TRIPPED
1001	28-Feb-21	HASSAN	66	HV3	BALEHONNUR_66	20:18(28.02.2021)			TRANSFORMER OPEN : TRANSFORMER FAULT
1002	28-Feb-21	HASSAN	66	HV3	BALEHONNUR_66	19:36	20:18	00:42	TRANSFORMER FAULT
1003	28-Feb-21	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1004	28-Feb-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1005	28-Feb-21	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:02	14:11	04:09	LINE CLEAR AVAILED
1006	28-Feb-21	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	09:13	15:15	06:02	LINE CLEAR AVAILED
1007	28-Feb-21	HASSAN	110	HV2	KONAJE_110	13:14	13:21	00:07	TRANSFORMER FAULT
1008	28-Feb-21	HASSAN	110	HV2	KONAJE_110	19:51	19:54	00:03	TRANSFORMER FAULT
1009	28-Feb-21	HASSAN	110	HV2	KUNDAPURA_110	10:26	11:01	00:35	LINE CLEAR AVAILED
1010	28-Feb-21	HASSAN	110	MRSSHM-BADRAVATY1	MRSMG_220	08:25	15:21	06:56	LINE CLEAR AVAILED
1011	28-Feb-21	HASSAN	110	MRSSHM-BADRAVATY2	MRSMG_220	08:25	15:21	06:56	LINE CLEAR AVAILED
1012	28-Feb-21	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	11:17	11:27	00:10	LOAD CURTAILMENT
1013	28-Feb-21	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:26(26.02.2021)	14:31(28.02.2021)	52:04 hrs	LINE CHARGED
1014	28-Feb-21	MYSURU	66	HV1	HANGLA_66	16:42	17:08	0:26	TRANSFORMER FAULT
1015	28-Feb-21	MYSURU	66	HV1	ELAVALA_66	22:26 (27/02/2021)			TRANSFORMER OPEN : TRANSFORMER FAULT
1016	28-Feb-21	MYSURU	66	HV2	KHBCOLONY_66	14:40	14:51	0:11	TRANSFORMER FAULT
1017	28-Feb-21	MYSURU	66	KADAKOLA-NANJANGUDU 1	NANJANGUDU_66	22:25	23:26	1:01	LINE FAULT
1018	28-Feb-21	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATION EFFECTED	12:34	19:09	6:34	HAND TRIPPED
1019	28-Feb-21	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
1020	28-Feb-21	MYSURU	66	MADHUVANAHALLI-HANNUR1	NO STATION EFFECTED	17:24	17:29	0:04	LINE FAULT
1021	28-Feb-21	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	12:27	12:32	0:04	LINE FAULT
1022	28-Feb-21	MYSURU	66	NANJANGUDU-BEGUR	NANJANGUDU_66	22:46	23:33	0:47	LINE FAULT
1023	28-Feb-21	MYSURU	220	KUSHLNAGARA-BASTIPURA 1	NO STATION EFFECTED	10:32	12:58	2:26	LINE CLEAR AVAILED
1024	28-Feb-21	MYSURU	220	KUSHLNAGARA-BASTIPURA 2	NO STATION EFFECTED	13:08	15:10	2:01	LINE CLEAR AVAILED
1025	28-Feb-21	TUMKUR	66	ANCHEPALYA 220kv- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	11:26	11:40	0:13	LINE FAULT
1026	28-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	03:53	04:03	0:10	LINE FAULT
1027	28-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	06:11	06:22	0:10	LINE FAULT
1028	28-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:29	10:37	0:07	LINE FAULT
1029	28-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:03	11:18	0:14	LINE FAULT
1030	28-Feb-21	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	17:03	17:14	0:11	LINE FAULT
1031	28-Feb-21	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	12:09	12:17	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1032	28-Feb-21	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	18:08	18:21	0:13	LINE FAULT
1033	28-Feb-21	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	21:14	21:45	0:30	LINE FAULT
1034	28-Feb-21	TUMKUR	66	I D HALLI- CLEAN MAX SOLAR	CLEANMAXSOLAR_IPP_66	15:43	16:03	0:19	MAIN SUPPLY FAILURE
1035	28-Feb-21	TUMKUR	66	MATHOD-RAMCO CEMENT _EHT_66	RAMCO CEMENT _EHT_66	06:29	06:34	0:05	LINE FAULT
1036	28-Feb-21	TUMKUR	66	TR-1	DYAVARANAHALLI_66	16:48	17:06	0:18	LINE CLEAR AVAILED
1037	28-Feb-21	TUMKUR	66	TR-1	MAVINAKATTE_66	16:09	16:15	0:06	TRANSFORMER FAULT
1038	28-Feb-21	TUMKUR	66	TR-1	SASALUHALLA_66	09:28	09:33	0:05	TRANSFORMER FAULT
1039	28-Feb-21	TUMKUR	66	TR-1	SHYLA PURA_66	13:51	15:48	1:57	HAND TRIPPED
1040	28-Feb-21	TUMKUR	66	TR-1	HANAGAL_66	08:29	09:54	1:25	LINE CLEAR AVAILED
1041	28-Feb-21	TUMKUR	66	TR-2	HONNUDIKE_66	15:01	15:04	0:03	TRANSFORMER FAULT
1042	28-Feb-21	TUMKUR	66	TR-2	PULAMG_66	11:52	12:01	0:08	TRANSFORMER FAULT
1043	28-Feb-21	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	10:08	17:51	7:42	LINE CLEAR AVAILED
1044	1-Mar-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
1045	1-Mar-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SIRSI_110	13:37	14:04	0:27	LINE CLEAR AVAILED
1046	1-Mar-21	BAGALKOT	110	110/11KV,HV2	HUNAGUND_110	14:40	14:43	0:03	TRANSFORMER FAULT
1047	1-Mar-21	BAGALKOT	110	110/33KV,HV2	KUDUCHI_110,CHINCHALI_33	11:00	12:23	1:23	TRANSFORMER FAULT
1048	1-Mar-21	BAGALKOT	110	BAGALKOT 220-BAGALKOT 1	STATION NOT AFFECTED BAGALKOT_110	4:32 (26.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1049	1-Mar-21	BAGALKOT	110	BAGALKOT220-RAMDURGA	STATION NOT AFFECTED RAMDURGA_110	7:40 (26.02.2021)	15:05 (01.02.2021)	80:37 hrs	LINE CHARGED
1050	1-Mar-21	BAGALKOT	110	BAGALKOT220-RAMDURGA	STATION NOT AFFECTED RAMDURGA_110	16:17 (01.03.2021)			LINE OPEN:LINE CLEAR AVAILED
1051	1-Mar-21	BAGALKOT	110	GADAG220-BETAGERI	STATION NOT AFFECTED GADAG_220	10:13 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1052	1-Mar-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
1053	1-Mar-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1054	1-Mar-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
1055	1-Mar-21	BAGALKOT	110	KANABARGI LAYOUT-NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
1056	1-Mar-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
1057	1-Mar-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
1058	1-Mar-21	BAGALKOT	110	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR_220	10:07	18:59	8:52	LINE CLEAR AVAILED
1059	1-Mar-21	BAGALKOT	110	MAHALINGAPUR-TERDAL	STATION NOT AFFECTED MAHALINGAPUR_220	15:30	19:38	4:08	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1060	1-Mar-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
1061	1-Mar-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1062	1-Mar-21	BAGALKOT	110	RAMDURGA-SOUDATTI1	STATION NOT AFFECTED RAMDURGA_110	14:55	16:17	1:22	HAND TRIPPED
1063	1-Mar-21	BAGALKOT	110	RAMDURGA-SOUDATTI2	STATION NOT AFFECTED RAMDURGA_110	14:55	16:17	1:22	HAND TRIPPED
1064	1-Mar-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
1065	1-Mar-21	BAGALKOT	110	SOUDATTI220- RAMDURG1(NARAGUND)	STATION NOT AFFECTED SOUDATTI_220	16:06	16:12	0:06	HAND TRIPPED
1066	1-Mar-21	BAGALKOT	110	SOUDATTI220-RAMDURG2	STATION NOT AFFECTED SOUDATTI_220	16:06	16:12	0:06	HAND TRIPPED
1067	1-Mar-21	BAGALKOT	110	SOUDATTI220-SOUDATTI2	STATION NOT AFFECTED SOUDATTI_110	15:07	16:51	1:44	LINE CLEAR AVAILED
1068	1-Mar-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	STATION NOT AFFECTED AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1069	1-Mar-21	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE_110	17:42 (28.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1070	1-Mar-21	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	12:40	16:58	4:18	LINE CLEAR AVAILED
1071	1-Mar-21	BAGALKOT	220	220/110KV,HV1,LV1	NO STATION AFFECTED CHIKKODI_220	17:42	19:10	1:28	TRANSFORMER FAULT
1072	1-Mar-21	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	08:35	18:42	10:07	LINE CLEAR AVAILED
1073	1-Mar-21	BAGALKOT	220	BAGALKOT-VAJRAMATTI	STATION NOT AFFECTED BAGALKOT_220	15:20	19:41	4:21	LINE CLEAR AVAILED
1074	1-Mar-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
1075	1-Mar-21	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	16:52 (25.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1076	1-Mar-21	BAGALKOT	220	BIDNAL-SOUDATTI	STATION NOT AFFECTED BIDNAL_220	14:47	15:07	0:20	LINE FAULT
1077	1-Mar-21	BAGALKOT	220	BIJAPUR- BAGEWADI2(GMR)	BIJAPUR_220	22:02 (25.02.2021)	11:25 (01.03.2021)	85:23 hrs	LINE CHARGED
1078	1-Mar-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
1079	1-Mar-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
1080	1-Mar-21	BAGALKOT	220	GADAG- HARTI2	GADAG_220	17:16 (25.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1081	1-Mar-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1082	1-Mar-21	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	18:57 (28.02.2021)	18:42 (01.02.2021)	23:45 hrs	LINE CHARGED
1083	1-Mar-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	13:21 (25.02.2021)	19:02 (01.03.2021)	101:41 hrs	LINE CHARGED
1084	1-Mar-21	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR1	VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
1085	1-Mar-21	BAGALKOT	220	VAJRAMATTI MAAHALINGAPUR2-	VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1086	1-Mar-21	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	STATION NOT AFFECTED VAJRAMATTI_220	13:27	19:39	6:12	LINE FAULT
1087	1-Mar-21	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	22:48	23:09	00:21	LOAD CHANGE OVER
1088	1-Mar-21	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	18:49	18:53	00:04	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1089	1-Mar-21	BENGALURU	66	B G ROAD - JIGANI 220	B G ROAD	18:10	18:25	00:15	LOAD CHANGE OVER
1090	1-Mar-21	BENGALURU	66	B G ROAD - SOMANAHALLI 220	B G ROAD	16:29	17:57	01:28	MAIN SUPPLY FAILURE
1091	1-Mar-21	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	10:35	11:28	00:52	LINE FAULT
1092	1-Mar-21	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	10:35	11:28	00:53	LINE FAULT
1093	1-Mar-21	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	11:31	12:06	00:35	LINE FAULT
1094	1-Mar-21	BENGALURU	66	BRIGADE MEADOWS - SOMANAHALLI 220	BRIGADE MEADOWS	16:28	17:08	00:40	MAIN SUPPLY FAILURE
1095	1-Mar-21	BENGALURU	66	BRIGADE MEADOWS - SUBRAMANYAPURA 220	BRIGADE MEADOWS	18:50	18:56	00:06	LOAD CHANGE OVER
1096	1-Mar-21	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	10:02	10:11	00:08	LINE FAULT
1097	1-Mar-21	BENGALURU	66	ELITE PROMENEDE - RBI	ELITE PROMENEDE	16:29	16:57	00:28	MAIN SUPPLY FAILURE
1098	1-Mar-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	14:07	14:26	00:18	LINE FAULT
1099	1-Mar-21	BENGALURU	66	HV1	DEVANAHALLI	22:01	22:10	00:08	TRANSFORMER FAULT
1100	1-Mar-21	BENGALURU	66	HV2	B G ROAD	12:50	12:54	00:04	LINE CLEAR AVAILED
1101	1-Mar-21	BENGALURU	66	HV2	NELAKADRENAHALLI	11:05	11:11	00:06	TRANSFORMER FAULT
1102	1-Mar-21	BENGALURU	66	ISCON - SOMANAHALLI 220	ISCON	16:29	16:36	00:07	MAIN SUPPLY FAILURE
1103	1-Mar-21	BENGALURU	66	JAYANAGARA - NATIONAL COLLEGE	JAYANAGARA	00:08	00:12	00:04	LOAD CHANGE OVER
1104	1-Mar-21	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	11:44	14:00	02:15	LOAD CURTAILMENT
1105	1-Mar-21	BENGALURU	66	KEMPANAHALLI - BIDADI 220	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	11:05	11:15	00:10	LINE CLEAR AVAILED
1106	1-Mar-21	BENGALURU	66	KEMPANAHALLI - BIDADI 220	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	11:30	12:15	00:45	LINE CLEAR AVAILED
1107	1-Mar-21	BENGALURU	66	KEMPANAHALLI - BIDADI 220	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	12:43	13:05	00:22	LINE CLEAR AVAILED
1108	1-Mar-21	BENGALURU	66	KEMPANAHALLI - BIDADI 220	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	13:30	13:45	00:15	LINE CLEAR AVAILED
1109	1-Mar-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	13:59	14:20	00:20	LINE CLEAR AVAILED
1110	1-Mar-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	09:27	09:51	00:24	LOAD CURTAILMENT
1111	1-Mar-21	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	06:07	06:12	00:05	LOAD CHANGE OVER
1112	1-Mar-21	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	16:29	17:01	00:32	MAIN SUPPLY FAILURE
1113	1-Mar-21	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	16:29	17:09	00:40	MAIN SUPPLY FAILURE
1114	1-Mar-21	BENGALURU	66	SRS PEENYA - DG 1	NO STATION AFFECTED	16:02	18:23	02:21	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1115	1-Mar-21	BENGALURU	66	TADIGOLU - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	10:02	10:37	00:35	LINE FAULT
1116	1-Mar-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	06:16	06:21	00:05	LINE FAULT
1117	1-Mar-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	06:16	06:21	00:05	LINE FAULT
1118	1-Mar-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	14:23	14:27	00:04	LINE FAULT
1119	1-Mar-21	BENGALURU	220	BIDADI 220 - SOMANAHALLI 1	SOMANAHALLI 220	16:28	17:03	00:35	LINE FAULT
1120	1-Mar-21	BENGALURU	220	BIDADI 220 - SOMANAHALLI 2	NO STATION AFFECTED	16:28	23:59	07:31	LINE FAULT
1121	1-Mar-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
1122	1-Mar-21	BENGALURU	220	LV2	BIDADI 220	11:30	11:37	00:07	TRANSFORMER FAULT
1123	1-Mar-21	BENGALURU	220	LV2	BIDADI 220	16:29	16:31	00:02	TRANSFORMER FAULT
1124	1-Mar-21	BENGALURU	220	SOMANAHALLI 220 - BIDADI 1	SOMANAHALLI 220	16:29	17:03	00:34	LINE FAULT
1125	1-Mar-21	BENGALURU	220	SOMANAHALLI 220 - BIDADI 2	SOMANAHALLI 220	16:29	17:50	01:21	LINE FAULT
1126	1-Mar-21	GULBARGA	66	HV1	HAMPASAGAR_66	08:16	08:24	00:08	TRANSFORMER FAULT
1127	1-Mar-21	GULBARGA	66	ITTAGI-HAMPASAGAR	HAMPASAGAR_66	09:14	13:00	03:46	LINE CLEAR AVAILED
1128	1-Mar-21	GULBARGA	66	ITTAGI-TAMBRAHALLI	TAMBRAHALLI_66	13:45	14:44	00:59	MAIN SUPPLY FAILURE
1129	1-Mar-21	GULBARGA	66	KOTTUR-UJJANI	UJJANI_66	22:33	22:39	00:06	LINE FAULT
1130	1-Mar-21	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110	11:06	11:20	00:14	LINE FAULT
1131	1-Mar-21	GULBARGA	110	HV2	HATTI_110	08:57	09:04	00:07	TRANSFORMER FAULT
1132	1-Mar-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	01:28	01:35	00:07	LINE FAULT
1133	1-Mar-21	GULBARGA	110	SINDHNOOR-MUNIRABAD1	KARATAGI_110,SRERAMNAGAR_110 ,GANGAVATHI_110,VENKATAGIRI_110	12:55	13:10	00:15	LINE FAULT
1134	1-Mar-21	GULBARGA	110	TEKKALKOTE-RENEW SOLAR_IPP	TEKKALKOTE_110	19:14(01.03.2021)			LINE OPEN:LINE CLEAR AVAILED
1135	1-Mar-21	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	10:17	19:33	09:16	HAND TRIPPED
1136	1-Mar-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:12	19:28	09:16	LINE CLEAR AVAILED
1137	1-Mar-21	HASSAN	66	CRPATNA-HNPURA	ATTICHOWDENAHALLY_66	09:11	09:16	00:05	LINE CLEAR AVAILED
1138	1-Mar-21	HASSAN	66	CRPATNA-SBELAGOLA	CRPATNA_220	10:35	11:17	00:42	HAND TRIPPED
1139	1-Mar-21	HASSAN	66	DUDDA-CKNDGL	DUDDA_66	12:55	15:10	02:15	LINE CLEAR AVAILED
1140	1-Mar-21	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	09:11	09:19	00:08	HAND TRIPPED
1141	1-Mar-21	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:17	19:33	09:16	LINE CLEAR AVAILED
1142	1-Mar-21	HASSAN	66	HV1	HOLALUR_66	11:08	17:19	06:11	LINE CLEAR AVAILED
1143	1-Mar-21	HASSAN	66	HV2	HOLALUR_66	09:34	17:19	07:45	LINE CLEAR AVAILED
1144	1-Mar-21	HASSAN	66	HV3	BALEHONNUR_66	20:18(28.02.2021)			TRANSFORMER OPEN : TRANSFORMER FAULT
1145	1-Mar-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1146	1-Mar-21	HASSAN	66	LV2	CRPATNA_220	10:33	11:11	00:38	TRANSFORMER FAULT
1147	1-Mar-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1148	1-Mar-21	HASSAN	110	ALKOLA-MRS	ALKOLA_110	10:36	10:54	00:18	LINE FAULT
1149	1-Mar-21	HASSAN	110	ALKOLA-SAGAR	ALKOLA_110	10:36	11:09	00:33	LINE FAULT
1150	1-Mar-21	HASSAN	110	HV1	ESSUR_110	12:20	13:16	00:56	LINE CLEAR AVAILED
1151	1-Mar-21	HASSAN	110	HV1	KAVOOR_220	09:20	18:46	09:26	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1152	1-Mar-21	HASSAN	110	HV2	ESSUR_110	10:23 (1.03.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1153	1-Mar-21	HASSAN	110	HV2	ANANDAPURA_110	10:43	11:32	00:49	HAND TRIPPED
1154	1-Mar-21	HASSAN	110	JOG-JST1	mghejog_gen	10:36	11:14	00:38	LINE FAULT
1155	1-Mar-21	HASSAN	110	JOG-JST2	mghejog_gen	10:36	11:13	00:37	LINE FAULT
1156	1-Mar-21	HASSAN	110	LPH(LST-4)	ANANDAPURA_110	10:36	11:09	00:33	HAND TRIPPED
1157	1-Mar-21	HASSAN	110	SHIMOGA	ANANDAPURA_110	10:36	11:05	00:29	LINE FAULT
1158	1-Mar-21	HASSAN	220	KEMAR-Varahi3	KEMAR_220	11:57 (1.03.2021)			LINE OPEN:LINE CLEAR AVAILED
1159	1-Mar-21	HASSAN	220	MRSSHM-HSN4001	MRSMG_220	13:34	13:45	00:11	LINE FAULT
1160	1-Mar-21	HASSAN	400	TALAGU-HSN400	TALAGUPPA_400	18:03 (1.03.2021)			LINE OPEN:LINE CLEAR AVAILED
1161	1-Mar-21	MYSURU	66	BEGUR 220-SINDHUVALLIPURA	NO STATION EFFECTED	7:06	7:10	0:04	LINE FAULT
1162	1-Mar-21	MYSURU	66	DUNDANAHALLI-HULIYUR DURGA	DUNDANAHALLI_66	18:09	19:36	1:27	LINE CLEAR AVAILED
1163	1-Mar-21	MYSURU	66	ELWALA-HOOTAGALLI	ELAVALA_66 GAVADAGERE_66	18:39	19:05	0:26	HAND TRIPPED
1164	1-Mar-21	MYSURU	66	HV1	KIADBMANDYA_66	6:18	6:48	0:30	MAIN SUPPLY FAILURE
1165	1-Mar-21	MYSURU	66	HV1	KIADBMANDYA_66	6:57	7:12	0:14	MAIN SUPPLY FAILURE
1166	1-Mar-21	MYSURU	66	HV1	THANDYA_66	15:02	15:44	0:42	LINE CLEAR AVAILED
1167	1-Mar-21	MYSURU	66	HV1	ELAVALA_66	22:26 (27/02/2021)			TRANSFORMER OPEN : TRANSFORMER FAULT
1168	1-Mar-21	MYSURU	66	HV2	BGNAGARA_66	17:30	17:51	0:20	TRANSFORMER FAULT
1169	1-Mar-21	MYSURU	66	HV3	KIKKERI_66	14:09	16:53	2:43	LINE CLEAR AVAILED
1170	1-Mar-21	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66	2:46	2:53	0:06	LINE FAULT
1171	1-Mar-21	MYSURU	66	KIADB MANDYA-TK HALLI	KOLKARANADODDI_66	8:10	9:48	1:38	LINE CLEAR AVAILED
1172	1-Mar-21	MYSURU	66	KIADB MANDYA-TK HALLI	K_HONNALGERE_66 KIADBMANDYA_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	14:22	17:14	2:52	LINE FAULT
1173	1-Mar-21	MYSURU	66	KM DODDI-MANDYA	KOLKARANADODDI_66	7:45	9:41	1:55	LINE CLEAR AVAILED
1174	1-Mar-21	MYSURU	66	KM DODDI-MANDYA	KOLKARANADODDI_66	14:23	17:05	2:42	LINE CLEAR AVAILED
1175	1-Mar-21	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATION EFFECTED	10:59	13:05	2:06	HAND TRIPPED
1176	1-Mar-21	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
1177	1-Mar-21	MYSURU	66	KUSHALNAGARA-MYSORE 2	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	18:42	18:55	0:13	LINE FAULT
1178	1-Mar-21	MYSURU	66	PERIYAPATNA-HANGODU	PONNAMPET_66 VIRAJPET_66	21:25	21:36	0:11	LINE FAULT
1179	1-Mar-21	MYSURU	66	TALKADU-ADANI	NO STATION EFFECTED	17:10	17:16	0:06	HAND TRIPPED
1180	1-Mar-21	MYSURU	220	HOOTAGALLI-BASTIPURA 2	NO STATIONS INTERRUPTED.	11:41	12:10	0:28	LINE CLEAR AVAILED
1181	1-Mar-21	MYSURU	220	HOOTAGALLI-VAJMANGALA	NO STATION EFFECTED	11:39	12:15	0:35	LOAD CURTAILMENT
1182	1-Mar-21	MYSURU	220	KADAKOLA-KOZIKODE	NO STATION EFFECTED	8:23	18:52	10:28	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1183	1-Mar-21	MYSURU	220	KR PETE 220-CR PATNA	KRPET_220 AKKIEBBAL_66 ANEGOLAL_66 BANANGADI_66 BOGADHI MANDYA_66 BOOKANAKERE_66 CHINAKURALI_66 G MALLIGERE_66 GANJIGERE_66 GUDDENAHALLI_66 HARIYALDAMMATEMPLE_66 JAKKANAHALLY_66 KIKKERI_66 KRISHNAPURA_66 KRPET_66 MADESWARAPURA_66 NAGAMANGALA_66 SANTHEBACHALLI_66 SHEELUNERE_66	11:05	11:17	0:11	MAIN SUPPLY FAILURE
1184	1-Mar-21	MYSURU	220	TUBINKERE-BASTIPURA	TUBINAKERE_220 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI _66 BASARALU_66 TARIPURA_66 ARAKERE_66 GAMANAHALLY_66 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66 DUNDANAHALLI_66 GARUDANAUKADDA_66 KOPPA_66 PANDAVAPURA_66 SRIRANGAPATNA_66 BESAGARAHALLI_66 DODDABYADARAHALLI_66	10:31	14:50	4:19	LINE FAULT
1185	1-Mar-21	MYSURU	220	TUBINKERE-HUYGONALLI	KRPET_220 AKKIEBBAL_66 ANEGOLAL_66 BANANGADI_66 BOGADHI MANDYA_66 BOOKANAKERE_66 CHINAKURALI_66 G MALLIGERE_66 GANJIGERE_66 GUDDENAHALLI_66 HARIYALDAMMATEMPLE_66 JAKKANAHALLY_66 KIKKERI_66 KRISHNAPURA_66 KRPET_66 MADESWARAPURA_66 NAGAMANGALA_66 SANTHEBACHALLI_66 SHEELUNERE_66	10:31	11:24	0:53	HAND TRIPPED
1186	1-Mar-21	MYSURU	220	TUBINKERE-KOTTIPURA 2	NO STATION EFFECTED	10:31	11:37	1:06	HAND TRIPPED
1187	1-Mar-21	MYSURU	220	TUBINKERE-YELIYURU	NO STATION EFFECTED	10:31	11:25	0:54	HAND TRIPPED
1188	1-Mar-21	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	14:56	15:11	0:14	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1189	1-Mar-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	10:00	18:55	8:54	LINE CLEAR AVAILED
1190	1-Mar-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:27	18:41	0:13	LINE FAULT
1191	1-Mar-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	17:55	18:31	0:35	HAND TRIPPED
1192	1-Mar-21	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	10:42	10:50	0:08	LINE FAULT
1193	1-Mar-21	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	08:07	08:18	0:11	LINE FAULT
1194	1-Mar-21	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	10:48	10:58	0:09	LINE FAULT
1195	1-Mar-21	TUMKUR	66	THALLAK 220kv -BGKERE 1	BGKERE_66	18:11	18:23	0:11	HAND TRIPPED
1196	1-Mar-21	TUMKUR	66	THALLAK 220kv -BGKERE 2	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	18:10	18:19	0:08	HAND TRIPPED
1197	1-Mar-21	TUMKUR	66	THALLAK 220kv- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	18:10	18:19	0:08	HAND TRIPPED
1198	1-Mar-21	TUMKUR	66	THALLAK 220kv- GOWRASAMUDRA	GOWRASAMUDRA_66	18:11	18:22	0:10	HAND TRIPPED
1199	1-Mar-21	TUMKUR	66	THALLAK 220kv- SEI DIAMOND SOLAR IPP_66	SEL DIAMOND SOLAR_IPP_66	18:12	18:23	0:11	HAND TRIPPED
1200	1-Mar-21	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	18:11	18:52	0:40	LINE FAULT
1201	1-Mar-21	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	17:55	18:52	0:56	LINE FAULT
1202	1-Mar-21	TUMKUR	66	TR-1	CHANNAGIRI_66	02:52	03:10	0:18	LINE CLEAR AVAILED
1203	1-Mar-21	TUMKUR	66	TR-1	MATHOD_66	09:31	09:45	0:13	TRANSFORMER FAULT
1204	1-Mar-21	TUMKUR	66	TR-1	THOVINAKERE_66	08:34	08:50	0:15	TRANSFORMER FAULT
1205	1-Mar-21	TUMKUR	66	TR-1	THOVINAKERE_66	15:23:07	16:30:51	1:07 hrs	TRANSFORMER CHARGED
1206	1-Mar-21	TUMKUR	66	TR-2	CHANNAGIRI_66	05:25	05:33	0:07	TRANSFORMER FAULT
1207	1-Mar-21	TUMKUR	66	TR-2	HANAGAL_66	11:37	11:45	0:07	LINE CLEAR AVAILED
1208	1-Mar-21	TUMKUR	66	TR-2	HONNUDIKE_66	15:51	16:10	0:19	LINE CLEAR AVAILED
1209	1-Mar-21	TUMKUR	66	TR-2	MATHOD_66	11:02	11:11	0:08	TRANSFORMER FAULT
1210	1-Mar-21	TUMKUR	66	TR-2(LV SIDE)	THALLAKK_220	15:00	18:18	3:18	TRANSFORMER FAULT
1211	1-Mar-21	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	02:02	02:11	0:09	TRANSFORMER FAULT
1212	1-Mar-21	TUMKUR	110	TR-1	TANDAGA_110	09:06	09:14	0:07	TRANSFORMER FAULT
1213	1-Mar-21	TUMKUR	220	HONNALLI 220kv- DAVANAGERE 220kv	HONNALLI_220	11:44	12:15	0:30	MAIN SUPPLY FAILURE
1214	1-Mar-21	TUMKUR	220	THALLAK 220kv- SEI VENUS DIAMOND IPP_66	SEI VENUS DIAMOND_IPP_66	15:00	18:59	3:58	LINE CLEAR AVAILED