

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 30.10.2018 & 31.10.2018 TO 05.11.2018

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	30-Oct-18	BAGALKOT	110	110/11KV, HV1	TORVI(BIJAPUR)_110	11:05	12:08	1:03	LINE CLEAR AVAILED
2	30-Oct-18	BAGALKOT	110	TORVI(BIJAPUR)-BHUTANAL	BHUTANAL_110	12:05	12:07	0:02	LINE FAULT
3	30-Oct-18	BAGALKOT	110	CHIKKODI220-KHADAKALAT	KHADAKALAT_110,NIPPANI_110	8:25	8:39	0:14	LINE FAULT
4	30-Oct-18	BAGALKOT	220	GHTAPRABHA-KUDACHI	GHATAPRABHA_220	12:13	21:45	9:32	LINE FAULT
5	30-Oct-18	BAGALKOT	220	KUDACHI-GHATAPRABHA	KUDACHI_220	16:48	21:45	4:57	NBFC ISSUED
6	30-Oct-18	BAGALKOT	110	110/11KV, HV2	KUD DHARWAD_110	12:08	13:10	1:02	LINE CLEAR AVAILED
7	30-Oct-18	BAGALKOT	110	110/33KV,HV2	UTTUR_110	20:15	20:30	0:15	TRANSFORMER FAULT
8	30-Oct-18	BAGALKOT	110	110/11KV,HV2	SHIRGOAN_110	13:07	14:00	0:53	HAND TRIPPED
9	30-Oct-18	BAGALKOT	110	CHIKKODI 220-RAIBAG	RAIBAG_110	10:42	12:08	1:26	HAND TRIPPED
10	30-Oct-18	BAGALKOT	110	JOG 1&2-SIRSI	SIRSI_110	11:26	15:05	3:39	HAND TRIPPED
11	30-Oct-18	BAGALKOT	220	HUBLI 2-SIRSI	SIRSI_220	0:00	16:13	16:13	LINE CLEAR AVAILED
12	31-Oct-18	BAGALKOT	110	SUPA1-AMBEWADI	AMBEWADI_220	10:01	12:36	2:35	LINE CLEAR AVAILED
13	31-Oct-18	BAGALKOT	110	110/11KV, HV3	BILAGI_110	1:40	4:43	3:03	TRANSFORMER FAULT
14	31-Oct-18	BAGALKOT	220	220/110KV, HV1&LV1	CHIKKODI_220	10:18	12:50	2:32	LINE CLEAR AVAILED
15	31-Oct-18	BAGALKOT	110	110/33KV, HV2	GULEDGUDDA_110	6:41	6:57	0:16	TRANSFORMER FAULT
16	31-Oct-18	BAGALKOT	110	110/33KV, HV2	GULEDGUDDA_110	10:16	10:22	0:06	TRANSFORMER FAULT
17	31-Oct-18	BAGALKOT	110	110/11K, HV1	HIDIKAL_110	14:30	17:47	3:17	LINE CLEAR AVAILED
18	31-Oct-18	BAGALKOT	110	110/11KV, HV4	HUKKERI_110	9:14	9:41	0:27	TRANSFORMER FAULT
19	31-Oct-18	BAGALKOT	110	KARWAR220-BINAGA	BINAGA_110	10:25	15:42	5:17	LINE CLEAR AVAILED
20	31-Oct-18	BAGALKOT	110	110/33KV, HV1	KUMATA_110	13:47	14:11	0:24	LINE CLEAR AVAILED
21	31-Oct-18	BAGALKOT	110	110/11KV, HV1	LOKAPUR_110	10:42	10:45	0:03	TRANSFORMER FAULT
22	31-Oct-18	BAGALKOT	110	110/11KV,HV2	SHIROL_110	19:54	20:08	0:14	HAND TRIPPED
23	31-Oct-18	BAGALKOT	110	BPCL2-SHIRAHATTI	SHIRAHATTI_110	5:57	8:14	2:17	LINE FAULT
24	31-Oct-18	BAGALKOT	110	BPCL2-SHIRAHATTI	SHIRAHATTI_110	8:14	22:32	14:18	LINE FAULT
25	31-Oct-18	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	12:32	21:33	9:01	LINE FAULT
26	31-Oct-18	BAGALKOT	110	110/33KV,HV3	NIPPANI_110	12:45	13:21	0:36	HAND TRIPPED
27	31-Oct-18	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	14:22	14:32	0:10	TRANSFORMER FAULT
28	31-Oct-18	BAGALKOT	110	110/11KV,HV1	MURDESHWARA_110	11:32	11:50	0:18	HAND TRIPPED
29	31-Oct-18	BAGALKOT	110	110/33KV,HV3	MURDESHWARA_110	11:32	11:50	0:18	HAND TRIPPED
30	1-Nov-18	BAGALKOT	110	110/11KV, HV2	ANKALI_110	10:50	11:15	0:25	LINE CLEAR AVAILED
31	1-Nov-18	BAGALKOT	110	110/11KV, HV2	BANAHATTI_110	18:26	19:00	0:34	LINE CLEAR AVAILED
32	1-Nov-18	BAGALKOT	110	CHIKKODI-BELAGUM2	CHIKKODI_220	21:02	22:52	1:50	HAND TRIPPED
33	1-Nov-18	BAGALKOT	110	110/33KV, HV2	GULEDGUDDA_110	7:57	8:06	0:09	TRANSFORMER FAULT
34	1-Nov-18	BAGALKOT	110	110/33KV, HV2	GULEDGUDDA_110	8:35	8:44	0:09	TRANSFORMER FAULT
35	1-Nov-18	BAGALKOT	110	ASHOKA IRON PLANT-MACHE	MACHE_110	12:31	13:36	1:05	LINE CLEAR AVAILED
36	1-Nov-18	BAGALKOT	110	110/33KV,HV4	ZALKI_110	12:54	13:03	0:09	TRANSFORMER FAULT
37	1-Nov-18	BAGALKOT	110	UGAR KHUD-KAGAWAD	UGAR KHUD_110	19:38	19:47	0:09	LINE FAULT
38	1-Nov-18	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	14:45	16:31	1:46	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
39	1-Nov-18	BAGALKOT	110	CHIKKODI220-RAIBAG	RAIBAG_110	10:47	12:12	1:25	NBFC ISSUED
40	2-Nov-18	BAGALKOT	220	XELDOM-AMBEWADI	AMBEWADI_220	12:08	15:07	2:59	HAND TRIPPED
41	2-Nov-18	BAGALKOT	110	110/11KV, HV1	KUDACHI_220	19:14	19:23	0:09	TRANSFORMER FAULT
42	2-Nov-18	BAGALKOT	110	110/11KV, HV1	NAVANAGAR(H)_110	7:23	7:40	0:17	TRANSFORMER FAULT
43	3-Nov-18	BAGALKOT	110	AMBEWADI-NK2	KAVALWADA_110	23:10	23:18	0:08	LINE FAULT
44	3-Nov-18	BAGALKOT	110	110/11KV, HV2	BANAHATTI_110	17:24	18:30	1:06	LINE CLEAR AVAILED
45	3-Nov-18	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	2:05	7:51	5:46	HAND TRIPPED
46	3-Nov-18	BAGALKOT	110	GAJENDRAGAD-RON1&2	RON_110	18:55	19:40	0:45	MAIN SUPPLY FAILURE
47	3-Nov-18	BAGALKOT	110	SHIRGUPPI SUGARS-KAGAWADA	KAGAWADA_110	19:22	19:40	0:18	LINE FAULT
48	3-Nov-18	BAGALKOT	110	110/11KV, HV2	MUNAVALLI_110	14:08	14:46	0:38	HAND TRIPPED
49	3-Nov-18	BAGALKOT	110	110/11KV, HV1	NAVALGUND_110	16:31	16:55	0:24	LINE CLEAR AVAILED
50	3-Nov-18	BAGALKOT	110	RANEENNUR-AREMALLAPUR	HONNATTI_110&AREMALLAPUR_110	3:50	13:40	9:50	HAND TRIPPED
51	3-Nov-18	BAGALKOT	110	RON -HIREHAL	HIREHAL_110	18:47	19:45	0:58	LINE FAULT
52	3-Nov-18	BAGALKOT	110	110/11KV HV-2	RON_110	18:47	19:46	0:59	TRANSFORMER FAULT
53	3-Nov-18	BAGALKOT	110	110/33KV, HV2	SAVANUR_110	14:13	14:18	0:05	HAND TRIPPED
54	3-Nov-18	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	15:03	15:12	0:09	HAND TRIPPED
55	3-Nov-18	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	23:21	23:59	0:38	LINE FAULT
56	3-Nov-18	BAGALKOT	220	220/110KV ,HV-1 &LV-1	SRS HUBLI_220	11:44	16:18	4:34	HAND TRIPPED
57	3-Nov-18	BAGALKOT	110	SIRSI 220-KAVALAWAD	KAVALWADA_110	23:10	23:24	0:14	LINE FAULT
58	3-Nov-18	BAGALKOT	110	UGAR JKHUD-KAGAWAD	KAGAWADA_110	18:45	19:11	0:26	LINE FAULT
59	3-Nov-18	BAGALKOT	110	110/33KV, HV4	ZALAKI_110	9:46	9:55	0:09	TRANSFORMER FAULT
60	4-Nov-18	BAGALKOT	110	110/11KV, HV2	KIADB BIJAPUR_110	16:15	16:40	0:25	LINE CLEAR AVAILED
61	4-Nov-18	BAGALKOT	110	GADAG220-BETAGERI	BETAGERI_110	23:10	23:59	0:49	LINE FAULT
62	4-Nov-18	BAGALKOT	110	GAJENDRAGAD-RON1&2	RON_110	12:13	19:34	7:21	HAND TRIPPED
63	4-Nov-18	BAGALKOT	110	KUSTAGI-GAJENDRAGA	GAJENDRAGAD_110	19:33	20:14	0:41	MAIN SUPPLY FAILURE
64	4-Nov-18	BAGALKOT	110	110/33KV, HV2	GULEDAGUDDA_110	9:38	9:51	0:13	TRANSFORMER FAULT
65	4-Nov-18	BAGALKOT	110	110/33KV, HV2	KUDACHI_110	1:59	2:30	0:31	TRANSFORMER FAULT
66	4-Nov-18	BAGALKOT	110	110/11KV, HV2	MAMDAPUR(G)_110	21:12	23:59	2:47	TRANSFORMER FAULT
67	4-Nov-18	BAGALKOT	110	RON -GAJENDRAGAD	GEJENDRAGAD_110	14:00	19:38	5:38	HAND TRIPPED
68	4-Nov-18	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	0:00	17:11	17:11	LINE CLEAR AVAILED
69	4-Nov-18	BAGALKOT	110	110/11KV,HV-2	UGAR KHUD_110	6:20	6:27	0:07	TRANSFORMER FAULT
70	5-Nov-18	BAGALKOT	110	110/11KV,HV-2	BAGALKOT_110	11:55	12:06	0:11	TRANSFORMER FAULT
71	5-Nov-18	BAGALKOT	110	110/11KV,HV-2	BELUR_110	11:58	12:05	0:07	TRANSFORMER FAULT
72	5-Nov-18	BAGALKOT	110	CHADACHAN-INDIAN SUGARS	CHADACHAN_110	3:43	3:45	0:02	LINE FAULT
73	5-Nov-18	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	0:07	9:36	9:29	LINE FAULT
74	5-Nov-18	BAGALKOT	110	GADAG 220-BETAGERI	BETAGERI_110	0:00	17:49	17:49	LINE CLEAR AVAILED
75	5-Nov-18	BAGALKOT	110	GAJENDRAGAD-KUSHTAGI	GAJENDRAGAD_110	0:34	3:12	2:38	HAND TRIPPED
76	5-Nov-18	BAGALKOT	110	GAJENDRAGAD-KUSHTAGI	GAJENDRAGAD_110	17:59	18:40	0:41	HAND TRIPPED
77	5-Nov-18	BAGALKOT	110	GAJENDRAGAD-KUSHTAGI	GAJENDRAGAD_110	20:04	20:05	0:01	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
78	5-Nov-18	BAGALKOT	110	GOPANAKOPPA-MRITYUNJAYANAGAR 2	MRUTYUNJAYANAGAR_110	6:25	15:00	8:35	LINE FAULT
79	5-Nov-18	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	0:58	1:22	0:24	HAND TRIPPED
80	5-Nov-18	BAGALKOT	110	KULIGOD-GAMESH	KULIGOD_110	6:25	6:26	0:01	MAIN SUPPLY FAILURE
81	5-Nov-18	BAGALKOT	110	110/33KV,HV-3	MACHE_110	13:30	14:17	0:47	HAND TRIPPED
82	5-Nov-18	BAGALKOT	110	110/33KV,HV-2	MATTIHAL_110	18:08	18:57	0:49	MAIN SUPPLY FAILURE
83	5-Nov-18	BAGALKOT	110	BAGEWADI-MATIIHAL	MATTIHAL_110	18:08	18:51	0:43	LINE FAULT
84	5-Nov-18	BAGALKOT	110	PG HUNASYAL-SATISH SUGARS	PG HUNASYAL_110	5:36	5:48	0:12	LINE FAULT
85	5-Nov-18	BAGALKOT	110	110/11KV,HV-2	PG HUNASYAL_110	10:02	10:12	0:10	HAND TRIPPED
86	5-Nov-18	BAGALKOT	110	110/11KV HV-2	RON_110	1:27	1:35	0:08	TRANSFORMER FAULT
87	5-Nov-18	BAGALKOT	110	110/11KV,HV-1	SIDDAPUR_110	16:23	17:33	1:10	LINE CLEAR AVAILED
88	5-Nov-18	BAGALKOT	110	110/33KV,HV-4	ZALAKI_110	14:48	15:52	1:04	LINE CLEAR AVAILED
89	5-Nov-18	BAGALKOT	220	KUDACHI-ATHANI	KUDACHI_220	14:41	15:39	0:58	LINE CLEAR AVAILED
90	30-Oct-18	BANGALORE	66	HV1	ANJANAPURA	12:13	12:16	0:03	TRANSFORMER FAULT
91	30-Oct-18	BANGALORE	66	BG ROAD - SOMANAHALLI 220	BG ROAD	9:22	9:37	0:15	LINE FAULT
92	30-Oct-18	BANGALORE	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	11:12	11:48	0:35	LINE CLEAR AVAILED
93	30-Oct-18	BANGALORE	66	ISRO LAYOUT - SARAKKI	ISRO LAYOUT	15:55	16:00	0:05	LOAD CHANGEOVER
94	30-Oct-18	BANGALORE	66	ISRO LAYOUT - SUBRAMANYAPURA 220	ISRO LAYOUT	11:02	11:30	0:27	LOAD CHANGEOVER
95	30-Oct-18	BANGALORE	66	HV1	SARAKKI	10:05	14:13	4:08	LINE CLEAR AVAILED
96	30-Oct-18	BANGALORE	66	HV3	SARAKKI	13:00	17:35	4:35	LINE CLEAR AVAILED
97	30-Oct-18	BANGALORE	66	SARAKKI - SUBRAMANYAPURA 2	SARAKKI	11:00	11:30	0:30	LOAD CHANGEOVER
98	30-Oct-18	BANGALORE	66	SARAKKI - JAYADEVA 1 & 2	SARAKKI	17:15	17:30	0:15	LOAD CHANGEOVER
99	30-Oct-18	BANGALORE	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIGEHALI, SRIGANDAKAVAL	17:41	18:23	0:42	LINE FAULT
100	30-Oct-18	BANGALORE	66	HV1	TELECOM LAYOUT	13:15	13:21	0:06	LINE CLEAR AVAILED
101	30-Oct-18	BANGALORE	220	BUS SECTIONALIZER	HOODY 220	17:20	17:40	0:20	LINE FAULT
102	30-Oct-18	BANGALORE	220	HV1	HOODY 220	17:20	17:45	0:25	MAIN SUPPLY FAILURE
103	30-Oct-18	BANGALORE	220	HV3	HOODY 220	17:20	17:42	0:22	MAIN SUPPLY FAILURE
104	30-Oct-18	BANGALORE	66	HOODY 220 - GRAPHITE INDIA(EHT)	GRAPHITE INDIA(EHT)	17:20	17:56	0:36	MAIN SUPPLY FAILURE
105	30-Oct-18	BANGALORE	66	HOODY 220 - HP (EHT)	HP (EHT)	17:20	17:52	0:32	MAIN SUPPLY FAILURE
106	30-Oct-18	BANGALORE	66	HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTHINIKETHAN	17:20	17:46	0:26	MAIN SUPPLY FAILURE
107	30-Oct-18	BANGALORE	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	17:20	17:49	0:29	MAIN SUPPLY FAILURE
108	30-Oct-18	BANGALORE	66	HV1	HOODY 220	17:20	17:49	0:29	MAIN SUPPLY FAILURE
109	30-Oct-18	BANGALORE	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	17:20	17:37	0:17	MAIN SUPPLY FAILURE
110	30-Oct-18	BANGALORE	66	HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTHINIKETHAN	12:53	13:37	0:43	LINE CLEAR AVAILED
111	30-Oct-18	BANGALORE	66	POTTERY ROAD - HEBBAL 220	POTTERY ROAD	17:53	17:58	0:04	LOAD CHANGEOVER
112	30-Oct-18	BANGALORE	66	POTTERY ROAD - ITC (EHT)	ITC (EHT)	17:20	17:59	0:39	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
113	30-Oct-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1	VIDYANAGAR, GRIND WELL (EHT)	8:24	10:35	2:11	MAIN SUPPLY FAILURE
114	30-Oct-18	BANGALORE	220	BEGUR 220 - HOSKOTE 220	HOSKOTE 220	8:24	10:18	1:53	LINE FAULT
115	30-Oct-18	BANGALORE	66	HV2	DODDABELAVANGALA	0:06	0:14	0:08	TRANSFORMER FAULT
116	30-Oct-18	BANGALORE	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	10:40	10:45	0:05	LOAD CHANGEOR
117	30-Oct-18	BANGALORE	66	HENNUR CROSS - SAHAKARINAGAR	HENNUR CROSS	10:38	10:42	0:04	LOAD CHANGEOR
118	30-Oct-18	BANGALORE	66	HENNUR CROSS - VIDYANAGAR	HENNUR CROSS	8:24	9:00	0:35	MAIN SUPPLY FAILURE
119	30-Oct-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1	VIDYANAGAR, GRIND WELL (EHT), HBR LAYOUT	12:30	13:04	0:34	MAIN SUPPLY FAILURE
120	30-Oct-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	8:24	10:34	2:10	MAIN SUPPLY FAILURE
121	30-Oct-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	12:30	13:03	0:33	MAIN SUPPLY FAILURE
122	30-Oct-18	BANGALORE	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	8:24	9:55	1:31	MAIN SUPPLY FAILURE
123	30-Oct-18	BANGALORE	220	HV1	HOSKOTE 220	8:24	10:29	2:04	MAIN SUPPLY FAILURE
124	30-Oct-18	BANGALORE	220	HV2	HOSKOTE 220	8:24	10:30	2:06	MAIN SUPPLY FAILURE
125	30-Oct-18	BANGALORE	220	HV1	HOSKOTE 220	12:30	12:55	0:25	TRANSFORMER FAULT
126	30-Oct-18	BANGALORE	220	HV2	HOSKOTE 220	12:30	12:46	0:16	TRANSFORMER FAULT
127	30-Oct-18	BANGALORE	66	HV1	HOSKOTE 220	12:30	12:57	0:27	MAIN SUPPLY FAILURE
128	30-Oct-18	BANGALORE	66	HOSKOTE 220 - PILAGUMPA	PILAGUMPA	8:24	10:30	2:06	MAIN SUPPLY FAILURE
129	30-Oct-18	BANGALORE	66	HOSKOTE - VOLVO	VOLVO, NANDAGUDI	8:24	10:30	2:06	MAIN SUPPLY FAILURE
130	30-Oct-18	BANGALORE	66	HOSKOTE 220 - PILAGUMPA	PILAGUMPA	12:30	13:05	0:35	MAIN SUPPLY FAILURE
131	30-Oct-18	BANGALORE	66	HOSKOTE - VOLVO	VOLVO, NANDAGUDI	12:30	13:07	0:37	MAIN SUPPLY FAILURE
132	30-Oct-18	BANGALORE	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI	6:51	6:55	0:04	LINE FAULT
133	30-Oct-18	BANGALORE	66	HV2	SOMAYAJJANAHALLI	12:02	12:53	0:50	LINE CLEAR AVAILED
134	30-Oct-18	BANGALORE	66	HV2	YEDUMADU	12:50	13:25	0:35	LINE CLEAR AVAILED
135	30-Oct-18	BANGALORE	66	HV2	HONNIGANAHALLI	15:20	16:20	1:00	LINE CLEAR AVAILED
136	30-Oct-18	BANGALORE	66	HV2	HONNIGANAHALLI	5:45	6:15	0:30	TRANSFORMER FAULT
137	30-Oct-18	BANGALORE	66	HOSKOTE 220 - BOODIGERE	BOODIGERE	8:24	10:36	2:11	MAIN SUPPLY FAILURE
138	30-Oct-18	BANGALORE	66	HOSKOTE 220 - BOODIGERE	BOODIGERE	12:30	13:05	0:35	MAIN SUPPLY FAILURE
139	30-Oct-18	BANGALORE	66	BOODIGERE - HOSKOTE 220	BOODIGERE	13:05	15:20	2:15	LINE CLEAR AVAILED
140	31-Oct-18	BANGALORE	66	HV4	A STATION 66	5:48	5:53	0:04	LINE CLEAR AVAILED
141	31-Oct-18	BANGALORE	66	AUSTIN TOWN - KORMANGALA	KORMANGALA	14:59	15:24	0:25	LINE FAULT
142	31-Oct-18	BANGALORE	66	HV2	DEVARABISANAHALLI	11:31	11:45	0:13	LINE CLEAR AVAILED
143	31-Oct-18	BANGALORE	66	HV2	DEVARABISANAHALLI	14:20	14:33	0:13	LINE CLEAR AVAILED
144	31-Oct-18	BANGALORE	66	HV1	BANASAWADI	11:49	13:35	1:46	LINE CLEAR AVAILED
145	31-Oct-18	BANGALORE	66	HV3	BANASAWADI	13:33	14:35	1:02	LINE CLEAR AVAILED
146	31-Oct-18	BANGALORE	66	HEBBAL 220 - LR BANDE	LR BANDE	11:51	15:00	3:09	LINE CLEAR AVAILED
147	31-Oct-18	BANGALORE	66	HV1	LR BANDE	11:51	15:07	3:16	LINE CLEAR AVAILED
148	31-Oct-18	BANGALORE	66	HV2	LR BANDE	11:51	15:07	3:16	LINE CLEAR AVAILED
149	31-Oct-18	BANGALORE	66	NRS 220 - VIJAY NGR MY2	VIJAYANAGAR	5:53	6:21	0:27	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
150	31-Oct-18	BANGALORE	66	HV1	VIJAYANAGAR	5:53	6:21	0:27	MAIN SUPPLY FAILURE
151	31-Oct-18	BANGALORE	66	HV1	TK HALLI 220	13:45	13:53	0:08	LINE CLEAR AVAILED
152	31-Oct-18	BANGALORE	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	6:54	7:15	0:21	MAIN SUPPLY FAILURE
153	31-Oct-18	BANGALORE	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	6:54	7:16	0:22	MAIN SUPPLY FAILURE
154	31-Oct-18	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	6:54	7:22	0:28	MAIN SUPPLY FAILURE
155	31-Oct-18	BANGALORE	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	6:54	7:20	0:26	MAIN SUPPLY FAILURE
156	31-Oct-18	BANGALORE	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	6:54	7:17	0:23	MAIN SUPPLY FAILURE
157	31-Oct-18	BANGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	6:54	7:18	0:24	MAIN SUPPLY FAILURE
158	31-Oct-18	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	6:54	7:14	0:20	MAIN SUPPLY FAILURE
159	31-Oct-18	BANGALORE	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	6:54	7:20	0:26	MAIN SUPPLY FAILURE
160	31-Oct-18	BANGALORE	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	6:54	7:15	0:21	MAIN SUPPLY FAILURE
161	31-Oct-18	BANGALORE	220	HV1	CHINTAMANI 220	6:54	7:12	0:18	MAIN SUPPLY FAILURE
162	31-Oct-18	BANGALORE	220	HV2	CHINTAMANI 220	6:54	7:12	0:18	MAIN SUPPLY FAILURE
163	31-Oct-18	BANGALORE	220	HV3	CHINTAMANI 220	6:54	7:12	0:18	MAIN SUPPLY FAILURE
164	31-Oct-18	BANGALORE	220	CHINTAMANI 220 - PGCIL 1	CHINTAMANI 220	6:54	7:12	0:18	MAIN SUPPLY FAILURE
165	31-Oct-18	BANGALORE	220	CHINTAMANI 220 - PGCIL 2	CHINTAMANI 220	6:54	7:12	0:18	MAIN SUPPLY FAILURE
166	31-Oct-18	BANGALORE	66	KOLAR 220 - BANGARPET 1	BANGARPET	6:54	7:25	0:31	MAIN SUPPLY FAILURE
167	31-Oct-18	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	6:54	7:25	0:31	MAIN SUPPLY FAILURE
168	31-Oct-18	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI, NARASAPURA	6:54	7:25	0:31	MAIN SUPPLY FAILURE
169	31-Oct-18	BANGALORE	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	6:54	7:25	0:31	MAIN SUPPLY FAILURE
170	31-Oct-18	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	6:54	7:25	0:31	MAIN SUPPLY FAILURE
171	31-Oct-18	BANGALORE	66	KOLAR 220 - DALASNUR	MALLASANDRA, DRDO (EHT), DAALSNUR	6:54	7:25	0:31	MAIN SUPPLY FAILURE
172	31-Oct-18	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	6:54	7:25	0:31	MAIN SUPPLY FAILURE
173	31-Oct-18	BANGALORE	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	6:54	7:25	0:31	MAIN SUPPLY FAILURE
174	31-Oct-18	BANGALORE	220	KOLAR 220 - PGCIL 1	KOLAR 220	6:54	7:15	0:21	MAIN SUPPLY FAILURE
175	31-Oct-18	BANGALORE	220	KOLAR 220 - PGCIL 2	KOLAR 220	6:54	7:15	0:21	MAIN SUPPLY FAILURE
176	31-Oct-18	BANGALORE	220	KOLAR 220 - MALUR 1	MALUR 220	6:54	7:15	0:21	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
177	31-Oct-18	BANGALORE	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	6:54	7:15	0:21	MAIN SUPPLY FAILURE
178	31-Oct-18	BANGALORE	220	HV1	KOLAR 220	6:54	7:20	0:26	MAIN SUPPLY FAILURE
179	31-Oct-18	BANGALORE	220	HV2	KOLAR 220	6:54	7:20	0:26	MAIN SUPPLY FAILURE
180	31-Oct-18	BANGALORE	220	HV3	KOLAR 220	6:54	7:20	0:26	MAIN SUPPLY FAILURE
181	31-Oct-18	BANGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	6:54	7:34	0:40	MAIN SUPPLY FAILURE
182	31-Oct-18	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	6:54	7:34	0:40	MAIN SUPPLY FAILURE
183	31-Oct-18	BANGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	6:54	7:34	0:40	MAIN SUPPLY FAILURE
184	31-Oct-18	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT)	6:54	7:34	0:40	MAIN SUPPLY FAILURE
185	31-Oct-18	BANGALORE	66	MALUR 220 - MALUR 66	MALUR 66	6:54	7:34	0:40	MAIN SUPPLY FAILURE
186	31-Oct-18	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	6:54	7:30	0:36	MAIN SUPPLY FAILURE
187	31-Oct-18	BANGALORE	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	6:54	7:25	0:31	MAIN SUPPLY FAILURE
188	31-Oct-18	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	6:54	7:25	0:31	MAIN SUPPLY FAILURE
189	31-Oct-18	BANGALORE	220	HV1	SARJAPURA 220	6:54	7:20	0:26	MAIN SUPPLY FAILURE
190	31-Oct-18	BANGALORE	220	HV2	SARJAPURA 220	6:54	7:20	0:26	MAIN SUPPLY FAILURE
191	31-Oct-18	BANGALORE	220	HV1	MALUR 220	6:54	7:34	0:40	MAIN SUPPLY FAILURE
192	31-Oct-18	BANGALORE	220	HV2	MALUR 220	6:54	7:34	0:40	MAIN SUPPLY FAILURE
193	31-Oct-18	BANGALORE	66	HV1	BANGARPET	11:03	11:24	0:21	LINE CLEAR AVAILED
194	31-Oct-18	BANGALORE	66	HV2	DODDABELAVANGALA	15:05	15:15	0:10	TRANSFORMER FAULT
195	31-Oct-18	BANGALORE	66	HV1	DEVANAHALLI	14:16	14:25	0:08	TRANSFORMER FAULT
196	31-Oct-18	BANGALORE	66	HULLENAHALLI - KUDUR	KUDUR	14:04	15:43	1:38	LINE CLEAR AVAILED
197	31-Oct-18	BANGALORE	66	KGF - KYASAMBALLI	KYASAMBALLI, ANDERSONPET, DODDAKARI	6:54	7:50	0:56	LINE FAULT
198	31-Oct-18	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	13:10	13:35	0:25	LOAD CURTAILMENT
199	31-Oct-18	BANGALORE	66	HV1	SM MANGALA	6:16	6:26	0:09	TRANSFORMER FAULT
200	31-Oct-18	BANGALORE	66	HV1	SOMAYAJJANAHALLI	11:30	13:00	1:29	LINE CLEAR AVAILED
201	31-Oct-18	BANGALORE	66	HV2	KYALANUR	13:25	14:00	0:34	LINE CLEAR AVAILED
202	31-Oct-18	BANGALORE	66	HV2	VOLVO	14:32	17:28	2:55	LINE CLEAR AVAILED
203	1-Nov-18	BANGALORE	66	HSR LAYOUT 220 - KORMANGALA	KORMANGALA	13:01	13:03	0:01	LINE CLEAR AVAILED
204	1-Nov-18	BANGALORE	66	HV1	KORMANGALA	13:01	13:03	0:01	MAIN SUPPLY FAILURE
205	1-Nov-18	BANGALORE	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	3:36	3:56	0:20	LINE FAULT
206	1-Nov-18	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	3:56	4:16	0:20	LINE FAULT
207	1-Nov-18	BANGALORE	66	HV3	CB PURA I/A	12:41	13:46	1:05	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
208	1-Nov-18	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE1	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	5:17	5:22	0:04	LINE FAULT
209	1-Nov-18	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE1	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	5:49	5:54	0:05	LINE FAULT
210	1-Nov-18	BANGALORE	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	15:46	21:20	5:33	LINE FAULT
211	1-Nov-18	BANGALORE	66	GANJIGUNTE - CHINTAMANI 1	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	5:17	5:23	0:05	LINE FAULT
212	1-Nov-18	BANGALORE	66	GANJIGUNTE - CHINTAMANI 2	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	5:17	5:23	0:05	LINE FAULT
213	1-Nov-18	BANGALORE	66	GANJIGUNTE - CHINTAMANI 1	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	5:49	6:00	0:10	LINE FAULT
214	1-Nov-18	BANGALORE	66	GANJIGUNTE - CHINTAMANI 2	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	5:49	6:00	0:10	LINE FAULT
215	1-Nov-18	BANGALORE	66	DABUSPET 220 - TEMAGONDALU	TEMAGONDALU, T BEGUR	6:30	6:48	0:18	LINE FAULT
216	1-Nov-18	BANGALORE	66	KOLAR 220 - NANAGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	0:00	0:08	0:08	LINE FAULT
217	1-Nov-18	BANGALORE	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	0:08	0:18	0:09	MAIN SUPPLY FAILURE
218	1-Nov-18	BANGALORE	220	KOLAR 220 - BANGARPET RAILWAYS 2	BANGARPET RAILWAYS 2	12:07	12:12	0:05	LINE CLEAR AVAILED
219	2-Nov-18	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	6:22	6:31	0:08	LINE FAULT
220	2-Nov-18	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	17:03	17:12	0:09	LINE FAULT
221	2-Nov-18	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	17:12	18:16	1:03	LINE FAULT
222	2-Nov-18	BANGALORE	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	7:56	8:05	0:08	LINE FAULT
223	2-Nov-18	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	11:32	11:40	0:07	LINE FAULT
224	2-Nov-18	BANGALORE	66	MALUR 220 - HOSKOTE 2	MALUE I/A, JADIGENAHALLI	15:39	15:46	0:07	LINE FAULT
225	2-Nov-18	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD	5:12	5:42	0:30	LINE FAULT
226	2-Nov-18	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD	6:03	6:45	0:42	LINE FAULT
227	2-Nov-18	BANGALORE	66	HV2	VIJAYANAGARA	16:58	17:02	0:03	LOAD CHANGEOVER
228	2-Nov-18	BANGALORE	66	HV1	TK HALLI 220	13:22	14:07	0:45	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
229	2-Nov-18	BANGALORE	66	TK HALLI 220 - IGGALUR	IGGALUR, AKKURMOLE	17:07	17:15	0:08	LINE FAULT
230	2-Nov-18	BANGALORE	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	7:46	7:57	0:10	LINE FAULT
231	2-Nov-18	BANGALORE	66	HSR LAYOUT 220 - KORMANGALA	KORMANGALA, K & C VALLEY, NAL (EHT)	11:36	12:38	1:01	LINE FAULT
232	2-Nov-18	BANGALORE	66	HV1	KORMANGALA	11:36	12:00	0:23	MAIN SUPPLY FAILURE
233	2-Nov-18	BANGALORE	220	HAL 220 - EDC 220	EDC 220	15:37	16:31	0:53	LINE FAULT
234	2-Nov-18	BANGALORE	220	EDC 220 - HAL 220	EDC 220	15:37	16:31	0:53	LINE FAULT
235	2-Nov-18	BANGALORE	220	HV1	EDC 220	15:37	16:34	0:57	TRANSFORMER FAULT
236	2-Nov-18	BANGALORE	220	HV2	EDC 220	15:37	16:34	0:57	TRANSFORMER FAULT
237	2-Nov-18	BANGALORE	220	EDC 220 - A STATION 220	A STATION 220	15:37	15:41	0:04	MAIN SUPPLY FAILURE
238	2-Nov-18	BANGALORE	66	HV1	EDC 220	15:37	16:35	0:58	MAIN SUPPLY FAILURE
239	2-Nov-18	BANGALORE	66	HV2	EDC 220	15:37	16:35	0:57	MAIN SUPPLY FAILURE
240	2-Nov-18	BANGALORE	66	EDC 220 - B STATION	B STATION	15:37	16:25	0:47	MAIN SUPPLY FAILURE
241	2-Nov-18	BANGALORE	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN, AMARJYOTHI, KORMANGALA	15:37	16:37	1:00	MAIN SUPPLY FAILURE
242	2-Nov-18	BANGALORE	66	A STATION 220 - VICTORIA HOSPITAL	VICTORIA HOSPITAL	15:37	15:43	0:05	MAIN SUPPLY FAILURE
243	2-Nov-18	BANGALORE	66	A STATION 220 - A STATION 1	A STATION 66	15:37	15:41	0:04	MAIN SUPPLY FAILURE
244	2-Nov-18	BANGALORE	66	EDC 220 - BMTC	BMTC	15:37	16:38	1:01	MAIN SUPPLY FAILURE
245	2-Nov-18	BANGALORE	66	HV1	A STATION 66	15:37	15:41	0:04	MAIN SUPPLY FAILURE
246	2-Nov-18	BANGALORE	66	HV2	A STATION 66	15:37	15:41	0:04	MAIN SUPPLY FAILURE
247	2-Nov-18	BANGALORE	66	HV1	AMARJYOTHI	15:37	16:17	0:40	MAIN SUPPLY FAILURE
248	2-Nov-18	BANGALORE	66	HV2	KORMANGALA	15:37	16:12	0:34	MAIN SUPPLY FAILURE
249	3-Nov-18	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	9:56	10:02	0:06	LINE FAULT
250	3-Nov-18	BANGALORE	66	HV1	CHANDAPURA	12:07	12:08	0:01	LINE CLEAR AVAILED
251	3-Nov-18	BANGALORE	66	HV2	CHANDAPURA	12:07	12:08	0:01	LINE CLEAR AVAILED
252	3-Nov-18	BANGALORE	66	HV1	JIGANI 66	10:02	18:12	8:09	LINE CLEAR AVAILED
253	3-Nov-18	BANGALORE	66	JIGANI 66 - JIGANI 220	JIGANI 66	10:02	19:27	9:24	LINE CLEAR AVAILED
254	3-Nov-18	BANGALORE	220	NELAMANGALA 400 - YELAHANKA 220	YELAHANKA 220	10:52	10:59	0:06	LOAD CURTAILMENT
255	3-Nov-18	BANGALORE	220	BUS COUPLER	YELAHANKA 220	10:06	10:59	0:53	LINE FAULT
256	3-Nov-18	BANGALORE	66	HV1	YELAHANKA 220	10:52	10:59	0:07	MAIN SUPPLY FAILURE
257	3-Nov-18	BANGALORE	66	YELAHANKA 220 - LINE 4	SAHAKARINAGAR, WHEEL&AXEL(EHT)	10:52	10:59	0:07	MAIN SUPPLY FAILURE
258	3-Nov-18	BANGALORE	66	YELAHANKA 220 - LINE 6	SOLADEVANAHALLI	10:52	10:59	0:07	MAIN SUPPLY FAILURE
259	3-Nov-18	BANGALORE	66	YELAHANKA 220 - LINE 8	RAJANAKUNTE	10:52	10:59	0:07	MAIN SUPPLY FAILURE
260	3-Nov-18	BANGALORE	66	HV1	ABBIGERE	10:02	10:06	0:04	LINE CLEAR AVAILED
261	3-Nov-18	BANGALORE	66	HV2	ABBIGERE	10:56	10:58	0:02	LINE CLEAR AVAILED
262	3-Nov-18	BANGALORE	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	8:02	8:10	0:08	LOAD CHANGEORVER
263	3-Nov-18	BANGALORE	66	HV1	SIR MV LAYOUT	12:40	12:45	0:05	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
264	3-Nov-18	BANGALORE	66	HV1	CHANDRA LAYOUT	10:18	10:21	0:02	LINE CLEAR AVAILED
265	3-Nov-18	BANGALORE	66	HV2	CHANDRA LAYOUT	13:32	13:35	0:02	LINE CLEAR AVAILED
266	3-Nov-18	BANGALORE	66	HV2	VIJAYANAGARA	21:39	21:45	0:06	LOAD CHANGEOVER
267	3-Nov-18	BANGALORE	66	HV2	TAVAREKERE	10:31	10:33	0:01	LINE CLEAR AVAILED
268	3-Nov-18	BANGALORE	66	RBI - SOMANAHALLI 220	RBI	8:10	8:20	0:10	LOAD CHANGEOVER
269	3-Nov-18	BANGALORE	220	SRS PEENYA 220 - HEBBAL 220	HEBBAL 220, CPRI(EHT)	10:50	11:04	0:14	LOAD CURTAILMENT
270	3-Nov-18	BANGALORE	66	HEBBAL 220 - BANASWADI	BANASWADI	10:50	11:05	0:15	MAIN SUPPLY FAILURE
271	3-Nov-18	BANGALORE	66	HEBBAL 220 - C STATION 1 & 2	C STATION	10:50	11:05	0:15	MAIN SUPPLY FAILURE
272	3-Nov-18	BANGALORE	66	HEBBAL 220 - IISC	IISC	10:50	11:05	0:15	MAIN SUPPLY FAILURE
273	3-Nov-18	BANGALORE	66	HEBBAL 220 - LR BANDE	LR BANDE	10:50	11:05	0:15	MAIN SUPPLY FAILURE
274	3-Nov-18	BANGALORE	66	HV1	HEBBAL 220	10:50	11:05	0:15	MAIN SUPPLY FAILURE
275	3-Nov-18	BANGALORE	66	HV2	HEBBAL 220	10:50	11:05	0:15	MAIN SUPPLY FAILURE
276	3-Nov-18	BANGALORE	66	HV3	HEBBAL 220	10:50	11:05	0:15	MAIN SUPPLY FAILURE
277	3-Nov-18	BANGALORE	66	HAL 220 - ADUGODI 1	LEELA VENTURE	13:19	14:11	0:51	LINE FAULT
278	3-Nov-18	BANGALORE	66	HAL 220 - ADUGODI 1	LEELA VENTURE	14:13	14:19	0:06	HAND TRIPPED
279	3-Nov-18	BANGALORE	66	HAL 220 - ADUGODI 1	LEELA VENTURE	14:37	15:45	1:07	LINE CLEAR AVAILED
280	3-Nov-18	BANGALORE	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI, LEELA VENTURE	14:49	14:58	0:08	LOAD CHANGEOVER
281	3-Nov-18	BANGALORE	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI, LEELA VENTURE	14:59	15:13	0:14	LINE FAULT
282	3-Nov-18	BANGALORE	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI, LEELA VENTURE	16:29	17:09	0:39	LINE CLEAR AVAILED
283	3-Nov-18	BANGALORE	66	HV1	LEELA VENTURE	13:19	14:30	1:10	MAIN SUPPLY FAILURE
284	3-Nov-18	BANGALORE	66	HV1	LEELA VENTURE	14:37	15:45	1:07	MAIN SUPPLY FAILURE
285	3-Nov-18	BANGALORE	66	HV2	LEELA VENTURE	14:49	15:13	0:23	MAIN SUPPLY FAILURE
286	3-Nov-18	BANGALORE	66	HV2	LEELA VENTURE	16:29	17:09	0:39	MAIN SUPPLY FAILURE
287	3-Nov-18	BANGALORE	66	HV1	AMARJYOTHI	11:16	11:26	0:09	LINE CLEAR AVAILED
288	3-Nov-18	BANGALORE	66	HV1	AMARJYOTHI	13:19	14:21	1:02	MAIN SUPPLY FAILURE
289	3-Nov-18	BANGALORE	66	HV2	AMARJYOTHI	14:59	15:13	0:14	MAIN SUPPLY FAILURE
290	3-Nov-18	BANGALORE	66	HV1	AMARJYOTHI	14:37	14:55	0:17	MAIN SUPPLY FAILURE
291	3-Nov-18	BANGALORE	66	HV2	AMARJYOTHI	16:29	17:09	0:39	MAIN SUPPLY FAILURE
292	4-Nov-18	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	9:56	10:02	0:06	LINE FAULT
293	4-Nov-18	BANGALORE	66	HV1	CHANDAPURA	12:07	12:08	0:01	LINE CLEAR AVAILED
294	4-Nov-18	BANGALORE	66	HV2	CHANDAPURA	12:07	12:08	0:01	LINE CLEAR AVAILED
295	4-Nov-18	BANGALORE	66	HV1	JIGANI 66	10:02	18:12	8:09	LINE CLEAR AVAILED
296	4-Nov-18	BANGALORE	66	JIGANI 66 - JIGANI 220	JIGANI 66	10:02	19:27	9:24	LINE CLEAR AVAILED
297	4-Nov-18	BANGALORE	66	ANEKAL - YARANDANAHALLI	ANEKAL	10:30	10:50	0:20	LOAD CHANGEOVER
298	4-Nov-18	BANGALORE	66	ATTIBELE - ANEKAL	ANEKAL, SURYANAGAR	13:20	15:30	2:10	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
299	4-Nov-18	BANGALORE	66	ATTIBELE - SARJAPURA 220	ATTIBELE, ANEKAL, SURYANAGAR	12:45	13:20	0:35	LINE FAULT
300	4-Nov-18	BANGALORE	66	ATTIBELE - SARJAPURA 220	ATTIBELE	13:38	13:50	0:12	LINE FAULT
301	4-Nov-18	BANGALORE	66	ATTIBELE - SARJAPURA 220	ATTIBELE	15:15	15:20	0:05	LINE FAULT
302	4-Nov-18	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	5:45	5:52	0:07	LINE FAULT
303	4-Nov-18	BANGALORE	66	GANJIGUNTE - CHINTAMANI 2	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	5:45	5:52	0:07	LINE FAULT
304	4-Nov-18	BANGALORE	66	HV2	KEMBODI	19:15	19:53	0:38	LINE CLEAR AVAILED
305	4-Nov-18	BANGALORE	66	SURYANAGAR - YARANDANAHALLI 220	SURYANAGAR	10:33	10:53	0:20	LOAD CHANGEOVER
306	4-Nov-18	BANGALORE	66	HV1	SURYANAGAR	12:45	15:36	2:51	MAIN SUPPLY FAILURE
307	4-Nov-18	BANGALORE	66	YELAHANKA 220 - LINE 3	ATTUR YELAHANKA, ESCORTS (EHT), MANYATHA TECH PARK, ABBIGERE	9:09	9:47	0:37	LINE FAULT
308	4-Nov-18	BANGALORE	66	HV4	A STATION 66	11:08	11:31	0:22	LINE CLEAR AVAILED
309	4-Nov-18	BANGALORE	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	10:11	10:18	0:07	LOAD CHANGEOVER
310	4-Nov-18	BANGALORE	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	17:35	17:39	0:04	LOAD CHANGEOVER
311	4-Nov-18	BANGALORE	66	HV1	IISC	22:51	23:12	0:21	LINE CLEAR AVAILED
312	4-Nov-18	BANGALORE	66	HV1	REMCO	10:31	10:33	0:02	LOAD CHANGEOVER
313	4-Nov-18	BANGALORE	220	YARANDANAHALLI 220 - SOMANAHALLI 220	YARANDANAHALLI 220	10:58	15:23	4:25	LINE CLEAR AVAILED
314	4-Nov-18	BANGALORE	220	HV2	YARANDANAHALLI 220	10:45	15:24	4:39	MAIN SUPPLY FAILURE
315	4-Nov-18	BANGALORE	220	HV3	YARANDANAHALLI 220	10:45	15:24	4:39	MAIN SUPPLY FAILURE
316	4-Nov-18	BANGALORE	220	YARANDANAHALLI 220 - HOSUR 220	YARANDANAHALLI 220	12:33	13:07	0:34	LINE CLEAR AVAILED
317	4-Nov-18	BANGALORE	220	HV1	YARANDANAHALLI 220	12:28	13:08	0:40	LINE CLEAR AVAILED
318	4-Nov-18	BANGALORE	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BOMMASANDRA I/A, BIOCON (EHT)	10:25	10:35	0:10	LOAD CHANGEOVER
319	4-Nov-18	BANGALORE	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BOMMASANDRA I/A, BIOCON (EHT)	12:28	13:36	1:08	LINE CLEAR AVAILED
320	4-Nov-18	BANGALORE	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BOMMASANDRA I/A, BIOCON (EHT)	16:44	17:25	0:41	LINE CLEAR AVAILED
321	4-Nov-18	BANGALORE	66	YARANDANAHALLI 220 - JIGANI 66	JIGANI 220	12:32	12:50	0:17	LOAD CHANGEOVER
322	4-Nov-18	BANGALORE	66	HV1	YARANDANAHALLI 220	12:20	16:43	4:23	LINE CLEAR AVAILED
323	4-Nov-18	BANGALORE	66	HV2	YARANDANAHALLI 220	12:28	13:10	0:42	LINE CLEAR AVAILED
324	4-Nov-18	BANGALORE	66	HV3	YARANDANAHALLI 220	12:28	13:20	0:52	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
325	4-Nov-18	BANGALORE	66	YARANDANAHALLI 220 - TIMES OF INDIA(EHT)	TIMES OF INDIA(EHT)	10:45	15:34	4:49	MAIN SUPPLY FAILURE
326	4-Nov-18	BANGALORE	220	SOMANAHALLI 220 - YARANDANAHALLI 220	JIGANI 220	10:58	11:29	0:31	LINE CLEAR AVAILED
327	4-Nov-18	BANGALORE	66	HV1	JIGANI 220	10:58	11:29	0:31	MAIN SUPPLY FAILURE
328	4-Nov-18	BANGALORE	66	HV2	JIGANI 220	10:58	11:29	0:31	MAIN SUPPLY FAILURE
329	4-Nov-18	BANGALORE	66	HV1	JIGANI 220	12:32	12:50	0:17	MAIN SUPPLY FAILURE
330	4-Nov-18	BANGALORE	66	HV2	JIGANI 220	12:32	12:50	0:17	MAIN SUPPLY FAILURE
331	4-Nov-18	BANGALORE	66	JIGANI 220 - JIGANI 66	JIGANI 220	15:53	16:04	0:11	LOAD CHANGEOVER
332	4-Nov-18	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	5:15	5:40	0:25	LINE FAULT
333	5-Nov-18	BANGALORE	66	HV1	DABUS PET 220	12:45	12:50	0:04	LINE CLEAR AVAILED
334	5-Nov-18	BANGALORE	66	MALUR 220 - KGF 1	KYASAMBALLI, ANDERSONPET	15:07	15:42	0:34	LINE FAULT
335	5-Nov-18	BANGALORE	66	HV1	KYALANUR	15:21	16:04	0:43	LINE CLEAR AVAILED
336	5-Nov-18	BANGALORE	66	YEDUMADU - KANAKAPURA 220	YEDUMADU	16:30	16:35	0:05	LOAD CHANGEOVER
337	5-Nov-18	BANGALORE	66	KGF - KYASAMBALLI	KYASAMBALLI, ANDERSONPET	15:07	15:39	0:32	LINE FAULT
338	5-Nov-18	BANGALORE	66	HV1	ANJANAPURA	23:09	23:15	0:06	TRANSFORMER FAULT
339	5-Nov-18	BANGALORE	66	NRS 220 - VIJAY NGR MY1	VIJAYANAGARA	8:50	9:16	0:25	LINE FAULT
340	5-Nov-18	BANGALORE	66	RBI - SOMANAHALLI 220	RBI	16:10	16:15	0:05	LOAD CHANGEOVER
341	5-Nov-18	BANGALORE	66	RBI - ELITE PROMENEDE	RBI	9:15	9:20	0:05	LOAD CHANGEOVER
342	5-Nov-18	BANGALORE	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	7:25	7:30	0:05	LOAD CHANGEOVER
343	5-Nov-18	BANGALORE	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	16:25	16:30	0:05	LOAD CHANGEOVER
344	5-Nov-18	BANGALORE	66	HV2	RMV	9:45	9:48	0:02	LINE CLEAR AVAILED
345	5-Nov-18	BANGALORE	66	CHANDRA LAYOUT - MYSORE ROAD 2	VIJAYANAGARA	15:15	15:54	0:39	LINE CLEAR AVAILED
346	5-Nov-18	BANGALORE	66	HV1	VIJAYANAGARA	8:50	9:16	0:25	MAIN SUPPLY FAILURE
347	5-Nov-18	BANGALORE	66	HV1	VIJAYANAGARA	15:15	15:54	0:39	MAIN SUPPLY FAILURE
348	5-Nov-18	BANGALORE	66	HV1	REMCO	10:33	10:37	0:04	LOAD CHANGEOVER
349	5-Nov-18	BANGALORE	66	HV1	REMCO	17:08	17:14	0:06	LOAD CHANGEOVER
350	5-Nov-18	BANGALORE	220	BIDADI 220 - SOMANAHALLI 1	SOMANAHALLI 220	7:06	8:10	1:03	LINE FAULT
351	5-Nov-18	BANGALORE	220	BIDADI 220 - SOMANAHALLI 2	SOMANAHALLI 220	7:06	8:13	1:06	LINE FAULT
352	5-Nov-18	BANGALORE	220	HV1	SOMANAHALLI 220	7:06	8:40	1:33	MAIN SUPPLY FAILURE
353	5-Nov-18	BANGALORE	220	HV2	SOMANAHALLI 220	7:06	8:41	1:34	TRANSFORMER FAULT
354	5-Nov-18	BANGALORE	220	HV3	SOMANAHALLI 220	7:06	8:43	1:36	TRANSFORMER FAULT
355	5-Nov-18	BANGALORE	66	SOMANAHALLI 220 - JIGANI 1	SOUTH CITY	7:06	7:46	0:39	MAIN SUPPLY FAILURE
356	5-Nov-18	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	7:06	8:51	1:44	MAIN SUPPLY FAILURE
357	5-Nov-18	BANGALORE	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE	7:06	9:20	2:13	MAIN SUPPLY FAILURE
358	5-Nov-18	BANGALORE	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	7:06	7:42	0:35	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
359	5-Nov-18	BANGALORE	66	SOMANAHALLI 220 - SUBRAMANYAPURA 2	SHOBHA FOREST	7:06	9:00	1:53	MAIN SUPPLY FAILURE
360	5-Nov-18	BANGALORE	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	7:06	9:40	2:33	MAIN SUPPLY FAILURE
361	5-Nov-18	BANGALORE	66	SOMANAHALLI 220 - KANAKAPURA 1	YEDUMADU, HANUMANTHNAGAR	7:06	9:06	1:59	MAIN SUPPLY FAILURE
362	5-Nov-18	BANGALORE	66	BRIGADE MEADOWS - SHOBHA FOREST	BRIGADE MEADOWS	7:06	18:08	11:01	MAIN SUPPLY FAILURE
363	5-Nov-18	BANGALORE	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	7:06	7:43	0:36	MAIN SUPPLY FAILURE
364	5-Nov-18	BANGALORE	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	16:05	16:15	0:10	LOAD CHANGEOVER
365	5-Nov-18	BANGALORE	66	ISKON - SUBRAMANYAPURA 220	ISKON	17:25	17:30	0:05	LOAD CHANGEOVER
366	5-Nov-18	BANGALORE	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	17:24	17:29	0:05	LOAD CHANGEOVER
367	5-Nov-18	BANGALORE	66	SHOBHA FOREST - SUBRAMANYAPURA 220	SHOBHA FOREST	18:06	18:08	0:02	LOAD CHANGEOVER
368	30-Oct-18	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPURA_110,MANVI_110	19:01	19:04	0:03	LINE FAULT
369	30-Oct-18	GULBARGA	110	KAVITHAL-GMSH	KAVITAL_110	10:38	17:47	7:09	LINE CLEAR AVAILED
370	30-Oct-18	GULBARGA	110	HANUMASAGAR-KUSTAGI	HANUMASAGAR_110,HANUMANAL_110, HIREGONNAGAR_110	10:52	17:28	6:36	NBFC ISSUED
371	30-Oct-18	GULBARGA	110	BHALKI-LADHA	LADHA_110	17:04	17:17	0:13	LINE FAULT
372	30-Oct-18	GULBARGA	110	BHALKI-MGSSK	MGSSK_IPP	18:20	18:45	0:25	LINE FAULT
373	30-Oct-18	GULBARGA	110	SANTAPUR-RNW_SLR	SANTHAPUR_110	10:48	11:00	0:12	LINE FAULT
374	30-Oct-18	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	10:40	10:50	0:10	LINE FAULT
375	30-Oct-18	GULBARGA	110	HV2	KOLHAR_110	10:55	12:00	1:05	LINE CLEAR AVAILED
376	30-Oct-18	GULBARGA	110	GURUGUNTA-KHEL_IPP,LJVL_IPP	KHEL_IPP,LJVL_IPP	10:15	16:00	5:45	LINE CLEAR AVAILED
377	31-Oct-18	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,JANAWADA_110. DONGRAGOA_110,DIGGI_110	12:03	12:07	0:04	LINE FAULT
378	31-Oct-18	GULBARGA	110	HV2	KAMPLI_110	9:23	9:34	0:11	TRANSFORMER FAULT
379	31-Oct-18	GULBARGA	110	HV1	LINGASUGUR_220	7:20	7:35	0:15	TRANSFORMER FAULT
380	31-Oct-18	GULBARGA	110	HV2	LINGASUGUR_220	7:20	7:45	0:25	TRANSFORMER FAULT
381	31-Oct-18	GULBARGA	110	MALLAT-MADALAPUR	MADALAPUR_110	3:18	3:24	0:06	LINE FAULT
382	31-Oct-18	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_GLB_110, BTPS WATER WORKS	20:03	20:17	0:14	LINE FAULT
383	31-Oct-18	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPURA_110,KURDICROSS_1 10,MANVI_110	21:51	22:01	0:10	LINE FAULT
384	31-Oct-18	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPURA_110,KURDICROSS_1 10,MANVI_110	23:08	23:14	0:06	LINE FAULT
385	1-Nov-18	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPURA_110,KURDICROSS_1 10,MANVI_110	19:39	19:48	0:09	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
386	1-Nov-18	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPURA_110,KURDICROSS_110,MANVI_110	20:25	20:34	0:09	LINE FAULT
387	1-Nov-18	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	20:26	23:59	3:33	LINE FAULT
388	1-Nov-18	GULBARGA	110	SINDHANOOR-RAICHUR1	BYAGAWAT_110,VALKAMDINNI_110	4:24	15:55	11:31	LINE FAULT
389	1-Nov-18	GULBARGA	110	SINDHANOOR-PGLR_WIND	SIDHANOOR_220	19:07	20:00	0:53	LINE FAULT
390	1-Nov-18	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI_110,	18:15	18:26	0:11	LOAD CURTAILMENT
391	1-Nov-18	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110	18:20	19:17	0:57	LOAD CURTAILMENT
392	1-Nov-18	GULBARGA	110	RAICHUR-SHAHABAD1	DEODURGA_110,GABUR_110	18:20	18:58	0:38	LOAD CURTAILMENT
393	1-Nov-18	GULBARGA	110	RAICHUR-SINDHANOOR1	BYAGAWAT_110,VALKAMDINNI_110	22:45	22:56	0:11	LINE FAULT
394	1-Nov-18	GULBARGA	110	HV1	HANUMASAGAR_110	10:00	11:30	1:30	LINE CLEAR AVAILED
395	1-Nov-18	GULBARGA	110	BHALKI-HALBARGA	BHALKI_110-LADHA_110-MGSSK_IPP-BSSK_IPP	3:55	4:10	0:15	LINE FAULT
396	1-Nov-18	GULBARGA	110	BHALKI-BSSK	BSSK_IPP	3:55	9:45	5:50	LINE FAULT
397	1-Nov-18	GULBARGA	110	HV1	BYAGAWAT_110	15:30	16:05	0:35	LINE CLEAR AVAILED
398	1-Nov-18	GULBARGA	110	YELBURGA-PP_IPP	PP_IPP	8:15	8:25	0:10	LINE FAULT
399	1-Nov-18	GULBARGA	110	SANTHAPUR-HALBARGA	SANTHAPUR_110,DONGARGAON_110, KAMALANAGAR_110	17:40	22:50	5:10	LINE CLEAR AVAILED
400	1-Nov-18	GULBARGA	110	SANTHAPUR-CLEANSOLAR	SANTHAPUR_110	18:00	22:50	4:50	LINE CLEAR AVAILED
401	1-Nov-18	GULBARGA	66	LV1	ITTAGI_220	8:15	8:20	0:05	TRANSFORMER FAULT
402	1-Nov-18	GULBARGA	66	ITTAGI-HIRAHADAGALLI2	HIREHADAGALI_66,GIRIYAPURA_66, SOVENAHALLI_66,MAGALA_66, TUNGA_IPP	8:15	8:26	0:11	LINE FAULT
403	2-Nov-18	GULBARGA	110	WADAGERA-RENWSOLR	WADAGERA_110	2:34	2:40	0:06	LINE FAULT
404	2-Nov-18	GULBARGA	110	WADAGERA-RENWSOLR	WADAGERA_110	2:40	8:39	5:59	LINE FAULT
405	2-Nov-18	GULBARGA	110	RAICHUR-SINDHANOOR	SIRWAR_110,ALKOD_110,BYAGAWAT_110,VALKAMDINI_110	6:35	7:30	0:55	LINE FAULT
406	2-Nov-18	GULBARGA	110	RAICHUR-SINDHANOOR1	ALKOD_11-,SIRWAR_110, BYAGAWAT_110, VALKAMDINI_110	6:35	7:30	0:55	LINE FAULT
407	2-Nov-18	GULBARGA	110	HV4	YELBURGA_110	6:46	7:02	0:16	TRANSFORMER FAULT
408	2-Nov-18	GULBARGA	110	HV1	LINGASUGUR_220	7:26	7:40	0:14	TRANSFORMER FAULT
409	2-Nov-18	GULBARGA	110	WADAGERA-RENWSOLR	WADAGERA_110	8:40	14:00	5:20	LINE CLEAR AVAILED
410	2-Nov-18	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	12:10	12:15	0:05	LINE FAULT
411	2-Nov-18	GULBARGA	110	HV1	RAICHUR_220	15:03	15:06	0:03	TRANSFORMER FAULT
412	2-Nov-18	GULBARGA	110	HV1	RAICHUR_220	15:03	15:06	0:03	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
413	2-Nov-18	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGAON_110,MARGUTTI_110	18:05	18:21	0:16	LINE FAULT
414	2-Nov-18	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	20:10	20:32	0:22	LINE FAULT
415	2-Nov-18	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110, MANVI_110	22:54	23:00	0:06	LINE FAULT
416	3-Nov-18	GULBARGA	220	RTPS-RAICHUR1	RAICHUR_220	0:00	10:32	10:32	HAND TRIPPED
417	3-Nov-18	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARAGUTTI_110	11:39	11:46	0:07	LINE FAULT
418	3-Nov-18	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	10:49	11:01	0:12	LINE FAULT
419	3-Nov-18	GULBARGA	110	BETAGERA-DAMBAL	BETAGERA_110	10:55	13:10	2:15	LINE CLEAR AVAILED
420	3-Nov-18	GULBARGA	110	SANTHAPUR-RNWSLR	SANTHAPUR_110	10:48	10:50	0:02	LINE FAULT
421	3-Nov-18	GULBARGA	110	MALLAT-MADALAPUR	MADALAPUR_110	19:52	20:13	0:21	LINE FAULT
422	4-Nov-18	GULBARGA	220	HV1	KUSTAGI_220	12:09	12:23	0:14	TRANSFORMER FAULT
423	4-Nov-18	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	19:28	19:50	0:22	LINE FAULT
424	4-Nov-18	GULBARGA	220	HV1	KUSTAGI_220	19:50	19:55	0:05	LOAD CHANGEOVER
425	4-Nov-18	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	20:20	20:33	0:13	LINE FAULT
426	4-Nov-18	GULBARGA	110	SANTHAPUR-CSPSLR,WARDHASLR,RNWSLR	SANTHAPUR_110	11:41	13:18	1:37	LINE CLEAR AVAILED
427	4-Nov-18	GULBARGA	110	PDHALLI-CLNSLR	PDHALLI_110	7:31	7:46	0:15	LINE FAULT
428	4-Nov-18	GULBARGA	110	HV1	RAICHUR_220	0:23	0:34	0:11	TRANSFORMER FAULT
429	4-Nov-18	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGWA T_110,VALKAMDINI_110	21:18	21:44	0:26	LINE FAULT
430	4-Nov-18	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGWA T_110,VALKAMDINI_110	22:53	23:02	0:09	LINE FAULT
431	4-Nov-18	GULBARGA	110	MALLAT-MADALAPUR	MADALAPUR_110	5:31	5:39	0:08	LINE FAULT
432	4-Nov-18	GULBARGA	110	HALBARGA-KOLHAR1,2	KOLHAR_110	11:01	12:30	1:29	LINE CLEAR AVAILED
433	4-Nov-18	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,JANAWADA_110, DONGRAGOA_110,DIGGI_110	11:06	11:37	0:31	LINE FAULT
434	4-Nov-18	GULBARGA	110	HV3	KOLHAR_110	10:48	13:20	2:32	TRANSFORMER FAULT
435	4-Nov-18	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	10:48	13:20	2:32	LINE CLEAR AVAILED
436	4-Nov-18	GULBARGA	110	KUSTAGI-YELBURGA,ILKAL1,2	YELBURGA_110,ILKAL_110	12:10	12:25	0:15	LINE FAULT
437	4-Nov-18	GULBARGA	110	KUSTAGI-YELBURGA,ILKAL1,2	YELBURGA_110,ILKAL_110	12:30	13:20	0:50	LINE FAULT
438	4-Nov-18	GULBARGA	110	KUSTAGI-KANAKAGIRI	KANAKAGIRI_110,GANDAL_110	12:50	13:14	0:24	LINE FAULT
439	4-Nov-18	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110	19:30	23:59	4:29	LINE FAULT
440	4-Nov-18	GULBARGA	110	KUSTAGI-ILKAL1,2	ILKAL_110	19:30	19:50	0:20	LINE FAULT
441	4-Nov-18	GULBARGA	110	KUSTAGI-KANAKAGIRI	KANAKAGIRI_110,GANDAL_110	19:30	19:50	0:20	LINE FAULT
442	5-Nov-18	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220	0:40	1:06	0:26	LINE FAULT
443	5-Nov-18	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	1:48	2:02	0:14	LINE FAULT
444	5-Nov-18	GULBARGA	220	HV1,LV1	HALBARGA_220	19:07	19:13	0:06	TRANSFORMER FAULT
445	5-Nov-18	GULBARGA	110	JANAWADA-SANTHAPUR	JANAWADA_110	0:53	1:01	0:08	LINE FAULT
446	5-Nov-18	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	11:15	11:39	0:24	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
447	5-Nov-18	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPURA_110,MANVI_110	1:26	1:30	0:04	LINE FAULT
448	5-Nov-18	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPURA_110,MANVI_110	6:04	6:38	0:34	LINE FAULT
449	5-Nov-18	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPURA_110,MANVI_110	1:56	2:00	0:04	LINE FAULT
450	5-Nov-18	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPURA_110,MANVI_110	3:35	3:38	0:03	LINE FAULT
451	5-Nov-18	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_GLB_110	10:37	10:46	0:09	LINE FAULT
452	5-Nov-18	GULBARGA	110	SINDHANOOR-FUTURE-1	TURVIHAL_110	12:13	12:18	0:05	LINE FAULT
453	5-Nov-18	GULBARGA	110	HV1	SIRWAR_110	10:45	12:35	1:50	LINE CLEAR AVAILED
454	5-Nov-18	GULBARGA	110	MALLAT-MADALAPUR	MADALAPUR_110	18:16	18:34	0:18	LINE FAULT
455	5-Nov-18	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVATHI_110,SRERAMANAGARA_110,KARATAGI_110	18:15	18:23	0:08	LINE FAULT
456	5-Nov-18	GULBARGA	110	MUNIRABAD-VYASANKERE1	DONIMALAI_110	18:25	18:35	0:10	LINE FAULT
457	5-Nov-18	GULBARGA	110	HV1	KOLHAR_110	10:30	10:45	0:15	TRANSFORMER FAULT
458	5-Nov-18	GULBARGA	110	HV1	KOLHAR_110	15:30	15:45	0:15	TRANSFORMER FAULT
459	5-Nov-18	GULBARGA	110	HV1	KOLHAR_110	16:00	16:15	0:15	TRANSFORMER FAULT
460	5-Nov-18	GULBARGA	110	HV2	KOLHAR_110	17:40	18:05	0:25	LINE CLEAR AVAILED
461	5-Nov-18	GULBARGA	110	MUNIRABAD-STAR METALLIC	STAR METALLIC_IPP	18:26	18:40	0:14	LINE FAULT
462	5-Nov-18	GULBARGA	110	GURUMITKAL-KONKAL	KONKAL_110	20:48	20:55	0:07	LINE CLEAR AVAILED
463	5-Nov-18	GULBARGA	110	JANAWADA-KOLHAR	JANAWADA_110	19:10	19:20	0:10	LINE FAULT
464	5-Nov-18	GULBARGA	66	HV2	HIREHADAGALI_66	11:49	15:08	3:19	LINE CLEAR AVAILED
465	5-Nov-18	GULBARGA	66	MUNIRABAD-MSDLINE	HANASI_66	8:10	19:13	11:03	LINE CLEAR AVAILED
466	5-Nov-18	GULBARGA	66	MUNIRABAD-MSDLINE	HANASI_66	20:34	20:45	0:11	LINE FAULT
467	5-Nov-18	GULBARGA	66	MUNIRABAD-MSDLINE	HANASI_66	20:44	20:45	0:01	LINE FAULT
468	5-Nov-18	GULBARGA	66	MUNIRABAD-MSDLINE	HANASI_66	21:46	23:59	2:13	LINE CLEAR AVAILED
469	30-Oct-18	HASSAN	66	ARAKALGUD_66	ARAKAL-MALLIPATNA	13:00	15:10	2:10	LINE CLEAR AVAILED
470	30-Oct-18	HASSAN	66	ARAKALGUD_66	ARAKAL-MALLIPATNA	15:40	16:24	0:44	LINE CLEAR AVAILED
471	30-Oct-18	HASSAN	110	HV1	ESSUR_66	10:36	12:00	1:24	LINE CLEAR AVAILED
472	30-Oct-18	HASSAN	110	HV2	GANDAS_110	6:03	6:10	0:07	LINE FAULT
473	30-Oct-18	HASSAN	110	HV1	GURUPURA_110	6:30	11:15	4:45	MAIN SUPPLY FAILURE
474	30-Oct-18	HASSAN	110	HV2	GANDAS_110	13:04	16:21	3:17	LINE CLEAR AVAILED
475	30-Oct-18	HASSAN	110	HV1	GURUPURA_110	11:59	12:34	0:35	LINE CLEAR AVAILED
476	30-Oct-18	HASSAN	220	HV3	KEMAR_220	10:27	12:19	1:52	LINE CLEAR AVAILED
477	30-Oct-18	HASSAN	220	HV1	MSEZ_220	6:37	18:44	12:07	LINE CLEAR AVAILED
478	30-Oct-18	HASSAN	220	KEMAR_220	KEMAR-Kavoor2	6:37	18:44	12:07	LINE CLEAR AVAILED
479	30-Oct-18	HASSAN	220	KEMAR_220	kemar-Varahi3	12:02	16:00	3:58	LINE CLEAR AVAILED
480	30-Oct-18	HASSAN	66	MOSALEHOSHALLY_66	MOSALEH-HNPRA	10:50	14:31	3:41	LINE CLEAR AVAILED
481	30-Oct-18	HASSAN	66	HV1	MOSALEHOSHALLY_66	10:50	14:31	3:41	LINE CLEAR AVAILED
482	30-Oct-18	HASSAN	110	HV3	MRSSHM-SK LINE	6:29	11:11	4:42	LINE CLEAR AVAILED
483	30-Oct-18	HASSAN	220	HV3	MRSMSG_220	10:51	13:38	2:47	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
484	30-Oct-18	HASSAN	220	HV2	MRSSHM-VARAH13	6:02	6:26	0:24	LINE FAULT
485	30-Oct-18	HASSAN	220	MRS MG_220	MRSSHM-VARAH13	7:18	11:45	4:27	LINE CLEAR AVAILED
486	30-Oct-18	HASSAN	220	HV2	MSEZ_220	12:30	18:35	6:05	LINE CLEAR AVAILED
487	30-Oct-18	HASSAN	220	MSEZ_220	MSEZ-KEMAR1	6:36	18:44	12:08	NBFC ISSUED
488	30-Oct-18	HASSAN	220	MSEZ_220	MSEZ-KEMAR2	6:36	18:44	12:08	NBFC ISSUED
489	30-Oct-18	HASSAN	66	RAMNATPURA_66	RAMNAT-KATTEPURA_MINIH	18:03	18:20	0:17	LINE FAULT
490	30-Oct-18	HASSAN	220	TALAGUPPA_400	TALAGU-ST3	10:14	15:40	5:26	LINE CLEAR AVAILED
491	30-Oct-18	HASSAN	66	UDDURKOPLU_66	UDDURKO-SUZLON1	9:53	18:17	8:24	LINE CLEAR AVAILED
492	30-Oct-18	HASSAN	220	VARAHI_GEN	VARAHI-KEMAR3	12:02	16:00	3:58	NBFC ISSUED
493	30-Oct-18	HASSAN	220	VARAHI_GEN	UDDURKO-SHMG3	6:27	11:35	5:08	NBFC ISSUED
494	31-Oct-18	HASSAN	220	HV2	MSEZ_220	9:43	18:27	8:44	LINE CLEAR AVAILED
495	31-Oct-18	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	6:43	13:02	6:19	NBFC ISSUED
496	31-Oct-18	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	6:44	13:02	6:18	NBFC ISSUED
497	31-Oct-18	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	6:42	13:03	6:21	LINE CLEAR AVAILED
498	31-Oct-18	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	6:45	13:03	6:18	LINE CLEAR AVAILED
499	31-Oct-18	HASSAN	110	HV2	GANDASI_110	12:19	12:22	0:03	HAND TRIPPED
500	31-Oct-18	HASSAN	110	HV1	KONAJE_110	10:31	11:27	0:56	LINE CLEAR AVAILED
501	31-Oct-18	HASSAN	110	HV2	KONAJE_110	11:31	12:39	1:08	LINE CLEAR AVAILED
502	31-Oct-18	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	12:22	15:44	3:22	LINE CLEAR AVAILED
503	31-Oct-18	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLI_66	13:37	13:45	0:08	LINE CLEAR AVAILED
504	31-Oct-18	HASSAN	66	HV1	ATTICHOWDENAHALLI_66	13:37	13:45	0:08	LINE CLEAR AVAILED
505	31-Oct-18	HASSAN	66	HV2	BELUR_66	7:04	7:13	0:09	TRANSFORMER FAULT
506	31-Oct-18	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	13:48	14:21	0:33	LINE CLEAR AVAILED
507	31-Oct-18	HASSAN	66	HV1	BYACHANAHALLI_66	10:42	10:46	0:04	LINE CLEAR AVAILED
508	31-Oct-18	HASSAN	66	HV1	BYACHANAHALLI_66	13:48	14:21	0:33	LINE CLEAR AVAILED
509	31-Oct-18	HASSAN	66	HV1	BYACHANAHALLI_66	15:32	15:42	0:10	LINE CLEAR AVAILED
510	31-Oct-18	HASSAN	66	HV1	BYACHANAHALLI_66	17:12	17:51	0:39	LINE CLEAR AVAILED
511	31-Oct-18	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	18:05	18:20	0:15	LINE CLEAR AVAILED
512	31-Oct-18	HASSAN	66	UDDURKO-SUZLON2	UDDURKOPLU_66	9:42	18:03	8:21	LINE CLEAR AVAILED
513	1-Nov-18	HASSAN	220	KEMAR-Varahi1	KEMAR_220	9:56	15:50	5:54	NBFC ISSUED
514	1-Nov-18	HASSAN	220	MRSSHM-ANTRSNH	MRS MG_220	4:48	6:43	1:55	LINE FAULT
515	1-Nov-18	HASSAN	220	HV2	MSEZ_220	8:51	23:59	15:08	LINE CLEAR AVAILED
516	1-Nov-18	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	10:38	13:23	2:45	NBFC ISSUED
517	1-Nov-18	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	10:39	13:22	2:43	LINE CLEAR AVAILED
518	1-Nov-18	HASSAN	220	VARAHI-KEMAR1	varahi_gen	9:55	15:51	5:56	LINE CLEAR AVAILED
519	1-Nov-18	HASSAN	110	MRSSHM-MYSORE	MRS MG_220	10:05	12:04	1:59	LINE CLEAR AVAILED
520	1-Nov-18	HASSAN	110	LV2	MSEZ_220	8:51	23:59	15:08	LINE CLEAR AVAILED
521	1-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	11:59	12:10	0:11	LINE CLEAR AVAILED
522	1-Nov-18	HASSAN	66	HV1	GORUR_66	14:56	15:00	0:04	TRANSFORMER FAULT
523	1-Nov-18	HASSAN	66	HASSN220-HN PURA	HASSAN_220	0:26	0:52	0:26	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
524	1-Nov-18	HASSAN	66	HV1	HASSAN_66	15:11	15:40	0:29	TRANSFORMER FAULT
525	1-Nov-18	HASSAN	66	HV2	HASSAN_66	15:19	15:32	0:13	HAND TRIPPED
526	1-Nov-18	HASSAN	66	HV1	SALAGAME_66	11:15	11:22	0:07	TRANSFORMER FAULT
527	1-Nov-18	HASSAN	66	UDDURKO-NITTUR1	UDDURKOPLU_66	12:11	16:15	4:04	LINE CLEAR AVOID
528	1-Nov-18	HASSAN	66	UDDURKO-NITTUR2	UDDURKOPLU_66	10:00	12:10	2:10	HAND TRIPPED
529	1-Nov-18	HASSAN	66	UDDURKO-NITTUR2	UDDURKOPLU_66	14:48	16:15	1:27	LINE CLEAR AVOID
530	2-Nov-18	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	12:09	13:43	1:34	LINE CLEAR AVOID
531	2-Nov-18	HASSAN	220	VMRSSHM-ARAH13	MRSMSG_220	11:03	11:15	0:12	LINE FAULT
532	2-Nov-18	HASSAN	220	HV2	MSEZ_220	18:24	18:25	0:01	LINE CLEAR AVOID
533	2-Nov-18	HASSAN	220	SHRAVTY-SHIMOGA3	SHRAVATY_GEN	12:09	13:43	1:34	LINE CLEAR AVOID
534	2-Nov-18	HASSAN	110	LV2	MSEZ_220	18:24	18:25	0:01	LINE CLEAR AVOID
535	2-Nov-18	HASSAN	110	HV1	ARASIKERE_110	17:44	18:14	0:30	HAND TRIPPED
536	2-Nov-18	HASSAN	110	KADUR-NGNHL	KADUR_220	9:11	9:31	0:20	HAND TRIPPED
537	2-Nov-18	HASSAN	110	KADUR-TNGL	KADUR_220	8:11	9:11	1:00	HAND TRIPPED
538	2-Nov-18	HASSAN	110	KONAJE-MANJESWARG	KONAJE_220	10:06	16:11	6:05	LINE CLEAR AVOID
539	2-Nov-18	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	11:36	11:45	0:09	LINE CLEAR AVOID
540	2-Nov-18	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	10:12	11:45	1:33	LINE CLEAR AVOID
541	2-Nov-18	HASSAN	110	HV4	MRSMSG_220	9:50	10:08	0:18	TRANSFORMER FAULT
542	2-Nov-18	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:00	14:27	3:27	LINE CLEAR AVOID
543	2-Nov-18	HASSAN	66	HV2	BELUR_66	9:01	9:08	0:07	TRANSFORMER FAULT
544	2-Nov-18	HASSAN	66	HV1	BYACHANAHALLY_66	13:47	13:51	0:04	HAND TRIPPED
545	2-Nov-18	HASSAN	66	HV1	BYACHANAHALLY_66	15:05	15:10	0:05	HAND TRIPPED
546	2-Nov-18	HASSAN	66	HV2	HIRESAVE_66	12:11	16:08	3:57	LINE CLEAR AVOID
547	2-Nov-18	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	9:52	9:56	0:04	HAND TRIPPED
548	2-Nov-18	HASSAN	66	LV4	MRSMSG_220	9:50	10:08	0:18	TRANSFORMER FAULT
549	2-Nov-18	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPPALU_666	10:30	15:50	5:20	LINE CLEAR AVOID
550	2-Nov-18	HASSAN	66	UDDURKO-SUZLON2	UDDURKOPPALU_666	15:50	18:14	2:24	LINE CLEAR AVOID
551	3-Nov-18	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	16:40	17:20	0:40	LINE FAULT
552	3-Nov-18	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	16:40	17:20	0:40	LINE FAULT
553	3-Nov-18	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	16:40	17:20	0:40	LINE FAULT
554	3-Nov-18	HASSAN	66	Lv1	HOLENARASIPURA_220	16:40	17:20	0:40	TRANSFORMER FAULT
555	3-Nov-18	HASSAN	66	Lv2	HOLENARASIPURA_220	16:40	17:20	0:40	TRANSFORMER FAULT
556	3-Nov-18	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	16:40	17:20	0:40	LINE FAULT
557	3-Nov-18	HASSAN	66	HNPR-2MYSOR1	HOLENARASIPURA_220	21:54	22:04	0:10	LINE FAULT
558	3-Nov-18	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	16:40	17:20	0:40	LINE FAULT
559	3-Nov-18	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	6:37	7:03	0:26	LINE FAULT
560	3-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	11:18	11:28	0:10	LINE CLEAR AVOID
561	3-Nov-18	HASSAN	66	GENDEHA-HASSAN	GENDEHALLI_66	6:12	7:02	0:50	MAIN SUPPLY FAILURE
562	3-Nov-18	HASSAN	66	HV1	GENDEHALLI_66	6:59	9:56	2:57	LINE CLEAR AVOID
563	3-Nov-18	HASSAN	66	HV1	GENDEHALLI_66	10:01	10:27	0:26	LINE CLEAR AVOID

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
564	3-Nov-18	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	6:20	6:59	0:39	MAIN SUPPLY FAILURE
565	3-Nov-18	HASSAN	66	HV1	HARIHARAPURA_66	16:46	17:17	0:31	MAIN SUPPLY FAILURE
566	3-Nov-18	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	12:29	12:31	0:02	HAND TRIPPED
567	4-Nov-18	HASSAN	220	GESOPA-TALGUPA2	gerusoppa_gen	3:41	15:27	11:46	LINE FAULT
568	4-Nov-18	HASSAN	220	MRSSHM-VARAH1	MRSMG_220	0:00	8:50	8:50	LINE FAULT
569	4-Nov-18	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	13:58	14:10	0:12	LINE FAULT
570	4-Nov-18	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	14:15	14:41	0:26	HAND TRIPPED
571	4-Nov-18	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	3:42	4:12	0:30	LINE FAULT
572	4-Nov-18	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	0:00	8:50	8:50	LINE FAULT
573	4-Nov-18	HASSAN	220	HV1	GOPALAPURA_220	9:52	13:32	3:40	LINE CLEAR AVAILED
574	4-Nov-18	HASSAN	110	NK2	mghe_gen	0:00	17:14	17:14	LINE FAULT
575	4-Nov-18	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	13:58	13:59	0:01	MAIN SUPPLY FAILURE
576	4-Nov-18	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	14:36	14:41	0:05	HAND TRIPPED
577	4-Nov-18	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	13:58	13:59	0:01	MAIN SUPPLY FAILURE
578	4-Nov-18	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	14:36	14:41	0:05	HAND TRIPPED
579	4-Nov-18	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	14:36	14:41	0:05	HAND TRIPPED
580	4-Nov-18	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	13:58	14:02	0:04	MAIN SUPPLY FAILURE
581	4-Nov-18	HASSAN	110	SHRLKPSHIRALKOPPA	SHIRALKOPPA_220	14:36	14:41	0:05	HAND TRIPPED
582	4-Nov-18	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	14:36	14:41	0:05	HAND TRIPPED
583	4-Nov-18	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	21:24	21:32	0:08	MAIN SUPPLY FAILURE
584	4-Nov-18	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	21:32	21:37	0:05	LINE FAULT
585	5-Nov-18	HASSAN	110	AJAMPURA-KADUR	AJAMPURA_110	18:16	18:46	0:30	LINE CLEAR AVAILED
586	5-Nov-18	HASSAN	110	HV1	CHANDRAGUTTI_110	11:08	11:19	0:11	HAND TRIPPED
587	5-Nov-18	HASSAN	110	MADHUVA-KUNDAPURA	MADHUVANA_110	21:33	21:49	0:16	LINE FAULT
588	5-Nov-18	HASSAN	110	MADHUVA-KUNDAPURA	MADHUVANA_110	21:49	22:28	0:39	LINE FAULT
589	5-Nov-18	HASSAN	110	MADHUVA-KUNDAPURA	MADHUVANA_110	22:28	23:59	1:31	LINE FAULT
590	5-Nov-18	HASSAN	66	UDDURKOP-HASSAN1	UDDURKOPPALU_66	11:51	12:34	0:43	HAND TRIPPED
591	5-Nov-18	HASSAN	66	UDDURKOP-HASSAN2	UDDURKOPPALU_66	12:42	12:58	0:16	HAND TRIPPED
592	5-Nov-18	HASSAN	66	HASSN22-HN PURA	HASSAN_220	12:17	12:36	0:19	LINE CLEAR AVAILED
593	5-Nov-18	HASSAN	66	MHASSN22-MALLALI	HASSAN_220	11:32	11:50	0:18	LINE CLEAR AVAILED
594	5-Nov-18	HASSAN	66	HASSN22-SKPURA	HASSAN_220	12:55	13:10	0:15	LINE CLEAR AVAILED
595	5-Nov-18	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	11:51	12:33	0:42	LINE CLEAR AVAILED
596	30-Oct-18	MYSORE	66	HV2	AKKIHEBBAL_66	18:45	18:55	0:10	TRANSFORMER FAULT
597	30-Oct-18	MYSORE	66	BG NAGARA-NAGAMANGALA	BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	19:20	23:59	4:39	HAND TRIPPED
598	30-Oct-18	MYSORE	66	COWDALLI-MARTHALLI	RAMAPURA_MYS_66 MARTAHALLI_66	15:35	15:56	0:21	LINE CLEAR AVAILED
599	30-Oct-18	MYSORE	66	HV1	COWDALLI_66	15:35	15:56	0:21	LINE CLEAR AVAILED
600	30-Oct-18	MYSORE	66	HV2	COWDALLI_66	15:35	15:56	0:21	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
601	30-Oct-18	MYSORE	66	HV2	DEVANOORNGUDU_66	11:15	11:30	0:15	TRANSFORMER FAULT
602	30-Oct-18	MYSORE	66	HV2	GUNDULPET_66	7:26	7:40	0:13	LINE CLEAR AVAILED
603	30-Oct-18	MYSORE	66	HV1	HEBBAL_66	11:15	11:40	0:25	LINE CLEAR AVAILED
604	30-Oct-18	MYSORE	66	HV1	K_HONNALGERE_66	12:35	12:56	0:21	LINE CLEAR AVAILED
605	30-Oct-18	MYSORE	66	KR PET 220-BUKANAKERE	SHEELUNERE, GANJIGERE, BOOKANAKERE, CHINAKURULI & BANNANGADI	12:45	13:28	0:43	LINE FAULT
606	30-Oct-18	MYSORE	66	KR PET 220-MADESHWARAPURA	MADESHWARAPURA, G MALLIGERE, JAKKANAHALLI, GUDDENAHALLI, BOGADHI & NAGAMANGALA	12:45	13:26	0:41	LINE FAULT
607	30-Oct-18	MYSORE	220	KR PET 220-YACHANAHALLY	KR PETE & ITS DOWNSTREAM	12:45	12:52	0:07	LINE FAULT
608	30-Oct-18	MYSORE	220	KR PET 220-YACHANAHALLY	KR PETE 220KV, TUBINAKERE 220KV & ITS DOWNSTREAM STATIONS	13:16	13:21	0:05	LINE FAULT
609	30-Oct-18	MYSORE	220	KR PET 220-TUBINAKERE	TUBINAKERE & ITS DOWN STREAM STATIONS	12:52	13:13	0:20	LINE FAULT
610	30-Oct-18	MYSORE	66	MANDYA-HAMPAPURA	CHIKKMANDYA, HAMPAPURA, KOPPA, BESAGARAHALLI & DUNDANAHALLI	13:13	23:59	10:45	HAND TRIPPED
611	30-Oct-18	MYSORE	66	MANDYA-M2	MALAVALLI & HADLI	3:05	3:16	0:10	LINE FAULT
612	30-Oct-18	MYSORE	66	MANDYA-M2	MALAVALLI & HADLI	13:13	13:30	0:16	HAND TRIPPED
613	30-Oct-18	MYSORE	66	HV2	PANYADAHUNDI	21:34	22:11	0:37	TRANSFORMER FAULT
614	30-Oct-18	MYSORE	66	HV2	TALAKADU	6:01	6:07	0:05	HAND TRIPPED
615	30-Oct-18	MYSORE	66	HV1	TALAKADU	6:01	6:07	0:05	HAND TRIPPED
616	30-Oct-18	MYSORE	66	TUBINAKERE-ARAKERE	PANDAVAPURA, ARAKERE, GAMANHALLI & TARIPURA	12:45	13:43	0:58	HAND TRIPPED
617	30-Oct-18	MYSORE	66	TUBINAKERE-G UKKADA	MANDYA PANDAVAPURA DB HALLI G UKKADA SR PATNA	12:45	23:59	11:14	HAND TRIPPED
618	30-Oct-18	MYSORE	66	TUBINAKERE-MC2	MANDYA PANDAVAPURA DB HALLI G UKKADA SR PATNA	12:45	23:59	11:14	HAND TRIPPED
619	30-Oct-18	MYSORE	66	TUBINAKERE-MC4	MANDYA PANDAVAPURA DB HALLI G UKKADA SR PATNA	12:45	23:59	11:14	HAND TRIPPED
620	30-Oct-18	MYSORE	66	TUBINAKERE-PANDAVAPURA	MANDYA PANDAVAPURA DB HALLI G UKKADA SR PATNA	12:45	23:59	11:14	HAND TRIPPED
621	30-Oct-18	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BGNAGARA_66 BASARALU_66 SHIVALLY_66 VADERALLI_66,	12:45	13:45	1:00	HAND TRIPPED
622	30-Oct-18	MYSORE	66	HV1	TUBINAKERE_220	12:45	13:39	0:54	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
623	30-Oct-18	MYSORE	66	HV2	TUBINAKERE_220	12:45	13:39	0:54	HAND TRIPPED
624	31-Oct-18	MYSORE	66	DUNDANAHALLI-HULIYURDURGA	BESAGARAHALLI_66 CHIKKA_MANDYA_66 DUNDANAHALLI_66 HAMPAPURA_66 KOPPA_66	16:20	23:59	7:39	HAND TRIPPED
625	31-Oct-18	MYSORE	66	HV1	ELAVALA_66	11:10	12:17	1:07	LINE CLEAR AVAILED
626	31-Oct-18	MYSORE	66	HV1	KOPPA_66	16:37	16:50	0:13	HAND TRIPPED
627	31-Oct-18	MYSORE	66	HV2	KOPPA_66	16:37	16:50	0:13	HAND TRIPPED
628	31-Oct-18	MYSORE	66	HV3	KUSHALNAGARA_220	13:53	14:09	0:15	TRANSFORMER FAULT
629	31-Oct-18	MYSORE	66	HV3	KUSHALNAGARA_220	14:09	23:59	9:49	TRANSFORMER FAULT
630	31-Oct-18	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66 KRNAGARA_66 BILIKERE_66 GVGUDI_66	16:51	17:01	0:10	LINE FAULT
631	31-Oct-18	MYSORE	66	HV4	KUSHALNAGARA_220	17:40	18:02	0:22	LINE CLEAR AVAILED
632	31-Oct-18	MYSORE	66	HV1	SHIVALLY_66	14:00	14:04	0:03	HAND TRIPPED
633	31-Oct-18	MYSORE	66	HV2	SHIVALLY_66	14:00	14:04	0:03	HAND TRIPPED
634	31-Oct-18	MYSORE	66	HV1	THALAKADU_66	5:21	5:26	0:05	HAND TRIPPED
635	31-Oct-18	MYSORE	66	HV2	THALAKADU_66	5:21	5:26	0:05	HAND TRIPPED
636	31-Oct-18	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	9:48	10:41	0:52	LINE CLEAR AVAILED
637	31-Oct-18	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BASARALU_66	9:48	14:01	4:12	LINE CLEAR AVAILED
638	31-Oct-18	MYSORE	220	HV1	TUBINAKERE_220	9:47	13:41	3:54	LINE CLEAR AVAILED
639	31-Oct-18	MYSORE	220	HV2	TUBINAKERE_220	9:47	13:43	3:56	LINE CLEAR AVAILED
640	31-Oct-18	MYSORE	220	HV1	TUBINAKERE_220	13:51	15:58	2:06	TRANSFORMER FAULT
641	31-Oct-18	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	15:07	15:29	0:22	LINE FAULT
642	31-Oct-18	MYSORE	66	HV1	TUBINAKERE_220	9:47	10:18	0:31	LINE CLEAR AVAILED
643	31-Oct-18	MYSORE	66	HV2	TUBINAKERE_220	9:47	10:19	0:32	LINE CLEAR AVAILED
644	31-Oct-18	MYSORE	66	HV1	TUBINAKERE_220	9:41	9:44	0:03	HAND TRIPPED
645	31-Oct-18	MYSORE	66	HV1	TUBINAKERE_220	16:30	16:36	0:06	HAND TRIPPED
646	31-Oct-18	MYSORE	66	VAJAMANGALA-DEVNUR (MYS)	DEVANOORMYS_66 RAJEEVNAGARA_66 FTS_66	16:13	16:31	0:18	LINE FAULT
647	1-Nov-18	MYSORE	66	HV2	KIKKERI_66	12:53	13:36	0:43	LINE CLEAR AVAILED
648	1-Nov-18	MYSORE	66	HV3	KUSHALNAGARA_220	13:46	14:33	0:46	LINE CLEAR AVAILED
649	1-Nov-18	MYSORE	66	HV1	THALAKADU_66	6:33	6:36	0:03	MAIN SUPPLY FAILURE
650	1-Nov-18	MYSORE	66	HV2	THALAKADU_66	6:33	6:36	0:03	MAIN SUPPLY FAILURE
651	1-Nov-18	MYSORE	66	HV1	THALAKADU_66	23:27	23:34	0:06	MAIN SUPPLY FAILURE
652	1-Nov-18	MYSORE	66	HV2	THALAKADU_66	23:27	23:34	0:06	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
653	1-Nov-18	MYSORE	66	TUBINAKERE-MANDYA 2	MANDYA_66 MALAVALLI_66 HADLI_66 BESAGARAHALLI_66 CHIKKA_MANDYA_66 DUNDANAHALLI_66 HAMPAPURA_66 KOPPA_66	14:52	15:06	0:13	LINE FAULT
654	1-Nov-18	MYSORE	66	TUBINAKERE-MANDYA 4	MANDYA_66 MALAVALLI_66 HADLI_66 BESAGARAHALLI_66 CHIKKA_MANDYA_66 DUNDANAHALLI_66 HAMPAPURA_66 KOPPA_66	14:52	15:04	0:12	LINE FAULT
655	2-Nov-18	MYSORE	66	KADAKOLA-SARGURU 2	DOORA_66 HURA_66 HULLAHALLI_66	6:26	6:35	0:08	LINE FAULT
656	2-Nov-18	MYSORE	66	HV3	KIKKERI_66	13:11	14:06	0:54	LINE CLEAR AVAILED
657	2-Nov-18	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	BOGADHI MANDYA_66 GUDDENAHALLI_66 G MALLIGERE_66 JAKKANAHALLY_66 MADESWARAPURA_66 NAGAMANGALA_66	7:05	7:16	0:10	LINE FAULT
658	2-Nov-18	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	BOGADHI MANDYA_66 GUDDENAHALLI_66 G MALLIGERE_66 JAKKANAHALLY_66 MADESWARAPURA_66 NAGAMANGALA_66	8:40	8:55	0:15	LINE FAULT
659	2-Nov-18	MYSORE	66	KUSHALANAGARA 220-MERCERA-1	MADIKERI_66 SUNTIKOPPA_66	12:21	15:22	3:00	LINE CLEAR AVAILED
660	2-Nov-18	MYSORE	66	KUSHALANAGARA 220-SUNTIKOPPA	MADIKERI_66 SUNTIKOPPA_66	12:22	15:22	3:00	LINE CLEAR AVAILED
661	2-Nov-18	MYSORE	66	HV1	THALAKADU_66	1:43	1:45	0:02	HAND TRIPPED
662	2-Nov-18	MYSORE	66	HV2	THALAKADU_66	1:43	1:45	0:02	MAIN SUPPLY FAILURE
663	2-Nov-18	MYSORE	66	HV1	THALAKADU_66	5:07	5:11	0:04	MAIN SUPPLY FAILURE
664	2-Nov-18	MYSORE	66	HV2	THALAKADU_66	5:07	5:11	0:04	MAIN SUPPLY FAILURE
665	2-Nov-18	MYSORE	66	HV1	THALAKADU_66	6:17	6:22	0:05	MAIN SUPPLY FAILURE
666	2-Nov-18	MYSORE	66	HV2	THALAKADU_66	6:17	6:22	0:05	MAIN SUPPLY FAILURE
667	2-Nov-18	MYSORE	66	HV1	THALAKADU_66	6:26	6:37	0:10	MAIN SUPPLY FAILURE
668	2-Nov-18	MYSORE	66	HV2	THALAKADU_66	6:26	6:37	0:10	MAIN SUPPLY FAILURE
669	2-Nov-18	MYSORE	66	HV1	TERAKANAMBE_66	13:55	15:13	1:17	LINE CLEAR AVAILED
670	2-Nov-18	MYSORE	66	HV2	TERAKANAMBE_66	12:13	13:41	1:27	LINE CLEAR AVAILED
671	2-Nov-18	MYSORE	220	HV2	TUBINAKERE_220	4:15	4:42	0:27	TRANSFORMER FAULT
672	2-Nov-18	MYSORE	220	HV2	TUBINAKERE_220	4:42	9:23	4:40	TRANSFORMER FAULT
673	2-Nov-18	MYSORE	220	HV2	TUBINAKERE_220	9:23	9:41	0:17	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
674	2-Nov-18	MYSORE	220	HV2	TUBINAKERE_220	9:41	10:15	0:33	TRANSFORMER FAULT
675	2-Nov-18	MYSORE	220	HV2	TUBINAKERE_220	10:15	12:05	1:49	LINE CLEAR AVAILED
676	2-Nov-18	MYSORE	220	HV2	TUBINAKERE_220	12:30	14:51	2:21	TRANSFORMER FAULT
677	2-Nov-18	MYSORE	66	HV2	TUBINAKERE_220	4:22	5:23	1:01	HAND TRIPPED
678	2-Nov-18	MYSORE	66	HV2	TUBINAKERE_220	12:28	12:57	0:29	HAND TRIPPED
679	2-Nov-18	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66 PANDAVAPURA_66 DODDABYADARAHALLI_66 GARUDANAUKADDA_66 SRIRANGAPATNA_66 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	4:21	5:24	1:02	HAND TRIPPED
680	2-Nov-18	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66 PANDAVAPURA_66 DODDABYADARAHALLI_66 GARUDANAUKADDA_66 SRIRANGAPATNA_66 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	4:21	5:26	1:04	HAND TRIPPED
681	2-Nov-18	MYSORE	66	TUBINAKERE-G UKKADA	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66 PANDAVAPURA_66 DODDABYADARAHALLI_66 GARUDANAUKADDA_66 SRIRANGAPATNA_66 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	4:21	5:27	1:06	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
682	2-Nov-18	MYSORE	66	TUBINAKERE-PANDAVAPURA	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66 PANDAVAPURA_66 DODDABYADARAHALLI_66 GARUDANAUKADDA_66 SRIRANGAPATNA_66 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	4:21	5:18	0:56	HAND TRIPPED
683	2-Nov-18	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66 PANDAVAPURA_66 DODDABYADARAHALLI_66 GARUDANAUKADDA_66 SRIRANGAPATNA_66 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	12:37	12:57	0:20	HAND TRIPPED
684	2-Nov-18	MYSORE	66	TUBINAKERE-G UKKADA	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66 PANDAVAPURA_66 DODDABYADARAHALLI_66 GARUDANAUKADDA_66 SRIRANGAPATNA_66 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	12:37	13:02	0:24	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
685	2-Nov-18	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66 PANDAVAPURA_66 DODDABYADARAHALLI_66 GARUDANAUKADDA_66 SRIRANGAPATNA_66 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	12:37	12:58	0:20	HAND TRIPPED
686	2-Nov-18	MYSORE	66	TUBINAKERE-PANDAVAPURA	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66 PANDAVAPURA_66 DODDABYADARAHALLI_66 GARUDANAUKADDA_66 SRIRANGAPATNA_66 SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	12:37	12:57	0:20	HAND TRIPPED
687	3-Nov-18	MYSORE	66	HV1	HUNSUR_66	10:26	10:33	0:06	TRANSFORMER FAULT
688	3-Nov-18	MYSORE	66	HV1	HUNSUR_66	16:15	17:16	1:00	LINE CLEAR AVAILED
689	3-Nov-18	MYSORE	66	KR PETE 220-BOOKANKERE	SHEELUNERE_66 GANJIGERE_66 BOOKANAKERE_66 CHINAKURALI_66 BANANGADI_66	13:06	13:12	0:05	LINE FAULT
690	3-Nov-18	MYSORE	66	KR PETE 220-MADESHWARAPURA	JAKKANAHALLY_66 MADESWARAPURA_66 NAGAMANGALA_66 G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI MANDYA_66	12:21	12:28	0:06	LINE FAULT
691	3-Nov-18	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66	15:55	16:07	0:12	LINE FAULT
692	3-Nov-18	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	11:27	11:31	0:03	LINE FAULT
693	3-Nov-18	MYSORE	66	HV2	PONNAMPET_66	6:38	6:46	0:07	TRANSFORMER FAULT
694	3-Nov-18	MYSORE	66	HV2	THALAKADU_66	17:05	17:20	0:15	TRANSFORMER FAULT
695	3-Nov-18	MYSORE	66	HV1	THALAKADU_66	18:07	18:11	0:03	HAND TRIPPED
696	3-Nov-18	MYSORE	66	HV2	THALAKADU_66	18:07	18:11	0:03	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
697	3-Nov-18	MYSORE	66	TALAKADU-PARINAMIPURA	THALAKADU_66	14:22	15:52	1:29	LINE CLEAR AVAILED
698	4-Nov-18	MYSORE	66	HANAGODU-PONNAMPETE	PONNAMPET_66 VIRAJPET_66	16:30	16:43	0:13	LINE FAULT
699	4-Nov-18	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66 KIADBMANDYA_66	20:39	20:52	0:12	LINE FAULT
700	4-Nov-18	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66 K_HONNALGERE_66	20:52	21:17	0:25	HAND TRIPPED
701	4-Nov-18	MYSORE	66	KR NAGARA-BILIKERE	BILIKERE_66 GVGUDI_66	11:16	11:31	0:14	LINE FAULT
702	4-Nov-18	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	6:20	6:33	0:13	LINE FAULT
703	4-Nov-18	MYSORE	66	PERIAPATNA-HANAGODU	PONNAMPET_66 VIRAJPET_66	16:30	16:42	0:12	LINE FAULT
704	4-Nov-18	MYSORE	66	PERIAPATNA-HUNSUR	HUNSUR_66 HANAGODU_66	16:30	16:38	0:08	LINE FAULT
705	5-Nov-18	MYSORE	66	CR NAGARA-PANNYADAHUNDI	DEVANOORNGUDU_66 HEMMARAGALA_66 KARYA_66 PANDYADAHUNDI_66	17:12	18:01	0:49	LINE FAULT
706	5-Nov-18	MYSORE	66	HV2	KIKKERI_66	13:19	14:12	0:53	LINE CLEAR AVAILED
707	5-Nov-18	MYSORE	66	HV2	KMDODDI_66	22:39	22:51	0:11	TRANSFORMER FAULT
708	5-Nov-18	MYSORE	66	HV1	PANDYADAHUNDI_66	17:15	23:59	6:44	TRANSFORMER FAULT
709	5-Nov-18	MYSORE	66	HV2	PANDYADAHUNDI_66	18:20	18:40	0:20	HAND TRIPPED
710	5-Nov-18	MYSORE	66	HV2	PONNAMPET_66	11:21	12:15	0:53	LINE CLEAR AVAILED
711	5-Nov-18	MYSORE	66	HV1	SANTHEMARAHALLI_66	12:50	13:35	0:45	LINE CLEAR AVAILED
712	5-Nov-18	MYSORE	66	HV2	SANTHEMARAHALLI_66	12:00	13:42	1:42	LINE CLEAR AVAILED
713	5-Nov-18	MYSORE	66	SFC SIVA-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66 THUMBLA_66 TNARASIPURA_66	10:37	10:48	0:10	LINE FAULT
714	5-Nov-18	MYSORE	66	CR NAGARA-PANNYADAHUNDI	DEVANOORNGUDU_66 HEMMARAGALA_66 KARYA_66 PANDYADAHUNDI_66	17:12	18:01	0:49	LINE FAULT
715	5-Nov-18	MYSORE	66	HV2	KIKKERI_66	13:19	14:12	0:53	LINE CLEAR AVAILED
716	5-Nov-18	MYSORE	66	HV2	KMDODDI_66	22:39	22:51	0:11	TRANSFORMER FAULT
717	5-Nov-18	MYSORE	66	HV1	PANDYADAHUNDI_66	17:15	23:59	6:44	TRANSFORMER FAULT
718	5-Nov-18	MYSORE	66	HV2	PANDYADAHUNDI_66	18:20	18:40	0:20	HAND TRIPPED
719	5-Nov-18	MYSORE	66	HV2	PONNAMPET_66	11:21	12:15	0:53	LINE CLEAR AVAILED
720	5-Nov-18	MYSORE	66	HV1	SANTHEMARAHALLI_66	12:50	13:35	0:45	LINE CLEAR AVAILED
721	5-Nov-18	MYSORE	66	HV2	SANTHEMARAHALLI_66	12:00	13:42	1:42	LINE CLEAR AVAILED
722	5-Nov-18	MYSORE	66	SFC SIVA-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66 THUMBLA_66 TNARASIPURA_66	10:37	10:48	0:10	LINE FAULT
723	30-Oct-18	TUMKUR	220	DAVANGERE SRS- HONNALLI	HONNALLI_220	16:18	16:19	0:01	HAND TRIPPED
724	30-Oct-18	TUMKUR	220	HONNALLI 220kV- DAVANGERE	HONNALLI_220	12:09	16:32	4:22	LINE CLEAR AVAILED
725	30-Oct-18	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	MRSMSG_220	12:09	16:32	4:22	HAND TRIPPED
726	30-Oct-18	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	10:33	13:07	2:33	LINE CLEAR AVAILED
727	30-Oct-18	TUMKUR	66	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	ANTHRASANAHALLI 220KV- CHELUR	17:37	17:52	0:14	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
728	30-Oct-18	TUMKUR	66	KOLALA_66, URDIGERE_66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	17:37	19:31	1:53	LINE FAULT
729	30-Oct-18	TUMKUR	66	TR-2	CHANNAGIRI_66	15:59	16:02	0:03	TRANSFORMER FAULT
730	30-Oct-18	TUMKUR	66	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	DAVANGERE SRS- H- HOSPET	10:46	10:59	0:13	LINE FAULT
731	30-Oct-18	TUMKUR	66	TR-2	GARAGA_66	16:39	18:26	1:47	LINE CLEAR AVAILED
732	30-Oct-18	TUMKUR	66	TR-1	GARAGA_66	17:50	18:26	0:36	LINE CLEAR AVAILED
733	30-Oct-18	TUMKUR	66	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	HIRIYUR 220kv- BEVINAHALLI	10:42	10:59	0:16	LINE FAULT
734	30-Oct-18	TUMKUR	66	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	HIRIYUR 220kv- BEVINAHALLI	11:14	11:23	0:09	LINE FAULT
735	30-Oct-18	TUMKUR	66	HOLALKERE_66	HOLALKERE- RAMGIRI 2	0:30	0:36	0:05	LINE FAULT
736	30-Oct-18	TUMKUR	66	HOLALKERE_66	HOLALKERE- RAMGIRI 2	15:57	16:05	0:07	LINE FAULT
737	30-Oct-18	TUMKUR	66	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	HONNALLI 220kv- CHANNAGIRI	18:05	18:11	0:06	LINE FAULT
738	30-Oct-18	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	9:12	9:49	0:37	LINE FAULT
739	30-Oct-18	TUMKUR	66	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	KUKKAWADA- LINGADAHALLI	0:30	0:51	0:20	LINE FAULT
740	30-Oct-18	TUMKUR	66	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	KUKKAWADA- SRS DAVANGERE	0:30	0:42	0:11	LINE FAULT
741	30-Oct-18	TUMKUR	66	MEDIGESHI- CLEANSOLAR IPP	CLEANSOLAR_IPP_66	12:08	12:13	0:04	HAND TRIPPED
742	30-Oct-18	TUMKUR	66	PAVAGADA- VENKATAPURA	VENKATAPURA_66	10:34	11:36	1:01	LINE CLEAR AVAILED
743	30-Oct-18	TUMKUR	66	TR-1	PULAMG_66	16:12	16:56	0:44	LINE CLEAR AVAILED
744	30-Oct-18	TUMKUR	66	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	SHYLAPURA- MADHUGIRI	8:01	11:04	3:03	HAND TRIPPED
745	30-Oct-18	TUMKUR	66	TELAGI- VESTAS IPP	VESTAS_IPP_66	10:41	11:00	0:18	LINE CLEAR AVAILED
746	31-Oct-18	TUMKUR	220	ANCHEPALYA 220kv- MAGADI	ANCHEPALYA_220	16:41	17:44	1:03	LINE CLEAR AVAILED
747	31-Oct-18	TUMKUR	110	SAMPIGE- DODDAGUNI	SAMPIGE_110	15:44	16:32	0:48	MAIN SUPPLY FAILURE
748	31-Oct-18	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	15:44	16:32	0:48	MAIN SUPPLY FAILURE
749	31-Oct-18	TUMKUR	110	TR-1 & TR-2	SAMPIGE_110	15:44	16:32	0:48	MAIN SUPPLY FAILURE
750	31-Oct-18	TUMKUR	66	ANCHEPALYA 220kv- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	2:51	3:01	0:10	LINE FAULT
751	31-Oct-18	TUMKUR	66	TR-2	BEVINAHALLI_66	12:25	13:45	1:19	LINE CLEAR AVAILED
752	31-Oct-18	TUMKUR	66	TR-2	BRAHMASANDRA_66	10:09	14:55	4:46	LINE CLEAR AVAILED
753	31-Oct-18	TUMKUR	66	TR-1	BRAHMASANDRA_66	16:44	17:38	0:54	LINE CLEAR AVAILED
754	31-Oct-18	TUMKUR	66	TR-2	CHELURU_66	15:40	18:21	2:41	LINE CLEAR AVAILED
755	31-Oct-18	TUMKUR	66	CHITRADURGA 220kv- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	16:33	16:44	0:11	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
756	31-Oct-18	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	16:51	17:02	0:11	LINE CLEAR AVAIED
757	31-Oct-18	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:03	12:21	1:17	LINE FAULT
758	31-Oct-18	TUMKUR	66	TR-1	HIEMALLANAHOLE_66	10:13	13:48	3:34	LINE CLEAR AVAIED
759	31-Oct-18	TUMKUR	66	TR-2	HIEMALLANAHOLE_66	13:48	18:42	4:54	LINE CLEAR AVAIED
760	31-Oct-18	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66	6:58	7:06	0:08	LINE FAULT
761	31-Oct-18	TUMKUR	66	TR-2	HONNALLI_220	14:36	15:42	1:05	LINE CLEAR AVAIED
762	31-Oct-18	TUMKUR	66	TR-1	HONNALLI_220	15:42	16:34	0:52	LINE CLEAR AVAIED
763	31-Oct-18	TUMKUR	66	HONNALLI 220KV- HONNALLI	HONNALLI_66, KATTIGE_66, MALEBENNUR_66 , NANDIGUDI_66, BANUVALLI_66	16:25	16:35	0:10	LINE FAULT
764	31-Oct-18	TUMKUR	66	TR-2	SHYLAPURA_66	0:16	0:32	0:15	TRANSFORMER FAULT
765	31-Oct-18	TUMKUR	66	THALLAK 220kV- CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:18	16:42	0:24	HAND TRIPPED
766	31-Oct-18	TUMKUR	66	TR-1	HARAPPANAHALLI_66	12:29	15:45	3:15	TRANSFORMER FAULT
767	31-Oct-18	TUMKUR	66	MADHUGIRI 66kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	13:54	16:41	2:46	MAIN SUPPLY FAILURE
768	1-Nov-18	TUMKUR	220	ANTHRASANAHALLI 220kV- SHIMOGA	ANTHRASANAHALLI_220	4:47	6:42	1:55	LINE FAULT
769	1-Nov-18	TUMKUR	220	ANTHRASANAHALLI 220kV- NELAMANGALA	ANTHRASANAHALLI_220	4:47	5:11	0:24	LINE FAULT
770	1-Nov-18	TUMKUR	110	TR-1	MAYASANDRA_110	12:09	12:25	0:15	TRANSFORMER FAULT
771	1-Nov-18	TUMKUR	66	TR-2	BENNEHALLI_66	11:28	12:01	0:33	LINE CLEAR AVAIED
772	1-Nov-18	TUMKUR	66	TR-2	CHELURU_66	15:22	16:38	1:16	LINE CLEAR AVAIED
773	1-Nov-18	TUMKUR	66	TR-1	HANAGAL_66	10:08	10:18	0:09	LINE CLEAR AVAIED
774	1-Nov-18	TUMKUR	66	HIRIYUR 220kV- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	4:45	4:53	0:08	LINE FAULT
775	1-Nov-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	18:00	18:12	0:12	LINE FAULT
776	1-Nov-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	18:49	19:01	0:12	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
777	1-Nov-18	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	13:51	14:03	0:12	LINE FAULT
778	1-Nov-18	TUMKUR	66	HONNALLI 220KV- HONNALLI	HONNALLI_66, KATTIGE_66, MALEBENNUR_66 , NANDIGUDI_66, BANUVALLI_66	14:22	14:33	0:11	LINE FAULT
779	1-Nov-18	TUMKUR	66	TR-1	MYLANAHALLI_66	12:38	12:48	0:10	TRANSFORMER FAULT
780	1-Nov-18	TUMKUR	66	TR-2	RAMPURA_66	12:26	13:22	0:56	LINE CLEAR AVAILED
781	1-Nov-18	TUMKUR	66	THALLAK 220kv- CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:48	16:58	0:09	LINE FAULT
782	1-Nov-18	TUMKUR	66	UCHANGIDURGA- PALLAGATTE	PALLAGATTE_66	15:04	15:13	0:09	LINE FAULT
783	1-Nov-18	TUMKUR	66	KORA- ANTHRASANAHALLI	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	4:48	5:26	0:38	MAIN SUPPLY FAILURE
784	2-Nov-18	TUMKUR	110	TR-1	KALLUR_110	10:51	12:25	1:34	TRANSFORMER FAULT
785	2-Nov-18	TUMKUR	66	ANCHEPALYA 220kv- KUNIGAL	KUNIGAL_66	16:31	16:52	0:21	LINE CLEAR AVAILED
786	2-Nov-18	TUMKUR	66	BENNEHALLI-SUZLON	SUZLON_IPP_66	16:12	16:29	0:16	LINE FAULT
787	2-Nov-18	TUMKUR	66	TR-1	CHIKKABANAGERE_66	15:29	15:50	0:21	LINE CLEAR AVAILED
788	2-Nov-18	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	12:13	12:32	0:19	LINE CLEAR AVAILED
789	2-Nov-18	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	10:18	13:32	3:14	LINE CLEAR AVAILED
790	2-Nov-18	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66	12:48	13:00	0:12	LINE FAULT
791	2-Nov-18	TUMKUR	66	HOSAKERE- MADHUGIRI	HOSAKERE_66, MEDIGESHI_66, PAVAGADA_66, VENKATAPURA_66	9:16	9:20	0:03	LINE CLEAR AVAILED
792	2-Nov-18	TUMKUR	66	TR-2	HOSKERE_66	9:21	9:41	0:19	LINE CLEAR AVAILED
793	2-Nov-18	TUMKUR	66	TR-2	KORATAGERE_66	8:57	9:08	0:11	HAND TRIPPED
794	2-Nov-18	TUMKUR	66	TR-1 & TR-2	KUNIGAL_66	16:33	16:55	0:21	LINE CLEAR AVAILED
795	2-Nov-18	TUMKUR	66	MEDIGESHI- CLEANSOLAR IPP	CLEANSOLAR_IPP_66	13:12	13:27	0:14	HAND TRIPPED
796	3-Nov-18	TUMKUR	110	HONNAVALLI- ADAN SOLAR	ADANSOLAR_IPP_66	14:35	15:01	0:25	LINE FAULT
797	3-Nov-18	TUMKUR	110	TR-1	TURUVEKERE_110	15:02	15:32	0:29	TRANSFORMER FAULT
798	3-Nov-18	TUMKUR	110	DODDAGUNI- SAMPIGE	SAMPIGE_110	9:15	9:55	0:40	MAIN SUPPLY FAILURE
799	3-Nov-18	TUMKUR	110	TR-1	GUNGURMALE_110	12:54	13:43	0:48	LINE CLEAR AVAILED
800	3-Nov-18	TUMKUR	110	KADEHALLI- KB CROSS	KADEHALLI_110	17:33	17:48	0:15	LINE CLEAR AVAILED
801	3-Nov-18	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	10:30	10:39	0:08	LOAD CURTAILMENT
802	3-Nov-18	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	17:18	17:41	0:23	LINE FAULT
803	3-Nov-18	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	18:09	23:59	5:49	LINE FAULT
804	3-Nov-18	TUMKUR	110	TR-1	TALKERE_110	17:29	18:06	0:37	HAND TRIPPED
805	3-Nov-18	TUMKUR	110	TR-1(100MVA)	NITTUR_220	9:15	9:47	0:32	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
806	3-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	1:47	1:54	0:07	LINE FAULT
807	3-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	10:15	10:25	0:10	LINE FAULT
808	3-Nov-18	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:31	6:47	0:15	LINE FAULT
809	3-Nov-18	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	15:45	17:32	1:47	LINE CLEAR AVAILED
810	3-Nov-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	17:04	17:18	0:13	LINE FAULT
811	3-Nov-18	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	10:38	10:50	0:12	LINE FAULT
812	3-Nov-18	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	17:16	17:41	0:24	LINE CLEAR AVAILED
813	3-Nov-18	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS1_EHT_66	11:23	11:33	0:10	LINE FAULT
814	3-Nov-18	TUMKUR	66	NAGALAMADIKE-MADHUGIRI	NAGALMADIKE_66	19:50	20:05	0:15	LINE FAULT
815	3-Nov-18	TUMKUR	66	TR-1	PAVAGADA_66	0:02	0:17	0:14	TRANSFORMER FAULT
816	3-Nov-18	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	22:18	23:12	0:53	MAIN SUPPLY FAILURE
817	4-Nov-18	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	19:09	19:56	0:46	HAND TRIPPED
818	4-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	12:58	13:11	0:12	LINE FAULT
819	4-Nov-18	TUMKUR	66	BUKKAPATNA- GOLDENHATCHERIES_IPP	GOLDENHATCHERIES_IPP_66	8:57	9:04	0:06	LINE CLEAR AVAILED
820	4-Nov-18	TUMKUR	66	TR-1 &2	CHANNAGIRI_66	10:31	14:50	4:19	LINE CLEAR AVAILED
821	4-Nov-18	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:16	18:34	0:17	LINE FAULT
822	4-Nov-18	TUMKUR	66	TR-1	HALUVAGALU_66	10:08	10:25	0:17	TRANSFORMER FAULT
823	4-Nov-18	TUMKUR	66	TR-1	HALUVAGALU_66	13:11	13:22	0:11	TRANSFORMER FAULT
824	4-Nov-18	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	9:16	10:09	0:53	HAND TRIPPED
825	4-Nov-18	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66, RKP2_IPP_66	9:16	10:09	0:53	HAND TRIPPED
826	4-Nov-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	10:20	10:33	0:13	LOAD CURTAILMENT
827	4-Nov-18	TUMKUR	66	MADHUGIRI 220kV- KALLAMBELLA	SIRA_66, KALLAMBELLA_66	8:42	8:54	0:12	LINE FAULT
828	4-Nov-18	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	6:15	6:29	0:14	LINE FAULT
829	4-Nov-18	TUMKUR	66	TR-1	MAVINAKATTE_66	8:14	8:26	0:11	TRANSFORMER FAULT
830	4-Nov-18	TUMKUR	66	RANGENAHALLI- AZURE SOLAR	AZURE SOLAR_IPP_66	18:09	19:40	1:30	HAND TRIPPED
831	4-Nov-18	TUMKUR	66	TAVAREKERE (C)- GOPPENAHALLI	TAVAREKERE(C)_66	10:21	17:04	6:42	LINE CLEAR AVAILED
832	4-Nov-18	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:10	14:28	4:18	LINE FAULT
833	4-Nov-18	TUMKUR	66	TR-1 &2	DEVARAHALLI_66	0:00	0:02	0:01	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
834	5-Nov-18	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	17:06	17:10	0:04	HAND TRIPPED
835	5-Nov-18	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	17:05	17:08	0:02	HAND TRIPPED
836	5-Nov-18	TUMKUR	110	TR-1	SHETYKERE_110	13:26	15:20	1:54	LINE CLEAR AVAILED
837	5-Nov-18	TUMKUR	220	TR-1	ANTHRASANAHALLI_220	10:46	12:28	1:42	LINE CLEAR AVAILED
838	5-Nov-18	TUMKUR	220	TR-1	MADHUGIRI_220	12:36	12:45	0:09	HAND TRIPPED
839	5-Nov-18	TUMKUR	220	TR-2	MADHUGIRI_220	12:52	13:01	0:09	HAND TRIPPED
840	5-Nov-18	TUMKUR	400	GUTTUR 400- BEERANAHALLI	GUTTUR_400	11:55	17:38	5:43	HAND TRIPPED
841	5-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	16:12	16:25	0:12	LINE FAULT
842	5-Nov-18	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	10:46	12:29	1:43	HAND TRIPPED
843	5-Nov-18	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	13:28	15:41	2:13	LINE CLEAR AVAILED
844	5-Nov-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:28	18:26	9:57	HAND TRIPPED
845	5-Nov-18	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	8:42	8:53	0:10	LINE FAULT
846	5-Nov-18	TUMKUR	66	TR-2	GULIGENAHALLI_66	12:21	14:18	1:57	LINE CLEAR AVAILED
847	5-Nov-18	TUMKUR	66	TR-1	HALUVAGALU_66	12:03	12:14	0:11	LINE CLEAR AVAILED
848	5-Nov-18	TUMKUR	66	TR-1	HALUVAGALU_66	13:14	13:37	0:22	TRANSFORMER FAULT
849	5-Nov-18	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	15:47	15:57	0:09	LINE FAULT
850	5-Nov-18	TUMKUR	66	TR-1 & TR-2(LV SIDE)	MADHUGIRI_220	12:36	13:01	0:25	HAND TRIPPED
851	5-Nov-18	TUMKUR	66	TR-1	NEELAGUNDA_220	0:27	0:34	0:06	TRANSFORMER FAULT
852	5-Nov-18	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	8:42	8:57	0:15	LINE FAULT
853	5-Nov-18	TUMKUR	66	TR-1	THIMMASANDRA_66	12:35	14:00	1:25	LINE CLEAR AVAILED
854	5-Nov-18	TUMKUR	66	TR-1	YEDIYUR_66	16:05	16:37	0:31	LINE CLEAR AVAILED