

**400/220/110/66 kV TRANSMISSION OUTAGES FROM : 26.10.2021 To 01.11.2021**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	26-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN. LINE CLEAR AVOIDED
2	26-Oct-2021	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN. LINE CLEAR AVOIDED
3	26-Oct-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN. LINE CLEAR AVOIDED
4	26-Oct-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
5	26-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
6	26-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA 110	18:15 (24.06.2021)			LINE OPEN. LINE CLEAR AVOIDED
7	26-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET 66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVOIDED
8	26-Oct-2021	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED CHIKKODI_110 , KHAROSHI_33 & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
9	26-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI 220	17:40 (04.10.2021)			LINE OPEN. LINE CLEAR AVOIDED
10	26-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI 220	17:47 (04.10.2021)			LINE OPEN. LINE CLEAR AVOIDED
11	26-Oct-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:32 (23.10.2021)			LINE OPEN, LINE FAULT
12	26-Oct-2021	BAGALKOT	220	AMBEWADI- PONDA1(XELDOM)	AMBEWADI_220	17:27 (25.10.2021)	16:16 (26.10.2021)	22:49HRS	LINE CHARGED
13	26-Oct-2021	BAGALKOT	220	AMBEWADI- PONDA2	AMBEWADI_220	17:27 (25.10.2021)	16:26 (26.10.2021)	22:49HRS	LINE CHARGED
14	26-Oct-2021	BAGALKOT	220	SIRSI- SHRAVATHY1	SIRSI_220	20:11 (25.10.2021)			LINE OPEN. LINE CLEAR AVOIDED
15	26-Oct-2021	BAGALKOT	110	HAVERI-BASAVAN KATTI_110	BASAVAN KATTI_110	0:29	15:58	15:29	HAND TRIPPED
16	26-Oct-2021	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	7:38	8:38	1:00	TRANSFORMER FAULT
17	26-Oct-2021	BAGALKOT	110	ITANAL-KABBUR	KABBUR_110	11:08	13:16	2:08	LINE CLEAR AVOIDED
18	26-Oct-2021	BAGALKOT	110	110/11KV,HV2	YADAWAD_110	22:10 (26.10.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
19	26-Oct-2021	BAGALKOT	110	SAVANUR-110KV SOLAR(ASPN)	SAVANUR_110	0:15	0:20	0:05	LINE FAULT
20	26-Oct-2021	BAGALKOT	110	NAVALGUND-DHARWAD BIO	NAVALGUND_110	12:45	13:35	0:50	LINE CLEAR AVOIDED
21	26-Oct-2021	BAGALKOT	110	MUDALGI-KULIGOD	KULIGOD_110	10:45	16:25	5:40	NFBC ISSUED
22	26-Oct-2021	BAGALKOT	220	BELGAUM- KANABARGI2(NARENDRA2)	BELGAUM_220	10:55	23:59	13:04	HAND TRIPPED
23	26-Oct-2021	BAGALKOT	110	110/11KV,HV1	BAGALKOT_220	11:06	14:22	3:16	LINE CLEAR AVOIDED
24	26-Oct-2021	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	10:52	23:52	13:00	HAND TRIPPED
25	26-Oct-2021	BAGALKOT	220	220/110KV,HV1,LV1	AMBEWADI_220	17:27 (25.10.2021)	13:33 (26.10.2021)	20:06HRS	TRANSFORMER CHARGED
26	26-Oct-2021	BAGALKOT	110	110/11KV,HV1	GIRISAGARA_110	14:35	17:35	3:00	LINE CLEAR AVOIDED
27	26-Oct-2021	BAGALKOT	110	110/11KV,HV2	GIRISAGARA_110	14:35	17:35	3:00	LINE CLEAR AVOIDED
28	26-Oct-2021	BAGALKOT	110	110/11KV,HV2	SHIROL_110	11:15	12:40	1:25	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
29	26-Oct-2021	BAGALKOT	220	220/110KV,HV3	GADAG_220	10:39	18:15	7:36	LINE CLEAR AVAILED
30	26-Oct-2021	BAGALKOT	110	110/11KV,HV1	BELLATTI_110	0:05	0:45	0:40	TRANSFORMER FAULT
31	26-Oct-2021	BAGALKOT	110	KULIGOD-MUDALAGI	KULIGOD_110	10:45	16:25	5:10	LINE CLEAR AVAILED
32	26-Oct-2021	BAGALKOT	110	110/11KV,HV1	BENAKATTI_110	14:30	16:35	2:05	LINE CLEAR AVAILED
33	26-Oct-2021	BAGALKOT	110	110/11KV,HV2	BENAKATTI_110	14:30	16:35	2:05	LINE CLEAR AVAILED
34	26-Oct-2021	BAGALKOT	110	110/11KV,HV2	BENAKATTI_110	16:40	16:50	0:10	TRANSFORMER FAULT
35	26-Oct-2021	BAGALKOT	110	110/11KV,HV1	KATAKOL_110	14:35	23:59	9:24	LINE CLEAR AVAILED
36	26-Oct-2021	BAGALKOT	110	110/11KV,HV2	KATAKOL_110	18:00	18:20	0:20	LINE CLEAR AVAILED
37	26-Oct-2021	BENGALURU	66	HV2	BOODIGERE	13:38	15:51	2:13	LINE CLEAR AVAILED
38	26-Oct-2021	BENGALURU	66	HV2	DEVARABISANAHALLI	11:30	11:35	0:05	LINE CLEAR AVAILED
39	26-Oct-2021	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	18:18	18:32	0:14	LINE FAULT
40	26-Oct-2021	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	16:10	16:30	0:20	MAIN SUPPLY FAILURE
41	26-Oct-2021	BENGALURU	66	KADUGODI - EPIP 220	KADUGODI	18:18	18:33	0:15	LINE FAULT
42	26-Oct-2021	BENGALURU	66	KADUGODI - ARMY WELFARE ORGANIZATION	ARMY WELFARE ORGANIZATION, KONDASPURA	18:18	18:53	0:35	LINE FAULT
43	26-Oct-2021	BENGALURU	66	KADUGODI - ARMY WELFARE ORGANIZATION	ARMY WELFARE ORGANIZATION, KONDASPURA	19:48	21:23	1:35	LINE CLEAR AVAILED
44	26-Oct-2021	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:53	12:04	0:11	LINE FAULT
45	26-Oct-2021	BENGALURU	66	HV2	VIJAYANAGARA	12:03	12:18	0:15	TRANSFORMER FAULT
46	26-Oct-2021	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	10:36	13:30	2:54	LINE CLEAR AVAILED
47	26-Oct-2021	BENGALURU	66	HV1	VIKAS TECH PARK 220	10:45	14:00	3:15	LINE CLEAR AVAILED
48	26-Oct-2021	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	11:58	14:40	2:42	LINE CLEAR AVAILED
49	26-Oct-2021	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	13:45	14:50	1:05	LINE CLEAR AVAILED
50	26-Oct-2021	BENGALURU	220	HV2	VIKAS TECH PARK 220	12:54	14:53	1:59	LINE CLEAR AVAILED
51	26-Oct-2021	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	14:53	16:35	1:42	LINE CLEAR AVAILED
52	26-Oct-2021	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	14:53	16:35	1:42	LINE CLEAR AVAILED
53	26-Oct-2021	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	14:53	16:35	1:42	LINE CLEAR AVAILED
54	26-Oct-2021	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	14:53	16:35	1:42	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
55	26-Oct-2021	BENGALURU	66	VIDYANAGAR - HOSKOTE 220	NO STATION AFFECTED	17:51	18:37	0:46	MAIN SUPPLY FAILURE
56	26-Oct-2021	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	16:10	16:30	0:19	LINE FAULT
57	26-Oct-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	6:35	6:48	0:12	LINE FAULT
58	26-Oct-2021	BENGALURU	66	HV1	VOLVO	9:45	11:20	1:35	LINE CLEAR AVAILED
59	26-Oct-2021	BENGALURU	66	HV1	VOLVO	11:05	16:30	5:25	LINE CLEAR AVAILED
60	26-Oct-2021	BENGALURU	66	HV2	VOLVO	11:10	11:20	0:10	LINE CLEAR AVAILED
61	26-Oct-2021	BENGALURU	66	HV2	VOLVO	18:15	18:20	0:05	LINE CLEAR AVAILED
62	26-Oct-2021	BENGALURU	66	HV2	SARJAPURA 220	12:07	12:25	0:17	LINE CLEAR AVAILED
63	26-Oct-2021	BENGALURU	66	HV2	SARJAPURA 220	14:00	15:18	1:18	LINE CLEAR AVAILED
64	26-Oct-2021	BENGALURU	66	HV1	KEMBODI	12:15	12:20	0:05	LINE CLEAR AVAILED
65	26-Oct-2021	BENGALURU	66	HV2	HONNIGANAHALLI	19:05	19:10	0:04	TRANSFORMER FAULT
66	26-Oct-2021	BENGALURU	66	LV2	GOWRIBIDANUR 220	10:45	12:52	2:06	LINE CLEAR AVAILED
67	26-Oct-2021	BENGALURU	66	HV1	DABUSPET 220	10:54	14:25	3:31	LINE CLEAR AVAILED
68	26-Oct-2021	BENGALURU	66	JIGANI LINK ROAD - JIGANI 66	JIGANI LINK ROAD	16:50	16:55	0:05	LOAD CHANGE OVER
69	26-Oct-2021	BENGALURU	66	HV2	BUDIKOTE	8:45	9:30	0:45	LINE CLEAR AVAILED
70	26-Oct-2021	BENGALURU	66	HV1	GODURU	14:56	16:48	1:52	LINE CLEAR AVAILED
71	26-Oct-2021	BENGALURU	220	LV2	VIKAS TECH PARK 220	14:53:00(26/10/2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
72	26-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	0:16	10:10	9:54	LINE CLEAR AVAILED
73	26-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR1	HIRIYUR_400	11:15	18:50	7:35	NFBC ISSUED
74	26-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
75	26-Oct-2021	GULBARGA	220	HUMNABAD-HALBARGA	HALABARGA_220	15:10	17:35	2:25	LINE CLEAR AVAILED
76	26-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN. LINE CLEAR AVAILED
77	26-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN. LINE CLEAR AVAILED
78	26-Oct-2021	GULBARGA	110	GULBARGAUNIVERSITY-GULBARGASOUTH	GULBARGA UNIVERSITY_110	10:30(26.10.2021)			LINE OPEN. LINE CLEAR AVAILED
79	26-Oct-2021	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110	4:34	4:49	0:15	LINE FAULT
80	26-Oct-2021	GULBARGA	110	NIRNA-CHITGUPPA	CHITGUPPA_110	4:30	4:55	0:25	MAIN SUPPLY FAILURE
81	26-Oct-2021	GULBARGA	110	HV3	VALKAMDINNI_110	16:06	16:11	0:05	TRANSFORMER FAULT
82	26-Oct-2021	GULBARGA	110	HV3	SOMASAMUNDRA_110	11:00	17:17	6:17	LINE CLEAR AVAILED
83	26-Oct-2021	GULBARGA	110	HV1	SOMASAMUNDRA_110	13:05	16:48	3:43	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
84	26-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAM DINNI_110	1:25	1:40	0:15	LINE FAULT
85	26-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAM DINNI_110	2:22	2:30	0:08	LINE FAULT
86	26-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAM DINNI_110	4:32	4:40	0:08	LINE FAULT
87	26-Oct-2021	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110	15:04	15:12	0:08	LINE FAULT
88	26-Oct-2021	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	10:38	14:35	3:57	LINE CLEAR AVAILED
89	26-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:28	5:34	0:06	LINE FAULT
90	26-Oct-2021	GULBARGA	110	SHAHAPUR-WARAD SOLAR IPP	SHAHAPUR_220	18:57(26.10.2021)			LINE OPEN. LINE CLEAR AVAILED
91	26-Oct-2021	GULBARGA	110	ALIPUR-MINERAL	ALIPUR_220	12:30	16:45	4:15	LINE FAULT
92	26-Oct-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,M GSSK_IPP,BHALKI SUGAR IPP	10:31	16:34	6:03	NFBC ISSUED
93	26-Oct-2021	GULBARGA	110	NALWAR-SHAHPUR	NALWAR_110	4:30	4:35	0:05	LINE FAULT
94	26-Oct-2021	GULBARGA	110	NALWAR-CLEANS LR	NALWAR_110	18:10	20:50	2:40	LINE CLEAR AVAILED
95	26-Oct-2021	GULBARGA	110	HV2	DEODURGA_110	12:00	14:05	2:05	LINE CLEAR AVAILED
96	26-Oct-2021	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE_110	5:30	5:35	0:05	MAIN SUPPLY FAILURE
97	26-Oct-2021	GULBARGA	110	HV1	MATAMARI_110	13:45	13:50	0:05	TRANSFORMER FAULT
98	26-Oct-2021	GULBARGA	110	KANAKAGIRI-KUSHTAGI	KANAKAGIRI_110	11:40	12:45	1:05	LINE CLEAR AVAILED
99	26-Oct-2021	GULBARGA	110	HV2	MANVI_110	12:10	15:45	3:35	LINE CLEAR AVAILED
100	26-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	JAWALGERA_110	1:35	1:40	0:05	LINE FAULT
101	26-Oct-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	4:55	5:00	0:05	MAIN SUPPLY FAILURE
102	26-Oct-2021	GULBARGA	110	HV1	YAKATPUR_110	18:20	18:40	0:20	LINE CLEAR AVAILED
103	26-Oct-2021	GULBARGA	66	HV12	KOTTUR_66	10:15	11:35	1:20	LINE CLEAR AVAILED
104	26-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
105	26-Oct-2021	HASSAN	220	MRSSHM-VARAH1	MRS MG_220	19:43(21.10.2021)			LINE OPEN. LINE CLEAR AVAILED
106	26-Oct-2021	HASSAN	220	MRSSHM-ANTRSNH	MRS MG_220	23:32(21.10.2021)			LINE OPEN. LINE CLEAR AVAILED
107	26-Oct-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	19:32(21.10.2021)			LINE OPEN. LINE CLEAR AVAILED
108	26-Oct-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	22:30(21.10.2021)			LINE OPEN. LINE CLEAR AVAILED
109	26-Oct-2021	HASSAN	220	VARAH1-SHMG3	varahi_gen	13:10(25.10.2021)			LINE OPEN. LINE CLEAR AVAILED
110	26-Oct-2021	HASSAN	220	MRSSHM-VARAH13	MRS MG_220	13:59(25.10.2021)			LINE OPEN. LINE CLEAR AVAILED
111	26-Oct-2021	HASSAN	110	LPH-LST3	lph_gen	20:33(26.10.2021)			LINE OPEN. LINE CLEAR AVAILED
112	26-Oct-2021	HASSAN	110	LV1	ARASIKERE_220	11:45	15:47	4:02	LINE CLEAR AVAILED
113	26-Oct-2021	HASSAN	110	HV1	BANAVARA_110	10:40	12:45	2:05	MAIN SUPPLY FAILURE
114	26-Oct-2021	HASSAN	110	HV1	BANAVARA_110	12:55	14:32	1:37	LINE CLEAR AVAILED
115	26-Oct-2021	HASSAN	110	HV2	BANAVARA_110	10:40	12:45	2:05	MAIN SUPPLY FAILURE
116	26-Oct-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	11:39	13:59	2:20	LINE CLEAR AVAILED
117	26-Oct-2021	HASSAN	110	HV1	KALLUSADARAHALLY_110	10:45	13:00	2:15	MAIN SUPPLY FAILURE
118	26-Oct-2021	HASSAN	110	KALLUSA-KADUR	KALLUSADARAHALLY_110	10:45	13:00	2:15	MAIN SUPPLY FAILURE
119	26-Oct-2021	HASSAN	110	HV1	KARAYA_110	10:23	13:43	3:20	LINE CLEAR AVAILED
120	26-Oct-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	11:40	14:00	2:20	NFBC ISSUED
121	26-Oct-2021	HASSAN	110	HV1	KEMAR_220	10:38	19:03	8:25	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
122	26-Oct-2021	HASSAN	110	HV2	KEMAR_220	10:39	18:58	8:19	LINE CLEAR AVAILED
123	26-Oct-2021	HASSAN	110	SHIVAPU-BIRUR	SHIVAPURA_110	9:58	12:11	2:13	MAIN SUPPLY FAILURE
124	26-Oct-2021	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	10:35	13:28	2:53	NFBC ISSUED
125	26-Oct-2021	HASSAN	66	HV1	DODDAKADANUR_66	10:35	13:29	2:54	NFBC ISSUED
126	26-Oct-2021	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	10:35	14:26	3:51	NFBC ISSUED
127	26-Oct-2021	HASSAN	66	HV2	HALEBEEDU_66	11:20	12:45	1:25	LINE CLEAR AVAILED
128	26-Oct-2021	HASSAN	66	HV2	HALEBEEDU_66	15:13	15:51	0:38	LINE CLEAR AVAILED
129	26-Oct-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	10:26	13:21	2:55	LINE CLEAR AVAILED
130	26-Oct-2021	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	10:24	13:21	2:57	LINE CLEAR AVAILED
131	26-Oct-2021	HASSAN	66	HV1	SOMANAHALLI_66	14:29	16:24	1:55	LINE CLEAR AVAILED
132	26-Oct-2021	HASSAN	66	TAVAREC-IDLE	TAVARECHATNAHALLI_66	9:37	9:56	0:19	LINE FAULT
133	26-Oct-2021	HASSAN	66	CHANNAR-SHETHLY	CHANNARAYAPATNA_66	17:19	17:30	0:11	LINE FAULT
134	26-Oct-2021	MYSURU	66	CR NAGARA- CHANDAKAWADI	CHANDAKAVADI_66	14:16	17:33	22:44	LINE CLEAR AVAILED
135	26-Oct-2021	MYSURU	66	HV2	GVGUDI_66	12:12	12:55	0:43	TRANSFORMER FAULT
136	26-Oct-2021	MYSURU	66	HV2	HAMPAPURA_66	12:16	15:00	2:44	LINE CLEAR AVAILED
137	26-Oct-2021	MYSURU	66	HV2	KADAKOLA_66	11:01	18:31	7:30	LINE CLEAR AVAILED
138	26-Oct-2021	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66	16:55	18:49	1:54	LINE FAULT
139	26-Oct-2021	MYSURU	66	KIRUGAVALU-MALIYUR	NO STATIONS EFFECTED	5:39	5:49	0:09	LINE FAULT
140	26-Oct-2021	MYSURU	66	HV1	MADDUR_66	11:54	12:05	0:11	HAND TRIPPED
141	26-Oct-2021	MYSURU	66	MADHUVANAHALLI- KUNTHUR	NO STATIONS EFFECTED	11:57	12:04	0:06	LINE FAULT
142	26-Oct-2021	MYSURU	66	HV1	NANJANGUDU_66	12:01	12:31	0:29	LINE CLEAR AVAILED
143	26-Oct-2021	MYSURU	66	HV2	NANJANGUDU_66	11:24	11:53	0:29	LINE CLEAR AVAILED
144	26-Oct-2021	MYSURU	66	HV1	PONNAMPET_66	11:07	11:24	0:17	LINE CLEAR AVAILED
145	26-Oct-2021	MYSURU	66	HV2	SATHEGALA_66	11:51	14:10	2:18	LINE CLEAR AVAILED
146	26-Oct-2021	MYSURU	66	SANTHESARGUR-MASTER POWER	NO STATIONS EFFECTED	9:23	9:35	0:12	LINE FAULT
147	26-Oct-2021	MYSURU	66	TERAKANAMBI-CR NAGARA	TERAKANAMBE_66	16:30	16:35	0:05	HAND TRIPPED
148	26-Oct-2021	MYSURU	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	17:46	17:52	0:06	LINE FAULT
149	26-Oct-2021	MYSURU	220	HV2	TUBINKERE_220	15:10:00 (25.10.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
150	26-Oct-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN. LINE CLEAR AVAILED
151	26-Oct-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN. LINE CLEAR AVAILED
152	26-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50 (5.10.2021)			LINE OPEN. LINE CLEAR AVAILED
153	26-Oct-2021	TUMKUR	220	TR-1(HV SIDE)	THALLAK_220	17:57	18:33	0:36	LINE CLEAR AVAILED
154	26-Oct-2021	TUMKUR	220	TR-1(HV SIDE)	CHITRADURGA_220	11:07	11:46	0:39	LINE CLEAR AVAILED
155	26-Oct-2021	TUMKUR	220	TR-1(HV SIDE)	NITTUR_220	11:39	12:22	0:42	LINE CLEAR AVAILED
156	26-Oct-2021	TUMKUR	220	TR-2(HV SIDE)	NITTUR_220	12:24	12:57	0:33	LINE CLEAR AVAILED
157	26-Oct-2021	TUMKUR	110	TR-2(LV SIDE)	NITTUR_220	12:24	12:58	0:34	LINE CLEAR AVAILED
158	26-Oct-2021	TUMKUR	110	TR-1(LV SIDE)	NITTUR_220	11:39	12:23	0:43	LINE CLEAR AVAILED
159	26-Oct-2021	TUMKUR	110	TR-1(HV SIDE)	NITTUR_220	13:28	13:55	0:27	LINE CLEAR AVAILED
160	26-Oct-2021	TUMKUR	110	TR-2(HV SIDE)	NITTUR_220	13:02	13:54	0:52	LINE CLEAR AVAILED
161	26-Oct-2021	TUMKUR	66	TR-1	BELLAVI_66	7:34	11:01	3:27	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
162	26-Oct-2021	TUMKUR	66	TR-1	BHARAMAGIRI_66	11:49	12:02	0:12	LINE CLEAR AVAILED
163	26-Oct-2021	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	11:06	11:47	0:40	LINE CLEAR AVAILED
164	26-Oct-2021	TUMKUR	66	HANAGAL- B G KERE	BGKERE_66,GUDEKOTE_66	6:00	10:29	4:28	LINE CLEAR AVAILED
165	26-Oct-2021	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	5:59	10:29	4:29	LINE CLEAR AVAILED
166	26-Oct-2021	TUMKUR	66	TR-1	HANAGAL_66	5:59	10:29	4:29	LINE CLEAR AVAILED
167	26-Oct-2021	TUMKUR	66	TR-2	HANAGAL_66	5:59	10:29	4:29	LINE CLEAR AVAILED
168	26-Oct-2021	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	13:56	14:01	0:04	LINE FAULT
169	26-Oct-2021	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR_IPP_66	BPCLSOLAR_IPP_66	23:03	23:05	0:01	LINE FAULT
170	26-Oct-2021	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	BADAVANAHALLI_66	16:19	19:12	2:53	LINE FAULT
171	26-Oct-2021	TUMKUR	66	MADHUGIRI 66kV- MADHUGIRI (OLD) 220KV	MADHUGIRI_66	16:19	16:38	0:19	LINE FAULT
172	26-Oct-2021	TUMKUR	66	TR-1	MELEKOTE_66	14:22	18:06	3:44	LINE CLEAR AVAILED
173	26-Oct-2021	TUMKUR	66	NAGASAMUDRA- RAMPURA	NAGASAMUDRA_66	10:06	10:09	0:02	HAND TRIPPED
174	26-Oct-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	8:17	8:51	0:33	LINE CLEAR AVAILED
175	26-Oct-2021	TUMKUR	66	TR-2	THERIYUR_66	16:59	17:24	0:24	LINE CLEAR AVAILED
176	26-Oct-2021	TUMKUR	66	THALLAK 220kV- CHALLAKERE2	CHALLAKERE_66, SANIKERE_66	16:14	16:34	0:20	LINE FAULT
177	26-Oct-2021	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEI DIAMOND SOLAR_IPP_66	17:59	20:19	2:20	HAND TRIPPED
178	26-Oct-2021	TUMKUR	66	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	17:16	18:59	1:43	HAND TRIPPED
179	26-Oct-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	17:42	20:15	2:32	LINE CLEAR AVAILED
180	26-Oct-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUN SOLAR2	17:25	20:15	2:50	LINE CLEAR AVAILED
181	26-Oct-2021	TUMKUR	66	TR-1(LV SIDE)	THALLAK_220	17:58	18:33	0:35	LINE CLEAR AVAILED
182	26-Oct-2021	TUMKUR	66	TR-1	CHITRAHALLI_66	5:56	6:27	0:31	MAIN SUPPLY FAILURE
183	26-Oct-2021	TUMKUR	66	HANGAL66-RAMPURA	RAMPURA_66,NAGASAMU DRA_66	5:59	10:29	4:29	LINE CLEAR AVAILED
184	27-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN. LINE CLEAR AVAILED
185	27-Oct-2021	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN. LINE CLEAR AVAILED
186	27-Oct-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN. LINE CLEAR AVAILED
187	27-Oct-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
188	27-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
189	27-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN. LINE CLEAR AVAILED
190	27-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
191	27-Oct-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:32 (23.10.2021)			LINE OPEN, LINE FAULT
192	27-Oct-2021	BAGALKOT	220	SIRSI- SHRAVATHY1	SIRSI_220	20:11 (25.10.2021)			LINE OPEN. LINE CLEAR AVAILED
193	27-Oct-2021	BAGALKOT	110	110/11KV,HV2	YADAWAD_110	8:12	10:55	2:43	TRANSFORMER FAULT
194	27-Oct-2021	BAGALKOT	110	MAMADAPUR-TODALBAGI	TODALBAGI_110	11:10	11:27	0:17	HAND TRIPPED
195	27-Oct-2021	BAGALKOT	110	TODALBAGI-SAVALAGI	TODALBAGI_110	11:20	11:31	0:11	HAND TRIPPED
196	27-Oct-2021	BAGALKOT	110	KUMTA 1-SIRSI	SIRSI_110	10:10	14:20	4:10	NFBC ISSUED
197	27-Oct-2021	BAGALKOT	110	KUMTA 2-SIRSI	SIRSI_110	10:10	14:20	4:10	NFBC ISSUED
198	27-Oct-2021	BAGALKOT	110	AIGALI-SAVALAGI	SAVALAGI_110	11:33	12:24	0:51	HAND TRIPPED
199	27-Oct-2021	BAGALKOT	110	110/33KV,HV 3	GUDUR_33,KANDAGAL_33, BHANDARGAL_33 ILKAL_110	12:30	14:00	1:30	HAND TRIPPED
200	27-Oct-2021	BAGALKOT	110	110/11KV,HV4	ILKAL_110	15:45	16:20	0:35	HAND TRIPPED
201	27-Oct-2021	BAGALKOT	110	KUSHTAGI 2-ILKAL	ILKAL_110	15:05	16:15	1:10	HAND TRIPPED
202	27-Oct-2021	BAGALKOT	110	KUSHTAGI 1-ILKAL	ILKAL_110	16:20	17:20	1:00	HAND TRIPPED
203	27-Oct-2021	BAGALKOT	110	110/11KV,HV 2	MANTUR_110	13:05	14:25	1:20	HAND TRIPPED
204	27-Oct-2021	BAGALKOT	110	MALGHAN(B)-BASAVA SUGARS	MALGHAN(B)_110	20:45	20:50	0:05	LINE FAULT
205	27-Oct-2021	BAGALKOT	110	SIRSI 1-KUMTA	KUMTA_110	10:00	14:15	4:15	LINE CLEAR AVAILED
206	27-Oct-2021	BAGALKOT	110	ITNAL-BPCL 2	ITNAL_110	23:00	23:10	0:10	LINE FAULT
207	27-Oct-2021	BAGALKOT	110	KABBUR 2-ITNAL	ITNAL_110	23:00	23:10	0:10	LINE FAULT
208	27-Oct-2021	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	13:05	13:20	0:15	LINE FAULT
209	27-Oct-2021	BAGALKOT	110	HUKKERI-VSL	HUKKERI_110	13:05	13:25	0:20	LINE FAULT
210	27-Oct-2021	BAGALKOT	110	110,11KV,HV 1	HIREHAL_110	16:10	16:30	0:20	LINE CLEAR AVAILED
211	27-Oct-2021	BAGALKOT	110	DAVALESHWAR-SAIDAPUR	DAVALESHWAR_110	4:45	5:00	0:15	LINE FAULT
212	27-Oct-2021	BAGALKOT	110	GUTAL(AREMANAPUR)-HOSAHONNATTI	HOSAHONNATTI_110	15:45	15:48	0:03	HAND TRIPPED
213	27-Oct-2021	BAGALKOT	110	GUTTAL(AREMANAPUR)-HOSAHONNATTI	HOSAHONNATTI_110	16:03	17:39	1:36	HAND TRIPPED
214	27-Oct-2021	BAGALKOT	110	110/33KV,HV 4	SHIRGUPPI_33,KOTWADI_3 3 ANKALI_110	17:10	17:20	0:10	TRANSFORMER FAULT
215	27-Oct-2021	BAGALKOT	110	ALABAL-SPRS	ALABAL_110	11:30	12:45	1:15	LINE CLEAR AVAILED
216	27-Oct-2021	BAGALKOT	110	ALABAL-RAYS SOLAR	ALABAL_110	11:45	12:32	0:47	LINE CLEAR AVAILED
217	27-Oct-2021	BAGALKOT	110	ATHANI220- HALIYAL	HALIYAL_110	12:33	13:35	1:02	LINE CLEAR AVAILED
218	27-Oct-2021	BAGALKOT	110	ATHANI220- HALIYAL	HALIYAL_110	13:35	17:24	3:49	LINE CLEAR AVAILED
219	27-Oct-2021	BAGALKOT	110	ATHANI220- HALIYAL	HALIYAL_110	19:27	19:55	0:28	HAND TRIPPED
220	27-Oct-2021	BAGALKOT	110	ATHANI220-KSSKN	ATHANI_220	14:44	15:59	1:15	LINE CLEAR AVAILED
221	27-Oct-2021	BAGALKOT	220	220/110KV, HV1&LV1	CHIKKODI_220	13:01	13:06	0:05	LINE CLEAR AVAILED
222	27-Oct-2021	BAGALKOT	220	220/110KV, HV4&LV4	GADAG_220	15:05	17:10	2:05	LINE CLEAR AVAILED
223	27-Oct-2021	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	6:40 (27.10.2021)			LINE OPEN. LINE CLEAR AVAILED
224	27-Oct-2021	BAGALKOT	220	NAGJHARI1- HUBLI	HUBLI_220	15:07	18:45	3:38	LINE FAULT
225	27-Oct-2021	BAGALKOT	220	NAGJHARI2- HUBLI	HUBLI_220	12:00	18:45	6:45	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
226	27-Oct-2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	11:16	14:37	3:21	LINE FAULT
227	27-Oct-2021	BAGALKOT	110	110/11KV,HV2	MANTUR_110	13:05	14:25	01:20	LINE CLEAR AVAILED
228	27-Oct-2021	BAGALKOT	110	110/11KV,HV1	MUNDAGNUR_110	13:15	14:30	01:15	LINE CLEAR AVAILED
229	27-Oct-2021	BAGALKOT	110	110/33KV,HV4	ANKALI_110	17:10	17:15	00:05	TRANSFORMER FAULT
230	27-Oct-2021	BAGALKOT	110	110/11KV,HV1	UMMACHAGI_110	10:50	11:05	00:15	TRANSFORMER FAULT
231	27-Oct-2021	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED CHIKKODI_110 , KHAROSHI_33 & KERUR_33	21:32 (28.09.2021)	20:30 (27.10.2021)	714:02HRS	TRANSFORMER CHARGED
232	27-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN. LINE CLEAR AVAILED
233	27-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN. LINE CLEAR AVAILED
234	27-Oct-2021	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	9:07	9:09	0:02	LOAD CHANGE OVER
235	27-Oct-2021	BENGALURU	66	HV1	KUMBALAGODU	6:32	6:35	0:03	LINE CLEAR AVAILED
236	27-Oct-2021	BENGALURU	66	HV2	NIMHANS 220	12:25	12:32	0:07	LINE CLEAR AVAILED
237	27-Oct-2021	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	13:06	13:13	0:07	LOAD CHANGE OVER
238	27-Oct-2021	BENGALURU	66	PADMANABHANAGAR - SUBRAMANYAPURA 220	PADMANABHANAGAR	17:18	17:21	0:03	LOAD CHANGE OVER
239	27-Oct-2021	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	13:27	13:46	0:19	LINE FAULT
240	27-Oct-2021	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	10:29	10:42	0:13	MAIN SUPPLY FAILURE
241	27-Oct-2021	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	13:29	16:36	3:06	LINE CLEAR AVAILED
242	27-Oct-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	15:38	16:36	0:57	LINE CLEAR AVAILED
243	27-Oct-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	14:11	15:37	1:25	LINE CLEAR AVAILED
244	27-Oct-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	14:11	15:37	1:26	LINE CLEAR AVAILED
245	27-Oct-2021	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	10:29	10:42	0:13	MAIN SUPPLY FAILURE
246	27-Oct-2021	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	13:29	13:34	0:04	LINE CLEAR AVAILED
247	27-Oct-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	10:30	10:42	0:12	MAIN SUPPLY FAILURE
248	27-Oct-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	13:29	13:35	0:05	LINE CLEAR AVAILED
249	27-Oct-2021	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL(EHT)	10:30	10:42	0:12	MAIN SUPPLY FAILURE
250	27-Oct-2021	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL(EHT)	13:29	13:35	0:05	LINE CLEAR AVAILED
251	27-Oct-2021	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	6:21	6:31	0:09	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
252	27-Oct-2021	BENGALURU	66	HV3	KGF	13:56	14:09	0:13	TRANSFORMER FAULT
253	27-Oct-2021	BENGALURU	66	LV2	MALUR 220	10:30	13:34	3:04	LINE CLEAR AVAILED
254	27-Oct-2021	BENGALURU	220	HV2	MALUR 220	10:30	13:27	2:57	LINE CLEAR AVAILED
255	27-Oct-2021	BENGALURU	66	MATHIKERE - NELAMANGALA	MATHIKERE	11:05	15:37	4:32	LINE CLEAR AVAILED
256	27-Oct-2021	BENGALURU	66	HV1	SM MANGALA	13:38	13:56	0:17	LINE CLEAR AVAILED
257	27-Oct-2021	BENGALURU	66	HV2	SM MANGALA	13:32	13:44	0:11	LINE CLEAR AVAILED
258	27-Oct-2021	BENGALURU	66	HV2	SOMAYAJJANAHALLI	11:17	13:01	1:44	LINE CLEAR AVAILED
259	27-Oct-2021	BENGALURU	66	HV1	VOLVO	14:50	16:30	1:40	LINE CLEAR AVAILED
260	27-Oct-2021	BENGALURU	66	HV1	VOLVO	16:25	16:30	0:05	LINE CLEAR AVAILED
261	27-Oct-2021	BENGALURU	66	AGALKOTE - ANCHEPALYA 220	AGALKOTE	12:25	12:35	0:10	MAIN SUPPLY FAILURE
262	27-Oct-2021	BENGALURU	66	T G HALLI - ANCHEPALYA 220	T G HALLI	11:50	14:02	2:11	MAIN SUPPLY FAILURE
263	27-Oct-2021	BENGALURU	66	MAGADI 66 - ANCHEPALYA 220	MAGADI 66	11:50	14:02	2:11	MAIN SUPPLY FAILURE
264	27-Oct-2021	BENGALURU	66	GUDEMARANAHALLI - ANCHEPALYA 220	GUDEMARANAHALLI	11:50	14:02	2:11	MAIN SUPPLY FAILURE
265	27-Oct-2021	BENGALURU	220	LV2	VIKAS TECH PARK 220	14:53:00(26/10/2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
266	27-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:23(26.10.2021)	12:23(27.10.2021)	17:00HRS	LINE CHARGED
267	27-Oct-2021	GULBARGA	400	BPS-JINDAL4	BPS_400	9:48	17:06	7:18	LINE CLEAR AVAILED
268	27-Oct-2021	GULBARGA	220	HV1	SHAHAPUR_220	22:56 (27.10.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
269	27-Oct-2021	GULBARGA	220	HV1 & HV2	HUMNABAD_220	15:25	18:22	2:57	LINE CLEAR AVAILED
270	27-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
271	27-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE 110	14:55(30.07.2021)			LINE OPEN. LINE CLEAR AVAILED
272	27-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY 110	09:17(14.08.2021)			LINE OPEN. LINE CLEAR AVAILED
273	27-Oct-2021	GULBARGA	110	GULBARGAUNIVERSITY-GULBARGASOUTH	GULBARGA UNIVERSITY 110	10:30(26.10.2021)			LINE OPEN. LINE CLEAR AVAILED
274	27-Oct-2021	GULBARGA	110	SHAHAPUR-WARAD SOLAR IPP	SHAHAPUR_220	18:57(26.10.2021)	00:45(27.10.2021)	06:48HRS	LINE CHARGED
275	27-Oct-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	4:02	4:08	0:06	LINE FAULT
276	27-Oct-2021	GULBARGA	110	HV2	HATTI_110	13:02	13:13	0:11	TRANSFORMER FAULT
277	27-Oct-2021	GULBARGA	110	KAVITAL-GMSH_IPP	KAVITAL_110	8:12	8:26	0:14	LINE CLEAR AVAILED
278	27-Oct-2021	GULBARGA	110	HV2	KAVITAL_110	9:51	10:13	0:22	LINE CLEAR AVAILED
279	27-Oct-2021	GULBARGA	110	MASKI-SINDHNOOR	MASKI_110	3:42	3:50	0:08	MAIN SUPPLY FAILURE
280	27-Oct-2021	GULBARGA	110	HV1	GANDHINAGAR_110	5:27	5:43	0:16	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
281	27-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	JAWALGERA_110	2:00	2:05	0:05	LINE FAULT
282	27-Oct-2021	GULBARGA	110	HV1	JAWALGERA_110	13:15	13:40	0:25	LINE CLEAR AVAILED
283	27-Oct-2021	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	2:11	2:23	0:12	MAIN SUPPLY FAILURE
284	27-Oct-2021	GULBARGA	110	BYGWAT-MALLAT	BYGWAT_110	19:40	19:50	0:10	MAIN SUPPLY FAILURE
285	27-Oct-2021	GULBARGA	110	DUBALGUNDI-HUMNABAD	DUBALGUNDI_110	15:10	18:35	3:25	MAIN SUPPLY FAILURE
286	27-Oct-2021	GULBARGA	110	HV2	GOOGLE_110	19:30	19:35	0:05	TRANSFORMER FAULT
287	27-Oct-2021	GULBARGA	110	GULBARGAUNIVERSITY-GULBARGASOUTH	GULBARGA UNIVERSITY_110	11:25(27.10.2021)	18:00(27.10.2021)	14:35HRS	LINE CHARGED
288	27-Oct-2021	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDI NNI_110	19:40	19:50	0:10	LINE FAULT
289	27-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	11:10	12:10	1:00	LINE CLEAR AVAILED
290	27-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	18:50	18:55	0:05	LINE FAULT
291	27-Oct-2021	GULBARGA	110	SEDAM-KURUKUNTA	KURUKUNTA_110	17:02	17:47	0:45	LINE CLEAR AVAILED
292	27-Oct-2021	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORAWAR TEMPLE_110	23:15	23:25	0:10	LINE FAULT
293	27-Oct-2021	GULBARGA	110	SHAHAPUR-WARAD SOLAR IPP	SHAHAPUR_220	18:24	23:47	5:23	LINE CLEAR AVAILED
294	27-Oct-2021	GULBARGA	110	HV4	SHAHAPUR_220	22:52	23:06	0:14	TRANSFORMER FAULT
295	27-Oct-2021	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KEREHALLI_110,MALLAPUR_110	22:59 (27.10.2021)			LINE OPEN, LINE FAULT
296	27-Oct-2021	GULBARGA	110	ALIPUR-BALLARY NORTH1	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PDHALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELS_IPP	14:12	14:24	0:12	LINE CLEAR AVAILED
297	27-Oct-2021	GULBARGA	66	HV3	TELALI_66	9:10	10:10	1:00	LINE CLEAR AVAILED
298	27-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
299	27-Oct-2021	HASSAN	220	MRSSHM-VARAH1	MRS MG_220	19:43(21.10.2021)			LINE OPEN. LINE CLEAR AVAILED
300	27-Oct-2021	HASSAN	220	MRSSHM-ANTRSNH	MRS MG_220	23:32(21.10.2021)			LINE OPEN. LINE CLEAR AVAILED
301	27-Oct-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	19:32(21.10.2021)			LINE OPEN. LINE CLEAR AVAILED
302	27-Oct-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	22:30(21.10.2021)			LINE OPEN. LINE CLEAR AVAILED
303	27-Oct-2021	HASSAN	220	VARAH1-SHMG3	varahi_gen	13:10(25.10.2021)			LINE OPEN. LINE CLEAR AVAILED
304	27-Oct-2021	HASSAN	220	MRSSHM-VARAH13	MRS MG_220	13:59(25.10.2021)			LINE OPEN. LINE CLEAR AVAILED
305	27-Oct-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	14:44(27.10.2021)			LINE OPEN. LINE CLEAR AVAILED
306	27-Oct-2021	HASSAN	110	LPH-LST3	lph_gen	20:33(26.10.2021)	12:57(27.10.2021)	16:24hrs	LINE CHARGED
307	27-Oct-2021	HASSAN	220	HV2	KAVOOR_220	10:11	16:47	6:36	LINE CLEAR AVAILED
308	27-Oct-2021	HASSAN	110	LV2	KAVOOR_220	10:10	16:49	6:39	LINE CLEAR AVAILED
309	27-Oct-2021	HASSAN	220	GERSOPA-SHIMOGA	gerusoppa_gen	2:35	14:48	12:13	LINE FAULT
310	27-Oct-2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRS MG_220	2:35	14:45	12:10	LINE FAULT
311	27-Oct-2021	HASSAN	110	HV2	ANAVATTI_110	13:02	13:10	0:08	TRANSFORMER FAULT
312	27-Oct-2021	HASSAN	110	HV1	KONAJE_110	9:18	9:22	0:04	HAND TRIPPED
313	27-Oct-2021	HASSAN	110	HV1	KONAJE_110	14:36	14:40	0:04	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
314	27-Oct-2021	HASSAN	110	HV2	KONAJE_110	9:19	9:22	0:03	HAND TRIPPED
315	27-Oct-2021	HASSAN	110	HV2	KONAJE_110	14:36	14:40	0:04	HAND TRIPPED
316	27-Oct-2021	HASSAN	110	HV3	KONAJE_110	9:19	9:22	0:03	HAND TRIPPED
317	27-Oct-2021	HASSAN	110	HV3	KONAJE_110	14:36	14:40	0:04	HAND TRIPPED
318	27-Oct-2021	HASSAN	110	HV1	SAGARA_110	11:13	18:10	6:57	LINE CLEAR AVAILED
319	27-Oct-2021	HASSAN	66	HV1	CHANNARAPATNA_66	11:22	12:11	0:49	LINE CLEAR AVAILED
320	27-Oct-2021	HASSAN	66	CRPATNA2-MATTANAVILE	CRPATNA_220	11:29	12:26	0:57	LINE CLEAR AVAILED
321	27-Oct-2021	HASSAN	66	CRPATNA2-SBELAGOLA	CRPATNA_220	11:29	12:25	0:56	LINE CLEAR AVAILED
322	27-Oct-2021	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLY_66	18:30	18:34	0:04	HAND TRIPPED
323	27-Oct-2021	MYSURU	66	BESAGARAHALLI-DUDDANHALLI	NO STATIONS EFFECTED	13:59	14:44	22:44	HAND TRIPPED
324	27-Oct-2021	MYSURU	66	BESAGARAHALLI-KOPPA	NO STATIONS EFFECTED	10:47	13:59	3:12	HAND TRIPPED
325	27-Oct-2021	MYSURU	66	HV1	BOGADHI_66	11:35	12:52	1:17	LINE CLEAR AVAILED
326	27-Oct-2021	MYSURU	66	HV2	BOGADHI_66	5:16	18:31	13:15	HAND TRIPPED
327	27-Oct-2021	MYSURU	66	HV2	BOGADHI_66	11:35	18:49	7:14	LINE CLEAR AVAILED
328	27-Oct-2021	MYSURU	66	HV2	BOGADHI_66	14:04	14:10	0:05	HAND TRIPPED
329	27-Oct-2021	MYSURU	66	CR NAGARA-HONNALLY	ARKALAWADI_66 ATTIGULIPURA_66 HONNALLY MYS 66	15:46	16:18	0:32	LINE CLEAR AVAILED
330	27-Oct-2021	MYSURU	66	HV2	DEVANOORNGUDU_66	9:45	10:20	0:34	LINE CLEAR AVAILED
331	27-Oct-2021	MYSURU	66	HV2	DEVANOORNGUDU_66	12:55	16:38	3:42	LINE CLEAR AVAILED
332	27-Oct-2021	MYSURU	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	16:08	16:10	0:02	HAND TRIPPED
333	27-Oct-2021	MYSURU	66	ELIVALA-HOOTGALLY	NO STATIONS EFFECTED	7:26	11:17	3:51	NFBC ISSUED
334	27-Oct-2021	MYSURU	66	HV1	ELAVALA_66	9:34	9:53	0:19	TRANSFORMER FAULT
335	27-Oct-2021	MYSURU	66	HV1	ELAVALA_66	9:53	13:16	3:22	LINE CLEAR AVAILED
336	27-Oct-2021	MYSURU	66	HAMPAPURA-BASARALU	KOPPA_66	11:22	13:46	2:23	LINE CLEAR AVAILED
337	27-Oct-2021	MYSURU	66	KADAKOLA-SARGUR 1	HAMPAPURA_66 JAIPUR 66	6:35	6:41	0:06	LINE FAULT
338	27-Oct-2021	MYSURU	66	KHONALAGERE-IGLOOR	K_HONNALGERE_66	10:31	10:39	0:07	LINE CLEAR AVAILED
339	27-Oct-2021	MYSURU	66	KHONALA-IGLOOR	NO STATIONS EFFECTED	18:26	18:36	0:09	HAND TRIPPED
340	27-Oct-2021	MYSURU	66	KIRUGAVALU-MALIYUR	NO STATIONS EFFECTED	6:18	6:31	0:13	LINE FAULT
341	27-Oct-2021	MYSURU	66	KIRUGAVALU-MALIYUR	NO STATIONS EFFECTED	7:07	7:16	0:09	LINE FAULT
342	27-Oct-2021	MYSURU	66	HV2	MALAVALLI_66	18:17	18:18	0:01	HAND TRIPPED
343	27-Oct-2021	MYSURU	66	TN PURA-THAYUR	TNARASIPURA_66	8:10	8:54	0:44	LINE FAULT
344	27-Oct-2021	MYSURU	66	TUBINKERE-NAGAMGL1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BGNAGARA_66 HARADANAHALLI_66 VADERALLI_66	23:30	23:35	0:05	LINE FAULT
345	27-Oct-2021	MYSURU	66	HV1	VAJAMANGALA_220	12:42	13:54	1:12	LINE CLEAR AVAILED
346	27-Oct-2021	MYSURU	220	HV2	TUBINKERE_220	15:10:00 (25.10.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
347	27-Oct-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN. LINE CLEAR AVAILED
348	27-Oct-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN. LINE CLEAR AVAILED
349	27-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50 (5.10.2021)			LINE OPEN. LINE CLEAR AVAILED
350	27-Oct-2021	TUMKUR	220	TR-1(HV SIDE)	CHITRADURGA_220	1:34	2:14	0:40	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
351	27-Oct-2021	TUMKUR	220	TR-2(HV SIDE)	CHITRADURGA_220	1:34	2:14	0:40	TRANSFORMER FAULT
352	27-Oct-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	19:46	19:58	0:11	HAND TRIPPED
353	27-Oct-2021	TUMKUR	110	TR-1	KALLUR_110	15:16	15:24	0:07	HAND TRIPPED
354	27-Oct-2021	TUMKUR	110	TR-1	KEREKODI_110	10:10	12:22	2:12	LINE CLEAR AVAILED
355	27-Oct-2021	TUMKUR	110	KEREKODI-HONNAVALI 110	KEREKODI_110	10:39	12:21	1:42	LINE CLEAR AVAILED
356	27-Oct-2021	TUMKUR	110	TR-1(LV SIDE)	CHITRADURGA_220	1:34	2:15	0:40	TRANSFORMER FAULT
357	27-Oct-2021	TUMKUR	66	TR-2(LV SIDE)	CHITRADURGA_220	1:34	2:16	0:41	TRANSFORMER FAULT
358	27-Oct-2021	TUMKUR	66	CHITRADURGA 66KV-PANDARAHALLI 2	CHITRADURGA_66 OLD MUSS,PANDARAHALLI_66, CHITRAHALLI_66,HDPURA_66,HOLALKERE_66,RAMGIRI_66	2:09	2:23	0:13	MAIN SUPPLY FAILURE
359	27-Oct-2021	TUMKUR	66	CHITRADURGA 66KV-PANDARAHALLI 2	CHITRADURGA_66 OLD MUSS,PANDARAHALLI_66, CHITRAHALLI_66,HDPURA_66,HOLALKERE_66,RAMGIRI_66	12:01	12:23	0:21	HAND TRIPPED
360	27-Oct-2021	TUMKUR	66	CHITRADURGA 66KV-MEGMICON 1_IPP_66	MEGMICON 1_IPP_66	2:10	2:29	0:18	MAIN SUPPLY FAILURE
361	27-Oct-2021	TUMKUR	66	CHITRADURGA 66KV-MEGMICON 2_IPP_66	MEGMICON 2_IPP_66	2:10	2:29	0:18	MAIN SUPPLY FAILURE
362	27-Oct-2021	TUMKUR	66	TR-1	DEVARAHALLI_66	13:27	14:20	0:52	MAIN SUPPLY FAILURE
363	27-Oct-2021	TUMKUR	66	DAVANGERE SRS-AVAREGERE66	AVAREGERE_66,MELLEKATE_66,KADAJI_66	10:01	17:33	7:31	LINE CLEAR AVAILED
364	27-Oct-2021	TUMKUR	66	HANAGAL- B G KERE	BGKERE_66,GUDEKOTE_66	6:04	10:16	4:12	LINE CLEAR AVAILED
365	27-Oct-2021	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	6:03	10:16	4:13	LINE CLEAR AVAILED
366	27-Oct-2021	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	14:39	14:43	0:03	LINE FAULT
367	27-Oct-2021	TUMKUR	66	TR-1	HANAGAL_66	6:04	10:16	4:12	LINE CLEAR AVAILED
368	27-Oct-2021	TUMKUR	66	TR-2	HANAGAL_66	6:03	10:16	4:13	LINE CLEAR AVAILED
369	27-Oct-2021	TUMKUR	66	HANGAL66-RAMPURA	RAMPURA_66,NAGASAMUDRA_66	6:04	10:16	4:12	LINE CLEAR AVAILED
370	27-Oct-2021	TUMKUR	66	HANGAL66-RAMPURA	RAMPURA_66,NAGASAMUDRA_66	14:42	14:49	0:06	LINE FAULT
371	27-Oct-2021	TUMKUR	66	HIRIYUR 220KV-BEVINAHALLI	BEVINAHALLI_66	10:01	10:30	0:29	LINE FAULT
372	27-Oct-2021	TUMKUR	66	HIRIYUR 220KV-RANGANATHPURA	RANGANATHAPURA_66	10:33	10:40	0:07	HAND TRIPPED
373	27-Oct-2021	TUMKUR	66	HIRIYUR 220KV-RANGANATHPURA	RANGANATHAPURA_66	11:20	12:23	1:02	LINE CLEAR AVAILED
374	27-Oct-2021	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	11:37	11:45	0:07	LINE FAULT
375	27-Oct-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	11:45	11:54	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
376	27-Oct-2021	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	13:26	14:04	0:37	LINE CLEAR AVAILED
377	27-Oct-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNA GIRI_66	13:26	14:04	0:37	LINE CLEAR AVAILED
378	27-Oct-2021	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	BADAVANAHALLI_66	10:29	12:04	1:35	LINE CLEAR AVAILED
379	27-Oct-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	13:18	13:24	0:05	TRANSFORMER FAULT
380	27-Oct-2021	TUMKUR	66	NAGASAMUDRA- RAMPURA	NAGASAMUDRA_66	9:59	10:00	0:01	MAIN SUPPLY FAILURE
381	27-Oct-2021	TUMKUR	66	TR-1	RAMAPURA_66	10:09	10:15	0:06	MAIN SUPPLY FAILURE
382	27-Oct-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	11:14	12:24	1:09	LINE CLEAR AVAILED
383	27-Oct-2021	TUMKUR	66	TR-2	RANGANATHAPURA_66	11:12	12:23	1:10	LINE CLEAR AVAILED
384	27-Oct-2021	TUMKUR	66	RANGANATHAPURA- WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	10:37	12:26	1:48	LINE CLEAR AVAILED
385	27-Oct-2021	TUMKUR	66	RANGANATHAPURA- WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	10:37	12:26	1:48	LINE CLEAR AVAILED
386	27-Oct-2021	TUMKUR	66	SASALUHALLA-MAYAKONDA	SASALUHALLA_66	11:08	11:36	0:28	MAIN SUPPLY FAILURE
387	27-Oct-2021	TUMKUR	66	SASALUHALLA-MAYAKONDA	SASALUHALLA_66	12:01	12:36	0:34	MAIN SUPPLY FAILURE
388	27-Oct-2021	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	11:25	11:38	0:13	HAND TRIPPED
389	27-Oct-2021	TUMKUR	66	TR-2	HULIYURDURGA_66	9:32	13:56	4:23	LINE CLEAR AVAILED
390	28-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN. LINE CLEAR AVAILED
391	28-Oct-2021	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN. LINE CLEAR AVAILED
392	28-Oct-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN. LINE CLEAR AVAILED
393	28-Oct-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
394	28-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
395	28-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN. LINE CLEAR AVAILED
396	28-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
397	28-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN. LINE CLEAR AVAILED
398	28-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN. LINE CLEAR AVAILED
399	28-Oct-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:32 (23.10.2021)			LINE OPEN, LINE FAULT
400	28-Oct-2021	BAGALKOT	220	SIRSI- SHRAVATHY1	SIRSI_220	20:11 (25.10.2021)			LINE OPEN. LINE CLEAR AVAILED
401	28-Oct-2021	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	6:40 (27.10.2021)			LINE OPEN. LINE CLEAR AVAILED
402	28-Oct-2021	BAGALKOT	220	220/110KV, HV1&LV1	CHIKKODI_220	13:01 (27.10.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
403	28-Oct-2021	BAGALKOT	110	110/11KV,HV1	AKSHAYA COLONY_110	6:39 (28.10.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
404	28-Oct-2021	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110 & KAROSHI &KERUR_33	13:03	17:09	4:06	LINE CLEAR AVAILED
405	28-Oct-2021	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110,KAROSHI_3 3 &KERUR_33	18:01	18:12	0:11	HAND TRIPPED
406	28-Oct-2021	BAGALKOT	110	110/33KV,HV1	CHIKKODI_110,KAKABBUR_ 33,VIJAYANAGAR_33	18:00	18:02	0:02	HAND TRIPPED
407	28-Oct-2021	BAGALKOT	110	MAHALINGPUR(MUDHOL)- UTTUR	UTTUR_110	14:05 (4.10.2021)	10:44 (28.10.2021)	572:39HRS	LINE CHARGED
408	28-Oct-2021	BAGALKOT	110	MAHALINGPUR-UTTUR	UTTUR_110	13:20	13:24	0:04	HAND TRIPPED
409	28-Oct-2021	BAGALKOT	110	110/11KV,HV2	UTTUR_110	10:34	10:45	0:11	TRANSFORMER FAULT
410	28-Oct-2021	BAGALKOT	110	110/11KV,HV2	UTTUR_110	13:20	13:25	0:05	TRANSFORMER FAULT
411	28-Oct-2021	BAGALKOT	110	MAHALINGPUR- RANNABELAGALI	RANNABELAGALI_110	9:00	13:25	4:25	LINE CLEAR AVAILED
412	28-Oct-2021	BAGALKOT	110	UMACHAGI-KIRUVATTI	KIRUVATTI_110	8:45 (12.10.2021)	9:30 (28.10.2021)	360:45HRS	LINE CHARGED
413	28-Oct-2021	BAGALKOT	110	110/11KV, HV1	SIRSI_220	9:50	17:21	7:31	LINE CLEAR AVAILED
414	28-Oct-2021	BAGALKOT	110	HAVERI220- HANGAL(TILUVALLI)	TILUVALLI_110	3:51	4:08	0:17	LINE FAULT
415	28-Oct-2021	BAGALKOT	110	HAVERI220- HANGAL(TILUVALLI)	TILUVALLI_110	12:48	17:11	0:17	LINE CLEAR AVAILED
416	28-Oct-2021	BAGALKOT	110	KARWAR220- ARGA	ARGA_110	9:33	13:47	4:14	LINE CLEAR AVAILED
417	28-Oct-2021	BAGALKOT	220	HIREBENDIGERI2(TADAS2)- BIDNAL	BIDNAL_220	9:06	17:19	8:13	LINE CLEAR AVAILED
418	28-Oct-2021	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	12:05	15:55	3:50	LINE CLEAR AVAILED
419	28-Oct-2021	BAGALKOT	110	SIRSI-KAVALWADA	SIRSI_220	9:50	17:41	7:51	LINE CLEAR AVAILED
420	28-Oct-2021	BAGALKOT	110	SIRSI-UMMACHAGI	SIRSI_220	9:33	17:47	8:14	LINE CLEAR AVAILED
421	28-Oct-2021	BAGALKOT	110	110/11KV,HV1	UMMACHAGI_110	10:50	11:05	0:15	TRANSFORMER FAULT
422	28-Oct-2021	BAGALKOT	220	110/33KV,HV1	CHIKKODI_220	16:50	17:10	0:20	LINE CLEAR AVAILED
423	28-Oct-2021	BAGALKOT	110	INDI-DEVARAHIPPARAGI	INDI_220	17:47	18:00	0:13	LINE FAULT
424	28-Oct-2021	BAGALKOT	110	110/11KV,HV1	KATKOL_110	10:55	18:10	7:15	LINE CLEAR AVAILED
425	28-Oct-2021	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI	11:50	11:55	0:05	LOAD CHANGE OVER
426	28-Oct-2021	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	10:02	10:08	0:06	LINE FAULT
427	28-Oct-2021	BENGALURU	66	HV1	BANASWADI	11:10	11:15	0:05	LOAD CHANGE OVER
428	28-Oct-2021	BENGALURU	66	HV3	BANASWADI	11:10	11:15	0:05	LOAD CHANGE OVER
429	28-Oct-2021	BENGALURU	220	HOODY 220 - MALUR 220	NO STATION AFFECTED	6:05	11:25	5:20	LINE FAULT
430	28-Oct-2021	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	5:46	6:29	0:43	LINE FAULT
431	28-Oct-2021	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	13:30	14:02	0:32	LINE FAULT
432	28-Oct-2021	BENGALURU	66	HV1	RMV	11:36	11:57	0:21	LINE CLEAR AVAILED
433	28-Oct-2021	BENGALURU	66	HV2	RMV	11:36	11:57	0:21	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
434	28-Oct-2021	BENGALURU	66	ST.JOHNS WOOD - HSR LAYOUT 220	ST.JOHNS WOOD	13:27	13:33	0:06	LOAD CHANGE OVER
435	28-Oct-2021	BENGALURU	66	ST.JOHNS WOOD - ADUGODI	ST.JOHNS WOOD	13:49	13:54	0:05	LOAD CHANGE OVER
436	28-Oct-2021	BENGALURU	66	SUBRAMANYAPURA 220 - RR NAGAR	RR NAGAR	11:53	11:57	0:04	LINE CLEAR AVAILED
437	28-Oct-2021	BENGALURU	66	SUBRAMANYAPURA 220 - RR NAGAR	RR NAGAR	14:02	14:14	0:12	LINE CLEAR AVAILED
438	28-Oct-2021	BENGALURU	66	HV2	REMCO	11:53	11:57	0:04	MAIN SUPPLY FAILURE
439	28-Oct-2021	BENGALURU	66	HV2	REMCO	14:02	14:14	0:12	MAIN SUPPLY FAILURE
440	28-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	5:15	6:09	0:54	LINE FAULT
441	28-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	10:02	10:27	0:25	LINE FAULT
442	28-Oct-2021	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	10:32	10:54	0:22	MAIN SUPPLY FAILURE
443	28-Oct-2021	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	10:32	10:54	0:22	LINE CLEAR AVAILED
444	28-Oct-2021	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	10:32	10:54	0:22	LINE CLEAR AVAILED
445	28-Oct-2021	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	10:32	10:54	0:22	LINE CLEAR AVAILED
446	28-Oct-2021	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	10:32	10:54	0:22	LINE CLEAR AVAILED
447	28-Oct-2021	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	11:56	12:53	0:56	LINE CLEAR AVAILED
448	28-Oct-2021	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	10:31	10:40	0:08	LINE FAULT
449	28-Oct-2021	BENGALURU	66	KOLAR 220 - MULBAGAL	NO STATION AFFECTED	15:26	17:35	2:08	LINE CLEAR AVAILED
450	28-Oct-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	5:41	5:53	0:11	LINE FAULT
451	28-Oct-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	11:22	11:24	0:01	LINE CLEAR AVAILED
452	28-Oct-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	11:22	11:24	0:01	LINE CLEAR AVAILED
453	28-Oct-2021	BENGALURU	66	HV1	KYALANUR	13:02	14:01	0:59	LINE CLEAR AVAILED
454	28-Oct-2021	BENGALURU	66	HV2	MELUR	12:07	13:20	1:13	LINE CLEAR AVAILED
455	28-Oct-2021	BENGALURU	66	HV2	MELUR	16:09	17:08	0:58	LINE CLEAR AVAILED
456	28-Oct-2021	BENGALURU	66	HV2	VOLVO	0:55	1:15	0:20	TRANSFORMER FAULT
457	28-Oct-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	10:31	10:57	0:25	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
458	28-Oct-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:31	10:56	0:24	MAIN SUPPLY FAILURE
459	28-Oct-2021	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	10:31	10:57	0:25	MAIN SUPPLY FAILURE
460	28-Oct-2021	BENGALURU	66	HV1	SARJAPURA 220	10:31	10:57	0:25	MAIN SUPPLY FAILURE
461	28-Oct-2021	BENGALURU	66	HV2	SARJAPURA 220	10:31	10:55	0:23	MAIN SUPPLY FAILURE
462	28-Oct-2021	BENGALURU	220	HV1	SARJAPURA 220	10:31	10:55	0:23	MAIN SUPPLY FAILURE
463	28-Oct-2021	BENGALURU	220	HV2	SARJAPURA 220	10:31	10:56	0:24	MAIN SUPPLY FAILURE
464	28-Oct-2021	BENGALURU	220	MALUR 220 - SOMANHALLI 1	SARJAPURA 220, VIKAS TECH PARK 220	10:31	10:52	0:20	MAIN SUPPLY FAILURE
465	28-Oct-2021	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	12:55	13:00	0:05	LINE CLEAR AVAILED
466	28-Oct-2021	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR	13:05	14:45	1:40	LINE CLEAR AVAILED
467	28-Oct-2021	BENGALURU	66	HV1	H GOLLAHALLI	7:48(28-10-2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
468	28-Oct-2021	BENGALURU	66	HV2	ANEKAL	22:47(28-10-2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
469	28-Oct-2021	BENGALURU	220	LV2	VIKAS TECH PARK 220	14:53:00(26/10/2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
470	28-Oct-2021	GULBARGA	220	HV1	SHAHAPUR_220	22:56 (27.10.2021)	4:56 (28.10.2021)	6:00 HRS	TRANSFORMER CHARGED
471	28-Oct-2021	GULBARGA	220	HV1	SHAHAPUR_220	12:30	17:48	5:18	LINE CLEAR AVAILED
472	28-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
473	28-Oct-2021	GULBARGA	220	HV2	NEELAGUNDA_220	5:54	5:56	0:02	TRANSFORMER FAULT
474	28-Oct-2021	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	23:25	23:34	0:09	LINE FAULT
475	28-Oct-2021	GULBARGA	220	LINGAPUR-GDHALLI2	GDHALLI_220,DHRUVADES H_IPP	11:23	17:22	5:59	LINE CLEAR AVAILED
476	28-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN. LINE CLEAR AVAILED
477	28-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN. LINE CLEAR AVAILED
478	28-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	17:52(28.10.2021)			MAIN SUPPLY FAILURE
479	28-Oct-2021	GULBARGA	110	KADAGANCHI-TCDSOLAR_IPP	KADAGANCHI_110	22:05(28.10.2021)			LINE OPEN. LINE CLEAR AVAILED
480	28-Oct-2021	GULBARGA	110	MASKI-SINDHNOOR	MASKI_110	1:23	1:28	0:05	MAIN SUPPLY FAILURE
481	28-Oct-2021	GULBARGA	110	MASKI-SINDHNOOR	MASKI_110	9:15	9:18	0:03	MAIN SUPPLY FAILURE
482	28-Oct-2021	GULBARGA	110	NIRNA-CHITGUPPA	NIRNA_110	5:15	5:25	0:10	MAIN SUPPLY FAILURE
483	28-Oct-2021	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KEREHALLI_110,MALLAPUR_110	22:59 (27.10.2021)	00:15 (28.10.2021)	1:16 HRS	LINE CHARGED
484	28-Oct-2021	GULBARGA	110	NIRNA-CHITGUPPA	NIRNA_110	18:10	18:20	0:10	MAIN SUPPLY FAILURE
485	28-Oct-2021	GULBARGA	110	VALKAMDINNI-SINDHANOOR110	VALKAMDINNI_110	19:50	20:00	0:10	MAIN SUPPLY FAILURE



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
486	28-Oct-2021	GULBARGA	110	JAWALAGERA-ADAVI AMARESHWARA	JAWALAGERA_110	4:55	5:00	0:05	MAIN SUPPLY FAILURE
487	28-Oct-2021	GULBARGA	110	JAWALAGERA-ADAVI AMARESHWARA	JAWALAGERA_110	19:15	19:25	0:10	LINE FAULT
488	28-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	17:57	18:02	0:05	MAIN SUPPLY FAILURE
489	28-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	21:10	21:20	0:10	LINE CLEAR AVAILED
490	28-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	13:05	13:15	0:10	LINE CLEAR AVAILED
491	28-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAM DINNI_110	22:50	23:00	0:10	LINE FAULT
492	28-Oct-2021	GULBARGA	110	MALLAT-MADLAPUR	ADVIAMARESHWARA_110	19:18	19:29	0:11	LINE FAULT
493	28-Oct-2021	GULBARGA	110	SINDHANOOR- SINDHANOOR1	SINDHANOOR_110,MUDDA PUR_110,MASKI_110	1:18	1:28	0:10	LINE FAULT
494	28-Oct-2021	GULBARGA	110	SINDHANOOR-ADAVI AMARESHWAR	ADAVI AMARESHWARA_110	19:20	19:30	0:10	MAIN SUPPLY FAILURE
495	28-Oct-2021	GULBARGA	110	SHAHAPUR-RAICHUR 1& 2	DEODURGA_110	13:04	21:14	8:10	LINE CLEAR AVAILED
496	28-Oct-2021	GULBARGA	110	HV3	SHAHAPUR_220	16:15	18:05	1:50	LINE CLEAR AVAILED
497	28-Oct-2021	GULBARGA	110	SINDHANOOR- SINDHANOOR1	SINDHANOOR_110,MUDDA PUR_110,MASKI_110,VALA KAMADINNI_110	1:18	1:28	13:40	LINE FAULT
498	28-Oct-2021	GULBARGA	110	SINDHANOOR- PGLR WIND IPP	SINDHANOOR_220	7:15	13:40	13:40	LINE CLEAR AVAILED
499	28-Oct-2021	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESU GUR_110,SIRIGERA CROSS_110,NSL SUGAR IPP,VOORA IPP,	9:10	12:22	13:40	LINE FAULT
500	28-Oct-2021	GULBARGA	110	SINDHANOOR- ADVIAMARESHWARA	ADVIAMARESHWARA_11 0	9:10	12:32	13:40	LINE FAULT
501	28-Oct-2021	GULBARGA	110	SINDHANOOR- ADVIAMARESHWARA	ADVIAMARESHWARA_11 0	22:06	22:16	13:40	LINE FAULT
502	28-Oct-2021	GULBARGA	110	SINDHANOOR- SINDHANOOR1&2	SINDHANOOR_110,MUDDA PUR_110,MASKI_110	9:10	13:55	13:40	LINE FAULT
503	28-Oct-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	14:20	14:30	0:10	LINE FAULT
504	28-Oct-2021	GULBARGA	110	SINDHANOOR- SINDHANOOR2	SINDHANOOR_110,,VALAK AMADINNI_110,	19:50	20:00	0:10	LINE FAULT
505	28-Oct-2021	GULBARGA	110	KAVITAL-SINDHANOOR(IDLE LINE)	KAVITAL_110	3:42(28.10.2021)			LINE OPEN, LINE FAULT
506	28-Oct-2021	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	11:07	11:40	0:33	MAIN SUPPLY FAILURE
507	28-Oct-2021	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	17:32	17:38	0:06	MAIN SUPPLY FAILURE
508	28-Oct-2021	GULBARGA	110	HV1	CHOWDAPUR_110	17:03	17:08	0:05	TRANSFORMER FAULT
509	28-Oct-2021	GULBARGA	110	HV1	GOOGLE_110	9:00	11:25	2:25	LINE CLEAR AVAILED
510	28-Oct-2021	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE_110	12:55	13:05	0:10	MAIN SUPPLY FAILURE
511	28-Oct-2021	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE_110	18:00	18:10	0:10	MAIN SUPPLY FAILURE
512	28-Oct-2021	GULBARGA	110	HV2	MATAMARI_110	12:00	18:20	6:20	LINE CLEAR AVAILED
513	28-Oct-2021	GULBARGA	66	GUDEKOTE-BADALADUKU	GUDEKOTE_66	7:15	7:20	0:05	MAIN SUPPLY FAILURE
514	28-Oct-2021	GULBARGA	66	HALAVAGALU-NEELAGUNDA	HALAVAGALU_66	5:40	6:00	0:20	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
515	28-Oct-2021	GULBARGA	66	HARAPANAHALLI-NEELAGUNDA	HARAPANAHALLI_66	5:45	6:00	0:15	MAIN SUPPLY FAILURE
516	28-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
517	28-Oct-2021	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	19:43(21.10.2021)			LINE OPEN. LINE CLEAR AVAILED
518	28-Oct-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	23:32(21.10.2021)			LINE OPEN. LINE CLEAR AVAILED
519	28-Oct-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	19:32(21.10.2021)			LINE OPEN. LINE CLEAR AVAILED
520	28-Oct-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	22:30(21.10.2021)			LINE OPEN. LINE CLEAR AVAILED
521	28-Oct-2021	HASSAN	220	VARAH1-SHMG3	varahi_gen	13:10(25.10.2021)			LINE OPEN. LINE CLEAR AVAILED
522	28-Oct-2021	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	13:59(25.10.2021)			LINE OPEN. LINE CLEAR AVAILED
523	28-Oct-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	14:44(27.10.2021)			LINE OPEN. LINE CLEAR AVAILED
524	28-Oct-2021	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	14:12	14:55	0:43	HAND TRIPPED
525	28-Oct-2021	HASSAN	220	HV1	MSEZ_220	14:58	16:26	1:28	LINE CLEAR AVAILED
526	28-Oct-2021	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	9:44	18:30	8:46	HAND TRIPPED
527	28-Oct-2021	HASSAN	110	AJAMPU-KADUR	AJJAMPURA_110	10:00	15:10	5:10	LINE CLEAR AVAILED
528	28-Oct-2021	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	12:10	19:41	7:31	LINE CLEAR AVAILED
529	28-Oct-2021	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_110	10:04	15:15	5:11	LINE CLEAR AVAILED
530	28-Oct-2021	HASSAN	110	KADUR-AJAMPURA	KADUR_220	10:00	15:11	5:11	LINE CLEAR AVAILED
531	28-Oct-2021	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	9:56	10:04	0:08	LINE FAULT
532	28-Oct-2021	HASSAN	66	HV1	HAGARE_66	11:47	12:52	1:05	LINE CLEAR AVAILED
533	28-Oct-2021	HASSAN	66	HV2	HALLIMYSORE_66	9:50	10:23	0:33	LINE CLEAR AVAILED
534	28-Oct-2021	HASSAN	66	HV1	YESLUR_66	9:57	10:06	0:09	MAIN SUPPLY FAILURE
535	28-Oct-2021	MYSURU	66	HV1	HANNUR_66	13:02	14:17	22:44	LINE CLEAR AVAILED
536	28-Oct-2021	MYSURU	66	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	10:52	11:17	0:25	HAND TRIPPED
537	28-Oct-2021	MYSURU	66	HV2	MALAVALLI_66	1:46	18:31	16:45	LINE CLEAR AVAILED
538	28-Oct-2021	MYSURU	66	MEGALAPURA-HEBBANI	THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66 CHIDRAVALLI_66BGPURA_66 THALAKADU_66 CHANDALLI_66	11:35	18:49	7:14	LINE FAULT
539	28-Oct-2021	MYSURU	66	TALAKADU-PARINAMIPURA	NO STATIONS EFFECTED	12:15	15:00	2:45	LINE CLEAR AVAILED
540	28-Oct-2021	MYSURU	66	TN PURA-THAYUR	NO STATIONS EFFECTED	14:48	15:15	0:26	HAND TRIPPED
541	28-Oct-2021	MYSURU	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	18:04	18:11	0:07	LINE FAULT
542	28-Oct-2021	MYSURU	66	HOOTAGALLI-RBI	NO STATIONS EFFECTED	0:05	0:24	0:19	LINE FAULT
543	28-Oct-2021	MYSURU	220	HV2	TUBINKERE_220	15:10:00(25.10.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
544	28-Oct-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN. LINE CLEAR AVAILED
545	28-Oct-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN. LINE CLEAR AVAILED
546	28-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50 (5.10.2021)			LINE OPEN. LINE CLEAR AVAILED
547	28-Oct-2021	MYSURU	66	HV1	ELAVALA_66	18:57:03 (27.10.2021)	13:45:00 (28.10.2021)	18:47HRS	TRANSFORMER CHARGED
548	28-Oct-2021	TUMKUR	110	TR-3	GUBBI_110	13:30	13:53	0:23	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
549	28-Oct-2021	TUMKUR	110	KB CROSS 220kv-MAYASANDRA	MAYASANDRA_110, TALKERE_110,KADEHALLI_110,	4:57	5:21	0:23	LINE FAULT
550	28-Oct-2021	TUMKUR	66	ANTHRASANAHALI 220KV-CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI 66	16:48	17:05	0:16	LINE FAULT
551	28-Oct-2021	TUMKUR	66	ANTHRASANAHALI 220kv-KOLTEGERE	KOLTEGERE,CHIKKATOTLUKERE_66,BELADARA_66	8:12	8:58	0:46	LINE FAULT
552	28-Oct-2021	TUMKUR	66	TR-1	BELLAVI_66	9:29	9:53	0:23	LINE CLEAR AVAILED
553	28-Oct-2021	TUMKUR	66	TR-2	BHARAMAGIRI_66	5:00	5:05	0:05	TRANSFORMER FAULT
554	28-Oct-2021	TUMKUR	66	BHARAMAGIRI66-SRS 220KV HIRIYUR	BHARAMAGIRI_66	10:28	10:38	0:10	LINE FAULT
555	28-Oct-2021	TUMKUR	66	TR-2	BHARAMAGIRI_66	20:50	20:53	0:03	TRANSFORMER FAULT
556	28-Oct-2021	TUMKUR	66	HANAGAL- B G KERE	BGKERE_66,GUDEKOTE_66	5:58	10:05	4:07	LINE CLEAR AVAILED
557	28-Oct-2021	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	5:57	9:39	3:41	LINE CLEAR AVAILED
558	28-Oct-2021	TUMKUR	66	TR-1	HANAGAL_66	5:57	9:44	3:46	LINE CLEAR AVAILED
559	28-Oct-2021	TUMKUR	66	TR-2	HANAGAL_66	5:57	9:39	3:41	LINE CLEAR AVAILED
560	28-Oct-2021	TUMKUR	66	HANGAL66-RAMPURA	RAMPURA_66,NAGASAMUDRA_66	5:57	9:39	3:41	LINE CLEAR AVAILED
561	28-Oct-2021	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	18:27	18:29	0:02	HAND TRIPPED
562	28-Oct-2021	TUMKUR	66	TR-2	HINDASGHATTA_66	13:55	13:57	0:01	HAND TRIPPED
563	28-Oct-2021	TUMKUR	66	TR-2	HONNALLI_220	11:34	14:57	3:23	LINE CLEAR AVAILED
564	28-Oct-2021	TUMKUR	66	HONNALLI 220kv-KUNDUR66	KUNDUR_66,MALEBENNUR_66,DEVARABELKERE_66	18:06	18:15	0:09	LINE FAULT
565	28-Oct-2021	TUMKUR	66	TR-2	HULIYURDURGA_66	4:17	4:25	0:08	TRANSFORMER FAULT
566	28-Oct-2021	TUMKUR	66	TR-2	HULIYURDURGA_66	9:29	16:37	7:07	LINE CLEAR AVAILED
567	28-Oct-2021	TUMKUR	66	TR-2	KORA_66	0:29	0:42	0:13	TRANSFORMER FAULT
568	28-Oct-2021	TUMKUR	66	NAGASAMUDRA- RAMPURA	NAGASAMUDRA_66	9:26	9:38	0:12	MAIN SUPPLY FAILURE
569	28-Oct-2021	TUMKUR	66	TR-2	TAVAREKERE(H)	11:33	12:04	0:30	LINE CLEAR AVAILED
570	28-Oct-2021	TUMKUR	66	PD KOTE66-AZURE POWER IPP_66	AZURE POWER_IPP_66	18:25	19:32	1:06	HAND TRIPPED
571	28-Oct-2021	TUMKUR	66	PD KOTE 66-CLEAR SOLAR IPP_66	CLEAR SOLAR_IPP_66	18:25	19:03	0:38	HAND TRIPPED
572	28-Oct-2021	TUMKUR	66	PD KOTE66-SOLITAIRE IPP_66	SOLITAIRE_IPP_66	18:25	19:31	1:06	HAND TRIPPED
573	28-Oct-2021	TUMKUR	66	PDKOTE66-HIRIYUR_66	PD KOTE_66	18:23	18:28	0:05	LINE FAULT
574	29-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN. LINE CLEAR AVAILED
575	29-Oct-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN. LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
576	29-Oct-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN. LINE CLEAR AVAILED
577	29-Oct-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
578	29-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
579	29-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN. LINE CLEAR AVAILED
580	29-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
581	29-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN. LINE CLEAR AVAILED
582	29-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN. LINE CLEAR AVAILED
583	29-Oct-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:32 (23.10.2021)			LINE OPEN, LINE FAULT
584	29-Oct-2021	BAGALKOT	220	SIRSI- SHRAVATHY1	SIRSI_220	20:11 (25.10.2021)			LINE OPEN. LINE CLEAR AVAILED
585	29-Oct-2021	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	6:40 (27.10.2021)			LINE OPEN. LINE CLEAR AVAILED
586	29-Oct-2021	BAGALKOT	220	220/110KV, HV1&LV1	CHIKKODI_220	13:01 (27.10.2021)	21:15 (29.10.2021)	55:09HRS	TRANSFORMER CHARGED
587	29-Oct-2021	BAGALKOT	110	110/11KV,HV1	AKSHAYA COLONY_110	6:39 (28.10.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
588	29-Oct-2021	BAGALKOT	110	BANAHATTI-JAMAKHANDI	JAMAKHANDI_110	12:35	13:11	0:36	HAND TRIPPED
589	29-Oct-2021	BAGALKOT	110	ITANAL-KABBUR	KABBUR_110	5:58	6:26	0:28	LINE FAULT
590	29-Oct-2021	BAGALKOT	110	ITANAL-BPCL	ITANAL_110	5:58	6:21	0:23	LINE FAULT
591	29-Oct-2021	BAGALKOT	110	110/11KV,HV2	KUD DHARWAD_110	8:40	8:44	0:04	TRANSFORMER FAULT
592	29-Oct-2021	BAGALKOT	110	110/11KV,HV2	YELPARAHATTI_110	18:00	18:13	0:13	TRANSFORMER FAULT
593	29-Oct-2021	BAGALKOT	110	NAVALGUND-110 KV SOLAR LINE	NAVALGUND_110	10:30	16:45	6:15	NFBC ISSUED
594	29-Oct-2021	BAGALKOT	110	NAVALGUND-KONNUR	NAVALGUND_110	10:18	16:54	6:36	NFBC ISSUED
595	29-Oct-2021	BAGALKOT	110	110/11KV,HV2	YADAWAD_110	15:00	15:56	0:56	LINE CLEAR AVAILED
596	29-Oct-2021	BAGALKOT	110	110/11KV,HV2	MORATAGI_110	9:55	10:00	0:05	TRANSFORMER FAULT
597	29-Oct-2021	BAGALKOT	110	110/33KV,HV3	LAKMANAHALLI_110, ALNAVAR_33	22:29	22:57	0:28	TRANSFORMER FAULT
598	29-Oct-2021	BAGALKOT	220	HIREBENDIGERI2(TADAS2)- BIDNAL	BIDNAL_220	10:39	11:17	0:38	LINE CLEAR AVAILED
599	29-Oct-2021	BAGALKOT	220	HIREBENDIGERI2(TADAS2)- BIDNAL	BIDNAL_220	11:58	14:49	2:51	LINE CLEAR AVAILED
600	29-Oct-2021	BAGALKOT	220	NAGJHARI2- BIDNAL	BIDNAL_220	12:14	13:11	0:57	LINE FAULT
601	29-Oct-2021	BAGALKOT	220	NAGJHARI3- HUBLI	HUBLI_220	11:05	17:40	6:35	LINE CLEAR AVAILED
602	29-Oct-2021	BAGALKOT	110	110/11KV, HV1	CHIKKODI_220	14:40	16:50	2:10	LINE CLEAR AVAILED
603	29-Oct-2021	BAGALKOT	110	BIDNAL220- NARAGUND	NARAGUND_110	10:20	16:55	6:35	LINE CLEAR AVAILED
604	29-Oct-2021	BAGALKOT	110	BIDNAL220- KONNUR	KONNUR_110	10:00	17:00	7:00	LINE CLEAR AVAILED
605	29-Oct-2021	BAGALKOT	110	110/33KV, HV3	KONNUR_110	10:00	17:00	7:00	LINE CLEAR AVAILED
606	29-Oct-2021	BAGALKOT	110	110/11KV, HV1	KONNUR_110	10:00	17:00	7:00	LINE CLEAR AVAILED
607	29-Oct-2021	BAGALKOT	110	110/11KV, HV1	NARAGUND_110	10:20	16:55	6:35	LINE CLEAR AVAILED
608	29-Oct-2021	BAGALKOT	110	SHIROL -MANTUR	SHIROL_110	12:25	13:00	0:35	LINE CLEAR AVAILED
609	29-Oct-2021	BAGALKOT	110	110/11KV, HV1	MANTUR_110	15:35	16:05	0:30	LINE CLEAR AVAILED
610	29-Oct-2021	BAGALKOT	110	110/33KV HV1	BELUR_110	11:08	13:59	2:51	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
611	29-Oct-2021	BAGALKOT	110	110/11KV HV1	ITANAL_110	7:35	7:45	0:10	TRANSFORMER FAULT
612	29-Oct-2021	BAGALKOT	110	110/11KV HV2	RAIBAG_110	8:23	8:27	0:04	HAND TRIPPED
613	29-Oct-2021	BAGALKOT	110	INDI220- DEVAR HIPPARAGI	DEVAR HIPPARGI_110	4:01	4:10	0:09	LINE FAULT
614	29-Oct-2021	BAGALKOT	110	INDI220- LACHYAN	LACHYAN_110	11:00	14:40	3:40	LINE CLEAR AVAILED
615	29-Oct-2021	BAGALKOT	110	INDI220- LACHYAN	LACHYAN_110	18:36	18:41	0:05	LINE FAULT
616	29-Oct-2021	BENGALURU	66	HV1	ANJANAPURA	10:00	16:25	6:25	LINE CLEAR AVAILED
617	29-Oct-2021	BENGALURU	66	HV2	ANJANAPURA	10:00	16:25	6:25	LINE CLEAR AVAILED
618	29-Oct-2021	BENGALURU	66	ANJANAPURA - KHODAYS 220	ANJANAPURA	10:00	16:25	6:25	LINE CLEAR AVAILED
619	29-Oct-2021	BENGALURU	220	A STATION 220 - EAST DIVISION COMOUND 220	A STATION 220	11:12	11:17	0:05	MAIN SUPPLY FAILURE
620	29-Oct-2021	BENGALURU	66	A STATION 220 - C STATION	C STATION	11:12	11:38	0:26	LINE CLEAR AVAILED
621	29-Oct-2021	BENGALURU	66	A STATION 220 - SHOBHA INDRAPRASTA	SHOBHA INDRAPRASTA	11:12	11:17	0:05	LINE CLEAR AVAILED
622	29-Oct-2021	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	11:12	11:18	0:06	LINE CLEAR AVAILED
623	29-Oct-2021	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	11:12	11:18	0:06	LINE CLEAR AVAILED
624	29-Oct-2021	BENGALURU	220	EAST DIVISION COMPOUND 220 - HAL 220	EAST DIVISION COMPOUND 220	11:12	11:37	0:25	MAIN SUPPLY FAILURE
625	29-Oct-2021	BENGALURU	66	BMTC - EAST DIVISION COMPOUND 220	BMTC	11:12	11:49	0:37	MAIN SUPPLY FAILURE
626	29-Oct-2021	BENGALURU	66	EAST DIVISION COMPOUND 220 - AUSTIN TOWN	AUSTIN TOWN	11:12	11:46	0:34	LINE CLEAR AVAILED
627	29-Oct-2021	BENGALURU	66	EAST DIVISION COMPOUND 220 - B STATION	B STATION	11:12	11:46	0:34	LINE CLEAR AVAILED
628	29-Oct-2021	BENGALURU	66	HV2	GOKULA	14:00	14:02	0:02	LINE CLEAR AVAILED
629	29-Oct-2021	BENGALURU	66	HV1	GOKULA	10:56	10:58	0:02	LINE CLEAR AVAILED
630	29-Oct-2021	BENGALURU	220	HAL 220 - HOODY 400 1	HAL 220	11:12	11:51	0:39	MAIN SUPPLY FAILURE
631	29-Oct-2021	BENGALURU	220	HAL 220 - HOODY 400 2	HAL 220	11:12	11:33	0:21	LINE CLEAR AVAILED
632	29-Oct-2021	BENGALURU	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	11:12	11:52	0:40	LINE CLEAR AVAILED
633	29-Oct-2021	BENGALURU	66	HAL 220 - HAL (EHT)	HAL (EHT)	11:12	11:52	0:40	LINE CLEAR AVAILED
634	29-Oct-2021	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK (EHT)	11:12	11:52	0:40	LINE CLEAR AVAILED
635	29-Oct-2021	BENGALURU	66	HAL 220 - HOODY 2	GTRE (EHT)	11:12	11:51	0:39	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
636	29-Oct-2021	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARIYOTHI	11:12	11:48	0:36	LINE CLEAR AVAILED
637	29-Oct-2021	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	11:12	11:52	0:40	LINE CLEAR AVAILED
638	29-Oct-2021	BENGALURU	220	HOODY 400 - HAL 220 1	HAL 220	11:12	11:51	0:39	LINE FAULT
639	29-Oct-2021	BENGALURU	66	ITI 220 - NGEF	NGEF, NGEF(EHT)	2:09	3:04	0:55	LINE FAULT
640	29-Oct-2021	BENGALURU	66	HV2	KORAMANGALA 220	13:00	13:02	0:02	LINE CLEAR AVAILED
641	29-Oct-2021	BENGALURU	66	HV1	AMAR JYOTHI	11:12	11:26	0:14	MAIN SUPPLY FAILURE
642	29-Oct-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	16:57	17:08	0:11	MAIN SUPPLY FAILURE
643	29-Oct-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	18:30	18:35	0:05	LOAD CHANGE OVER
644	29-Oct-2021	BENGALURU	66	HV1	NAGANATHPURA 220	10:00	17:00	7:00	LINE CLEAR AVAILED
645	29-Oct-2021	BENGALURU	66	HV2	NAGANATHPURA 220	10:00	17:00	7:00	LINE CLEAR AVAILED
646	29-Oct-2021	BENGALURU	66	HV3	NAGANATHPURA 220	10:00	17:00	7:00	LINE CLEAR AVAILED
647	29-Oct-2021	BENGALURU	66	HV1	NIMHANS 220	12:08	12:10	0:02	LINE CLEAR AVAILED
648	29-Oct-2021	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	12:03	12:05	0:02	LINE CLEAR AVAILED
649	29-Oct-2021	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	16:57	18:31	1:34	LINE FAULT
650	29-Oct-2021	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	16:57	17:08	0:11	LINE FAULT
651	29-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	5:19	7:09	1:50	LINE FAULT
652	29-Oct-2021	BENGALURU	66	HV1	VIJAYANAGARA	11:09	11:31	0:22	MAIN SUPPLY FAILURE
653	29-Oct-2021	BENGALURU	66	AGALKOTE - ANCHEPALYA 220	AGALKOTE	9:56	10:40	0:44	MAIN SUPPLY FAILURE
654	29-Oct-2021	BENGALURU	66	T G HALLI - ANCHEPALYA 220	T G HALLI	9:56	10:40	0:44	MAIN SUPPLY FAILURE
655	29-Oct-2021	BENGALURU	66	MAGADI 66 - ANCHEPALYA 220	MAGADI 66	9:56	10:40	0:44	MAIN SUPPLY FAILURE
656	29-Oct-2021	BENGALURU	66	GUDEMARANAHALLI - ANCHEPALYA 220	GUDEMARANAHALLI	9:56	10:40	0:44	MAIN SUPPLY FAILURE
657	29-Oct-2021	BENGALURU	66	HV1	Y HUNSENHALLI	12:33	17:06	4:32	LINE CLEAR AVAILED
658	29-Oct-2021	BENGALURU	66	HV2	Y HUNSENHALLI	12:10	12:25	0:15	LINE CLEAR AVAILED
659	29-Oct-2021	BENGALURU	66	HV2	VOLVO	2:45	3:01	0:16	TRANSFORMER FAULT
660	29-Oct-2021	BENGALURU	66	HV1	SM MANGALA	8:42	9:00	0:18	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
661	29-Oct-2021	BENGALURU	66	HV1	SM MANGALA	9:01	9:16	0:15	LINE CLEAR AVAILED
662	29-Oct-2021	BENGALURU	66	HV2	SM MANGALA	8:42	9:00	0:18	LINE CLEAR AVAILED
663	29-Oct-2021	BENGALURU	66	HV2	MELUR	13:55	14:02	0:07	LINE CLEAR AVAILED
664	29-Oct-2021	BENGALURU	66	HV2	MELUR	13:30	13:36	0:06	LINE CLEAR AVAILED
665	29-Oct-2021	BENGALURU	66	HV1	MALLASANDRA	13:37	15:34	1:57	LINE CLEAR AVAILED
666	29-Oct-2021	BENGALURU	66	HV1	KUNDANA	11:57	12:50	0:52	LINE CLEAR AVAILED
667	29-Oct-2021	BENGALURU	66	HV2	KGF	5:55	6:30	0:35	TRANSFORMER FAULT
668	29-Oct-2021	BENGALURU	220	HV2	CHINTAMANI 220	16:28	16:54	0:25	LINE CLEAR AVAILED
669	29-Oct-2021	BENGALURU	66	LV2	CHINTAMANI 220	16:28	16:54	0:26	LINE CLEAR AVAILED
670	29-Oct-2021	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	6:39	6:49	0:09	LINE FAULT
671	29-Oct-2021	BENGALURU	66	VIDYANAGAR - HOSKOTE 220	NO STATION AFFECTED	11:09	13:12	2:02	LINE CLEAR AVAILED
672	29-Oct-2021	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	16:36	16:48	0:11	LINE CLEAR AVAILED
673	29-Oct-2021	BENGALURU	220	LV2	VIKAS TECH PARK 220	14:53:00(26/10/2021)	12:43(29/10/2021)	69:50HRS	TRANSFORMER CHARGED
674	29-Oct-2021	BENGALURU	66	HV2	ANEKAL	22:47(28-10-2021)	12:44(29-10-2021)	13:56HRS	TRANSFORMER CHARGED
675	29-Oct-2021	BENGALURU	66	HV1	H GOLLAHALLI	7:48(28-10-2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
676	29-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
677	29-Oct-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:06(29.10.2021)			LINE OPEN. LINE CLEAR AVAILED
678	29-Oct-2021	GULBARGA	220	HV1	KAPNOOR_220	16:30	17:30	1:00	LINE CLEAR AVAILED
679	29-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE 110	14:55(30.07.2021)			LINE OPEN. LINE CLEAR AVAILED
680	29-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY 110	09:17(14.08.2021)			LINE OPEN. LINE CLEAR AVAILED
681	29-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	19:05(29.10.2021)			LINE OPEN, LINE FAULT
682	29-Oct-2021	GULBARGA	110	KAVITAL-SINDHANOOR(IDLE LINE)	KAVITAL_110	3:42(28.10.2021)			LINE OPEN, LINE FAULT
683	29-Oct-2021	GULBARGA	110	KAVITAL-SINDHANOOR(IDLE LINE)	KAVITAL_110	3:42(28.10.2021)			LINE OPEN, LINE FAULT
684	29-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	17:52(28.10.2021)	18:45(29.10.2021)	0:53HRS	LINE CHARGED
685	29-Oct-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAISAPUR_110,WADAGERA_110,SAN NATHI_IPP,COREGREENSUGARS IPP	20:07	20:15	0:08	LINE FAULT
686	29-Oct-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP,HUNASIGI_110,ASKI 110	19:30	19:44	0:14	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
687	29-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,GABBUR_110	1:20	1:25	0:05	LINE FAULT
688	29-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,GABBUR_110	17:45	17:50	0:05	LINE FAULT
689	29-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,GABBUR_110	19:05	19:15	0:10	LINE FAULT
690	29-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,GABBUR_110	19:50	19:58	0:08	LINE FAULT
691	29-Oct-2021	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESU GUR_110,SIRIGERA CROSS_110,NSL SUGAR IPP,VOORA IPP,	5:15	5:25	13:40	LINE FAULT
692	29-Oct-2021	GULBARGA	110	SINDHNOOR- PGLR WIND IPP	SINDHANOOR_220	13:20	13:30	13:40	LINE FAULT
693	29-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAM DINNI_110	3:25	3:35	13:40	LINE FAULT
694	29-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAM DINNI_110	20:12	20:30	13:40	LINE FAULT
695	29-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAM DINNI_110	20:50	21:41	13:40	LINE FAULT
696	29-Oct-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	23:20	23:35	13:40	LINE FAULT
697	29-Oct-2021	GULBARGA	110	HV3	VALKAMDINNI_110	7:12	7:15	1:16	TRANSFORMER FAULT
698	29-Oct-2021	GULBARGA	110	KADAGANCHI-TCDSOLAR_IPP	KADAGANCHI_110	22:05(28.10.2021)	00:10(29.10.2021)	2:05HRS	LINE CHARGED
699	29-Oct-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_1 10	16:30	17:37	1:07	LINE CLEAR AVAILED
700	29-Oct-2021	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGU TT_110	16:30	17:38	1:08	LINE CLEAR AVAILED
701	29-Oct-2021	GULBARGA	110	HV1	KAMALANAGAR_110	8:07	8:15	0:08	TRANSFORMER FAULT
702	29-Oct-2021	GULBARGA	110	CHOWDAPUR-AFZALPUR	CHOWDAPUR_110	16:10	18:05	1:55	LINE CLEAR AVAILED
703	29-Oct-2021	GULBARGA	110	HATTI-SOMANMARDHI_IPP	HATTI_110	20:26	20:36	0:10	LINE FAULT
704	29-Oct-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	KEMBHAVI_110	21:50	22:00	0:10	MAIN SUPPLY FAILURE
705	29-Oct-2021	GULBARGA	110	YERADONA-BENNUR	BENNUR_110	20:45	20:50	0:05	LINE FAULT
706	29-Oct-2021	GULBARGA	110	NANDUR- GULBARGAUNIVERSITY	NANDUR_110	15:50	15:55	0:05	MAIN SUPPLY FAILURE
707	29-Oct-2021	GULBARGA	110	JAWALGERA- ADVIAMRESHWAR	ADVIAMRESHWAR_110	0:40	0:45	0:05	LINE FAULT
708	29-Oct-2021	GULBARGA	110	GULBARGAUNIVERSITY- GULBARGANORTH,SHAHABA D	GULBARGA UNIVERSITY_110,GULBARG ANORTH_110,GULBARGAS OUTH_110	15:50	16:00	0:10	LINE FAULT
709	29-Oct-2021	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_110	6:25	6:50	0:25	LINE CLEAR AVAILED
710	29-Oct-2021	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_110	6:50	6:55	0:05	LINE CLEAR AVAILED
711	29-Oct-2021	GULBARGA	66	HV2	HALAVAGALU_66	8:35	8:40	0:05	TRANSFORMER FAULT
712	29-Oct-2021	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	5:45	5:55	0:10	MAIN SUPPLY FAILURE
713	29-Oct-2021	HASSAN	220	MRSSHM-VARAH13	MRS MG_220	13:59(25.10.2021)	21:20 (29.10.2021)	103:20 hrs	LINE CHARGED
714	29-Oct-2021	HASSAN	220	VARAHI-SHMG3	varahi_gen	13:10(25.10.2021)	21:52 (29.10.2021)	104:41 hrs	LINE CHARGED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
715	29-Oct-2021	HASSAN	110	SORABA-SHR220	SORABA_110	22:30(21.10.2021)	15:27(29.10.2021)	184:56 hrs	LINE CHARGED
716	29-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
717	29-Oct-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	19:32(21.10.2021)			LINE OPEN. LINE CLEAR AVAILED
718	29-Oct-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	14:44(27.10.2021)			LINE OPEN. LINE CLEAR AVAILED
719	29-Oct-2021	HASSAN	220	MRSSHM-VARAH12	MRSMG_220	17:17 (29.10.2021)			LINE OPEN. LINE CLEAR AVAILED
720	29-Oct-2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	17:17 (29.10.2021)			LINE OPEN, LINE FAULT
721	29-Oct-2021	HASSAN	220	HV2	KAVOOR_220	9:50	11:50	2:00	LINE CLEAR AVAILED
722	29-Oct-2021	HASSAN	110	LV2	KAVOOR_220	9:50	11:50	2:00	LINE CLEAR AVAILED
723	29-Oct-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	10:20	13:00	2:40	LINE CLEAR AVAILED
724	29-Oct-2021	HASSAN	220	HV1	MRSMG_220	15:35	19:37	4:02	LINE CLEAR AVAILED
725	29-Oct-2021	HASSAN	220	HV3	MRSMG_220	10:40	11:06	0:26	LINE CLEAR AVAILED
726	29-Oct-2021	HASSAN	110	HV4	MRSMG_220	12:13	12:23	0:10	TRANSFORMER FAULT
727	29-Oct-2021	HASSAN	110	LV1	MRSMG_220	15:35	19:37	4:02	LINE CLEAR AVAILED
728	29-Oct-2021	HASSAN	110	LV3	MRSMG_220	10:40	11:06	0:26	LINE CLEAR AVAILED
729	29-Oct-2021	HASSAN	110	MRSSHM-SS1	MRSMG_220	19:57	19:58	0:01	HAND TRIPPED
730	29-Oct-2021	HASSAN	110	MRSSHM-SS2	MRSMG_220	19:57	19:58	0:01	HAND TRIPPED
731	29-Oct-2021	HASSAN	66	LV1	MRSMG_220	11:05	15:20	4:15	LINE CLEAR AVAILED
732	29-Oct-2021	HASSAN	66	LV2	MRSMG_220	11:05	15:20	4:15	LINE CLEAR AVAILED
733	29-Oct-2021	HASSAN	66	LV3	MRSMG_220	11:05	15:20	4:15	LINE CLEAR AVAILED
734	29-Oct-2021	HASSAN	66	LV4	MRSMG_220	12:13	12:23	0:10	TRANSFORMER FAULT
735	29-Oct-2021	HASSAN	110	HV3	BANTWAL_110	12:45	15:32	2:47	LINE CLEAR AVAILED
736	29-Oct-2021	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	8:30	8:35	0:05	HAND TRIPPED
737	29-Oct-2021	HASSAN	110	HV2	BELAGUMBA_110	10:40	11:30	0:50	LINE CLEAR AVAILED
738	29-Oct-2021	HASSAN	110	HV2	HOSANGADI_110	9:59	14:00	4:01	LINE CLEAR AVAILED
739	29-Oct-2021	HASSAN	110	HV1	KEMAR_220	10:37	18:23	7:46	LINE CLEAR AVAILED
740	29-Oct-2021	HASSAN	110	HV2	KEMAR_220	14:36	18:22	3:46	LINE CLEAR AVAILED
741	29-Oct-2021	HASSAN	110	HV1	KONAJE_110	8:50	8:55	0:05	HAND TRIPPED
742	29-Oct-2021	HASSAN	110	HV2	KONAJE_110	8:50	8:55	0:05	HAND TRIPPED
743	29-Oct-2021	HASSAN	110	HV3	KONAJE_110	8:50	8:55	0:05	HAND TRIPPED
744	29-Oct-2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	11:21	12:31	1:10	MAIN SUPPLY FAILURE
745	29-Oct-2021	HASSAN	110	PUTTUR-VITLA	PUTTUR_220	11:21	16:11	4:50	LINE FAULT
746	29-Oct-2021	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	11:01	11:10	0:09	LINE FAULT
747	29-Oct-2021	HASSAN	66	HV2	ARKD_66	3:14	3:30	0:16	TRANSFORMER FAULT
748	29-Oct-2021	HASSAN	66	HV2	ARKD_66	11:01	11:16	0:15	TRANSFORMER FAULT
749	29-Oct-2021	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	3:15	3:35	0:20	LINE FAULT
750	29-Oct-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	18:13	18:23	0:10	LINE FAULT
751	29-Oct-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	18:13	18:25	0:12	LINE FAULT
752	29-Oct-2021	HASSAN	66	HV1	YESLUR_66	11:07	11:20	0:13	MAIN SUPPLY FAILURE
753	29-Oct-2021	MYSURU	66	HV2	AKKIHEBBAL_66	6:19	6:31	22:44	TRANSFORMER FAULT
754	29-Oct-2021	MYSURU	66	HV1	BYLUKUPPE_66	13:47	15:01	1:14	LINE CLEAR AVAILED
755	29-Oct-2021	MYSURU	66	HV2	BYLUKUPPE_66	13:10	14:10	1:00	LINE CLEAR AVAILED
756	29-Oct-2021	MYSURU	66	CHUNCHUNKATTE-HV1	CHUNCHUNKATTE_66	7:54	18:31	10:37	LINE FAULT
757	29-Oct-2021	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	14:54	18:49	3:54	LINE FAULT
758	29-Oct-2021	MYSURU	66	HV1	HANNUR_66	12:46	14:58	2:12	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
759	29-Oct-2021	MYSURU	66	HV1	HUNSUR_66	12:52	13:52	1:00	LINE CLEAR AVAILED
760	29-Oct-2021	MYSURU	66	HV2	HUNSUR_66	11:51	12:52	1:01	LINE CLEAR AVAILED
761	29-Oct-2021	MYSURU	66	KADAKOLA-SARGUR2	HULLAHALLI_66 HURA_66 DOORA_66 CHANDRAVADI_66	18:12	18:18	0:05	LINE FAULT
762	29-Oct-2021	MYSURU	66	KADAKOLA-SARGUR1	JAIPUR_66 HAMPAPURA_66	12:29	12:33	0:03	LINE FAULT
763	29-Oct-2021	MYSURU	66	KOLLEGALA-PARINAMIPURA	PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	11:34	12:09	0:35	HAND TRIPPED
764	29-Oct-2021	MYSURU	66	MADHUVANAHALLI- LOKKANAHALLI	PGPALYA_66 LOKKANAHALLI_66	17:29	17:33	0:04	LINE FAULT
765	29-Oct-2021	MYSURU	66	PONNAMPETE-VIRAJPET	VIRAJPET_66	13:09	15:31	2:22	LINE CLEAR AVAILED
766	29-Oct-2021	MYSURU	66	SFC SHIVA-PGL	NO STATIONS EFFECTED	5:53	6:01	0:08	LINE FAULT
767	29-Oct-2021	MYSURU	66	SFC SHIVA-HEBBANI 2	NO STATIONS EFFECTED	5:52	6:07	0:15	LINE FAULT
768	29-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	0:11	0:16	0:05	LINE FAULT
769	29-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	2:14	2:20	0:06	LINE FAULT
770	29-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	12:08	15:15	3:07	LINE CLEAR AVAILED
771	29-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 2	SHIVALLY_66	12:08	15:15	3:07	LINE CLEAR AVAILED
772	29-Oct-2021	MYSURU	220	HV2	TUBINKERE_220	15:10:00 (25.10.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
773	29-Oct-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN. LINE CLEAR AVAILED
774	29-Oct-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN. LINE CLEAR AVAILED
775	29-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50 (5.10.2021)			LINE OPEN. LINE CLEAR AVAILED
776	29-Oct-2021	TUMKUR	220	TR-1(HV SIDE)	ANCHEPALYA_220	9:56	18:36	8:39	LINE CLEAR AVAILED
777	29-Oct-2021	TUMKUR	110	TR-2	NITTUR_220	14:19	16:18	1:58	LINE CLEAR AVAILED
778	29-Oct-2021	TUMKUR	66	ANCHEPALYA 220kv- AMRUTHUR	AMRUTHUR_66, SANTEMNAVATTUR_66,YED AVANI_66	10:31	10:35	0:04	HAND TRIPPED
779	29-Oct-2021	TUMKUR	66	ANCHEPALYA 220kv- AMRUTHUR	AMRUTHUR_66, SANTEMNAVATTUR_66,YED AVANI_66	17:44	20:03	2:19	LINE FAULT
780	29-Oct-2021	TUMKUR	66	ANCHEPALYA 220kv- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66	10:31	10:33	0:01	HAND TRIPPED
781	29-Oct-2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENNAHALLI_66,SRI GIRI PURA	10:31	10:35	0:03	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
782	29-Oct-2021	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	10:31	10:35	0:03	HAND TRIPPED
783	29-Oct-2021	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	10:31	10:36	0:04	HAND TRIPPED
784	29-Oct-2021	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	9:56	18:37	8:41	LINE CLEAR AVAILED
785	29-Oct-2021	TUMKUR	66	TR-2(LV SIDE)	ANCHEPALYA_220	9:58	10:32	0:33	LINE CLEAR AVAILED
786	29-Oct-2021	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	10:31	10:35	0:04	HAND TRIPPED
787	29-Oct-2021	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR_66	YEDIYUR_66, THIPPUR_66, JI DDEGERE_66	10:31	10:35	0:03	HAND TRIPPED
788	29-Oct-2021	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	7:36	7:39	0:03	HAND TRIPPED
789	29-Oct-2021	TUMKUR	66	TR-1	CHIKKABANAGERE_66	15:15	18:08	2:52	TRANSFORMER FAULT
790	29-Oct-2021	TUMKUR	66	TR-2	DAVANGERE_66	10:20	13:58	3:38	LINE CLEAR AVAILED
791	29-Oct-2021	TUMKUR	66	TR-1	DAVANGERE_66	10:20	13:58	3:38	LINE CLEAR AVAILED
792	29-Oct-2021	TUMKUR	66	DAVANGERE SRS- AVAREGERE66	AVAREGERE_66, MELLEKAT TE_66, KADAJJI_66	14:30	14:47	0:17	LINE FAULT
793	29-Oct-2021	TUMKUR	66	DAVANGERE SRS- CHITRADURGA2	CHITRADURGA_220	14:30	14:47	0:17	LINE FAULT
794	29-Oct-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	1:24	1:34	0:10	LINE FAULT
795	29-Oct-2021	TUMKUR	66	TR-1	DAVANAGERE_SRS_220KV	10:22	14:25	4:02	LINE CLEAR AVAILED
796	29-Oct-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	1:24	1:34	0:10	LINE FAULT
797	29-Oct-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:53	16:06	0:12	LINE FAULT
798	29-Oct-2021	TUMKUR	66	TR-1	HANAGAL_66	11:06	11:43	0:37	LINE CLEAR AVAILED
799	29-Oct-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:42	6:47	0:05	LINE FAULT
800	29-Oct-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	16:34	16:43	0:08	LINE FAULT
801	29-Oct-2021	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	6:30	6:39	0:08	LINE FAULT
802	29-Oct-2021	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	17:59	18:07	0:07	LINE FAULT
803	29-Oct-2021	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	BADAVANAHALLI_66	16:05	18:19	2:14	LINE FAULT
804	29-Oct-2021	TUMKUR	66	MADHUGIRI 66kV- MADHUGIRI (OLD) 220KV	MADHUGIRI_66	16:05	16:25	0:19	LINE FAULT
805	29-Oct-2021	TUMKUR	66	TR-1	PATNAYAKANAHALLI_66	7:10	7:15	0:04	HAND TRIPPED
806	29-Oct-2021	TUMKUR	66	TR-2	PATNAYAKANAHALLI_66	7:10	7:15	0:05	HAND TRIPPED
807	29-Oct-2021	TUMKUR	66	PATTNAYAKANAHALLI66- SIRA66	PATTNAYAKANAHALLI_66	6:06	7:12	1:06	LINE FAULT
808	29-Oct-2021	TUMKUR	66	PD KOTE 66-CLEAR SOLAR IPP_66	CLEAR SOLAR_IPP_66	14:29	14:36	0:06	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
809	29-Oct-2021	TUMKUR	66	PD KOTE66-AZURE POWER IPP_66	AZURE POWER_IPP_66	16:34	17:20	0:46	LINE CLEAR AVAILED
810	29-Oct-2021	TUMKUR	66	PD KOTE66-AZURE POWER IPP_66	AZURE POWER_IPP_66	18:30	23:49	5:18	LINE CLEAR AVAILED
811	30-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN. LINE CLEAR AVAILED
812	30-Oct-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN. LINE CLEAR AVAILED
813	30-Oct-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN. LINE CLEAR AVAILED
814	30-Oct-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
815	30-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
816	30-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN. LINE CLEAR AVAILED
817	30-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
818	30-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN. LINE CLEAR AVAILED
819	30-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN. LINE CLEAR AVAILED
820	30-Oct-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:32 (23.10.2021)			LINE OPEN, LINE FAULT
821	30-Oct-2021	BAGALKOT	220	SIRSI- SHRAVATHY1	SIRSI_220	20:11 (25.10.2021)			LINE OPEN. LINE CLEAR AVAILED
822	30-Oct-2021	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	6:40 (27.10.2021)			LINE OPEN. LINE CLEAR AVAILED
823	30-Oct-2021	BAGALKOT	110	110/11KV,HV1	AKSHAYA COLONY_110	6:39 (28.10.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
824	30-Oct-2021	BAGALKOT	220	220/110KV, HV1&LV1	CHIKKODI_220	11:10	16:45	5:35	LINE CLEAR AVAILED
825	30-Oct-2021	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED AINAPUR_110	14:26	14:59	0:33	HAND TRIPPED
826	30-Oct-2021	BAGALKOT	110	110/11KV,HV1	THORVI_110	15:42	17:19	1:37	HAND TRIPPED
827	30-Oct-2021	BAGALKOT	110	110/11KV,HV2	TAKKALAKI_110	11:34	11:44	0:10	TRANSFORMER FAULT
828	30-Oct-2021	BAGALKOT	110	HUBLI-PH COMPOUND	PH COMPOUND_110	10:16	18:48	8:32	LINE CLEAR AVAILED
829	30-Oct-2021	BAGALKOT	110	BIDNAL-PH COMPOUND	PH COMPOUND_110	18:48 (30.10.2021)			LINE OPEN. LINE CLEAR AVAILED
830	30-Oct-2021	BAGALKOT	110	MORATAGI-BAGEWADI2	MORATAGI_110	6:00	6:05	0:05	LINE FAULT
831	30-Oct-2021	BAGALKOT	110	KULIGERE CROSS-KONNUR	KULIGERE CROSS_110	9:47 (30.10.2021)			LINE OPEN. LINE CLEAR AVAILED
832	30-Oct-2021	BAGALKOT	110	HUNGUND-ILKAL2	HUNGUND_110	11:36	12:02	0:26	LINE CLEAR AVAILED
833	30-Oct-2021	BAGALKOT	110	HUNGUND-ILKAL2	HUNGUND_110	12:21	17:30	5:09	LINE CLEAR AVAILED
834	30-Oct-2021	BAGALKOT	110	110/11KV, HV1	BHOJ_110	13:00	13:40	0:40	LINE CLEAR AVAILED
835	30-Oct-2021	BAGALKOT	110	ATHANI220- AIGALI	AIGAL_110	6:27	6:41	0:14	LINE FAULT
836	30-Oct-2021	BAGALKOT	110	110/11KV, HV1	KATARKI_110	11:30	12:50	1:20	LINE CLEAR AVAILED
837	30-Oct-2021	BAGALKOT	220	220/110KV, HV2	HUBLI_220	10:18	17:29	7:11	LINE CLEAR AVAILED
838	30-Oct-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	14:17	15:52	1:35	LINE CLEAR AVAILED
839	30-Oct-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	7:30	8:36	1:06	LINE FAULT
840	30-Oct-2021	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	18:50	19:50	1:00	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
841	30-Oct-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	19:50	19:58	0:08	LOAD CURTAILMENT
842	30-Oct-2021	BENGALURU	66	DRDO (EHT) - SRINIVASAPURA	MALLASANDRA/TD HALLI, DALSNUR, YELDUR	19:55	20:42	0:47	LOAD CURTAILMENT
843	30-Oct-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	18:50	19:55	1:05	LOAD CURTAILMENT
844	30-Oct-2021	BENGALURU	66	HV2	KEMBODI	9:40	10:55	1:15	LINE CLEAR AVAILED
845	30-Oct-2021	BENGALURU	66	DEVANAHALLI - DB PURA 1	DEVANAHALLI	17:58	18:04	0:06	LINE FAULT
846	30-Oct-2021	BENGALURU	66	HV1	MALLASANDRA	11:19	13:00	1:41	LINE CLEAR AVAILED
847	30-Oct-2021	BENGALURU	66	HV1	MALLASANDRA	13:09	14:07	0:57	LINE CLEAR AVAILED
848	30-Oct-2021	BENGALURU	66	HV3	KGF	15:03	15:13	0:10	LINE CLEAR AVAILED
849	30-Oct-2021	BENGALURU	66	HV2	KGF	14:38	15:03	0:25	LINE CLEAR AVAILED
850	30-Oct-2021	BENGALURU	66	HV1	DODDAKARI	16:04	17:01	0:56	LINE CLEAR AVAILED
851	30-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - THAYALUR	THAYALUR, NG HULKUR, MALLANAYAKANAHALLI	6:00	6:30	0:30	LINE FAULT
852	30-Oct-2021	BENGALURU	66	ELECTRONIC CITY - INFOSYS (EHT)	INFOSYS (EHT)	10:01	17:41	7:40	LINE CLEAR AVAILED
853	30-Oct-2021	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	11:31	12:05	0:33	LINE CLEAR AVAILED
854	30-Oct-2021	BENGALURU	66	GOLF LINKS - ADUGODI 1	GOLF LINKS	19:45	19:52	0:07	LOAD CHANGE OVER
855	30-Oct-2021	BENGALURU	66	HULIMANGALA - ELECTRONIC CITY	HULIMANGALA	10:02	17:33	7:31	LINE CLEAR AVAILED
856	30-Oct-2021	BENGALURU	66	HV1	AMARJYOTHI	17:12	17:16	0:03	LINE CLEAR AVAILED
857	30-Oct-2021	BENGALURU	66	HV1	ELECTRONIC CIT	10:14	17:45	7:30	LINE CLEAR AVAILED
858	30-Oct-2021	BENGALURU	66	HV2	ELECTRONIC CIT	13:30	17:47	4:16	LINE CLEAR AVAILED
859	30-Oct-2021	BENGALURU	66	HV3	ELECTRONIC CIT	10:09	17:45	7:35	LINE CLEAR AVAILED
860	30-Oct-2021	BENGALURU	66	HV3	ITI	17:07	17:48	0:41	LINE CLEAR AVAILED
861	30-Oct-2021	BENGALURU	66	HV1	RR NAGAR	16:49	16:56	0:06	TRANSFORMER FAULT
862	30-Oct-2021	BENGALURU	66	HV1	RR NAGAR	18:46	19:28	0:42	LINE CLEAR AVAILED
863	30-Oct-2021	BENGALURU	66	HV1	H GOLLAHALLI	7:48(28-10-2021)	18:30(30-10-2021)	58:41hrs	TRANSFORMER CHARGED
864	30-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
865	30-Oct-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:06(29.10.2021)	06:09(30.10.2021)	8:03HRS	LINE CHARGED
866	30-Oct-2021	GULBARGA	220	MALLAT-RTPS	MALLAT_220	11:35	17:04	5:29	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
867	30-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN. LINE CLEAR AVAILED
868	30-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN. LINE CLEAR AVAILED
869	30-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	19:05 (29.10.2021)	14:45 (30.10.2021)	19:40HRS	LINE CHARGED
870	30-Oct-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	9:30	9:40	0:10	LINE FAULT
871	30-Oct-2021	GULBARGA	110	JANAWADA-SANTAPUR	SANTHAPUR_110	18:54	20:04	1:10	LOAD CURTAILMENT
872	30-Oct-2021	GULBARGA	110	HV3	VALKAMDINNI_110	15:00	15:05	0:05	TRANSFORMER FAULT
873	30-Oct-2021	GULBARGA	110	HV3	VALKAMDINNI_110	20:33	20:43	0:10	TRANSFORMER FAULT
874	30-Oct-2021	GULBARGA	110	HV3	VALKAMDINNI_110	22:08	22:14	0:06	TRANSFORMER FAULT
875	30-Oct-2021	GULBARGA	110	HV4	YELBURGA_110	12:58	13:19	0:21	TRANSFORMER FAULT
876	30-Oct-2021	GULBARGA	110	HV1	GABBUR_110	11:00	11:05	0:05	TRANSFORMER FAULT
877	30-Oct-2021	GULBARGA	110	BENNUR-SINDHANOOR	BENNUR_110	2:29	2:39	0:10	MAIN SUPPLY FAILURE
878	30-Oct-2021	GULBARGA	110	BENNUR-SINDHANOOR	BENNUR_110	13:50	13:55	0:05	MAIN SUPPLY FAILURE
879	30-Oct-2021	GULBARGA	110	HV1	CHOWDAPUR_110	14:25	14:27	0:02	TRANSFORMER FAULT
880	30-Oct-2021	GULBARGA	110	HV1	CHOWDAPUR_110	16:30	16:42	0:12	TRANSFORMER FAULT
881	30-Oct-2021	GULBARGA	110	HV2	KANAKAGIRI_110	10:15	10:25	0:10	TRANSFORMER FAULT
882	30-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,GABBUR_110	13:00	16:45	3:45	LINE CLEAR AVAILED
883	30-Oct-2021	GULBARGA	110	RAICHUR-MATMARI	MATMARI_110	22:40	23:02	0:22	LINE FAULT
884	30-Oct-2021	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110,KONKAL_110	14:32	14:38	0:06	LINE FAULT
885	30-Oct-2021	GULBARGA	110	HV1	NANDUR_110	12:10	18:45	6:35	LINE CLEAR AVAILED
886	30-Oct-2021	GULBARGA	110	MUNIRABAD-TIE LINE	MUNIRABAD_220	9:02	14:35	5:33	LINE OPEN. LINE CLEAR AVAILED
887	30-Oct-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	22:07	22:15	0:08	LINE FAULT
888	30-Oct-2021	GULBARGA	110	MALLAT-MADALAPUR	MADALAPUR_110,MANVI_110,ADAVI AMARESHWAR_110	22:17	22:25	0:08	LINE FAULT
889	30-Oct-2021	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDI NNI_110	22:51	22:58	0:07	LINE FAULT
890	30-Oct-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	23:20	23:28	0:08	LINE FAULT
891	30-Oct-2021	GULBARGA	66	HV1,HV2	GUDEKOTE_66	11:40	13:05	1:25	LINE CLEAR AVAILED
892	30-Oct-2021	GULBARGA	66	GUDEKOTE-KUDLIGI	GUDEKOTE_66	1:00	1:25	0:25	LINE CLEAR AVAILED
893	30-Oct-2021	GULBARGA	66	HV2	HALAVAGALU_66	16:30	16:35	0:05	TRANSFORMER FAULT
894	30-Oct-2021	GULBARGA	66	HV1	TELGI_66	15:50	15:55	0:05	TRANSFORMER FAULT
895	30-Oct-2021	GULBARGA	66	MUNIRABAD-MHDLIN	VENKATAPUR_66,RSSTEELS_66,UPHALLI_66,HBHALLI_66	12:30	15:30	3:00	LINE CLEAR AVAILED
896	30-Oct-2021	GULBARGA	66	MUNIRABAD-MSDLIN	HANASI_66	9:30	15:42	6:12	LINE CLEAR AVAILED
897	30-Oct-2021	GULBARGA	66	ITTAGI-HIREHADGALI2	HIREHADGALI_66,GIRIYAPUR_66,MAGALA_66,SOVEN HALLI_66,TUNGA BHADRA IPP	18:14	18:19	0:05	LINE FAULT
898	30-Oct-2021	HASSAN	220	MRSSHM-VARAH12	MRSMG_220	17:17 (29.10.2021)	10:32 (30.10.2021)	17:14 hrs	LINE CHARGED
899	30-Oct-2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	17:17 (29.10.2021)	10:32 (30.10.2021)	17:14 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
900	30-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
901	30-Oct-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	19:32(21.10.2021)			LINE OPEN. LINE CLEAR AVAILED
902	30-Oct-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	14:44(27.10.2021)			LINE OPEN. LINE CLEAR AVAILED
903	30-Oct-2021	HASSAN	110	SORABA-SHR220	SORABA_110	13:13 (30.10.2021)			LINE OPEN. LINE CLEAR AVAILED
904	30-Oct-2021	HASSAN	220	HV2	KAVOOR_220	9:30	16:29	6:59	LINE CLEAR AVAILED
905	30-Oct-2021	HASSAN	110	LV2	KAVOOR_220	9:30	16:29	6:59	LINE CLEAR AVAILED
906	30-Oct-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	17:41	17:55	0:14	LINE FAULT
907	30-Oct-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	10:06	12:30	2:24	LINE CLEAR AVAILED
908	30-Oct-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	18:54	21:58	3:04	NFBC ISSUED
909	30-Oct-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	22:14	22:44	0:30	HAND TRIPPED
910	30-Oct-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	12:31	13:49	1:18	LINE CLEAR AVAILED
911	30-Oct-2021	HASSAN	220	HV2	MRSMG_220	7:49	12:18	4:29	LINE CLEAR AVAILED
912	30-Oct-2021	HASSAN	110	LV2	MRSMG_220	7:49	12:28	4:39	LINE CLEAR AVAILED
913	30-Oct-2021	HASSAN	110	MRSSHM-SS1	MRSMG_220	12:28	12:30	0:02	HAND TRIPPED
914	30-Oct-2021	HASSAN	110	MRSSHM-SS2	MRSMG_220	12:29	13:00	0:31	HAND TRIPPED
915	30-Oct-2021	HASSAN	66	MRSSHM-BD-1	MRSMG_220	18:28	19:09	0:41	LINE FAULT
916	30-Oct-2021	HASSAN	220	HV1	SHIRALKOPPA_220	11:30	15:45	4:15	LINE CLEAR AVAILED
917	30-Oct-2021	HASSAN	220	HV2	SHIRALKOPPA_220	15:40	18:08	2:28	LINE CLEAR AVAILED
918	30-Oct-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	17:41	17:55	0:14	LINE FAULT
919	30-Oct-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	10:06	12:30	2:24	NFBC ISSUED
920	30-Oct-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	18:54	21:58	3:04	NFBC ISSUED
921	30-Oct-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	22:14	22:44	0:30	HAND TRIPPED
922	30-Oct-2021	HASSAN	110	HV3	PUTTUR_110	9:34	12:08	2:34	LINE CLEAR AVAILED
923	30-Oct-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	12:31	13:50	1:19	NFBC ISSUED
924	30-Oct-2021	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	19:00	19:35	0:35	LINE FAULT
925	30-Oct-2021	HASSAN	110	LV1	SHIRALKOPPA_220	11:21	15:45	4:24	LINE CLEAR AVAILED
926	30-Oct-2021	HASSAN	110	LV2	SHIRALKOPPA_220	15:39	18:08	2:29	LINE CLEAR AVAILED
927	30-Oct-2021	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYAPATNA_66	17:16	17:25	0:09	LINE FAULT
928	30-Oct-2021	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYAPATNA_66	20:03	20:15	0:12	LINE FAULT
929	30-Oct-2021	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	18:28	19:09	0:41	LINE FAULT
930	30-Oct-2021	HASSAN	66	HV1	HETTUR_66	13:22	15:17	1:55	LINE CLEAR AVAILED
931	30-Oct-2021	HASSAN	66	HV1	HOLALUR_66	10:42	13:44	3:02	NFBC ISSUED
932	30-Oct-2021	HASSAN	66	HV2	HOLALUR_66	10:42	13:44	3:02	NFBC ISSUED
933	30-Oct-2021	HASSAN	66	HV1	HOLEHONNUR_66	10:37	13:46	3:09	NFBC ISSUED
934	30-Oct-2021	HASSAN	66	HV2	HOLEHONNUR_66	10:37	13:46	3:09	NFBC ISSUED
935	30-Oct-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	10:35	13:44	3:09	NFBC ISSUED
936	30-Oct-2021	HASSAN	66	HASSN22-BELUR	HASSAN_220	10:13	13:08	2:55	LINE CLEAR AVAILED
937	30-Oct-2021	HASSAN	66	HASAN22-UDDURKOPLU	HASSAN_220	10:22	11:08	0:46	LINE CLEAR AVAILED
938	30-Oct-2021	MYSURU	66	HV2	ADDIHALLI_66	6:25	19:20	22:44	LINE CLEAR AVAILED
939	30-Oct-2021	MYSURU	66	HV1	BETTADAPURA_66	10:12	12:26	2:13	LINE CLEAR AVAILED
940	30-Oct-2021	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	18:18	21:24	3:05	HAND TRIPPED
941	30-Oct-2021	MYSURU	220	HV1	KADAKOLA_66	10:03	11:35	1:32	LINE CLEAR AVAILED
942	30-Oct-2021	MYSURU	220	KR PETE 220-CR PATNA	NO STATIONS EFFECTED	16:03	18:01	1:57	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
943	30-Oct-2021	MYSURU	66	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	9:44	11:41	1:57	HAND TRIPPED
944	30-Oct-2021	MYSURU	66	THANDYA-KADAKOLA	NO STATIONS EFFECTED	9:09	11:41	2:32	HAND TRIPPED
945	30-Oct-2021	MYSURU	66	MUGUR-THAYUR	THAYUR_66 , TN PURA_66	17:30	17:35	0:05	LINE FAULT
946	30-Oct-2021	MYSURU	220	HV2	TUBINKERE_220	15:10:00(25.10.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
947	30-Oct-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN. LINE CLEAR AVAILED
948	30-Oct-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)	9:41:00 (30/10/2021)	99:32HRS	LINE CHARGED
949	30-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50 (5.10.2021)			LINE OPEN. LINE CLEAR AVAILED
950	30-Oct-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN. LINE CLEAR AVAILED
951	30-Oct-2021	MYSURU	66	FTS-HOOTAGALLI 1	NO STATIONS EFFECTED	9:30:05 (30.10.2021)			LINE OPEN. LINE CLEAR AVAILED
952	30-Oct-2021	MYSURU	66	KR PETE 220- MAHADESHWARAPURA	NO STATIONS EFFECTED	11:03:31 (30.10.2021)			LINE OPEN. LINE CLEAR AVAILED
953	30-Oct-2021	TUMKUR	66	TUMKUR_66	ANTHRASANAHALI 220KV- TUMKUR	9:53	13:57	4:04	LINE CLEAR AVAILED
954	30-Oct-2021	TUMKUR	66	DAVANGERE SRS- AVAREGERE66	AVAREGERE_66,MELLEKAT TE_66,KADAJJI_66	10:46	10:55	0:09	LINE FAULT
955	30-Oct-2021	TUMKUR	66	DAVANGERE SRS- AVAREGERE66	AVAREGERE_66,MELLEKAT TE_66,KADAJJI_66	11:29	11:39	0:09	LINE FAULT
956	30-Oct-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:50	11:00	0:09	LINE FAULT
957	30-Oct-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:08	11:27	0:19	LINE FAULT
958	30-Oct-2021	TUMKUR	66	TR-2	HINDASGHATTA_66	12:45	12:49	0:04	LINE CLEAR AVAILED
959	30-Oct-2021	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	16:02	16:37	0:35	LINE FAULT
960	30-Oct-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	JAVAGONDANAHALLI_66	14:41	14:47	0:06	LINE FAULT
961	30-Oct-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKAWADA_66	11:29	11:38	0:09	HAND TRIPPED
962	30-Oct-2021	TUMKUR	66	MADHUGIRI 220kv- BADAVANAHALLI	MADHUGIRI_66, BADAVANAHALLI_66	9:54	10:14	0:20	LINE FAULT
963	30-Oct-2021	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	9:54	10:01	0:07	LINE FAULT
964	30-Oct-2021	TUMKUR	66	TR-1	PD KOTE_66	12:34	12:45	0:11	LINE CLEAR AVAILED
965	31-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN. LINE CLEAR AVAILED
966	31-Oct-2021	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN. LINE CLEAR AVAILED
967	31-Oct-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN. LINE CLEAR AVAILED
968	31-Oct-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
969	31-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
970	31-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN. LINE CLEAR AVAILED
971	31-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
972	31-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN. LINE CLEAR AVAILED
973	31-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN. LINE CLEAR AVAILED
974	31-Oct-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:32 (23.10.2021)			LINE OPEN. LINE CLEAR AVAILED
975	31-Oct-2021	BAGALKOT	220	SIRSI- SHRAVATHY1	SIRSI_220	20:11 (25.10.2021)			LINE OPEN. LINE CLEAR AVAILED
976	31-Oct-2021	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	6:40 (27.10.2021)	17:16 (31.10.2021)	106:36HRS	LINE CHARGED
977	31-Oct-2021	BAGALKOT	110	110/11KV,HV1	AKSHAYA COLONY_110	6:39 (28.10.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
978	31-Oct-2021	BAGALKOT	110	BIDNAL-PH COMPOUND	PH COMPOUND_110	18:48 (30.10.2021)	10:59 (31.10.2021)	16:11HRS	LINE CHARGED
979	31-Oct-2021	BAGALKOT	110	KULIGERE CROSS-KONNUR	KULIGERE CROSS_110	9:47 (30.10.2021)	10:34 (31.10.2021)	24:47HRS	LINE CHARGED
980	31-Oct-2021	BAGALKOT	220	AMBEWADI- NARENDRA2	AMBEWADI_220	15:07	15:47	0:40	LINE FAULT
981	31-Oct-2021	BAGALKOT	220	220/110KV, HV1&LV1	BELGAUM_220	10:38	13:02	2:24	LINE CLEAR AVAILED
982	31-Oct-2021	BAGALKOT	110	BELGAUM220- HUKKERI (UCHAGOAN)	UCHAGOAN_110	10:10	13:03	2:53	HAND TRIPPED
983	31-Oct-2021	BAGALKOT	110	ANKALAGI-HIDIKAL	ANKALAGI_110	13:10 (12.10.21)	10:25 (31.10.21)	477:15HRS	LINE CHARGED
984	31-Oct-2021	BAGALKOT	110	ANKALAGI-HIDIKAL	ANKALAGI_110	13:31 (31.10.21)			LINE OPEN. LINE CLEAR AVAILED
985	31-Oct-2021	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	9:19	18:33	9:14	LINE FAULT
986	31-Oct-2021	BAGALKOT	220	220/110KV,HV1 ,LV1	BIDNAL_220	11:00 (31.10.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
987	31-Oct-2021	BAGALKOT	110	BIDNAL220-PH COMPOUND	PH COMPOUND_110	10:35	10:59	0:24	HAND TRIPPED
988	31-Oct-2021	BAGALKOT	110	BIDNAL220-ANNIGERI	ANNIGERI_110	10:05 (31.10.21)			LINE OPEN. LINE CLEAR AVAILED
989	31-Oct-2021	BAGALKOT	110	BIDNAL220-GADAGROAD	GADAGROAD_110	09:57:00 (31.10.21)			LINE OPEN. LINE CLEAR AVAILED
990	31-Oct-2021	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	10:15:00 (31.10.21)			LINE OPEN. LINE CLEAR AVAILED
991	31-Oct-2021	BAGALKOT	110	GADAGROAD-GOPANKOPPA	GADAGROAD_110	9:39 (31.10.2021)			LINE OPEN. LINE CLEAR AVAILED
992	31-Oct-2021	BAGALKOT	110	BIJAPUR 220- ENERCON(BAGEWADI )	BIJAPUR_220	8:57	9:00	0:03	LINE FAULT
993	31-Oct-2021	BAGALKOT	110	BIDNAL-NAVLGUND	NAVLGUND_110	10:40 (31.10.2021)			MAIN SUPPLY FAILURE
994	31-Oct-2021	BAGALKOT	110	110/33KV,HV3	AMBUJA_33,SHIGGOAN_33 ,KPCL CHANDAPUR_33, SHIGGOAN_110	13:28	13:41	0:13	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
995	31-Oct-2021	BAGALKOT	110	110/33KV,HV3	AMBUJA_33,SHIGGOAN_33 ,KPCL CHANDAPUR_33, SHIGGOAN_110	13:44	13:52	0:08	TRANSFORMER FAULT
996	31-Oct-2021	BAGALKOT	110	110/33KV,HV3	AMBUJA_33,SHIGGOAN_33 ,KPCL CHANDAPUR_33, SHIGGOAN_110	15:26	15:34	0:08	TRANSFORMER FAULT
997	31-Oct-2021	BAGALKOT	110	VAJJARMATTI220- VAJRAMATTI	VAJJARMATTI_110	10:30	17:05	6:35	LINE CLEAR AVAILED
998	31-Oct-2021	BAGALKOT	220	HUBLI- BIDNAL1	HUBLI_220	9:18	10:08	0:50	LINE FAULT
999	31-Oct-2021	BAGALKOT	110	110/11KV, HV2	NAVANAGAR(H)_110	18:14	22:19	4:05	TRANSFORMER FAULT
1000	31-Oct-2021	BAGALKOT	110	SHEDBAL- KITTUR	SHEDBAL_110	6:13	9:15	3:02	LINE FAULT
1001	31-Oct-2021	BAGALKOT	220	NARENDRA- KANABARGI	NARENDRA_220	10:26	13:47	3:21	NFBC ISSUED
1002	31-Oct-2021	BAGALKOT	110	INDI220- LACHYAN	LACHYAN_110, HIREBEVNUR_110, RODAGI_110	2:45	2:50	0:05	LINE FAULT
1003	31-Oct-2021	BAGALKOT	110	110/33KV, HV2	KONNUR_110	10:15	10:35	0:20	MAIN SUPPLY FAILURE
1004	31-Oct-2021	BAGALKOT	110	110/11KV, HV2	KONNUR_110	10:15	10:35	0:20	MAIN SUPPLY FAILURE
1005	31-Oct-2021	BAGALKOT	110	110/11KV, HV1	NARAGUND_110	10:15	10:35	0:20	MAIN SUPPLY FAILURE
1006	31-Oct-2021	BAGALKOT	110	110/11KV, HV1	MANTUR-110KV	12:28	12:33	0:05	TRANSFORMER FAULT
1007	31-Oct-2021	BAGALKOT	220	NAGJHARI1- AMBEWADI	AMBEWADI_220	0:38	0:42	0:04	HAND TRIPPED
1008	31-Oct-2021	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	7:29	8:33	1:04	LINE CLEAR AVAILED
1009	31-Oct-2021	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL(EHT)	7:29	8:33	1:04	LINE CLEAR AVAILED
1010	31-Oct-2021	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	11:08	12:51	1:43	MAIN SUPPLY FAILURE
1011	31-Oct-2021	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	11:08	12:51	1:43	MAIN SUPPLY FAILURE
1012	31-Oct-2021	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	11:08	12:51	1:43	MAIN SUPPLY FAILURE
1013	31-Oct-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPETE	11:08	11:30	0:22	MAIN SUPPLY FAILURE
1014	31-Oct-2021	BENGALURU	66	BANGARPETE - MALUR 220	BANGARPETE	13:00	13:10	0:10	LOAD CHANGE OVER
1015	31-Oct-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	3:13	3:35	0:22	LINE FAULT
1016	31-Oct-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	5:13	5:35	0:21	LINE FAULT
1017	31-Oct-2021	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	11:01	12:51	1:49	MAIN SUPPLY FAILURE
1018	31-Oct-2021	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	7:55	8:05	0:10	LINE FAULT
1019	31-Oct-2021	BENGALURU	66	HV2	MALLASANDRA	11:50	12:57	1:06	LINE CLEAR AVAILED
1020	31-Oct-2021	BENGALURU	66	LV2	KOLAR 220	11:14	12:47	1:33	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1021	31-Oct-2021	BENGALURU	66	KACHMARANAHALLI - DOMMASANDRA	KACHMARANAHALLI	15:25	15:30	0:05	LOAD CHANGE OVER
1022	31-Oct-2021	BENGALURU	66	KACHMARANAHALLI - SHAMRAJ TECH PARK	KACHMARANAHALLI	11:15	11:17	0:02	LOAD CHANGE OVER
1023	31-Oct-2021	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	8:30	9:29	0:59	LINE FAULT
1024	31-Oct-2021	BENGALURU	66	HV1	RR NAGAR	10:10	10:20	0:09	TRANSFORMER FAULT
1025	31-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:22(31.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1026	31-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1027	31-Oct-2021	GULBARGA	220	ALIPUR-RAGALPADU	ALIPUR_220	4:58	6:23	1:25	LINE FAULT
1028	31-Oct-2021	GULBARGA	220	HV1	ITTAGI_220	22:05	22:11	0:06	TRANSFORMER FAULT
1029	31-Oct-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	1:39	7:15	5:36	LINE CLEAR AVAILED
1030	31-Oct-2021	GULBARGA	220	MALLAT-RTPS	MALLAT_220	6:00	6:12	0:12	LINE FAULT
1031	31-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN. LINE CLEAR AVAILED
1032	31-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN. LINE CLEAR AVAILED
1033	31-Oct-2021	GULBARGA	110	KUDITINI-ALIPUR	KUDITINI_110,TORANGALU_110	2:34	2:39	0:05	LINE FAULT
1034	31-Oct-2021	GULBARGA	110	HV1	KUDITINI_110	6:00	6:10	0:10	TRANSFORMER FAULT
1035	31-Oct-2021	GULBARGA	110	HV1	KUDITINI_110	9:45	9:55	0:10	TRANSFORMER FAULT
1036	31-Oct-2021	GULBARGA	110	HV1	KUDITINI_110	15:15	15:20	0:05	TRANSFORMER FAULT
1037	31-Oct-2021	GULBARGA	110	HV1	KUDITINI_110	15:24	15:30	0:06	TRANSFORMER FAULT
1038	31-Oct-2021	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,HATTI_110	0:35	0:43	0:08	LINE FAULT
1039	31-Oct-2021	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,HATTI_110	0:45	0:53	0:08	LINE FAULT
1040	31-Oct-2021	GULBARGA	110	MASKI-RENEW SOLAR	MASKI_110	0:35	1:00	0:25	LINE FAULT
1041	31-Oct-2021	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,HATTI_110	21:41	21:49	0:08	LINE FAULT
1042	31-Oct-2021	GULBARGA	110	MASKI-RENEW SOLAR	MASKI_110	21:41	21:50	0:09	LINE FAULT
1043	31-Oct-2021	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,HATTI_110	19:11	19:20	0:09	LINE FAULT
1044	31-Oct-2021	GULBARGA	110	MASKI-RENEW SOLAR	MASKI_110	19:11	19:39	0:28	LINE FAULT
1045	31-Oct-2021	GULBARGA	110	HV1	MATAMARI_110	12:05	12:10	0:05	TRANSFORMER FAULT
1046	31-Oct-2021	GULBARGA	110	MATAMARI-RAICHUR	MATAMARI_110	10:40	11:00	0:20	MAIN SUPPLY FAILURE
1047	31-Oct-2021	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE_110	1:25	1:30	0:05	MAIN SUPPLY FAILURE
1048	31-Oct-2021	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE_110	6:05	6:10	0:05	MAIN SUPPLY FAILURE
1049	31-Oct-2021	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE_110	14:35	14:40	0:05	MAIN SUPPLY FAILURE
1050	31-Oct-2021	GULBARGA	110	HV2	CHOWDAPUR_110	9:39	9:44	0:05	TRANSFORMER FAULT
1051	31-Oct-2021	GULBARGA	110	HV2	CHOWDAPUR_110	12:29	12:39	0:10	TRANSFORMER FAULT
1052	31-Oct-2021	GULBARGA	110	HV1	CHOWDAPUR_110	12:50	14:25	1:35	LINE CLEAR AVAILED
1053	31-Oct-2021	GULBARGA	110	HV1	CHOWDAPUR_110	15:09	15:16	0:07	TRANSFORMER FAULT
1054	31-Oct-2021	GULBARGA	110	KADAGANCHI-KAPNOOR	KADAGANCHI_110,ALAND_110	13:25	13:35	0:10	LINE FAULT
1055	31-Oct-2021	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	13:50	13:55	0:05	MAIN SUPPLY FAILURE
1056	31-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,GABBUR_110	1:27	1:35	0:08	LINE FAULT
1057	31-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,GABBUR_110	5:58	6:05	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1058	31-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,GABBUR_110	14:32	14:41	0:09	LINE FAULT
1059	31-Oct-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YERADON A_110,BENNUR_110,BTPS WATER WORKS,KAMPLI_110	2:30	2:40	0:10	LINE FAULT
1060	31-Oct-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YERADON A_110,BENNUR_110,BTPS WATER WORKS,KAMPLI_110	13:48	13:58	0:10	LINE FAULT
1061	31-Oct-2021	GULBARGA	110	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110,VALKA MDINNI_110,BYAGWAT_110	11:41	11:51	0:10	LINE FAULT
1062	31-Oct-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	0:22	0:30	0:08	LINE FAULT
1063	31-Oct-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	1:00	1:08	0:08	LINE FAULT
1064	31-Oct-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	2:40	2:48	0:08	LINE FAULT
1065	31-Oct-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	3:18	3:25	0:07	LINE FAULT
1066	31-Oct-2021	GULBARGA	110	SEDAM-VICAT SAGAR	SEDAM_220	2:52	3:14	0:22	LINE FAULT
1067	31-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY1 (IDLE LINE)	GULBARGA UNIVERSITY_110	12:40 (31.10.2021)			LINE OPEN, LINE FAULT
1068	31-Oct-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAG I_110,DEVANGAON_110,RENUKA_IPP,AFZALPUR_110, KARAJAGI_110	18:55(31.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1069	31-Oct-2021	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	2:31	2:42	0:11	LINE FAULT
1070	31-Oct-2021	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	2:31	2:42	0:11	LINE FAULT
1071	31-Oct-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAISAPUR_110,WADAGERA_110,SAN NATHI_IPP,COREGREENSUGARS_IPP	6:13	6:20	0:07	LINE FAULT
1072	31-Oct-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	22:35 (31.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1073	31-Oct-2021	GULBARGA	66	HV2	UCCHANAGIDURGA_66	9:00	9:30	0:30	LINE CLEAR AVAILED
1074	31-Oct-2021	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	16:10	16:35	0:25	MAIN SUPPLY FAILURE
1075	31-Oct-2021	GULBARGA	66	LV1	ITTAGI_220	22:05	22:11	0:06	TRANSFORMER FAULT
1076	31-Oct-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	14:44(27.10.2021)	17:26 (31.10.2021)	98:41 hrs	LINE CHARGED
1077	31-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1078	31-Oct-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	19:32(21.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1079	31-Oct-2021	HASSAN	110	SORABA-SHR220	SORABA_110	13:13 (30.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1080	31-Oct-2021	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	17:18 (31.10.2021)			LINE OPEN, LINE FAULT
1081	31-Oct-2021	HASSAN	220	HV1	KEMAR_220	17:16	17:35	0:19	TRANSFORMER FAULT
1082	31-Oct-2021	HASSAN	220	HV2	KEMAR_220	17:16	17:38	0:22	TRANSFORMER FAULT
1083	31-Oct-2021	HASSAN	220	HV3	KEMAR_220	17:17	17:42	0:25	TRANSFORMER FAULT
1084	31-Oct-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	12:56	14:14	1:18	NFBC ISSUED
1085	31-Oct-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	17:21	18:02	0:41	HAND TRIPPED
1086	31-Oct-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	17:21	17:47	0:26	HAND TRIPPED
1087	31-Oct-2021	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	17:21	17:45	0:24	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1088	31-Oct-2021	HASSAN	110	HV1	KEMAR_220	17:22	17:40	0:18	HAND TRIPPED
1089	31-Oct-2021	HASSAN	110	HV2	KEMAR_220	17:22	17:46	0:24	HAND TRIPPED
1090	31-Oct-2021	HASSAN	110	LV1	KEMAR_220	17:16	17:36	0:20	HAND TRIPPED
1091	31-Oct-2021	HASSAN	110	LV2	KEMAR_220	17:17	17:40	0:23	HAND TRIPPED
1092	31-Oct-2021	HASSAN	110	KEMAR-Manipal1	KEMAR_220	17:17	18:21	1:04	LINE FAULT
1093	31-Oct-2021	HASSAN	110	KEMAR-Manipal2	KEMAR_220	17:16	18:30	1:14	LINE FAULT
1094	31-Oct-2021	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	16:55	17:52	0:57	LINE FAULT
1095	31-Oct-2021	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	16:55	17:50	0:55	LINE FAULT
1096	31-Oct-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	14:02	14:41	0:39	LINE FAULT
1097	31-Oct-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	12:27	14:06	1:39	LINE CLEAR AVAILED
1098	31-Oct-2021	HASSAN	110	AJAMPU-SHIVANI	AJJAMPURA_110	9:54	10:20	0:26	LINE FAULT
1099	31-Oct-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	17:16	18:05	0:49	MAIN SUPPLY FAILURE
1100	31-Oct-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	17:16	17:47	0:31	MAIN SUPPLY FAILURE
1101	31-Oct-2021	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	17:16	18:24	1:08	LINE FAULT
1102	31-Oct-2021	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	17:16	17:50	0:34	MAIN SUPPLY FAILURE
1103	31-Oct-2021	HASSAN	110	HV1	NANDIKUR_110	16:55	17:50	0:55	HAND TRIPPED
1104	31-Oct-2021	HASSAN	110	HV2	NANDIKUR_110	16:55	17:50	0:55	HAND TRIPPED
1105	31-Oct-2021	HASSAN	110	NANDIKU-ISTRL	NANDIKUR_110	16:55	17:50	0:55	MAIN SUPPLY FAILURE
1106	31-Oct-2021	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	16:55	17:50	0:55	MAIN SUPPLY FAILURE
1107	31-Oct-2021	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	16:55	17:50	0:55	MAIN SUPPLY FAILURE
1108	31-Oct-2021	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	19:59	20:30	0:31	LINE FAULT
1109	31-Oct-2021	HASSAN	66	HV1	AREHALLI_HSN_66	20:00	20:43	0:43	LINE CLEAR AVAILED
1110	31-Oct-2021	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	14:31	14:53	0:22	LINE FAULT
1111	31-Oct-2021	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	18:42	18:54	0:12	LINE FAULT
1112	31-Oct-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	18:16	18:23	0:07	LINE FAULT
1113	31-Oct-2021	HASSAN	66	HV1	SIGEBAGI_66	13:06	13:41	0:35	LINE CLEAR AVAILED
1114	31-Oct-2021	MYSURU	66	HV2	ADDIHALLI_66	12:35	18:00	22:44	LINE CLEAR AVAILED
1115	31-Oct-2021	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	10:59	11:05	0:05	LINE FAULT
1116	31-Oct-2021	MYSURU	66	HV1	HANNUR_66	17:39	17:55	0:16	HAND TRIPPED
1117	31-Oct-2021	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	SUNTIKOPPA_66	17:55	19:41	1:45	LINE CLEAR AVAILED
1118	31-Oct-2021	MYSURU	66	SUNTIKOPPA-MADIKERI	SUNTIKOPPA_66	19:41	20:29	0:48	LINE CLEAR AVAILED
1119	31-Oct-2021	MYSURU	66	TUBINKERE-G UKKADA	G UKKADA_66 SR PATNA_66	12:43	12:48	0:05	LINE FAULT
1120	31-Oct-2021	MYSURU	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	5:49	6:05	0:16	LINE FAULT
1121	31-Oct-2021	MYSURU	220	HV2	TUBINKERE_220	15:10:00 (25.10.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1122	31-Oct-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1123	31-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50 (5.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1124	31-Oct-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1125	31-Oct-2021	MYSURU	66	FTS-HOOTAGALLI 1	NO STATIONS EFFECTED	9:30:05 (30.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1126	31-Oct-2021	MYSURU	66	KR PETE 220- MAHADESHWARAPURA	NO STATIONS EFFECTED	11:03:31 (30.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1127	31-Oct-2021	TUMKUR	220	TR-2	ANTHARASANAHALLI_220	14:03	14:29	0:25	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1128	31-Oct-2021	TUMKUR	220	TR-3	ANTHARASANAHALI_220	14:03	14:28	0:24	TRANSFORMER FAULT
1129	31-Oct-2021	TUMKUR	110	TR-2	NITTUR_220	17:07	17:43	0:35	LINE CLEAR AVAILED
1130	31-Oct-2021	TUMKUR	110	TR-2	NITTUR_220	20:43	21:13	0:29	TRANSFORMER FAULT
1131	31-Oct-2021	TUMKUR	66	TR-1	ANTHARASANAHALI_220	14:27	14:38	0:11	HAND TRIPPED
1132	31-Oct-2021	TUMKUR	66	TR-2	ANTHARASANAHALI_220	14:27	14:39	0:11	HAND TRIPPED
1133	31-Oct-2021	TUMKUR	66	ANTHRASANAHALI 220KV-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	14:27	14:32	0:04	HAND TRIPPED
1134	31-Oct-2021	TUMKUR	66	ANTHRASANAHALI 220KV-KORA	KORA_66, THOVINAKERE_66	14:26	14:31	0:05	HAND TRIPPED
1135	31-Oct-2021	TUMKUR	66	TR-3(LV-3)	ANTHARASANAHALI_220	14:03	14:31	0:27	TRANSFORMER FAULT
1136	31-Oct-2021	TUMKUR	66	DAVANGERE SRS-KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:52	15:03	0:11	LINE FAULT
1137	31-Oct-2021	TUMKUR	66	DAVANGERE SRS-YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJIHALI_66	14:52	15:03	0:11	LINE FAULT
1138	31-Oct-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:45	6:52	0:06	LINE FAULT
1139	31-Oct-2021	TUMKUR	66	HONNALLI 220KV-LINGADAHALLI-CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	18:15	18:21	0:06	LINE FAULT
1140	31-Oct-2021	TUMKUR	66	HONNALLI 220KV-SASUVEHALI	SASUVEHALI_66,	16:33	16:40	0:07	LINE FAULT
1141	31-Oct-2021	TUMKUR	66	KORATAGERE-HOLAVANHALLI	HOLAVINAHALLI_66,	18:05	18:14	0:09	HAND TRIPPED
1142	31-Oct-2021	TUMKUR	66	MADHUGIRI 220kv-PULLAMAGATTA	PULLAMGATTA_66	5:55	6:06	0:10	LINE FAULT
1143	31-Oct-2021	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	4:23	4:50	0:26	MAIN SUPPLY FAILURE
1144	31-Oct-2021	TUMKUR	66	PKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	4:23	4:52	0:28	MAIN SUPPLY FAILURE
1145	31-Oct-2021	TUMKUR	66	PKOTE-AZURE SOLAR	AZURE SOLAR	4:24	4:48	0:23	MAIN SUPPLY FAILURE
1146	31-Oct-2021	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	11:22	11:31	0:08	LINE FAULT
1147	31-Oct-2021	TUMKUR	66	PAVAGADA 220kv- YN HOSAKETE	PAVAGADA_220	6:05	6:15	0:09	LINE FAULT
1148	31-Oct-2021	TUMKUR	66	PAVAGADA 220kv- YN HOSAKETE	PAVAGADA_220	8:52	8:59	0:06	LINE FAULT
1149	1-Nov-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN. LINE CLEAR AVAILED
1150	1-Nov-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN. LINE CLEAR AVAILED
1151	1-Nov-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN. LINE CLEAR AVAILED
1152	1-Nov-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
1153	1-Nov-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
1154	1-Nov-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN. LINE CLEAR AVAILED
1155	1-Nov-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1156	1-Nov-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)	16:48 (01.11.2021)	671:08HRS	LINE CHARGED
1157	1-Nov-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1158	1-Nov-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:32 (23.10.2021)			LINE OPEN, LINE FAULT
1159	1-Nov-2021	BAGALKOT	220	SIRSI- SHRAVATHY1	SIRSI_220	20:11 (25.10.2021)	13:56 (01.11.2021)	161:45HRS	LINE CHARGED
1160	1-Nov-2021	BAGALKOT	110	110/11KV,HV1	AKSHAYA COLONY_110	6:39 (28.10.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1161	1-Nov-2021	BAGALKOT	110	ANKALAGI-HIDIKAL	ANKALAGI_110	13:31 (31.10.21)			LINE OPEN. LINE CLEAR AVAILED
1162	1-Nov-2021	BAGALKOT	220	220/110KV,HV1 ,LV1	BIDNAL_220	11:00 (31.10.2021)	11:46 (1.11.21)	24:46HRS	TRANSFORMER CHARGED
1163	1-Nov-2021	BAGALKOT	110	BIDNAL220-ANNIGERI	ANNIGERI_110	10:05 (31.10.21)	12:18:00 (01.11.21)	26:13HRS	LINE CHARGED
1164	1-Nov-2021	BAGALKOT	110	BIDNAL220-GADAGROAD	GADAGROAD_110	09:57:00 (31.10.21)	12:06:00 (1.11.21)	26:09HRS	LINE CHARGED
1165	1-Nov-2021	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	10:15:00 (31.10.21)	12:04:00 (1.11.21)	25:49HRS	LINE CHARGED
1166	1-Nov-2021	BAGALKOT	110	GADAGROAD-GOPANKOPPA	GADAGROAD_110	9:39 (31.10.2021)	12:16 (01.11.2021)	26:37HRS	LINE CHARGED
1167	1-Nov-2021	BAGALKOT	110	CHIKKODI220-ANKALI	CHIKKODI_220	4:20	4:45	0:25	LINE FAULT
1168	1-Nov-2021	BAGALKOT	220	SHARAVATHY1- SIRSI	SIRSI_220	14:00	18:41	4:41	LINE FAULT
1169	1-Nov-2021	BAGALKOT	220	SHARAVATHY2- SIRSI	SIRSI_220	16:48	18:51	2:03	HAND TRIPPED
1170	1-Nov-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:51 (01.11.2021)			LINE OPEN. LINE CLEAR AVAILED
1171	1-Nov-2021	BAGALKOT	110	AMBEWADI- SUPA1	AMBEWADI_220	16:07	16:50	0:43	LINE FAULT
1172	1-Nov-2021	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	6:52	15:42	8:50	HAND TRIPPED
1173	1-Nov-2021	BAGALKOT	110	AINAPUR-ATHANI SUGARS	STATION NOT AFFECTED AINAPUR_110	21:05	21:14	0:09	LINE FAULT
1174	1-Nov-2021	BAGALKOT	110	110/11KV,HV2	ANKALI_110	4:49	5:27	0:38	TRANSFORMER FAULT
1175	1-Nov-2021	BAGALKOT	110	BIDNAL220-PH COMPOUND	PH COMPOUND_110	11:49	12:03	0:14	HAND TRIPPED
1176	1-Nov-2021	BAGALKOT	110	110/11KV,HV2	YELPARHATTI_110	12:07	12:24	0:17	LINE CLEAR AVAILED
1177	1-Nov-2021	BAGALKOT	110	110/11KV,HV2	TAKKALAKI_110	11:36	11:43	0:07	TRANSFORMER FAULT
1178	1-Nov-2021	BAGALKOT	110	SIRSI-SIRSI2(KAVALWADA)	SIRSI_110	5:45	9:13	3:28	LINE FAULT
1179	1-Nov-2021	BAGALKOT	110	ITNAL-HIDIKAL2	ITNAL_110	15:45	17:30	1:45	HAND TRIPPED
1180	1-Nov-2021	BAGALKOT	220	GHATAPRBHA- NARENDRA1	GHATAPRABHA_220	7:43	8:43	1:00	LINE FAULT
1181	1-Nov-2021	BAGALKOT	110	110/11KV, HV2	ANKALI_110	4:20	5:25	1:05	TRANSFORMER FAULT
1182	1-Nov-2021	BAGALKOT	110	110/33KV, HV3	ANKALI_110, NANDIKARALI_33	4:20	5:10	0:50	TRANSFORMER FAULT
1183	1-Nov-2021	BAGALKOT	110	110/11KV, HV2	SHIRAGUPPI_110	16:25	16:30	0:05	HAND TRIPPED
1184	1-Nov-2021	BAGALKOT	110	110/11KV, HV2	MANTUR_110	6:00	6:05	0:05	TRANSFORMER FAULT
1185	1-Nov-2021	BENGALURU	66	H GOLAHALLI - T GOLAHALLI 220	H GOLLAHALLI	6:00	6:40	0:40	LINE CLEAR AVAILED
1186	1-Nov-2021	BENGALURU	66	YELAHANKA 220 - LINE3	WHEELS & AXLE(EHT), ESCORTS ( EHT )YHT(9), ATTUR YELAHANKA	10:59	11:56	0:57	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1187	1-Nov-2021	BENGALURU	66	YELAHANKA 220 - LINE4/DG4	SAHAKARINAGAR, ESCORTS(EHT)YHT(8), PLATINUM CITY.	12:14	13:13	0:58	LINE CLEAR AVAILED
1188	1-Nov-2021	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	5:12	5:23	0:11	LINE FAULT
1189	1-Nov-2021	BENGALURU	66	KOLAR 220 - THAYLUR	NO STATION AFFECTED	12:12	12:17	0:05	LINE FAULT
1190	1-Nov-2021	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	10:15	17:38	7:22	LINE CLEAR AVAILED
1191	1-Nov-2021	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	10:15	17:38	7:22	LINE CLEAR AVAILED
1192	1-Nov-2021	BENGALURU	66	GANIJUGUNTE - DIBBURAHALLI	DIBBURAHALLI	3:49	3:59	0:10	LINE FAULT
1193	1-Nov-2021	BENGALURU	66	HV2	KUNDANA	18:23	18:55	0:31	LINE CLEAR AVAILED
1194	1-Nov-2021	BENGALURU	66	ABBIGERE - DG 3	ABBIGERE	10:47	10:51	0:04	LOAD CHANGE OVER
1195	1-Nov-2021	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	12:02	12:13	0:11	LOAD CHANGE OVER
1196	1-Nov-2021	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	8:08	8:15	0:06	LINE FAULT
1197	1-Nov-2021	BENGALURU	66	HV2	HSR LAYOUT 220	1:13	1:48	0:34	TRANSFORMER FAULT
1198	1-Nov-2021	BENGALURU	66	HV2	HSR LAYOUT 220	15:35	16:30	0:54	LINE CLEAR AVAILED
1199	1-Nov-2021	BENGALURU	66	BANASWADI - ITI 220	BANASWADI	9:03	9:05	0:02	LOAD CHANGE OVER
1200	1-Nov-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:22(31.10.2021)	9:08(01.11.2021)	10:46HRS	LINE CHARGED
1201	1-Nov-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:22(01.11.2021)			LINE OPEN. LINE CLEAR AVAILED
1202	1-Nov-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1203	1-Nov-2021	GULBARGA	220	HV1	ITTAGI_220	1:30	10:50	9:20	LINE CLEAR AVAILED
1204	1-Nov-2021	GULBARGA	220	HV2	ITTAGI_220	10:30	10:40	0:10	TRANSFORMER FAULT
1205	1-Nov-2021	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	19:32	20:09	0:37	LINE FAULT
1206	1-Nov-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN. LINE CLEAR AVAILED
1207	1-Nov-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN. LINE CLEAR AVAILED
1208	1-Nov-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY1 (IDLE LINE)	GULBARGA UNIVERSITY_110	12:40 (31.10.2021)			LINE OPEN, LINE FAULT
1209	1-Nov-2021	GULBARGA	110	HV1	MYLAR_110	12:02	12:21	0:19	LINE CLEAR AVAILED
1210	1-Nov-2021	GULBARGA	110	NALWAR-CLNSLR	NALWAR_110	5:40	5:50	0:10	LINE FAULT
1211	1-Nov-2021	GULBARGA	110	HV1	CHOWDAPUR_110	7:25	7:33	0:08	TRANSFORMER FAULT
1212	1-Nov-2021	GULBARGA	110	HV2	CHOWDAPUR_110	13:17	13:25	0:08	TRANSFORMER FAULT
1213	1-Nov-2021	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	6:03	6:08	0:05	LINE FAULT
1214	1-Nov-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	6:05	6:10	0:05	MAIN SUPPLY FAILURE
1215	1-Nov-2021	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	9:40	9:55	0:15	MAIN SUPPLY FAILURE
1216	1-Nov-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	4:07	4:12	0:05	LINE FAULT
1217	1-Nov-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,GABBUR_110	6:15	6:22	0:07	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1218	1-Nov-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,GABBUR_110	23:20	23:40	0:20	LINE FAULT
1219	1-Nov-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YERADON A_110,BENNUR_110,BTPS WATER WORKS,KAMPLI_110	9:44	9:54	0:10	LINE FAULT
1220	1-Nov-2021	GULBARGA	110	MALLAT-MADALAPUR	MADALAPUR_110,MANVI_ 110,ADAVI AMARESHWAR_110	20:24	20:36	0:12	LINE FAULT
1221	1-Nov-2021	GULBARGA	110	SEDAM-KURUKUNTA	KURUKUNTA_110	17:09	17:32	0:23	LINE CLEAR AVAILED
1222	1-Nov-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAG I_110,DEVANGAON_110,RE NUKA_IPP,AFZALPUR_110, KARAJAGI_110	18:55(31.10.2021)	00:28 (01.11.2021)	5:33 HRS	LINE CHARGED
1223	1-Nov-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI 110	22:35 (31.10.2021)	00:05 (01.11.2021)	1:30 HRS	LINE CHARGED
1224	1-Nov-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI 110	6:05	6:08	0:03	LINE FAULT
1225	1-Nov-2021	GULBARGA	66	HV1	HPHALLI_66	14:50	15:00	0:10	TRANSFORMER FAULT
1226	1-Nov-2021	GULBARGA	66	HV1	HPHALLI_66	16:00	18:20	2:20	LINE CLEAR AVAILED
1227	1-Nov-2021	GULBARGA	66	HV1	BENNEHALLI_66	12:20	12:50	0:30	LINE CLEAR AVAILED
1228	1-Nov-2021	GULBARGA	66	HV3	TELAGI_66	15:40	15:50	0:10	TRANSFORMER FAULT
1229	1-Nov-2021	GULBARGA	66	TELAGI-SRS DAVANAGERE	TELAGI_66	22:05	22:15	0:10	LINE FAULT
1230	1-Nov-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	19:32(21.10.2021)	17:12 (1.11.2021)	261:39 hrs	LINE CHARGED
1231	1-Nov-2021	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	17:18 (31.10.2021)	6:47 (1.11.2021)	13:28 hrs	LINE CHARGED
1232	1-Nov-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1233	1-Nov-2021	HASSAN	110	SORABA-SHR220	SORABA_110	13:13 (30.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1234	1-Nov-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	10:22	16:22	6:00	NFBC ISSUED
1235	1-Nov-2021	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	10:34	16:20	5:46	NFBC ISSUED
1236	1-Nov-2021	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	15:42	17:14	1:32	LINE FAULT
1237	1-Nov-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:35	17:27	1:52	LINE FAULT
1238	1-Nov-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:35	16:22	0:47	LINE FAULT
1239	1-Nov-2021	HASSAN	110	KEMAR-Manipal1	KEMAR_220	16:37	17:07	0:30	LINE FAULT
1240	1-Nov-2021	HASSAN	110	KEMAR-Manipal2	KEMAR_220	16:37	17:08	0:31	LINE FAULT
1241	1-Nov-2021	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	16:24	17:28	1:04	LINE FAULT
1242	1-Nov-2021	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	10:22	16:17	5:55	LINE CLEAR AVAILED
1243	1-Nov-2021	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	16:29	17:51	1:22	LINE FAULT
1244	1-Nov-2021	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	15:42	17:25	1:43	LINE FAULT
1245	1-Nov-2021	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	16:50	18:41	1:51	NFBC ISSUED
1246	1-Nov-2021	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	10:22	16:18	5:56	NFBC ISSUED
1247	1-Nov-2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	17:35	17:50	0:15	LINE FAULT
1248	1-Nov-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	15:35	17:27	1:52	LINE FAULT
1249	1-Nov-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:36	16:22	0:46	LINE FAULT
1250	1-Nov-2021	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	16:20	17:02	0:42	LINE FAULT
1251	1-Nov-2021	HASSAN	110	LPH-MGHE 2	lph_gen	17:53	17:54	0:01	HAND TRIPPED
1252	1-Nov-2021	HASSAN	110	LPH-MGHE 2	lph_gen	18:05	18:06	0:01	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1253	1-Nov-2021	HASSAN	110	LPH-MGHE 2	lph_gen	18:12	18:13	0:01	HAND TRIPPED
1254	1-Nov-2021	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	16:37	17:11	0:34	LINE FAULT
1255	1-Nov-2021	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	15:28	17:12	1:44	HAND TRIPPED
1256	1-Nov-2021	HASSAN	110	NANDIKU-ISTR1	NANDIKUR_110	16:24	17:28	1:04	HAND TRIPPED
1257	1-Nov-2021	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	16:24	17:30	1:06	LINE FAULT
1258	1-Nov-2021	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	16:24	17:28	1:04	LINE FAULT
1259	1-Nov-2021	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	16:24	17:28	1:04	HAND TRIPPED
1260	1-Nov-2021	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	15:42	16:24	0:42	MAIN SUPPLY FAILURE
1261	1-Nov-2021	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	16:40	17:27	0:47	MAIN SUPPLY FAILURE
1262	1-Nov-2021	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	15:42	16:24	0:42	MAIN SUPPLY FAILURE
1263	1-Nov-2021	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	16:40	17:27	0:47	MAIN SUPPLY FAILURE
1264	1-Nov-2021	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	15:42	16:24	0:42	MAIN SUPPLY FAILURE
1265	1-Nov-2021	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	16:40	17:21	0:41	MAIN SUPPLY FAILURE
1266	1-Nov-2021	HASSAN	110	HV2	VITTAL_110	16:43	17:25	0:42	HAND TRIPPED
1267	1-Nov-2021	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	10:40	10:50	0:10	LINE FAULT
1268	1-Nov-2021	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	17:30	17:40	0:10	LINE FAULT
1269	1-Nov-2021	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	3:00	3:06	0:06	LINE FAULT
1270	1-Nov-2021	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	5:30	6:35	1:05	LINE FAULT
1271	1-Nov-2021	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	17:29	17:50	0:21	MAIN SUPPLY FAILURE
1272	1-Nov-2021	MYSURU	66	HV2	AKKIHEBBAL_66	2:30	2:40	22:44	TRANSFORMER FAULT
1273	1-Nov-2021	MYSURU	66	HV1	CHUNCHANAKATTE_66	22:29	22:35	0:06	TRANSFORMER FAULT
1274	1-Nov-2021	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	18:30	21:04	2:33	HAND TRIPPED
1275	1-Nov-2021	MYSURU	66	HANNUR-AMP SOLAR	NO STATIONS EFFECTED	7:00	7:17	0:17	LINE FAULT
1276	1-Nov-2021	MYSURU	66	KUSHALNAGARA 220-MERCERA-1	MADIKERI_66	17:49	18:00	0:11	LINE FAULT
1277	1-Nov-2021	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	17:49	18:00	0:11	LINE FAULT
1278	1-Nov-2021	MYSURU	66	MUGUR-CLEAN SOLAR	NO STATIONS EFFECTED	18:01	20:52	2:50	LINE CLEAR AVAILED
1279	1-Nov-2021	MYSURU	66	HOOTAGALLI-RBI	NO STATIONS EFFECTED	10:20	13:10	2:50	LINE CLEAR AVAILED
1280	1-Nov-2021	MYSURU	220	HV2	TUBINKERE_220	15:10:00 (25.10.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1281	1-Nov-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1282	1-Nov-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09(10/10/2021)			LINE OPEN. LINE CLEAR AVAILED
1283	1-Nov-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50 (5.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1284	1-Nov-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1285	1-Nov-2021	MYSURU	66	FTS-HOOTAGALLI 1	NO STATIONS EFFECTED	9:30:05 (30.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1286	1-Nov-2021	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	NO STATIONS EFFECTED	11:03:31 (30.10.2021)			LINE OPEN. LINE CLEAR AVAILED
1287	1-Nov-2021	MYSURU	66	HV1	HANNUR_66	8:25:31 (01.11.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1288	1-Nov-2021	MYSURU	66	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PG PALYA 66	23:58:54 (01.11.2021)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1289	1-Nov-2021	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR IPP_66	AZURE POWER SOLAR IPP_66	7:29:00 PM(31.10.2021)	2:20:32 AM(01.11.2021)	7:00HRS	LINE CHARGED
1290	1-Nov-2021	TUMKUR	110	TR-2	NITTUR_220	14:46	17:37	2:51	LINE CLEAR AVAILED
1291	1-Nov-2021	TUMKUR	66	TR-1	BUKKAPATNA_66	11:46	12:13	0:27	LINE CLEAR AVAILED
1292	1-Nov-2021	TUMKUR	66	TR-2	CHITRAHALLI_66	8:02	8:05	0:02	TRANSFORMER FAULT
1293	1-Nov-2021	TUMKUR	66	TR-2	CHITRAHALLI_66	8:10	8:14	0:04	TRANSFORMER FAULT
1294	1-Nov-2021	TUMKUR	66	DAVANGERE SRS-AVAREGERE66	AVAREGERE_66,MELLEKATE 66,KADAJJI 66	18:22	18:30	0:08	LINE FAULT
1295	1-Nov-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	21:25	21:30	0:04	LINE FAULT
1296	1-Nov-2021	TUMKUR	66	JAVAGONDANAHALLI-BEVINAHALLI	JAVAGONDANAHALLI_66	11:43	12:04	0:20	LOAD CURTAILMENT
1297	1-Nov-2021	TUMKUR	66	MADHUGIRI 220kV-PULLAMAGATTA	PULLAMGATTA_66	5:31	6:23	0:51	LINE FAULT
1298	1-Nov-2021	TUMKUR	66	TR-1	NIDSALE_66	8:40	9:28	0:47	LINE CLEAR AVAILED
1299	1-Nov-2021	TUMKUR	66	PATTNAYAKANAHALLI-TAVAREKERE(SIRA)	PATTNAYAKANAHALLI_66	6:21	6:43	0:21	LINE FAULT
1300	1-Nov-2021	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	8:24	8:34	0:10	LINE FAULT
1301	1-Nov-2021	TUMKUR	66	PAVAGADA-MADHUGIRI	PAVAGADA_66	8:24	8:29	0:04	LINE FAULT
1302	1-Nov-2021	TUMKUR	66	TR-1	SASALIHALLA_66	0:12	0:16	0:04	TRANSFORMER FAULT