

400/220/110/66 kV TRANSMISSION OUTAGES FROM 24.05.22 TO 30.05.22

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	24-May-22	BAGALKOT	110	110/11KV, HV1	CHADCHAN_110	7:20 (19.05.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
2	24-May-22	BAGALKOT	110	110/11KV, HV1	GADAG_110	5:25	6:00	0:35	HAND TRIPPED
3	24-May-22	BAGALKOT	110	110/11KV, HV1	THORVI_110	11:51	11:57	0:06	TRANSFORMER FAULT
4	24-May-22	BAGALKOT	110	110/11KV, HV2	BISNAL_110	4:05	6:45	2:40	TRANSFORMER FAULT
5	24-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED BISANAL_110	5:30	7:31	2:01	HAND TRIPPED
6	24-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED DEVARGENNUR_110	10:06	10:37	0:31	TRANSFORMER FAULT
7	24-May-22	BAGALKOT	110	110/11KV, HV3	BIJAPUR CITY_110	19:10	19:14	0:04	TRANSFORMER FAULT
8	24-May-22	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	17:00	17:21	0:21	TRANSFORMER FAULT
9	24-May-22	BAGALKOT	110	110/11KV,HV1	YADAWAD_110	12:01	12:25	0:24	LINE CLEAR AVOIDED
10	24-May-22	BAGALKOT	110	110/11KV,HV2	SHIRBUR_110	16:43	17:55	1:12	LINE CLEAR AVOIDED
11	24-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
12	24-May-22	BAGALKOT	110	110/33KV, HV1	TEGGI_33 STATION NOT AFFECTED BISANAL_110	6:11	7:31	1:20	HAND TRIPPED
13	24-May-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
14	24-May-22	BAGALKOT	110	110/33KV, HV4	GADAG_110, LAKKUNDI_33, HULKOTI_33	5:25	6:00	0:35	HAND TRIPPED
15	24-May-22	BAGALKOT	110	220/110KV, LV1	AEQUS_110	16:01	19:37	3:36	LINE CLEAR AVOIDED
16	24-May-22	BAGALKOT	110	AMBEWADI-NK1(HALIYAL)	AMBEWADI_220	8:54 (23.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
17	24-May-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
18	24-May-22	BAGALKOT	110	ANNIGERI-GADAG	ANNIGERI_110	5:37 (24.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
19	24-May-22	BAGALKOT	110	GADAG- ANNIGERI	GADAG_110	5:25	6:00	0:35	HAND TRIPPED
20	24-May-22	BAGALKOT	110	HALIYAL-ALNAVAR	STATION NOT AFFECTED HALIYAL_110	16:10	18:18	2:08	NFBC ISSUED
21	24-May-22	BAGALKOT	110	HALYAL-GMR	STATION NOT AFFECTED HALYAL_110	16:01	18:18	2:17	NFBC ISSUED
22	24-May-22	BAGALKOT	110	HUKKERI- VSL COGEN	VSL COGEN_110 HUKKERI_110	10:10	13:25	3:15	LINE CLEAR AVOIDED
23	24-May-22	BAGALKOT	110	HUKKERI-HATTARGI	HUKKERI_110	10:10	16:10	6:00	LINE CLEAR AVOIDED
24	24-May-22	BAGALKOT	110	HUKKERI-KOTABAGI	KOTABAGI_110	10:10	16:10	6:00	LINE CLEAR AVOIDED
25	24-May-22	BAGALKOT	110	KARWAR-SOLARIS(BINAGA)	KARWAR_220	13:18	13:48	0:30	LOAD CHANGE OVER
26	24-May-22	BAGALKOT	110	KERUR-KONNUR	KERUR_110	19:37	19:41	0:04	LINE FAULT
27	24-May-22	BAGALKOT	110	KUMATA-SIRS1(KRCL RAILWAY)	STATION NOT AFFECTED KUMATA_110	12:43	12:46	0:03	LINE FAULT
28	24-May-22	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	MAHALINGAPUR_220	4:46	4:57	0:11	LINE FAULT
29	24-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVOIDED
30	24-May-22	BAGALKOT	110	SANKESHWAR-HUKKERI	STATION NOT AFFECTED SANKESHWAR_110	10:15	13:15	3:00	LINE CLEAR AVOIDED
31	24-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
32	24-May-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED CHIKODI_220	10:42	13:12	2:30	LINE CLEAR AVOIDED
33	24-May-22	BAGALKOT	220	BAGEWADI-BIJAPUR1	STATION NOT AFFECTED BAGEWADI_220	17:54 (19.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
34	24-May-22	BAGALKOT	220	BAGEWADI-BIJAPUR2	STATION NOT AFFECTED BAGEWADI_220	17:54 (19.05.2022)			LINE OPEN:LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
35	24-May-22	BAGALKOT	220	BELGAUM- NARENDRA1	STATION NOT AFFECTED BELGAUM_220	9:01 (14.05.2022)			LINE OPEN:LINE CLEAR AVAILED
36	24-May-22	BAGALKOT	220	BIDNAL- HUBLI3 (HUBLI2)	STATION NOT AFFECTED BIDNAL_220	22:33 (23.05.2022)	12:57 (24.05.2022)	14:24 hrs	LINE CHARGED
37	24-May-22	BAGALKOT	220	CHIKKODI- MUGALAKHOD2	STATION NOT AFFECTED CHIKODI_220	12:23	12:57	0:34	LINE CLEAR AVAILED
38	24-May-22	BAGALKOT	220	HUBLI-BIDNAL2	HUBLI_220	22:33 (23.05.2022)	12:46 (24.05.2022)	14:13 hrs	LINE CHARGED
39	24-May-22	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:40	15:21	3:41	LINE CLEAR AVAILED
40	24-May-22	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	16:59 (23.05.2022)	15:20 (24.05.2022)	22:21 hrs	LINE CHARGED
41	24-May-22	BAGALKOT	220	NARENDRA- BELGAUM1	STATION NOT AFFECTED NARENDRA_220	9:01 (14.05.2022)			LINE OPEN:LINE CLEAR AVAILED
42	24-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
43	24-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
44	24-May-22	BAGALKOT	220	VAJRAMATTI-BAGALKOT2	VAJRAMATTI_220	12:12	19:14	7:01	LINE CLEAR AVAILED
45	24-May-22	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	14:08	14:14	0:06	LOAD CHANGE OVER
46	24-May-22	BENGALURU	66	ABBIGERE - YELAHANKA 220	ABBIGERE	11:48	11:55	0:07	LOAD CHANGE OVER
47	24-May-22	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66, SM MANGALA	12:55	18:24	5:29	LINE CLEAR AVAILED
48	24-May-22	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, DIBBURAHALLI	12:38	12:46	0:08	LOAD CHANGE OVER
49	24-May-22	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, DIBBURAHALLI	15:52	15:57	0:05	LOAD CHANGE OVER
50	24-May-22	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	12:38	12:46	0:08	LOAD CHANGE OVER
51	24-May-22	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	15:52	15:58	0:05	LOAD CHANGE OVER
52	24-May-22	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	12:38	12:47	0:09	LOAD CHANGE OVER
53	24-May-22	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	15:52	16:00	0:08	LOAD CHANGE OVER
54	24-May-22	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLIC CROSS, YENIGADALE	12:38	12:46	0:08	LOAD CHANGE OVER
55	24-May-22	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLIC CROSS, YENIGADALE	15:52	15:58	0:06	LOAD CHANGE OVER
56	24-May-22	BENGALURU	66	CHINTAMANI 66 - CHINTAMANI 220	CHINTAMANI 66	12:49	12:53	0:04	LOAD CHANGE OVER
57	24-May-22	BENGALURU	66	CHINTAMANI 66 - SM MANGALA	CHINTAMANI 66	18:25	18:28	0:03	LOAD CHANGE OVER
58	24-May-22	BENGALURU	66	DABUSPETE 220 - AVEREHALLI	AVAREHALLI	11:10	11:50	0:40	LINE FAULT
59	24-May-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 1	MANCHENAHALLI, GUNDAMGERE	7:10	7:25	0:15	LINE FAULT
60	24-May-22	BENGALURU	66	HV1	MELUR	15:30	15:47	0:17	TRANSFORMER FAULT
61	24-May-22	BENGALURU	66	HV1	SANKALGERE	10:00	11:12	1:12	LINE CLEAR AVAILED
62	24-May-22	BENGALURU	66	HV2	ATTIBELE	14:45	14:50	0:05	LOAD CHANGE OVER
63	24-May-22	BENGALURU	66	HV2	THAYLUR	16:13	16:42	0:28	LINE CLEAR AVAILED
64	24-May-22	BENGALURU	66	HV3	ELECTRONIC CITY P2 S1	3:42	3:53	0:11	TRANSFORMER FAULT
65	24-May-22	BENGALURU	66	JIGANI LINK ROAD - JIGANI 220	JIGANI LINK ROAD	14:13	14:20	0:07	LOAD CHANGE OVER
66	24-May-22	BENGALURU	66	KEMBODI - KOLAR 220	KEMBODI	13:37	14:37	1:00	LINE FAULT
67	24-May-22	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	10:07	10:35	0:28	LINE CLEAR AVAILED
68	24-May-22	BENGALURU	66	LAKSHMIPURA - ADDGAL	ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	10:03	10:15	0:11	LINE FAULT
69	24-May-22	BENGALURU	66	LV1	CHINTAMANI 220	12:38	15:57	3:18	LINE CLEAR AVAILED
70	24-May-22	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	16:18	16:48	0:30	LOAD CHANGE OVER
71	24-May-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	16:46	16:48	0:02	LOAD CHANGE OVER
72	24-May-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	16:18	16:45	0:27	LOAD CHANGE OVER
73	24-May-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	16:18	16:44	0:26	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
74	24-May-22	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	1:25	1:35	0:10	MAIN SUPPLY FAILURE
75	24-May-22	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	6:28	6:31	0:03	LOAD CHANGE OVER
76	24-May-22	BENGALURU	66	SANKALGERE - CHANNAPATNA 220	SANKALGERE	10:00	10:42	0:42	MAIN SUPPLY FAILURE
77	24-May-22	BENGALURU	66	SARIAPURA 220 - ATTIBELE	ATTIBELE	14:16	14:20	0:03	LINE CLEAR AVAILED
78	24-May-22	BENGALURU	66	SM MANGALA - CHINTAMANI 220	SM MANGALA	12:02	12:30	0:28	LOAD CHANGE OVER
79	24-May-22	BENGALURU	66	SM MANGALA - KOLAR 220	SM MANGALA	18:32	1:20	6:48	LOAD CHANGE OVER
80	24-May-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	1:25	1:35	0:10	LINE FAULT
81	24-May-22	BENGALURU	66	WELCAST STEEL - ABBIGERE	WELCAST STEEL	11:38	11:45	0:07	LOAD CHANGE OVER
82	24-May-22	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	14:20	14:24	0:04	LOAD CHANGE OVER
83	24-May-22	BENGALURU	220	HV1	CHINTAMANI 220	12:38	15:55	3:16	LINE CLEAR AVAILED
84	24-May-22	BENGALURU	220	HV2	MALUR 220	16:19	16:41	0:22	LOAD CHANGE OVER
85	24-May-22	BENGALURU	220	MALUR 220 - KOLAR 1 220	MALUR 220	16:05	16:10	0:05	LOAD CHANGE OVER
86	24-May-22	GULBARGA	66	MAGALA-HIREHADAGALLI	MAGALA_66	14:56	15:01	0:05	LINE FAULT
87	24-May-22	GULBARGA	66	TAMBRAHALLI-ITTAGGI	TAMBRAHALLI_66	14:15	15:00	0:45	MAIN SUPPLY FAILURE
88	24-May-22	GULBARGA	110	HV1	NANDUR_110	17:00	20:25	3:25	LINE CLEAR AVAILED
89	24-May-22	GULBARGA	110	HV2	DEODURGA_110	0:50	0:55	0:05	TRANSFORMER FAULT
90	24-May-22	GULBARGA	110	HV2	DEODURGA_110	11:10	11:20	0:10	LINE CLEAR AVAILED
91	24-May-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	5:25	6:29	1:04	LINE FAULT
92	24-May-22	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	5:35	6:17	0:42	LINE FAULT
93	24-May-22	GULBARGA	110	SHAHABAD-FARTHABAD	FARTHABAD_110,GULBARGA SOUTH_110	11:50	13:58	2:08	LINE CLEAR AVAILED
94	24-May-22	GULBARGA	110	SHAHABAD-RAICHUR_1 & 2	JEWARGI_110,NALWAR_110	11:02	17:18	6:16	LINE CLEAR AVAILED
95	24-May-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	3:17	3:27	0:10	LINE FAULT
96	24-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SA NNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
97	24-May-22	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	5:35	5:50	0:15	LINE CLEAR AVAILED
98	24-May-22	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	5:32	5:46	0:14	LINE FAULT
99	24-May-22	GULBARGA	220	ALIPUR-RAGALPADU	RAGALPADU_220	2:35(17.05.2022)			LINE OPEN:LINE CLEAR AVAILED
100	24-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
101	24-May-22	GULBARGA	220	KUDLIGI-HIREMALLANAHALLI 1&2	KUDLIGI_220	17:25(08.05.2022)			LINE OPEN:LINE FAULT
102	24-May-22	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	01:55(17.05.2022)			LINE OPEN:LINE CLEAR AVAILED
103	24-May-22	GULBARGA	220	MALLAT-RTPS LINE 3	MALLAT_220	12:55(23/05/2022)	13:50 (24.05.2022)	24:55 HRS	LINE CHARGED
104	24-May-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN:LINE FAULT
105	24-May-22	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	5:30(19.05.2022)	13:20(24.05.2022)	158:51HRS	LINE CHARGED
106	24-May-22	HASSAN	66	AREHALI-SAKLESPUR	AREHALLI_66	11:30	15:05	3:35	MAIN SUPPLY FAILURE
107	24-May-22	HASSAN	66	HV1	HADAVANAHALLY_66	13:25	16:00	2:35	LINE CLEAR AVAILED
108	24-May-22	HASSAN	66	HV1	HARIHARPURA_66	10:00	13:10	3:10	LINE CLEAR AVAILED
109	24-May-22	HASSAN	66	HV1	HOLALUR_66	15:25	16:10	0:45	TRANSFORMER FAULT
110	24-May-22	HASSAN	66	HV1	SOMNAHALLY_66	16:40	17:30	0:50	LINE CLEAR AVAILED
111	24-May-22	HASSAN	66	HV2	HADAVANAHALLY_66	10:20	13:25	3:05	LINE CLEAR AVAILED
112	24-May-22	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	11:15	15:10	3:55	LINE CLEAR AVAILED
113	24-May-22	HASSAN	66	SAKALE-HANBAL	SAKALESHPURA_66	11:30	15:02	3:32	LINE CLEAR AVAILED
114	24-May-22	HASSAN	66	SAKALE-HASSAN	SAKALESHPURA_66	11:10	15:13	4:03	NFBC ISSUED
115	24-May-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	10:05	17:00	6:55	LINE CLEAR AVAILED
116	24-May-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	10:05	16:05	6:00	LINE CLEAR AVAILED
117	24-May-22	HASSAN	110	ANVATTI-BARNGI	ANAVATTI:110	8:00	8:20	0:20	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
118	24-May-22	HASSAN	110	ANVATTI-BARNGI	ANAVATTI:110	19:15	19:33	0:18	HAND TRIPPED
119	24-May-22	HASSAN	110	BARANGI-ANVATTI	BARANGI:110	19:15	19:30	0:15	HAND TRIPPED
120	24-May-22	HASSAN	110	HV1	BRAHMAVARA:110	9:54	13:15	3:21	LINE CLEAR AVAILED
121	24-May-22	HASSAN	110	HV1	ESSUR:110	10:15	18:35	8:20	LINE CLEAR AVAILED
122	24-May-22	HASSAN	110	HV1	NAVUNDA_110	9:05	16:00	6:55	HAND TRIPPED
123	24-May-22	HASSAN	110	HV2	BARANGI_110	10:22(17.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
124	24-May-22	HASSAN	110	HV2	BRAHMAVARA:110	11:19	13:15	1:56	LINE CLEAR AVAILED
125	24-May-22	HASSAN	110	HV2	ESSUR:110	10:15	18:35	8:20	LINE CLEAR AVAILED
126	24-May-22	HASSAN	110	HV2	KADUR_220	10:45	11:25	0:40	TRANSFORMER FAULT
127	24-May-22	HASSAN	110	HV2	NAVUNDA_110	9:05	16:07	7:02	LINE CLEAR AVAILED
128	24-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
129	24-May-22	HASSAN	110	JOG110-LPH	JOG_110	11:00	11:15	0:15	HAND TRIPPED
130	24-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
131	24-May-22	HASSAN	110	KADUR-NGNHL	KADUR_220	11:05	11:25	0:20	LINE FAULT
132	24-May-22	HASSAN	110	KADUR-TNGL	KADUR_220	11:05	11:25	0:20	LINE FAULT
133	24-May-22	HASSAN	110	KADUR-YGTI	KADUR_220	11:05	11:25	0:20	LINE FAULT
134	24-May-22	HASSAN	110	KEMAR-Manipal1	KEMAR:220	10:26	11:49	1:23	LINE CLEAR AVAILED
135	24-May-22	HASSAN	110	LPH-MGHE 1	gen_lph	11:03	11:12	0:09	HAND TRIPPED
136	24-May-22	HASSAN	110	LV2	KADUR_220	11:45	12:52	1:07	LINE CLEAR AVAILED
137	24-May-22	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	10:26	11:49	1:23	NFBC ISSUED
138	24-May-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LINE OPEN:LINE FAULT
139	24-May-22	HASSAN	110	NAVUNDA-MADHUVANA	NAVUNDA_110	9:05	16:00	6:55	LINE CLEAR AVAILED
140	24-May-22	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	9:57	15:53	5:56	LINE CLEAR AVAILED
141	24-May-22	HASSAN	110	SHR220	BARANGI:110	8:00	8:15	0:15	HAND TRIPPED
142	24-May-22	HASSAN	110	SHRLKP-BARANG	SHIRaLKOPPA_220	7:59	19:30	11:31	LINE CLEAR AVAILED
143	24-May-22	HASSAN	220	GOPAL-HSN400	GOPALAPURA_220	12:05	14:40	2:35	LINE CLEAR AVAILED
144	24-May-22	HASSAN	220	HASSN400-GOPALPURA	HASSAN:400	12:05	14:40	2:35	NFBC ISSUED
145	24-May-22	HASSAN	220	HV2	GOPALAPURA_220	13:28	18:32	5:04	LINE CLEAR AVAILED
146	24-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
147	24-May-22	HASSAN	220	SHRAVITY-SIRISI 1	gen_sharavaty	11:31	15:45	4:14	LINE CLEAR AVAILED
148	24-May-22	HASSAN	220	VARAHI-SHIMOGA2	gen_varahi	13:18	14:19	1:01	LINE FAULT
149	24-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
150	24-May-22	MYSURU	66	AKKIHEBBAL-KAVERI HYDRO	NO STATIONS EFFECTED	10:16	10:21	0:05	LINE FAULT
151	24-May-22	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
152	24-May-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
153	24-May-22	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	12:03:00 (14.5.2022)			LINE OPEN:LINE FAULT
154	24-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
155	24-May-22	MYSURU	66	HOOTGALLY-BANNIKUPPE	NO STATIONS EFFECTED	9:00	13:50	4:50	LINE CLEAR AVAILED
156	24-May-22	MYSURU	66	HV1	BESAGARAHALLI_66	10:50	12:55	2:05	LINE CLEAR AVAILED
157	24-May-22	MYSURU	66	HV1	JYOTHINAGARA_66	10:51	13:13	2:22	LINE CLEAR AVAILED
158	24-May-22	MYSURU	66	HV1	KRPET_220	10:00	14:35	4:35	LINE CLEAR AVAILED
159	24-May-22	MYSURU	66	HV1	MADHUVANAHALLI_220	14:31	15:33	1:02	LINE CLEAR AVAILED
160	24-May-22	MYSURU	66	HV1	MADIKERI_66	9:19	18:30	9:11	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
161	24-May-22	MYSURU	66	HV1	NAGAMANGALA_66	1:15	1:20	0:05	TRANSFORMER FAULT
162	24-May-22	MYSURU	66	HV1	PERIYAPATNA_66	12:40	13:26	0:46	TRANSFORMER FAULT
163	24-May-22	MYSURU	66	HV1	SUNTIKOPPA_66	10:46	10:51	0:05	TRANSFORMER FAULT
164	24-May-22	MYSURU	66	HV2	BESAGARAHALLI_66	12:35	14:20	1:45	LINE CLEAR AVAILED
165	24-May-22	MYSURU	66	HV2	DEVANOORMYS_66	11:44	12:10	0:26	LINE CLEAR AVAILED
166	24-May-22	MYSURU	66	HV2	DEVANOORNGUDU_66	16:19	17:57	1:38	LINE CLEAR AVAILED
167	24-May-22	MYSURU	66	HV2	JYOTHINAGARA_66	13:14	15:15	2:00	LINE CLEAR AVAILED
168	24-May-22	MYSURU	66	HV2	KOLLEGALA_66	17:10	17:14	0:03	TRANSFORMER FAULT
169	24-May-22	MYSURU	66	HV2	KRPET_220	12:10	13:30	1:20	LINE CLEAR AVAILED
170	24-May-22	MYSURU	66	HV2	MADHUVANAHALLI_220	13:53	14:19	0:26	LINE CLEAR AVAILED
171	24-May-22	MYSURU	66	JAKKANAHALLI-NAGMANGALA	G MALLIGERE_66	10:21	13:40	3:18	NFBC ISSUED
172	24-May-22	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57:05 (4/5/2022)			LINE OPEN:LINE CLEAR AVAILED
173	24-May-22	MYSURU	66	KOLLEGALA-PARINAMIPURA	CHANDALLI_66PARINAMIPURA_66THALAKADU_66	15:57	16:03	0:06	LINE FAULT
174	24-May-22	MYSURU	66	KR PETE 220-BOOKANAKERE	SHEELUNERE_66BOOKANAKERE_66CHINAKURALI_66 GANJIGERE_66	22:46	22:51	0:04	LINE FAULT
175	24-May-22	MYSURU	66	KR PETE 220-SB HALLI 2	ADICHUNCHANAGIRI_66BGNAGARA_66SANTHEBAC HALLI_66VADERALLI_66KADABALLY_66	16:08	17:35	1:27	LINE CLEAR AVAILED
176	24-May-22	MYSURU	66	KR PETE 220-SB HALLI1	HARIYALDAMMATEMPLE_66	13:36	16:16	2:40	LINE CLEAR AVAILED
177	24-May-22	MYSURU	66	KR PETE-HUYGONAHALLI 2	NO STATIONS EFFECTED	10:17	10:25	0:08	LINE FAULT
178	24-May-22	MYSURU	66	KR PETE-KIKKERI	KIKKERI_66	10:17	10:25	0:08	LINE FAULT
179	24-May-22	MYSURU	66	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	19:00	19:06	0:06	LINE FAULT
180	24-May-22	MYSURU	66	KUNTHUR-DODDRAIPET	NO STATIONS EFFECTED	19:00	19:06	0:06	LINE FAULT
181	24-May-22	MYSURU	66	MADHUVANAHALLI-DODDINADUWADI	NO STATIONS EFFECTED	10:03	11:08	1:05	LINE CLEAR AVAILED
182	24-May-22	MYSURU	66	MADHUVANAHALLI-HANNUR1	NO STATIONS EFFECTED	13:20	14:03	0:42	LINE CLEAR AVAILED
183	24-May-22	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	12:36	13:20	0:44	LINE CLEAR AVAILED
184	24-May-22	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	10:30	11:24	0:53	LINE CLEAR AVAILED
185	24-May-22	MYSURU	66	MADHUVANAHALLI-KOLLEGALA1	NO STATIONS EFFECTED	11:18	12:43	1:25	LINE CLEAR AVAILED
186	24-May-22	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	10:58	11:51	0:53	LINE CLEAR AVAILED
187	24-May-22	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	11:56	13:06	1:09	LINE CLEAR AVAILED
188	24-May-22	MYSURU	66	NANJANGUDU-SINDHUVALLI	NO STATIONS EFFECTED	18:29	18:43	0:13	LINE FAULT
189	24-May-22	MYSURU	220	HV1	NAGAMANGALA_220	11:27	11:37	0:10	TRANSFORMER FAULT
190	24-May-22	MYSURU	220	HV2	NAGAMANGALA_220	11:27	11:42	0:15	TRANSFORMER FAULT
191	24-May-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLTEGERE	KOLTEGERE,CHIKKATOTLUKERE_66, BELADARA_66	12:46	12:49	0:03	LINE FAULT
192	24-May-22	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	9:03	10:52	1:49	HAND TRIPPED
193	24-May-22	TUMKUR	220	TR-1	DAVANAGERE_SRS 220	14:35	16:25	1:50	LINE CLEAR AVAILED
194	24-May-22	TUMKUR	220	TR-3	DAVANAGERE_SRS 220	14:35	16:24	1:49	LINE CLEAR AVAILED
195	25-May-22	BAGALKOT	110	110/11KV, HV1	BISNAL_110	6:46	7:30	0:44	HAND TRIPPED
196	25-May-22	BAGALKOT	110	110/11KV, HV1	CHADCHAN_110	7:20 (19.05.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
197	25-May-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUNDAGANUR_110	11:30	13:30	2:00	LINE CLEAR AVAILED
198	25-May-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED HIREMASALI_110	18:16	19:15	0:59	LINE CLEAR AVAILED
199	25-May-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NAGANUR_110	11:19	11:49	0:30	HAND TRIPPED
200	25-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YELLAMANAWADI_110	16:01	16:28	0:27	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
201	25-May-22	BAGALKOT	110	110/11KV, HV4	BAILHONGAL_110	11:10	13:50	2:40	LINE CLEAR AVAILED
202	25-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
203	25-May-22	BAGALKOT	110	110/33KV, HV2	TEGGI_33 BISNAL_110	6:46	7:34	0:48	HAND TRIPPED
204	25-May-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
205	25-May-22	BAGALKOT	110	220/110KV, HV2 & LV2	STATION NOT AFFECTED CHIKODI_220	10:25	11:49	1:24	LINE CLEAR AVAILED
206	25-May-22	BAGALKOT	110	220MKHUBLI-2-MKHUBLI	STATION NOT AFFECTED MK HUBLI_110	13:13	16:15	3:02	NFBC ISSUED
207	25-May-22	BAGALKOT	110	AMBEWADI-NK1(HALIYAL)	AMBEWADI_220	8:54 (23.05.2022)			LINE OPEN:LINE CLEAR AVAILED
208	25-May-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVAILED
209	25-May-22	BAGALKOT	110	ANNIGERI-GADAG	ANNIGERI_110	5:37 (24.05.2022)	16:17 (25.05.2022)	34:40 hrs	LOAD CHANGE OVER
210	25-May-22	BAGALKOT	110	BILAGI-GIRASAGAR	GIRISAGAR_110 BISNAL_110	6:40	6:45	0:05	LINE CLEAR AVAILED
211	25-May-22	BAGALKOT	110	BILAGI-GIRASAGAR	GIRISAGAR_110 BISNAL_110	7:25	7:35	0:10	LINE CLEAR AVAILED
212	25-May-22	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	14:20	15:04	0:44	LINE CLEAR AVAILED
213	25-May-22	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:19	16:14	0:55	LINE CLEAR AVAILED
214	25-May-22	BAGALKOT	110	HUKKERI-HATTARGI	STATION NOT AFFECTED HUKKERI_110	10:50	23:59	13:09	LINE CLEAR AVAILED
215	25-May-22	BAGALKOT	110	JAMBAGI KD- MUDHOL(VJRM)	JAMBAGI KD_110	5:27	5:35	0:08	LINE FAULT
216	25-May-22	BAGALKOT	110	M.K HUBLI220-MK HUBLI2	STATION NOT AFFECTED MK HUBLI_220	13:12	16:16	3:04	LINE CLEAR AVAILED
217	25-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
218	25-May-22	BAGALKOT	110	RANEENNUR220-HIREKERUR	HIREKERUR_110	12:55	13:10	0:15	LINE FAULT
219	25-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
220	25-May-22	BAGALKOT	220	220/110KV, HV1 & LV1	STATION NOT AFFECTED KARWAR_220	16:19	19:39	3:20	LINE CLEAR AVAILED
221	25-May-22	BAGALKOT	220	220/110KV, HV2 & LV2	STATION NOT AFFECTED KARWAR_220	12:40	16:18	3:38	LINE CLEAR AVAILED
222	25-May-22	BAGALKOT	220	BAGEWADI-BIJAPUR1	STATION NOT AFFECTED BAGEWADI_220	17:54 (19.05.2022)			LINE OPEN:LINE CLEAR AVAILED
223	25-May-22	BAGALKOT	220	BAGEWADI-BIJAPUR2	STATION NOT AFFECTED BAGEWADI_220	17:54 (19.05.2022)			LINE OPEN:LINE CLEAR AVAILED
224	25-May-22	BAGALKOT	220	BELGAUM- NARENDRA1	STATION NOT AFFECTED BELGAUM_220	9:01 (14.05.2022)			LINE OPEN:LINE CLEAR AVAILED
225	25-May-22	BAGALKOT	220	BIDNAL- ANNIGERI	STATION NOT AFFECTED BIDNAL_220	14:18	14:58	0:40	LOAD CHANGE OVER
226	25-May-22	BAGALKOT	220	BIDNAL- TADAS2 (HIREBENDIGERI)	STATION NOT AFFECTED BIDNAL_220	9:06	19:54	10:48	LINE CLEAR AVAILED
227	25-May-22	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	11:45	12:51	1:06	HAND TRIPPED
228	25-May-22	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	12:51	18:18	5:27	LINE FAULT
229	25-May-22	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	12:44	18:19	5:35	HAND TRIPPED
230	25-May-22	BAGALKOT	220	KARWAR- KADRA-2	STATION NOT AFFECTED KARWAR_220	10:23	15:18	4:55	LINE CLEAR AVAILED
231	25-May-22	BAGALKOT	220	NARENDRA- BELGAUM1	STATION NOT AFFECTED NARENDRA_220	9:01 (14.05.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
232	25-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
233	25-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
234	25-May-22	BAGALKOT	220	SIRSI-SHARAVATI1	STATION NOT AFFECTED SIRSI_220	13:46	14:25	0:39	HAND TRIPPED
235	25-May-22	BAGALKOT	220	SIRSI-SHARAVATI2	STATION NOT AFFECTED SIRSI_220	9:14	11:46	2:32	HAND TRIPPED
236	25-May-22	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	18:22	18:24	0:02	LOAD CHANGE OVER
237	25-May-22	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	16:14	16:21	0:07	MAIN SUPPLY FAILURE
238	25-May-22	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	17:42	20:08	2:25	LINE FAULT
239	25-May-22	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	4:33	4:41	0:07	LINE FAULT
240	25-May-22	BENGALURU	66	HBR LAYOUT 66 - KONDASPURA	KONDASPURA	22:37(25-5-2022)			LINE OPEN:LINE FAULT
241	25-May-22	BENGALURU	66	HBR LAYOUT 66 - KONDASPURA	KONDASPURA	22:37(25-5-2022)	11:52(26-5-2022)	13:14 hrs	LINE CHARGED
242	25-May-22	BENGALURU	66	HV1	HSR LAYOUT_220	15:45	15:54	0:09	TRANSFORMER FAULT
243	25-May-22	BENGALURU	66	HV2	KEMBODI	12:30	12:35	0:05	LINE CLEAR AVOIDED
244	25-May-22	BENGALURU	66	HV2	M GOLLAHALLI	13:40	15:23	1:42	LINE CLEAR AVOIDED
245	25-May-22	BENGALURU	66	HV2	SARJAPURA 220	11:05	13:08	2:03	LINE CLEAR AVOIDED
246	25-May-22	BENGALURU	66	HV2	VOLVO	16:07	16:10	0:03	LINE CLEAR AVOIDED
247	25-May-22	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	14:59	15:39	0:40	LINE CLEAR AVOIDED
248	25-May-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALALI	11:45	11:55	0:10	LINE FAULT
249	25-May-22	BENGALURU	66	KUDUR - SIRIGIRIPURA	SIRIGIRIPURA	8:14	8:39	0:25	LINE FAULT
250	25-May-22	BENGALURU	66	KUDUR - SIRIGIRIPURA	SIRIGIRIPURA	8:39	9:04	0:25	LINE FAULT
251	25-May-22	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	19:40	19:43	0:03	LOAD CHANGE OVER
252	25-May-22	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	16:12	16:19	0:07	MAIN SUPPLY FAILURE
253	25-May-22	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	16:14	16:21	0:07	MAIN SUPPLY FAILURE
254	25-May-22	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	22:11	22:14	0:03	LOAD CHANGE OVER
255	25-May-22	BENGALURU	66	SOBHA FOREST - SUBRAMANYAPURA 220	SOBHA FOREST	16:14	16:30	0:16	MAIN SUPPLY FAILURE
256	25-May-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	16:14	16:32	0:18	MAIN SUPPLY FAILURE
257	25-May-22	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	16:14	16:20	0:06	MAIN SUPPLY FAILURE
258	25-May-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR,K HONALGERE, YATHAMBADI	10:36	11:08	0:32	LINE FAULT
259	25-May-22	BENGALURU	220	KHODAYS 220 - SUBRAMAYAPURA 220	SUBRAMANYAPURA 220	16:14	16:30	0:16	LINE FAULT
260	25-May-22	BENGALURU	220	SUBRAMANYAPURA 220 - KHODAYS 220	SUBRAMANYAPURA 220	16:14	16:20	0:06	LINE FAULT
261	25-May-22	GULBARGA	66	HV1	ITTAGI_220	11:08	12:05	0:57	LINE CLEAR AVOIDED
262	25-May-22	GULBARGA	110	HV1	GABBUR_110	7:30	7:45	0:15	TRANSFORMER FAULT
263	25-May-22	GULBARGA	110	HV1	HOLAGUNDI_110	15:50	15:55	0:05	TRANSFORMER FAULT
264	25-May-22	GULBARGA	110	HV1	JAWALGERA_110	10:00	10:30	0:30	LINE CLEAR AVOIDED
265	25-May-22	GULBARGA	110	HV1	KURKUNTA_110	7:30	7:45	0:15	LOAD CURTAILMENT
266	25-May-22	GULBARGA	110	HV1	MAHAGOAN_110	7:30	8:00	0:30	LOAD CURTAILMENT
267	25-May-22	GULBARGA	110	HV1	SHORAPUR_110	13:42	16:18	2:36	LINE CLEAR AVOIDED
268	25-May-22	GULBARGA	110	HV2	CHINCHOLI_110	10:19	17:52	7:33	LINE CLEAR AVOIDED
269	25-May-22	GULBARGA	110	HV2	CHOWDAPUR_110	13:05	13:10	0:05	TRANSFORMER FAULT
270	25-May-22	GULBARGA	110	HV2	HANUMANAL_110	23:15	23:55	0:40	TRANSFORMER FAULT
271	25-May-22	GULBARGA	110	LADHA-WARDHA SOLAR	LADHA_110	19:00	22:10	3:10	LINE CLEAR AVOIDED
272	25-May-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	2:50	3:10	0:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
273	25-May-22	GULBARGA	110	RAICHUR-APMC_1	APMC_110,CHIKSUGUR_110,SHAKTINAGAR_110	4:27	4:40	0:13	LINE FAULT
274	25-May-22	GULBARGA	110	RAICHUR-APMC_2	APMC_110,CHIKSUGUR_110,SHAKTINAGAR_110	4:27	4:40	0:13	LINE FAULT
275	25-May-22	GULBARGA	110	RAICHUR-SHAHAPUR_2	GOOGLE_110	20:42	20:44	0:02	LINE FAULT
276	25-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SA NNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
277	25-May-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAG AR_110,MALLAPURA_110	4:30	4:40	0:10	LINE FAULT
278	25-May-22	GULBARGA	220	ALIPUR-RAGALPADU	RAGALPADU_220	2:35(17.05.2022)			LINE OPEN:LINE CLEAR AVAILED
279	25-May-22	GULBARGA	220	BADELADUKU(KUDLIGI)-HIEMALLANAHALLI 1&2	BADELADUKU_220	17:25(08.05.2022)	19:18 (25.05.2022)	409:53 HRS	LINE CHARGED
280	25-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
281	25-May-22	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	01:55(17.05.2022)			LINE OPEN:LINE CLEAR AVAILED
282	25-May-22	GULBARGA	220	LINGAPUR-MUNIRABAD2	MUNIRABAD_220	8:41	15:34	6:53	LINE CLEAR AVAILED
283	25-May-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN:LINE FAULT
284	25-May-22	HASSAN	66	BELLU66-HASSAN	BELUR_66	10:00	17:35	7:35	LINE CLEAR AVAILED
285	25-May-22	HASSAN	66	BELLU66-MUDIGERE	BELUR_66	10:00	17:15	7:15	LINE CLEAR AVAILED
286	25-May-22	HASSAN	66	GENDEHL-MUDIGERE	GENDEHALLY_66	10:05	17:45	7:40	MAIN SUPPLY FAILURE
287	25-May-22	HASSAN	66	HNPR2-HASS3	HNPURA_220	11:15	13:15	2:00	LINE CLEAR AVAILED
288	25-May-22	HASSAN	66	HNPR2-RNPR1	HNPURA_220	11:35	11:40	0:05	LINE FAULT
289	25-May-22	HASSAN	66	HNPR2-RNPR1	HNPURA_220	18:10	18:20	0:10	LINE FAULT
290	25-May-22	HASSAN	66	HV1	BELUR_66	10:00	17:10	7:10	LINE CLEAR AVAILED
291	25-May-22	HASSAN	66	HV1	CHANNARAYAPATNA_66	12:15	13:10	0:55	LINE CLEAR AVAILED
292	25-May-22	HASSAN	66	HV1	HALEBEEDU_66	19:45	20:50	1:05	TRANSFORMER FAULT
293	25-May-22	HASSAN	66	HV1	MOSALEHOSHALLY_66	11:10	11:25	0:15	LOAD CHANGE OVER
294	25-May-22	HASSAN	66	HV1	MOSALEHOSHALLY_66	13:20	13:25	0:05	LOAD CHANGE OVER
295	25-May-22	HASSAN	66	HV1	RAMESHWARNAGRA_66	15:25	16:10	0:45	LINE CLEAR AVAILED
296	25-May-22	HASSAN	66	HV1	SBELAGOLA_66	10:35	13:40	3:05	LINE CLEAR AVAILED
297	25-May-22	HASSAN	66	HV2	BELUR_66	10:00	17:10	7:10	LINE CLEAR AVAILED
298	25-May-22	HASSAN	66	HV2	HALEBEEDU_66	19:45	22:40	2:55	TRANSFORMER FAULT
299	25-May-22	HASSAN	66	HV2	SBELAGOLA_66	12:15	13:40	1:25	LINE CLEAR AVAILED
300	25-May-22	HASSAN	66	HV4	BALEHONNUR_66	19:48	20:08	0:20	TRANSFORMER FAULT
301	25-May-22	HASSAN	66	MSHOSHL-BIOMASS	MOSALEHOSHALLY_66	11:25	13:20	1:55	LOAD CHANGE OVER
302	25-May-22	HASSAN	66	MSHOSHL-HNPRA	MOSALEHOSHALLY_66	11:10	13:15	2:05	NFBC ISSUED
303	25-May-22	HASSAN	66	SAKALE-IPCL1	SAKALESH PURA_66	10:25	17:30	7:05	LINE CLEAR AVAILED
304	25-May-22	HASSAN	66	SAKALE-IPCL2	SAKALESH PURA_66	10:25	17:30	7:05	LINE CLEAR AVAILED
305	25-May-22	HASSAN	110	BRAMAV-MANIPAL	BRAHMAVARA_110	11:14	11:16	0:02	HAND TRIPPED
306	25-May-22	HASSAN	110	GURPUR-MDBDRE	GURUPURA_110	10:55	15:00	4:05	NFBC ISSUED
307	25-May-22	HASSAN	110	HV1	JAVAGAL_110	7:30	7:45	0:15	TRANSFORMER FAULT
308	25-May-22	HASSAN	110	HV1	KONAJE_110	10:27	13:13	2:46	LINE CLEAR AVAILED
309	25-May-22	HASSAN	110	HV1	KONDENALU_110	7:30	7:45	0:15	TRANSFORMER FAULT
310	25-May-22	HASSAN	110	HV1	PUTTUR_110	9:20	11:28	2:08	LINE CLEAR AVAILED
311	25-May-22	HASSAN	110	HV2	BANAVAR_110	7:25	7:40	0:15	HAND TRIPPED
312	25-May-22	HASSAN	110	HV2	BARANGI_110	10:22(17.05.2022)	14:(25.05.2022)	89:47HRS	TRANSFORMER CHARGED
313	25-May-22	HASSAN	110	HV2	BARANGI_110	13:13	16:11	2:58	LINE CLEAR AVAILED
314	25-May-22	HASSAN	110	HV2	GANDASI_110	7:30	7:45	0:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
315	25-May-22	HASSAN	110	HV2	PUTTUR_110	11:29	12:46	1:17	LINE CLEAR AVAIED
316	25-May-22	HASSAN	110	HV2	SAGARA_110	10:00	18:30	8:30	LINE CLEAR AVAIED
317	25-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAIED
318	25-May-22	HASSAN	110	HV5	MRSMSG_220	9:29	14:34	5:05	LINE CLEAR AVAIED
319	25-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAIED
320	25-May-22	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	10:45	10:47	0:02	LINE CLEAR AVAIED
321	25-May-22	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	15:35	15:37	0:02	LINE CLEAR AVAIED
322	25-May-22	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	10:02	13:13	3:11	LINE CLEAR AVAIED
323	25-May-22	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	18:15	20:04	1:49	LINE CLEAR AVAIED
324	25-May-22	HASSAN	110	LPH-LST3	gen_lph	11:41	12:26	0:45	LINE CLEAR AVAIED
325	25-May-22	HASSAN	110	LPH-MGHE 1	gen_lph	11:38	12:28	0:50	HAND TRIPPED
326	25-May-22	HASSAN	110	LV1	PUTTUR_220	9:45	14:50	5:05	LINE CLEAR AVAIED
327	25-May-22	HASSAN	110	MANIPA-NITTUR	MANIPAL_110	11:15	12:10	0:55	LINE CLEAR AVAIED
328	25-May-22	HASSAN	110	MOODABI-GURUPURA	MOODABIDRE_110	11:00	15:00	4:00	LINE CLEAR AVAIED
329	25-May-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LINE OPEN:LINE FAULT
330	25-May-22	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	18:58	19:48	0:50	NFBC ISSUED
331	25-May-22	HASSAN	110	TALAGU-L1-LST 3 LPH	TALAGUPPA_110	11:45	12:25	0:40	NFBC ISSUED
332	25-May-22	HASSAN	220	GOPAL-BASTIPURA	GOPALAPURA_220	10:15	12:40	2:25	LINE CLEAR AVAIED
333	25-May-22	HASSAN	220	HV1	PUTTUR_220	9:45	14:50	5:05	LINE CLEAR AVAIED
334	25-May-22	HASSAN	220	HV2	GOPALAPURA_220	8:05(25.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAIED
335	25-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAIED
336	25-May-22	HASSAN	220	MRSSTM-SHARAVATHY3	MRSMSG_220	12:05	12:51	0:46	LINE CLEAR AVAIED
337	25-May-22	HASSAN	220	SHRAVTY-SHIMOGA3	gen_sharavaty	12:05	12:57	0:52	LINE FAULT
338	25-May-22	HASSAN	220	SHRAVTY-SHIRALKOPPA	gen_sharavaty	9:29	14:34	5:05	NFBC ISSUED
339	25-May-22	HASSAN	220	SHRAVTY-SIRISI 1	gen_sharavaty	13:46	14:25	0:39	HAND TRIPPED
340	25-May-22	HASSAN	220	SHRAVTY-SIRISI 2	gen_sharavaty	9:15	11:46	2:31	LINE FAULT
341	25-May-22	HASSAN	220	SHRLKP-SGS	shiralkoppa_220	12:08	14:48	2:40	LINE CLEAR AVAIED
342	25-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAIED
343	25-May-22	MYSURU	66	CHUNCHANKATTE-RAVANDUR	NO STATIONS EFFECTED	11:14	11:37	0:23	LINE FAULT
344	25-May-22	MYSURU	66	CR NAGARA-HONGANUR	HONGANUR_66	9:12	17:23	8:11	LINE CLEAR AVAIED
345	25-May-22	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAIED
346	25-May-22	MYSURU	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	9:54	16:59	7:05	LINE CLEAR AVAIED
347	25-May-22	MYSURU	66	GUNDLUPETE-HANGALA	BHARGI_66HANGLA_66	10:05	17:30	7:25	LINE CLEAR AVAIED
348	25-May-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAIED
349	25-May-22	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	12:03:00 (14.5.2022)			LINE OPEN:LINE FAULT
350	25-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAIED
351	25-May-22	MYSURU	66	HV1	HANAGODU_66	7:28	7:38	0:10	LINE CLEAR AVAIED
352	25-May-22	MYSURU	66	HV1	PANDAVAPURA_66	7:28	7:33	0:05	LINE CLEAR AVAIED
353	25-May-22	MYSURU	66	HV1	TUBINAKERE_220	10:24	12:25	2:01	LINE CLEAR AVAIED
354	25-May-22	MYSURU	66	HV2	AKKIHBBAL_66	7:27	7:44	0:16	LINE CLEAR AVAIED
355	25-May-22	MYSURU	66	HV2	BOOKANAKERE_66	7:27	7:34	0:06	LINE CLEAR AVAIED
356	25-May-22	MYSURU	66	HV2	HALGUR_66	7:28	7:53	0:25	LINE CLEAR AVAIED
357	25-May-22	MYSURU	66	HV2	HANNUR_66	9:00	9:10	0:10	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
358	25-May-22	MYSURU	66	HV2	KIRUGVALU_66	7:28	7:53	0:24	LINE CLEAR AVAILED
359	25-May-22	MYSURU	66	HV2	SUTTUR_66	7:38	18:33	10:55	LINE CLEAR AVAILED
360	25-May-22	MYSURU	66	HV2	TUBINAKERE_220	11:14	11:33	0:19	HAND TRIPPED
361	25-May-22	MYSURU	66	HV2	TUBINAKERE_220	12:23	16:14	3:51	LINE CLEAR AVAILED
362	25-May-22	MYSURU	66	HV2	VAJAMANGALA_220	11:37	14:25	2:48	LINE CLEAR AVAILED
363	25-May-22	MYSURU	66	HV3	TUBINAKERE_220	10:15	12:29	2:14	LINE CLEAR AVAILED
364	25-May-22	MYSURU	66	K R PETE 220-BOOKANAKERE	SHEELUNERE_66BOOKANAKERE_66CHINAKURALI_66 GANJIGERE_66	11:00	17:42	6:41	LINE CLEAR AVAILED
365	25-May-22	MYSURU	66	K R PETE 220-SB HALLI2	NO STATIONS EFFECTED	14:00	14:45	0:45	LINE CLEAR AVAILED
366	25-May-22	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57:05 (4/5/2022)			LINE OPEN:LINE CLEAR AVAILED
367	25-May-22	MYSURU	66	KUSHALNAGARA-BETTADAPURA	BETTADHAPURA_66KITTUR_66RAVANDUR_66	11:00	12:00	1:00	LINE CLEAR AVAILED
368	25-May-22	MYSURU	66	KUSHALNAGARA-PERIYAPATNA 1	NO STATIONS EFFECTED	11:42	12:55	1:13	LINE CLEAR AVAILED
369	25-May-22	MYSURU	66	KUSHALNAGARA-RAMNATHAPURA1	CBHALLI_66RUDRAPATNA_66ALURSIDDAPURA_66KA NGAL_66	16:16	16:22	0:06	LINE FAULT
370	25-May-22	MYSURU	66	KUSHALNAGARA-RAMNATHAPURA1	CBHALLI_66RUDRAPATNA_66ALURSIDDAPURA_66KA NGAL_66	16:22	20:59	4:37	LINE FAULT
371	25-May-22	MYSURU	66	KUSHALNAGARA-RAMNATHAPURA1	CBHALLI_66RUDRAPATNA_66ALURSIDDAPURA_66KA NGAL_66	21:03	21:20	0:16	HAND TRIPPED
372	25-May-22	MYSURU	66	KUSHALNAGARA-RAMNATHAPURA1	CBHALLI_66RUDRAPATNA_66ALURSIDDAPURA_66KA NGAL_66	21:41	21:46	0:04	LINE FAULT
373	25-May-22	MYSURU	66	KUSHALNAGARA-RAMNATHAPURA1	CBHALLI_66RUDRAPATNA_66ALURSIDDAPURA_66KA NGAL_66	21:46:00 (25/5/2022)			LINE OPEN:LINE FAULT
374	25-May-22	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66 YELANDUR_66	10:30	15:45	5:15	NFBC ISSUED
375	25-May-22	MYSURU	66	PANDAVAPURA-CHINKURALI	BANANGADI_66	13:42	18:40	4:57	NFBC ISSUED
376	25-May-22	MYSURU	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	11:20	15:46	4:25	LINE CLEAR AVAILED
377	25-May-22	MYSURU	66	TUBINKERE-NAGAMANGALA2	HARADANAHALLI(JAK)_66 SHIVALLY _66BASARALU_66KESLAGERE_66	17:38	17:44	0:05	LINE FAULT
378	25-May-22	MYSURU	220	CR NAGARA-MADHUVANAHALLI1	NO STATIONS EFFECTED	9:55	11:44	1:48	LINE CLEAR AVAILED
379	25-May-22	MYSURU	220	CR NAGARA-MADHUVANAHALLI2	NO STATIONS EFFECTED	11:50	13:18	1:28	LINE CLEAR AVAILED
380	25-May-22	MYSURU	220	GUNDLUPETE-BEGUR 1	NO STATIONS EFFECTED	16:19	17:07	0:47	LINE CLEAR AVAILED
381	25-May-22	MYSURU	220	GUNDLUPETE-BEGUR 2	NO STATIONS EFFECTED	16:20	17:08	0:48	LINE CLEAR AVAILED
382	25-May-22	MYSURU	220	HV1	MADHUVANAHALLI_220	9:45	11:06	1:21	LINE CLEAR AVAILED
383	25-May-22	MYSURU	220	HV1	TUBINAKERE_220	15:56	18:26	2:29	LINE CLEAR AVAILED
384	25-May-22	MYSURU	220	HV2	MADHUVANAHALLI_220	11:28	13:02	1:34	LINE CLEAR AVAILED
385	25-May-22	MYSURU	220	HV2	TUBINAKERE_220	10:45	15:56	5:11	LINE CLEAR AVAILED
386	25-May-22	MYSURU	220	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	13:24	15:19	1:55	LINE CLEAR AVAILED
387	25-May-22	TUMKUR	66	ANCHEPALYA 220KV- B G NAGARA_66	B G NAGARA_66,JIDDEGERE_66,THIPPUR_66,YEDIYUR_6 6	15:51	16:01	0:10	LINE FAULT
388	25-May-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, BRAHMASANDRA_66,THOVINAKERE_66,ANKASANDR A_66	23:23(25.05.2022	0:13(26.05.2022)	0:40 hrs	LINE CHARGED
389	25-May-22	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	16:50	17:05	0:15	LINE CLEAR AVAILED
390	25-May-22	TUMKUR	220	ANCHEPALYA 220KV- NEMMANGALA-1	ANCHEPALYA_220	13:43	14:04	0:21	LINE FAULT
391	25-May-22	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	12:52	13:08	0:16	LINE FAULT
392	26-May-22	BAGALKOT	110	110/11KV, HV1	BELLATTI_110	10:48	17:23	6:35	LINE CLEAR AVAILED
393	26-May-22	BAGALKOT	110	110/11KV, HV1	CHADCHAN_110	7:20 (19.05.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
394	26-May-22	BAGALKOT	110	110/11KV, HV1	NARAGUND_110	10:00	16:55	6:55	MAIN SUPPLY FAILURE
395	26-May-22	BAGALKOT	110	110/11KV, HV2	BEDI_110	22:22 (26.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
396	26-May-22	BAGALKOT	110	110/11KV, HV2	HALIYAL_110	19:00	19:09	0:09	TRANSFORMER FAULT
397	26-May-22	BAGALKOT	110	110/11KV, HV2	KONNUR_110	10:00	16:55	6:55	MAIN SUPPLY FAILURE
398	26-May-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED MUDHOL_110	17:17	18:36	1:19	HAND TRIPPED
399	26-May-22	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	12:49	12:52	0:03	TRANSFORMER FAULT
400	26-May-22	BAGALKOT	110	110/11KV,HV1	TOLAMATTI_110	17:34	18:15	0:41	LINE CLEAR AVOIDED
401	26-May-22	BAGALKOT	110	110/11KV,HV2	KANABARGI LAYOUT_110	9:20	9:40	0:20	HAND TRIPPED
402	26-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
403	26-May-22	BAGALKOT	110	110/11KV,HV3	BIJAPUR CITY_110	15:54	15:57	0:03	TRANSFORMER FAULT
404	26-May-22	BAGALKOT	110	110/11KV,HV3(HV1)	SAVALAGI_110	10:36	10:41	0:05	LINE CLEAR AVOIDED
405	26-May-22	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	13:47	13:50	0:03	TRANSFORMER FAULT
406	26-May-22	BAGALKOT	110	110/33KV, HV1	KONNUR_110	10:00	16:55	6:55	MAIN SUPPLY FAILURE
407	26-May-22	BAGALKOT	110	110/33KV, HV3	BELLATTI_110, HOLEITAGI_33, SURANAGI_33	10:48	17:23	6:35	LINE CLEAR AVOIDED
408	26-May-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
409	26-May-22	BAGALKOT	110	110/33KV,HV2(HV1)	KALA BILAGI_33,HIREPADASALAGI LIS_33,TUNGAL LIS_33 SAVALAGI_110	12:01	12:36	0:35	LINE CLEAR AVOIDED
410	26-May-22	BAGALKOT	110	AIGALI- SAVALAGI (YELLAMANAWADI)	STATION NOT AFFECTED AIGALI_110	2:15	2:20	0:05	LINE FAULT
411	26-May-22	BAGALKOT	110	AMBEWADI-NK1(HALIYAL)	AMBEWADI_220	8:54 (23.05.2022)	10:25 (26.05.2022)	73:31 hrs	LINE CHARGED
412	26-May-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
413	26-May-22	BAGALKOT	110	BAILHONGAL(MK HUBLI1)-MK HUBLI	STATION NOT AFFECTED MK HUBLI_110	10:07	11:55	1:48	HAND TRIPPED
414	26-May-22	BAGALKOT	110	BELLATTI- AB SOLAR	BELLATTI_110	13:51	17:28	3:37	LINE CLEAR AVOIDED
415	26-May-22	BAGALKOT	110	BELLATTI- ENERCON2	STATION NOT AFFECTED BELLATTI_110	10:02	18:37	8:35	LINE CLEAR AVOIDED
416	26-May-22	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	12:07	12:10	0:03	LINE FAULT
417	26-May-22	BAGALKOT	110	GHATAPRABHA-P G HUNSHAYL	STATION NOT AFFECTED PG HUNSHYAL_110	12:54	14:38	1:44	LOAD CHANGE OVER
418	26-May-22	BAGALKOT	110	HALIYAL- KAWALWADA	HALIYAL_110	10:24	10:40	0:16	HAND TRIPPED
419	26-May-22	BAGALKOT	110	HUBLI- KALGHATAGI	HUBLI_220	15:04	17:03	1:59	LINE CLEAR AVOIDED
420	26-May-22	BAGALKOT	110	KADANKOPPA-KAVALWADA	KADANKOPPA_110	10:18	10:29	0:11	HAND TRIPPED
421	26-May-22	BAGALKOT	110	KONNUR-KERUR	KERUR_110	1:58	2:07	0:09	HAND TRIPPED
422	26-May-22	BAGALKOT	110	KUD DHARWAD(NARENDRA)-TADASINAKOPPA	STATION NOT AFFECTED TADASINAKOAPP_110	11:28	15:55	4:27	LOAD CHANGE OVER
423	26-May-22	BAGALKOT	110	LAKMESWAR-BELLATTI	BELLATTI_110	13:53	17:23	3:30	HAND TRIPPED
424	26-May-22	BAGALKOT	110	MKH UBLI2-MK HUBLI	STATION NOT AFFECTED MK HUBLI_110	13:15	16:15	3:00	LINE CLEAR AVOIDED
425	26-May-22	BAGALKOT	110	MUGALKHOD- ITANAL1	STATION NOT AFFECTED ITANAL_110	6:25	12:35	6:10	LINE FAULT
426	26-May-22	BAGALKOT	110	NARAGUND-BPCL	STATION NOT AFFECTED NARAGUND_110	10:00	17:08	7:08	LINE CLEAR AVOIDED
427	26-May-22	BAGALKOT	110	NARAGUND-BPCL	STATION NOT AFFECTED NARAGUND_110	17:08	17:23	0:15	LINE FAULT
428	26-May-22	BAGALKOT	110	NARENDRA220- TADASINAKOPPA	NARENDRA_220	11:28	15:54	4:26	LINE CLEAR AVOIDED
429	26-May-22	BAGALKOT	110	NAVALAGUND-KONNUR	STATION NOT AFFECTED NAVALGUND_110	10:03	16:54	6:51	HAND TRIPPED
430	26-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVOIDED
431	26-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
432	26-May-22	BAGALKOT	110	TODALBAGI-JAMAKHANDI SUGAR	TODALBAGI_110	2:29	2:31	0:02	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
433	26-May-22	BAGALKOT	110	TODALBAGI-MAMADAPUR	TODALBAGI_110	2:29	2:36	0:07	LINE FAULT
434	26-May-22	BAGALKOT	110	YELLAMANAVADI-SAVALAGI	SAVALAGI_110	2:23	2:25	0:02	LINE FAULT
435	26-May-22	BAGALKOT	220	110/11KV, HV1	VAJRAMATTI_220	12:10	12:15	0:05	TRANSFORMER FAULT
436	26-May-22	BAGALKOT	220	110/11KV, HV1	VAJRAMATTI_220	15:10	15:15	0:05	TRANSFORMER FAULT
437	26-May-22	BAGALKOT	220	110/11KV, HV1	VAJRAMATTI_220	22:00	22:20	0:20	TRANSFORMER FAULT
438	26-May-22	BAGALKOT	220	220/110KV, HV1	GHATAPRABHA_220	12:20	13:10	0:50	TRANSFORMER FAULT
439	26-May-22	BAGALKOT	220	220/110KV, HV2	GHATAPRABHA_220	08:02	17:12	9:10	LINE CLEAR AVAILED
440	26-May-22	BAGALKOT	220	220/110KV,HV1,LV1	CHIKKODI_220	15:16	16:05	0:49	LINE CLEAR AVAILED
441	26-May-22	BAGALKOT	220	220/110KV,HV1,LV1	CHIKKODI_220	16:08	17:02	0:54	LINE CLEAR AVAILED
442	26-May-22	BAGALKOT	220	220/110KV,HV1,LV1	MK HUBLI_220	07:10	11:03	3:53	LINE CLEAR AVAILED
443	26-May-22	BAGALKOT	220	220/110KV,HV2,LV2	MK HUBLI_220	11:08	14:38	3:30	LINE CLEAR AVAILED
444	26-May-22	BAGALKOT	220	AMBEWADI-PONDA-2	STATION NOT AFFECTED AMBEWADI_220	13:11	18:16	5:05	LINE FAULT
445	26-May-22	BAGALKOT	220	BAGEWADI-BIJAPUR1	STATION NOT AFFECTED BAGEWADI_220	17:54 (19.05.2022)			LINE OPEN:LINE CLEAR AVAILED
446	26-May-22	BAGALKOT	220	BAGEWADI-BIJAPUR2	STATION NOT AFFECTED BAGEWADI_220	17:54 (19.05.2022)			LINE OPEN:LINE CLEAR AVAILED
447	26-May-22	BAGALKOT	220	BELGAUM- KANABARGI2	STATION NOT AFFECTED BELGAUM_220	19:20	20:04	0:44	HAND TRIPPED
448	26-May-22	BAGALKOT	220	BELGAUM- NARENDRA1	STATION NOT AFFECTED BELGAUM_220	9:01 (14.05.2022)	20:03 (26.05.2022)	299:02 hrs	LINE CHARGED
449	26-May-22	BAGALKOT	220	BIDNAL- NAGJHARI	STATION NOT AFFECTED BIDNAL_220	10:16	11:35	1:19	LOAD CHANGE OVER
450	26-May-22	BAGALKOT	220	NARENDRA- BELGAUM1	STATION NOT AFFECTED NARENDRA_220	9:01 (14.05.2022)	20:03 (26.05.2022)	299:02 hrs	LINE CHARGED
451	26-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
452	26-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
453	26-May-22	BENGALURU	66	BYDRAHALLI - KODIGEHALLI	KODIGEHALLI	10:48	11:40	0:52	LINE FAULT
454	26-May-22	BENGALURU	66	BYDRAHALLI - SRS PEENYA 220	BYDRAHALLI, KODIGEHALLI, SRIGANDA KAVALU	19:19	20:10	0:51	MAIN SUPPLY FAILURE
455	26-May-22	BENGALURU	66	BYDRAHALLI - SRS PEENYA 220	BYDRAHALLI, SRIGANDA KAVALU	10:48	11:10	0:22	MAIN SUPPLY FAILURE
456	26-May-22	BENGALURU	66	HBR LAYOUT 66 - KONDASPURA	KONDASPURA	22:37(25-5-2022)	11:52(26-5-2022)	13:14 hrs	LINE CHARGED
457	26-May-22	BENGALURU	66	HOSKOTE 220 - BIAL BEGUR	NO STATION AFFECTED	14:45	15:41	0:55	LINE FAULT
458	26-May-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	BELL CERAMICS (EHT), KONDASPURA	8:30	11:25	2:54	LINE CLEAR AVAILED
459	26-May-22	BENGALURU	66	HV1	CHINTAMANI 66	13:20	14:36	1:15	TRANSFORMER FAULT
460	26-May-22	BENGALURU	66	HV1	DEVANAHALLI	13:30	13:42	0:12	TRANSFORMER FAULT
461	26-May-22	BENGALURU	66	HV1	DODDAKARI	7:12	8:00	0:47	LINE CLEAR AVAILED
462	26-May-22	BENGALURU	66	HV1	HUKUNDA	3:08	3:14	0:06	TRANSFORMER FAULT
463	26-May-22	BENGALURU	66	HV1	HUKUNDA	3:16	3:20	0:04	TRANSFORMER FAULT
464	26-May-22	BENGALURU	66	HV1	MELUR	22:45	22:55	0:09	TRANSFORMER FAULT
465	26-May-22	BENGALURU	66	HV1	YELAHANKA 220	11:25	11:27	0:02	LINE CLEAR AVAILED
466	26-May-22	BENGALURU	66	HV2	NANDAGUDI	11:22	11:35	0:13	LINE CLEAR AVAILED
467	26-May-22	BENGALURU	66	HV2	PILLAGUMPA	15:02	15:12	0:10	TRANSFORMER FAULT
468	26-May-22	BENGALURU	66	HV2	YELAHANKA 220	13:21	13:23	0:02	LINE CLEAR AVAILED
469	26-May-22	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	15:08	18:47	3:39	LINE FAULT
470	26-May-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	15:08	15:40	0:31	MAIN SUPPLY FAILURE
471	26-May-22	BENGALURU	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	15:30	18:39	3:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
472	26-May-22	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDI, LAKKUR	15:30	15:59	0:28	MAIN SUPPLY FAILURE
473	26-May-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	15:08	15:33	0:24	MAIN SUPPLY FAILURE
474	26-May-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	15:08	15:36	0:27	MAIN SUPPLY FAILURE
475	26-May-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	15:08	15:30	0:21	MAIN SUPPLY FAILURE
476	26-May-22	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, SRIGANDA KAVALU	10:48	11:10	0:22	LINE FAULT
477	26-May-22	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, SRIGANDA KAVALU	19:19	20:03	0:44	LINE CLEAR AVAILED
478	26-May-22	BENGALURU	66	SRS PEENYA 220 - DG1	NO STATION AFFECTED	19:15	21:52	2:37	LINE FAULT
479	26-May-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	17:30	18:19	0:49	LINE CLEAR AVAILED
480	26-May-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML	17:30	18:19	0:49	LINE CLEAR AVAILED
481	26-May-22	BENGALURU	66	YELAHANKA 220 - LINE1	NO STATION AFFECTED	10:20	13:37	3:17	LINE CLEAR AVAILED
482	26-May-22	BENGALURU	66	YELAHANKA 220 - LINE2	NO STATION AFFECTED	10:20	13:37	3:17	LINE CLEAR AVAILED
483	26-May-22	BENGALURU	220	HV1	MALUR 220	15:30	15:56	0:25	TRANSFORMER FAULT
484	26-May-22	BENGALURU	220	HV2	MALUR 220	15:08	15:28	0:19	TRANSFORMER FAULT
485	26-May-22	BENGALURU	220	LV1	MALUR 220	15:30	15:58	0:27	TRANSFORMER FAULT
486	26-May-22	BENGALURU	220	LV2	MALUR 220	15:08	15:29	0:20	TRANSFORMER FAULT
487	26-May-22	GULBARGA	66	BADELADUKU-KUDLIGI	KUDLIGI_66,HANSI_66	14:40	16:55	2:15	LINE CLEAR AVAILED
488	26-May-22	GULBARGA	66	HV3	TELAGI_66	11:05	11:20	0:15	LINE CLEAR AVAILED
489	26-May-22	GULBARGA	110	AURAD-DONGARGAON	DONGARGAON_110	17:15	17:20	0:05	LINE FAULT
490	26-May-22	GULBARGA	110	HALBARGA-HALLIKHED	HALLIKHED_110	18:18	19:30	1:12	LINE FAULT
491	26-May-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_110,DIGGI_110	5:22	5:32	0:10	LINE FAULT
492	26-May-22	GULBARGA	110	HV1	HALKUNDI_110	7:39	10:20	2:41	TRANSFORMER FAULT
493	26-May-22	GULBARGA	110	HV1	MATAMARI_110	17:45	17:50	0:05	TRANSFORMER FAULT
494	26-May-22	GULBARGA	110	HV2	CHIDRI_110	14:40	14:50	0:10	TRANSFORMER FAULT
495	26-May-22	GULBARGA	110	HV2	CHOWDAPUR_110	14:08	14:11	0:03	TRANSFORMER FAULT
496	26-May-22	GULBARGA	110	HV3	SHAHAPUR_110	12:50	13:05	0:15	TRANSFORMER FAULT
497	26-May-22	GULBARGA	110	HV3	SHAHAPUR_110	15:40	16:55	1:15	LINE CLEAR AVAILED
498	26-May-22	GULBARGA	110	HV3	SHAHAPUR_110	17:10	17:25	0:15	TRANSFORMER FAULT
499	26-May-22	GULBARGA	110	SEDAM-CLEAN_MAX_IPP	SEDAM_220	19:56 (26.05.2022)			LINE OPEN:LINE CLEAR AVAILED
500	26-May-22	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	5:50	6:10	0:20	LINE FAULT
501	26-May-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	22:25	22:30	0:05	LINE FAULT
502	26-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SAANNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
503	26-May-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	3:05	3:15	0:10	LINE FAULT
504	26-May-22	GULBARGA	220	ALIPUR-RAGALPADU	RAGALPADU_220	2:35(17.05.2022)			LINE OPEN:LINE CLEAR AVAILED
505	26-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
506	26-May-22	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	10:30	16:34	6:04	LINE CLEAR AVAILED
507	26-May-22	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	01:55(17.05.2022)			LINE OPEN:LINE CLEAR AVAILED
508	26-May-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN:LINE FAULT
509	26-May-22	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	10:30	15:51	5:21	LINE CLEAR AVAILED
510	26-May-22	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	10:30	15:51	5:21	LINE CLEAR AVAILED
511	26-May-22	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	10:30	16:08	5:38	LINE CLEAR AVAILED
512	26-May-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:30	15:56	5:26	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
513	26-May-22	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	10:30	15:56	5:26	LINE CLEAR AVAILED
514	26-May-22	HASSAN	66	CRPATNA-CRPTNA1	CHANNARAYAPATNA_220	10:40	15:48	5:08	LINE CLEAR AVAILED
515	26-May-22	HASSAN	66	CRPATNA-CRPTNA2	CHANNARAYAPATNA_220	10:40	15:48	5:08	LINE CLEAR AVAILED
516	26-May-22	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	18:49	19:10	0:21	LINE FAULT
517	26-May-22	HASSAN	66	HNPR2-HNPR1	HNPURA_220	2:32	2:38	0:06	LINE FAULT
518	26-May-22	HASSAN	66	HV1	ATTICHODANAHALLY_66	10:30	16:00	5:30	MAIN SUPPLY FAILURE
519	26-May-22	HASSAN	66	HV1	BAGUR_66	10:30	16:05	5:35	MAIN SUPPLY FAILURE
520	26-May-22	HASSAN	66	HV1	CHANNARAYAPATNA_66	10:30	15:51	5:21	LINE CLEAR AVAILED
521	26-May-22	HASSAN	66	HV1	HALEBEEDU_66	0:30	1:00	0:30	HAND TRIPPED
522	26-May-22	HASSAN	66	HV1	KANDLI_66	12:30	14:10	1:40	LINE CLEAR AVAILED
523	26-May-22	HASSAN	66	HV2	CHANNARAYAPATNA_66	10:30	15:52	5:22	LINE CLEAR AVAILED
524	26-May-22	HASSAN	66	HV2	HALEBEEDU_66	0:34	1:05	0:31	HAND TRIPPED
525	26-May-22	HASSAN	66	HV2	HALEBEEDU_66	9:45	12:50	3:05	LINE CLEAR AVAILED
526	26-May-22	HASSAN	66	HV2	HALEBEEDU_66	16:05	16:09	0:04	HAND TRIPPED
527	26-May-22	HASSAN	66	HV2	RAMPURA_66	10:30	16:00	5:30	MAIN SUPPLY FAILURE
528	26-May-22	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	9:50	14:20	4:30	LINE CLEAR AVAILED
529	26-May-22	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	14:20	14:35	0:15	HAND TRIPPED
530	26-May-22	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	9:55	10:00	0:05	HAND TRIPPED
531	26-May-22	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	13:47	14:14	0:27	MAIN SUPPLY FAILURE
532	26-May-22	HASSAN	66	SAKALE-IPCL1	SAKALESHUPURA_66	11:50	17:09	5:19	LINE CLEAR AVAILED
533	26-May-22	HASSAN	66	SAKALE-IPCL1	SAKALESHUPURA_66	18:16	18:21	0:05	LINE CLEAR AVAILED
534	26-May-22	HASSAN	66	SAKALE-IPCL2	SAKALESHUPURA_66	11:50	17:09	5:19	LINE CLEAR AVAILED
535	26-May-22	HASSAN	66	SAKALE-KDLGRE	SIGEBAGI_66	14:00	14:10	0:10	HAND TRIPPED
536	26-May-22	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPPALU_66	18:55	19:10	0:15	LINE FAULT
537	26-May-22	HASSAN	66	UDDURKO-SUZLON2	UDDURKOPPALU_66	18:55	19:20	0:25	LINE FAULT
538	26-May-22	HASSAN	110	ANAVATI-BARNGI	ANAVATI	9:05	9:35	0:30	MAIN SUPPLY FAILURE
539	26-May-22	HASSAN	110	ANAVATI-BARNGI	ANAVATI	9:35	18:10	8:35	LOAD CHANGE OVER
540	26-May-22	HASSAN	110	BARANG-ANVATTI	BARANG	17:35	18:10	0:35	LOAD CHANGE OVER
541	26-May-22	HASSAN	110	BARANG-SHR220	BARANG	8:55	9:35	0:40	LOAD CHANGE OVER
542	26-May-22	HASSAN	110	BARANG-SHR220	BARANG	17:35	17:55	0:20	LOAD CHANGE OVER
543	26-May-22	HASSAN	110	GURUVA-SLVPWR	GURUVA	11:07	13:01	1:54	LINE CLEAR AVAILED
544	26-May-22	HASSAN	110	HV1	BARANG	17:10	17:20	0:10	LINE CLEAR AVAILED
545	26-May-22	HASSAN	110	HV1	KAVOOR	9:40(26.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
546	26-May-22	HASSAN	110	HV1	SHIKARIPURA_110	10:00	18:25	8:25	LINE CLEAR AVAILED
547	26-May-22	HASSAN	110	HV2	BARANG	11:35	17:05	5:30	LINE CLEAR AVAILED
548	26-May-22	HASSAN	110	HV2	GURUVA	10:12	13:48	3:36	LINE CLEAR AVAILED
549	26-May-22	HASSAN	110	HV2	PUTUR_110	0:00	0:16	0:16	TRANSFORMER FAULT
550	26-May-22	HASSAN	110	HV2	SHIKARIPURA_110	15:25	18:25	3:00	LINE CLEAR AVAILED
551	26-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
552	26-May-22	HASSAN	110	JOG110-LPH	JOG110	11:00	12:55	1:55	LINE CLEAR AVAILED
553	26-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
554	26-May-22	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:16	11:15	0:59	LINE CLEAR AVAILED
555	26-May-22	HASSAN	110	LLPH-ST4	gen_lph	11:02	12:55	1:53	LINE CLEAR AVAILED
556	26-May-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
557	26-May-22	HASSAN	110	MSEZ-GSS31	MSEZ_220	9:06	12:59	3:53	NFBC ISSUED
558	26-May-22	HASSAN	110	MSEZ-GSS32	MSEZ_220	13:09	17:48	4:39	NFBC ISSUED
559	26-May-22	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	11:52	12:23	0:31	LINE CLEAR AVAILED
560	26-May-22	HASSAN	110	SAGAR-LST4	SAGAR_110	11:02	12:50	1:48	LINE CLEAR AVAILED
561	26-May-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	8:55	17:57	9:02	LINE CLEAR AVAILED
562	26-May-22	HASSAN	220	ARSK2-SHMG	ARSK2	9:46	11:26	1:40	LINE FAULT
563	26-May-22	HASSAN	220	GOPALA-HNPUR21	GOPALAP	10:15	12:40	2:25	LINE CLEAR AVAILED
564	26-May-22	HASSAN	220	GOPALA-HNPUR22	GOPALAP	12:45	14:20	1:35	LINE CLEAR AVAILED
565	26-May-22	HASSAN	220	HNPR2-GPLPR1	HNPR2	10:15	12:40	2:25	LINE CLEAR AVAILED
566	26-May-22	HASSAN	220	HNPR2-GPLPR2	HNPR2	12:45	14:20	1:35	LINE CLEAR AVAILED
567	26-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
568	26-May-22	HASSAN	220	KAVOOR-KEMR1	KAVOOR	11:50	12:20	0:30	HAND TRIPPED
569	26-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
570	26-May-22	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
571	26-May-22	MYSURU	66	HANNUR-AJIIPURA	COWDALLI_66MARTAHALLI_66RAMAPURA_MYS_66 AJIIPURA_66BANDALLI_66	8:31	17:57	9:26	LINE CLEAR AVAILED
572	26-May-22	MYSURU	66	HANNUR-KOTHANUR	NO STATIONS EFFECTED	13:45	16:40	2:55	LINE CLEAR AVAILED
573	26-May-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
574	26-May-22	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	12:03:00 (14.5.2022)			LINE OPEN:LINE FAULT
575	26-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
576	26-May-22	MYSURU	66	HOOTAGALLI-KAGGERE HAMPAPURA	KAGGEREHAMPAPURA_66	10:27	11:35	1:08	LINE CLEAR AVAILED
577	26-May-22	MYSURU	66	HV1	BANNIMANTAP_66	12:51	13:38	0:47	HAND TRIPPED
578	26-May-22	MYSURU	66	HV1	DATTAGALLY_66	8:51	16:49	7:57	TRANSFORMER FAULT
579	26-May-22	MYSURU	66	HV1	KIKKERI_66	12:53	17:42	4:49	LINE CLEAR AVAILED
580	26-May-22	MYSURU	66	HV1	RKNAGARA_66	12:51	13:37	0:45	LINE CLEAR AVAILED
581	26-May-22	MYSURU	66	HV2	BANNIMANTAP_66	12:51	13:38	0:47	HAND TRIPPED
582	26-May-22	MYSURU	66	HV2	HULLAHALLI_66	12:06	12:29	0:23	LINE CLEAR AVAILED
583	26-May-22	MYSURU	66	HV2	KIKKERI_66	15:10	17:35	2:25	LINE CLEAR AVAILED
584	26-May-22	MYSURU	66	HV3	KIKKERI_66	10:03	17:43	7:39	LINE CLEAR AVAILED
585	26-May-22	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57:05 (4/5/2022)			LINE OPEN:LINE CLEAR AVAILED
586	26-May-22	MYSURU	66	KK HALLI -MANDYA	KADKOTHANAHALLI_66	10:05	17:05	7:00	LINE CLEAR AVAILED
587	26-May-22	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	G MALLIGERE_66JAKKANAHALLY_66MADESWARAPUR A_66	15:31	15:39	0:07	LINE FAULT
588	26-May-22	MYSURU	66	KUSHALNAGARA-RAMANTHAPURA1	CBHALLI_66RUDRAPATNA_66ALURSIDDAPURA_66KA NGAL_66	6:33	6:49	0:15	HAND TRIPPED
589	26-May-22	MYSURU	66	KUSHALNAGARA-RAMANTHAPURA1	CBHALLI_66RUDRAPATNA_66ALURSIDDAPURA_66KA NGAL_66	9:04	11:40	2:35	LINE CLEAR AVAILED
590	26-May-22	MYSURU	66	KUSHALNAGARA-RAMNATHAPURA1	CBHALLI_66RUDRAPATNA_66ALURSIDDAPURA_66KA NGAL_66	21:46:00 (25/5/2022)	6:03:00 (26/5/2022)	8:17 hrs	LINE CHARGED
591	26-May-22	MYSURU	66	MADHUVANAHALLI-HANNUR1	HANNUR_66	14:51	16:34	1:42	NFBC ISSUED
592	26-May-22	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	14:51	16:34	1:42	NFBC ISSUED
593	26-May-22	MYSURU	66	MANDYA-CHIKKAMANDYA	CHIKKAMANDYA_66	10:12	14:11	3:58	LINE CLEAR AVAILED
594	26-May-22	MYSURU	66	TUBINKERE-MANDYA 2	NO STATIONS EFFECTED	16:05	16:40	0:35	HAND TRIPPED
595	26-May-22	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:45	17:20	1:35	HAND TRIPPED
596	26-May-22	MYSURU	66	VIJAYANAGARA-BANNIMANTAP	NO STATIONS EFFECTED	13:27	19:55	6:28	NFBC ISSUED
597	26-May-22	MYSURU	220	CR NAGARA-BEGUR 1	NO STATIONS EFFECTED	11:26	12:57	1:31	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
598	26-May-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66,SOKKE_66	0:56	1:08	0:12	LINE FAULT
599	26-May-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66,SOKKE_66	2:25	2:48	0:23	LINE FAULT
600	26-May-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66,SOKKE_66	4:15	5:18	1:03	LINE FAULT
601	26-May-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66,SOKKE_66	16:17	16:27	0:10	LINE FAULT
602	26-May-22	TUMKUR	66	TR-1	PAVAGADA_220	5:10	5:15	0:05	TRANSFORMER FAULT
603	26-May-22	TUMKUR	66	TR-1	PAVAGADA_220	10:35	10:40	0:05	TRANSFORMER FAULT
604	26-May-22	TUMKUR	66	TR-1	PAVAGADA_220	12:50	12:55	0:05	TRANSFORMER FAULT
605	26-May-22	TUMKUR	110	BANDIHALLI 110- KB CROSS	BANDIHALLI_110	12:00	12:35	0:35	MAIN SUPPLY FAILURE
606	26-May-22	TUMKUR	110	BANDIHALLI 110- KB CROSS	BANDIHALLI_110	12:00	12:35	0:35	MAIN SUPPLY FAILURE
607	26-May-22	TUMKUR	110	BANDIHALLI- TIPTUR	TIPTUR_110,HALKURKE_110,HUNSEGHATTA_110,KE REKODI_110	12:00	12:35	0:35	MAIN SUPPLY FAILURE
608	26-May-22	TUMKUR	110	BANDIHALLI- TIPTUR	TIPTUR_110,HALKURKE_110,HUNSEGHATTA_110,KE REKODI_110	12:00	12:35	0:35	MAIN SUPPLY FAILURE
609	26-May-22	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110	11:58	12:27	0:29	MAIN SUPPLY FAILURE
610	26-May-22	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110,TIMMANAHALLI_110,HANDANKERE_110,HULIYAR_110,SHETYKERE_110,KATRIKEHAL_110	11:58	12:27	0:29	MAIN SUPPLY FAILURE
611	26-May-22	TUMKUR	110	HULIYAR110-C N HALLI	HULIYAR_110	12:00	12:35	0:35	MAIN SUPPLY FAILURE
612	26-May-22	TUMKUR	110	KB CROSS 220KV- BANDIHALLI(TIPTUR110)	TIPTUR_110,KARADI_66,BANDIHALLI_110,HUNSEGHATTA_110	11:59	12:27	0:28	MAIN SUPPLY FAILURE
613	26-May-22	TUMKUR	110	KB CROSS 220KV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110,SHETYKERE_110,TIMMANAHALLI_110,HANDANKERE_110,HULIYAR_110	11:59	12:27	0:28	MAIN SUPPLY FAILURE
614	26-May-22	TUMKUR	110	KB CROSS 220KV-TURUVEKERE110	TURUVEKERE_110,TANDAGA_110,NONAVINAKERE_110,GUNGURMALE_110	11:59	12:27	0:28	MAIN SUPPLY FAILURE
615	26-May-22	TUMKUR	110	TR-1	BANDIHALLI_110	12:00	12:35	0:35	MAIN SUPPLY FAILURE
616	26-May-22	TUMKUR	110	TR-1	BANDIHALLI_110	12:00	12:35	0:35	MAIN SUPPLY FAILURE
617	26-May-22	TUMKUR	110	TR-1	HULIYAR_110	12:00	12:35	0:35	MAIN SUPPLY FAILURE
618	26-May-22	TUMKUR	110	TR-1	HUNSEGHATTA_110	12:00	12:35	0:35	MAIN SUPPLY FAILURE
619	26-May-22	TUMKUR	110	TR-2	BANDIHALLI_110	12:00	12:35	0:35	MAIN SUPPLY FAILURE
620	26-May-22	TUMKUR	110	TR-2	BANDIHALLI_110	12:00	12:35	0:35	MAIN SUPPLY FAILURE
621	26-May-22	TUMKUR	110	TR-2	HULIYAR_110	12:00	12:35	0:35	MAIN SUPPLY FAILURE
622	26-May-22	TUMKUR	110	TR-2	HUNSEGHATTA_110	12:00	12:35	0:35	MAIN SUPPLY FAILURE
623	26-May-22	TUMKUR	110	TR-2	KBCROSS_220	11:59	12:27	0:28	MAIN SUPPLY FAILURE
624	26-May-22	TUMKUR	110	TR-3	HULIYAR_110	12:00	12:35	0:35	MAIN SUPPLY FAILURE
625	26-May-22	TUMKUR	220	KB CROSS 220KV- SHIMOGA	KBCROSS_220	11:59	12:27	0:28	LINE FAULT
626	26-May-22	TUMKUR	220	TR-1	KBCROSS_220	09:57(26.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1	27-May-22	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	11:08	12:35	1:27	LINE CLEAR AVAILED
2	27-May-22	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	11:08	12:36	1:28	LINE CLEAR AVAILED
3	27-May-22	BAGALKOT	110	110/11KV, HV1	BHOI_110	12:05	12:20	0:15	LINE CLEAR AVAILED
4	27-May-22	BAGALKOT	110	110/11KV, HV1	CHADCHAN_110	7:20 (19.05.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
5	27-May-22	BAGALKOT	110	110/11KV, HV1	HALIYAL_110	10:00	10:25	0:25	LINE CLEAR AVAILED
6	27-May-22	BAGALKOT	110	110/11KV, HV1	RANEENNUR_220	11:43	11:46	0:03	TRANSFORMER FAULT
7	27-May-22	BAGALKOT	110	110/11KV, HV2	ALBAL_110	8:45	19:56	11:11	LINE CLEAR AVAILED
8	27-May-22	BAGALKOT	110	110/11KV, HV2	MUDHOL_110	08:30	09:38	1:08	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
9	27-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED BEDI_110	22:22 (26.05.2022)	10:10 (27.05.2022)	11:48 hrs	TRANSFORMER CHARGED
10	27-May-22	BAGALKOT	110	110/11KV, HV3	STATIO NOT AFFECTED BIJAPUR CITY_110	13:29	13:38	0:09	TRANSFORMER FAULT
11	27-May-22	BAGALKOT	110	110/11KV,HV1	PH COMPOUND_110	21:47	23:16	1:29	TRANSFORMER FAULT
12	27-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
13	27-May-22	BAGALKOT	110	110/33K, HV2	HALIYAL_110	10:00	10:45	0:45	LINE CLEAR AVOIDED
14	27-May-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
15	27-May-22	BAGALKOT	110	ALBAL-YELLAMMANAWADI	ALBAL_110	8:45	19:56	11:11	LINE CLEAR AVOIDED
16	27-May-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
17	27-May-22	BAGALKOT	110	ATHANI220-TODALBAGI	TODALBAGI_110	03:05	03:10	0:05	MAIN SUPPLY FAILURE
18	27-May-22	BAGALKOT	110	HAVERI220- TILUVALLI	HAVERI_220	06:34	06:48	0:14	LINE FAULT
19	27-May-22	BAGALKOT	110	HUKKERI-HATTARGI	STATION NOT AFFECTED HUKKERI_110	10:50 (25.05.2022)	18:46 (27.05.2022)	55:56 hrs	LINE CLEAR AVOIDED
20	27-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVOIDED
21	27-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
22	27-May-22	BAGALKOT	110	SIRSI220- SIRSI2	SIRSI_220	12:15	14:07	1:52	NFBC ISSUED
23	27-May-22	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	12:14	14:10	1:56	LINE CLEAR AVOIDED
24	27-May-22	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	23:28 (27.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
25	27-May-22	BAGALKOT	110	TODALBAGI-JAMAKHANDI SUGARS	TODALBAGI_110, JKD SUGARS_IPP	3:15	3:20	0:05	LINE FAULT
26	27-May-22	BAGALKOT	110	YLWD-F2 Cbreaker(SAVALAGI)	STATION NOT AFFECTED YELLAMANAWADI_110	3:03	3:11	0:08	LINE FAULT
27	27-May-22	BAGALKOT	110	YLWD-F3 Cbreaker(ALBAL)	STATION NOT AFFECTED YELLAMANAWADI_110	8:40	19:49	11:09	NFBC ISSUED
28	27-May-22	BAGALKOT	220	220/110KV, HV3	CHIKKODI_220	10:54	12:50	1:56	LINE CLEAR AVOIDED
29	27-May-22	BAGALKOT	220	AMBEWADI- PONDA2	AMBEWADI_220	13:12	17:18	4:06	LINE FAULT
30	27-May-22	BAGALKOT	220	BAGEWADI-BIJAPUR1	STATION NOT AFFECTED BAGEWADI_220	17:54 (19.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
31	27-May-22	BAGALKOT	220	BAGEWADI-BIJAPUR2	STATION NOT AFFECTED BAGEWADI_220	17:54 (19.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
32	27-May-22	BAGALKOT	220	BIDNAL-TADAS-2	TADAS_220 STATIO NOT AFFECTED BIDNAL_220	10:51	14:32	3:41	LINE CLEAR AVOIDED
33	27-May-22	BAGALKOT	220	CHIKKODI-KOLAHAPUR2(MUDASHINGI)	STATIO NOT AFFECTED CHIKKODI_220	12:06	12:49	0:43	LINE CLEAR AVOIDED
34	27-May-22	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	12:26	15:56	3:30	LINE CLEAR AVOIDED
35	27-May-22	BAGALKOT	220	KARWAR-KADRA-1	KARWAR_220	9:12	11:12	2:00	LINE CLEAR AVOIDED
36	27-May-22	BAGALKOT	220	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	22:21 (27.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
37	27-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
38	27-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
39	27-May-22	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	20:05	20:20	0:15	LOAD CHANGE OVER
40	27-May-22	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	20:10	20:30	0:20	LINE FAULT
41	27-May-22	BENGALURU	66	GANIJUGUNTE - DIBBURAHALLI	DIBBURAHALLI	8:01	8:12	0:10	LINE FAULT
42	27-May-22	BENGALURU	66	HEBBALA 220 - C STATION 1 & 2	C STATION	16:27	16:48	0:21	LINE FAULT
43	27-May-22	BENGALURU	66	HV1	CHINTAMANI 66	16:14	17:02	0:48	LINE CLEAR AVOIDED
44	27-May-22	BENGALURU	66	HV1	KEMBODI	9:54	10:40	0:45	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
45	27-May-22	BENGALURU	66	HV1	MANCHENAHALLI	13:30	14:00	0:30	LINE CLEAR AVAILED
46	27-May-22	BENGALURU	66	HV1	MANCHENAHALLI	14:40	15:30	0:50	LINE CLEAR AVAILED
47	27-May-22	BENGALURU	66	HV1	MEI LAYOUT	11:17	11:18	0:01	LINE CLEAR AVAILED
48	27-May-22	BENGALURU	66	HV1	MEI LAYOUT	16:12	16:14	0:02	LOAD CHANGE OVER
49	27-May-22	BENGALURU	66	HV1	MELUR	15:18	17:10	1:52	TRANSFORMER FAULT
50	27-May-22	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	1:29	1:40	0:11	TRANSFORMER FAULT
51	27-May-22	BENGALURU	66	HV2	CB PURA URBAN	22:23	22:27	0:03	TRANSFORMER FAULT
52	27-May-22	BENGALURU	66	HV2	CB PURA URBAN	14:16	14:20	0:03	LINE CLEAR AVAILED
53	27-May-22	BENGALURU	66	HV2	DODDABELAVANGALA	8:12	8:18	0:05	TRANSFORMER FAULT
54	27-May-22	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA CIRCLE	17:11	17:32	0:20	LINE CLEAR AVAILED
55	27-May-22	BENGALURU	66	NELAMANGALA 66 - DABUSPETE 220	NELAMANGALA 66	18:31	18:43	0:12	LINE FAULT
56	27-May-22	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	10:15	10:22	0:07	MAIN SUPPLY FAILURE
57	27-May-22	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	13:38	13:44	0:06	MAIN SUPPLY FAILURE
58	27-May-22	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	10:05	10:08	0:03	LOAD CHANGE OVER
59	27-May-22	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	14:12	14:15	0:03	LOAD CHANGE OVER
60	27-May-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	10:19	10:24	0:05	LOAD CHANGE OVER
61	27-May-22	GULBARGA	66	BADELADUKU-CHORNOOR	CHORNOOR_66	1:00	1:15	0:15	LINE FAULT
62	27-May-22	GULBARGA	66	HV1	PUNABGHATA_66	13:45	14:10	0:25	LINE CLEAR AVAILED
63	27-May-22	GULBARGA	66	HV2	TAMBRAHALLI_66	21:00	21:05	0:05	TRANSFORMER FAULT
64	27-May-22	GULBARGA	110	DUBALGUNDI-HUMNABAD	DUBALGUNDI_110	7:00	12:10	5:10	LINE CLEAR AVAILED
65	27-May-22	GULBARGA	110	HALBARGA-HALLIKHED	HALLIKHED_110	6:45	10:05	3:20	LINE CLEAR AVAILED
66	27-May-22	GULBARGA	110	HALBARGA-HUMNABAD	HUMNABAD_110	7:52	12:22	4:30	NFBC ISSUED
67	27-May-22	GULBARGA	110	HV1	NIRNA_110	11:08	11:14	0:06	TRANSFORMER FAULT
68	27-May-22	GULBARGA	110	HV2	CHITGUPPA_110	9:35	9:40	0:05	TRANSFORMER FAULT
69	27-May-22	GULBARGA	110	HV2	CHITGUPPA_110	6:40	11:45	5:05	LINE CLEAR AVAILED
70	27-May-22	GULBARGA	110	HV2	KUSTAGI_220	9:45	9:50	15:14	TRANSFORMER FAULT
71	27-May-22	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONNAGAR_110,HANUM ANAL_110	4:13	4:33	0:20	LINE FAULT
72	27-May-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	2:42	2:52	0:10	LINE FAULT
73	27-May-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	21:14	21:19	0:05	LINE FAULT
74	27-May-22	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110,SASTHAPUR_110,WARDHA SOLAR_110	6:30	12:22	5:52	LINE CLEAR AVAILED
75	27-May-22	GULBARGA	110	SEDAM-CLEAN MAX_IPP	SEDAM_220	19:56 (26.05.2022)	3:02 (27.05.2022)	7:06 HRS	LINE CHARGED
76	27-May-22	GULBARGA	110	SEDAM-VASAVADATTA CEMENT	SEDAM_220	18:40 (27.05.2022)			LINE OPEN:LINE CLEAR AVAILED
77	27-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SA NNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
78	27-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SA NNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
79	27-May-22	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	11:15	18:10	6:55	LINE CLEAR AVAILED
80	27-May-22	GULBARGA	220	ALIPUR-RAGALPADU	RAGALPADU_220	2:35(17.05.2022)			LINE OPEN:LINE CLEAR AVAILED
81	27-May-22	GULBARGA	220	HV1 & LV1	HUMNABAD_220	7:02	11:46	4:44	LINE CLEAR AVAILED
82	27-May-22	GULBARGA	220	HV1&HV2	MALLAT_220	11:35	12:00	0:25	TRANSFORMER FAULT
83	27-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
84	27-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
85	27-May-22	GULBARGA	220	HV2	SEDAM_220	15:14	13:20	15:14	LINE CLEAR AVAILED
86	27-May-22	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	01:55(17.05.2022)			LINE OPEN:LINE CLEAR AVAILED
87	27-May-22	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	11:23(27.05.22)			LINE OPEN:LINE CLEAR AVAILED
88	27-May-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN:LINE FAULT
89	27-May-22	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	9:55	11:05	1:10	NFBC ISSUED
90	27-May-22	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	9:55	11:05	1:10	NFBC ISSUED
91	27-May-22	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	9:55	11:15	1:20	LINE CLEAR AVAILED
92	27-May-22	HASSAN	66	HV1	DODDAKADANUR_66	9:55	11:05	1:10	NFBC ISSUED
93	27-May-22	HASSAN	66	HV1 CB	NAGARTHI_110	8:20	11:15	2:55	LINE CLEAR AVAILED
94	27-May-22	HASSAN	66	HV2	SINGAPURA_66	10:38	12:25	1:47	LINE CLEAR AVAILED
95	27-May-22	HASSAN	66	MRSSTM-DVG2	MRSMG_220	4:26	4:35	0:09	LINE FAULT
96	27-May-22	HASSAN	66	NGRTHI-L1 CB	NAGARTHI_110	8:20	11:15	2:55	LINE CLEAR AVAILED
97	27-May-22	HASSAN	66	NGRTHI-L2 CB	NAGARTHI_110	6:27	6:50	0:23	LINE FAULT
98	27-May-22	HASSAN	66	NGRTHI-L2 CB	NAGARTHI_110	10:10	11:15	1:05	LINE CLEAR AVAILED
99	27-May-22	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	12:09	16:00	3:51	LINE CLEAR AVAILED
100	27-May-22	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	12:09	16:00	3:51	LINE CLEAR AVAILED
101	27-May-22	HASSAN	110	ANANDA-LPH(LST-4)	ANANDPURA_110	10:20	17:20	7:00	LINE CLEAR AVAILED
102	27-May-22	HASSAN	110	ANANDA-SHIMOGA	ANANDPURA_110	10:45	17:21	6:36	LINE CLEAR AVAILED
103	27-May-22	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	10:40	11:15	0:35	LINE CLEAR AVAILED
104	27-May-22	HASSAN	110	HV1	BARANGI_110	18:20	18:32	0:12	HAND TRIPPED
105	27-May-22	HASSAN	110	HV1	BARANGI_110	20:40	20:44	0:04	HAND TRIPPED
106	27-May-22	HASSAN	110	HV1	KADUR_220	10:24	12:24	2:00	LINE CLEAR AVAILED
107	27-May-22	HASSAN	110	HV1	KAVOOR	9:40(26.05.2022)	17:52(27.05.2022)	32:12HRS	TRANSFORMER CHARGED
108	27-May-22	HASSAN	110	HV1	SORABA_110	13:30	13:45	0:15	LINE CLEAR AVAILED
109	27-May-22	HASSAN	110	HV2	ANANDPURA_110	11:00	17:27	6:27	LINE CLEAR AVAILED
110	27-May-22	HASSAN	110	HV2	BARANGI_110	18:20	18:32	0:12	HAND TRIPPED
111	27-May-22	HASSAN	110	HV2	BARANGI_110	20:40	20:44	0:04	HAND TRIPPED
112	27-May-22	HASSAN	110	HV2	KAVOOR_220	23:59	17:52	17:52	LINE CLEAR AVAILED
113	27-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
114	27-May-22	HASSAN	110	HV3	SAGARA_110	13:40	15:55	2:15	LINE CLEAR AVAILED
115	27-May-22	HASSAN	110	HV4	PUTUR_110	9:30	16:42	7:12	LINE CLEAR AVAILED
116	27-May-22	HASSAN	110	JOG110-MGHE	JOG_110	9:55	16:30	6:35	NFBC ISSUED
117	27-May-22	HASSAN	110	JOG-JLT3	mghe_gen	9:51	19:35	9:44	LINE CLEAR AVAILED
118	27-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
119	27-May-22	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:43	14:06	3:23	LINE CLEAR AVAILED
120	27-May-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LINE OPEN:LINE FAULT
121	27-May-22	HASSAN	110	MSEZ-GSS31	MSEZ_220	10:05	14:17	4:12	LINE CLEAR AVAILED
122	27-May-22	HASSAN	110	MSEZ-GSS32	MSEZ_220	10:05	14:17	4:12	LINE CLEAR AVAILED
123	27-May-22	HASSAN	110	SAGARA-SORABA	SAGARA_110	10:55	17:25	6:30	NFBC ISSUED
124	27-May-22	HASSAN	110	SAGARA-TAL	SAGARA_110	11:35	12:20	0:45	LINE CLEAR AVAILED
125	27-May-22	HASSAN	110	SHIRAL-SHIRL	SHIRALKOPPA_110	10:40	11:10	0:30	MAIN SUPPLY FAILURE
126	27-May-22	HASSAN	110	SHIRAL-SHIRL	SHIRALKOPPA_110	11:17	11:45	0:28	MAIN SUPPLY FAILURE
127	27-May-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	10:41	11:10	0:29	MAIN SUPPLY FAILURE
128	27-May-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	11:16	11:56	0:40	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
129	27-May-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	10:40	11:10	0:30	MAIN SUPPLY FAILURE
130	27-May-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	11:16	11:56	0:40	MAIN SUPPLY FAILURE
131	27-May-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	10:40	11:10	0:30	MAIN SUPPLY FAILURE
132	27-May-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:16	11:56	0:40	MAIN SUPPLY FAILURE
133	27-May-22	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	10:40	11:10	0:30	MAIN SUPPLY FAILURE
134	27-May-22	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	11:16	11:56	0:40	MAIN SUPPLY FAILURE
135	27-May-22	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	13:04	13:09	0:05	MAIN SUPPLY FAILURE
136	27-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
137	27-May-22	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	10:39	11:10	0:31	LINE CLEAR AVAILED
138	27-May-22	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	11:17	11:55	0:38	LINE CLEAR AVAILED
139	27-May-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	10:39	11:10	0:31	LINE CLEAR AVAILED
140	27-May-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:17	11:55	0:38	LINE CLEAR AVAILED
141	27-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
142	27-May-22	MYSURU	66	BYLUKUPPE-KUSHALANAGARA	BYLUKUPPE_66	12:39	13:41	01:02	LINE FAULT
143	27-May-22	MYSURU	66	C R NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	12:11	12:16	00:05	LINE FAULT
144	27-May-22	MYSURU	66	D R PETE-KUNTUR	JANNUR_66 MUGUR_66 SANTHEMARAHALLI_66 TNARASIPURA_66 THAYUR_66	12:58	13:08	00:10	LINE FAULT
145	27-May-22	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
146	27-May-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
147	27-May-22	MYSURU	66	HEBBANI-MEGAHALAPURA	GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	18:47	18:57	00:10	LINE FAULT
148	27-May-22	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	12:03:00 (14.5.2022)			LINE OPEN:LINE FAULT
149	27-May-22	MYSURU	66	HEBBANI-VADAKEPURA	KIRUGAVALU_66 MALIYURU_66 VADKEPURA_66	19:22	19:38	00:16	LINE FAULT
150	27-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
151	27-May-22	MYSURU	66	HV1	BANNIMANTAP_66	10:45	11:32	00:47	LINE CLEAR AVAILED
152	27-May-22	MYSURU	66	HV1	BANNIMANTAP_66	11:35	11:38	00:03	TRANSFORMER FAULT
153	27-May-22	MYSURU	66	HV1	DATTAGALLY_66	12:45	13:31	00:45	LINE CLEAR AVAILED
154	27-May-22	MYSURU	66	HV1	RKNAGARA_66	10:41	16:22	05:40	LINE CLEAR AVAILED
155	27-May-22	MYSURU	66	HV2	ARAKERE_66	04:44	04:55	00:11	TRANSFORMER FAULT
156	27-May-22	MYSURU	66	HV2	BANNIMANTAP_66	10:45	11:32	00:47	LINE CLEAR AVAILED
157	27-May-22	MYSURU	66	HV2	BANNIMANTAP_66	11:35	11:38	00:03	TRANSFORMER FAULT
158	27-May-22	MYSURU	66	HV2	SANTHEMARAHALLI_66	16:44	17:17	00:33	LINE CLEAR AVAILED
159	27-May-22	MYSURU	66	K R PETE 220-C R PATNA	NO STATIONS EFFECTED	14:13	15:45	01:32	LINE CLEAR AVAILED
160	27-May-22	MYSURU	66	K R PETE 220-K R PETE 1	AKKIHEBBAL_66 KIKKERI_66 KRPET_66	10:55	18:09	07:14	LINE CLEAR AVAILED
161	27-May-22	MYSURU	66	K R PETE 220-K R PETE 2	NO STATIONS EFFECTED	10:55	18:09	07:14	LINE CLEAR AVAILED
162	27-May-22	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57:05 (4/5/2022)	23:50:00 (27/05/2022)	12:52 hrs	LOAD CHANGE OVER
163	27-May-22	MYSURU	66	KIADB MANDYA-T K HALLI	KIADBMANDYA_66	10:03	13:05	03:02	LINE CLEAR AVAILED
164	27-May-22	MYSURU	66	KIADB MANDYA-TUMBEEKERE	TUMBEEKERE_66	10:03	14:38	04:35	LINE CLEAR AVAILED
165	27-May-22	MYSURU	66	MADDUR-KIADB MANDYA	NO STATIONS EFFECTED	09:54	14:04	04:09	LOAD CHANGE OVER
166	27-May-22	MYSURU	220	HV1	KRPET_220	10:11	13:06	02:55	LINE CLEAR AVAILED
167	27-May-22	MYSURU	220	HV1	KRPET_220	13:08	16:44	03:36	LINE CLEAR AVAILED
168	27-May-22	TUMKUR	66	BENKIKERE-CHANNAGIRI	BENKIKERE_66	11:15	13:35	2:20	LINE CLEAR AVAILED
169	27-May-22	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	16:13	16:30	0:17	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
170	27-May-22	TUMKUR	66	HONNALLI 220KV- KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	13:21	13:31	0:10	LINE FAULT
171	27-May-22	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	6:07	6:17	0:10	LINE FAULT
172	27-May-22	TUMKUR	66	HONNAVALLI 110- KADUR110	HONNAVALLI_110	11:34	11:45	0:11	LINE FAULT
173	27-May-22	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:16	10:28	0:12	LINE FAULT
174	27-May-22	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR2	WELSPUN SOLAR2	10:14	10:28	0:14	LINE FAULT
175	27-May-22	TUMKUR	66	TR2	MADHUGIRI_220	9:58	10:12	0:14	TRANSFORMER FAULT
176	27-May-22	TUMKUR	66	TR2	MADHUGIRI_220	23:20	23:59	0:40	TRANSFORMER FAULT
177	27-May-22	TUMKUR	220	THALLAK_220-HM HOLE LINE-2	THALLAK_220	12:12	18:02	5:50	NFBC ISSUED
178	27-May-22	TUMKUR	220	TR2	ANTHRASANAHALI_220	11:32	17:35	6:03	LINE CLEAR AVAILED
179	28-May-22	BAGALKOT	110	110/11KV, HV1	BHOJ_110	07:35	09:15	1:40	LINE CLEAR AVAILED
180	28-May-22	BAGALKOT	110	110/11KV, HV1	CHADCHAN_110	7:20 (19.05.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
181	28-May-22	BAGALKOT	110	110/11KV, HV1	KUDACHI_220	12:38	12:43	0:05	TRANSFORMER FAULT
182	28-May-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED ATHARGA_110	17:17	18:27	1:10	LINE CLEAR AVAILED
183	28-May-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED HIREMASALI_110	18:17	18:59	0:42	LINE CLEAR AVAILED
184	28-May-22	BAGALKOT	110	110/11KV, HV1	TOLAMATTI_110	12:45	13:55	1:10	LINE CLEAR AVAILED
185	28-May-22	BAGALKOT	110	110/11KV,HV1	KUD DHARWAD_110	11:51	16:27	4:36	LINE CLEAR AVAILED
186	28-May-22	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	16:13	16:28	0:15	TRANSFORMER FAULT
187	28-May-22	BAGALKOT	110	110/11KV,HV1	RAIBAG_110	05:40	05:57	0:17	TRANSFORMER FAULT
188	28-May-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED TOLAMATTI_110	12:46	13:54	1:08	LINE CLEAR AVAILED
189	28-May-22	BAGALKOT	110	110/11KV,HV2	KUD DHARWAD_110	16:29	17:08	0:39	LINE CLEAR AVAILED
190	28-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
191	28-May-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
192	28-May-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVAILED
193	28-May-22	BAGALKOT	110	BIDNAL220-GADAG	STATIO NOT AFFECTED BIDNAL_220	11:55	18:43	6:48	NFBC ISSUED
194	28-May-22	BAGALKOT	110	GADAG ROAD-GOPANAKOPPA(BIDNAL(220)	GADAG ROAD_110	11:45	14:38	2:53	HAND TRIPPED
195	28-May-22	BAGALKOT	110	HIREBEVANUR-INDI/LACHYAN(RODGI)	RODAGI_110	5:22	5:30	0:08	LINE FAULT
196	28-May-22	BAGALKOT	110	HUNAGUND-ILKAL1	HUNAGUND_110	10:51	17:42	6:51	LINE CLEAR AVAILED
197	28-May-22	BAGALKOT	110	HUNAGUND-ILKAL2	HUNAGUND_110	10:51	17:42	6:51	LINE CLEAR AVAILED
198	28-May-22	BAGALKOT	110	ILKAL-AVADA SOLAR	AVAADA SOLAR_110 ILKAL_110	10:19	17:19	7:00	LINE CLEAR AVAILED
199	28-May-22	BAGALKOT	110	ILKAL-KUSHTAGI1&2	ILKAL_110	10:19	17:19	7:00	LINE CLEAR AVAILED
200	28-May-22	BAGALKOT	110	MAHALINGAPUR- TERDAL	MAHALINGAPUR_220	07:30	07:52	0:22	LINE FAULT
201	28-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
202	28-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
203	28-May-22	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	23:28 (27.05.2022)	12:15 (28.05.2022)	12:47 hrs	LINE CHARGED
204	28-May-22	BAGALKOT	110	YLWD-F3 Cbreaker(ALBAL)	STATION NOT AFFECTED YELAMANAWADI_110	8:00	10:40	2:40	NFBC ISSUED
205	28-May-22	BAGALKOT	220	BAGEWADI-BIJAPUR1	STATION NOT AFFECTED BAGEWADI_220	17:54 (19.05.2022)			LINE OPEN:LINE CLEAR AVAILED
206	28-May-22	BAGALKOT	220	BAGEWADI-BIJAPUR2	STATION NOT AFFECTED BAGEWADI_220	17:54 (19.05.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
207	28-May-22	BAGALKOT	220	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	22:21 (27.05.2022)	00:19 (28.05.2022)	1:58 hrs	LINE CHARGED
208	28-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
209	28-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
210	28-May-22	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	5:20	5:28	0:08	LOAD CHANGE OVER
211	28-May-22	BENGALURU	66	HV1	JIGANI 220	5:58	19:10	13:12	LINE CLEAR AVAILED
212	28-May-22	BENGALURU	66	HV1	MALLASANDRA	10:51	11:25	0:34	LINE CLEAR AVAILED
213	28-May-22	BENGALURU	66	HV1	SARAKKI	13:15	14:30	1:15	LINE CLEAR AVAILED
214	28-May-22	BENGALURU	66	HV1	ST JOHNS	14:31	14:35	0:04	LINE CLEAR AVAILED
215	28-May-22	BENGALURU	66	HV1	YARANDANAHALLI 220	6:06	6:37	0:31	LOAD CHANGE OVER
216	28-May-22	BENGALURU	66	HV2	JIGANI 220	5:58	19:10	13:12	LINE CLEAR AVAILED
217	28-May-22	BENGALURU	66	HV2	MANCHENAHALLI	14:41	16:00	1:19	LINE CLEAR AVAILED
218	28-May-22	BENGALURU	66	HV2	NANDINI LAYOUT	11:18	11:23	0:05	LINE CLEAR AVAILED
219	28-May-22	BENGALURU	66	HV2	ST JOHNS	10:53	10:59	0:06	LINE CLEAR AVAILED
220	28-May-22	BENGALURU	66	HV2	ST JOHNS	16:22	16:24	0:02	LOAD CHANGE OVER
221	28-May-22	BENGALURU	66	HV2	YARANDANAHALLI 220	6:12	6:15	0:03	LOAD CHANGE OVER
222	28-May-22	BENGALURU	66	HV3	YARANDANAHALLI 220	6:06	6:37	0:31	LOAD CHANGE OVER
223	28-May-22	BENGALURU	66	JAGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGANDODDI	5:58	7:00	1:02	LINE CLEAR AVAILED
224	28-May-22	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	5:58	6:23	0:25	LINE CLEAR AVAILED
225	28-May-22	BENGALURU	66	JIGANI 66 - JIGANI LINK ROAD	JIGANI 66	10:20	18:50	8:30	LINE CLEAR AVAILED
226	28-May-22	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NO STATION AFFECTED	5:46	6:04	0:18	LINE FAULT
227	28-May-22	BENGALURU	66	KOTHIPURA 220 - MELLAHALLI	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, URAGAHALLI	1:42	1:52	0:10	LINE FAULT
228	28-May-22	BENGALURU	66	KOTHIPURA 220 - MELLAHALLI	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, URAGAHALLI	13:35	14:05	0:30	LINE FAULT
229	28-May-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	6:06	6:35	0:29	LOAD CHANGE OVER
230	28-May-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, SAMANDURU	6:06	6:35	0:29	LOAD CHANGE OVER
231	28-May-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	6:06	6:35	0:29	LOAD CHANGE OVER
232	28-May-22	BENGALURU	66	YARANDANAHALLI 220 - JIGANI 66	KUMBARANAHALLI	11:35	13:25	1:50	LINE CLEAR AVAILED
233	28-May-22	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	6:06	6:35	0:29	LOAD CHANGE OVER
234	28-May-22	BENGALURU	220	HV1	JIGANI 220	5:58	18:47	12:49	LINE CLEAR AVAILED
235	28-May-22	BENGALURU	220	HV2	JIGANI 220	5:58	18:47	12:49	LINE CLEAR AVAILED
236	28-May-22	BENGALURU	220	JIGANI 220 - MYLASANDRA 400	JIGANI 220	5:58	18:47	12:49	LINE CLEAR AVAILED
237	28-May-22	BENGALURU	220	JIGANI 220 - YERANDANAHALLI 220	JIGANI 220	5:58	18:47	12:49	LINE CLEAR AVAILED
238	28-May-22	BENGALURU	220	LV1	JIGANI 220	5:58	18:51	12:53	LINE CLEAR AVAILED
239	28-May-22	BENGALURU	220	LV2	JIGANI 220	5:58(28-5-2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
240	28-May-22	BENGALURU	400	DEVANAHALLI 400 - HOODY 400 1 O/G	NO STATION AFFECTED	21:02(28-5-2022)			LINE OPEN:LINE FAULT
241	28-May-22	BENGALURU	400	DEVANAHALLI 400 - NELAMANGALA 400 I/C	NO STATION AFFECTED	21:02(28-5-2022)			LINE OPEN:LINE FAULT
242	28-May-22	BENGALURU	400	DEVANAHALLI 400 - PAVAGADA 400 1 I/C	NO STATION AFFECTED	21:02(28-5-2022)			LINE OPEN:LINE FAULT
243	28-May-22	BENGALURU	400	DEVANAHALLI 400 - PAVAGADA 400 2 I/C	NO STATION AFFECTED	21:02(28-5-2022)			LINE OPEN:LINE FAULT
244	28-May-22	BENGALURU	400	DEVANAHALLI 400 - SINGANAYAKANAHALLI 400 I/C	NO STATION AFFECTED	21:02(28-5-2022)			LINE OPEN:LINE FAULT
245	28-May-22	GULBARGA	66	HV2	BENNEHALLI_66	17:30	17:35	0:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
246	28-May-22	GULBARGA	110	HV1	KUSTAGI_220	7:30	7:55	15:14	TRANSFORMER FAULT
247	28-May-22	GULBARGA	110	HV2	ALIPUR_220	7:20	7:49	0:29	TRANSFORMER FAULT
248	28-May-22	GULBARGA	110	HV2	GULBARGAUNIVERSITY_110	13:20	13:40	0:20	LINE CLEAR AVAIED
249	28-May-22	GULBARGA	110	HV2	NANDUR_110	11:55	12:45	0:50	LINE CLEAR AVAIED
250	28-May-22	GULBARGA	110	HV2	NIRNA_110	15:05	15:10	0:05	TRANSFORMER FAULT
251	28-May-22	GULBARGA	110	KUSTAGI-ILKAL_1 & 2	ILKAL_110	10:22	16:52	15:14	NFBC ISSUED
252	28-May-22	GULBARGA	110	MUNIRABAD-SINDHANQOR2	KAMPLI_110,MUKUNDA_110,KEREHALLI_110,MALLA PUR_110	12:21	12:33	0:12	LINE FAULT
253	28-May-22	GULBARGA	110	RAJESHWAR-WARDHA SOLAR	WARDHA SOLAR_IPP	4:00	10:55	6:55	LINE CLEAR AVAIED
254	28-May-22	GULBARGA	110	SEDAM-VASAVADATTA CEMENT	SEDAM_220	18:40 (27.05.2022)	2:20 (28.05.2022)	7:40 HRS	LINE CHARGED
255	28-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SA NNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAIED
256	28-May-22	GULBARGA	220	ALIPUR-RAGALPADU	RAGALPADU_220	2:35(17.05.2022)			LINE OPEN:LINE CLEAR AVAIED
257	28-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
258	28-May-22	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	01:55(17.05.2022)			LINE OPEN:LINE CLEAR AVAIED
259	28-May-22	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	11:23(27.05.22)			LINE OPEN:LINE CLEAR AVAIED
260	28-May-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN:LINE FAULT
261	28-May-22	HASSAN	66	HV1	HASSAN_66	10:42	10:50	0:08	HAND TRIPPED
262	28-May-22	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	10:58	12:10	1:12	MAIN SUPPLY FAILURE
263	28-May-22	HASSAN	66	MRSSTM-DVG2	MRSMTG_220	6:33	6:42	0:09	LINE FAULT
264	28-May-22	HASSAN	66	SAKALE-HASSAN1	SAKLESHPUA_66	10:59	12:13	1:14	NFBC ISSUED
265	28-May-22	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	10:59	12:15	1:16	MAIN SUPPLY FAILURE
266	28-May-22	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	14:20	17:56	3:36	LINE CLEAR AVAIED
267	28-May-22	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	10:59	12:15	1:16	MAIN SUPPLY FAILURE
268	28-May-22	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	14:20	17:56	3:36	LINE CLEAR AVAIED
269	28-May-22	HASSAN	110	HV2	KEMAR_220	22:25	22:36	0:11	TRANSFORMER FAULT
270	28-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAIED
271	28-May-22	HASSAN	110	JOG-JLT4	mghe_gen	12:41	16:38	3:57	LINE CLEAR AVAIED
272	28-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAIED
273	28-May-22	HASSAN	110	KADUR-AJAMPURA	KADUR_220	17:18	18:10	0:52	LINE FAULT
274	28-May-22	HASSAN	110	LPH-MGHE 2	lph_gen	11:26	16:27	5:01	NFBC ISSUED
275	28-May-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LINE OPEN:LINE FAULT
276	28-May-22	HASSAN	110	SAGARA-ALKOLA	SAGARA_110	11:15	12:30	1:15	LINE FAULT
277	28-May-22	HASSAN	110	SHIRAL-SHIRL	SHIRALKOPPA_110	13:02	13:16	0:14	MAIN SUPPLY FAILURE
278	28-May-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	13:04	13:08	0:04	MAIN SUPPLY FAILURE
279	28-May-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	13:04	13:08	0:04	MAIN SUPPLY FAILURE
280	28-May-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	13:04	13:08	0:04	MAIN SUPPLY FAILURE
281	28-May-22	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	13:05	13:09	0:04	MAIN SUPPLY FAILURE
282	28-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAIED
283	28-May-22	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	11:10	13:03	1:53	LINE CLEAR AVAIED
284	28-May-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:10	13:02	1:52	HAND TRIPPED
285	28-May-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	13:02	13:16	0:14	MAIN SUPPLY FAILURE
286	28-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAIED
287	28-May-22	MYSURU	66	CR NAGAR-HONNALLY	HONNALLY_66 ATTIGULIPURA_66 ARAKALAWADI_66	10:43	17:06	06:23	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
288	28-May-22	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
289	28-May-22	MYSURU	66	HANNUR-AJJIPURA	BANDALLI_66 AJJIPURA_66 COWDALI_66 RAMAMPURA_66 MARTAHALLI_66	08:30	18:55	10:25	LINE CLEAR AVAILED
290	28-May-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
291	28-May-22	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	12:03:00 (14.5.2022)			LINE OPEN:LINE FAULT
292	28-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
293	28-May-22	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVNUR(N'GUD)_66 SUTTUR_66	18:53	18:58	00:05	LINE FAULT
294	28-May-22	MYSURU	66	KK DODDI-TK HALLI	KK DODDI_66	10:05	16:30	06:25	LINE CLEAR AVAILED
295	28-May-22	MYSURU	66	MADDUR-K.HONALGERE	SOMANAHALLI_66	19:03	19:16	00:13	LINE FAULT
296	28-May-22	MYSURU	66	MADHUVANAHALLI-PGPALYA	LOKKANAHALLI_66 PGPALYA_66	09:34	09:40	00:06	LINE FAULT
297	28-May-22	MYSURU	66	MADHUVANAHALLI-PGPALYA	LOKKANAHALLI_66 PGPALYA_66	10:02	16:12	06:09	NFBC ISSUED
298	28-May-22	MYSURU	66	TUBINKERE-MANDYA2	NO STATIONS EFFECTED	09:50	13:45	03:55	LINE CLEAR AVAILED
299	28-May-22	MYSURU	66	TUBINKERE-MANDYA4	NO STATIONS EFFECTED	09:50	13:45	03:55	LINE CLEAR AVAILED
300	28-May-22	MYSURU	66	TUBINKERE-NAGAMGALA1	NO STATIONS EFFECTED	03:01	03:14	00:12	LINE FAULT
301	28-May-22	MYSURU	66	VAJMANGALA-DEVNUR(MYS)	RAJEEVNAGARA_66 DEVNUR(MYS)_66	00:37	00:48	00:11	LOAD CHANGE OVER
302	28-May-22	MYSURU	66	VAJMANGALA-DEVNUR(MYS)	RAJEEVNAGARA_66 DEVNUR(MYS)_66	11:39	11:41	00:02	LOAD CHANGE OVER
303	28-May-22	MYSURU	66	VAJMANGALA-JYOTHINAGARA	JYOTHINAGARA_66 FTS_66 DK MAIDANA_66	00:37	00:48	00:11	LOAD CHANGE OVER
304	28-May-22	MYSURU	66	VAJMANGALA-JYOTHINAGARA	JYOTHINAGARA_66 FTS_66 DK MAIDANA_66	11:39	11:41	00:02	LOAD CHANGE OVER
305	28-May-22	MYSURU	220	VAJMANGALA-HV2	NO STATIONS EFFECTED	10:42	11:34	00:52	LINE CLEAR AVAILED
306	28-May-22	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:54	10:14	0:20	LINE FAULT
307	28-May-22	TUMKUR	66	HONNALLI 220KV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	12:26	12:36	0:10	LINE FAULT
308	28-May-22	TUMKUR	66	HONNALLI 220KV- KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	14:25	14:35	0:10	LINE FAULT
309	29-May-22	BAGALKOT	110	110/110/11KV,HV3	UDAYMBAG_110	10:10	16:10	2:20	LINE CLEAR AVAILED
310	29-May-22	BAGALKOT	110	110/11KV, HV1	CHADCHAN_110	7:20 (19.05.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
311	29-May-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED DEVARGENNUR_110	7:23	9:41	2:18	TRANSFORMER FAULT
312	29-May-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED HIREMASALI_110	18:08	18:51	0:43	LINE CLEAR AVAILED
313	29-May-22	BAGALKOT	110	110/11KV, HV2	ALBAL_110	7:15	10:40	3:25	LINE CLEAR AVAILED
314	29-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED DEVARGENNUR_110	7:30	8:10	0:40	TRANSFORMER FAULT
315	29-May-22	BAGALKOT	110	110/11KV,HV1	JAMAKHANDI_110	10:00	19:42	9:42	LINE CLEAR AVAILED
316	29-May-22	BAGALKOT	110	110/11KV,HV2	JAMAKHANDI_110	10:00	19:44	9:44	LINE CLEAR AVAILED
317	29-May-22	BAGALKOT	110	110/11KV,HV2	KULIGOD_110	19:53	20:00	0:07	TRANSFORMER FAULT
318	29-May-22	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	9:54	9:59	0:05	TRANSFORMER FAULT
319	29-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED UDAYMBAG_110	10:31	16:08	5:37	LINE CLEAR AVAILED
320	29-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
321	29-May-22	BAGALKOT	110	110/11KV,HV2A	JAMAKHANDI_110	10:00	19:32	9:32	LINE CLEAR AVAILED
322	29-May-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
323	29-May-22	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS	SAIPRIYA SUGARS_110 ALBAL_110	7:14	10:46	3:32	LINE CLEAR AVAILED
324	29-May-22	BAGALKOT	110	ALBAL-YELLAMMANAWADI	ALBAL_110	7:15	10:40	3:25	LINE CLEAR AVAILED
325	29-May-22	BAGALKOT	110	AMBEWADI- NK1 (HALIYAL)	AMBEWADI_220	11:58	15:00	3:02	LINE FAULT
326	29-May-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
327	29-May-22	BAGALKOT	110	BELGAUM220- KANABARGI LAYOUT	BELGAUM_220	15:53	17:46	9:39	LINE CLEAR AVAILED
328	29-May-22	BAGALKOT	110	BELGAUM220- NEHRU NAGAR	BELGAUM_220	09:02	12:34	21:36	LINE CLEAR AVAILED
329	29-May-22	BAGALKOT	110	BELGAUM220- VADAGOAN	BELGAUM_220	12:10	20:13	8:23	LINE CLEAR AVAILED
330	29-May-22	BAGALKOT	110	BELGAUM220-BELAUM	BELGAUM_110	9:07	12:37	3:30	LINE CLEAR AVAILED
331	29-May-22	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	KANABARGI LAYOUT_110	15:53	19:46	3:53	LINE CLEAR AVAILED
332	29-May-22	BAGALKOT	110	GHATAPRABHA- GHATAPRABHA2	GHATAPRABHA_220	17:19	18:29	01:10	LINE FAULT
333	29-May-22	BAGALKOT	110	HUKKERI-VSL SUGARS	VSL SUGARS_110 HUKKERI_110	9:28	9:31	0:03	LINE FAULT
334	29-May-22	BAGALKOT	110	ITNAL-HIDKAL(MUGALKHOD3)	STATION NOT AFFECTED ITNAL_110	1:12	1:24	0:12	LINE FAULT
335	29-May-22	BAGALKOT	110	JAMAKHANDI-PRABHULINGESHWAR(NAVALAGI)	JAMAKHANDI_110	9:50	19:24	9:34	NFBC ISSUED
336	29-May-22	BAGALKOT	110	MUGALKHOD- ITANAL3	MUGALKHOD_220	01:12	01:24	2:36	LINE FAULT
337	29-May-22	BAGALKOT	110	NAVALAGI-JAMAKHANDI	JAMAKHANDI_110	10:01	19:21	9:20	LINE CLEAR AVAILED
338	29-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
339	29-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
340	29-May-22	BAGALKOT	110	TAKKALAKI-KNS SOLAR	TAKKALAKI_110	5:58	6:10	0:12	HAND TRIPPED
341	29-May-22	BAGALKOT	110	TAKKALAKI-KNS SOLAR	TAKKALAKI_110	13:09	13:12	0:03	HAND TRIPPED
342	29-May-22	BAGALKOT	110	TAKKALAKI-THORVI	TAKKALAKI_110	6:00	6:09	0:09	LOAD CHANGE OVER
343	29-May-22	BAGALKOT	110	TAKKALAKI-TIKOTA	TAKKALAKI_110	6:00	6:08	0:08	LOAD CHANGE OVER
344	29-May-22	BAGALKOT	110	TAKKALAKI-TIKOTA	TAKKALAKI_110	13:10	13:12	0:02	LOAD CHANGE OVER
345	29-May-22	BAGALKOT	110	TAKKALAKI-WARADA SOLAR	TAKKALAKI_110	6:00	6:11	0:11	HAND TRIPPED
346	29-May-22	BAGALKOT	110	THORVI(BJCTY)-BHUTANAL	STATIO NOT AFFECTED THORVI_110	5:56	13:08	7:12	LINE CLEAR AVAILED
347	29-May-22	BAGALKOT	110	YLWD-F3 Cbreaker(ALBAL)	STATION NOT AFFECTEDYELLAMANAWADI_110	7:15	10:37	3:22	NFBC ISSUED
348	29-May-22	BAGALKOT	220	BAGEWADI-BIJAPUR1	STATION NOT AFFECTED BAGEWADI_220	17:54 (19.05.2022)			LINE OPEN:LINE CLEAR AVAILED
349	29-May-22	BAGALKOT	220	BAGEWADI-BIJAPUR2	STATION NOT AFFECTED BAGEWADI_220	17:54 (19.05.2022)			LINE OPEN:LINE CLEAR AVAILED
350	29-May-22	BAGALKOT	220	HUBLI- NAGAJHARI2	HUBLI_220	12:55	14:07	1:12	LINE FAULT
351	29-May-22	BAGALKOT	220	HUBLI- NARENDRA2	HUBLI_220	09:28	11:27	1:59	LINE CLEAR AVAILED
352	29-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
353	29-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
354	29-May-22	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	5:58	6:12	0:14	LINE FAULT
355	29-May-22	BENGALURU	66	C STATION 1 & 2 - A STATION 220	C STATION 1 & 2	7:31	7:36	0:05	LOAD CHANGE OVER
356	29-May-22	BENGALURU	66	CHELUR - YENNIGADALE	CHELUR	20:17	20:28	0:11	LINE FAULT
357	29-May-22	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	10:16	10:26	0:10	LINE FAULT
358	29-May-22	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLIC CROSS, YENIGADALE	14:01	14:11	0:09	LINE FAULT
359	29-May-22	BENGALURU	66	HV1	DASHAVARA	4:21	4:26	0:05	TRANSFORMER FAULT
360	29-May-22	BENGALURU	66	HV1	HUKUNDA	13:32	13:40	0:07	TRANSFORMER FAULT
361	29-May-22	BENGALURU	66	HV1	HUKUNDA	17:01	17:09	0:08	TRANSFORMER FAULT
362	29-May-22	BENGALURU	66	HV1	HUKUNDA	17:35	17:40	0:04	TRANSFORMER FAULT
363	29-May-22	BENGALURU	66	HV1	PATHPALYA	11:49	11:53	0:04	TRANSFORMER FAULT
364	29-May-22	BENGALURU	66	HV1	PATHPALYA	11:07	11:17	0:10	TRANSFORMER FAULT
365	29-May-22	BENGALURU	66	HV2	CHATRA	16:03	16:19	0:16	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
366	29-May-22	BENGALURU	66	HV2	TYAMAGONDLU	22:04	22:10	0:06	TRANSFORMER FAULT
367	29-May-22	BENGALURU	66	HV2	TYAMAGONDLU	22:37	22:43	0:06	TRANSFORMER FAULT
368	29-May-22	BENGALURU	66	JAYADEVA - ADUGODI 1	NO STATION AFFECTED	14:05	15:25	1:20	LINE FAULT
369	29-May-22	BENGALURU	66	JIGANI 66 - JIGANI LINK ROAD	JIGANI 66	7:13	7:18	0:05	LOAD CHANGE OVER
370	29-May-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	3:33	3:44	0:10	LINE FAULT
371	29-May-22	BENGALURU	66	KUMBARANAHALLI - JIGANI 220	KUMBARANAHALLI, BAGANDODDI	5:55	6:35	0:40	LOAD CHANGE OVER
372	29-May-22	BENGALURU	66	LV1	MALUR 220	13:38	16:07	2:29	LINE CLEAR AVOID
373	29-May-22	BENGALURU	66	LV1	MALUR 220	13:37	16:06	2:28	LINE CLEAR AVOID
374	29-May-22	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	13:38	16:08	2:30	LINE CLEAR AVOID
375	29-May-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	13:37	16:09	2:32	LINE CLEAR AVOID
376	29-May-22	BENGALURU	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	13:36	16:07	2:30	LINE CLEAR AVOID
377	29-May-22	BENGALURU	66	MALUR 220 - KGF 2	BANGARPETE	13:37	16:08	2:31	LINE CLEAR AVOID
378	29-May-22	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	13:37	16:08	2:31	LINE CLEAR AVOID
379	29-May-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	13:37	16:07	2:30	LINE CLEAR AVOID
380	29-May-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	13:37	16:07	2:29	LINE CLEAR AVOID
381	29-May-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	13:37	16:08	2:31	LINE CLEAR AVOID
382	29-May-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR	20:17	20:28	0:11	LINE FAULT
383	29-May-22	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	10:51	18:44	7:53	LINE CLEAR AVOID
384	29-May-22	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	9:10	10:40	1:30	MAIN SUPPLY FAILURE
385	29-May-22	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	12:10	16:31	4:21	MAIN SUPPLY FAILURE
386	29-May-22	BENGALURU	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	9:10	10:06	0:56	MAIN SUPPLY FAILURE
387	29-May-22	BENGALURU	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	12:10	16:31	4:21	MAIN SUPPLY FAILURE
388	29-May-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	9:10	10:06	0:56	MAIN SUPPLY FAILURE
389	29-May-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	12:10	16:31	4:21	MAIN SUPPLY FAILURE
390	29-May-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML	9:10	10:06	0:56	MAIN SUPPLY FAILURE
391	29-May-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML	12:10	16:31	4:21	MAIN SUPPLY FAILURE
392	29-May-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	9:10	10:06	0:56	MAIN SUPPLY FAILURE
393	29-May-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	12:10	16:31	4:21	MAIN SUPPLY FAILURE
394	29-May-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, NG HULKUR, MALLANAYAKANAHALLI	9:10	10:06	0:56	MAIN SUPPLY FAILURE
395	29-May-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, NG HULKUR, MALLANAYAKANAHALLI	12:10	16:31	4:21	MAIN SUPPLY FAILURE
396	29-May-22	BENGALURU	66	TG HALLI	TAVAREKERE	9:55	16:07	6:12	LINE CLEAR AVOID
397	29-May-22	BENGALURU	66	YARANDANAHALLI 220 - JIGANI 66	KUMBARANAHALLI	5:57	9:40	3:43	LINE FAULT
398	29-May-22	BENGALURU	220	HV1	T GOLLAHALLI 220	9:10	10:06	0:56	TRANSFORMER FAULT
399	29-May-22	BENGALURU	220	HV2	T GOLLAHALLI 220	9:35	10:06	0:31	LOAD CHANGE OVER
400	29-May-22	BENGALURU	220	LV2	JIGANI 220	5:58(28-5-2022)	7:19(29-5-2022)	25:20 hrs	TRANSFORMER CHARGED
401	29-May-22	BENGALURU	220	T GOLLAHALLI 220 - PGCIL 1 220	T GOLLAHALLI 220	9:10	12:10	3:00	LINE FAULT
402	29-May-22	BENGALURU	220	T GOLLAHALLI 220 - PGCIL 1 220	T GOLLAHALLI 220	12:10	16:31	4:21	LINE CLEAR AVOID
403	29-May-22	BENGALURU	220	T GOLLAHALLI 220 - PGCIL 2 220	T GOLLAHALLI 220	12:10	16:25	4:15	LINE CLEAR AVOID
404	29-May-22	BENGALURU	400	DEVANAHALLI 400 - HOODY 400 1 O/G	NO STATION AFFECTED	21:02(28-5-2022)	2:19(29-5-2022)	5:16 hrs	LINE CHARGED
405	29-May-22	BENGALURU	400	DEVANAHALLI 400 - NELAMANGALA 400 I/C	NO STATION AFFECTED	21:02(28-5-2022)	2:19(29-5-2022)	5:16 hrs	LINE CHARGED
406	29-May-22	BENGALURU	400	DEVANAHALLI 400 - PAVAGADA 400 1 I/C	NO STATION AFFECTED	21:02(28-5-2022)	2:19(29-5-2022)	5:16 hrs	LINE CHARGED
407	29-May-22	BENGALURU	400	DEVANAHALLI 400 - PAVAGADA 400 2 I/C	NO STATION AFFECTED	21:02(28-5-2022)	2:19(29-5-2022)	5:16 hrs	LINE CHARGED
408	29-May-22	BENGALURU	400	DEVANAHALLI 400 - SINGANAYAKANAHALLI 400 I/C	NO STATION AFFECTED	21:02(28-5-2022)	2:19(29-5-2022)	5:16 hrs	LINE CHARGED
409	29-May-22	GULBARGA	66	HV1	PUNABGHATA_66	10:00	10:10	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
410	29-May-22	GULBARGA	66	HV2	BENNEHALLI_66	4:20	4:25	0:05	TRANSFORMER FAULT
411	29-May-22	GULBARGA	66	HV2	BENNEHALLI_66	11:30	11:35	0:05	TRANSFORMER FAULT
412	29-May-22	GULBARGA	66	PUNABGHATA-NEELAGUNDA	PUNABGHATA_66,UCCHANIDURGA_66	17:05	17:10	0:05	LINE FAULT
413	29-May-22	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PDHALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELS ACC	5:37	5:51	0:14	LINE FAULT
414	29-May-22	GULBARGA	110	CHOWDAPUR-AFZALPUR	AFZALPUR_110	4:05	8:30	4:25	LINE FAULT
415	29-May-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	19:21	19:45	0:24	LINE FAULT
416	29-May-22	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	6:47	10:48	4:01	LINE CLEAR AVAILED
417	29-May-22	GULBARGA	110	HV1	CHITGUPPA_110	6:40	11:00	4:20	LINE CLEAR AVAILED
418	29-May-22	GULBARGA	110	HV2	KUSTAGI_220	7:05	7:19	15:14	TRANSFORMER FAULT
419	29-May-22	GULBARGA	110	HV3	VALKAMDINNI_110	4:46	4:50	0:04	TRANSFORMER FAULT
420	29-May-22	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	19:22	19:27	0:05	LINE FAULT
421	29-May-22	GULBARGA	110	KUSTAGI-ILKAL_2	ILKAL_110	10:22	16:52	15:14	LINE CLEAR AVAILED
422	29-May-22	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORWAR TEMPLE_110	7:55	8:00	0:05	LINE FAULT
423	29-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SA NNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
424	29-May-22	GULBARGA	220	ALIPUR-RAGALPADU	RAGALPADU_220	2:35(17.05.2022)			LINE OPEN:LINE CLEAR AVAILED
425	29-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
426	29-May-22	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	01:55(17.05.2022)			LINE OPEN:LINE CLEAR AVAILED
427	29-May-22	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	11:23(27.05.22)			LINE OPEN:LINE CLEAR AVAILED
428	29-May-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN:LINE FAULT
429	29-May-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	16:40	17:05	0:25	LINE FAULT
430	29-May-22	HASSAN	66	HV1	CHANNARAYAPATNA_66	17:15	18:20	1:05	TRANSFORMER FAULT
431	29-May-22	HASSAN	66	HV1	SIGEBAGE_66	9:10	16:20	7:10	LINE CLEAR AVAILED
432	29-May-22	HASSAN	66	SAKALE-HV1	SAKLESH PURA_66	1:14	1:25	0:11	LINE FAULT
433	29-May-22	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	13:55	17:58	4:03	LINE CLEAR AVAILED
434	29-May-22	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	13:56	17:57	4:01	LINE CLEAR AVAILED
435	29-May-22	HASSAN	110	BRAHMAV-BRHM-NITUR	BRAHMAVARA_110	16:49	16:55	0:06	LOAD CHANGE OVER
436	29-May-22	HASSAN	110	HV1	NAVUNDA_110	4:39	4:47	0:08	TRANSFORMER FAULT
437	29-May-22	HASSAN	110	HV2	ALKOLA_110	8:27	10:02	1:35	LINE CLEAR AVAILED
438	29-May-22	HASSAN	110	HV2	ALKOLA_110	14:10	15:15	1:05	TRANSFORMER FAULT
439	29-May-22	HASSAN	110	HV2	ALKOLA_110	15:26	15:36	0:10	HAND TRIPPED
440	29-May-22	HASSAN	110	HV2	ALKOLA_110	15:43	15:50	0:07	HAND TRIPPED
441	29-May-22	HASSAN	110	HV2	KONAJE_110	1:37	2:19	0:42	MAIN SUPPLY FAILURE
442	29-May-22	HASSAN	110	HV2	SAGARA_110	13:40	14:35	0:55	LINE CLEAR AVAILED
443	29-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
444	29-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
445	29-May-22	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	1:37	2:19	0:42	MAIN SUPPLY FAILURE
446	29-May-22	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	16:49	16:52	0:03	LOAD CHANGE OVER
447	29-May-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LINE OPEN:LINE FAULT
448	29-May-22	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	1:38	8:00	6:22	LINE FAULT
449	29-May-22	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	1:38	2:15	0:37	LINE FAULT
450	29-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
451	29-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
452	29-May-22	MYSURU	66	CR NAGAR-DODDARAYAPETE	DODDARAYAPETE_66 SANTHEMARALLI_66	09:02	17:19	08:17	LINE CLEAR AVAILED
453	29-May-22	MYSURU	66	CR NAGAR-KABALLY	KABALLY_66	16:14	17:32	01:18	LINE CLEAR AVAILED
454	29-May-22	MYSURU	66	DEVNUR(N'GUD)-BANNARI1	BANNARIIPP	06:39	12:33	05:54	LINE CLEAR AVAILED
455	29-May-22	MYSURU	66	DEVNUR(N'GUD)-BANNARI2	BANNARIIPP	06:39	12:33	05:54	LINE CLEAR AVAILED
456	29-May-22	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
457	29-May-22	MYSURU	66	HANNUR-KOTHANUR	NO STATIONS EFFECTED	14:48	16:00	01:11	NFBC ISSUED
458	29-May-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
459	29-May-22	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	12:03:00 (14.5.2022)			LINE OPEN:LINE FAULT
460	29-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
461	29-May-22	MYSURU	66	HV1	COWDALLI_66	13:27	13:32	00:04	TRANSFORMER FAULT
462	29-May-22	MYSURU	66	HV1	COWDALLI_66	14:41	14:44	00:03	TRANSFORMER FAULT
463	29-May-22	MYSURU	66	HV1	DODDINDUNVADI_66	10:40	16:20	05:40	LINE CLEAR AVAILED
464	29-May-22	MYSURU	66	HV1	DODDINDUNVADI_66	10:40	16:20	05:40	LINE CLEAR AVAILED
465	29-May-22	MYSURU	66	HV1	MADHUVANAHALLI_66	09:35	13:27	03:52	LINE CLEAR AVAILED
466	29-May-22	MYSURU	66	HV2	KOLLEGALA_66	15:58	15:59	00:01	TRANSFORMER FAULT
467	29-May-22	MYSURU	66	HV2	KOLLEGALA_66	16:34	16:39	00:04	TRANSFORMER FAULT
468	29-May-22	MYSURU	66	HV2	MADHUVANAHALLI_66	13:35	15:01	01:26	LINE CLEAR AVAILED
469	29-May-22	MYSURU	66	HV2	SHEELNERE_66	06:30	06:40	00:10	TRANSFORMER FAULT
470	29-May-22	MYSURU	66	KHONALAGERE-MADDUR	NO STATIONS EFFECTED	11:10	12:33	01:23	HAND TRIPPED
471	29-May-22	MYSURU	66	KIADB SOMANAHALLI-MADDUR	SOMANAHALLI_66	09:45	13:04	03:19	LINE CLEAR AVAILED
472	29-May-22	MYSURU	66	MADHUVANAHALLI-KUNTHUR	KUNTHUR_66	09:51	13:18	03:27	LINE CLEAR AVAILED
473	29-May-22	MYSURU	66	MUGUR-JANNUR	JANNUR_66	12:10	16:45	04:35	LINE CLEAR AVAILED
474	29-May-22	MYSURU	66	MUGUR-KUNTHUR	KUNTHUR_66	09:00	17:00	08:00	NFBC ISSUED
475	29-May-22	MYSURU	220	KADAKOLA-BASTIPURA1	NO STATIONS EFFECTED	09:33	12:24	02:51	NFBC ISSUED
476	29-May-22	MYSURU	220	MADHUVANAHALLI-WARD SOLAR	NO STATIONS EFFECTED	13:35	16:00	02:25	LINE CLEAR AVAILED
477	29-May-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:28	12:38	0:10	LINE FAULT
478	29-May-22	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	19:10	19:30	0:20	LINE FAULT
479	29-May-22	TUMKUR	66	TR2	KBCROSS_220	17:10	17:41	0:31	LINE CLEAR AVAILED
1	30-May-22	BAGALKOT	110	110/11KV, HV1	KAGAWADA_110	16:35	17:29	0:54	LINE CLEAR AVAILED
2	30-May-22	BAGALKOT	110	110/11KV, HV1	CHADCHAN_110	7:20 (19.05.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
3	30-May-22	BAGALKOT	110	110/11KV, HV2	BANAHATTI_110	16:40	17:27	0:47	LINE CLEAR AVAILED
4	30-May-22	BAGALKOT	110	110/11KV, HV2	KUD DHARWAD_110	23:29	23:37	0:08	TRANSFORMER FAULT
5	30-May-22	BAGALKOT	110	110/11KV,HV1	RAIBAG_110	5:55	6:18	0:23	TRANSFORMER FAULT
6	30-May-22	BAGALKOT	110	110/11KV,HV1	RATHIHALI_110	10:40 (28.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
7	30-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
8	30-May-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
9	30-May-22	BAGALKOT	110	AMBEWADI-NK-1(HALIYAL)	HALIYAL_110	12:00	14:59	2:32	LINE FAULT
10	30-May-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVAILED
11	30-May-22	BAGALKOT	110	BELGAUM-NEHARUNAGAR	NEHARUNAGAR_110	17:20	17:25	0:05	LINE FAULT
12	30-May-22	BAGALKOT	110	BJCTV(THORVI)- BHUTANAL	THORVI_110	6:00	12:44	6:44	LINE CLEAR AVAILED
13	30-May-22	BAGALKOT	110	GHATAPRABHA220-MANTUR	MANTUR_110	18:23	18:44	0:21	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
14	30-May-22	BAGALKOT	110	HALIYAL- GMR (ALANAVAR)	HALIYAL_110	10:27	10:35	0:08	LINE FAULT
15	30-May-22	BAGALKOT	110	HALIYAL- GMR (ALANAVAR)	HALIYAL_110	17:32	17:40	0:08	LINE FAULT
16	30-May-22	BAGALKOT	110	HUKKERI- KOTWAGI LIS	HUKKERI_110	3:45	6:08	2:23	LINE FAULT
17	30-May-22	BAGALKOT	110	KD JAMBAGI-MUDHOL	MUDHOL_110	5:53	6:10	0:17	LINE FAULT
18	30-May-22	BAGALKOT	110	MANTUR-TB5	MANTUR(GHP)_110	18:43	18:54	0:11	HAND TRIPPED
19	30-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
20	30-May-22	BAGALKOT	110	RANEENNUR-BALLIGAVI	STATION NOT AFFECTED RANEENNUR_220	10:07	16:28	6:21	NFBC ISSUED
21	30-May-22	BAGALKOT	110	RANEENNUR-BYADAGI	STATION NOT AFFECTED RANEENNUR_220	11:50	13:38	1:48	LINE CLEAR AVAILED
22	30-May-22	BAGALKOT	110	SANKESHWAR-HUKKERI	STATION NOT AFFECTED SANKESHWAR_110	8:15	23:59	15:45	LINE CLEAR AVAILED
23	30-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
24	30-May-22	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	11:11	12:43	1:32	NFBC ISSUED
25	30-May-22	BAGALKOT	110	TAKKALAKI-KNS SOLAR	TAKKALAKI_110	6:00	6:05	0:05	HAND TRIPPED
26	30-May-22	BAGALKOT	110	TAKKALAKI-KNS SOLAR	TAKKALAKI_110	12:45	12:46	0:01	HAND TRIPPED
27	30-May-22	BAGALKOT	110	TAKKALAKI-THORVI	TAKKALAKI_110	6:03	6:05	0:02	LOAD CHANGE OVER
28	30-May-22	BAGALKOT	110	TAKKALAKI-THORVI	TAKKALAKI_110	12:44	12:46	0:02	LOAD CHANGE OVER
29	30-May-22	BAGALKOT	110	TAKKALAKI-TIKOTA	TAKKALAKI_110	6:03	6:04	0:01	LOAD CHANGE OVER
30	30-May-22	BAGALKOT	110	TAKKALAKI-TIKOTA	TAKKALAKI_110	12:45	12:47	0:02	LOAD CHANGE OVER
31	30-May-22	BAGALKOT	110	VAJRAMATTI220- KD JAMBAGI	KD JAMBAGI_110	6:07	6:09	0:02	LINE FAULT
32	30-May-22	BAGALKOT	220	BAGEWADI-BIJAPUR1	STATION NOT AFFECTED BAGEWADI_220	17:54 (19.05.2022)			LINE OPEN:LINE CLEAR AVAILED
33	30-May-22	BAGALKOT	220	BAGEWADI-BIJAPUR2	STATION NOT AFFECTED BAGEWADI_220	17:54 (19.05.2022)			LINE OPEN:LINE CLEAR AVAILED
34	30-May-22	BAGALKOT	220	BIDNAL- TADAS1(HIRE BENDIGERI1)	BIDNAL_220	11:31	14:49	3:18	LINE CLEAR AVAILED
35	30-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
36	30-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
37	30-May-22	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	21:17	21:31	0:14	LINE FAULT
38	30-May-22	BENGALURU	66	HV1	HAL 220	18:20	18:21	0:01	LINE CLEAR AVAILED
39	30-May-22	BENGALURU	66	HV1	YARANDANAHALLI 220	9:30	17:55	8:25	LINE CLEAR AVAILED
40	30-May-22	BENGALURU	66	HV1	MELUR	12:48	17:31	4:42	LINE CLEAR AVAILED
41	30-May-22	BENGALURU	66	HV1	HUKUNDA	21:10	21:29	0:18	TRANSFORMER FAULT
42	30-May-22	BENGALURU	66	HV1	ALUR	15:46	15:50	0:03	LINE CLEAR AVAILED
43	30-May-22	BENGALURU	66	HV2	BRIGADE METROPOLIS	9:11	9:25	0:14	TRANSFORMER FAULT
44	30-May-22	BENGALURU	66	HV2	BRIGADE METROPOLIS	12:44	12:49	0:05	LOAD CHANGE OVER
45	30-May-22	BENGALURU	66	HV2	HAL 220	18:17	18:19	0:02	LINE CLEAR AVAILED
46	30-May-22	BENGALURU	66	HV2	YARANDANAHALLI 220	18:00	19:24	1:24	LINE CLEAR AVAILED
47	30-May-22	BENGALURU	66	HV2	CB PURA URBAN	10:46	10:55	0:08	TRANSFORMER FAULT
48	30-May-22	BENGALURU	66	HV2	KUNDANA	13:39	14:53	1:13	LINE CLEAR AVAILED
49	30-May-22	BENGALURU	66	HV2	ALUR	15:46	15:50	0:03	LINE CLEAR AVAILED
50	30-May-22	BENGALURU	66	HV2	GOWRIBIDANUR 220	0:19	0:25	0:06	TRANSFORMER FAULT
51	30-May-22	BENGALURU	66	HV3	YARANDANAHALLI 220	9:30	19:27	9:57	LINE CLEAR AVAILED
52	30-May-22	BENGALURU	66	KGF - KAMASAMUDRA	KAMASAMUDRA	11:35	12:00	0:25	MAIN SUPPLY FAILURE
53	30-May-22	BENGALURU	66	LV1	MALUR 220	11:31	15:42	4:11	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
54	30-May-22	BENGALURU	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	11:30	11:35	0:05	MAIN SUPPLY FAILURE
55	30-May-22	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	5:30	5:33	0:03	LOAD CHANGE OVER
56	30-May-22	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	5:45	15:47	10:02	LOAD CHANGE OVER
57	30-May-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	18:27	18:48	0:21	LINE FAULT
58	30-May-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	19:22	19:45	0:22	LINE CLEAR AVAILED
59	30-May-22	BENGALURU	66	TEKAL - KGF	TEKAL, BUDIKOTE, TORLAKKI	15:40	15:43	0:03	LOAD CHANGE OVER
60	30-May-22	BENGALURU	220	HV1	MALUR 220	11:31	15:40	4:09	LINE CLEAR AVAILED
61	30-May-22	GULBARGA	66	HV2	PUNABGHATA_66	21:35	21:40	0:05	TRANSFORMER FAULT
62	30-May-22	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJAINI_66,BENNEHALLI_66	19:13	19:25	0:12	LINE FAULT
63	30-May-22	GULBARGA	66	PUNABGHATA-NEELAGUNDA	PUNABGHATA_66,UCCHANIDURGA_66,BILCHOD_66	21:50	21:55	0:05	LINE FAULT
64	30-May-22	GULBARGA	66	PUNABGHATA-NEELAGUNDA	PUNABGHATA_66,UCCHANIDURGA_66,BILCHOD_66	22:00	22:40	0:40	LINE FAULT
65	30-May-22	GULBARGA	110	CHICKSUGUR-APMC-RCR	CHICKSUGUR_110,SHAKTINAGAR_110,YAPPALDINNI_110	17:44	18:19	0:35	LINE FAULT
66	30-May-22	GULBARGA	110	GALAG-ALKOD	GALAG_110	10:30	11:00	0:30	MAIN SUPPLY FAILURE
67	30-May-22	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	9:28	10:15	0:47	LINE FAULT
68	30-May-22	GULBARGA	110	HUMNABAD-MANEIKHELLI	MANAIKHELLI_110	16:35	17:07	0:32	LINE FAULT
69	30-May-22	GULBARGA	110	HUMNABAD-MANEIKHELLI	MANAIKHELLI_110	17:08	17:27	0:19	LINE FAULT
70	30-May-22	GULBARGA	110	HV1	RAJESHWAR_110	18:22	18:28	0:06	TRANSFORMER FAULT
71	30-May-22	GULBARGA	110	HV1	NIRNA_110	16:45	16:50	0:05	TRANSFORMER FAULT
72	30-May-22	GULBARGA	110	HV2	KUSTAGI_220	9:27	9:33	15:14	TRANSFORMER FAULT
73	30-May-22	GULBARGA	110	HV2	CHICKSUGUR_110	11:42	13:10	1:28	TRANSFORMER FAULT
74	30-May-22	GULBARGA	110	HV3	CHICKSUGUR_110	17:44	18:20	0:36	TRANSFORMER FAULT
75	30-May-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	9:28	9:37	0:09	LINE FAULT
76	30-May-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	9:57	10:10	0:13	LINE FAULT
77	30-May-22	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGUTTI_110	1:40	3:05	1:25	LINE FAULT
78	30-May-22	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGUTTI_110	10:30	17:30	7:00	LINE FAULT
79	30-May-22	GULBARGA	110	KUSTAGI-KANAKGIRI	GANADAL_110,NAVALI_110	11:35	13:15	1:40	LINE CLEAR AVAILED
80	30-May-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110	21:48	21:53	0:05	LINE FAULT
81	30-May-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	3:56	4:06	0:10	LINE FAULT
82	30-May-22	GULBARGA	110	NANDUR-GULBARGAUNIVERSITY	NANDUR_110	13:28	13:38	0:10	MAIN SUPPLY FAILURE
83	30-May-22	GULBARGA	110	NIRNA-CHITGUPPA	NIRNA_110	16:55	17:35	0:40	MAIN SUPPLY FAILURE
84	30-May-22	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	18:05	18:20	0:15	LINE CLEAR AVAILED
85	30-May-22	GULBARGA	110	SEDAM-SHREE CEMENT_IPP	SEDAM_220	12:15 (30.05.2022)			LINE OPEN:LINE CLEAR AVAILED
86	30-May-22	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,R ENUKA_IPP,AFZALPUR_110,KARAJAGI_110	11:42	11:45	0:03	LINE CLEAR AVAILED
87	30-May-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	11:42	11:45	0:03	LINE FAULT
88	30-May-22	GULBARGA	110	SHAHABAD-FARTHABAD	FARTHABAD_110,GULBARGA SOUTH_110	16:40	17:15	0:35	LINE CLEAR AVAILED
89	30-May-22	GULBARGA	110	SHAHABAD-GULBARGA UNIVERCITY-2	GULBARGA UNIVERCITY_110,NANDUOOR_110	11:30	17:35	6:05	LINE CLEAR AVAILED
90	30-May-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNASAGI_110	4:24	4:28	0:04	LINE FAULT
91	30-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SA NNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
92	30-May-22	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	3:20	3:30	0:10	LINE CLEAR AVAILED
93	30-May-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	1:27	1:50	0:23	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
94	30-May-22	GULBARGA	220	ALIPUR-RAGALPADU	RAGALPADU_220	2:35(17.05.2022)			LINE OPEN:LINE CLEAR AVAILED
95	30-May-22	GULBARGA	220	HV1&HV2	MALLAT_220	11:35	12:00	0:25	TRANSFORMER FAULT
96	30-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
97	30-May-22	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	01:55(17.05.2022)			LINE OPEN:LINE CLEAR AVAILED
98	30-May-22	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	11:23(30.5.22)			LINE OPEN:LINE CLEAR AVAILED
99	30-May-22	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	9:30	10:02	0:32	LINE FAULT
100	30-May-22	GULBARGA	400	BTPSG-GUTTUR	GUTTUR_400	10:50	11:02	0:12	LINE FAULT
101	30-May-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN:LINE FAULT
102	30-May-22	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:10	17:55	7:45	LINE CLEAR AVAILED
103	30-May-22	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:10	17:50	7:40	LINE CLEAR AVAILED
104	30-May-22	HASSAN	66	HNPR2-CRPTN	HNPURA_220	16:33	16:51	0:18	LINE FAULT
105	30-May-22	HASSAN	66	HNPR2-MYSOR1	HNPURA_220	16:33	16:51	0:18	LINE FAULT
106	30-May-22	HASSAN	66	HNPR2-MYSOR2	HNPURA_220	16:33	16:51	0:18	LINE FAULT
107	30-May-22	HASSAN	66	HV1	HIRESAVE_66	10:30	15:25	4:55	LINE CLEAR AVAILED
108	30-May-22	HASSAN	66	HV2	HIRESAVE_66	10:30	15:25	4:55	LINE CLEAR AVAILED
109	30-May-22	HASSAN	66	SAKALE-IPCL1	SAKALESH PURA_66	11:10	17:30	6:20	LINE CLEAR AVAILED
110	30-May-22	HASSAN	66	SAKALE-IPCL2	SAKALESH PURA_66	11:10	17:10	6:00	LINE CLEAR AVAILED
111	30-May-22	HASSAN	110	ALKOLA-SAGAR	ALKOLA_110	10:30	10:45	0:15	LINE FAULT
112	30-May-22	HASSAN	110	ANANDA-SS2	ANANDAPURA_110	10:30	10:40	0:10	LINE FAULT
113	30-May-22	HASSAN	110	HGUNJE-HIRIYADKA	HEGGUNJE_220	11:30	12:26	0:56	NFBC ISSUED
114	30-May-22	HASSAN	110	HV2	HEGGUNJE_220	12:02	12:23	0:21	LINE CLEAR AVAILED
115	30-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
116	30-May-22	HASSAN	110	JOG-JST2	gen_mghe	10:30	10:50	0:20	MAIN SUPPLY FAILURE
117	30-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
118	30-May-22	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:50	13:45	2:55	LINE CLEAR AVAILED
119	30-May-22	HASSAN	110	LPH-LST4	gen_lph	10:30	10:50	0:20	LINE FAULT
120	30-May-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:05(23.05.2022)			LINE OPEN:LINE FAULT
121	30-May-22	HASSAN	110	SAGARA-IDLE	SAGARA_110	10:30	10:50	0:20	MAIN SUPPLY FAILURE
122	30-May-22	HASSAN	110	SAGARA-JST1	SAGARA_110	9:50	16:20	6:30	NFBC ISSUED
123	30-May-22	HASSAN	110	SAGARA-JST2	SAGARA_110	10:30	10:50	0:20	MAIN SUPPLY FAILURE
124	30-May-22	HASSAN	110	SAGARA-LST4	SAGARA_110	10:30	10:50	0:20	MAIN SUPPLY FAILURE
125	30-May-22	HASSAN	110	SAGARA-SAGAR	SAGARA_110	10:30	10:50	0:20	MAIN SUPPLY FAILURE
126	30-May-22	HASSAN	110	SAGARA-SORABA	SAGARA_110	10:30	10:50	0:20	MAIN SUPPLY FAILURE
127	30-May-22	HASSAN	110	SAGARA-TAL	SAGARA_110	10:30	10:50	0:20	MAIN SUPPLY FAILURE
128	30-May-22	HASSAN	110	TALAGU-SAGAR	TALAGUPPA_400	10:30	15:00	4:30	LINE FAULT
129	30-May-22	HASSAN	220	HV2	GOPALAPURA_220	8:05(25.05.2022)	16:25(31.05.2022)	144:30 hrs	TRANSFORMER CHARGED
130	30-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
131	30-May-22	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	12:19	14:29	2:10	LINE FAULT
132	30-May-22	HASSAN	220	SHRAVITY-MRSSHM	gen_sharavaty	12:19	14:29	2:10	LINE FAULT
133	30-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
134	30-May-22	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	13:15	15:25	2:10	LINE CLEAR AVAILED
135	30-May-22	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	14:50	15:25	0:35	LINE CLEAR AVAILED
136	30-May-22	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
137	30-May-22	MYSURU	66	HANAGODU-HUNSURU	NO STATIONS EFFECTED	10:50	17:30	6:40	LINE CLEAR AVAILED
138	30-May-22	MYSURU	66	HARADANAHALLY JAKKANAHALLY-LAXJEET	NO STATIONS EFFECTED	18:32	18:37	0:05	LINE FAULT
139	30-May-22	MYSURU	66	HDKOTE-TARAKA	ANTHARSANTHE_66	17:33	17:50	0:16	LINE FAULT
140	30-May-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
141	30-May-22	MYSURU	66	HEBBANI-MEGAHALAPURA	CHIDRAVALLI_66THUMBLA_66BGPURA_66GARGESH WARI_66VYASRAJPURA_66	3:07	3:20	0:13	LINE FAULT
142	30-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
143	30-May-22	MYSURU	66	HV1	HANAGODU_66	10:50	17:30	6:40	LINE CLEAR AVAILED
144	30-May-22	MYSURU	66	HV2	GUNDULPET_66	11:30	14:48	3:18	LINE CLEAR AVAILED
145	30-May-22	MYSURU	66	KADAKOLA-D K MAIDANA	NO STATIONS EFFECTED	16:34	16:39	0:05	LINE FAULT
146	30-May-22	MYSURU	66	KADAKOLA-MANDAKAKLLI	MANDAKALLI_66	16:34	16:40	0:06	LINE FAULT
147	30-May-22	MYSURU	66	KOLLEGALA-PARINAMIPURA	PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	9:20	9:25	0:05	LINE FAULT
148	30-May-22	MYSURU	66	MADHUVANAHALLI-HANNUR 1	NO STATIONS EFFECTED	15:44	15:52	0:08	LINE FAULT
149	30-May-22	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	9:32	9:37	0:05	LINE FAULT
150	30-May-22	MYSURU	66	MUGUR-THAYURU	TNARASIPURA_66THAYUR_66	18:55	19:00	0:05	LINE FAULT
151	30-May-22	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	HARADANAHALLI(JAK)_66 SHIVALLY _66BASARALU_66KESLAGERE_66	18:50	18:58	0:08	LINE FAULT
152	30-May-22	MYSURU	66	VAJAMANGALA-HEBBANI	NO STATIONS EFFECTED	18:45	18:59	0:14	LINE FAULT
153	30-May-22	MYSURU	220	MADHUVANAHALLI-HEBBANI 1	NO STATIONS EFFECTED	13:54	14:09	0:15	LINE FAULT
154	30-May-22	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	11:30	13:23	1:53	LINE CLEAR AVAILED
155	30-May-22	TUMKUR	220	BARC-1	THALLAK 220	13:33	13:57	0:24	LINE FAULT