

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM:28.01.2020 TO 03.02.2020

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	28-Jan-2020	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	6:52	6:56	0:04	LOAD CURTAILMENT
2	28-Jan-2020	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	8:17	23:59	15:42	LINE FAULT
3	28-Jan-2020	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	13:57	14:22	0:25	LINE CLEAR AVAILED
4	28-Jan-2020	BAGALKOT	110	110/11KV,HV1	ARGA_110	16:03	17:29	1:26	LINE CLEAR AVAILED
5	28-Jan-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI2	BAGALKOT_220	10:04	13:01	2:57	LINE CLEAR AVAILED
6	28-Jan-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI2	BAGALKOT_220	15:00	17:50	2:50	LINE CLEAR AVAILED
7	28-Jan-2020	BAGALKOT	220	BAGEWADI-ADPH 2	BAGEWADI_220	0:00	16:16	16:16	LINE CLEAR AVAILED
8	28-Jan-2020	BAGALKOT	220	ADPH1-BAGEWADI	BAGEWADI_220	16:45	23:59	7:14	LINE CLEAR AVAILED
9	28-Jan-2020	BAGALKOT	220	FORTUNE FIVE1-BAGEWADI	BAGEWADI_220	10:45	23:59	13:14	LINE CLEAR AVAILED
10	28-Jan-2020	BAGALKOT	110	DKSS COGEN-CHIKKODI	CHIKKODI_220	5:10	5:50	0:40	LINE FAULT
11	28-Jan-2020	BAGALKOT	110	RON1&2-GAJENDRAGAD	GAJENDRAGAD_110	6:25	6:41	0:16	HAND TRIPPED
12	28-Jan-2020	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD_110	6:29	6:37	0:08	HAND TRIPPED
13	28-Jan-2020	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD_110	13:55	23:59	10:04	LINE CLEAR AVAILED
14	28-Jan-2020	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	6:52	7:03	0:11	LOAD CURTAILMENT
15	28-Jan-2020	BAGALKOT	110	GOPANAKOPPA-NARAGUND	NARAGUND_110	7:54	13:00	5:06	LINE FAULT
16	28-Jan-2020	BAGALKOT	110	110/11KV,HV1	GUTTAL_110	9:14	9:23	0:09	TRANSFORMER FAULT
17	28-Jan-2020	BAGALKOT	110	110/33KV,HV1	HANGAL_110,PALA_33	6:52	7:07	0:15	LOAD CURTAILMENT
18	28-Jan-2020	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	11:10	18:35	7:25	LINE CLEAR AVAILED
19	28-Jan-2020	BAGALKOT	110	HIREKERUR-SHRLKP(BELLIGAVI)	BELLIGAVI_110	6:47	8:13	1:26	LINE CLEAR AVAILED
20	28-Jan-2020	BAGALKOT	110	HIREKERUR-SHRLKP(BELLIGAVI)	BELLIGAVI_110	9:47	10:32	0:45	HAND TRIPPED
21	28-Jan-2020	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR2	VAJRAMATTI_220	7:03	8:19	1:16	LINE FAULT
22	28-Jan-2020	BAGALKOT	110	NAREGAL-RON	RON_110	6:05	13:35	7:30	LINE FAULT
23	28-Jan-2020	BAGALKOT	110	GAJENDRAGHAD1&2-RON	RON_110	13:23	13:55	0:32	LINE CLEAR AVAILED
24	28-Jan-2020	BAGALKOT	110	GAMESH-RON	RON_110	13:40	13:48	0:08	HAND TRIPPED
25	28-Jan-2020	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	4:24	16:06	11:42	LINE FAULT
26	28-Jan-2020	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	16:11	16:19	0:08	HAND TRIPPED
27	28-Jan-2020	BAGALKOT	220	BALLIGAVI(SHIROLAKOPPA)-RANEBENNUR	RANEBENNUR_220	6:42	6:48	0:06	HAND TRIPPED
28	28-Jan-2020	BAGALKOT	220	GUTTUR-RANEBENNUR	RANEBENNUR_220	12:30	13:12	0:42	HAND TRIPPED
29	28-Jan-2020	BAGALKOT	220	BALLIGAVI(SHIROLAKOPPA)-RANEBENNUR	RANEBENNUR_220	13:10	23:59	10:49	LINE CLEAR AVAILED
30	28-Jan-2020	BAGALKOT	110	RANEBENNUR-HIREKERUR	HIREKERUR_110	8:20	8:54	0:34	HAND TRIPPED
31	28-Jan-2020	BAGALKOT	110	RANEBENNUR-BYADAGI	BYADAGI_110	10:45	10:50	0:05	LINE FAULT
32	28-Jan-2020	BAGALKOT	110	110/11KV,HV2	PH COMPOUND_110	10:49	17:41	6:52	LINE CLEAR AVAILED
33	28-Jan-2020	BAGALKOT	220	220/110KV,HV1,LV1	KUDACHI_220	8:17	9:08	0:51	TRANSFORMER FAULT
34	28-Jan-2020	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	15:40	17:31	1:51	LINE CLEAR AVAILED
35	28-Jan-2020	BAGALKOT	110	110/33KV,HV2	HUBLI_220	13:16	16:28	3:12	LINE CLEAR AVAILED
36	28-Jan-2020	BAGALKOT	110	110/33KV,HV1	HUBLI_220	10:31	13:03	2:32	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
37	28-Jan-2020	BAGALKOT	110	110/11KV,HV3	HUBLI_220	10:48	11:51	1:03	LINE CLEAR AVAILED
38	28-Jan-2020	BAGALKOT	110	CHIKKODI220-RAIBAG1	RAIBAG_110	6:03	6:45	0:42	LINE FAULT
39	28-Jan-2020	BAGALKOT	110	CHIKKODI220-RAIBAG2	RAIBAG_110	6:48	7:12	0:24	HAND TRIPPED
40	28-Jan-2020	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	10:01	10:09	0:08	LOAD CHANGEOVER
41	28-Jan-2020	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	16:25	16:30	0:05	LOAD CHANGEOVER
42	28-Jan-2020	BENGALURU	66	VOLVO	HV2	18:05	18:40	0:35	LINE FAULT
43	28-Jan-2020	BENGALURU	66	VICTORIA - A STATION 220	VICTORIA	10:03	10:08	0:05	LOAD CHANGEOVER
44	28-Jan-2020	BENGALURU	66	VICTORIA - NRS RAJAJINAGAR 220	VICTORIA	17:04	17:13	0:09	LOAD CHANGEOVER
45	28-Jan-2020	BENGALURU	66	SIDDALAGHATTA - CHINTAMANI 220	SIDDALAGHATTA, MELUR	15:10	15:16	0:06	LINE FAULT
46	28-Jan-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	13:15	15:43	2:28	LINE CLEAR AVAILED
47	28-Jan-2020	BENGALURU	66	YELAHANKA 220 - RAJANKUNTE	RAJANKUNTE	8:58	9:55	0:57	LINE FAULT
48	28-Jan-2020	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	11:05	11:10	0:05	LOAD CHANGEOVER
49	28-Jan-2020	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	10:00	14:00	4:00	LINE CLEAR AVAILED
50	28-Jan-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	HOSKOTE 220	10:00	16:00	6:00	LINE CLEAR AVAILED
51	28-Jan-2020	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	10:00	14:00	4:00	LINE CLEAR AVAILED
52	28-Jan-2020	BENGALURU	66	BEGUR 220 - BIAL 1 (EHT)	BIAL (EHT)	10:00	14:00	4:00	LINE CLEAR AVAILED
53	28-Jan-2020	BENGALURU	66	BEGUR 220 - BIAL 2 (EHT)	BIAL (EHT)	10:00	14:00	4:00	LINE CLEAR AVAILED
54	28-Jan-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	9:28	9:38	0:10	LINE FAULT
55	28-Jan-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	13:34	14:03	0:29	LINE CLEAR AVAILED
56	28-Jan-2020	BENGALURU	66	CHINTAMANI 220 - SRINIVASAPURA	SRINIVASAPURA, KODIHALLI	13:34	14:03	0:29	LINE CLEAR AVAILED
57	28-Jan-2020	BENGALURU	66	HV2	C STATION	10:07	10:12	0:05	LOAD CHANGEOVER
58	28-Jan-2020	BENGALURU	66	HV2	C STATION	16:38	16:41	0:03	LOAD CHANGEOVER
59	28-Jan-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	10:00	16:16	6:16	LINE CLEAR AVAILED
60	28-Jan-2020	BENGALURU	66	HOSKOTE 220 - PILAGUMPA	PILAGUMPA	10:00	17:00	7:00	LINE CLEAR AVAILED
61	28-Jan-2020	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	10:00	16:33	6:33	LINE CLEAR AVAILED
62	28-Jan-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	10:00	16:34	6:34	LINE CLEAR AVAILED
63	28-Jan-2020	BENGALURU	220	HOSKOTE 220 - BEGUR 220	HOSKOTE 220	10:00	16:04	6:04	LINE CLEAR AVAILED
64	28-Jan-2020	BENGALURU	66	HV2	HOSUR RAMAPURA	10:30	12:10	1:40	LINE CLEAR AVAILED
65	28-Jan-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	10:28	10:37	0:09	LINE CLEAR AVAILED
66	28-Jan-2020	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	7:20	8:01	0:41	LOAD CURTAILMENT
67	28-Jan-2020	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	7:20	8:00	0:40	LOAD CURTAILMENT
68	28-Jan-2020	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	18:30	18:34	0:04	LINE FAULT
69	28-Jan-2020	BENGALURU	66	HV1	CHIKKABALLAPURA IND AREA	10:00	17:24	7:24	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
70	28-Jan-2020	GULBARGA	220	SEDAM-HUMNABAD2	SEDAM_220	10:26	11:30	1:04	LINE CLEAR AVAILED
71	28-Jan-2020	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	15:13	17:04	1:51	NFBC ISSUED
72	28-Jan-2020	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	17:15	18:20	1:05	NFBC ISSUED
73	28-Jan-2020	GULBARGA	110	HV3	ALAND_110	6:50	7:20	0:30	LOAD CURTAILMENT
74	28-Jan-2020	GULBARGA	110	HV3	HANUMSAGAR_110	6:50	6:55	0:05	LOAD CURTAILMENT
75	28-Jan-2020	GULBARGA	110	HV2	JEWARGI_110	6:55	7:00	0:05	TRANSFORMER FAULT
76	28-Jan-2020	GULBARGA	110	HV1	MAHAGAON_110	6:50	7:15	0:25	LOAD CURTAILMENT
77	28-Jan-2020	GULBARGA	110	HV1	PDHALLI_110	6:50	6:55	0:05	LOAD CURTAILMENT
78	28-Jan-2020	GULBARGA	110	HV1	SIRWAR_110	6:50	7:00	0:10	LOAD CURTAILMENT
79	28-Jan-2020	GULBARGA	110	HV1,HV2,HV3	TEKKALKOTE_110	11:30	13:10	1:40	LINE CLEAR AVAILED
80	28-Jan-2020	GULBARGA	110	HV3	YELBURGA_110	6:52	7:12	0:20	LOAD CURTAILMENT
81	28-Jan-2020	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	8:05	8:25	0:20	LINE FAULT
82	28-Jan-2020	GULBARGA	110	SHAHAPUR-KBJNL	SHAHAPUR_220	0:58	1:03	0:05	LINE FAULT
83	28-Jan-2020	GULBARGA	66	HV1	HANASI_66	8:25	9:20	0:55	TRANSFORMER FAULT
84	28-Jan-2020	GULBARGA	66	HV1	HANASI_66	9:40	10:11	0:31	TRANSFORMER FAULT
85	28-Jan-2020	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	8:59	9:20	0:21	LINE CLEAR AVAILED
86	28-Jan-2020	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	9:50	10:11	0:21	LINE CLEAR AVAILED
87	28-Jan-2020	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110,MASKI_110,KAVITHAL_110, SOMANAMARDI_IPP,GAMESHA_IPP	10:40	14:40	4:00	LINE CLEAR AVAILED
88	28-Jan-2020	GULBARGA	110	RAICHUR-MATMARI	MATMARI_110	7:00	7:30	0:30	LOAD CURTAILMENT
89	28-Jan-2020	GULBARGA	110	MALLAT-BYAGAWAT2	MASLAPUR_110,MANVI_110	2:10	2:15	0:05	LINE FAULT
90	28-Jan-2020	GULBARGA	110	MALLAT-BYAGAWAT2	MASLAPUR_110,MANVI_110	5:01	5:03	0:02	LINE FAULT
91	28-Jan-2020	GULBARGA	110	MALLAT-BYAGAWAT2	MASLAPUR_110,MANVI_110	5:41	5:44	0:03	LINE FAULT
92	28-Jan-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_IPP	23:03	23:10	0:07	LINE FAULT
93	28-Jan-2020	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGOAN_110, DIGGI_110	8:05	8:25	0:20	LINE FAULT
94	28-Jan-2020	HASSAN	220	SHARAVTY-SHIRALKOPPA	sharavathy_gen	0:03	12:25	12:22	LINE FAULT
95	28-Jan-2020	HASSAN	220	HV1	SHIRALKOPPA_220	0:00	17:20	17:20	LINE CLEAR AVAILED
96	28-Jan-2020	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	0:05	12:25	12:20	MAIN SUPPLY FAILURE
97	28-Jan-2020	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	0:05	1:40	1:35	MAIN SUPPLY FAILURE
98	28-Jan-2020	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	7:00	8:00	1:00	HAND TRIPPED
99	28-Jan-2020	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	17:39	17:43	0:04	HAND TRIPPED
100	28-Jan-2020	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	0:05	1:40	1:35	MAIN SUPPLY FAILURE
101	28-Jan-2020	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	7:00	7:30	0:30	HAND TRIPPED
102	28-Jan-2020	HASSAN	110	LV1	SHIRALKOPPA_220	0:00	17:20	17:20	LINE CLEAR AVAILED
103	28-Jan-2020	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	6:40	7:30	0:50	HAND TRIPPED
104	28-Jan-2020	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	17:26	17:33	0:07	HAND TRIPPED
105	28-Jan-2020	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	6:40	7:20	0:40	HAND TRIPPED
106	28-Jan-2020	HASSAN	110	HV1	NITTUR_110	10:05	14:55	4:50	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
107	28-Jan-2020	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	11:46	13:40	1:54	MAIN SUPPLY FAILURE
108	28-Jan-2020	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	9:11	17:18	8:07	LINE CLEAR AVAILED
109	28-Jan-2020	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	9:11	17:42	8:31	LINE CLEAR AVAILED
110	28-Jan-2020	HASSAN	110	HV1	HALADY_110	9:12	17:20	8:08	LINE CLEAR AVAILED
111	28-Jan-2020	HASSAN	110	HV2	HALADY_110	9:12	17:21	8:09	LINE CLEAR AVAILED
112	28-Jan-2020	HASSAN	110	NAVATI-BARNGI	ANAVATI	17:40	17:45	0:05	MAIN SUPPLY FAILURE
113	28-Jan-2020	HASSAN	110	HV2	GANDSI_110	6:51	7:02	0:11	LOAD CURTAILMENT
114	28-Jan-2020	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	9:11	17:16	8:05	LINE CLEAR AVAILED
115	28-Jan-2020	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	10:02	14:40	4:38	LINE CLEAR AVAILED
116	28-Jan-2020	HASSAN	110	HV1	JAVAGAL_110	6:52	7:06	0:14	LOAD CURTAILMENT
117	28-Jan-2020	HASSAN	110	KADUR-NGNHL	KADUR_220	7:22	8:02	0:40	LOAD CURTAILMENT
118	28-Jan-2020	HASSAN	110	KEMAR-Manipal1	KEMAR_220	13:11	16:08	2:57	NFBC ISSUED
119	28-Jan-2020	HASSAN	110	KEMR-Manipal2	KEMAR_220	10:16	12:52	2:36	NFBC ISSUED
120	28-Jan-2020	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	10:10	12:55	2:45	LINE CLEAR AVAILED
121	28-Jan-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	10:23	11:30	1:07	LINE CLEAR AVAILED
122	28-Jan-2020	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	16:29	16:36	0:07	LINE CLEAR AVAILED
123	28-Jan-2020	HASSAN	110	HV2	SORABA_110	15:29	16:56	1:27	TRANSFORMER FAULT
124	28-Jan-2020	HASSAN	110	HV2	SORABA_110	16:56	23:08	6:12	TRANSFORMER FAULT
125	28-Jan-2020	HASSAN	66	HV1	HANGARANAHALLY_66	13:39	14:18	0:39	LINE CLEAR AVAILED
126	28-Jan-2020	HASSAN	66	HNPUA-RAMNATHPURA	HNPUA_66	10:55	16:13	5:18	LINE CLEAR AVAILED
127	28-Jan-2020	HASSAN	66	HNPUA-RAMNATHPURA	HNPUA_66	16:52	20:23	3:31	LINE CLEAR AVAILED
128	28-Jan-2020	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	10:30	11:00	0:30	LINE CLEAR AVAILED
129	28-Jan-2020	HASSAN	66	HV2	UDAYAPURA_66	10:12	10:19	0:07	TRANSFORMER FAULT
130	28-Jan-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	6:51	7:05	0:14	LOAD CURTAILMENT
131	28-Jan-2020	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	10:31	11:06	0:35	LINE CLEAR AVAILED
132	28-Jan-2020	MYSORE	66	HV2	BILIKERE_66	11:31	11:38	0:07	TRANSFORMER FAULT
133	28-Jan-2020	MYSORE	66	HV1	COWDALLI_66	9:02	14:00	4:57	LINE CLEAR AVAILED
134	28-Jan-2020	MYSORE	66	HV1	COWDALLI_66	19:20	19:30	0:10	LINE CLEAR AVAILED
135	28-Jan-2020	MYSORE	66	HV2	COWDALLI_66	13:41	19:35	5:54	LINE CLEAR AVAILED
136	28-Jan-2020	MYSORE	66	HV1	DODDINADUVADI_66	11:14	11:55	0:40	LINE CLEAR AVAILED
137	28-Jan-2020	MYSORE	66	HV2	DODDINADUVADI_66	11:14	11:55	0:40	LINE CLEAR AVAILED
138	28-Jan-2020	MYSORE	66	HV1	DODDARAYAPET_66	16:05	20:25	4:20	LINE CLEAR AVAILED
139	28-Jan-2020	MYSORE	66	HV2	KOLLEGALA_66	9:29	11:30	2:01	LINE CLEAR AVAILED
140	28-Jan-2020	MYSORE	66	KUSHALNAGARA 220-MYSORE-1	MIRLE_66	4:00	4:12	0:11	LINE FAULT
141	28-Jan-2020	MYSORE	66	KUSHALNAGARA 220-MYSORE-1	BHERYA_66 BILIKERE_66 DMG_HALLI_66 GVGUDI_66 KRNAGARA_66 MIRLE_66	10:57	11:18	0:20	LINE FAULT
142	28-Jan-2020	MYSORE	66	KUSHALNAGARA 220-MYSORE-1	BHERYA_66 BILIKERE_66 DMG_HALLI_66 GVGUDI_66 KRNAGARA_66 MIRLE_66	14:58	15:09	0:11	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
143	28-Jan-2020	MYSORE	66	HV1	RKNAGARA_66	11:48	13:45	1:56	LINE CLEAR AVAILED
144	28-Jan-2020	TUMKUR	220	TR-1(HV SIDE)	HONNALLI_220	15:37	15:47	0:09	HAND TRIPPED
145	28-Jan-2020	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	16:42	17:46	1:04	LINE CLEAR AVAILED
146	28-Jan-2020	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	9:05	15:06	6:00	LINE FAULT
147	28-Jan-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	1:25	2:10	0:44	LINE FAULT
148	28-Jan-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	0:34	0:43	0:08	LINE FAULT
149	28-Jan-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	0:34	0:42	0:08	LINE FAULT
150	28-Jan-2020	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	18:59	20:01	1:02	LINE CLEAR AVAILED
151	28-Jan-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	17:02	18:58	1:55	LINE CLEAR AVAILED
152	28-Jan-2020	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	16:52	19:14	2:22	LINE CLEAR AVAILED
153	28-Jan-2020	TUMKUR	66	HIRIYURkV 220kV- SUZLON 2	SUZLON1_IPP_66	19:43	19:44	0:00	HAND TRIPPED
154	28-Jan-2020	TUMKUR	66	TR-1	HONNALLI_220	15:35	15:56	0:20	LINE CLEAR AVAILED
155	28-Jan-2020	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	14:47	15:02	0:14	LINE CLEAR AVAILED
156	28-Jan-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:34	15:56	0:22	HAND TRIPPED
157	28-Jan-2020	TUMKUR	66	TR-1(LV SIDE)	HONNALLI_220	15:27	15:53	0:26	LINE CLEAR AVAILED
158	28-Jan-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	15:35	15:58	0:22	HAND TRIPPED
159	28-Jan-2020	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	14:58	15:13	0:14	LINE CLEAR AVAILED
160	28-Jan-2020	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	18:12	18:17	0:04	HAND TRIPPED
161	28-Jan-2020	TUMKUR	66	SAVALANGA 66kV-HNLI220_NYMT	SAVALANGA_66	11:21	11:27	0:06	MAIN SUPPLY FAILURE
162	28-Jan-2020	TUMKUR	66	TR-1	SAVALANGA_66	11:21	11:22	0:01	MAIN SUPPLY FAILURE
163	28-Jan-2020	TUMKUR	66	TR-2	TAVAREKERE(C)_66	15:56	16:00	0:03	TRANSFORMER FAULT
164	29-Jan-2020	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	0:00	14:28	14:28	LINE CLEAR AVAILED
165	29-Jan-2020	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,SEABIRD_33,MASTIGATT A_33	10:30	11:09	0:39	LINE CLEAR AVAILED
166	29-Jan-2020	BAGALKOT	110	BAGALKOT220-KERUR	KERUR_110	11:07	11:30	0:23	LINE FAULT
167	29-Jan-2020	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	6:49	6:58	0:09	LOAD CURTAILMENT
168	29-Jan-2020	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	6:48	6:59	0:11	LOAD CURTAILMENT
169	29-Jan-2020	BAGALKOT	110	110/11KV,HV2	TODALBAGI_110	17:05	17:20	0:15	HAND TRIPPED
170	29-Jan-2020	BAGALKOT	110	JAMKAHANDI SUGARS-TODALBAGI	TODALBAGI_110	0:30	1:24	0:54	LINE FAULT
171	29-Jan-2020	BAGALKOT	110	110/11KV,HV4	HUBLI_220	10:06	11:50	1:44	LINE CLEAR AVAILED
172	29-Jan-2020	BAGALKOT	110	RANEENNUR-RATTIHALI	RATTIHALI_110	1:20	1:35	0:15	LINE FAULT
173	29-Jan-2020	BAGALKOT	110	RANEENNUR-RATTIHALI	RATTIHALI_110	2:33	2:45	0:12	LINE FAULT
174	29-Jan-2020	BAGALKOT	110	RANEENNUR-HIREKERUR	HIREKERUR_110	16:10	23:59	7:49	LINE CLEAR AVAILED
175	29-Jan-2020	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110	18:15	23:59	5:44	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
176	29-Jan-2020	BAGALKOT	220	SIRSI-HUBLI	SIRSI_220	11:33	14:19	2:46	LINE CLEAR AVAILED
177	29-Jan-2020	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	16:35	17:15	0:40	MAIN SUPPLY FAILURE
178	29-Jan-2020	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA, ADUGODI	16:35	17:15	0:40	MAIN SUPPLY FAILURE
179	29-Jan-2020	BENGALURU	220	NIMHANS 220 - EDC 220	NIMHANS 220	16:35	17:15	0:40	MAIN SUPPLY FAILURE
180	29-Jan-2020	BENGALURU	220	HV1	NIMHANS 220	16:35	17:15	0:40	MAIN SUPPLY FAILURE
181	29-Jan-2020	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	16:35	16:45	0:10	MAIN SUPPLY FAILURE
182	29-Jan-2020	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	16:35	16:45	0:10	MAIN SUPPLY FAILURE
183	29-Jan-2020	BENGALURU	66	EDC 220 - B STATION	B STATION	16:35	17:09	0:34	MAIN SUPPLY FAILURE
184	29-Jan-2020	BENGALURU	66	EDC 220 - BMTC	BMTC	16:35	17:14	0:39	MAIN SUPPLY FAILURE
185	29-Jan-2020	BENGALURU	220	HV1	EDC 220	16:35	17:01	0:26	MAIN SUPPLY FAILURE
186	29-Jan-2020	BENGALURU	220	HV2	EDC 220	16:35	17:01	0:26	MAIN SUPPLY FAILURE
187	29-Jan-2020	BENGALURU	66	HV1	EDC 220	16:35	17:10	0:35	MAIN SUPPLY FAILURE
188	29-Jan-2020	BENGALURU	66	HV2	EDC 220	16:35	17:10	0:35	MAIN SUPPLY FAILURE
189	29-Jan-2020	BENGALURU	66	HV1	TELECOM LAYOUT	11:00	11:07	0:07	LINE CLEAR AVAILED
190	29-Jan-2020	BENGALURU	220	HOODY 400 - HSR LAYOUT 220	KORMAMNGALA 220	13:45	13:56	0:11	LINE FAULT
191	29-Jan-2020	BENGALURU	220	HOODY 400 - HAL 1	HAL 220, EDC 220	16:35	18:44	2:09	LINE FAULT
192	29-Jan-2020	BENGALURU	220	HOODY 400 - HAL 2	HAL 220, EDC 220	16:35	16:49	0:14	LINE FAULT
193	29-Jan-2020	BENGALURU	66	KORMANGALA 220 - ADUGODI	ADUGODI, BOSCH (EHT)	13:45	14:00	0:15	MAIN SUPPLY FAILURE
194	29-Jan-2020	BENGALURU	66	KORMANGALA 220 - AMARJYOTHI	AMARJYOTHI	13:45	13:56	0:11	MAIN SUPPLY FAILURE
195	29-Jan-2020	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	13:45	14:00	0:15	MAIN SUPPLY FAILURE
196	29-Jan-2020	BENGALURU	66	KORMANGALA 220 - AUSTIN TOWN	AUSTIN TOWN	13:45	14:00	0:15	MAIN SUPPLY FAILURE
197	29-Jan-2020	BENGALURU	66	GOLF LINKS - AMARJYOTHI	GOLF LINKS	21:45	21:50	0:05	LOAD CHANGEOVER
198	29-Jan-2020	BENGALURU	66	GOLF LINKS - HAL 2	GOLF LINKS	17:50	17:55	0:05	LOAD CHANGEOVER
199	29-Jan-2020	BENGALURU	66	HV3	ADUGODI	17:30	17:36	0:06	LOAD CHANGEOVER
200	29-Jan-2020	BENGALURU	66	HV3	ELECTRONIC CITY	18:02	19:20	1:18	LINE CLEAR AVAILED
201	29-Jan-2020	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI	16:35	16:53	0:18	MAIN SUPPLY FAILURE
202	29-Jan-2020	BENGALURU	66	GOLF LINKS - HAL 2	GOLF LINKS	16:35	17:05	0:30	MAIN SUPPLY FAILURE
203	29-Jan-2020	BENGALURU	66	HV1	AMARJYOTHI	13:45	13:53	0:08	MAIN SUPPLY FAILURE
204	29-Jan-2020	BENGALURU	220	HSR LAYOUT 220 - HOODY 220	HSR LAYOUT 220	13:46	15:03	1:17	LINE FAULT
205	29-Jan-2020	BENGALURU	220	HSR LAYOUT 220 - EPIP 220	HSR LAYOUT 220	13:46	13:56	0:10	LINE FAULT
206	29-Jan-2020	BENGALURU	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	16:35	16:55	0:20	MAIN SUPPLY FAILURE
207	29-Jan-2020	BENGALURU	66	HAL 220 - HAL (EHT)	HAL (EHT)	16:35	16:55	0:20	MAIN SUPPLY FAILURE
208	29-Jan-2020	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK (EHT)	16:35	16:55	0:20	MAIN SUPPLY FAILURE
209	29-Jan-2020	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	16:35	16:55	0:20	MAIN SUPPLY FAILURE
210	29-Jan-2020	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	16:35	16:55	0:20	MAIN SUPPLY FAILURE
211	29-Jan-2020	BENGALURU	66	HAL 220 - BMRCL (EHT)	BMRCL (EHT)	16:35	16:55	0:20	MAIN SUPPLY FAILURE
212	29-Jan-2020	BENGALURU	220	HAL 220 - HOODY 1	HAL 220	16:35	16:52	0:17	LINE FAULT
213	29-Jan-2020	BENGALURU	220	HAL 220 - HOODY 2	HAL 220	16:35	16:52	0:17	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
214	29-Jan-2020	BENGALURU	66	MALUR 220 - MASTHI	MASTHI, LAKKUR, DEVANGONDHI	0:02	0:05	0:02	LINE FAULT
215	29-Jan-2020	BENGALURU	66	MALUR 220 - MASTHI	MASTHI, LAKKUR, DEVANGONDHI	7:14	7:45	0:31	LOAD CURTAILMENT
216	29-Jan-2020	BENGALURU	66	MALUR 220 - MASTHI	MASTHI, LAKKUR, DEVANGONDHI	10:08	10:14	0:06	LINE FAULT
217	29-Jan-2020	BENGALURU	66	MALUR 220 - MASTHI	MASTHI, LAKKUR, DEVANGONDHI	18:24	18:29	0:05	LINE FAULT
218	29-Jan-2020	BENGALURU	66	MALUR 220 - MASTHI	MASTHI, LAKKUR, DEVANGONDHI	19:03	19:09	0:06	LINE FAULT
219	29-Jan-2020	BENGALURU	66	KOLAR 220 - TYALUR	TYALUR	7:15	7:40	0:25	LOAD CURTAILMENT
220	29-Jan-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL,KYALANUR	22:15	22:47	0:31	LOAD CURTAILMENT
221	29-Jan-2020	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	22:15	23:26	1:11	LOAD CURTAILMENT
222	29-Jan-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL(EHT), SUGUTUR, SM MANGALA	22:47	23:25	0:38	LOAD CURTAILMENT
223	29-Jan-2020	BENGALURU	66	PADMANABANAGAR - NIMHAS 220	PADMANABANAGARA	16:35	16:52	0:17	MAIN SUPPLY FAILURE
224	29-Jan-2020	BENGALURU	66	PADMANABANAGAR - SUBRAMANYAPURA 220	PADMANABANAGARA	21:21	21:28	0:06	LOAD CHANGEOVER
225	29-Jan-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	18:33	18:39	0:06	LINE FAULT
226	29-Jan-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	11:55	14:23	2:28	LINE CLEAR AVAILED
227	29-Jan-2020	BENGALURU	66	NRS 220 - MYSORE ROAD 2	VIJAYNAGAR	7:29	10:04	2:35	LINE FAULT
228	29-Jan-2020	BENGALURU	66	HV1	VIJAYNAGAR	17:10	17:28	0:18	LOAD CHANGEOVER
229	29-Jan-2020	BENGALURU	66	DB PURA 220 - DG2	DODDABELAVANGALA, GUNDAMGERE	10:54	11:00	0:06	LINE FAULT
230	29-Jan-2020	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	DODDABELAVANGALA, GUNDAMGERE	7:29	8:02	0:33	LOAD CURTAILMENT
231	29-Jan-2020	GULBARGA	110	MUNIRABAD-SIDHANOOR1	VENKATGIRI_110,GANGAVATHI_110,SR INAGAR_110,KARTAGI_110	0:05	0:25	0:20	LINE FAULT
232	29-Jan-2020	GULBARGA	110	MUNIRABAD-SIDHANOOR1	VENKATGIRI_110,GANGAVATHI_110,SR INAGAR_110,KARTAGI_110	0:48	0:55	0:07	LINE FAULT
233	29-Jan-2020	GULBARGA	110	MUNIRABAD-SIDHANOOR1	VENKATGIRI_110,GANGAVATHI_110,SR INAGAR_110,KARTAGI_110	3:38	3:50	0:12	LINE FAULT
234	29-Jan-2020	GULBARGA	220	ITTAGI-NEELGUNDA	NEELGUNDA_220	13:30	15:55	2:25	LINE FAULT
235	29-Jan-2020	GULBARGA	220	ITTAGI-NEELGUNDA	NEELGUNDA_220	15:55	17:35	1:40	LINE CLEAR AVAILED
236	29-Jan-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	17:40	18:25	0:45	HAND TRIPPED
237	29-Jan-2020	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	9:45	12:18	2:33	LINE CLEAR AVAILED
238	29-Jan-2020	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	12:25	13:20	0:55	LINE CLEAR AVAILED
239	29-Jan-2020	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	13:23	14:06	0:43	LINE CLEAR AVAILED
240	29-Jan-2020	HASSAN	220	SSGRAVITY-SHIMOGA3	sharavathy_gen	10:14	18:16	8:02	NFBC ISSUED
241	29-Jan-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	14:10	14:20	0:10	LINE FAULT
242	29-Jan-2020	HASSAN	220	HV1	ANAVATTI_110	14:10	14:20	0:10	TRANSFORMER FAULT
243	29-Jan-2020	HASSAN	110	HV1	HALADY_110	6:48	7:08	0:20	TRANSFORMER FAULT
244	29-Jan-2020	HASSAN	110	HV1	MOODABIDRE_110	9:35	10:25	0:50	HAND TRIPPED
245	29-Jan-2020	HASSAN	110	HV1	MOODABIDRE_110	10:38	10:49	0:11	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
246	29-Jan-2020	HASSAN	66	HV1	UDAYAPURA_66	15:00	18:40	3:40	LINE CLEAR AVAILED
247	29-Jan-2020	HASSAN	66	HV2	UDAYAPURA_66	11:00	15:00	4:00	LINE CLEAR AVAILED
248	29-Jan-2020	MYSORE	66	BASARALU-MANDYA	BASARALU_66	10:00	13:35	3:35	LINE CLEAR AVAILED
249	29-Jan-2020	MYSORE	66	HV1	CHINAKURALI_66	13:05	14:03	0:58	LINE CLEAR AVAILED
250	29-Jan-2020	MYSORE	66	KUSHALNAGARA-MYSORE-1	BHERYA_66 BILIKERE_66 DMG_HALLI_66 GVGUDI_66 KRNAGARA_66 MIRLE_66	7:26	7:49	0:23	LOAD CURTAILMENT
251	29-Jan-2020	MYSORE	66	KUSHALNAGARA-MYSORE-2	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66 CHUNCHUNKATTE_66	7:26	7:49	0:23	LOAD CURTAILMENT
252	29-Jan-2020	MYSORE	66	HV1	PANDAVAPURA_66	6:47	8:02	1:14	LOAD CURTAILMENT
253	29-Jan-2020	MYSORE	66	HV2	PONNAMPET_66	6:47	7:00	0:13	LOAD CURTAILMENT
254	29-Jan-2020	MYSORE	66	VAJAMANGALA-JYOTHINAGARA	FTS_66 JYOTHINAGARA_66 BANNIMANTAP_66	8:03	8:13	0:10	LINE FAULT
255	29-Jan-2020	TUMKUR	220	TR-1	HIRIYUR_220	14:01	14:13	0:12	LINE CLEAR AVAILED
256	29-Jan-2020	TUMKUR	110	TR-1	BANDIHALLI_110	11:06	11:50	0:43	LINE CLEAR AVAILED
257	29-Jan-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	14:17	14:22	0:04	TRANSFORMER FAULT
258	29-Jan-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	8:28	8:32	0:03	LINE FAULT
259	29-Jan-2020	TUMKUR	66	TR-2	HIREHALLY_66	8:41	8:46	0:05	TRANSFORMER FAULT
260	29-Jan-2020	TUMKUR	66	TR-1	HIREMALLANAHOLE_66	8:39	8:44	0:04	TRANSFORMER FAULT
261	29-Jan-2020	TUMKUR	66	SAVALANGA 66KV-HNLI220_NYMT	SAVALANGA_66	10:03	15:35	5:31	LINE CLEAR AVAILED
262	29-Jan-2020	TUMKUR	66	TR-1	TR-1	10:03	15:35	5:31	LINE CLEAR AVAILED
263	29-Jan-2020	TUMKUR	66	TR-2	TAVAREKERE(C)_66	0:02	0:03	0:01	TRANSFORMER FAULT
264	30-Jan-2020	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	7:00	7:06	0:06	LOAD CURTAILMENT
265	30-Jan-2020	BAGALKOT	110	BAGALKOT220-KERUR	KERUR_110	7:32	7:53	0:21	LOAD CURTAILMENT
266	30-Jan-2020	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	7:18	7:30	0:12	LINE FAULT
267	30-Jan-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI2	BAGALKOT_220	8:26	23:59	15:33	LINE CLEAR AVAILED
268	30-Jan-2020	BAGALKOT	220	ADPH1-BAGEWADI	BAGEWADI_220	0:00	18:07	18:07	LINE CLEAR AVAILED
269	30-Jan-2020	BAGALKOT	220	ADPH2-BAGEWADI	BAGEWADI_220	14:28	18:07	3:39	LINE CLEAR AVAILED
270	30-Jan-2020	BAGALKOT	110	110/11KV,HV2	GOPANAKOPPA_110	11:56	18:01	6:05	LINE CLEAR AVAILED
271	30-Jan-2020	BAGALKOT	110	110/33KV,HV1	HANGAL_110,PALA_33	7:00	7:56	0:56	LOAD CURTAILMENT
272	30-Jan-2020	BAGALKOT	110	MY FAIR SOLAR-HIREHAL	HIREHAL_110	8:06	8:29	0:23	HAND TRIPPED
273	30-Jan-2020	BAGALKOT	110	VISHWANATH SUGARS-HUKKERI	HUKKERI_110	7:25	7:43	0:18	LINE FAULT
274	30-Jan-2020	BAGALKOT	110	HUBLI220-TARIHAL2	TARIHAL_110	10:36	12:49	2:13	LINE CLEAR AVAILED
275	30-Jan-2020	BAGALKOT	110	TADASINAKOPPA-TARIHAL	TARIHAL_110	12:52	23:59	11:07	LINE CLEAR AVAILED
276	30-Jan-2020	BAGALKOT	110	110/11KV,HV2	SHIROL_110	12:06	13:34	1:28	LINE CLEAR AVAILED
277	30-Jan-2020	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	7:31	7:38	0:07	HAND TRIPPED
278	30-Jan-2020	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	15:24	16:08	0:44	LINE CLEAR AVAILED
279	30-Jan-2020	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	9:40	16:43	7:03	LINE CLEAR AVAILED
280	30-Jan-2020	BAGALKOT	110	110/11KV,HV2	PG HUNSHYAL_110	14:48	16:08	1:20	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
281	30-Jan-2020	BAGALKOT	220	NARENDRA-BELGAUM1	NERENDRA_220	20:38	23:59	3:21	LINE FAULT
282	30-Jan-2020	BAGALKOT	110	MK HUBLI-KITTUR	KITTUR_110	13:23	16:12	2:49	LINE CLEAR AVAILED
283	30-Jan-2020	BAGALKOT	110	110/11KV,HV2	KULIGOD_110	12:06	13:15	1:09	LINE CLEAR AVAILED
284	30-Jan-2020	BAGALKOT	110	AMBEWADI220-KIRUVATTI	KIRUVATTI_110	11:15	16:43	5:28	LINE CLEAR AVAILED
285	30-Jan-2020	BAGALKOT	110	110/11KV,HV3	JAMKHANDI_110	5:39	11:35	5:56	LINE CLEAR AVAILED
286	30-Jan-2020	BAGALKOT	110	ILKAL1&2-HUNAGUND	HUNGUND_110	3:48	10:30	6:42	LINE CLEAR AVAILED
287	30-Jan-2020	BAGALKOT	110	ILKAL1&2-HUNAGUND	HUNGUND_110	10:34	23:59	13:25	LINE CLEAR AVAILED
288	30-Jan-2020	BAGALKOT	110	MAREGUDDI-MUNDUGANUR	MUNDUGANUR_110	6:55	7:05	0:10	MAIN SUPPLY FAILURE
289	30-Jan-2020	BENGALURU	66	MALUR 220 - MASTHI	MAASTHI, DEVANGONDHI, LAKKUR	0:08	0:15	0:07	LINE FAULT
290	30-Jan-2020	BENGALURU	66	MALUR 220 - MASTHI	MAASTHI, DEVANGONDHI, LAKKUR	5:18	5:28	0:09	LINE FAULT
291	30-Jan-2020	BENGALURU	66	MALUR 220 - MASTHI	MAASTHI, DEVANGONDHI, LAKKUR	19:43	19:51	0:08	LINE FAULT
292	30-Jan-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL(EHT), SUGUTUR, SM MANGALA	3:19	3:56	0:37	LINE FAULT
293	30-Jan-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), SRINIVASAPURA	7:24	7:51	0:27	LOAD CURTAILMENT
294	30-Jan-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL(EHT), SUGUTUR, SM MANGALA	22:10	22:30	0:20	MAIN SUPPLY FAILURE
295	30-Jan-2020	BENGALURU	66	HV1	D CROSS	22:28	22:43	0:14	TRANSFORMER FAULT
296	30-Jan-2020	BENGALURU	66	SRS PEENYA 220 - NELAKADRINAHALLI	NELAKADRINAHALLI	8:54	10:22	1:28	LINE FAULT
297	30-Jan-2020	BENGALURU	66	HV3	ELECTRONIC CITY	16:56	17:55	0:59	LINE CLEAR AVAILED
298	30-Jan-2020	BENGALURU	66	ITI - HOODY 220	ITI	14:03	15:42	1:39	LINE CLEAR AVAILED
299	30-Jan-2020	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	14:30	14:40	0:10	LINE CLEAR AVAILED
300	30-Jan-2020	BENGALURU	66	HV2	SHAMARAJU TECH PARK	20:26	21:15	0:49	TRANSFORMER FAULT
301	30-Jan-2020	BENGALURU	66	HV3	YARANDANAHALLI 220	15:32	15:48	0:16	TRANSFORMER FAULT
302	30-Jan-2020	BENGALURU	220	HV1	YARANDANAHALLI	10:30	11:07	0:37	TRANSFORMER FAULT
303	30-Jan-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	10:30	11:12	0:42	LINE CLEAR AVAILED
304	30-Jan-2020	BENGALURU	66	HV2	YARANDANAHALLI 220	10:30	11:07	0:37	LINE CLEAR AVAILED
305	30-Jan-2020	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	7:14	7:45	0:31	LINE CLEAR AVAILED
306	30-Jan-2020	BENGALURU	66	DALASNUR - SRINIVASPURA	SRINIVASPURA,DRDO,MALLASANDRA	22:08	22:32	0:24	LOAD CURTAILMENT
307	30-Jan-2020	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	15:08	16:15	1:07	LINE FAULT
308	30-Jan-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	8:04	10:28	2:24	LINE CLEAR AVAILED
309	30-Jan-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	CHIKKENAHALLI, ALLIMARADANHALLI, CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	8:29	10:28	1:59	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
310	30-Jan-2020	GULBARGA	220	HV2	KUSTIGI_220	2:35	10:20	7:45	TRANSFORMER FAULT
311	30-Jan-2020	GULBARGA	220	HV1	KUSTIGI_220	10:03	10:22	0:19	TRANSFORMER FAULT
312	30-Jan-2020	GULBARGA	220	HV2	KUSTIGI_220	16:00	18:20	2:20	LINE CLEAR AVAILED
313	30-Jan-2020	GULBARGA	220	HV1	KUSTIGI_220	17:55	18:16	0:21	TRANSFORMER FAULT
314	30-Jan-2020	GULBARGA	110	MALLAT-BYAGAWAT2	MASDLAPUR_110,MANVI_110	0:25	0:37	0:12	LINE FAULT
315	30-Jan-2020	GULBARGA	110	RAICHUR-SHAHAPUR 2	GABBUR_110,DEVADURA_110	1:55	2:30	0:35	LINE FAULT
316	30-Jan-2020	GULBARGA	110	RAICHUR-SHAHAPUR 2	GABBUR_110,DEVADURA_110	3:07	3:37	0:30	LINE FAULT
317	30-Jan-2020	GULBARGA	110	RAICHUR-SHAHAPUR	GABBUR_110,DEVADURA_110	4:10	6:28	2:18	LINE FAULT
318	30-Jan-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	7:00	8:01	1:01	LINE FAULT
319	30-Jan-2020	GULBARGA	110	HV1	CHINCHOLI_110	7:01	7:18	0:17	LOAD CURTAILMENT
320	30-Jan-2020	GULBARGA	110	HV1	KURKUNTA_110	7:01	7:11	0:10	LOAD CURTAILMENT
321	30-Jan-2020	GULBARGA	110	HV1	MAHAGOAN_110	7:01	7:15	0:14	LOAD CURTAILMENT
322	30-Jan-2020	GULBARGA	110	HV4	YELBURGA_110	7:01	7:12	0:11	LOAD CURTAILMENT
323	30-Jan-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	7:34	8:01	0:27	LINE FAULT
324	30-Jan-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNSAGI_110,ASKI_110	21:20	21:26	0:06	LINE FAULT
325	30-Jan-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_IPP	21:20	21:40	0:20	LINE FAULT
326	30-Jan-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNSAGI_110,ASKI_111	21:40	21:51	0:11	LINE FAULT
327	30-Jan-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_IPP	23:45	23:50	0:05	LINE FAULT
328	30-Jan-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	15:10	23:59	8:49	LINE FAULT
329	30-Jan-2020	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	9:56	14:18	4:22	LINE CLEAR AVAILED
330	30-Jan-2020	HASSAN	220	MRSSHM-HSN4001	MRSMG_220	9:06	11:28	2:22	LINE CLEAR AVAILED
331	30-Jan-2020	HASSAN	220	MRSSHM-KBCRS	MRSMG_220	0:00	18:10	18:10	LINE CLEAR AVAILED
332	30-Jan-2020	HASSAN	220	MRSSHM-VARAH12	MRSMG_220	15:23	19:29	4:06	LINE FAULT
333	30-Jan-2020	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	9:56	14:18	4:22	NFBC ISSUED
334	30-Jan-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA-400	15:10	23:59	8:49	LINE FAULT
335	30-Jan-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	15:23	19:29	4:06	LINE FAULT
336	30-Jan-2020	HASSAN	110	HV1	ANAVATTI_110	11:10	11:20	0:10	TRANSFORMER FAULT
337	30-Jan-2020	HASSAN	110	HV2	GANDSI_110	7:00	7:13	0:13	LOAD CURTAILMENT
338	30-Jan-2020	HASSAN	110	HV1	HOSANGADI_110	12:41	13:31	0:50	LINE CLEAR AVAILED
339	30-Jan-2020	HASSAN	110	HV1	JAVAGAL_110	7:00	7:11	0:11	LOAD CURTAILMENT
340	30-Jan-2020	HASSAN	110	HV1	MANIPAL_110	10:05	10:39	0:34	LINE CLEAR AVAILED
341	30-Jan-2020	HASSAN	66	HV1	BAGUR_66	8:40	12:36	3:56	MAIN SUPPLY FAILURE
342	30-Jan-2020	HASSAN	66	HV2	BAGUR_66	8:40	12:36	3:56	MAIN SUPPLY FAILURE
343	30-Jan-2020	HASSAN	66	BAGUR-UDAYAPUR	BAGUR_66	8:40	12:36	3:56	MAIN SUPPLY FAILURE
344	30-Jan-2020	HASSAN	66	RAMPURA-BAGUR	RAMPURA_66	12:00	12:53	0:53	LINE CLEAR AVAILED
345	30-Jan-2020	HASSAN	66	HV1	RAMPURA_66	10:20	12:55	2:35	LINE CLEAR AVAILED
346	30-Jan-2020	HASSAN	66	HV2	RAMPURA_66	11:39	12:59	1:20	LINE CLEAR AVAILED
347	30-Jan-2020	HASSAN	66	HV1	TAVARECHANAHALLI_66	14:15	14:30	0:15	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
348	30-Jan-2020	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	8:31	12:36	4:05	LINE CLEAR AVAILED
349	30-Jan-2020	HASSAN	66	HV2	UDAYAPURA_66	9:00	9:05	0:05	TRANSFORMER FAULT
350	30-Jan-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	7:00	7:15	0:15	LOAD CURTAILMENT
351	30-Jan-2020	MYSORE	66	HV2	BILIKERE_66	11:23	11:33	0:10	TRANSFORMER FAULT
352	30-Jan-2020	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	11:38	11:43	0:05	LINE FAULT
353	30-Jan-2020	MYSORE	66	HV1	MALAVALLI_66	10:12	16:48	6:36	LINE CLEAR AVAILED
354	30-Jan-2020	MYSORE	66	HV2	MALAVALLI_66	10:12	16:48	6:36	LINE CLEAR AVAILED
355	30-Jan-2020	MYSORE	66	MALLAVALLI-M2	MALAVALLI_66	14:52	16:48	1:55	LINE CLEAR AVAILED
356	30-Jan-2020	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	17:30	18:10	0:39	HAND TRIPPED
357	30-Jan-2020	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	17:31	18:01	0:30	HAND TRIPPED
358	30-Jan-2020	TUMKUR	110	TR-1	TURUVEKERE_110	9:52	9:57	0:05	TRANSFORMER FAULT
359	30-Jan-2020	TUMKUR	110	TR-1	BIDARE_110	10:59	14:25	3:25	LINE CLEAR AVAILED
360	30-Jan-2020	TUMKUR	110	TR-2	KADEHALLI_110	10:45	11:13	0:27	TRANSFORMER FAULT
361	30-Jan-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	17:29	18:03	0:33	HAND TRIPPED
362	30-Jan-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	17:29	18:06	0:36	HAND TRIPPED
363	30-Jan-2020	TUMKUR	110	TR-1(HV SIDE)	KBCROSS_220	12:02	12:32	0:29	HAND TRIPPED
364	30-Jan-2020	TUMKUR	110	TR-2 (LV SIDE)	KBCROSS_220	17:30	18:03	0:33	HAND TRIPPED
365	30-Jan-2020	TUMKUR	110	TR-2	SAMPIGE_110	7:00	7:07	0:07	MAIN SUPPLY FAILURE
366	30-Jan-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	7:00	7:15	0:15	HAND TRIPPED
367	30-Jan-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	7:49	8:06	0:16	LINE FAULT
368	30-Jan-2020	TUMKUR	66	TR-1	DAVANGERE_SRS_220	14:04	14:12	0:08	TRANSFORMER FAULT
369	30-Jan-2020	TUMKUR	66	TR-2	HIREGUNTANUR_66	0:05	0:12	0:07	HAND TRIPPED
370	30-Jan-2020	TUMKUR	66	TR-2	KOLALA_66	11:33	16:23	4:49	LINE CLEAR AVAILED
371	30-Jan-2020	TUMKUR	66	TR-1	MATHOD_66	8:07	8:15	0:07	TRANSFORMER FAULT
372	30-Jan-2020	TUMKUR	66	TR-1	PAVAGADA_220	11:44	12:34	0:49	LINE CLEAR AVAILED
373	30-Jan-2020	TUMKUR	66	TR-2	THOVINAKERE_66	17:13	17:22	0:09	HAND TRIPPED
374	31-Jan-2020	BAGALKOT	110	110/11KV,HV1	BIJAPUR_110	8:24	8:43	0:19	LINE CLEAR AVAILED
375	31-Jan-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI2	BAGALKOT_220	0:00	12:53	12:53	LINE CLEAR AVAILED
376	31-Jan-2020	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	8:48	14:21	5:33	LINE FAULT
377	31-Jan-2020	BAGALKOT	220	NARENDRA-BELGAUM1	NERENDRA_220	0:00	14:21	14:21	LINE CLEAR AVAILED
378	31-Jan-2020	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	6:00	9:10	3:10	LINE FAULT
379	31-Jan-2020	BAGALKOT	110	RANEENNUR220-BYADAGI	BYADAGI_110	6:00	23:59	17:59	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
380	31-Jan-2020	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	7:37	9:10	1:33	LINE CLEAR AVAILED
381	31-Jan-2020	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	6:02	6:08	0:06	LINE FAULT
382	31-Jan-2020	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	6:50	7:00	0:10	LINE FAULT
383	31-Jan-2020	BAGALKOT	110	110/33KV,HV2	GAJENDRAGAD_110,WIND_33	13:49	14:55	1:06	LINE CLEAR AVAILED
384	31-Jan-2020	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	10:53	15:20	4:27	LINE CLEAR AVAILED
385	31-Jan-2020	BAGALKOT	110	GOPANAKOPPA-NARAGUND	NARAGUND_110	6:02	23:59	17:57	LINE FAULT
386	31-Jan-2020	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	12:03	12:10	0:07	TRANSFORMER FAULT
387	31-Jan-2020	BAGALKOT	220	GUTTUR1-HAVERI	HAVERI_220	5:53	23:59	18:06	LINE FAULT
388	31-Jan-2020	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	5:53	19:36	13:43	LINE FAULT
389	31-Jan-2020	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	5:53	11:30	5:37	LINE FAULT
390	31-Jan-2020	BAGALKOT	110	HUKKERI-KOTTAWAGI LIS	KOTTAWAGI LIS_110	6:38	10:17	3:39	LINE FAULT
391	31-Jan-2020	BAGALKOT	110	HUKKERI-KOTTAWAGI LIS	KOTTAWAGI LIS_110	10:47	18:50	8:03	LINE FAULT
392	31-Jan-2020	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	14:16	14:20	0:04	TRANSFORMER FAULT
393	31-Jan-2020	BAGALKOT	110	110/11KV,HV1	TERDAL_110	9:51	10:02	0:11	TRANSFORMER FAULT
394	31-Jan-2020	BAGALKOT	110	SANKESHWAR-HUKERI	HUKKERI_110	6:10	6:34	0:24	LINE FAULT
395	31-Jan-2020	BAGALKOT	110	SANKESHWAR-HUKERI	HUKKERI_110	6:50	7:02	0:12	LINE FAULT
396	31-Jan-2020	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	4:04	4:12	0:08	LINE FAULT
397	31-Jan-2020	BAGALKOT	110	RANEENNUR-HONNATTI(AREMALLAPUR)	HONNATTI_110	7:30	7:50	0:20	LOAD CURTAILMENT
398	31-Jan-2020	BAGALKOT	110	110/11KV,HV1	MUNDARGI_110	15:31	16:46	1:15	LINE CLEAR AVAILED
399	31-Jan-2020	BAGALKOT	110	110/11KV,HV3	MUNDARGI_110	14:06	14:15	0:09	TRANSFORMER FAULT
400	31-Jan-2020	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(G)_110	16:46	19:05	2:19	TRANSFORMER FAULT
401	31-Jan-2020	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	10:14	10:17	0:03	TRANSFORMER FAULT
402	31-Jan-2020	BAGALKOT	110	110/11KV,HV1	MALGHAN(B)_110	11:15	11:20	0:05	TRANSFORMER FAULT
403	31-Jan-2020	BAGALKOT	110	BPCL-ITNAL	ITNAL_110	7:09	7:14	0:05	LINE FAULT
404	31-Jan-2020	BAGALKOT	110	110/33KV,HV1&2	SAVANUR,BANKAPUR_33,HULAGUR_33 ,HATTIMATTUR_33	11:35	11:42	0:07	HAND TRIPPED
405	31-Jan-2020	BAGALKOT	110	110/11KV,HV3	SAVANUR_110	11:30	11:55	0:25	HAND TRIPPED
406	31-Jan-2020	BAGALKOT	110	ILKAL1&2-HUNGUND	HUNGUND_110	0:00	12:24	12:24	LINE CLEAR AVAILED
407	31-Jan-2020	BENGALURU	66	MALUR 220 - HOSKOTE2	JADIGENAHALLI	7:08	7:18	0:10	LINE FAULT
408	31-Jan-2020	BENGALURU	66	MALUR 220 - KGF1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:09	12:14	0:05	LINE FAULT
409	31-Jan-2020	BENGALURU	66	HV1	MAGADI	9:45	10:07	0:22	LINE CLEAR AVAILED
410	31-Jan-2020	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	9:10	9:30	0:20	MAIN SUPPLY FAILURE
411	31-Jan-2020	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	13:11	13:20	0:09	LINE FAULT
412	31-Jan-2020	BENGALURU	66	HV1	KADUBEESANAHALLI	4:27	4:53	0:25	LINE CLEAR AVAILED
413	31-Jan-2020	BENGALURU	66	HV2	KADUBEESANAHALLI	4:27	4:53	0:25	LINE CLEAR AVAILED
414	31-Jan-2020	BENGALURU	66	HV1	HOODY 220	4:43	5:20	0:36	TRANSFORMER FAULT
415	31-Jan-2020	BENGALURU	66	HV1	BTM LAYOUT 4 PHASE	12:02	13:17	1:15	LINE CLEAR AVAILED
416	31-Jan-2020	GULBARGA	220	HV1	KUSTAGI_220	6:00	6:28	0:28	TRANSFORMER FAULT
417	31-Jan-2020	GULBARGA	220	HUMNABAD-SEDAM1	SEDAM_220	13:30	13:35	0:05	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
418	31-Jan-2020	GULBARGA	220	HUMNABAD-SEDAM1	SEDAM_220	17:00	17:10	0:10	LINE FAULT
419	31-Jan-2020	GULBARGA	220	HV2	HUMNABAD_220	15:50	15:55	0:05	TRANSFORMER FAULT
420	31-Jan-2020	GULBARGA	110	KUSTAGI-HANUMSAGAR	HANUMSAGAR_110	6:00	6:33	0:33	LINE FAULT
421	31-Jan-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGUR_IPP	2:37	2:45	0:08	LINE FAULT
422	31-Jan-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	3:45	3:50	0:05	LINE FAULT
423	31-Jan-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	4:18	7:05	2:47	LINE FAULT
424	31-Jan-2020	GULBARGA	110	SIDHANOOR220-SINDHANOOR1	MASKI_110,MUDDAPUR_110	7:25	7:40	0:15	LOAD CURTAILMENT
425	31-Jan-2020	GULBARGA	110	MALLAT-BYAGAWAT2	MASDLAPUR_110,MANVI_110	4:35	4:40	0:05	LINE FAULT
426	31-Jan-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT1_110	4:40	4:47	0:07	LINE FAULT
427	31-Jan-2020	GULBARGA	110	LV2	HUMNABAD_220	15:50	16:00	0:10	TRANSFORMER FAULT
428	31-Jan-2020	GULBARGA	110	LV2	HUMNABAD_220	16:50	17:30	0:40	TRANSFORMER FAULT
429	31-Jan-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	0:53	1:03	0:10	LINE FAULT
430	31-Jan-2020	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	8:10	8:15	0:05	LINE FAULT
431	31-Jan-2020	GULBARGA	110	GABUR-BPSLR_IPP	GABBUR_110,DEVADURA_110	20:15	20:20	0:05	LINE FAULT
432	31-Jan-2020	GULBARGA	66	ITTAGI-BENNEHALLI	BENNEHALLI_66	7:55	16:01	8:06	LINE CLEAR AVAILED
433	31-Jan-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	0:00	14:56	14:56	LINE FAULT
434	31-Jan-2020	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	10:12	14:23	4:11	LINE CLEAR AVAILED
435	31-Jan-2020	HASSAN	220	MRSSHM-HSN4001	MRSMG_220	6:51	11:23	4:32	LINE FAULT
436	31-Jan-2020	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	10:13	14:23	4:10	NFBC ISSUED
437	31-Jan-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	0:00	14:55	14:55	LINE FAULT
438	31-Jan-2020	HASSAN	110	HV2	GANDSI_110	12:39	14:00	1:21	LINE CLEAR AVAILED
439	31-Jan-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:31	10:40	0:09	LINE FAULT
440	31-Jan-2020	HASSAN	66	HV1	CHIKMAGALUR_66	11:45	12:06	0:21	LINE CLEAR AVAILED
441	31-Jan-2020	HASSAN	66	HV1	DUDDA_66	4:17	4:58	0:41	TRANSFORMER FAULT
442	31-Jan-2020	HASSAN	66	MATTNAV-DIDGTHL	MATTNAVILE_66	13:17	13:34	0:17	NFBC ISSUED
443	31-Jan-2020	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	23:28	23:52	0:24	LINE FAULT
444	31-Jan-2020	HASSAN	66	HV2	UDAYAPURA_66	7:32	7:37	0:05	TRANSFORMER FAULT
445	31-Jan-2020	HASSAN	66	HV2	UDAYAPURA_66	8:19	8:22	0:03	TRANSFORMER FAULT
446	31-Jan-2020	MYSORE	66	ELWALA-HUNSUR	GAVADAGERE_66	0:45	0:54	0:08	LINE FAULT
447	31-Jan-2020	MYSORE	66	KADAKOLA-SARGUR-1	B MATKERE_66 JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66 SANTHESARAGUR_66	13:04	13:10	0:06	LINE FAULT
448	31-Jan-2020	MYSORE	66	KOLLEGALA-PARINAMIPURA	CHANDALLI_66 PARINAMIPURA_66 THALAKADU_66	6:36	6:57	0:20	LINE FAULT
449	31-Jan-2020	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	7:02	7:08	0:05	LINE FAULT
450	31-Jan-2020	MYSORE	66	HV1	SATHEGALA_66	10:01	11:10	1:08	LINE CLEAR AVAILED
451	31-Jan-2020	MYSORE	66	HV1	SANIVARASANTHE_66	4:24	4:36	0:11	TRANSFORMER FAULT
452	31-Jan-2020	MYSORE	66	HV1	SANIVARASANTHE_66	9:50	10:03	0:12	TRANSFORMER FAULT
453	31-Jan-2020	TUMKUR	220	GUTTUR 400KV- HAVERI 2	GUTUR_400	5:53	19:37	13:43	NFBC ISSUED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
454	31-Jan-2020	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	6:17	7:53	1:36	LOAD CURTAILMENT
455	31-Jan-2020	TUMKUR	220	TR-3	HIRIYUR_220	7:06	17:30	10:24	LINE CLEAR AVAILED
456	31-Jan-2020	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	HONNALLI_220	11:54	15:59	4:04	LINE CLEAR AVAILED
457	31-Jan-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	11:55	12:12	0:16	LINE CLEAR AVAILED
458	31-Jan-2020	TUMKUR	110	TR-1	GUBBI_110	4:12	4:17	0:05	TRANSFORMER FAULT
459	31-Jan-2020	TUMKUR	110	TR-1	GUBBI_110	13:12	14:02	0:50	LINE CLEAR AVAILED
460	31-Jan-2020	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	6:39	6:44	0:05	LINE FAULT
461	31-Jan-2020	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	7:03	9:06	2:02	LOAD CURTAILMENT
462	31-Jan-2020	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	6:39	7:06	0:26	LOAD CURTAILMENT
463	31-Jan-2020	TUMKUR	110	TR-1	NITTUR_220	6:44	7:01	0:16	TRANSFORMER FAULT
464	31-Jan-2020	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	18:26	21:49	3:23	LINE CLEAR AVAILED
465	31-Jan-2020	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	7:29	7:47	0:17	LOAD CURTAILMENT
466	31-Jan-2020	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	6:39	7:47	1:08	LOAD CURTAILMENT
467	31-Jan-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	7:00	7:00	0:00	LINE FAULT
468	31-Jan-2020	TUMKUR	66	TR-3	AVAREGERE_66	5:14	5:46	0:32	TRANSFORMER FAULT
469	31-Jan-2020	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	8:05	8:15	0:09	LINE FAULT
470	31-Jan-2020	TUMKUR	66	TR-1	CHIKKABANAGERE_66	12:30	12:38	0:08	TRANSFORMER FAULT
471	31-Jan-2020	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	17:58	18:07	0:08	LINE FAULT
472	31-Jan-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	17:58	18:05	0:07	HAND TRIPPED
473	31-Jan-2020	TUMKUR	66	TR-2	CHITRADURGA_66	11:26	13:39	2:13	LINE CLEAR AVAILED
474	31-Jan-2020	TUMKUR	66	DAVANGERE66-DAVANGERE SRS	DAVANAGERE_66	11:02	11:16	0:14	HAND TRIPPED
475	31-Jan-2020	TUMKUR	66	TR-1	DAVANGERE_SRS_220	10:42	10:45	0:03	HAND TRIPPED
476	31-Jan-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	17:24	17:33	0:09	HAND TRIPPED
477	31-Jan-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	17:24	17:33	0:09	HAND TRIPPED
478	31-Jan-2020	TUMKUR	66	TR-1	HANAGAL_66	10:10	10:17	0:07	HAND TRIPPED
479	31-Jan-2020	TUMKUR	66	TR-1	HIRESHALLY_66	8:26	8:34	0:08	TRANSFORMER FAULT
480	31-Jan-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUND A_66	7:50	8:03	0:12	HAND TRIPPED
481	31-Jan-2020	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	7:50	8:03	0:12	HAND TRIPPED
482	31-Jan-2020	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	10:35	10:49	0:14	HAND TRIPPED
483	31-Jan-2020	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	7:50	7:58	0:07	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
484	31-Jan-2020	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	10:35	10:58	0:23	HAND TRIPPED
485	31-Jan-2020	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	7:23	9:45	2:21	MAIN SUPPLY FAILURE
486	31-Jan-2020	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	10:15	11:49	1:33	MAIN SUPPLY FAILURE
487	31-Jan-2020	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	18:28	19:36	1:08	MAIN SUPPLY FAILURE
488	31-Jan-2020	TUMKUR	66	MADHUGIRI 220KV- KORATAGERE 1	HOLAVINAHALLY_66	6:53	7:56	1:03	LOAD CURTAILMENT
489	31-Jan-2020	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	6:37	7:56	1:18	LOAD CURTAILMENT
490	31-Jan-2020	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	AVNTI_SLR_IPP_66	12:14	18:15	6:01	MAIN SUPPLY FAILURE
491	31-Jan-2020	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	15:53	18:20	2:27	MAIN SUPPLY FAILURE
492	31-Jan-2020	TUMKUR	66	TR-1&TR-2	MATHOD_66	15:06	15:40	0:34	MAIN SUPPLY FAILURE
493	31-Jan-2020	TUMKUR	66	MATHOD-RAMCO CEMENT _EHT_66	RAMCO CEMENT _EHT_66	15:03	18:06	3:02	MAIN SUPPLY FAILURE
494	31-Jan-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	8:12	8:23	0:11	TRANSFORMER FAULT
495	1-Feb-2020	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	13:36	23:59	10:23	LINE CLEAR AVAILED
496	1-Feb-2020	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	16:54	17:10	0:16	LINE FAULT
497	1-Feb-2020	BAGALKOT	220	BELGAUM-NARENDRA 2	BELGAUM_220	3:13	15:06	11:53	LINE FAULT
498	1-Feb-2020	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	5:14	11:56	6:42	LINE FAULT
499	1-Feb-2020	BAGALKOT	220	BIDNAL-SOUNDATTI	BIDNAL_220	4:34	10:57	6:23	LINE FAULT
500	1-Feb-2020	BAGALKOT	220	CHIKKODI-KUDACHI	CHIKKODI_220	7:30	10:20	2:50	LINE FAULT
501	1-Feb-2020	BAGALKOT	220	HAVERI-GUTUR 1	HAVERI_220	0:00	18:23	18:23	LINE CLEAR AVAILED
502	1-Feb-2020	BAGALKOT	110	HUKKERI-VISHWANATH SUGARS	HUKKERI_110	4:59	8:10	3:11	LINE FAULT
503	1-Feb-2020	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	3:13	4:18	1:05	MAIN SUPPLY FAILURE
504	1-Feb-2020	BAGALKOT	110	RAIBAG2-ITNAL	ITNAL_110	6:27	10:55	4:28	LINE FAULT
505	1-Feb-2020	BAGALKOT	110	110/11KV,HV 3	JAMAKHANDI_110	15:04	15:30	0:26	LINE CLEAR AVAILED
506	1-Feb-2020	BAGALKOT	110	TODALABAGI-JAMAKHANDI	JAMAKHANDI_110	21:27	21:47	0:20	LINE FAULT
507	1-Feb-2020	BAGALKOT	110	110/11KV,HV 1	KALADAGI_110	16:08	16:10	0:02	TRANSFORMER FAULT
508	1-Feb-2020	BAGALKOT	110	110/11KV,HV 2	KALAGHATGI	14:59	15:04	0:05	TRANSFORMER FAULT
509	1-Feb-2020	BAGALKOT	110	KONNUR-ANANT SOLAR	KONNUR_110	4:56	6:24	1:28	LINE FAULT
510	1-Feb-2020	BAGALKOT	110	KUDACHI 220- KUDACHI 110	KUDACHI_110	10:33	18:26	7:53	LINE CLEAR AVAILED
511	1-Feb-2020	BAGALKOT	220	220/110KV,HV1&LV1	KUDACHI_220	6:22	6:40	0:18	TRANSFORMER FAULT
512	1-Feb-2020	BAGALKOT	220	MAHALINGAPUR-SOUNDATTI	MAHALINGAPUR_220	2:58	13:10	10:12	LINE FAULT
513	1-Feb-2020	BAGALKOT	110	MAHALINGAPUR-GSML 1	MAHALINGAPUR_220	2:58	10:50	7:52	LINE FAULT
514	1-Feb-2020	BAGALKOT	110	110/11KV,HV 2	MAMADAPUR_110	9:00	15:30	6:30	LINE CLEAR AVAILED
515	1-Feb-2020	BAGALKOT	110	NAVALGUND-KONNUR NARAGUND	NAVALGUND_110	4:37	12:38	8:01	LINE FAULT
516	1-Feb-2020	BAGALKOT	110	CHIKKODI-NIPPANI	NIPPANI_110	15:11	16:43	1:32	LINE CLEAR AVAILED
517	1-Feb-2020	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	2:43	3:52	1:09	LINE FAULT
518	1-Feb-2020	BAGALKOT	110	110/33KV,HV 2	SAVALAGI_110&33KV- KALBILAGI,H.PADASALGI& TUNGAL LIS	11:52	13:30	1:38	LINE CLEAR AVAILED
519	1-Feb-2020	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	5:30	12:58	7:28	LINE FAULT
520	1-Feb-2020	BAGALKOT	110	110/11KV,HV 2	UGAR KHUD_110	4:32	5:06	0:34	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
521	1-Feb-2020	BAGALKOT	110	110/11KV,HV 2	UGAR KHUD_110	13:58	16:45	2:47	LINE CLEAR AVAILED
522	1-Feb-2020	BAGALKOT	110	110/11KV,HV 2	VAJRAMATTI_110	6:02	6:05	0:03	TRANSFORMER FAULT
523	1-Feb-2020	BAGALKOT	110	110/11KV,HV 2	VAJRAMATTI_110	8:57	9:01	0:04	TRANSFORMER FAULT
524	1-Feb-2020	BAGALKOT	110	110/11KV,HV 2	YARAGATTI_110	4:42	14:09	9:27	LINE CLEAR AVAILED
525	1-Feb-2020	BAGALKOT	110	110/11KV,HV 1,2&3	YARAGATTI_110	4:42	14:09	9:27	LINE CLEAR AVAILED
526	1-Feb-2020	BENGALURU	66	AMARJYOTHI - KORMANGALA 220	AMARJYOTHI	8:10	8:15	0:05	LOAD CHANGEOVER
527	1-Feb-2020	BENGALURU	66	AMARJYOTHI - HAL 2	AMARJYOTHI	17:10	17:20	0:10	LOAD CHANGEOVER
528	1-Feb-2020	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220		22:15	22:18	0:03	LOAD CHANGEOVER
529	1-Feb-2020	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	20:20	20:23	0:03	LOAD CHANGEOVER
530	1-Feb-2020	BENGALURU	66	HV1	DEVARBISANAHALLI	13:00	13:30	0:30	LINE CLEAR AVAILED
531	1-Feb-2020	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	10:10	10:25	0:15	LOAD CHANGEOVER
532	1-Feb-2020	BENGALURU	66	ELITE PROMENEDE - RBI	ELITE PROMENEDE	18:35	18:45	0:10	LOAD CHANGEOVER
533	1-Feb-2020	BENGALURU	66	GOLF LINKS - HAL 2	GOLF LINKS	8:10	8:15	0:05	LOAD CHANGEOVER
534	1-Feb-2020	BENGALURU	66	GOLF LINKS - KORMANGALA	GOLF LINKS	17:20	17:30	0:10	LOAD CHANGEOVER
535	1-Feb-2020	BENGALURU	66	HV1	KADUGODI	10:12	10:35	0:23	TRANSFORMER FAULT
536	1-Feb-2020	BENGALURU	66	KADUGODI - ARMY WELFARE ORGANIZATION	ARMY WELFARE ORGANIZATION, KONDASPURA	10:12	11:09	0:57	LINE FAULT
537	1-Feb-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	18:45	18:48	0:03	LINE FAULT
538	1-Feb-2020	BENGALURU	220	KOLAR 220 - RAILWAY TRACTION	RAILWAY TRACTION	0:05	2:40	2:35	LINE CLEAR AVAILED
539	1-Feb-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DAALSNUR	9:10	9:40	0:30	LOAD CURTAILMENT
540	1-Feb-2020	BENGALURU	66	HV2	NRS 220	23:17	23:32	0:14	LINE CLEAR AVAILED
541	1-Feb-2020	BENGALURU	66	HV2	NRS 220	23:12	23:19	0:07	LINE CLEAR AVAILED
542	1-Feb-2020	BENGALURU	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	23:50	23:55	0:05	LOAD CHANGEOVER
543	1-Feb-2020	BENGALURU	66	SIR MV LAYOUT - VRISHABHAVATHI 220	,KUMBALAGODU,KENGERI SATELLITE TOWN	14:32	14:45	0:13	LINE FAULT
544	1-Feb-2020	BENGALURU	66	SIR MV LAYOUT - KUMBALAGODU	KUMBALAGODU	14:32	14:45	0:13	LINE FAULT
545	1-Feb-2020	BENGALURU	66	SIR MV LAYOUT - VRISHABHAVATHI 220	,KUMBALAGODU,KENGERI SATELLITE TOWN	15:28	15:32	0:04	LINE FAULT
546	1-Feb-2020	BENGALURU	66	SIR MV LAYOUT - KUMBALAGODU	KUMBALAGODU	15:28	15:32	0:04	LINE FAULT
547	1-Feb-2020	BENGALURU	66	REMCO - VRISHBHAVATHI 220	REMCO	23:32	23:38	0:06	LOAD CHANGEOVER
548	1-Feb-2020	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	11:25	11:35	0:10	LOAD CHANGEOVER
549	1-Feb-2020	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	18:30	18:40	0:10	LOAD CHANGEOVER
550	1-Feb-2020	BENGALURU	66	HV2	HOSUR RAMAPURA	12:10	12:20	0:10	TRANSFORMER FAULT
551	1-Feb-2020	BENGALURU	66	HV1	KONDASPURA	14:53	15:08	0:15	TRANSFORMER FAULT
552	1-Feb-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	6:57	7:20	0:23	LINE FAULT
553	1-Feb-2020	GULBARGA	220	KAPNOOR220-HUMNABAD2	KAPNOOR_220	13:32	13:55	0:23	LINE FAULT
554	1-Feb-2020	GULBARGA	220	KAPNOOR220-HUMNABAD2	KAPNOOR_220	13:58	14:28	0:30	LINE FAULT
555	1-Feb-2020	GULBARGA	220	KAPNOOR220-HUMNABAD2	KAPNOOR_220	15:41	16:31	0:50	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
556	1-Feb-2020	GULBARGA	220	KAPNOOR220-HUMNABAD2	KAPNOOR_220	17:50	19:37	1:47	LINE FAULT
557	1-Feb-2020	GULBARGA	220	HUMNABA-KAPNOOR1	KAPNOOR_220	13:40	13:51	0:11	LINE FAULT
558	1-Feb-2020	GULBARGA	110	CHITAGUPPA-ACMESOLAR IPP	CHITGUPPA_110	11:48	11:55	0:07	LINE FAULT
559	1-Feb-2020	GULBARGA	66	HV1	CHORNOOR_66	12:55	13:06	0:11	TRANSFORMER FAULT
560	1-Feb-2020	GULBARGA	66	HV1	KOTTUR_66	13:00	13:10	0:10	TRANSFORMER FAULT
561	1-Feb-2020	GULBARGA	110	SIDHANOOR220-TURVIHAL	TURVIHAL_110	0:53	1:03	0:10	LINE FAULT
562	1-Feb-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	2:34	2:42	0:08	LINE FAULT
563	1-Feb-2020	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURU GOD_110,SHATHAVANA_IPP,AGRAWAL _IPP,SUZLON_IPP,KAMALAPUR_IPP,MA TR,RBNS_FACTORY	6:23	6:30	0:07	LINE FAULT
564	1-Feb-2020	GULBARGA	110	HV3	ALIPUR_220	3:10	3:48	0:38	TRANSFORMER FAULT
565	1-Feb-2020	GULBARGA	110	HV4	ALIPUR_220	11:31	12:10	0:39	HAND TRIPPED
566	1-Feb-2020	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	13:30	14:00	0:30	LINE CLEAR AVAILED
567	1-Feb-2020	GULBARGA	220	HV1	SEDAM_220	12:50	14:02	1:12	LINE CLEAR AVAILED
568	1-Feb-2020	GULBARGA	220	SHAHAPUR-SHORAPUR	SHORAPUR_110	23:23	23:31	0:08	LINE FAULT
569	1-Feb-2020	GULBARGA	220	SHAHAPUR-SHORAPUR	SHORAPUR_110	22:04	22:11	0:07	LINE FAULT
570	1-Feb-2020	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	10:43	23:59	13:16	NFBC ISSUED
571	1-Feb-2020	HASSAN	220	KAVOOR-BAJPE2	KAVOOR_220	9:55	16:36	6:41	LINE CLEAR AVAILED
572	1-Feb-2020	HASSAN	220	MRSSHM-KBCRS	MRSMG_220	13:46	14:03	0:17	HAND TRIPPED
573	1-Feb-2020	HASSAN	220	MRSSHM-KBCRS	MRSMG_220	14:54	15:07	0:13	LINE FAULT
574	1-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	10:42	23:59	13:17	LINE CLEAR AVAILED
575	1-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMG_220	10:48	23:59	13:11	LINE CLEAR AVAILED
576	1-Feb-2020	HASSAN	220	MRSSHM-VARAH1	MRSMG_220	10:19	12:44	2:25	NFBC ISSUED
577	1-Feb-2020	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	10:28	10:34	0:06	LINE FAULT
578	1-Feb-2020	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	10:42	10:47	0:05	LINE FAULT
579	1-Feb-2020	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	9:55	16:36	6:41	NFBC ISSUED
580	1-Feb-2020	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	5:19	23:59	18:40	LINE CLEAR AVAILED
581	1-Feb-2020	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	10:20	12:44	2:24	LINE CLEAR AVAILED
582	1-Feb-2020	HASSAN	110	HV3	BHADRAVATHI_110	13:48	14:00	0:12	TRANSFORMER FAULT
583	1-Feb-2020	HASSAN	110	HV1	KONAJE_110	10:47	10:49	0:02	HAND TRIPPED
584	1-Feb-2020	HASSAN	110	HV1	KONAJE_110	12:22	12:24	0:02	HAND TRIPPED
585	1-Feb-2020	HASSAN	110	HV2	KONAJE_110	10:47	10:50	0:03	HAND TRIPPED
586	1-Feb-2020	HASSAN	110	HV2	KONAJE_110	12:22	12:24	0:02	HAND TRIPPED
587	1-Feb-2020	HASSAN	110	HV3	KONAJE_110	10:47	10:49	0:02	HAND TRIPPED
588	1-Feb-2020	HASSAN	110	HV3	KONAJE_110	12:22	12:24	0:02	HAND TRIPPED
589	1-Feb-2020	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	15:27	15:31	0:04	HAND TRIPPED
590	1-Feb-2020	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	11:04	12:18	1:14	LINE CLEAR AVAILED
591	1-Feb-2020	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	11:02	12:20	1:18	LINE CLEAR AVAILED
592	1-Feb-2020	HASSAN	66	HV1	GANGUR_66	7:38	7:50	0:12	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
593	1-Feb-2020	HASSAN	66	HV1	HALLIMYSORE_66	16:45	16:56	0:11	TRANSFORMER FAULT
594	1-Feb-2020	HASSAN	66	HV1	HALLIMYSORE_66	16:58	17:10	0:12	TRANSFORMER FAULT
595	1-Feb-2020	HASSAN	66	HV2	HASSAN_66	11:30	23:59	12:29	TRANSFORMER FAULT
596	1-Feb-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	14:06	14:17	0:11	LINE FAULT
597	1-Feb-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	14:22	14:24	0:02	LINE FAULT
598	1-Feb-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	14:49	14:53	0:04	LINE CLEAR AVAILED
599	1-Feb-2020	HASSAN	66	HV2	UDAYAPURA_66	8:28	8:35	0:07	TRANSFORMER FAULT
600	1-Feb-2020	MYSORE	66	HV1	ADDIHALLI_66	10:02	10:04	0:01	TRANSFORMER FAULT
601	1-Feb-2020	MYSORE	66	BOOKANAKERE-CHINKURALI	BANANGADI_66, CHINAKURALI_66,	1:55	2:03	0:08	LINE FAULT
602	1-Feb-2020	MYSORE	66	BOOKANAKERE-CHINKURALI	BANANGADI_66, CHINAKURALI_66,	2:36	2:43	0:06	LINE FAULT
603	1-Feb-2020	MYSORE	66	HV1	KIADBMANDYA_66	16:35	17:33	0:58	LINE CLEAR AVAILED
604	1-Feb-2020	MYSORE	66	HV2	KIADBMANDYA_66	9:40	17:51	8:11	LINE CLEAR AVAILED
605	1-Feb-2020	MYSORE	66	KIADB MANDYA-MADDUR	KIADB MANDYA, MADDUR, TUMBEKERE & SOMANAHALLI STATION INTERRUPTED.	16:32	16:37	0:05	HAND TRIPPED
606	1-Feb-2020	MYSORE	66	HV1	KIRUGAVALU_66	12:33	13:19	0:45	LINE CLEAR AVAILED
607	1-Feb-2020	MYSORE	66	HV1	KRNAGARA_66	7:52	8:13	0:21	TRANSFORMER FAULT
608	1-Feb-2020	MYSORE	66	KR PETE 220-BOOKANAKERE	BANANGADI_66, BOOKANAKERE_66, CHINAKURALI_66, GANJIGERE_66, SHEELUNERE_66	10:36	10:43	0:06	LINE FAULT
609	1-Feb-2020	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66	2:54	3:09	0:15	LINE FAULT
610	1-Feb-2020	MYSORE	66	HV1	MADDUR-	10:39	10:43	0:04	HAND TRIPPED
611	1-Feb-2020	MYSORE	66	HV2	MADDUR_66	10:39	10:43	0:04	HAND TRIPPED
612	1-Feb-2020	MYSORE	66	MEGLAPURA-SFC	CHIDRAVALLI_66, GARGESHWARI_66, THUMBLA_66, TNARASIPURA_66, V	15:54	16:04	0:10	LINE FAULT
613	1-Feb-2020	MYSORE	66	VIJAYANAGARA-HOOTAGALY	VIJAYANAGRAMYS_66	1:32	8:18	6:46	LINE CLEAR AVAILED
614	1-Feb-2020	MYSORE	66	HV1	VIJAYANAGRAMYS_66	1:13	1:43	0:30	HAND TRIPPED
615	1-Feb-2020	MYSORE	66	HV2	VIJAYANAGRAMYS_66	1:13	1:44	0:30	HAND TRIPPED
616	1-Feb-2020	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	MRS MG_220	15:49	16:38	0:49	LINE CLEAR AVAILED
617	1-Feb-2020	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	13:45	15:19	1:34	LINE CLEAR AVAILED
618	1-Feb-2020	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	17:02	17:24	0:21	LINE CLEAR AVAILED
619	1-Feb-2020	TUMKUR	220	TR-1	KBCROSS_220	14:07	14:12	0:04	MAIN SUPPLY FAILURE
620	1-Feb-2020	TUMKUR	220	TR-1	KBCROSS_220	17:02	17:24	0:21	MAIN SUPPLY FAILURE
621	1-Feb-2020	TUMKUR	220	TR-2	KBCROSS_220	14:07	17:02	2:54	MAIN SUPPLY FAILURE
622	1-Feb-2020	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	13:48	21:32	7:43	LINE FAULT
623	1-Feb-2020	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	5:57	6:40	0:42	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
624	1-Feb-2020	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110	5:57	6:16	0:19	LINE FAULT
625	1-Feb-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	5:57	6:14	0:17	LINE FAULT
626	1-Feb-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	14:58	15:09	0:10	HAND TRIPPED
627	1-Feb-2020	TUMKUR	110	TR-1(HV SIDE)	KBCROSS_220	13:50	14:13	0:22	HAND TRIPPED
628	1-Feb-2020	TUMKUR	110	TR-2	KBCROSS_220	13:50	22:13	8:23	LINE CLEAR AVAILED
629	1-Feb-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	13:50	15:14	1:24	LINE CLEAR AVAILED
630	1-Feb-2020	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	12:27	13:53	1:25	LINE FAULT
631	1-Feb-2020	TUMKUR	66	TR-2	BELLAVI_66	13:56	14:07	0:11	TRANSFORMER FAULT
632	1-Feb-2020	TUMKUR	66	CHELLUR-ANTHRASANAHALI	CHELURU_66	12:31	13:57	1:26	MAIN SUPPLY FAILURE
633	1-Feb-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	8:35	8:39	0:04	LINE FAULT
634	1-Feb-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	11:04	11:45	0:40	LINE FAULT
635	1-Feb-2020	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	5:27	7:39	2:11	LINE CLEAR AVAILED
636	1-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:27	9:31	0:03	LINE FAULT
637	1-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:35	12:55	2:20	LINE FAULT
638	1-Feb-2020	TUMKUR	66	TR-2	HANAGAL_66	18:41	18:49	0:07	TRANSFORMER FAULT
639	1-Feb-2020	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	18:41	18:50	0:08	LINE CLEAR AVAILED
640	1-Feb-2020	TUMKUR	66	HIREHALLI - BADDIHALLI	HIREHALLY_66	9:39	12:25	2:45	LINE CLEAR AVAILED
641	1-Feb-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	11:01	12:29	1:27	LINE CLEAR AVAILED
642	1-Feb-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	11:01	12:29	1:27	LINE CLEAR AVAILED
643	1-Feb-2020	TUMKUR	66	KUNDUR- RSOLAR	RENEW WIND ENERGY_IPP_66	12:53	13:01	0:07	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
644	1-Feb-2020	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	12:53	13:01	0:07	HAND TRIPPED
645	1-Feb-2020	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	14:24	18:58	4:34	MAIN SUPPLY FAILURE
646	1-Feb-2020	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	7:47	7:54	0:07	HAND TRIPPED
647	1-Feb-2020	TUMKUR	66	TR-2	MANGALWADA_66	14:03	14:48	0:44	TRANSFORMER FAULT
648	2-Feb-2020	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	21:28	21:40	0:12	LINE FAULT
649	2-Feb-2020	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	0:00	15:02	15:02	LINE CLEAR AVAILED
650	2-Feb-2020	BAGALKOT	110	110/33KV,HV 3	MAMADAPUR_110 &DEVAR GENNUR_33KV	13:07	13:13	0:06	TRANSFORMER FAULT
651	2-Feb-2020	BAGALKOT	110	CHIKKODI-NIPPANI	NIPPANI_110	5:53	11:24	5:31	LINE FAULT
652	2-Feb-2020	BAGALKOT	110	110/11KV,HV 3	SAVALAGI_110	8:50	17:09	8:19	TRANSFORMER FAULT
653	2-Feb-2020	BAGALKOT	110	110/11KV,HV 2	UGAR KHUD_110	0:26	1:02	0:36	TRANSFORMER FAULT
654	2-Feb-2020	BAGALKOT	110	110/11KV,HV 2	UGAR KHUD_110	16:23	16:44	0:21	HAND TRIPPED
655	2-Feb-2020	BAGALKOT	110	110/11KV,HV 2	VAJRAMATTI_110	6:08	6:14	0:06	TRANSFORMER FAULT
656	2-Feb-2020	BAGALKOT	110	110/11KV,HV 2	VAJRAMATTI_110	11:22	11:51	0:29	TRANSFORMER FAULT
657	2-Feb-2020	BENGALURU	66	HV2	VIJAYAPURA	17:55	18:30	0:35	LINE CLEAR AVAILED
658	2-Feb-2020	BENGALURU	66	HV1	ANEKAL	12:49	13:03	0:14	LINE CLEAR AVAILED
659	2-Feb-2020	BENGALURU	66	HV2	ANEKAL	12:25	12:46	0:21	LINE CLEAR AVAILED
660	2-Feb-2020	BENGALURU	66	HV2	MANCHENAHALLI	10:06	10:21	0:15	TRANSFORMER FAULT
661	2-Feb-2020	BENGALURU	66	HV2	VIJAYAPURA	17:55	18:31	0:36	LINE CLEAR AVAILED
662	2-Feb-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	6:42	7:31	0:49	LINE FAULT
663	2-Feb-2020	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	15:15	15:20	0:05	LOAD CHANGEOVER
664	2-Feb-2020	BENGALURU	66	PLATINUM CITY - DG 4	PLATINUM CITY	22:35	22:40	0:05	LOAD CHANGEOVER
665	2-Feb-2020	BENGALURU	66	HV1	D CROSS	7:07	7:18	0:11	TRANSFORMER FAULT
666	2-Feb-2020	BENGALURU	66	HV2	PRESTIGE SHANTHINIKETHAN	7:23	7:28	0:05	LINE CLEAR AVAILED
667	2-Feb-2020	BENGALURU	66	NELAMANGALA 66 - ALUR	NELMANGALA 66	5:03	5:10	0:07	LOAD CHANGEOVER
668	2-Feb-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELMANGALA 66	20:30	20:40	0:10	LOAD CHANGEOVER
669	2-Feb-2020	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	15:47	15:52	0:05	LOAD CHANGEOVER
670	2-Feb-2020	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR	20:32	20:40	0:08	LOAD CHANGEOVER
671	2-Feb-2020	BENGALURU	66	KENGERI SATELLITE TOWN -KUMBALAGODU	KENGERI SATELLITE TOWN	20:05	20:07	0:02	LOAD CHANGEOVER
672	2-Feb-2020	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	10:19	10:29	0:10	LOAD CHANGEOVER
673	2-Feb-2020	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	18:36	18:44	0:08	LOAD CHANGEOVER
674	2-Feb-2020	BENGALURU	66	REMCO - SUBRAMANYAPURA 220	REMCO	20:10	20:18	0:08	LOAD CHANGEOVER
675	2-Feb-2020	BENGALURU	66	HV2	ANDERSONPETE	10:35	12:45	2:10	LINE CLEAR AVAILED
676	2-Feb-2020	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	18:32	18:52	0:20	MAIN SUPPLY FAILURE
677	2-Feb-2020	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	20:11	20:20	0:09	LOAD CHANGEOVER
678	2-Feb-2020	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	18:34	19:20	0:46	MAIN SUPPLY FAILURE
679	2-Feb-2020	BENGALURU	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT), HMT (EHT)	18:34	19:20	0:46	MAIN SUPPLY FAILURE
680	2-Feb-2020	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA, BEL (EHT), HMT (EHT)	19:40	19:55	0:15	LOAD CHANGEOVER

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
681	2-Feb-2020	BENGALURU	66	GOKULA - MATHIKERE	MATHIKERE	18:32	19:58	1:26	LINE FAULT
682	2-Feb-2020	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	18:33	19:20	0:47	LINE FAULT
683	2-Feb-2020	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	18:33	19:20	0:47	LINE FAULT
684	2-Feb-2020	GULBARGA	220	SHAHAPUR-SHORAPUR	SHORAPUR_110	0:25	0:49	0:24	LINE FAULT
685	2-Feb-2020	GULBARGA	220	SHAHAPUR-LINGASUGUR	LINGASUGUR_220	5:18	10:00	4:42	LINE FAULT
686	2-Feb-2020	GULBARGA	220	SHAHAPUR-SHORAPUR	SHORAPUR_110	22:32	22:38	0:06	LINE FAULT
687	2-Feb-2020	GULBARGA	220	SHAHAPUR-SHORAPUR	SHORAPUR_110	23:40	23:43	0:03	LINE FAULT
688	2-Feb-2020	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	MUKUNDA_110, KAMPLI_GLB_110, YERADONA_110, MALLAPURA_110, SRERAMANAGAR_110	3:25	3:38	0:13	LINE FAULT
689	2-Feb-2020	GULBARGA	110	HV1	HANUMANAL_110	14:10	14:20	0:10	TRANSFORMER FAULT
690	2-Feb-2020	GULBARGA	110	HV1	HANUMANAL_110	15:15	16:10	0:55	LINE CLEAR AVAILED
691	2-Feb-2020	GULBARGA	110	HV2	SHAKTINAGAR_110	4:50	5:34	0:44	TRANSFORMER FAULT
692	2-Feb-2020	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	6:44	7:01	0:17	LINE FAULT
693	2-Feb-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA-400	13:04	16:27	3:23	LINE CLEAR AVAILED
694	2-Feb-2020	HASSAN	110	MRSSHM-BADRAVATY1	MRSMG_220	9:04	11:12	2:08	LINE CLEAR AVAILED
695	2-Feb-2020	HASSAN	110	MRSSHM-BADRAVATY2	MRSMG_220	4:07	11:12	7:05	LINE FAULT
696	2-Feb-2020	HASSAN	110	ALKOLA-MRS	ALKOLA_110	10:05	10:19	0:14	LINE FAULT
697	2-Feb-2020	HASSAN	110	HV2	NAVUNDA_110	10:54	18:33	7:39	LINE CLEAR AVAILED
698	2-Feb-2020	HASSAN	110	HV1	SHIKARIPURA_110	10:09	17:32	7:23	LINE CLEAR AVAILED
699	2-Feb-2020	HASSAN	110	HV2	SHIKARIPURA_110	15:00	17:00	2:00	LINE CLEAR AVAILED
700	2-Feb-2020	HASSAN	66	HV2	HALEBEEDU_66	11:55	12:01	0:06	TRANSFORMER FAULT
701	2-Feb-2020	HASSAN	66	HV2	HASSAN_66	0:00	14:09	14:09	TRANSFORMER FAULT
702	2-Feb-2020	HASSAN	66	HV1	HNPURA_66	12:14	13:02	0:48	LINE CLEAR AVAILED
703	2-Feb-2020	HASSAN	66	HV2	UDAYAPURA_66	8:47	8:51	0:04	TRANSFORMER FAULT
704	2-Feb-2020	HASSAN	66	UDDUR	UDDURKOPLU_66	2:25	2:38	0:13	LINE FAULT
705	2-Feb-2020	MYSORE	66	HAMPAPURA-BASARALU	BESAGARAHALLI_66, BASARALU_66, KOPPA_66	9:06	9:17	0:11	LINE FAULT
706	2-Feb-2020	MYSORE	66	HV2	HARVEY_66	12:17	12:31	0:13	TRANSFORMER FAULT
707	2-Feb-2020	MYSORE	66	KR PETE 220-BOOKANAKERE	BANANGADI_66, BOOKANAKERE_66, CHINAKURALI_66, GANJIGERE_66, SHEELUNERE_66	9:29	11:06	1:37	LINE FAULT
708	2-Feb-2020	MYSORE	66	HV2	KRPET_220	9:24	10:17	0:53	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
709	2-Feb-2020	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	6:19	6:25	0:05	LINE FAULT
710	2-Feb-2020	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	9:24	10:18	0:54	LINE FAULT
711	2-Feb-2020	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	10:36	10:42	0:05	LINE FAULT
712	2-Feb-2020	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	13:28	13:42	0:14	LINE FAULT
713	2-Feb-2020	MYSORE	220	HV1	KUSHALNAGARA_220	10:17	17:41	7:23	LINE CLEAR AVAILED
714	2-Feb-2020	MYSORE	220	HV1	KUSHALNAGARA_220	10:17	17:41	7:24	LINE CLEAR AVAILED
715	2-Feb-2020	MYSORE	66	KUSHALANAGARA 220-RAMANTHAPURA 1	SOMWARPETE_33	9:06	18:15	9:09	LINE CLEAR AVAILED
716	2-Feb-2020	TUMKUR	66	TR-1	TURUVEKERE_110	22:41	22:50	0:08	TRANSFORMER FAULT
717	2-Feb-2020	TUMKUR	66	TR-2	BELLAVI_66	7:50	8:09	0:19	TRANSFORMER FAULT
718	2-Feb-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	0:33	0:43	0:10	LINE FAULT
719	2-Feb-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	8:50	8:59	0:08	LINE FAULT
720	2-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:09	12:40	1:30	LINE FAULT
721	2-Feb-2020	TUMKUR	66	HIREHALLI - BADDIHALLI	HIREHALLY_66	13:21	16:34	3:13	LINE CLEAR AVAILED
722	2-Feb-2020	TUMKUR	66	TR-1	KATTIGE_66	9:04	9:26	0:22	HAND TRIPPED
723	2-Feb-2020	TUMKUR	66	TR-2	MANGALWADA_66	8:57	9:02	0:05	TRANSFORMER FAULT
724	2-Feb-2020	TUMKUR	66	TR-2	HARIYABBE_66	8:25	10:03	1:38	LINE CLEAR AVAILED
725	3-Feb-2020	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	7:38	8:01	0:23	LOAD CURTAILMENT
726	3-Feb-2020	BAGALKOT	110	110/11KV,HV 1	BETAGERI_110	2:14	2:27	0:13	TRANSFORMER FAULT
727	3-Feb-2020	BAGALKOT	110	110/11KV,HV 1	BILAGI_110	17:54	18:05	0:11	TRANSFORMER FAULT
728	3-Feb-2020	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	0:57	2:08	1:11	LINE CLEAR AVAILED
729	3-Feb-2020	BAGALKOT	220	BIDNAL-HUBLI 1	BIDNAL_220	1:00	11:37	10:37	LINE CLEAR AVAILED
730	3-Feb-2020	BAGALKOT	220	BIDNAL-HUBLI 3	BIDNAL_220	1:01	2:11	1:10	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
731	3-Feb-2020	BAGALKOT	220	CHIKKODI-SANKESHWAR	SNAKESHWAR_110	14:35	14:47	0:12	LINE FAULT
732	3-Feb-2020	BAGALKOT	110	RON -HIREHAL	HIREHAL_110	21:05	23:59	2:54	LINE FAULT
733	3-Feb-2020	BAGALKOT	110	HUKKERI-VISHWANATH SUGARS	HUKKERI_110	14:57	15:00	0:03	LINE FAULT
734	3-Feb-2020	BAGALKOT	110	110/33KV,HV2	UTTUR_110,VANTAGODI_33,YADAWAD_33	4:16	4:28	0:12	TRANSFORMER FAULT
735	3-Feb-2020	BAGALKOT	110	HUBLI-BIDNAL2	BIDNAL_220	0:26	0:27	0:01	LINE CLEAR AVAILED
736	3-Feb-2020	BAGALKOT	110	220/110KV,LV1&LV2	RAMANAKOPP_110,PH COMPOUND_110,ANANDANAGAR_110,BIDNAL2_110,TARIHAL2_110,KALAGAT AGI_110,KADANAKOPPA_110	14:59	15:28	0:29	HAND TRIPPED
737	3-Feb-2020	BAGALKOT	110	HUBLI220-TARIHAL1	TARIHAL_110	14:58	16:00	1:02	LINE CLEAR AVAILED
738	3-Feb-2020	BAGALKOT	110	110/11KV,HV1&HV2	HUBLI_220	15:00	15:10	0:10	HAND TRIPPED
739	3-Feb-2020	BAGALKOT	110	HUBLI220-RAMANAKOPPA	RAMANAKOPP_110	1:56	1:58	0:02	LINE CLEAR AVAILED
740	3-Feb-2020	BAGALKOT	110	110/11KV,HV1	SIRSI_110	11:47	12:03	0:16	LINE CLEAR AVAILED
741	3-Feb-2020	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	11:07	11:25	0:18	LINE CLEAR AVAILED
742	3-Feb-2020	BAGALKOT	110	110/11KV,HV3	HUNGUND_110, KARADI_33, AMINGADA_33	6:43	6:50	0:07	TRANSFORMER FAULT
743	3-Feb-2020	BAGALKOT	110	110/11KV,HV3	HUNGUND_110, KARADI_33, AMINGADA_33	16:42	16:49	0:07	TRANSFORMER FAULT
744	3-Feb-2020	BAGALKOT	110	110/11KV,HV4	KERUR_110	19:25	19:59	0:34	TRANSFORMER FAULT
745	3-Feb-2020	BAGALKOT	110	110/11KV,HV4	KERUR_110	22:35	23:47	1:12	LINE CLEAR AVAILED
746	3-Feb-2020	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	11:06	12:49	1:43	LINE CLEAR AVAILED
747	3-Feb-2020	BAGALKOT	110	110/11KV,HV2	PH COMPOUND_110	10:27	23:59	13:32	LINE CLEAR AVAILED
748	3-Feb-2020	BAGALKOT	110	PG HUNSHYAL-MUDALGI	MUDALGI_110	12:50	13:10	0:20	LINE CLEAR AVAILED
749	3-Feb-2020	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	14:53	14:55	0:02	HAND TRIPPED
750	3-Feb-2020	BENGALURU	66	KORAMANGALA 220 - HAL 1	GOLF LINK	15:21	16:08	0:47	LINE FAULT
751	3-Feb-2020	BENGALURU	66	HV2	MATHIKERE	16:53	17:12	0:19	LINE CLEAR AVAILED
752	3-Feb-2020	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	17:30	17:35	0:05	LOAD CHANGE OVER
753	3-Feb-2020	BENGALURU	66	HV3	ADUGODI	11:57	12:54	0:56	LINE CLEAR AVAILED
754	3-Feb-2020	BENGALURU	66	HV1	AMARJYOTHI	16:26	16:30	0:03	LOAD CHANGE OVER
755	3-Feb-2020	BENGALURU	66	HV1	SIDDALAGATTA	17:33	17:44	0:11	LINE CLEAR AVAILED
756	3-Feb-2020	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	15:24	15:29	0:05	TRANSFORMER FAULT
757	3-Feb-2020	BENGALURU	66	AUSTIN TOWN - EDC 220	AUSTIN TOWN	12:25	12:25	0:00	LOAD CHANGE OVER
758	3-Feb-2020	BENGALURU	66	HAL 220 - HOODY 1	HAL 220, EDC 220	15:41	16:05	0:23	LINE FAULT
759	3-Feb-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:25	17:50	2:24	LINE CLEAR AVAILED
760	3-Feb-2020	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	12:02	12:16	0:14	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
761	3-Feb-2020	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	20:20	20:26	0:05	LINE CLEAR AVAILED
762	3-Feb-2020	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	12:02	12:24	0:21	LINE CLEAR AVAILED
763	3-Feb-2020	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	14:27	14:38	0:10	LINE FAULT
764	3-Feb-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	12:02	12:16	0:14	LINE CLEAR AVAILED
765	3-Feb-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	20:20	20:26	0:05	LINE CLEAR AVAILED
766	3-Feb-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	12:02	12:16	0:14	LINE CLEAR AVAILED
767	3-Feb-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	20:20	20:26	0:06	LINE CLEAR AVAILED
768	3-Feb-2020	BENGALURU	66	SIDLAGATTA - MELUR	MELUR	18:04	18:10	0:05	LINE CLEAR AVAILED
769	3-Feb-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	7:04	8:10	1:06	LOAD CURTAILMENT
770	3-Feb-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DAALSNUR	14:08	14:18	0:10	LINE FAULT
771	3-Feb-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DAALSNUR	15:25	17:50	2:24	LINE CLEAR AVAILED
772	3-Feb-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	7:11	7:23	0:12	LOAD CURTAILMENT
773	3-Feb-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	7:11	7:23	0:12	LOAD CURTAILMENT
774	3-Feb-2020	BENGALURU	66	KEMBODI - KOLAR 220	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	15:30	18:10	2:40	LOAD CURTAILMENT
775	3-Feb-2020	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	15:30	18:30	3:00	LOAD CURTAILMENT
776	3-Feb-2020	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	3:34	3:44	0:10	LINE FAULT
777	3-Feb-2020	GULBARGA	110	HV1	MANVI_110	13:25	13:34	0:09	TRANSFORMER FAULT
778	3-Feb-2020	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	6:01	7:00	0:59	LINE FAULT
779	3-Feb-2020	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	7:00	10:27	3:27	LINE CLEAR AVAILED
780	3-Feb-2020	GULBARGA	110	HV3	SHAHAPUR_220	11:51	12:35	0:44	TRANSFORMER FAULT
781	3-Feb-2020	GULBARGA	110	SINDHANOOR1-MANVI	MANVI_110	6:40	6:57	0:17	MAIN SUPPLY FAILURE
782	3-Feb-2020	GULBARGA	110	HV2	MANVI_110	9:05	9:15	0:10	TRANSFORMER FAULT
783	3-Feb-2020	GULBARGA	110	HV2	MANVI_110	9:20	9:25	0:05	TRANSFORMER FAULT
784	3-Feb-2020	GULBARGA	110	HV1	TEKKALKOTE_110	11:01	11:06	0:05	TRANSFORMER FAULT
785	3-Feb-2020	GULBARGA	220	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	12:25	14:40	2:15	LINE CLEAR AVAILED
786	3-Feb-2020	GULBARGA	220	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	6:04	6:26	0:22	LINE FAULT
787	3-Feb-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	5:30	5:45	0:15	LINE FAULT
788	3-Feb-2020	GULBARGA	110	SINDHANOOR-SINDHANOOR1	MASKI_110,MUDDAPUR_110	6:44	6:58	0:14	LINE FAULT
789	3-Feb-2020	GULBARGA	66	ITTAGI-TBHALLI	HAMPASAGAR_66,MORAGERE_66,TAM BRAHALLI_66	17:36	17:45	0:09	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
790	3-Feb-2020	GULBARGA	66	ITTAGI-KUDLIGI1,2	KUDLIGI_66,KOGALI_66,HANASI_66, CJHALLI_66,GUDEKOTE_66,HOSAHALLI_66, BANAVEKAL_66,CHORNOOR_66	17:40	18:02	0:22	LINE CLEAR AVAILED
791	3-Feb-2020	GULBARGA	220	HV1	ITTAGI_220	11:05	23:59	12:54	LINE CLEAR AVAILED
792	3-Feb-2020	GULBARGA	66	GUDEKOTET-KUDLIGI	GUDEKOTE_66	17:40	18:15	0:35	MAIN SUPPLY FAILURE
793	3-Feb-2020	GULBARGA	66	GUDEKOTET-KUDLIGI	GUDEKOTE_66	18:25	18:34	0:09	MAIN SUPPLY FAILURE
794	3-Feb-2020	GULBARGA	110	HV3	DEODURGA_110	12:50	14:00	1:10	LINE CLEAR AVAILED
795	3-Feb-2020	GULBARGA	110	HV3	BEVOOR_110	8:29	8:37	0:08	TRANSFORMER FAULT
796	3-Feb-2020	GULBARGA	110	HUMNABAD-BHALKI-1	BHALKI_110,LADHA_110	18:57	19:43	0:46	LINE FAULT
797	3-Feb-2020	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	18:17	18:32	0:15	LINE FAULT
798	3-Feb-2020	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	3:34	3:44	0:10	LINE FAULT
799	3-Feb-2020	GULBARGA	110	HV1	MANVI_110	13:25	13:34	0:09	TRANSFORMER FAULT
800	3-Feb-2020	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	6:01	7:00	0:59	LINE FAULT
801	3-Feb-2020	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	7:00	10:27	3:27	LINE CLEAR AVAILED
802	3-Feb-2020	GULBARGA	110	HV3	SHAHAPUR_220	11:51	12:35	0:44	TRANSFORMER FAULT
803	3-Feb-2020	GULBARGA	110	SINDHANOOR1-MANVI	MANVI_110	6:40	6:57	0:17	MAIN SUPPLY FAILURE
804	3-Feb-2020	GULBARGA	110	HV2	MANVI_110	9:05	9:15	0:10	TRANSFORMER FAULT
805	3-Feb-2020	GULBARGA	110	HV2	MANVI_110	9:20	9:25	0:05	TRANSFORMER FAULT
806	3-Feb-2020	GULBARGA	110	HV1	TEKKALKOTE_110	11:01	11:06	0:05	TRANSFORMER FAULT
807	3-Feb-2020	GULBARGA	220	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	12:25	14:40	2:15	LINE CLEAR AVAILED
808	3-Feb-2020	GULBARGA	220	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	6:04	6:26	0:22	LINE FAULT
809	3-Feb-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	5:30	5:45	0:15	LINE FAULT
810	3-Feb-2020	GULBARGA	110	SINDHANOOR-SINDHANOOR1	MASKI_110,MUDDAPUR_110	6:44	6:58	0:14	LINE FAULT
811	3-Feb-2020	GULBARGA	66	ITTAGI-TBHALLI	HAMPASAGAR_66,MORAGERE_66,TAM BRAHALLI_66	17:36	17:45	0:09	LINE CLEAR AVAILED
812	3-Feb-2020	GULBARGA	66	ITTAGI-KUDLIGI1,2	KUDLIGI_66,KOGALI_66,HANASI_66, CJHALLI_66,GUDEKOTE_66,HOSAHALLI_66, BANAVEKAL_66,CHORNOOR_66	17:40	18:02	0:22	LINE CLEAR AVAILED
813	3-Feb-2020	GULBARGA	220	HV1	ITTAGI_220	11:05	23:59	12:54	LINE CLEAR AVAILED
814	3-Feb-2020	GULBARGA	66	GUDEKOTET-KUDLIGI	GUDEKOTE_66	17:40	18:15	0:35	MAIN SUPPLY FAILURE
815	3-Feb-2020	GULBARGA	66	GUDEKOTET-KUDLIGI	GUDEKOTE_66	18:25	18:34	0:09	MAIN SUPPLY FAILURE
816	3-Feb-2020	GULBARGA	110	HV3	DEODURGA_110	12:50	14:00	1:10	LINE CLEAR AVAILED
817	3-Feb-2020	GULBARGA	110	HV3	BEVOOR_110	8:29	8:37	0:08	TRANSFORMER FAULT
818	3-Feb-2020	GULBARGA	110	HUMNABAD-BHALKI-1	BHALKI_110,LADHA_110	18:57	19:43	0:46	LINE FAULT
819	3-Feb-2020	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	18:17	18:32	0:15	LINE FAULT
820	3-Feb-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:10	17:18	4:08	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
821	3-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	10:52	12:11	1:19	LINE CLEAR AVAILED
822	3-Feb-2020	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	10:52	12:11	1:19	LINE CLEAR AVAILED
823	3-Feb-2020	HASSAN	110	HV1	ARASIKERE_110	14:29	15:42	1:13	LINE CLEAR AVAILED
824	3-Feb-2020	HASSAN	110	KADUR-YGTI	KADUR_220	10:13	12:18	2:05	LINE CLEAR AVAILED
825	3-Feb-2020	HASSAN	110	HV2	KARAYA_110	11:26	12:38	1:12	LINE CLEAR AVAILED
826	3-Feb-2020	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	11:20	19:39	8:19	LINE CLEAR AVAILED
827	3-Feb-2020	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	15:35	16:17	0:42	LINE CLEAR AVAILED
828	3-Feb-2020	HASSAN	66	HV1	DODDAKADANUR_66	12:42	13:10	0:28	MAIN SUPPLY FAILURE
829	3-Feb-2020	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	13:03	13:38	0:35	HAND TRIPPED
830	3-Feb-2020	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	12:39	13:07	0:28	LINE CLEAR AVAILED
831	3-Feb-2020	HASSAN	66	HV1	HOLALUR_66	8:57	9:30	0:33	LINE CLEAR AVAILED
832	3-Feb-2020	HASSAN	66	HV1	RAMPURA_66	8:02	8:12	0:10	TRANSFORMER FAULT
833	3-Feb-2020	MYSORE	66	HV2	ADDIHALLI_66	18:13	23:59	5:45	TRANSFORMER FAULT
834	3-Feb-2020	MYSORE	66	HV1	DKMAIDANA_66	13:22	13:45	0:22	LINE CLEAR AVAILED
835	3-Feb-2020	MYSORE	66	HV1	HEBBAL	15:07	15:42	0:35	LINE CLEAR AVAILED
836	3-Feb-2020	MYSORE	66	HV2	HOOTAGALLY_220	16:49	17:04	0:15	TRANSFORMER FAULT
837	3-Feb-2020	MYSORE	66	HV2	HOOTAGALLY_220	17:04	17:06	0:01	TRANSFORMER FAULT
838	3-Feb-2020	MYSORE	66	HV2	HOOTAGALLY_220	17:06	17:13	0:07	TRANSFORMER FAULT
839	3-Feb-2020	MYSORE	66	HV2	HOOTAGALLY_220	17:16	17:19	0:02	TRANSFORMER FAULT
840	3-Feb-2020	MYSORE	66	HUNSUR-HOOTAGALLI	HUNSUR_66	7:22	18:39	11:16	LINE CLEAR AVAILED
841	3-Feb-2020	MYSORE	66	HV1	HUNSUR_66	21:21	21:23	0:01	TRANSFORMER FAULT
842	3-Feb-2020	MYSORE	66	HUNSUR-ELWALA	HUNSUR_66	7:23	18:39	11:16	LINE CLEAR AVAILED
843	3-Feb-2020	MYSORE	66	KOLLEGALA-TALAKADU	PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	3:02	3:12	0:09	LINE FAULT
844	3-Feb-2020	MYSORE	66	KR PETE 220-BOOKANAKERE	GANJIGERE_66 SHEELUNERE_66 BOOKANAKERE_66 CHINAKURALI_66 BANANGADI_66	13:33	13:38	0:04	LINE FAULT
845	3-Feb-2020	MYSORE	66	HV4	SFCSHIVA_66	12:26	18:09	5:42	LINE CLEAR AVAILED
846	3-Feb-2020	MYSORE	66	HV1	SUNTIKOPPA_66	10:02	16:58	6:56	LINE CLEAR AVAILED
847	3-Feb-2020	TUMKUR	110	TR-1	BIDARE_110	3:08	3:12	0:03	TRANSFORMER FAULT
848	3-Feb-2020	TUMKUR	110	TR-1	DODDAGUNI_110	9:05	9:25	0:20	TRANSFORMER FAULT
849	3-Feb-2020	TUMKUR	110	TR-1& TR-2	KBCROSS_220	11:09	12:55	1:46	LINE CLEAR AVAILED
850	3-Feb-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	2:24	2:39	0:14	LINE FAULT
851	3-Feb-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	8:17	14:04	5:46	LINE CLEAR AVAILED
852	3-Feb-2020	TUMKUR	66	TR-2	AVAREGERE_66	9:30	9:45	0:14	TRANSFORMER FAULT
853	3-Feb-2020	TUMKUR	66	TR-1	BANUVALLI_66	9:27	9:35	0:08	HAND TRIPPED
854	3-Feb-2020	TUMKUR	66	TR-1	DAVANGERE_SRS_220	16:02	16:21	0:18	LINE CLEAR AVAILED
855	3-Feb-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	17:52	18:05	0:12	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
856	3-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:07	9:15	0:07	LINE FAULT
857	3-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	14:14	14:26	0:11	LINE FAULT
858	3-Feb-2020	TUMKUR	66	TR-2	HARAPPANAHALLI_66	12:12	15:21	3:09	LINE CLEAR AVAILED
859	3-Feb-2020	TUMKUR	66	TR-2	HARIYABBE_66	10:00	10:10	0:09	TRANSFORMER FAULT
860	3-Feb-2020	TUMKUR	66	TR-2	HIREGUNTANUR_66	0:02	0:04	0:01	TRANSFORMER FAULT
861	3-Feb-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUND A_66	7:20	7:27	0:06	LINE FAULT
862	3-Feb-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUND A_66	7:51	7:58	0:06	LINE FAULT
863	3-Feb-2020	TUMKUR	66	TR-2	KUKKAWADA_66	16:31	18:25	1:54	LINE CLEAR AVAILED
864	3-Feb-2020	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	7:10	7:13	0:03	LOAD CURTAILMENT
865	3-Feb-2020	TUMKUR	66	MADHUGIRI 220kV- SIRA 2	KALLAMBELLA_66, BUKKAPATNA_66	7:20	8:15	0:55	LOAD CURTAILMENT
866	3-Feb-2020	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	7:10	8:06	0:55	LOAD CURTAILMENT
867	3-Feb-2020	TUMKUR	66	TR-1	MEDIGESHI_66	13:00	14:05	1:05	LINE CLEAR AVAILED
868	3-Feb-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	8:55	9:13	0:18	LINE FAULT
869	3-Feb-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	7:17	13:50	6:33	LINE CLEAR AVAILED
870	3-Feb-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	18:18	18:21	0:02	TRANSFORMER FAULT