

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM: 11.05.21 TO 17.05.2021

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	11/May/2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
2	11/May/2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
3	11/May/2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
4	11/May/2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
5	11/May/2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
6	11/May/2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
7	11/May/2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
8	11/May/2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
9	11/May/2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19(20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
10	11/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	14:15 (04.05.2021)			LINE OPEN,LINE CLEAR AVAILED
11	11/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	14:16 (04.05.2021)			LINE OPEN,LINE CLEAR AVAILED
12	11/May/2021	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	23:52 (10.05.2021)	0:05 (11.05.2021)	0:13HRS	LINE CHARGED
13	11/May/2021	BAGALKOT	110	HAVERI-HANAGAL(TILUVALI)	HANAGAL_110	18:18 (10.05.2021)	8:36 (11.05.2021)	14:18HRS	LINE CHARGED
14	11/May/2021	BAGALKOT	220	BIDNAL-HUBLI1	STATION NOT AFFECTED BIDNAL_220	18:46 (10.05.2021)	7:50 (11.05.2021)	13:04HRS	LINE CHARGED
15	11/May/2021	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	18:07 (10.05.2021)	15:33 (11.05.2021)	21:26HRS	LINE CHARGED
16	11/May/2021	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	6:42	6:44	0:02	TRANSFORMER FAULT
17	11/May/2021	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	10:29	11:55	1:26	NFBC ISSUED
18	11/May/2021	BAGALKOT	110	BIJAPUR220-ENERCON	BIJAPUR_220	16:05	16:07	0:02	LINE FAULT
19	11/May/2021	BAGALKOT	220	CHIKKODI-BELGAUM1	CHIKKODI_220	10:29	11:55	1:26	LINE CLEAR AVAILED
20	11/May/2021	BAGALKOT	220	CHIKKODI-(KOLHAPUR2)MUDASHINGI	CHIKKODI_220	11:17	13:16	1:59	LINE CLEAR AVAILED
21	11/May/2021	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,AMENAGAD_33,KARAI_33,MYTRA SOLAR_33	17:33	17:40	0:07	TRANSFORMER FAULT
22	11/May/2021	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	14:08	14:14	0:06	TRANSFORMER FAULT
23	11/May/2021	BAGALKOT	110	110/11KV,HV2	LAXMESHWAR_110	13:45	14:40	0:55	LINE CLEAR AVAILED
24	11/May/2021	BAGALKOT	110	MK HUBLI-KITTUR	MK HUBLI_110	17:49	19:18	1:29	LINE FAULT
25	11/May/2021	BAGALKOT	110	110/11KV,HV4	KERUR_110	7:10	7:26	0:16	LINE CLEAR AVAILED
26	11/May/2021	BAGALKOT	110	110/33KV, HV4	HALASANGI_33, DULAKHED_33, NEVARGI_33 STATION NOT AFFECTED ZALKI_110	11:33	11:41	0:08	TRANSFORMER FAULT
27	11/May/2021	BAGALKOT	110	110/33KV, HV4	HALASANGI_33, DULAKHED_33, NEVARGI_33 STATION NOT AFFECTED ZALKI_110	11:56	12:04	0:08	TRANSFORMER FAULT
28	11/May/2021	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	15:33	16:05	0:32	LINE FAULT
29	11/May/2021	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	16:06 (11.05.2021)			LINE OPEN,LINE FAULT
30	11/May/2021	BAGALKOT	220	HUBLI-NAGZARI3	STATION NOT AFFECTED HUBLI_220	10:46	15:23	4:37	LINE CLEAR AVAILED
31	11/May/2021	BAGALKOT	110	110/33KV, HV3	SHIGGAON_33, AMBUJA_33, KPCL SOLAR_33 STATION NOT AFFECTED SHIGGAON_110	10:18	10:25	0:07	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
32	11/May/2021	BAGALKOT	110	110/11KV, HV2 (HV3)	STATION NOT AFFECTED MUNDARGI_110	22:38	23:43	1:05	TRANSFORMER FAULT
33	11/May/2021	BAGALKOT	110	MUNDAGOD-HUBLI220	STATION NOT AFFECTED MUNDAGOD_110	17:30 (10.05.2021)	8:21 (11.05.2021)	14:51HRS	LINE CHARGED
34	11/May/2021	BAGALKOT	110	MUKARTIHAL-KODANGAL SOLAR (SPV)	KODANGAL SOLAR_110 STATION NOT AFFECTED MUKARTIHAL_110	13:08	13:13	0:05	LINE FAULT
35	11/May/2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	19:28	19:58	0:30	MAIN SUPPLY FAILURE
36	11/May/2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	19:28	19:58	0:30	MAIN SUPPLY FAILURE
37	11/May/2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	19:28	19:58	0:30	MAIN SUPPLY FAILURE
38	11/May/2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	19:28	19:58	0:30	MAIN SUPPLY FAILURE
39	11/May/2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	19:28	19:58	0:30	MAIN SUPPLY FAILURE
40	11/May/2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	19:28	19:58	0:30	MAIN SUPPLY FAILURE
41	11/May/2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	19:28	19:58	0:30	MAIN SUPPLY FAILURE
42	11/May/2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	19:28	19:58	0:30	MAIN SUPPLY FAILURE
43	11/May/2021	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 1	MITTEMARI 220	19:28	19:51	0:23	LINE FAULT
44	11/May/2021	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	MITTEMARI 220	19:28	19:51	0:23	LINE FAULT
45	11/May/2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	19:28	19:51	0:23	LINE FAULT
46	11/May/2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	MITTEMARI 220	19:28	19:51	0:23	LINE FAULT
47	11/May/2021	BENGALURU	66	HV1	HOODY 220	10:42	14:50	4:08	TRANSFORMER FAULT
48	11/May/2021	BENGALURU	66	SRINIVASPURA - DALASNUR	SRINIVASPURA	7:25	7:45	0:20	LOAD CHANGE OVER
49	11/May/2021	BENGALURU	66	SRINIVASPURA - CHINTAMANI	SRINIVASPURA	9:25	9:40	0:15	LOAD CHANGE OVER
50	11/May/2021	BENGALURU	66	KODIHALLI - CHINTAMANI 220	KODIHALLI	7:25	7:35	0:10	LINE CLEAR AVOIDED
51	11/May/2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	19:05	19:20	0:15	LINE FAULT
52	11/May/2021	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	12:45	13:15	0:30	LINE FAULT
53	11/May/2021	BENGALURU	66	HV1	KYALANUR	18:15	18:40	0:25	TRANSFORMER FAULT
54	11/May/2021	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	7:41	7:48	0:07	LINE FAULT
55	11/May/2021	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	5:50	6:25	0:35	LINE FAULT
56	11/May/2021	BENGALURU	66	HV1	BOODIGERE	21:55	22:45	0:50	LINE CLEAR AVOIDED
57	11/May/2021	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK (EHT)	18:21	18:35	0:14	LINE FAULT
58	11/May/2021	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	NO STATION AFFECTED	16:04	16:16	0:12	LINE FAULT
59	11/May/2021	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	NO STATION AFFECTED	9:03	9:23	0:20	LINE FAULT
60	11/May/2021	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	NO STATION AFFECTED	14:40	14:52	0:12	LINE FAULT
61	11/May/2021	BENGALURU	66	HV3	DEVANAHALLI	19:41	19:45	0:04	TRANSFORMER FAULT
62	11/May/2021	BENGALURU	66	BIDADI 220 - RAMANAGARA	NO STATION AFFECTED	21:02:00(10/05/2021)	14:07(11.5.21)	17:09HRS	LINE CHARGED
63	11/May/2021	GULBARGA	220	BTPS-LINGAPUR	LINGAPUR_220	20:22(11.05.2021)			LINE OPEN,LINE FAULT
64	11/May/2021	GULBARGA	220	HV1	HALBARGA_220	16:19	16:27	0:08	LINE CLEAR AVOIDED
65	11/May/2021	GULBARGA	220	HV1	HALBARGA_220	8:19	8:26	0:07	LINE CLEAR AVOIDED
66	11/May/2021	GULBARGA	220	HV1	MALLAT_220	14:39	17:27	2:48	TRANSFORMER FAULT
67	11/May/2021	GULBARGA	110	HV1	ALIPUR_220	19:11(11.05.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
68	11/May/2021	GULBARGA	110	HALBARGA-KOLHAR2	KOLHAR_110	13:26	13:58	0:32	NFBC ISSUED
69	11/May/2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	7:51	20:29	12:38	LINE FAULT
70	11/May/2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	20:25	20:29	0:04	LINE FAULT
71	11/May/2021	GULBARGA	110	SINDHNOOR-MUNIRABAD	MUKUNDA_110,KAMPLI_110,YERADONA_110,SRN AGAR_110,MALLAPUR_110	20:35	20:45	0:10	LINE FAULT
72	11/May/2021	GULBARGA	110	SINDHNOOR-SUZLON_IPP	SINDHNOOR_220	23:44	23:54	0:10	LINE FAULT
73	11/May/2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	8:11	9:39	1:28	LINE CLEAR AVOIDED
74	11/May/2021	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	8:14	9:39	1:25	LINE CLEAR AVOIDED
75	11/May/2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	8:18	9:40	1:22	LINE CLEAR AVOIDED
76	11/May/2021	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	8:19	9:40	1:21	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
77	11/May/2021	GULBARGA	110	HV2	SHAHAPUR_220	15:48	16:06	0:18	TRANSFORMER FAULT
78	11/May/2021	GULBARGA	110	HV2	SHAHAPUR_220	16:30	16:39	0:09	TRANSFORMER FAULT
79	11/May/2021	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	4:39	4:46	0:07	LINE FAULT
80	11/May/2021	GULBARGA	110	HV2	DEODURGA_110	13:15	13:22	0:07	TRANSFORMER FAULT
81	11/May/2021	GULBARGA	110	HV2	DEODURGA_110	15:05	15:23	0:18	TRANSFORMER FAULT
82	11/May/2021	GULBARGA	110	RAICHUR-DEODURGA	DEODURGA_110	20:20	20:35	0:15	MAIN SUPPLY FAILURE
83	11/May/2021	GULBARGA	110	HALBARGA-KOLHAR	KOLHAR_110	12:10	12:25	0:15	LINE CLEAR AVAILED
84	11/May/2021	GULBARGA	110	HALBARGA-KOLHAR	KOLHAR_110	12:50	12:55	0:05	LINE FAULT
85	11/May/2021	GULBARGA	110	HALBARGA-KOLHAR	KOLHAR_110	12:25	14:05	1:40	LINE CLEAR AVAILED
86	11/May/2021	GULBARGA	110	KOLHAR-JANAWADA	JANAWADA_110	12:50	12:55	0:05	LINE CLEAR AVAILED
87	11/May/2021	GULBARGA	110	KOLHAR-JANAWADA	JANAWADA_110	12:10	12:25	0:15	LINE CLEAR AVAILED
88	11/May/2021	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	KOLHAR_110	12:10	12:25	0:15	LINE CLEAR AVAILED
89	11/May/2021	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	KOLHAR_110	12:50	12:55	0:05	LINE CLEAR AVAILED
90	11/May/2021	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	KOLHAR_110	12:55	14:10	1:15	LINE CLEAR AVAILED
91	11/May/2021	GULBARGA	110	HV2	TURVIHAL_110	14:00	14:20	0:20	TRANSFORMER FAULT
92	11/May/2021	GULBARGA	110	HV1	METRI_110	22:00	22:05	0:05	TRANSFORMER FAULT
93	11/May/2021	GULBARGA	66	HOSAHALLI-SMLWIND_IPP	HOSAHALLI_66	5:30	6:30	1:00	LINE FAULT
94	11/May/2021	GULBARGA	66	CJHALLI-HOSAHALLI	HOSAHALLI_66	5:30	6:20	0:50	LINE FAULT
95	11/May/2021	GULBARGA	66	MUNIRABAD-HANASI	HANASI_66	22:20(11.05.2021)			LINE OPEN,LINE CLEAR AVAILED
96	11/May/2021	GULBARGA	66	GUDEKOTE-HANAGAL	HANGAL_66	13:00(10.05.2021)	11:55(11.05.2021)	22:55HRS	LINE CHARGED
97	11/May/2021	GULBARGA	66	ITTAGI-HBHALLI	HAGARIBOMMANAHALLI_66	22:45	23:05	0:20	LINE FAULT
98	11/May/2021	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	16:26	16:57	0:31	LINE FAULT
99	11/May/2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	14:40	15:34	0:54	LINE FAULT
100	11/May/2021	HASSAN	220	MRSSHM-VARAHIZ	MRSMSG_220	10:40	10:53	0:13	HAND TRIPPED
101	11/May/2021	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	4:56	5:50	0:54	LINE FAULT
102	11/May/2021	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	10:09	10:53	0:44	HAND TRIPPED
103	11/May/2021	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	11:11	15:27	4:16	LINE CLEAR AVAILED
104	11/May/2021	HASSAN	220	HV1	SHIRALKOPPA_220	10:09	15:20	5:11	LINE CLEAR AVAILED
105	11/May/2021	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	10:09	10:53	0:44	HAND TRIPPED
106	11/May/2021	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:11	15:27	4:16	LINE CLEAR AVAILED
107	11/May/2021	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	10:09	10:57	0:48	HAND TRIPPED
108	11/May/2021	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	10:57	12:17	1:20	LINE FAULT
109	11/May/2021	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	10:09	10:54	0:45	HAND TRIPPED
110	11/May/2021	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	11:11	12:16	1:05	MAIN SUPPLY FAILURE
111	11/May/2021	HASSAN	110	LV1	SHIRALKOPPA_220	9:35	15:21	5:46	LINE CLEAR AVAILED
112	11/May/2021	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	10:00	10:21	0:21	LINE FAULT
113	11/May/2021	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	10:09	10:56	0:47	HAND TRIPPED
114	11/May/2021	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	11:11	12:15	1:04	LINE CLEAR AVAILED
115	11/May/2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	10:40	10:53	0:13	HAND TRIPPED
116	11/May/2021	HASSAN	110	HV2	ANANDAPURA_110	9:20	12:05	2:45	LINE CLEAR AVAILED
117	11/May/2021	HASSAN	110	HV2	ANANDAPURA_110	17:30	18:03	0:33	LINE CLEAR AVAILED
118	11/May/2021	HASSAN	110	HV2	ESSUR_110	7:38	9:10	1:32	TRANSFORMER FAULT
119	11/May/2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	10:24	10:34	0:10	NFBC ISSUED
120	11/May/2021	HASSAN	110	HV2	HOSANGADI_110	11:35	13:52	2:17	LINE CLEAR AVAILED
121	11/May/2021	HASSAN	110	HV1	HULICAL_110	14:30	19:10	4:40	TRANSFORMER FAULT
122	11/May/2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:24	12:33	2:09	LINE CLEAR AVAILED
123	11/May/2021	HASSAN	110	LPH-MGHE 2	lph_gen	15:10	15:20	0:10	HAND TRIPPED
124	11/May/2021	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYAPATNA_66	7:50	7:56	0:06	LINE FAULT
125	11/May/2021	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	16:24	16:34	0:10	MAIN SUPPLY FAILURE
126	11/May/2021	HASSAN	66	HV1	BANDISHETTYHALLI_66	16:24	16:34	0:10	MAIN SUPPLY FAILURE
127	11/May/2021	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	16:24	16:34	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
128	11/May/2021	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	18:20	20:22	2:02	MAIN SUPPLY FAILURE
129	11/May/2021	HASSAN	66	HV1	DODDAKADANUR_66	18:20	20:22	2:02	MAIN SUPPLY FAILURE
130	11/May/2021	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	18:20	20:22	2:02	MAIN SUPPLY FAILURE
131	11/May/2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	16:45	17:05	0:20	LINE FAULT
132	11/May/2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	17:52	20:36	2:44	LINE CLEAR AVAILED
133	11/May/2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	21:25	21:33	0:08	HAND TRIPPED
134	11/May/2021	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	16:45	17:05	0:20	LINE FAULT
135	11/May/2021	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	17:52	20:36	2:44	LINE CLEAR AVAILED
136	11/May/2021	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	16:25	16:30	0:05	LINE FAULT
137	11/May/2021	HASSAN	66	HV2	RAMNATHPURA_66	17:00	18:30	1:30	TRANSFORMER FAULT
138	11/May/2021	HASSAN	66	HV2	RAMNATHPURA_66	18:31	20:04	1:33	TRANSFORMER FAULT
139	11/May/2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	9:10	19:02	9:52	LINE CLEAR AVAILED
140	11/May/2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	9:10	19:02	9:52	LINE CLEAR AVAILED
141	11/May/2021	HASSAN	66	HV2	SALAGAME_66	15:05	15:36	0:31	TRANSFORMER FAULT
142	11/May/2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	5:50	5:58	0:08	HAND TRIPPED
143	11/May/2021	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	15:20	15:25	0:05	HAND TRIPPED
144	11/May/2021	HASSAN	66	SUZLON1	UDDURKOPLU_66	15:08	19:19	4:11	LINE FAULT
145	11/May/2021	MYSURU	66	KUSHALNAGARA-MERCERA-1	NO STATIONS INTERRUPTED	16:13	16:34	0:21	LINE FAULT
146	11/May/2021	MYSURU	66	KUSHALNAGARA-MYSORE-1	MIRLE_66	16:04	16:25	0:21	LINE FAULT
147	11/May/2021	MYSURU	66	KUSHALNAGARA-PERIYAPATNA-1	PERIYAPATNA_66 PONNAMPETE_66 KAMPALAPURA_66 VIRAJPET_66	16:13	16:30	0:17	LINE FAULT
148	11/May/2021	MYSURU	66	KUSHALNAGARA-PERIYAPATNA-2	BYLUKUPPE_66	16:13	16:32	0:19	LINE FAULT
149	11/May/2021	MYSURU	66	KUSHALNAGARA-HARANGI	NO STATIONS INTERRUPTED	16:13	16:35	0:22	LINE FAULT
150	11/May/2021	MYSURU	66	KUSHALNAGARA-RAMANTHAPURA1	KANGAL_66 ALUR SIDDAPUR_66 RUDRAPATNA_66 CB HALLI_66	16:13	16:24	0:11	LINE FAULT
151	11/May/2021	MYSURU	66	KUSHALNAGARA-RAMANTHAPURA1	KANGAL_66 ALUR SIDDAPUR_66 RUDRAPATNA_66 CB HALLI_66	17:01	19:48	2:47	LINE CLEAR AVAILED
152	11/May/2021	MYSURU	66	PERIYAPATNA-HANGODU	PERIYAPATNA_66 PONNAMPET_66 VIRAJPET_66	18:19	18:23	0:04	LINE FAULT
153	11/May/2021	MYSURU	66	PERIYAPATNA-HANGODU	PONNAMPET_66 VIRAJPET_66	18:41	2:33	07:51	LINE FAULT
154	11/May/2021	MYSURU	66	PERIYAPATNA-HUNSUR	KAMPALAPURA_66	14:39	14:46	0:06	LINE FAULT
155	11/May/2021	MYSURU	66	HV1	SATHEGALA_66	11:00	11:19	0:19	LINE CLEAR AVAILED
156	11/May/2021	MYSURU	66	SANTESARGUR-KADAKOLA 1	HD KOTE_66 ANTHARASANTHE_66	18:30	18:40	0:10	LINE FAULT
157	11/May/2021	MYSURU	66	HV5	SFC SIVA_66	12:46	3:48	15:01	LINE CLEAR AVAILED
158	11/May/2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66 BASARALU_66	12:06	12:12	0:06	LINE FAULT
159	11/May/2021	MYSURU	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	15:58	16:06	0:08	LINE FAULT
160	11/May/2021	MYSURU	66	YELANDUR-MAMBALLI	NO STATIONS INTERRUPTED	21:21	21:31	0:10	LINE FAULT
161	11/May/2021	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI-66	6:02	6:09	0:07	LINE FAULT
162	11/May/2021	MYSURU	66	HV5	SFCSHIVA_66	14:23 (05/05/2021)	05:11 (11/05/2021)	14:53HRS	TRANSFORMER CHARGED
163	11/May/2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN,LINE CLEAR AVAILED
164	11/May/2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN,LINE CLEAR AVAILED
165	11/May/2021	MYSURU	220	MADHUVANAHALLI-HEBBANI 1	NO STATIONS EFFECTED	11:38 (10/05/2021)			LINE OPEN,LINE CLEAR AVAILED
166	11/May/2021	TUMKUR	400	JAGALUR400-THALLAKK220	THALLAKK220	15:27	15:29	0:01	LINE FAULT
167	11/May/2021	TUMKUR	220	DAVANGERE SRS- SHIMOOGA 2	DAVANGERE_SRS_220	16:29	23:24	6:54	LINE FAULT
168	11/May/2021	TUMKUR	220	THALLAKK_220	TR-3(HV&LV SIDE)	15:20	16:17	0:57	LINE CLEAR AVAILED
169	11/May/2021	TUMKUR	220	THALLAKK_220	TR-3(HV&LV SIDE)	16:34	16:42	0:08	LINE CLEAR AVAILED
170	11/May/2021	TUMKUR	110	TR-1	KBCROSS_220	15:26:17 PM(10.5.2021)	12:37:03 PM(11.5.2021)	21:07HRS	TRANSFORMER CHARGED
171	11/May/2021	TUMKUR	110	TR-1	TURUVEKERE_110	9:00	9:43	0:42	TRANSFORMER FAULT
172	11/May/2021	TUMKUR	110	TR-1	TURUVEKERE_110	9:44	12:07	2:23	TRANSFORMER FAULT
173	11/May/2021	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	17:53	18:01	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
174	11/May/2021	TUMKUR	66	BRAHMASANDRA- ANKASANDRA_66	ANKASANDRA_66	14:14	14:44	0:30	LINE FAULT
175	11/May/2021	TUMKUR	66	BRAHMASANDRA- SUNWIKI STEEL_66	SUNWIKI STEEL_66	14:14	14:35	0:21	LINE FAULT
176	11/May/2021	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 1	CHITRADURGA_220	16:14	16:37	0:23	LINE FAULT
177	11/May/2021	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_220	16:14	16:37	0:23	LINE FAULT
178	11/May/2021	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_220	16:37	16:40	0:02	LINE FAULT
179	11/May/2021	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALI_66, CHALLAKERE_66, SANIKERE_66	22:24	22:35	0:10	LINE FAULT
180	11/May/2021	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA IPP_66	17:58	18:36	0:38	LINE FAULT
181	11/May/2021	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66	16:14	17:26	1:12	LINE FAULT
182	11/May/2021	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	17:01	17:15	0:14	LINE FAULT
183	11/May/2021	TUMKUR	66	TR-1	HANGAL_66	17:10	17:36	0:25	LINE CLEAR AVOIDED
184	11/May/2021	TUMKUR	66	TR-1	HIRIYUR_66	9:35	12:01	2:25	LINE CLEAR AVOIDED
185	11/May/2021	TUMKUR	66	TR-1	MADADKERE_66	15:29	15:35	0:05	TRANSFORMER FAULT
186	11/May/2021	TUMKUR	66	TR-1	MADADKERE_66	16:12	16:58	0:45	TRANSFORMER FAULT
187	11/May/2021	TUMKUR	66	TR-1	MATHOD_66	17:28	17:34	0:05	TRANSFORMER FAULT
188	11/May/2021	TUMKUR	66	MATHOD- PANCHANAHALLI	MATHOD_66,	16:25	16:30	0:05	LINE FAULT
189	11/May/2021	TUMKUR	66	TR-1	MAVINAKATTE_66	11:03	13:10	2:06	TRANSFORMER FAULT
190	11/May/2021	TUMKUR	66	TR-1	MAVINAKATTE_66	13:40	13:50	0:10	TRANSFORMER FAULT
191	11/May/2021	TUMKUR	66	TR-1	MAVINAKATTE_66	10:00	10:10	0:10	TRANSFORMER FAULT
192	11/May/2021	TUMKUR	66	TR-1	MAVINAKATTE_66	10:10	10:30	0:20	LINE CLEAR AVOIDED
193	11/May/2021	TUMKUR	66	TR-2	MAVINAKATTE_66	13:30	13:40	0:10	LINE CLEAR AVOIDED
194	11/May/2021	TUMKUR	66	PAVAGADA_220-NAGALMADIKE	PAVAGADA_220	2:05	2:28	0:23	LINE FAULT
195	11/May/2021	TUMKUR	66	THALLAK 220kV- P R PURA	MADHUGIRI_220	15:52	16:15	0:23	LINE FAULT
196	11/May/2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	15:20	16:42	1:22	LINE CLEAR AVOIDED
197	11/May/2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	15:20	16:42	1:22	LINE CLEAR AVOIDED
1	12/May/2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
2	12/May/2021	BAGALKOT	110	110/11KV, HV1	KALADAGI_110	19:00	19:59	0:59	LINE CLEAR AVOIDED
3	12/May/2021	BAGALKOT	110	110/11KV, HV2	THORVI_110	12:28	13:38	1:10	TRANSFORMER FAULT
4	12/May/2021	BAGALKOT	110	110/11KV, HV2	BYADAGI_110	15:54	16:04	0:10	TRANSFORMER FAULT
5	12/May/2021	BAGALKOT	110	110/11KV, HV3	MUNAVALLI_110, MUNAVALLI_33, MALLUR_33	20:39	21:15	0:36	TRANSFORMER FAULT
6	12/May/2021	BAGALKOT	110	110/11KV, HV4	HUKKERI_110	14:39	14:44	0:05	TRANSFORMER FAULT
7	12/May/2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, HALASANGI_33, NEVARGI_33, DULKHED_33	10:03	10:16	0:13	TRANSFORMER FAULT
8	12/May/2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, HALASANGI_33, NEVARGI_33, DULKHED_33	20:55	20:59	0:04	TRANSFORMER FAULT
9	12/May/2021	BAGALKOT	110	AMBEWADI-NK2	KAVALWADA_110	12:55	13:12	0:17	LINE FAULT
10	12/May/2021	BAGALKOT	110	AMBEWADI-NK2	KAVALWADA_110	14:09	14:15	0:06	HAND TRIPPED
11	12/May/2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVOIDED
12	12/May/2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVOIDED
13	12/May/2021	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	3:06	8:17	5:11	LINE FAULT
14	12/May/2021	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	15:36	15:54	0:18	LINE FAULT
15	12/May/2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
16	12/May/2021	BAGALKOT	110	MUNDARAGI-VIJAYA SUGARS	STATION NOT AFFECTED MUNDARGI_110	2:04	2:36	0:32	LINE FAULT
17	12/May/2021	BAGALKOT	110	NARENDRA-BELUR1	STATION NOT AFFECTED BELUR_110	15:01	16:44	1:43	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
18	12/May/2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
19	12/May/2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED KAVALWADA 110	12:55	15:54	2:59	LINE FAULT
20	12/May/2021	BAGALKOT	110	SIRSI220-UMACHAGI	STATION NOT AFFECTED UMACHAGI 110	12:55	15:53	2:58	LINE FAULT
21	12/May/2021	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED CHIKKODI 220	15:39	15:41	0:02	TRANSFORMER FAULT
22	12/May/2021	BAGALKOT	220	CHIKKODI-(GHATAP1)KUDUCHI1	STATION NOT AFFECTED CHIKKODI 220	15:52	15:53	0:01	LINE FAULT
23	12/May/2021	BAGALKOT	220	CHIKKODI-(GHATAP2)KUDUCHI2	STATION NOT AFFECTED CHIKKODI 220	15:53	15:54	0:01	LINE FAULT
24	12/May/2021	BAGALKOT	220	CHIKKODI-MUDASHINGI	STATION NOT AFFECTED CHIKKODI 220	10:34	19:08	8:34	NFBC ISSUED
25	12/May/2021	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HARERI 220	11:04	17:19	6:15	LINE FAULT
26	12/May/2021	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HARERI 220	12:24 (12.05.2021)			LINE OPEN,LINE CLEAR AVAILED
27	12/May/2021	BAGALKOT	220	HAVERI-NARENDRA1	STATION NOT AFFECTED HARERI 220	11:04	11:25	0:21	LINE FAULT
28	12/May/2021	BAGALKOT	220	HUBLI-NAGAZARI3	STATION NOT AFFECTED HUBLI 220	14:04	14:58	0:54	LINE FAULT
29	12/May/2021	BAGALKOT	220	HUBLI-NAGAZARI3	STATION NOT AFFECTED HUBLI 220	15:01	21:42	6:41	LINE FAULT
30	12/May/2021	BAGALKOT	220	HUBLI-NARENDRA1	STATION NOT AFFECTED HUBLI 220	11:25	11:26	0:01	LINE FAULT
31	12/May/2021	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI 220	10:37	14:22	3:45	LINE CLEAR AVAILED
32	12/May/2021	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI 220	13:42	15:50	2:08	LINE CLEAR AVAILED
33	12/May/2021	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI 220	16:06 (11.05.2021)	15:48 (12.05.2021)	23:42 hrs	LINE CHARGED
34	12/May/2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
35	12/May/2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
36	12/May/2021	BAGALKOT	220	NARENDRA-HUBLI1	STATION NOT AFFECTED NARENDRA 220	11:26	11:37	0:11	LINE FAULT
37	12/May/2021	BAGALKOT	220	NARENDRA-HUBLI2	STATION NOT AFFECTED NARENDRA 220	10:09	14:23	4:14	NFBC ISSUED
38	12/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI 220	14:15 (04.05.2021)	13:30 (12.05.2021)	191:15 hrs	LINE CHARGED
39	12/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI 220	15:53 (12.05.2021)			LINE OPEN,LINE CLEAR AVAILED
40	12/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI 220	14:16 (04.05.2021)			LINE OPEN,LINE CLEAR AVAILED
41	12/May/2021	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI 220	13:31	15:49	2:18	LINE CLEAR AVAILED
42	12/May/2021	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI 220	11:35 (11.05.2021)	15:50 (12.05.2021)	28:15 hrs	LINE CHARGED
43	12/May/2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
44	12/May/2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
45	12/May/2021	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	7:28	7:32	0:03	LINE FAULT
46	12/May/2021	BENGALURU	66	HV1	MAASTHI	10:31	10:44	0:13	TRANSFORMER FAULT
47	12/May/2021	BENGALURU	66	HV1	SARIAPURA 220	11:09	12:45	1:35	LINE CLEAR AVAILED
48	12/May/2021	BENGALURU	66	HV2	MAASTHI	10:28	10:44	0:16	TRANSFORMER FAULT
49	12/May/2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	7:09	7:13	0:04	LINE CLEAR AVAILED
50	12/May/2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	7:09	7:13	0:04	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
51	12/May/2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	7:09	7:13	0:04	LINE CLEAR AVAILED
52	12/May/2021	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	20:46	21:32	0:46	MAIN SUPPLY FAILURE
53	12/May/2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	20:46	21:34	0:48	MAIN SUPPLY FAILURE
54	12/May/2021	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	20:46	21:30	0:44	MAIN SUPPLY FAILURE
55	12/May/2021	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	20:46	21:30	0:44	MAIN SUPPLY FAILURE
56	12/May/2021	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	20:46	21:30	0:44	MAIN SUPPLY FAILURE
57	12/May/2021	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	20:46	21:30	0:44	MAIN SUPPLY FAILURE
58	12/May/2021	BENGALURU	220	HOODY 220 - MALUR 220	SARJAPURA 220, VIKAS TECH PARK 220	20:46	21:24	0:38	LINE FAULT
59	12/May/2021	BENGALURU	220	HV1	SARJAPURA 220	21:24	21:35	0:11	TRANSFORMER FAULT
60	12/May/2021	BENGALURU	220	HV1	SARJAPURA 220	21:24	21:35	0:11	MAIN SUPPLY FAILURE
61	12/May/2021	BENGALURU	220	MALUR 220 - HOODY 220	SARJAPURA 220, VIKAS TECH PARK 220	20:46	21:24	0:38	LINE FAULT
62	12/May/2021	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	NO STATION AFFECTED	6:00	7:01	1:01	LINE FAULT
63	12/May/2021	GULBARGA	66	HV1	HANASI_66	10:10	13:35	3:25	LINE CLEAR AVAILED
64	12/May/2021	GULBARGA	66	HV1	KOTTUR_66	8:41	8:45	0:04	TRANSFORMER FAULT
65	12/May/2021	GULBARGA	66	MUNIRABAD-HANASI	HANASI_66	22:20(11.05.2021)	8:20(12.05.2021)	10:00HRS	LINE CHARGED
66	12/May/2021	GULBARGA	110	HV1	ALIPUR_220	19:11(11.05.2021)	2:45(12.05.2021)	7:34HRS	TRANSFORMER CHARGED
67	12/May/2021	GULBARGA	110	HV1	SANKLAPUR_110	8:15	8:20	0:05	TRANSFORMER FAULT
68	12/May/2021	GULBARGA	110	HV2	SANKLAPUR_110	8:15	8:20	0:05	TRANSFORMER FAULT
69	12/May/2021	GULBARGA	110	HV2	MANTHAL_110	7:15	7:30	0:15	TRANSFORMER FAULT
70	12/May/2021	GULBARGA	110	HV2	SANKLAPUR_110	12:45	12:50	0:05	TRANSFORMER FAULT
71	12/May/2021	GULBARGA	110	HV2	SANKLAPUR_110	2:20	2:25	0:05	TRANSFORMER FAULT
72	12/May/2021	GULBARGA	110	HV3	MANTHAL_110	7:15	7:30	0:15	TRANSFORMER FAULT
73	12/May/2021	GULBARGA	110	MALLAT-KAMPLI	KAMPLI_110,KPC_IPP,MUKUNDA_110,KEREHALLI_110,MALLAPURA_110	11:40	13:00	1:20	MAIN SUPPLY FAILURE
74	12/May/2021	GULBARGA	110	MUNIRABAD-MALLAPUR	MALLAPUR_110	11:45	12:50	1:05	NFBC ISSUED
75	12/May/2021	GULBARGA	110	MUNIRABAD-SINDHNOOR2	KAMPLI_110,KPC_IPP,MUKUNDA_110,KEREHALLI_110,MALLAPURA_110	11:40	12:45	1:05	LINE CLEAR AVAILED
76	12/May/2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	3:36	3:40	0:04	LINE FAULT
77	12/May/2021	GULBARGA	110	RAICHUR-SINDHNOOR1	SIRWAR_110,ALKOD_110,BYAGAWATH_110,VALKA MDINNI_110(IDLE)	0:15	0:30	0:15	LINE FAULT
78	12/May/2021	GULBARGA	110	RAICHUR-SINDHNOOR2	GOOGLE_110	1:07	1:17	0:10	LINE FAULT
79	12/May/2021	GULBARGA	110	SINDHNOOR-SUZLON_IPP	SINDHANOOR_220	5:30	5:50	0:20	LINE FAULT
80	12/May/2021	GULBARGA	220	BTPS-LINGAPUR	LINGAPUR_220	20:22(11.05.2021)	1:13(12.05.2021)	4:51HRS	LINE CHARGED
81	12/May/2021	GULBARGA	220	HV1	HALBARGA_220	8:02	8:10	0:08	LINE CLEAR AVAILED
82	12/May/2021	GULBARGA	220	HV1	HALBARGA_220	15:50	15:58	0:08	LINE CLEAR AVAILED
83	12/May/2021	GULBARGA	220	HV2	HALBARGA_220	15:05	15:38	0:33	LINE CLEAR AVAILED
84	12/May/2021	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	6:17	8:22	2:05	LINE FAULT
85	12/May/2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400	18:04(11.05.2021)	12:38(12.05.2021)	18:34HRS	LINE CHARGED
86	12/May/2021	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	23:45	23:58	0:13	LINE FAULT
87	12/May/2021	HASSAN	66	CRPATNA2-MATTANAVILE	CRPATNA_220	23:11	23:26	0:15	LINE FAULT
88	12/May/2021	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	11:32	13:51	2:19	NFBC ISSUED
89	12/May/2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	13:44	14:50	1:06	LINE CLEAR AVAILED
90	12/May/2021	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	8:34	8:37	0:03	HAND TRIPPED
91	12/May/2021	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	13:45	14:51	1:06	LINE CLEAR AVAILED
92	12/May/2021	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	5:36	5:41	0:05	LINE FAULT
93	12/May/2021	HASSAN	66	HV1	BAGUR_66	13:10	14:49	1:39	LINE CLEAR AVAILED
94	12/May/2021	HASSAN	66	HV1	DODDAKADANUR_66	13:46	14:51	1:05	MAIN SUPPLY FAILURE
95	12/May/2021	HASSAN	66	HV1	HALLYMYSORE_66	13:45	14:50	1:05	NFBC ISSUED
96	12/May/2021	HASSAN	66	HV1	HANBALU_66	11:32	13:51	2:19	NFBC ISSUED
97	12/May/2021	HASSAN	66	HV1	SINGAPURA_66	10:22	12:47	2:25	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
98	12/May/2021	HASSAN	66	HV1	SOMANAHALLY_66	13:55	15:15	1:20	LINE CLEAR AVAILED
99	12/May/2021	HASSAN	66	HV2	HALLYMYSORE_66	13:45	14:50	1:05	NFBC ISSUED
100	12/May/2021	HASSAN	66	HV2	RAMNATHPURA_66	11:19	12:50	1:31	LINE CLEAR AVAILED
101	12/May/2021	HASSAN	66	HV2	S.BELAGOLA_66	12:07	13:38	1:31	LINE CLEAR AVAILED
102	12/May/2021	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	10:48	10:57	0:09	HAND TRIPPED
103	12/May/2021	HASSAN	66	SAKALE-HANBAL	SAKLESHHPURA_66	11:31	13:55	2:24	LINE CLEAR AVAILED
104	12/May/2021	HASSAN	66	SAKALE-IPCL1	SAKLESHHPURA_66	9:02	19:17	10:15	LINE CLEAR AVAILED
105	12/May/2021	HASSAN	66	SAKALE-IPCL2	SAKLESHHPURA_66	9:02	19:17	10:15	LINE CLEAR AVAILED
106	12/May/2021	HASSAN	66	SIGEBAG-SMG-DVG2	S.BELAGOLA_66	10:49	10:58	0:09	MAIN SUPPLY FAILURE
107	12/May/2021	HASSAN	110	HV1	NANDIKUR_110	13:02	14:09	1:07	LINE CLEAR AVAILED
108	12/May/2021	HASSAN	110	HV2	BAIKAMPADY_110	11:15	12:10	0:55	LINE CLEAR AVAILED
109	12/May/2021	HASSAN	110	HV2	NANDIKUR_110	14:10	14:52	0:42	LINE CLEAR AVAILED
110	12/May/2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	20:06	20:50	0:44	LINE FAULT
111	12/May/2021	HASSAN	220	KADUR-DABUSET	KADUR_220	10:38	11:31	0:53	LINE FAULT
112	12/May/2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	18:20	19:32	1:12	LINE FAULT
113	12/May/2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:57(12.5.2021)			LINE OPEN,LINE CLEAR AVAILED
114	12/May/2021	MYSURU	66	CR NAGARA-KABBALLI	NO STATIONS EFFECTED	5:56	6:08	0:11	LINE FAULT
115	12/May/2021	MYSURU	66	DMG HALLI-HV1	DMG_HALLI_66	7:23	7:39	0:16	LINE FAULT
116	12/May/2021	MYSURU	66	HARADANAHALLI(JAK)-LAXJEET	NO STATIONS EFFECTED	8:57	9:01	0:03	LINE FAULT
117	12/May/2021	MYSURU	66	HUNSUR-HANAGODU	HANAGODU_66	17:11	17:21	0:09	LINE FAULT
118	12/May/2021	MYSURU	66	HV1	DMG_HALLI_66	4:33	5:50	1:17	TRANSFORMER FAULT
119	12/May/2021	MYSURU	66	HV1	YELANDUR_66	11:08	11:46	0:38	LINE CLEAR AVAILED
120	12/May/2021	MYSURU	66	HV2	BGNAGARA_66	23:28	23:38	0:10	TRANSFORMER FAULT
121	12/May/2021	MYSURU	66	HV2	KMDODDI_66	11:36	12:01	0:24	TRANSFORMER FAULT
122	12/May/2021	MYSURU	66	HV2	SATHEGALA_66	19:09	19:16	0:07	TRANSFORMER FAULT
123	12/May/2021	MYSURU	66	HV5	SFC SIVA_66	12:46 (11/05/2021)	3:47 (12/05/2021)	15:01 HRS	TRANSFORMER CHARGED
124	12/May/2021	MYSURU	66	KM DODDI-MANDYA	NO STATIONS EFFECTED	11:51	11:59	0:07	HAND TRIPPED
125	12/May/2021	MYSURU	66	KM DODDI-TK HALLI	KMDODDI_66	11:47	11:58	0:11	LINE FAULT
126	12/May/2021	MYSURU	66	KUSHALANAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	17:33	17:43	0:09	LINE FAULT
127	12/May/2021	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	5:45	5:53	0:08	LINE FAULT
128	12/May/2021	MYSURU	66	PERIYAPATNA-HANAGODU	PONNAMPET_66, VIRAJPET_66	10:47	10:52	0:05	LINE FAULT
129	12/May/2021	MYSURU	66	PERIYAPATNA-HANGODU	PONNAMPET_66 VIRAJPET_66	18:41 (11/05/2021)	2:33 (12/05/2021)	7:52 HRS	LINE CHARGED
130	12/May/2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN,LINE CLEAR AVAILED
131	12/May/2021	MYSURU	66	TUBINAKERE-MC-2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66, BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66	20:58	21:05	0:07	LINE FAULT
132	12/May/2021	MYSURU	66	TUBINAKERE-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66, BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66	20:58	21:05	0:06	LINE FAULT
133	12/May/2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN,LINE CLEAR AVAILED
134	12/May/2021	TUMKUR	66	ANCHEPALYA 66kv-HEBBUR66	HEBBUR_66,THIMMASANDRA_66,HONNENAHALLI_66	18:03	18:17	0:13	LINE FAULT
135	12/May/2021	TUMKUR	66	BALENAHALLI CHITRADURGA	BALENAHALLI_66	16:21	17:25	1:04	MAIN SUPPLY FAILURE
136	12/May/2021	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES IPP 66	GOLDEN HATCHERIES_IPP_66	5:17	7:24	2:07	MAIN SUPPLY FAILURE
137	12/May/2021	TUMKUR	66	CHITRADURGA 220kv- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	16:13	17:22	1:09	LINE FAULT
138	12/May/2021	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	5:27	6:25	0:58	HAND TRIPPED
139	12/May/2021	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	16:35	16:41	0:06	HAND TRIPPED
140	12/May/2021	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	0:15	1:03	0:47	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
141	12/May/2021	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	16:36	16:41	0:05	HAND TRIPPED
142	12/May/2021	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 1	PANDARAHALLI_66	0:16	1:03	0:46	LINE FAULT
143	12/May/2021	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66	0:16	1:03	0:46	LINE FAULT
144	12/May/2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	7:14	7:23	0:08	LINE FAULT
145	12/May/2021	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	7:12	7:49	0:37	HAND TRIPPED
146	12/May/2021	TUMKUR	66	I D HALLI- CLEAN MAX SOLAR	CLEANMAXSOLAR_IPP_66	4:50	6:44	1:54	LINE FAULT
147	12/May/2021	TUMKUR	66	I D HALLI- KODIGENAHALLI	IDHALLY_66	4:49	5:44	0:54	LINE FAULT
148	12/May/2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:17	12:20	0:03	LINE FAULT
149	12/May/2021	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	BADAVANAHALLI_66	14:24	14:26	0:01	LINE CLEAR AVAILED
150	12/May/2021	TUMKUR	66	PAVAGADA220-MIDIGESHI66	MEDIGESHI_66	23:52	23:55	0:02	LINE FAULT
151	12/May/2021	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	17:19	18:13	0:54	LINE FAULT
152	12/May/2021	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR IPP_66	SEL DIAMOND SOLAR_IPP_66	17:19	18:07	0:48	LINE FAULT
153	12/May/2021	TUMKUR	66	TR-1	MATHOD_66	7:39	7:55	0:16	TRANSFORMER FAULT
154	12/May/2021	TUMKUR	66	TR-1	PAVAGADA_66	14:03	14:15	0:11	TRANSFORMER FAULT
155	12/May/2021	TUMKUR	66	TR-2	CHITRADURGA_220	16:35	16:42	0:07	HAND TRIPPED
156	12/May/2021	TUMKUR	66	TR-2	HINDASGHATTA_66	18:39	19:22	0:43	LINE CLEAR AVAILED
157	12/May/2021	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	16:13	16:41	0:27	TRANSFORMER FAULT
158	12/May/2021	TUMKUR	110	TR-3(HV SIDE)	GUBBI_110	7:14	7:59	0:44	TRANSFORMER FAULT
159	12/May/2021	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	10:26	15:59	5:33	LINE FAULT
160	12/May/2021	TUMKUR	220	TR-3(HV SIDE)	CHITRADURGA_220	16:13	16:26	0:13	TRANSFORMER FAULT
1	13/May/2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
2	13/May/2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
3	13/May/2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
4	13/May/2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
5	13/May/2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
6	13/May/2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
7	13/May/2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
8	13/May/2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
9	13/May/2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
10	13/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	14:16 (04.05.2021)			LINE OPEN,LINE CLEAR AVAILED
11	13/May/2021	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HARERI_220	12:24 (12.05.2021)	16:12 (13.05.2021)	27:48HRS	LINE CHARGED
12	13/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:53 (12.05.2021)			LINE OPEN,LINE CLEAR AVAILED
13	13/May/2021	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	12:19	15:58	3:39	LINE CLEAR AVAILED
14	13/May/2021	BAGALKOT	110	BIDNAL-NAVALUND	STATION NOT AFFECTED BIDNAL_220	5:21	13:11	7:50	LINE FAULT
15	13/May/2021	BAGALKOT	110	BIDNAL-NAVALUND	STATION NOT AFFECTED NAVALGUND_110	5:42	15:48	10:06	LINE CLEAR AVAILED
16	13/May/2021	BAGALKOT	110	CHIKKODI-TALANDAGI(KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:24	14:09	2:45	LINE FAULT
17	13/May/2021	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	11:06	16:12	5:06	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
18	13/May/2021	BAGALKOT	110	KAVALWADA-KALAGATAGI	STATION NOT AFFECTED KALAGATAGI_110	19:34	20:38	1:04	LINE FAULT
19	13/May/2021	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	14:08	17:14	3:06	LINE CLEAR AVAILED
20	13/May/2021	BAGALKOT	110	MUKARTHIHAL-SPV	STATION NOT AFFECTED MUKARTHAL_110	20:19	20:24	0:05	LINE FAULT
21	13/May/2021	BAGALKOT	110	110/11KV,HV3	STATION NOT AFFECTED MUNDARAGI_110	14:36	15:13	0:37	TRANSFORMER FAULT
22	13/May/2021	BAGALKOT	110	SIRSI-(JOG2)JOG	STATION NOT AFFECTED SIRSI_110	13:25	13:36	0:11	LINE FAULT
23	13/May/2021	BAGALKOT	110	SIRSI-(JOG2)JOG	STATION NOT AFFECTED SIRSI_110	16:35	19:27	2:52	LINE FAULT
24	13/May/2021	BAGALKOT	110	SIRSI-(JOG1)SIDDAPUR	STATION NOT AFFECTED SIRSI_110	16:35	19:27	2:52	LINE CLEAR AVAILED
25	13/May/2021	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED ZALKI_110	0:58	1:05	0:07	TRANSFORMER FAULT
26	13/May/2021	BAGALKOT	220	HUBLI-NAGIHARI3	STATION NOT AFFECTED HUBLI_220	12:10	19:32	7:22	LINE FAULT
27	13/May/2021	BAGALKOT	110	KERUR-KULIGERE CROSS	STATION NOT AFFECTED KULIGERE CROSS_110	13:25 (13.05.2021)			LINE OPEN,LINE CLEAR AVAILED
28	13/May/2021	BENGALURU	66	HV1	CHAKAVELU	16:24	17:25	1:00	TRANSFORMER FAULT
29	13/May/2021	BENGALURU	66	HV1	KACHMARANAHALLI	9:37	9:44	0:07	TRANSFORMER FAULT
30	13/May/2021	BENGALURU	66	HV1	KANAKAPURA 66	11:35	12:22	0:47	LINE CLEAR AVAILED
31	13/May/2021	BENGALURU	66	HV2	SADLI	16:03	16:14	0:11	TRANSFORMER FAULT
32	13/May/2021	BENGALURU	66	HV2	SOMAYAJJANAHALLI	16:09	16:45	0:35	LINE CLEAR AVAILED
33	13/May/2021	BENGALURU	66	HV1	SM MANGALA	2:02	2:39	0:36	TRANSFORMER FAULT
34	13/May/2021	BENGALURU	66	HV2	SM MANGALA	3:26	3:33	0:07	TRANSFORMER FAULT
35	13/May/2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI	11:06	11:16	0:09	LINE FAULT
36	13/May/2021	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	NO STATION AFFECTED	3:00	3:10	0:09	LINE FAULT
37	13/May/2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:01	11:06	0:05	LINE FAULT
38	13/May/2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	6:54	7:15	0:20	LINE FAULT
39	13/May/2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	10:13	10:19	0:06	LINE FAULT
40	13/May/2021	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	5:39	5:55	0:15	LINE FAULT
41	13/May/2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	3:00	3:10	0:09	MAIN SUPPLY FAILURE
42	13/May/2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	3:00	3:10	0:09	MAIN SUPPLY FAILURE
43	13/May/2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	3:00	3:10	0:09	MAIN SUPPLY FAILURE
44	13/May/2021	BENGALURU	66	HV3	ADUGODI	16:18	16:26	0:08	TRANSFORMER FAULT
45	13/May/2021	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	15:07	15:17	0:10	MAIN SUPPLY FAILURE
46	13/May/2021	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	17:19	17:21	0:02	LOAD CHANGE OVER
47	13/May/2021	BENGALURU	66	HV2	GOKULA	16:21	16:23	0:02	LINE CLEAR AVAILED
48	13/May/2021	BENGALURU	66	HV1	JAKKASANDRA	22:41	23:59	1:18	TRANSFORMER FAULT
49	13/May/2021	BENGALURU	66	HV1	KENGERI SATELLITE TOWN	8:48	8:59	0:11	TRANSFORMER FAULT
50	13/May/2021	BENGALURU	66	MEI LAYOUT - WIDIA	WIDIA, WIDIA(EHT)	17:26	18:49	1:23	LINE FAULT
51	13/May/2021	BENGALURU	66	RAJANUKUNTE - YELAHANKA 220	RAJANUKUNTE	5:45	5:55	0:10	MAIN SUPPLY FAILURE
52	13/May/2021	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	15:15	15:17	0:02	LOAD CHANGE OVER
53	13/May/2021	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	16:15	16:19	0:04	LOAD CHANGE OVER
54	13/May/2021	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT	17:26	18:17	0:51	LINE FAULT
55	13/May/2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	NO STATION AFFECTED	15:07	16:03	0:56	LINE FAULT
56	13/May/2021	BENGALURU	220	HV2	VIKAS TECH PARK	5:13	9:50	4:37	TRANSFORMER FAULT
57	13/May/2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	2:43	2:48	0:05	LINE FAULT
58	13/May/2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	2:48	3:15	0:27	LINE FAULT
59	13/May/2021	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	17:47	18:10	0:23	LINE FAULT
60	13/May/2021	BENGALURU	66	HV1	JAKKASANDRA	22:41(13/05/2021)			TRANSFORMER OPEN, TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
61	13/May/2021	GULBARGA	220	HV1	HALBARGA_220	7:50	7:59	0:09	LINE CLEAR AVAILED
62	13/May/2021	GULBARGA	220	HV1	HALBARGA_220	15:50	15:57	0:07	LINE CLEAR AVAILED
63	13/May/2021	GULBARGA	110	JANAWADA-SANTHPUR	SANTHPUR_110	5:29	5:45	0:16	LINE FAULT
64	13/May/2021	GULBARGA	110	HALBARGA-SANTHPUR	SANTHPUR_110	5:28	5:33	0:05	LINE FAULT
65	13/May/2021	GULBARGA	110	HV1	KUSHTAGI_220	16:00	16:58	0:58	TRANSFORMER FAULT
66	13/May/2021	GULBARGA	110	HV1	KUSHTAGI_220	16:38	16:48	0:10	TRANSFORMER FAULT
67	13/May/2021	GULBARGA	110	HV2	TEKKALKOTE_110	15:05	15:10	0:05	TRANSFORMER FAULT
68	13/May/2021	GULBARGA	110	HV2	DEODURGA_110	12:38	12:57	0:19	TRANSFORMER FAULT
69	13/May/2021	GULBARGA	110	JANAWADA-SANTHPUR	SANTHPUR_110	5:29	5:45	0:16	LINE FAULT
70	13/May/2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	4:00	4:25	0:25	LINE FAULT
71	13/May/2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	4:30	7:20	2:50	LINE CLEAR AVAILED
72	13/May/2021	GULBARGA	110	HV2	SHAHAPUR_220	7:30	8:18	0:48	TRANSFORMER FAULT
73	13/May/2021	GULBARGA	110	HV2	SHAHAPUR_220	10:54	11:03	0:09	TRANSFORMER FAULT
74	13/May/2021	GULBARGA	110	SINGHNOOR-RAICHUR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	0:10	0:30	0:20	LINE FAULT
75	13/May/2021	GULBARGA	110	SINDHNOOR-SUZLON_IPP	SINDHNOOR_220	3:35	3:55	0:20	LINE FAULT
76	13/May/2021	GULBARGA	110	SINDHNOOR-SUZLON_IPP	SINDHNOOR_220	4:25	4:35	0:10	LINE FAULT
77	13/May/2021	GULBARGA	110	SINDHNOOR-SUZLON_IPP	SINDHNOOR_220	4:45	6:15	1:30	LINE FAULT
78	13/May/2021	GULBARGA	110	SINDHNOOR-SUZLON_IPP	SINDHNOOR_220	21:40	21:50	0:10	LINE FAULT
79	13/May/2021	GULBARGA	66	HV1	KOGALI_66	10:57	11:00	0:03	TRANSFORMER FAULT
80	13/May/2021	GULBARGA	66	KUDLIGI-HANASI	HANASI_66	12:45	12:50	0:05	LINE CLEAR AVAILED
81	13/May/2021	GULBARGA	66	MUNIRABAD-HANASI	SOKKE_66	12:45	15:15	2:30	LINE CLEAR AVAILED
82	13/May/2021	GULBARGA	66	KUDLIGI-HANASI	HANASI_66	14:00	14:05	0:05	LINE CLEAR AVAILED
83	13/May/2021	GULBARGA	66	HV1	HANASI_66	12:00	12:50	0:50	LINE CLEAR AVAILED
84	13/May/2021	GULBARGA	66	HV1	CHORNOOR_66	2:55	3:02	0:07	TRANSFORMER FAULT
85	13/May/2021	GULBARGA	66	HV2	CHORNOOR_66	6:55	7:10	0:15	LINE CLEAR AVAILED
86	13/May/2021	GULBARGA	66	HV1	CHORNOOR_66	10:20	10:25	0:05	TRANSFORMER FAULT
87	13/May/2021	GULBARGA	66	HV2	CHORNOOR_66	16:10	16:20	0:10	LINE CLEAR AVAILED
88	13/May/2021	GULBARGA	66	HV1	CHORNOOR_66	2:55	3:00	0:05	TRANSFORMER FAULT
89	13/May/2021	GULBARGA	66	HV1	CHORNOOR_66	10:20	10:25	0:05	TRANSFORMER FAULT
90	13/May/2021	GULBARGA	66	HV2	CHORNOOR_66	6:50	7:10	0:20	LINE CLEAR AVAILED
91	13/May/2021	GULBARGA	66	KOTTUR-UJJAINI	UJJANI_66	5:10	7:05	1:55	NFBC ISSUED
92	13/May/2021	GULBARGA	66	ITTAGI-BENNEHALLI	BENNEHALLI_66.KOTTUR_66,UJJAINI_66	23:00	23:05	0:05	LINE FAULT
93	13/May/2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:57(12.5.2021)	7:40(13.05.2021)	9:02 hrs	LINE CHARGED
94	13/May/2021	HASSAN	220	KADUR-SHIMOGA	KADUR_220	18:21(13.05.2021)			LINE OPEN,LINE FAULT
95	13/May/2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	18:20(13.05.2021)			LINE OPEN,LINE FAULT
96	13/May/2021	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	18:28(13.05,2021)			LINE OPEN,LINE FAULT
97	13/May/2021	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	18:21(13.05.2021)			LINE OPEN,LINE FAULT
98	13/May/2021	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	18:51(13.05.2021)			LINE OPEN,LINE FAULT
99	13/May/2021	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	18:51(13.05.2021)			LINE OPEN,LINE FAULT
100	13/May/2021	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	18:21	18:39	0:18	LINE FAULT
101	13/May/2021	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	10:58	12:30	1:32	LINE CLEAR AVAILED
102	13/May/2021	HASSAN	220	HV2	MSEZ_220	14:14	15:22	1:08	LINE CLEAR AVAILED
103	13/May/2021	HASSAN	110	LV2	MSEZ_220	14:14	15:22	1:08	LINE CLEAR AVAILED
104	13/May/2021	HASSAN	220	SHRAVTY-TALAGUPPA1	sharavathy_gen	11:07	11:28	0:21	HAND TRIPPED
105	13/May/2021	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	11:07	11:28	0:21	HAND TRIPPED
106	13/May/2021	HASSAN	110	HV2	ANANDAPURA_110	9:16	18:01	8:45	LINE CLEAR AVAILED
107	13/May/2021	HASSAN	110	HV1	HIRENALLUR_110	15:13	16:24	1:11	LINE CLEAR AVAILED
108	13/May/2021	HASSAN	110	HV2	SHIRALKOPPA_110	12:42	17:20	4:38	TRANSFORMER FAULT
109	13/May/2021	HASSAN	110	HV2	SHIRALKOPPA_110	17:30	19:20	1:50	LINE CLEAR AVAILED
110	13/May/2021	HASSAN	66	HV1	DODDAKADANUR_66	0:23	0:30	0:07	MAIN SUPPLY FAILURE
111	13/May/2021	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	0:20	0:30	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
112	13/May/2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	9:01	19:38	10:37	LINE CLEAR AVAILED
113	13/May/2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	9:01	19:38	10:37	LINE CLEAR AVAILED
114	13/May/2021	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	10:52	11:16	0:24	LINE FAULT
115	13/May/2021	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	13:04	13:20	0:16	HAND TRIPPED
116	13/May/2021	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	12:46	12:59	0:13	LINE FAULT
117	13/May/2021	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPLU_66	11:58	14:00	2:02	LINE CLEAR AVAILED
118	13/May/2021	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPLU_66	11:58	14:00	2:02	LINE CLEAR AVAILED
119	13/May/2021	MYSURU	66	HV1	ARAKERE_66	4:35	4:41	0:06	TRANSFORMER FAULT
120	13/May/2021	MYSURU	66	CR NAGARA-YALANDUR	YALANDUR_66	23:43	23:52	0:09	LINE FAULT
121	13/May/2021	MYSURU	66	HV2	DATTAGALLY_66	11:39	12:27	0:47	LINE CLEAR AVAILED
122	13/May/2021	MYSURU	66	HV2	DKMAIDANA_66	10:43	14:56	4:13	LINE CLEAR AVAILED
123	13/May/2021	MYSURU	66	HV1	DODDABYADARAHALLI_66	11:14	12:07	0:52	LINE CLEAR AVAILED
124	13/May/2021	MYSURU	66	ELWALA-HOOTAGALLY	ELAVALA_66 GAVADAGERE_66	16:49	17:03	0:13	LINE FAULT
125	13/May/2021	MYSURU	66	HUNSUR-ELWALA	ELAVALA_66 GAVADAGERE_66	16:49	17:11	0:21	LINE FAULT
126	13/May/2021	MYSURU	66	JAKKANAHALLI-NAGMANGALA	G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI_66 NAGAMANGALA_66	20:11	20:20	0:08	LINE FAULT
127	13/May/2021	MYSURU	66	KADAKOLA-SARGUR 2	DOORA_66 HULLAHALLI_66 HURA_66 CHANDRAVADI_66	13:27	14:03	0:35	NFBC ISSUED
128	13/May/2021	MYSURU	66	KUNTHUR-DR PETE	SANTHEMARAHALLI_66 MUGUR_66 THAYURU_66JANNUR_66 TNARASIPURA_66	22:34	22:38	0:03	LINE FAULT
129	13/May/2021	MYSURU	66	KUSHALNAGARA-SUNTIKOPPA	NO STATIONS EFFECTED	17:34	17:41	0:07	LINE FAULT
130	13/May/2021	MYSURU	66	MADDUR-HV1	MADDUR_66	11:56	12:22	0:25	LINE CLEAR AVAILED
131	13/May/2021	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	6:33	6:37	0:03	LINE FAULT
132	13/May/2021	MYSURU	66	HV2	MEGALAPURA_66	12:30	13:15	0:44	LINE CLEAR AVAILED
133	13/May/2021	MYSURU	66	SANTESARGUR-KADAKOLA 2	NO STATIONS EFFECTED	3:30	3:40	0:10	LINE FAULT
134	13/May/2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN,LINE CLEAR AVAILED
135	13/May/2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN,LINE CLEAR AVAILED
136	13/May/2021	TUMKUR	110	TR-1	BANDIHALLI_110	17:05	17:33	0:27	TRANSFORMER FAULT
137	13/May/2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, BRAKMASANDRA_66,THOVINAKERE_66,ANKASAND RA_66	18:39	18:51	0:11	LINE FAULT
138	13/May/2021	TUMKUR	66	TR-2	BADDIHALLI_66	12:15	13:45	1:30	LINE CLEAR AVAILED
139	13/May/2021	TUMKUR	66	TR-2	BHARAMAGIR_66	20:00	20:37	0:37	TRANSFORMER FAULT
140	13/May/2021	TUMKUR	66	TR-2	HANAGAL_66	10:43	11:07	0:24	LINE CLEAR AVAILED
141	13/May/2021	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	2:24	2:49	0:24	LINE FAULT
142	13/May/2021	TUMKUR	66	TR-3	HARIYABBE_66	1:18	1:36	0:18	TRANSFORMER FAULT
143	13/May/2021	TUMKUR	66	TR-2	HIRIYUR_66	16:51	17:25	0:34	LINE CLEAR AVAILED
144	13/May/2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	17:26	17:42	0:15	LINE FAULT
145	13/May/2021	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	11:27	11:37	0:09	LINE FAULT
146	13/May/2021	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:16	15:29	0:12	LINE FAULT
147	13/May/2021	TUMKUR	66	TR-2	KIADB_VNP	11:08	15:11	4:03	LINE CLEAR AVAILED
148	13/May/2021	TUMKUR	66	TR-2	KIADB_VNP	15:17	22:13	6:55	LINE CLEAR AVAILED
149	13/May/2021	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	18:39	19:05	0:25	LINE FAULT
150	13/May/2021	TUMKUR	66	KORA- ANTHRASANAHALLI	KORA_66	18:39	19:05	0:25	MAIN SUPPLY FAILURE
151	13/May/2021	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	10:46	10:55	0:08	LINE FAULT
152	13/May/2021	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	18:41	18:59	0:18	LINE FAULT
153	13/May/2021	TUMKUR	66	PAVAGADA-MADHUGIRI(PAVAGADA 220)	PAVAGADA_66	18:41	19:10	0:29	LINE FAULT
154	13/May/2021	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	12:19	23:56	11:37	LINE CLEAR AVAILED
155	13/May/2021	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	1:31	3:06	1:35	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
156	13/May/2021	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR IPP 66	SEL DIAMOND SOLAR_IPP_66	1:31	3:06	1:35	LINE FAULT
157	13/May/2021	TUMKUR	66	THALLAK 220kV- THALLAK	SEI VENUS DIAMOND_IPP_66	1:31	3:06	1:35	LINE FAULT
158	13/May/2021	TUMKUR	66	TR-2(LV SIDE)	THALLAKK_220	1:31	2:36	1:05	TRANSFORMER FAULT
159	13/May/2021	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	1:31	3:16	1:44	TRANSFORMER FAULT
160	13/May/2021	TUMKUR	66	THALLAK 220kV- NAYAKANHATTI	CHITRADURGA_220	1:31	2:33	1:02	LINE CLEAR AVAILED
161	14/May/2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
162	14/May/2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
163	14/May/2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
164	14/May/2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
165	14/May/2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
166	14/May/2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
167	14/May/2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
168	14/May/2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
169	14/May/2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
170	14/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	14:16 (04.05.2021)			LINE OPEN,LINE CLEAR AVAILED
171	14/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:53 (12.05.2021)			LINE OPEN,LINE CLEAR AVAILED
172	14/May/2021	BAGALKOT	110	KERUR-KULIGERE CROSS	STATION NOT AFFECTED KULIGERE CROSS_110	13:25 (13.05.2021)	18:44 (14.05.2021)	5:19HRS	LINE CHARGED
173	14/May/2021	BAGALKOT	110	110/11KV,HV2	AIGALI_110	11:03	12:12	1:09	LINE CLEAR AVAILED
174	14/May/2021	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	AMBEWADI_220	19:31	20:38	1:07	LINE FAULT
175	14/May/2021	BAGALKOT	110	AMBWADI-XELDOM(PONDA1)	STATION NOT AFFECTED AMBEWADI_220	18:23 (14.05.2021)			LINE OPEN,LINE FAULT
176	14/May/2021	BAGALKOT	220	BIDNAL-NAGJHARI2	STATION NOT AFFECTED BIDNAL_220	19:33 (14.05.2021)			LINE OPEN,LINE FAULT
177	14/May/2021	BAGALKOT	110	BIDNAL-NAVALUND	STATION NOT AFFECTED BIDNAL_220	5:38	18:36	12:58	LINE FAULT
178	14/May/2021	BAGALKOT	110	BIDNAL-GADAG ROAD	STATION NOT AFFECTED BIDNAL_220	14:17	18:43	4:26	LINE CLEAR AVAILED
179	14/May/2021	BAGALKOT	110	BIDNAL-NAVALUND	STATION NOT AFFECTED NAVALGUND_110	16:45	20:26	3:41	LINE CLEAR AVAILED
180	14/May/2021	BAGALKOT	110	BIJAPUR220-ENERCON	STATION NOT AFFECTED BIJAPUR_220	9:29	19:17	9:48	NFBC ISSUED
181	14/May/2021	BAGALKOT	110	DAVALESHWAR-SAIDAPUR	SAIDAPUR_110	14:36	14:50	0:14	LINE FAULT
182	14/May/2021	BAGALKOT	110	GADAG ROAD-(GOPPANAKOPPA)BIDNAL	STATION NOT AFFECTED GADAG ROAD_110	14:14	18:52	4:38	NFBC ISSUED
183	14/May/2021	BAGALKOT	110	GOPPANAKOPPA-NARGUND(BIDNAL-NAVLUND)	STATION NOT AFFECTED GOPPANAKOPPA_110	11:24	14:19	2:55	LINE CLEAR AVAILED
184	14/May/2021	BAGALKOT	110	HALIYAL-ALNAVAR	ALNAVAR_110	18:20	19:02	0:42	LINE FAULT
185	14/May/2021	BAGALKOT	110	HAVERI-BYADAGI	STATION NOT AFFECTED BYADAGI_110	17:39	18:28	0:49	LINE FAULT
186	14/May/2021	BAGALKOT	220	GADAG-DHONI1	STATION NOT AFFECTED GADAG_220	14:51	15:21	0:30	LINE FAULT
187	14/May/2021	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	7:13	7:25	0:12	LINE CLEAR AVAILED
188	14/May/2021	BAGALKOT	110	KADANAKOPPA-KAVALWADA	KADANAKOPPA_110	19:45	21:19	1:34	LINE FAULT
189	14/May/2021	BAGALKOT	110	AMBEWADI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	20:00 (14.05.2021)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
190	14/May/2021	BAGALKOT	110	KONNUR-ANANTPUR SOLAR	STATION NOT AFFECTED KONNUR_110	4:04	4:16	0:12	LINE FAULT
191	14/May/2021	BAGALKOT	110	110/11KV,HV2	SHIROL_110	10:16	10:21	0:05	TRANSFORMER FAULT
192	14/May/2021	BAGALKOT	110	SIRSI-(JOG1)SIDDAPUR	STATION NOT AFFECTED SIRSI_110	15:12	15:38	0:26	LINE FAULT
193	14/May/2021	BAGALKOT	220	DHONI-GADAG1	STATION NOT AFFECTED DHONI_400	14:51	14:52	0:01	LINE FAULT
194	14/May/2021	BENGALURU	66	HV1	CHANDAPURA	1:26	1:30	0:03	TRANSFORMER FAULT
195	14/May/2021	BENGALURU	66	HV1	DODDALAHALLI	14:05	14:12	0:07	TRANSFORMER FAULT
196	14/May/2021	BENGALURU	66	HV1	VIJAYAPURA	15:37	15:45	0:07	TRANSFORMER FAULT
197	14/May/2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	15:46	15:58	0:11	LINE FAULT
198	14/May/2021	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	18:46	18:57	0:11	LINE FAULT
199	14/May/2021	BENGALURU	66	HEBBALA 220 - POTTERY ROAD	NO STATION AFFECTED	2:15	2:40	0:25	LINE FAULT
200	14/May/2021	BENGALURU	66	HV1	BANASAWADI	2:15	2:31	0:16	MAIN SUPPLY FAILURE
201	14/May/2021	BENGALURU	66	HV3	BANASAWADI	2:15	2:31	0:16	MAIN SUPPLY FAILURE
202	14/May/2021	BENGALURU	66	HV1	BANASAWADI	2:48	2:52	0:04	LOAD CHANGE OVER
203	14/May/2021	BENGALURU	66	AACHALU - KANAKPURA 220	ACHALU, HONNIGANAHALLI, HALAGUR, DODDALAHALLI	7:55	8:34	0:39	LINE FAULT
204	14/May/2021	BENGALURU	66	HV3	BANASAWADI	2:48	2:52	0:04	LOAD CHANGE OVER
205	14/May/2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	12:41	12:52	0:11	LINE CLEAR AVOIDED
206	14/May/2021	BENGALURU	66	HV1	JAKKASANDRA	0:00	2:57	2:57	TRANSFORMER FAULT
207	14/May/2021	BENGALURU	66	HV1	JAKKASANDRA	22:41(13/05/2021)	02:57:00(14/05/2021)	4:16HRS	TRANSFORMER CHARGED
208	14/May/2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400	16:03(14.05.2021)			LINE OPEN,LINE FAULT
209	14/May/2021	GULBARGA	220	HV1	HALBARGA_220	8:06	8:13	0:07	LINE CLEAR AVOIDED
210	14/May/2021	GULBARGA	220	HV1	HALBARGA_220	15:05	15:12	0:07	LINE CLEAR AVOIDED
211	14/May/2021	GULBARGA	220	BTPS-LINGAPUR	LINGAPUR_220	12:13	15:11	2:58	LINE FAULT
212	14/May/2021	GULBARGA	220	MALLAT-RTPS	MALLAT_220	14:27	16:50	2:23	LINE FAULT
213	14/May/2021	GULBARGA	220	MALLAT-LINGSUGUR	LINGSUGUR_220	14:27	16:47	2:20	LINE FAULT
214	14/May/2021	GULBARGA	220	HV1 & HV2	MALLAT_220	14:27	16:55	2:28	TRANSFORMER FAULT
215	14/May/2021	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,S HATVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAM ALAPUR_110,MATRI_110,RBNS FACTORY	6:12	6:20	0:08	LINE FAULT
216	14/May/2021	GULBARGA	110	HV1	LINGSUGUR_220	12:17	12:25	0:08	TRANSFORMER FAULT
217	14/May/2021	GULBARGA	110	HV1	KUDITINI_110	2:40	2:47	0:07	TRANSFORMER FAULT
218	14/May/2021	GULBARGA	110	MUNIRABAD-STAR METTALIC	STAR METTALIC	12:14	12:17	0:03	LINE FAULT
219	14/May/2021	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	19:50	20:10	0:20	LINE FAULT
220	14/May/2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	5:14	5:22	0:08	LINE FAULT
221	14/May/2021	GULBARGA	110	MUNIRABAD-SINDHNOOR2	KAMPLI_110,KPC_IPP,MUKUNDA_110,KEREHALLI_ 110,MALLAPURA_110	0:45	1:02	0:17	LINE FAULT
222	14/May/2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	5:13	5:23	0:10	LINE FAULT
223	14/May/2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	12:00	15:50	3:50	LINE CLEAR AVOIDED
225	14/May/2021	GULBARGA	66	HV1	ITTAGI_220	16:50	17:00	0:10	TRANSFORMER FAULT
226	14/May/2021	GULBARGA	66	HV1	HANASI_66	4:50	4:55	0:05	LINE CLEAR AVOIDED
227	14/May/2021	GULBARGA	66	HV2	CHORNOOR_66	16:32	17:25	0:53	LINE CLEAR AVOIDED
228	14/May/2021	GULBARGA	66	HV2	CHORNOOR_66	19:15	19:40	0:25	TRANSFORMER FAULT
229	14/May/2021	GULBARGA	66	HV2	CHORNOOR_66	20:00	20:25	0:25	TRANSFORMER FAULT
230	14/May/2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	22:54 (14.05.2021)			LINE OPEN,LINE FAULT
231	14/May/2021	HASSAN	220	KADUR-SHIMOGA	KADUR_220	18:21(13.05.2021)	7:51(14.05.2021)	13:29 hrs	LINE CHARGED
232	14/May/2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	18:20(13.05.2021)	8:25(14.05.2021)	14:04 hrs	LINE CHARGED
233	14/May/2021	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	18:28(13.05.2021)	7:41(14.05.2021)	13:22 hrs	LINE CHARGED
234	14/May/2021	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	18:21(13.05.2021)	7:51(14.05.2021)	13:29 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
235	14/May/2021	HASSAN	220	MRSSH-M-SHARAVATHY4	MRSMSG_220	18:51(13.05.2021)	12:06(14.05.2021)	17:14 hrs	LINE CHARGED
236	14/May/2021	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	18:51(13.05.2021)	12:06(14.05.2021)	17:14 hrs	LINE CHARGED
237	14/May/2021	HASSAN	110	MRSSH-BADRAVATY2	MRSMSG_220	14:48	15:46	0:58	LINE FAULT
238	14/May/2021	HASSAN	220	HV2	MSEZ_220	10:42	12:00	1:18	LINE CLEAR AVAIED
239	14/May/2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	10:31	10:38	0:07	HAND TRIPPED
240	14/May/2021	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	12:46	14:56	2:10	LINE CLEAR AVAIED
241	14/May/2021	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	10:38	13:38	3:00	LINE CLEAR AVAIED
242	14/May/2021	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	8:30	11:45	3:15	LINE CLEAR AVAIED
243	14/May/2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	11:45	12:58	1:13	LINE CLEAR AVAIED
244	14/May/2021	HASSAN	110	HV1	SAGARA_110	10:42	11:12	0:30	LINE CLEAR AVAIED
245	14/May/2021	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	10:38	11:04	0:26	LINE FAULT
246	14/May/2021	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYAPATNA_66	17:38	17:46	0:08	LINE FAULT
247	14/May/2021	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYAPATNA_66	17:47	18:59	1:12	LINE FAULT
248	14/May/2021	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYAPATNA_66	19:05	19:08	0:03	HAND TRIPPED
249	14/May/2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	8:51	19:53	11:02	LINE CLEAR AVAIED
250	14/May/2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	8:51	19:53	11:02	LINE CLEAR AVAIED
251	14/May/2021	MYSURU	66	HV1	BETTADHAPURA_66	18:45	19:11	0:26	LINE CLEAR AVAIED
252	14/May/2021	MYSURU	66	HV2	BETTADHAPURA_66	18:45	19:01	0:16	LINE CLEAR AVAIED
253	14/May/2021	MYSURU	66	CR NAGARA-YALANDUR	YALANDUR_66	10:59	17:31	6:32	NFBC ISSUED
254	14/May/2021	MYSURU	66	HV2	DKMAIDANA_66	12:16	13:10	0:53	LINE CLEAR AVAIED
255	14/May/2021	MYSURU	66	HV2	ELAVALA_66	12:39	13:13	0:34	LINE CLEAR AVAIED
256	14/May/2021	MYSURU	66	JAKKANAHALLI-NAGAMANGALA	G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI_66 NAGAMANGALA_66	21:43	21:49	0:06	LINE FAULT
257	14/May/2021	MYSURU	66	KADAKOLA-NANJANGUDU 1	NANJANGUDU_66	16:46	16:53	0:07	LINE FAULT
258	14/May/2021	MYSURU	66	KADAKOLA-THANDYA	THANDYA_66	16:46	16:54	0:07	LINE FAULT
259	14/May/2021	MYSURU	66	KOLLEGALA-PARINAMIPURA	CHANDALLI_66 PARINAMIPURA_66 THALAKADU_66	8:29	8:35	0:06	LINE FAULT
260	14/May/2021	MYSURU	66	KUNTHUR-DR PETE	SANTHEMARAHALLI_66 MUGUR_66 THAYURU_66 JANNUR_66 TNARASIPURA_66	3:58	4:02	0:03	LINE FAULT
261	14/May/2021	MYSURU	66	KUSHALNAGARA-MYSORE-2	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	5:50	6:06	0:16	LINE FAULT
262	14/May/2021	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	5:55	6:00	0:04	LINE FAULT
263	14/May/2021	MYSURU	66	YALANDUR-MAMBALLI	YALANDUR_66	10:55	17:35	6:40	LINE CLEAR AVAIED
264	14/May/2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN,LINE CLEAR AVAIED
265	14/May/2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN,LINE CLEAR AVAIED
266	14/May/2021	TUMKUR	66	THALLAK 220kV- NAYAKANHATTI	CHITRADURGA_220	17:04	19:43	2:39	LINE FAULT
267	14/May/2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	3:59	4:10	0:11	LINE FAULT
268	14/May/2021	TUMKUR	66	TR-1	BADAVANAHALLI_66	11:45	13:20	1:34	LINE CLEAR AVAIED
269	14/May/2021	TUMKUR	66	TR-1	BHARAMAGIR_66	21:41	21:45	0:03	TRANSFORMER FAULT
270	14/May/2021	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	6:03	6:13	0:10	LINE FAULT
271	14/May/2021	TUMKUR	66	TR-2	MADKERE_66	15:52	17:55	2:02	TRANSFORMER FAULT
272	14/May/2021	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	4:54	6:55	2:00	LINE CLEAR AVAIED
273	14/May/2021	TUMKUR	66	TR-1	TAVAREKERE(C)_66	8:14	8:31	0:16	TRANSFORMER FAULT
274	14/May/2021	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	17:30(14.05.2021)			LINE OPEN,LINE FAULT
275	14/May/2021	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	10:29:41(14.05.2021)			MAIN SUPPLY FAILURE
276	14/May/2021	TUMKUR	66	TR-1(LV1)	DAVANGERE_SRS_220	17:30:24(14.05.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1	15/May/2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAIED
2	15/May/2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED YADAWAD_110	11:46	12:26	0:40	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
3	15/May/2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TARIHAL_110	8:40	8:48	0:08	TRANSFORMER FAULT
4	15/May/2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED ZALKI_110	12:42	13:32	0:50	TRANSFORMER FAULT
5	15/May/2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TAKKALKI_110	9:28	9:32	0:04	TRANSFORMER FAULT
6	15/May/2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SOUDATTI_110	9:33	19:21	9:48	TRANSFORMER FAULT
7	15/May/2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED RANNABELAGALI_110	20:00	22:15	2:15	TRANSFORMER FAULT
8	15/May/2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TAKKALKI_110	10:38	10:43	0:05	TRANSFORMER FAULT
9	15/May/2021	BAGALKOT	110	110/11KV,HV1	GULEDAGUDDA_110	9:14	9:24	0:10	TRANSFORMER FAULT
10	15/May/2021	BAGALKOT	110	110/11KV,HV1	HUKKERI_110	16:06	16:19	0:13	TRANSFORMER FAULT
11	15/May/2021	BAGALKOT	110	110/11KV,HV1	HUKKERI_110	11:28	15:47	4:19	LINE CLEAR AVOIDED
12	15/May/2021	BAGALKOT	110	110/11KV,HV1	HUKKERI_110	16:56	17:08	0:12	TRANSFORMER FAULT
13	15/May/2021	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	14:49	15:01	0:12	TRANSFORMER FAULT
14	15/May/2021	BAGALKOT	110	110/11KV,HV2	THORVI_110	16:46	16:52	0:06	TRANSFORMER FAULT
15	15/May/2021	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	13:38	13:42	0:04	TRANSFORMER FAULT
16	15/May/2021	BAGALKOT	110	110/11KV,HV2	ITNAL_110	14:27	14:36	0:09	TRANSFORMER FAULT
17	15/May/2021	BAGALKOT	110	110/33KV, HV3	DUMWAD_33, IE_33 STATION NOT AFFECTED TARIHAL_110	9:45	11:06	1:21	LINE CLEAR AVOIDED
18	15/May/2021	BAGALKOT	110	110/33KV, HV4	DULKHAED_33, NIVARGI_33, HALASANGI_33 STATION NOT AFFECTED ZALKI_110	14:54	17:41	2:47	TRANSFORMER FAULT
19	15/May/2021	BAGALKOT	110	AMBEWADI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	20:00 (14.05.2021)	8:52 (15.05.2021)	12:52 hrs	LINE CHARGED
20	15/May/2021	BAGALKOT	110	AMBEWADI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	15:00	22:15	7:15	LINE CLEAR AVOIDED
21	15/May/2021	BAGALKOT	110	AMBEWADI-NK2	STATION NOT AFFECTED AMBEWADI_220	9:21	9:30	0:09	HAND TRIPPED
22	15/May/2021	BAGALKOT	110	AMBEWADI-NK2	STATION NOT AFFECTED AMBEWADI_220	18:47	18:51	0:04	HAND TRIPPED
23	15/May/2021	BAGALKOT	110	AMBEWADI-NK2	STATION NOT AFFECTED AMBEWADI_220	20:21	20:23	0:02	HAND TRIPPED
24	15/May/2021	BAGALKOT	110	AMBWADI-XELDOM(PONDA1)	STATION NOT AFFECTED AMBEWADI_220	18:23 (14.05.2021)			LINE OPEN,LINE FAULT
25	15/May/2021	BAGALKOT	110	ANKOLA-KUMTA2	STATION NOT AFFECTED ANKOLA_110	21:58 (15.05.2021)			LINE OPEN,LINE FAULT
26	15/May/2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVOIDED
27	15/May/2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVOIDED
28	15/May/2021	BAGALKOT	110	GADAG ROAD-BIDNAL(GOPPANAKOPPA)	STATION NOT AFFECTED GADAG ROAD_110	13:19	14:59	1:40	LINE CLEAR AVOIDED
29	15/May/2021	BAGALKOT	110	GADAG ROAD-GOPPANAKOPPA	STATION NOT AFFECTED GOPPANAKOPPA_110	13:01	15:01	2:00	NFBC ISSUED
30	15/May/2021	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	8:58 (15.05.2021)			LINE OPEN,LINE CLEAR AVOIDED
31	15/May/2021	BAGALKOT	110	GAJENDRAGAD-RON2	STATION NOT AFFECTED GAJENDRAGAD_110	8:58 (15.05.2021)			LINE OPEN,LINE CLEAR AVOIDED
32	15/May/2021	BAGALKOT	110	HALIYAL-ALNAVAR	ALNAVAR_110	13:30	13:43	0:13	LINE FAULT
33	15/May/2021	BAGALKOT	110	HALIYAL-ALNAVAR	ALNAVAR_110	14:53	18:11	3:18	LINE FAULT
34	15/May/2021	BAGALKOT	110	HATTARAGI-DADDI(BELGAUM)	DADDI_110	8:20	8:44	0:24	LINE FAULT
35	15/May/2021	BAGALKOT	110	HIREBEVANUR-RODAGI(INDI-LACHYAN)	RODAGI_110	15:26	15:32	0:06	LINE FAULT
36	15/May/2021	BAGALKOT	110	HIREHAL-RON	RON_110	8:27	8:38	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
37	15/May/2021	BAGALKOT	110	HUBLI-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA 110	15:19	16:16	0:57	LINE FAULT
38	15/May/2021	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA 110	20:18	20:29	0:11	HAND TRIPPED
39	15/May/2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
40	15/May/2021	BAGALKOT	110	MALGHAN(S)-MANALI SUGARS	MALGHAN(S) 110	19:02	19:09	0:07	LINE FAULT
41	15/May/2021	BAGALKOT	110	MRUTHYUNJAYANAGAR-NAREDA1	STATION NOT AFFECTED MRUTHYUNJAYANAGAR 110	11:09	13:04	1:55	LINE CLEAR AVAILED
42	15/May/2021	BAGALKOT	110	PG HUNSHYAL	MUDALGI 110	4:22	4:32	0:10	LINE FAULT
43	15/May/2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
44	15/May/2021	BAGALKOT	110	SIRSI-SIDDAPUR(JOG2)	STATION NOT AFFECTED SIRSI 110	10:22	11:53	1:31	NFBC ISSUED
45	15/May/2021	BAGALKOT	220	AMBEWADI-NAGJHARI1	STATION NOT AFFECTED AMBEWADI 220	13:40	16:27	2:47	LINE CLEAR AVAILED
46	15/May/2021	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI 220	20:24 (15.05.2021)			LINE OPEN,LINE FAULT
47	15/May/2021	BAGALKOT	220	BIDNAL-NAGJHARI2	STATION NOT AFFECTED BIDNAL 220	19:33 (14.05.2021)	14:0 (15.05.2021)	18:27 hrs	LINE CHARGED
48	15/May/2021	BAGALKOT	220	BIDNAL-NAGJHARI2	STATION NOT AFFECTED BIDNAL 220	14:00 (15.05.2021)			LINE OPEN,LINE FAULT
49	15/May/2021	BAGALKOT	220	GHATAPRABHA-KUDUCHI	STATION NOT AFFECTED GHATAPRABHA 220	18:13	18:18	0:05	LINE FAULT
50	15/May/2021	BAGALKOT	220	HUBLI-NAGZARI3	STATION NOT AFFECTED HUBLI 220	11:44	12:38	0:54	HAND TRIPPED
51	15/May/2021	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI 220	13:09	15:14	2:05	LINE CLEAR AVAILED
52	15/May/2021	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI 220	13:11	15:04	1:53	LINE CLEAR AVAILED
53	15/May/2021	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR 220	15:44	17:56	2:12	LINE FAULT
54	15/May/2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
55	15/May/2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
56	15/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI 220	15:53 (12.05.2021)	13:42 (15.05.2021)	69:49 hrs	LINE CHARGED
57	15/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI 220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
58	15/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI 220	14:16 (04.05.2021)	13:09 (15.05.2021)	262:53 hrs	LINE CHARGED
59	15/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI 220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
60	15/May/2021	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI 220	13:09	15:17	2:08	LINE CLEAR AVAILED
61	15/May/2021	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI 220	15:44	17:57	2:13	LINE FAULT
62	15/May/2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
63	15/May/2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
64	15/May/2021	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	7:38	7:42	0:04	LOAD CHANGE OVER
65	15/May/2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT	7:06	7:25	0:18	LINE FAULT
66	15/May/2021	BENGALURU	66	HV1	DEVANAHALLI	9:00	9:10	0:10	TRANSFORMER FAULT
67	15/May/2021	BENGALURU	66	HV1	MALLASANDRA	15:54	16:13	0:19	TRANSFORMER FAULT
68	15/May/2021	BENGALURU	66	HV1	MALLASANDRA	17:13	17:45	0:32	LINE CLEAR AVAILED
69	15/May/2021	BENGALURU	66	HV1	SM MANGALA	8:47	9:20	0:32	LINE CLEAR AVAILED
70	15/May/2021	BENGALURU	66	HV2	SOMAYAJANAHALLI	12:34	12:40	0:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
71	15/May/2021	BENGALURU	66	HV2	VOLVO	12:29	13:52	1:22	LINE CLEAR AVOIDED
72	15/May/2021	BENGALURU	66	HV2	JAGAMKOTE	8:34	10:17	1:43	LINE CLEAR AVOIDED
73	15/May/2021	BENGALURU	66	HV2	BANASHANKARI	12:50	12:55	0:05	LINE CLEAR AVOIDED
74	15/May/2021	BENGALURU	66	HV3	KGF	11:54	12:10	0:15	TRANSFORMER FAULT
75	15/May/2021	BENGALURU	66	HV3	KGF	12:10	13:30	1:20	LINE CLEAR AVOIDED
76	15/May/2021	BENGALURU	66	HV3	EPIP 220	5:41	6:15	0:34	TRANSFORMER FAULT
77	15/May/2021	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	8:20	8:26	0:05	LINE FAULT
78	15/May/2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	10:49	10:53	0:04	LINE CLEAR AVOIDED
79	15/May/2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	10:49	10:53	0:04	LINE CLEAR AVOIDED
80	15/May/2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	10:49	10:53	0:04	LINE CLEAR AVOIDED
81	15/May/2021	GULBARGA	66	ITTAGI-RENEWSOLAR1&2_IPP	ITTAGI_220	18:20	19:30	1:10	LINE CLEAR AVOIDED
82	15/May/2021	GULBARGA	66	ITTAGI-SUZLON1&2_IPP	ITTAGI_220	11:17	13:20	2:03	LINE CLEAR AVOIDED
83	15/May/2021	GULBARGA	110	ALIPUR-RVNL	ALIPUR_220	0:10	1:36	1:26	LINE FAULT
84	15/May/2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	15:16	19:00	3:44	LINE FAULT
85	15/May/2021	GULBARGA	110	HUMNABAD-RAJESHWAR	RAJESHWAR_110,SASTHAPUR_110,MANTHAL_110	23:00	23:10	0:10	LINE FAULT
86	15/May/2021	GULBARGA	110	HV1	SANKLAPUR_110	13:50	14:02	0:12	TRANSFORMER FAULT
87	15/May/2021	GULBARGA	110	HV1	MADIYAL_110	12:20	12:25	0:05	TRANSFORMER FAULT
88	15/May/2021	GULBARGA	110	HV1	MADIYAL_110	16:35	16:40	0:05	TRANSFORMER FAULT
89	15/May/2021	GULBARGA	110	HV1	NIRNA_110	17:50	17:55	0:05	TRANSFORMER FAULT
90	15/May/2021	GULBARGA	110	HV1	BENNUR_110	11:30	11:50	0:20	TRANSFORMER FAULT
91	15/May/2021	GULBARGA	110	HV2	SHAHAPUR_220	14:19	14:36	0:17	TRANSFORMER FAULT
92	15/May/2021	GULBARGA	110	HV2	HATTI_110	16:10	16:13	0:03	TRANSFORMER FAULT
93	15/May/2021	GULBARGA	110	HV2	HANUMANAL_110	7:13	7:22	0:09	TRANSFORMER FAULT
94	15/May/2021	GULBARGA	110	HV3	KAMPLI_110	15:00	15:06	0:06	TRANSFORMER FAULT
95	15/May/2021	GULBARGA	110	HV3	MADIYAL_110	15:45	17:35	1:50	TRANSFORMER FAULT
96	15/May/2021	GULBARGA	110	JANAWADA-SANTHPUR	SANTHPUR_110	18:20	18:50	0:30	LINE FAULT
97	15/May/2021	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	KOLHAR_110	11:46	12:20	0:34	LINE CLEAR AVOIDED
98	15/May/2021	GULBARGA	110	LINGSUGUR-SHAHAPUR	SHAHAPUR_220	10:38	11:08	0:30	LINE FAULT
99	15/May/2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	14:19	14:23	0:04	LINE CLEAR AVOIDED
100	15/May/2021	GULBARGA	110	MUNIRABAD-MALLAPUR	MALLAPUR_110	0:40	1:01	0:21	MAIN SUPPLY FAILURE
101	15/May/2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	14:15	14:25	0:10	LINE FAULT
102	15/May/2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	18:45	18:54	0:09	LINE FAULT
103	15/May/2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	0:45	0:50	0:05	LINE FAULT
104	15/May/2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	11:06	11:11	0:05	LINE FAULT
105	15/May/2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	15:13	15:23	0:10	LINE FAULT
106	15/May/2021	GULBARGA	110	RAJESHWAR-SATHAPUR	SASTHAPUR_110,MANTHAL_110(Station not affected)	23:00(15.05.2021)			LINE OPEN,LINE FAULT
107	15/May/2021	GULBARGA	110	SANKLAPUR-MUNIRABAD	SANKLAPUR_110	19:14	20:14	1:00	LINE CLEAR AVOIDED
108	15/May/2021	GULBARGA	110	SANKLAPUR-TORANGALLU	TORANGALLU_110,KUDITINI_110,KURUGOD_110,S HATVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAM ALAPUR_110,MATRI_110,RBNS FACTORY	9:15	11:20	2:05	LINE CLEAR AVOIDED
109	15/May/2021	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110,JEWARAGI_110,SHAHAPUR_110	11:25	11:40	0:15	LINE FAULT
110	15/May/2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	22:00	22:09	0:09	LINE FAULT
111	15/May/2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	10:05	19:27	9:22	LINE CLEAR AVOIDED
112	15/May/2021	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADONA_110,SRN AGAR_110,MALLAPUR_110	3:05	3:15	0:10	LINE FAULT
113	15/May/2021	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADONA_110,SRN AGAR_110,MALLAPUR_110	3:15	9:26	6:11	LINE FAULT
114	15/May/2021	GULBARGA	220	BTPSG-ALIPUR	ALIPUR_220	1:56	2:35	0:39	LINE FAULT
115	15/May/2021	GULBARGA	220	BTPS-LINGAPUR	LINGAPUR_220	0:12	2:57	2:45	LINE FAULT
116	15/May/2021	GULBARGA	220	HALBARGA-HUMNABAD1	HALBARGA_220	11:27	11:37	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
117	15/May/2021	GULBARGA	220	HUMNABAD-HALBARGA	HALBARGA_220	7:53	9:20	1:27	LINE CLEAR AVOIDED
118	15/May/2021	GULBARGA	220	HUMNABAD-HALBARGA	HALBARGA_220	9:24	12:25	3:01	LINE CLEAR AVOIDED
119	15/May/2021	GULBARGA	220	HV1	HALBARGA_220	8:10	8:17	0:07	TRANSFORMER FAULT
120	15/May/2021	GULBARGA	220	HV2	HUMNABAD_220	17:15	19:15	2:00	LINE CLEAR AVOIDED
121	15/May/2021	GULBARGA	220	RTPS-RAICHUR1	RTPS_220	18:03	18:28	0:25	LINE CLEAR AVOIDED
122	15/May/2021	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	11:47	18:26	6:39	LINE FAULT
123	15/May/2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400(Station not affected)	22:04(15.05.2021)			LINE OPEN,LINE FAULT
124	15/May/2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400	16:03(14.05.2021)	17:52(15.05.2021)	25:49HRS	LINE CHARGED
125	15/May/2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	19:50	20:29	0:39	MAIN SUPPLY FAILURE
126	15/May/2021	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	19:50	20:25	0:35	MAIN SUPPLY FAILURE
127	15/May/2021	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	11:10	14:41	3:31	MAIN SUPPLY FAILURE
128	15/May/2021	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYAPATNA_66	16:06	16:15	0:09	HAND TRIPPED
129	15/May/2021	HASSAN	66	HANUAL-SAKLESPUR	HANBALU_66	11:10	16:02	4:52	NFBC ISSUED
130	15/May/2021	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	6:37	6:52	0:15	LINE FAULT
131	15/May/2021	HASSAN	66	HV1	AREHALLI_HSN_66	11:10	16:49	5:39	NFBC ISSUED
132	15/May/2021	HASSAN	66	HV1	AREHALLI_HSN_66	17:15	17:37	0:22	LINE CLEAR AVOIDED
133	15/May/2021	HASSAN	66	HV1	HANBALU_66	11:10	16:03	4:53	NFBC ISSUED
134	15/May/2021	HASSAN	66	HV1	MAGGE_66	11:08	14:36	3:28	MAIN SUPPLY FAILURE
135	15/May/2021	HASSAN	66	HV1	MALALI_66	6:40	6:52	0:12	MAIN SUPPLY FAILURE
136	15/May/2021	HASSAN	66	HV1	SAKLESHPURA_66	11:26	15:06	3:40	MAIN SUPPLY FAILURE
137	15/May/2021	HASSAN	66	HV2	MAGGE_66	11:08	14:36	3:28	MAIN SUPPLY FAILURE
138	15/May/2021	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	11:00	14:34	3:34	LINE CLEAR AVOIDED
139	15/May/2021	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGARA_66	3:44	7:30	3:46	LINE FAULT
140	15/May/2021	HASSAN	66	SAKALE-HANBAL	SAKLESHPURA_66	11:23	16:00	4:37	NFBC ISSUED
141	15/May/2021	HASSAN	66	SAKALE-HASSAN1	SAKLESHPURA_66	11:10	14:45	3:35	NFBC ISSUED
142	15/May/2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	14:07	14:54	0:47	LINE CLEAR AVOIDED
143	15/May/2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	14:07	14:54	0:47	LINE CLEAR AVOIDED
144	15/May/2021	HASSAN	110	HV1	MSEZ_220	5:41	12:55	7:14	TRANSFORMER FAULT
145	15/May/2021	HASSAN	110	HV1	NANDIKUR_110	12:27	12:33	0:06	TRANSFORMER FAULT
146	15/May/2021	HASSAN	110	HV1	SAGARA_110	10:41	10:56	0:15	TRANSFORMER FAULT
147	15/May/2021	HASSAN	110	HV2	PUTTUR_110(STATION NOT EFFECTED)	9:34(15.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVOIDED
148	15/May/2021	HASSAN	110	HV2	NITTUR_110	15:34	17:05	1:31	TRANSFORMER FAULT
149	15/May/2021	HASSAN	110	HV2	BRAHMAVARA_110	7:36	11:39	4:03	TRANSFORMER FAULT
150	15/May/2021	HASSAN	110	HV3	HIRIYADKA_110	6:42	6:53	0:11	TRANSFORMER FAULT
151	15/May/2021	HASSAN	110	LV1	MSEZ_220	10:21	11:02	0:41	LINE CLEAR AVOIDED
152	15/May/2021	HASSAN	110	LV2	KEMAR_220	10:39	13:11	2:32	LINE CLEAR AVOIDED
153	15/May/2021	HASSAN	110	LV2	MSEZ_220	11:22	13:18	1:56	LINE CLEAR AVOIDED
154	15/May/2021	HASSAN	220	HV1	MSEZ_220	10:21	10:58	0:37	LINE CLEAR AVOIDED
155	15/May/2021	HASSAN	220	HV2	KEMAR_220	10:39	13:10	2:31	LINE CLEAR AVOIDED
156	15/May/2021	HASSAN	220	HV2	MSEZ_220	11:22	13:17	1:55	LINE CLEAR AVOIDED
157	15/May/2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	22:54 (14.05.2021)	11:27 (15.05.2021)	12:32 hrs	LINE CHARGED
158	15/May/2021	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	11:16	12:23	1:07	LINE CLEAR AVOIDED
159	15/May/2021	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	11:16	12:23	1:07	LINE CLEAR AVOIDED
160	15/May/2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	19:06	19:54	0:48	LINE FAULT
161	15/May/2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	1:12	7:43	6:31	LINE CLEAR AVOIDED
162	15/May/2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	14:49	20:31	5:42	LINE CLEAR AVOIDED
163	15/May/2021	MYSURU	66	ELAVALA-HUNSUR	GAVADAGERE_66	18:43	18:56	0:13	LINE FAULT
164	15/May/2021	MYSURU	66	HUNSUR-ELAVALA	GAVADAGERE_66	18:43	19:06	0:23	LINE FAULT
165	15/May/2021	MYSURU	66	HV1	HDKOTE_66	13:35	14:00	0:25	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
166	15/May/2021	MYSURU	66	HV2	KOLLEGALA_66	10:51	11:48	0:56	LINE CLEAR AVAILED
167	15/May/2021	MYSURU	66	HV2	MEGALAPURA_66	10:40	11:40	1:00	LINE CLEAR AVAILED
168	15/May/2021	MYSURU	66	HV2	SATHEGALA_66	3:26	3:39	0:13	TRANSFORMER FAULT
169	15/May/2021	MYSURU	66	KADAKOLA-SARAGURU 1	JAIPUR_66 HAMPAPURA(K)_66	7:14	7:17	0:02	LINE FAULT
170	15/May/2021	MYSURU	66	KADAKOLA-SARAGURU 1	JAIPUR_66 HAMPAPURA(K)_66	7:17	7:23	0:05	LINE FAULT
171	15/May/2021	MYSURU	66	KADAKOLA-SARAGURU 1	JAIPUR_66 HAMPAPURA(K)_66	7:23	9:52	2:29	LINE FAULT
172	15/May/2021	MYSURU	66	KUSHALANAGARA 220-MERCERA-1	MADIKERI_66	14:11	15:38	1:27	LINE CLEAR AVAILED
173	15/May/2021	MYSURU	66	KUSHALANAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	1:51	1:55	0:04	LINE FAULT
174	15/May/2021	MYSURU	66	KUSHALANAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	7:55	8:05	0:10	LINE FAULT
175	15/May/2021	MYSURU	66	KUSHALANAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	8:08	8:14	0:05	LINE FAULT
176	15/May/2021	MYSURU	66	KUSHALANAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	11:53	12:15	0:21	LINE FAULT
177	15/May/2021	MYSURU	66	KUSHALANAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	12:26	12:40	0:13	LINE FAULT
178	15/May/2021	MYSURU	66	KUSHALANAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	13:03	14:11	1:08	LINE FAULT
179	15/May/2021	MYSURU	66	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	14:11	15:35	1:24	LINE CLEAR AVAILED
180	15/May/2021	MYSURU	66	KUSHALANAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	15:35	16:33	0:57	LINE FAULT
181	15/May/2021	MYSURU	66	KUSHALANAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	16:36	17:31	0:54	LINE FAULT
182	15/May/2021	MYSURU	66	KUSHALANAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	17:31	18:04	0:33	LINE CLEAR AVAILED
183	15/May/2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN,LINE CLEAR AVAILED
184	15/May/2021	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	1:52	1:59	0:06	LINE FAULT
185	15/May/2021	MYSURU	66	SUNTIKOP-MADIKERI	MADIKERI_66	14:09	15:42	1:32	NFBC ISSUED
186	15/May/2021	MYSURU	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	18:50	19:10	0:20	LINE FAULT
187	15/May/2021	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66	18:59	19:11	0:12	HAND TRIPPED
188	15/May/2021	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66	18:50	19:10	0:20	HAND TRIPPED
189	15/May/2021	MYSURU	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	18:59	19:11	0:12	HAND TRIPPED
190	15/May/2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN,LINE CLEAR AVAILED
191	15/May/2021	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220(STATION NOT EFFECTED)	17:30(14.05.2021)			LINE OPEN,LINE FAULT
192	15/May/2021	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66(STATION NOT EFFECTED)	10:29:41(14.05.2021)			MAIN SUPPLY FAILURE
193	15/May/2021	TUMKUR	66	TR-1(LV1)	DAVANGERE_SRS_220(LOAD IS ON TR2)	17:30:24(14.05.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
194	15/May/2021	TUMKUR	66	ANTHRASANAHALLI 220kV- KOLTEGERE	KOLTEGERE,CHIKKATOTLUKERE_66, BELADARA_66	16:22	17:00	0:38	LINE FAULT
195	15/May/2021	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	17:33	18:09	0:35	LINE FAULT
196	15/May/2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	10:22	10:37	0:14	MAIN SUPPLY FAILURE
197	15/May/2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	12:42	12:54	0:11	MAIN SUPPLY FAILURE
198	15/May/2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:00	6:12	0:12	LINE FAULT
199	15/May/2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	11:58	12:05	0:07	LINE FAULT
200	15/May/2021	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	4:41	4:54	0:12	LINE FAULT
201	15/May/2021	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	5:38	5:44	0:06	LINE FAULT
202	15/May/2021	TUMKUR	66	MALEBENNUR66-HONNALLI_220	MALEBENNUR_66	4:06	4:35	0:29	LINE FAULT
203	15/May/2021	TUMKUR	66	NAGASAMUDRA- RAMPUR	RAMPURA_66	8:20	9:50	1:30	LINE CLEAR AVAILED
204	15/May/2021	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	3:00	3:17	0:17	LINE FAULT
205	15/May/2021	TUMKUR	66	TR-1	CHALLAKERE_66	11:34	11:49	0:15	LINE CLEAR AVAILED
206	15/May/2021	TUMKUR	66	TR-1	CHALLAKERE_66	16:17	16:19	0:01	TRANSFORMER FAULT
207	15/May/2021	TUMKUR	66	TR-1	HULIYURDURGA_66	14:09	16:16	2:06	LINE CLEAR AVAILED
208	15/May/2021	TUMKUR	66	TR-1	MADHUGIRI_220	14:20	14:40	0:19	LINE CLEAR AVAILED
209	15/May/2021	TUMKUR	66	TR-1	MADKERE_66	12:35	12:45	0:09	TRANSFORMER FAULT
210	15/May/2021	TUMKUR	66	TR-1	MAYAKONDA_66	14:46	15:09	0:23	TRANSFORMER FAULT
211	15/May/2021	TUMKUR	66	TR-1	MYLANAHALLI_66	13:50	14:09	0:18	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
212	15/May/2021	TUMKUR	66	TR-1	PAVAGADA_220	14:11	14:17	0:05	TRANSFORMER FAULT
213	15/May/2021	TUMKUR	66	TR-2	BALENAHALI_66	15:23	15:35	0:12	TRANSFORMER FAULT
214	15/May/2021	TUMKUR	66	TR-2	GUTTUR_66	10:39	10:42	0:02	HAND TRIPPED
215	15/May/2021	TUMKUR	66	TR-2	GUTTUR_66	13:00	13:02	0:01	HAND TRIPPED
216	15/May/2021	TUMKUR	66	TR-2	HIRIYUR_66	2:16	2:27	0:10	HAND TRIPPED
217	15/May/2021	TUMKUR	66	TR-2	HULIYURDURGA_66	14:11	16:16	2:05	LINE CLEAR AVAILED
218	15/May/2021	TUMKUR	66	TR-2	MALEBENNUR_66	4:35	4:52	0:16	TRANSFORMER FAULT
219	15/May/2021	TUMKUR	66	TR-2	MALEBENNUR_66	14:33	14:43	0:09	TRANSFORMER FAULT
220	15/May/2021	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	11:03	11:17	0:14	TRANSFORMER FAULT
221	15/May/2021	TUMKUR	110	TR-2	TURUVEKERE_110	11:25	12:16	0:51	LINE CLEAR AVAILED
222	16/May/2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
223	16/May/2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TAKKALKI_110	9:28	9:32	0:04	HAND TRIPPED
224	16/May/2021	BAGALKOT	110	110/11KV, HV1 (HV3)	STATION NOT AFFECTED SAVALAGI_110	7:48	7:56	0:08	TRANSFORMER FAULT
225	16/May/2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SIRSI_110	13:01	13:13	0:12	LINE CLEAR AVAILED
226	16/May/2021	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	10:30	12:30	2:00	LINE CLEAR AVAILED
227	16/May/2021	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED ANKOLA_110	5:04	11:03	5:59	TRANSFORMER FAULT
228	16/May/2021	BAGALKOT	110	110/11KV,HV1	HUKKERI_110	20:19	20:25	0:06	TRANSFORMER FAULT
229	16/May/2021	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	3:24	3:30	0:06	TRANSFORMER FAULT
230	16/May/2021	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	14:14	14:24	0:10	TRANSFORMER FAULT
231	16/May/2021	BAGALKOT	110	110/11KV,HV1	GADIGAWADA_33,ACME SOLAR_33 STATION NOT AFFECTED MK HUBLI_110	9:15	12:21	3:06	TRANSFORMER FAULT
232	16/May/2021	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	9:21	9:38	0:17	TRANSFORMER FAULT
233	16/May/2021	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	13:42	13:54	0:12	TRANSFORMER FAULT
234	16/May/2021	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	5:19	5:23	0:04	TRANSFORMER FAULT
235	16/May/2021	BAGALKOT	110	110/11KV,HV2	THORVI_110	7:28	7:30	0:02	TRANSFORMER FAULT
236	16/May/2021	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED CHIKKODI_110	16:40	19:16	2:36	TRANSFORMER FAULT
237	16/May/2021	BAGALKOT	110	110/11KV,HV2	KALAGATAGI_110	15:24	15:32	0:08	TRANSFORMER FAULT
238	16/May/2021	BAGALKOT	110	110/11KV,HV2A	JAMAKHANDI_110	16:03	16:24	0:21	LINE CLEAR AVAILED
239	16/May/2021	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	14:13	14:53	0:40	TRANSFORMER FAULT
240	16/May/2021	BAGALKOT	110	110/33KV, HV4	DULKHAED_33, NIVARGI_33, HALASANGI_33 STATION NOT AFFECTED ZALKI_110	11:52	11:56	0:04	TRANSFORMER FAULT
241	16/May/2021	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	7:16 (16.05.2021)			LOAD CURTAILMENT
242	16/May/2021	BAGALKOT	110	AMBWADI-XELDOM(PONDA1)	STATION NOT AFFECTED AMBEWADI_220	18:23 (14.05.2021)	19:27 (16.05.2021)	49:04 hrs	LINE CHARGED
243	16/May/2021	BAGALKOT	110	ANKOLA-KUMTA2	STATION NOT AFFECTED ANKOLA_110	21:58 (15.05.2021)	11:01 (16.05.2021)	13:03 hrs	LINE CHARGED
244	16/May/2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
245	16/May/2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
246	16/May/2021	BAGALKOT	110	BHUTNAL-THORVI	STATION NOT AFFECTED THORVI_110	7:28	7:29	0:01	LINE FAULT
247	16/May/2021	BAGALKOT	110	CHIKKODI-WIND MILL	STATION NOT AFFECTED CHIKKODI_110	19:45	20:47	1:02	LINE CLEAR AVAILED
248	16/May/2021	BAGALKOT	110	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	8:58 (15.05.2021)	14:13 (16.05.2021)	29:15 hrs	LINE CHARGED
249	16/May/2021	BAGALKOT	110	GAJENDRAGAD-RON2	STATION NOT AFFECTED GAJENDRAGAD_110	8:58 (15.05.2021)	14:13 (16.05.2021)	29:15 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
250	16/May/2021	BAGALKOT	110	HIREHAL-MFR SOLAR	STATION NOT AFFECTED HIREHAL_110	12:59	13:14	0:15	HAND TRIPPED
251	16/May/2021	BAGALKOT	110	HIREHAL-MFR SOLAR	STATION NOT AFFECTED HIREHAL_110	18:12	18:41	0:29	HAND TRIPPED
252	16/May/2021	BAGALKOT	110	KARWAR-(SOLARIS)BINAGA	STATION NOT AFFECTED KARWAR_220	7:32	8:47	1:15	LINE FAULT
253	16/May/2021	BAGALKOT	110	KARWAR-ARGA	ARGA_110	4:27	5:02	0:35	LINE FAULT
254	16/May/2021	BAGALKOT	110	KARWAR-ARGA	ARGA_110	6:53	8:44	1:51	LINE FAULT
255	16/May/2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
256	16/May/2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
257	16/May/2021	BAGALKOT	110	RON-GAJENDRAGAD1	GAJENDRAGAD_110	13:02	13:08	0:06	HAND TRIPPED
258	16/May/2021	BAGALKOT	110	RON-GAJENDRAGAD2	GAJENDRAGAD_110	13:02	13:08	0:06	HAND TRIPPED
259	16/May/2021	BAGALKOT	110	RON-GAMESH IPP	RON_110 GAMESH IPP_110	13:02	13:10	0:08	HAND TRIPPED
260	16/May/2021	BAGALKOT	110	SAVANUR-ASIANFEBTECH(HAVERI ASF)	ASIANFEBTECH IPP_110 STATION NOT AFFECTED SAVANUR_110	16:03	16:11	0:08	LINE FAULT
261	16/May/2021	BAGALKOT	110	SAVANUR-ASIANFEBTECH(HAVERI ASF)	ASIANFEBTECH IPP_110 STATION NOT AFFECTED SAVANUR_110	16:12	16:20	0:08	LINE FAULT
262	16/May/2021	BAGALKOT	110	SIRSI-KUMTA2	STATION NOT AFFECTED SIRSI_110	5:59	15:07	9:08	LINE FAULT
263	16/May/2021	BAGALKOT	220	AMBEEWADI-NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	0:23	0:43	0:20	LINE FAULT
264	16/May/2021	BAGALKOT	220	AMBEEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	20:24 (15.05.2021)			LINE OPEN,LINE FAULT
265	16/May/2021	BAGALKOT	220	BELGAUM220-UCHHAGOAN(HUKKERI)	UCHHAGOAN_110	18:59	19:37	0:38	LINE FAULT
266	16/May/2021	BAGALKOT	220	BIDNAL-NAGJHARI2	STATION NOT AFFECTED BIDNAL_220	14:00 (15.05.2021)			LINE OPEN,LINE FAULT
267	16/May/2021	BAGALKOT	220	GHATAPRABHA-KUDUCHI	STATION NOT AFFECTED GHATAPRABHA_220	7:07	9:45	2:38	LINE FAULT
268	16/May/2021	BAGALKOT	220	HUBLI-NAGZARI1	STATION NOT AFFECTED HUBLI_220	15:58	17:13	1:15	LINE FAULT
269	16/May/2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
270	16/May/2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
271	16/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
272	16/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
273	16/May/2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
274	16/May/2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
275	16/May/2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	9:19	11:02	1:42	LINE CLEAR AVAILED
276	16/May/2021	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI	12:50	13:04	0:14	LINE FAULT
277	16/May/2021	BENGALURU	66	HV1	SADALI	9:30	10:20	0:50	LINE CLEAR AVAILED
278	16/May/2021	BENGALURU	66	HV1	GODURU	22:20(16-MAY 2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
279	16/May/2021	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	13:55	14:11	0:16	LINE CLEAR AVAILED
280	16/May/2021	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGGANADODDI	13:20	14:05	0:45	MAIN SUPPLY FAILURE
281	16/May/2021	BENGALURU	66	KADUGODI - EPIP 220	KADUGODI	12:50	13:04	0:14	LINE FAULT
282	16/May/2021	BENGALURU	66	KADUGODI - KONDAKPURA	ARMY WELFARE ORGANIZATION, KONDAKPURA	12:50	13:16	0:26	LINE FAULT
283	16/May/2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	12:34	12:40	0:05	LINE FAULT
284	16/May/2021	GULBARGA	66	HV1	ITTAGI_220	14:54	20:26	5:32	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
285	16/May/2021	GULBARGA	66	ITTAGI-HIREHADAGALLI2	ITTAGI_220	16:52	16:58	0:06	LINE FAULT
286	16/May/2021	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,S HATVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAM ALAPUR_110,MATRI_110,RBNS FACTORY	16:44	16:56	0:12	LINE FAULT
287	16/May/2021	GULBARGA	110	HV1	SANKLAPUR_110	21:36	23:43	2:07	TRANSFORMER FAULT
288	16/May/2021	GULBARGA	110	HV1	MADIYAL_110	14:58	15:05	0:07	TRANSFORMER FAULT
289	16/May/2021	GULBARGA	110	HV1	NIRNA_110	8:30	8:35	0:05	TRANSFORMER FAULT
290	16/May/2021	GULBARGA	110	HV1	NIRNA_110	10:15	10:20	0:05	TRANSFORMER FAULT
291	16/May/2021	GULBARGA	110	HV1	NIRNA_110	13:20	13:25	0:05	TRANSFORMER FAULT
292	16/May/2021	GULBARGA	110	HV2	SANKLAPUR_110	14:50	15:02	0:12	TRANSFORMER FAULT
293	16/May/2021	GULBARGA	110	HV2	HATTI_110	12:20	12:23	0:03	TRANSFORMER FAULT
294	16/May/2021	GULBARGA	110	HV2	HATTI_110	12:52	12:55	0:03	TRANSFORMER FAULT
295	16/May/2021	GULBARGA	110	HV2	HATTI_110	14:15	14:19	0:04	TRANSFORMER FAULT
296	16/May/2021	GULBARGA	110	HV3	HANUMASAGAR_110	4:20	4:30	0:10	TRANSFORMER FAULT
297	16/May/2021	GULBARGA	110	HV3	HANUMASAGAR_110	10:22	11:00	0:38	TRANSFORMER FAULT
298	16/May/2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	0:18	0:28	0:10	LINE FAULT
299	16/May/2021	GULBARGA	110	KAPNOOR-KADAGANCHI	ALNAD_110,KADAGANCHI_110	0:20	0:25	0:05	MAIN SUPPLY FAILURE
300	16/May/2021	GULBARGA	110	KAPNOOR-KADAGANCHI	ALNAD_110,KADAGANCHI_110	9:30	9:45	0:15	LINE FAULT
301	16/May/2021	GULBARGA	110	KAPNOOR-KADAGANCHI	ALNAD_110,KADAGANCHI_110	10:10	10:15	0:05	LINE FAULT
302	16/May/2021	GULBARGA	110	KAPNOOR-KADAGANCHI	ALNAD_110,KADAGANCHI_110	12:05	12:10	0:05	LINE FAULT
303	16/May/2021	GULBARGA	110	KUSHATGI-HANUMASAGAR	HANUMASAGAR_110	12:50	13:30	0:40	MAIN SUPPLY FAILURE
304	16/May/2021	GULBARGA	110	KUSHATGI-HANUMASAGAR	HANUMASAGAR_110	12:00	12:34	0:34	MAIN SUPPLY FAILURE
305	16/May/2021	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	22:49	22:58	0:09	LINE FAULT
306	16/May/2021	GULBARGA	110	NIRNA-RENEWSOLAR1&2_IPP	NIRNA_110	18:20	20:20	2:00	LINE CLEAR AVAILED
307	16/May/2021	GULBARGA	110	RAICHUR-SINDHNOOR2	GOOGLE_110	5:35	5:40	0:05	LINE FAULT
308	16/May/2021	GULBARGA	110	RAJESHWAR-SATHAPUR	SASTHAPUR_110,MANTHAL_110	23:00(15.05.2021)	13:42(16.05.2021)	14:42HRS	LINE CHARGED
309	16/May/2021	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110,JEWARAGI_110,SHAHAPUR_110	10:00	10:10	0:10	LINE FAULT
310	16/May/2021	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110,JEWARAGI_110,SHAHAPUR_110	11:05	11:15	0:10	LINE FAULT
311	16/May/2021	GULBARGA	110	SINDHNOOR-SUZLON_IPP	SINDHNOOR_220	4:10	4:35	0:25	LINE FAULT
312	16/May/2021	GULBARGA	110	SINDHNOOR-TEKKALKOTE	TEKKALKOTE_110	14:15	14:30	0:15	LINE FAULT
313	16/May/2021	GULBARGA	220	HV1	SHAHAPUR_220	2:42	4:18	1:36	TRANSFORMER FAULT
314	16/May/2021	GULBARGA	220	HV1	HALBARGA_220	8:25	8:34	0:09	TRANSFORMER FAULT
315	16/May/2021	GULBARGA	220	HV1	HALBARGA_220	16:25	16:32	0:07	TRANSFORMER FAULT
316	16/May/2021	GULBARGA	220	HV2	KUSTAGI_220	11:55	12:15	0:20	TRANSFORMER FAULT
317	16/May/2021	GULBARGA	220	HV2	KUSTAGI_220	12:48	13:15	0:27	TRANSFORMER FAULT
318	16/May/2021	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	11:20	11:50	0:30	LINE FAULT
319	16/May/2021	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	13:20	18:53	5:33	LINE FAULT
320	16/May/2021	GULBARGA	400	BTPSG-HIRIYUR1	HIRIYUR_400	0:13	15:09	14:56	LINE FAULT
321	16/May/2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400(Station not affected)	22:04(15.05.2021)			LINE OPEN,LINE FAULT
322	16/May/2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400(Station not affected)	2:55(16.05.2021)			LINE OPEN,LINE FAULT
323	16/May/2021	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	13:10	13:32	0:22	LINE FAULT
324	16/May/2021	HASSAN	66	HV2	HALLIMYSORE_66	12:55	13:38	0:43	LINE CLEAR AVAILED
325	16/May/2021	HASSAN	66	HV2	KANDLI_66	10:15	10:25	0:10	TRANSFORMER FAULT
326	16/May/2021	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	11:34	11:46	0:12	LINE FAULT
327	16/May/2021	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	17:28	17:46	0:18	LINE FAULT
328	16/May/2021	HASSAN	110	HV1	BARANGI_110	11:36	12:34	0:58	LINE CLEAR AVAILED
329	16/May/2021	HASSAN	110	HV2	PUTTUR_110(STATION NOT EFFECTED)	9:34(15.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
330	16/May/2021	HASSAN	110	HV2	ANAVATTI_110	19:03	19:18	0:15	TRANSFORMER FAULT
331	16/May/2021	HASSAN	110	HV3	KAVOOR_220	12:15	13:05	0:50	LINE CLEAR AVAILED
332	16/May/2021	HASSAN	220	KEMAR-UPCL1	KEMAR_220	14:58	16:20	1:22	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
333	16/May/2021	HASSAN	220	KEMAR-UPCL2	KEMAR_220	14:58	16:20	1:22	LINE CLEAR AVAILED
334	16/May/2021	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	9:02	13:38	4:36	LINE FAULT
335	16/May/2021	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	9:02	13:38	4:36	LINE FAULT
336	16/May/2021	HASSAN	220	UPCL-KEMAR1	upcl_gen	14:58	16:20	1:22	NFBC ISSUED
337	16/May/2021	HASSAN	220	UPCL-KEMAR2	upcl_gen	14:58	16:20	1:22	NFBC ISSUED
338	16/May/2021	HASSAN	400	UPCL-HASSAN2	NO STATION EFFECTED	20:45(16.05.2021)			LINE OPEN,LINE CLEAR AVAILED
339	16/May/2021	MYSURU	66	CHUNCHUNKATTE-KUSHALANAGARA	CHUNCHUNKATTE_66	1:55	2:00	0:05	LINE FAULT
340	16/May/2021	MYSURU	66	HV1	KHBCOLONY_66	9:05	14:07	5:02	LINE CLEAR AVAILED
341	16/May/2021	MYSURU	66	HV2	KHBCOLONY_66	14:03	14:41	0:37	LINE CLEAR AVAILED
342	16/May/2021	MYSURU	66	KIADB MANDYA-TUMBEKERE	TUMBEKERE_66	8:18	8:23	0:04	LINE FAULT
343	16/May/2021	MYSURU	66	KR PETE 220-BOOKANAKERE	BANANGADI_66 BOOKANAKERE_66 CHINAKURALI_66 GANJIGERE_66 SHEELUNERE_66	7:47	7:52	0:04	LINE FAULT
344	16/May/2021	MYSURU	66	KUSHALANAGARA 220-MYSORE 1	BILIKERE_66 BHERYA_66 DMG_HALLI_66 GVGUDI_66 MIRLE_66 KRNAGARA_66	1:58	2:02	0:04	LINE FAULT
345	16/May/2021	MYSURU	66	MADHUVANAHALLY-KUNTHUR	NO STATIONS EFFECTED	8:43	8:54	0:10	LINE FAULT
346	16/May/2021	MYSURU	66	MAHADESHWARAPURA-JAKKANAHALLY	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 NAGAMANGALA_66	7:45	7:50	0:05	LINE FAULT
347	16/May/2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN,LINE CLEAR AVAILED
348	16/May/2021	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66	8:15	8:20	0:04	LINE FAULT
349	16/May/2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN,LINE CLEAR AVAILED
350	16/May/2021	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220(STATION NOT EFFECTED)	17:30(14.05.2021)			LINE OPEN,LINE FAULT
351	16/May/2021	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66(STATION NOT EFFECTED)	10:29:41(14.05.2021)			MAIN SUPPLY FAILURE
352	16/May/2021	TUMKUR	66	TR-1(LV1)	DAVANGERE_SRS_220(LOAD IS ON TR2)	17:30:24(14.05.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
353	16/May/2021	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	16:34	16:40	0:06	MAIN SUPPLY FAILURE
354	16/May/2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	10:12	10:16	0:04	MAIN SUPPLY FAILURE
355	16/May/2021	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:06	10:17	0:11	HAND TRIPPED
356	16/May/2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	9:05	9:11	0:06	HAND TRIPPED
357	16/May/2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	10:07	10:22	0:14	HAND TRIPPED
358	16/May/2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:42	10:55	0:12	LINE FAULT
359	16/May/2021	TUMKUR	66	TR-1	CHANNAGIRI_66	16:09	16:13	0:04	TRANSFORMER FAULT
360	16/May/2021	TUMKUR	66	TR-1	HOSADURGA_66	14:03	14:58	0:55	LINE CLEAR AVAILED
361	16/May/2021	TUMKUR	66	TR-1	HULIYURDURGA_66	13:46	15:12	1:25	LINE CLEAR AVAILED
362	16/May/2021	TUMKUR	66	TR-1	KUNIGAL_66	11:18	15:36	4:17	LINE CLEAR AVAILED
363	16/May/2021	TUMKUR	66	TR-1	MADKERE_66	14:05	14:10	0:04	TRANSFORMER FAULT
364	16/May/2021	TUMKUR	66	TR-2	GUTTUR_66	10:04	10:06	0:01	HAND TRIPPED
365	16/May/2021	TUMKUR	66	TR-2	GUTTUR_66	11:10	11:11	0:01	HAND TRIPPED
366	16/May/2021	TUMKUR	66	TR-2	HULIYURDURGA_66	13:46	15:12	1:25	LINE CLEAR AVAILED
367	16/May/2021	TUMKUR	66	TR-2	MALEBENNUR_66	6:00	6:09	0:09	TRANSFORMER FAULT
368	16/May/2021	TUMKUR	220	TR-1	HIRIYUR_220	10:05	10:15	0:10	TRANSFORMER FAULT
369	16/May/2021	TUMKUR	220	TR-1	HIRIYUR_220	12:40	12:50	0:10	TRANSFORMER FAULT
1	17/May/2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
2	17/May/2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
3	17/May/2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
4	17/May/2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
5	17/May/2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
6	17/May/2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
7	17/May/2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
8	17/May/2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
9	17/May/2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
10	17/May/2021	BAGALKOT	220	AMBEEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	20:24 (15.05.2021)			LINE OPEN,LINE FAULT
11	17/May/2021	BAGALKOT	220	BIDNAL-NAGJHARI2	STATION NOT AFFECTED BIDNAL_220	14:00 (15.05.2021)	17:16 (17.05.2021)	51:16HRS	LINE CHARGED
12	17/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
13	17/May/2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
14	17/May/2021	BAGALKOT	110	220/110KV,LV2	STATION NOT AFFECTED MK HUBLI_220	7:16 (16.05.2021)			LOAD CURTAILMENT
15	17/May/2021	BAGALKOT	110	AMBEWADI-NK2	KAVALWADA_110	17:54	18:08	0:14	HAND TRIPPED
16	17/May/2021	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	9:59	13:27	3:28	LINE CLEAR AVAILED
17	17/May/2021	BAGALKOT	110	110/11KV,HV2	THORVI_110	11:26	11:29	0:03	TRANSFORMER FAULT
18	17/May/2021	BAGALKOT	110	110/11KV,HV2	THORVI_110	14:15	17:11	2:56	TRANSFORMER FAULT
19	17/May/2021	BAGALKOT	110	110/11KV,HV2	THORVI_110	17:13	19:13	2:00	TRANSFORMER FAULT
20	17/May/2021	BAGALKOT	220	AMBEWADI-NAGJHARI2	STATION NOT AFFECTED AMBEWADI_220	16:25 (21.04.2021)	13:32 (17.05.2021)	621:07HRS	LINE CHARGED
21	17/May/2021	BAGALKOT	220	BIDNAL-(HUBLI3)HUBLI2	STATION NOT AFFECTED BIDNAL_220	11:02	11:23	0:21	LINE CLEAR AVAILED
22	17/May/2021	BAGALKOT	220	220/110KV,HV3,LV3(HV1)	CHIKKODI_220	10:03	15:22	5:19	LINE CLEAR AVAILED
23	17/May/2021	BAGALKOT	220	CHIKKODI-MUGALKOD1(BELGAUM1)	STATION NOT AFFECTED CHIKKODI_220	19:15 (17.05.2021)			LINE OPEN,LINE CLEAR AVAILED
24	17/May/2021	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	STATION NOT AFFECTED GAJENDRAGD_110	9:22	12:42	3:20	LINE CLEAR AVAILED
25	17/May/2021	BAGALKOT	110	HAVERI220-SAVANUR	STATION NOT AFFECTED HAVERI_220	2:27	2:45	0:18	LINE FAULT
26	17/May/2021	BAGALKOT	110	HAVERI220-BYADAGI	STATION NOT AFFECTED HAVERI_220	12:37	12:46	0:09	LINE FAULT
27	17/May/2021	BAGALKOT	110	HAVERI220-BYADAGI	STATION NOT AFFECTED HAVERI_220	12:59 (17.05.2021)			LINE OPEN,LINE CLEAR AVAILED
28	17/May/2021	BAGALKOT	110	HIDIKAL DAM-ANKALAGI	STATION NOT AFFECTED HIDIKAL DAM_110	9:31	9:56	0:25	LINE FAULT
29	17/May/2021	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	14:58	15:15	0:17	LINE CLEAR AVAILED
30	17/May/2021	BAGALKOT	110	KADANKOPPA-KAVALWADA	KADANKOPPA_110	6:39 (17.05.2021)			LINE OPEN,LINE FAULT
31	17/May/2021	BAGALKOT	110	KALAGATAGI-(KAVALWADA)ASPL	KALAGATAGI_110	18:51	21:53	3:02	LINE CLEAR AVAILED
32	17/May/2021	BAGALKOT	400	400/220KV,ICT1(HV/LV)	DHONI_220	11:33	13:23	1:50	LINE CLEAR AVAILED
33	17/May/2021	BAGALKOT	110	110/33KV, HV4	DULKHED_33, NEVARGI_33, HALASANGI_33 STATION NOT AFFECTED ZALKI_110	8:24	8:28	0:04	TRANSFORMER FAULT
34	17/May/2021	BAGALKOT	110	UMMACHAGI-SIRSI	STATION NOT AFFECTED UMACHAGI_110	7:54	19:02	11:08	LINE CLEAR AVAILED
35	17/May/2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TILUVALLI_110	9:11	11:36	2:25	TRANSFORMER FAULT
36	17/May/2021	BAGALKOT	110	SIRSI-KUMTA1	STATION NOT AFFECTED SIRSI_110	10:20	16:45	6:25	LINE CLEAR AVAILED
37	17/May/2021	BAGALKOT	110	SIRSI-KUMTA2	STATION NOT AFFECTED SIRSI_110	12:59	16:43	3:44	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
38	17/May/2021	BAGALKOT	220	HUBLI-NAGZARI3	STATION NOT AFFECTED HUBLI_220	11:36	17:31	5:55	LINE CLEAR AVOIDED
39	17/May/2021	BAGALKOT	220	HUBLI-BIDNAL2	STATION NOT AFFECTED HUBLI_220	11:12	11:23	0:11	LINE CLEAR AVOIDED
40	17/May/2021	BAGALKOT	110	SAVANUR-HAVERI220	SAVANUR_110 ASIAN FEBTECH IPP_110	2:27	3:23	0:56	LINE FAULT
41	17/May/2021	BAGALKOT	220	MUGALKHOD-CHIKKODI1	STATION NOT AFFECTED MUGALKHOD_220	19:16 (17.05.2021)			LINE OPEN,LINE CLEAR AVOIDED
42	17/May/2021	BENGALURU	66	HV3	ADUGODI	12:15	15:24	3:09	LINE CLEAR AVOIDED
43	17/May/2021	BENGALURU	66	HV2	BIDADI_220	18:10	18:44	0:34	LINE CLEAR AVOIDED
44	17/May/2021	BENGALURU	66	HOODY 220 - GRAPHITE INDIA (EHT)	GRAPHITE INDIA (EHT)	14:40	15:31	0:51	LINE FAULT
45	17/May/2021	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	11:57	12:25	0:28	LINE FAULT
46	17/May/2021	BENGALURU	66	HV1	SRINIVASPURA	13:15	13:25	0:10	TRANSFORMER FAULT
47	17/May/2021	BENGALURU	66	HV1	PATH PALYA	15:35	15:41	0:05	TRANSFORMER FAULT
48	17/May/2021	BENGALURU	66	HV2	SADLI	13:02	13:45	0:42	LINE CLEAR AVOIDED
49	17/May/2021	BENGALURU	66	HV1	ANDERSONPET	11:35	11:54	0:19	LINE CLEAR AVOIDED
50	17/May/2021	BENGALURU	66	HV1	ANDERSONPET	11:35	11:54	0:19	LINE CLEAR AVOIDED
51	17/May/2021	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	14:10	14:19	0:09	LOAD CHANGE OVER
52	17/May/2021	BENGALURU	66	HV1	GODURU	22:20(16-MAY_2021)	14:58(17.5.21)	16:37HRS	TRANSFORMER CHARGED
53	17/May/2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400	2:55(16.05.2021)			LINE OPEN,LINE FAULT
54	17/May/2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:04(15.05.2021)			LINE OPEN,LINE FAULT
55	17/May/2021	GULBARGA	400	BTPSG-HIRIYUR1	HIRIYUR_400	0:02	8:21	8:19	LINE FAULT
56	17/May/2021	GULBARGA	220	HV1	HALBARGA_220	7:14	7:24	0:10	LINE CLEAR AVOIDED
57	17/May/2021	GULBARGA	220	HV1	HALBARGA_220	15:00	15:30	0:30	LINE CLEAR AVOIDED
58	17/May/2021	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	11:54	16:02	4:08	LINE CLEAR AVOIDED
59	17/May/2021	GULBARGA	220	HV2	KUSHTAGI_220	10:30	10:45	0:15	TRANSFORMER FAULT
60	17/May/2021	GULBARGA	220	KUSHTAGI-LINGAPUR	LINGAPUR_220	11:02	12:45	1:43	LINE FAULT
61	17/May/2021	GULBARGA	220	HV2	KUSHATGI_220	22:35	22:58	0:23	TRANSFORMER FAULT
62	17/May/2021	GULBARGA	110	HALBARGA-ACMESOLAR_IPP	HALBARGA_220	15:00	15:32	0:32	LINE FAULT
63	17/May/2021	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,S HATVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAM ALAPUR_110,MATRI_110,RBNS FACTORY	8:20	13:35	5:15	LINE CLEAR AVOIDED
64	17/May/2021	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,S HATVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAM ALAPUR_110,MATRI_110,RBNS FACTORY	18:11	18:23	0:12	LINE FAULT
65	17/May/2021	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	4:39	4:47	0:08	LINE FAULT
66	17/May/2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	3:05	3:15	0:10	LINE FAULT
67	17/May/2021	GULBARGA	110	HV1	RAICHUR_220	11:20	12:08	0:48	LINE CLEAR AVOIDED
68	17/May/2021	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHICKSUGUR_110,SHAKTINAGAR_110,S URANA_IPP	12:53	17:42	4:49	LINE CLEAR AVOIDED
69	17/May/2021	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110,VALKAMDINNI_110	2:27	2:38	0:11	LINE FAULT
70	17/May/2021	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110,VALKAMDINNI_110	3:45	3:50	0:05	LINE FAULT
71	17/May/2021	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110,VALKAMDINNI_110	5:04	5:11	0:07	LINE FAULT
72	17/May/2021	GULBARGA	110	HV2	DEODURGA_110	16:50	17:20	0:30	TRANSFORMER FAULT
73	17/May/2021	GULBARGA	110	KUSHTAGI-BEVOOR	BEVOOR_110	10:35	13:10	2:35	MAIN SUPPLY FAILURE
74	17/May/2021	GULBARGA	110	KUSHTAGI-BEVOOR	BEVOOR_110	22:40	23:10	0:30	MAIN SUPPLY FAILURE
75	17/May/2021	GULBARGA	110	KUSHATAGI-YELBURGA	YELBURGA_110	13:03	13:30	0:27	LINE FAULT
76	17/May/2021	GULBARGA	110	ALIPUR-METRI	METRI_110	8:20	8:45	0:25	MAIN SUPPLY FAILURE
77	17/May/2021	GULBARGA	110	ALIPUR-METRI	METRI_110	13:35	13:40	0:05	MAIN SUPPLY FAILURE
78	17/May/2021	GULBARGA	110	ALIPUR-METRI	METRI_110	18:10	18:20	0:10	MAIN SUPPLY FAILURE
79	17/May/2021	GULBARGA	110	SHAHAPUR NALWAR	NALWAR_110	16:10	17:15	1:05	LINE CLEAR AVOIDED
80	17/May/2021	GULBARGA	110	CHITGUPPA-NIRNA	NIRNA_110	4:40	4:50	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
81	17/May/2021	GULBARGA	110	HV3	VALKAMDINNI_110	11:20	11:30	0:10	LINE CLEAR AVAILED
82	17/May/2021	GULBARGA	66	HV1	KUDLIGI_66	9:45	16:20	6:35	LINE CLEAR AVAILED
83	17/May/2021	GULBARGA	66	HV2	KUDLIGI_66	11:05	16:50	5:45	LINE CLEAR AVAILED
84	17/May/2021	GULBARGA	66	ITTAGI-HIREHADAGALLI2	HIREHADAGALI_66,GIRIYAPUR_66,MAGALA_66,SO VENHALLI_66,TUNGABHADRA IPP	5:02	5:20	0:18	LINE FAULT
85	17/May/2021	GULBARGA	66	ITTAGI-HIREHADAGALLI2	HIREHADAGALI_66,GIRIYAPUR_66,MAGALA_66,SO VENHALLI_66,TUNGABHADRA IPP	5:35	5:44	0:09	LINE FAULT
86	17/May/2021	GULBARGA	66	KOTTUR-UJJAINI	UJJAINI_66	18:35	18:45	0:10	LINE FAULT
87	17/May/2021	GULBARGA	66	HV1	KUDLIGI_66	1:35	4:40	3:05	TRANSFORMER FAULT
88	17/May/2021	GULBARGA	66	HV1	KUDLIGI_66	4:40	4:45	0:05	TRANSFORMER FAULT
89	17/May/2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	20:45(16.05.2021)	7:59(17.05.2021)	11:13 hrs	LINE CHARGED
90	17/May/2021	HASSAN	110	HV2	PUTTUR_110	9:34(15.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
91	17/May/2021	HASSAN	220	HV2	CHANNARAYAPATNA_66	11:25	13:16	1:51	LINE CLEAR AVAILED
92	17/May/2021	HASSAN	66	LV2	CHANNARAYAPATNA_66	11:24	13:16	1:52	LINE CLEAR AVAILED
93	17/May/2021	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	16:03	18:53	2:50	LINE CLEAR AVAILED
94	17/May/2021	HASSAN	110	HV1	HULICAL_110	17:38	17:50	0:12	TRANSFORMER FAULT
95	17/May/2021	HASSAN	110	HV1	HULICAL_110	19:14	19:26	0:12	TRANSFORMER FAULT
96	17/May/2021	HASSAN	110	HV2	SHIKARIPURA_110	8:06	8:54	0:48	LINE CLEAR AVAILED
97	17/May/2021	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	23:41	23:50	0:09	LINE FAULT
98	17/May/2021	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	14:08	14:22	0:14	LINE FAULT
99	17/May/2021	HASSAN	66	HV1	HOLENARASIPIURA_220	12:36	13:59	1:23	LINE CLEAR AVAILED
100	17/May/2021	HASSAN	66	HV1	KANDLI_66	9:44	9:52	0:08	TRANSFORMER FAULT
101	17/May/2021	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	12:29	13:38	1:09	LINE CLEAR AVAILED
102	17/May/2021	HASSAN	66	HV1	SALAGAME_66	12:29	13:36	1:07	LINE CLEAR AVAILED
103	17/May/2021	HASSAN	66	HV2	SALAGAME_66	12:29	13:36	1:07	LINE CLEAR AVAILED
104	17/May/2021	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	12:29	13:35	1:06	LINE CLEAR AVAILED
105	17/May/2021	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	12:28	13:34	1:06	MAIN SUPPLY FAILURE
106	17/May/2021	MYSURU	66	CHIKKAMANDYA-HAMPAPURA	HAMPAPURA_66, KOPPA_66 & BESAGARAHALLI_66	23:21	23:47	0:25	LINE FAULT
107	17/May/2021	MYSURU	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66 ATTIGULIPURA_66 ARKALAWADI_66	3:10	3:23	0:12	LINE FAULT
108	17/May/2021	MYSURU	66	HV1	HOSURGATE_66	16:31	17:05	0:33	LINE CLEAR AVAILED
109	17/May/2021	MYSURU	66	HV1	SINDHUVALLI_66	16:50	17:06	0:16	TRANSFORMER FAULT
110	17/May/2021	MYSURU	66	KADAKOLA-SARGUR 2	DOORA_66 HULLAHALLI_66 HURA_66	10:09	10:14	0:05	LINE FAULT
111	17/May/2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN,LINE CLEAR AVAILED
112	17/May/2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN,LINE CLEAR AVAILED
113	17/May/2021	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	17:30:24(14.05.2021)	12:30:22(17.05.2021)	67:00HRS	LINE CHARGED
114	17/May/2021	TUMKUR	66	TR-1(LV1)	DAVANGERE_SRS_220	17:30:24(14.05.2021)	7:09:02 (17.05.2021)	61:39HRS	TRANSFORMER CHARGED
115	17/May/2021	TUMKUR	110	TR-1	GUNGURMALE_110	7:43	9:06	1:22	LINE CLEAR AVAILED
116	17/May/2021	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	18:38	19:15	0:37	LINE FAULT
117	17/May/2021	TUMKUR	66	HANAGAL-THALLAK	HANAGAL_66	17:24	17:59	0:34	LINE FAULT
118	17/May/2021	TUMKUR	66	HANGAL66-RAMPURA	RAMPURA_66,NAGASAMUDRA_66, RAMPURA_66	17:40	18:05	0:24	MAIN SUPPLY FAILURE
119	17/May/2021	TUMKUR	66	TR-2	HOSKERE_66	9:06	9:29	0:22	TRANSFORMER FAULT
120	17/May/2021	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	18:49	19:21	0:31	LINE FAULT
121	17/May/2021	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	17:24	17:58	0:33	LINE FAULT
122	17/May/2021	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	17:24	17:36	0:11	LINE FAULT
123	17/May/2021	TUMKUR	66	TR-1	TUMKUR_66	16:44	19:26	2:42	LINE CLEAR AVAILED