

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 22.09.2020 TO 28.09.2020**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	22-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
2	22-Sep-2020	BAGALKOT	110	110/11KV, HV2	KULIGOD 110	14:10	15:38	01:28	TRANSFORMER FAULT
3	22-Sep-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL 110	14:14 (16.09.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
4	22-Sep-2020	BAGALKOT	110	AMBEWADI-NK2	KAVALWAD 110	13:26	13:33	00:07	HAND TRIPPED
5	22-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM 110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVOIDED
6	22-Sep-2020	BAGALKOT	110	BIDNAL- NAVALGUND	STATION NOT AFFECTED NAVALGUND 110	10:25 (21.09.2020)	16:40 (22.09.2020)	6:15 hrs	LINE CHARGED
7	22-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA 110	19:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVOIDED
8	22-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA 110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVOIDED
9	22-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING) GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVOIDED
10	22-Sep-2020	BAGALKOT	110	HUBLI- KALGHATAGI	KALGHATAGI 110	11:31	12:01	00:30	LINE FAULT
11	22-Sep-2020	BAGALKOT	110	HUBLI- KALGHATAGI	KALGHATAGI 110	15:26	20:26	05:00	LINE CLEAR AVOIDED
12	22-Sep-2020	BAGALKOT	110	HUBLI- KALGHATAGI	STATION NOT AFFECTED KALGHATAGI 110	20:35			LINE OPEN, LINE FAULT
13	22-Sep-2020	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA 110	15:34 (13.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
14	22-Sep-2020	BAGALKOT	110	KAVALWAD-HUBLI-KALGHATAGI	KALGHATAGI 110	11:30	13:20	01:50	LINE FAULT
15	22-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
16	22-Sep-2020	BAGALKOT	110	SIRSI220-SIRSI2	STATION NOT AFFECTED SIRSI 110	21:24 (21.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
17	22-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR 110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVOIDED
18	22-Sep-2020	BAGALKOT	220	220/110KV HV1,2&3 & LV 1,2&3	GADAG 220 (110KVBETAGERI,GADAG,SHIRAHATTI,SAMBAPURROAD,DAMBAL,&LAXMESHWAR)	13:15	13:26	00:11	HAND TRIPPED
19	22-Sep-2020	BAGALKOT	220	ADPH 1&2-BAGALKOT	BAGALKOT 220,(BAGALKOT 110,N AVANAGAR 110,KALADAGI 110,LOKAPUR 110,NEERBUDIHAL 110,GULLEDGUDDA 110 & 33KV,KATAGERI,GADDANAKERI)	13:04	13:56	00:52	HAND TRIPPED
20	22-Sep-2020	BAGALKOT	220	AMBEWADI-NARENDRA 2	STATION NOT AFFECTED AMBEWADI 220	21:21 (20.09.02020)	15:44 (22.09.2020)	19:55 hrs	LINE CHARGED
21	22-Sep-2020	BAGALKOT	220	BAGALKOT-GADAG 1	BAGALKOT 220	13:04	14:33	01:29	LINE CLEAR AVOIDED
22	22-Sep-2020	BAGALKOT	220	BAGALKOT-GADAG 2	BAGALKOT 220	13:04	13:56	00:52	HAND TRIPPED
23	22-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT 220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
24	22-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
25	22-Sep-2020	BAGALKOT	220	BAGEWADI-LINGASGUR	BAGEWADI_220 (110KV NIDAGUNDI,MUKARTIHAL,MUDEB IHAL,UKKALI,MAMADAPUR)	13:05	13:33	00:28	HAND TRIPPED
26	22-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	23:20 (21.09.02020)	8:05 (22.09.2020)	8:45 hrs	LINE CHARGED
27	22-Sep-2020	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN, LINE CLEAR AVAILED
28	22-Sep-2020	BAGALKOT	220	GADAG-BAGALKOT 1&2	GADAG_220	13:14	16:52	03:38	LINE CLEAR AVAILED
29	22-Sep-2020	BAGALKOT	220	GADAG-HARTI 1	GADAG_220	13:14	14:42	01:28	LINE CLEAR AVAILED
30	22-Sep-2020	BAGALKOT	220	GADAG-HARTI 2	GADAG_220	13:14	13:35	00:21	HAND TRIPPED
31	22-Sep-2020	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	11:56	15:43	03:47	LINE FAULT
32	22-Sep-2020	BAGALKOT	220	SIRSI-HUBLI 1&2	STATION NOT AFFECTED SIRSI_220	14:08 (21.09.2020)			LOAD CURTAILMENT
33	22-Sep-2020	BENGALURU	66	AGALAKOTE - KEMPAHAHALI	AGALAKOTE, MATHIKERE	12:00	12:25	00:25	LINE FAULT
34	22-Sep-2020	BENGALURU	66	AGALAKOTE - KEMPAHAHALI	AGALAKOTE	12:25	12:30	00:05	LINE FAULT
35	22-Sep-2020	BENGALURU	66	AGALAKOTE - MATHIKERE	MATHIKERE	12:25	13:20	00:55	LINE FAULT
36	22-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
37	22-Sep-2020	BENGALURU	66	HV1	BRIGADE METROPOLIS	12:35	12:40	00:05	LINE CLEAR AVAILED
38	22-Sep-2020	BENGALURU	66	HV1	L R BANDE	19:15	19:20	00:05	LINE CLEAR AVAILED
39	22-Sep-2020	BENGALURU	66	HV1	AGALAKOTE	12:00	12:55	00:55	TRANSFORMER FAULT
40	22-Sep-2020	BENGALURU	66	HV1	D CROSS	09:01	09:05	00:03	TRANSFORMER FAULT
41	22-Sep-2020	BENGALURU	66	HV2	BRIGADE METROPOLIS	11:25	11:30	00:05	LINE CLEAR AVAILED
42	22-Sep-2020	BENGALURU	66	HV2	SHOBHA CITY	10:27	10:35	00:08	LINE CLEAR AVAILED
43	22-Sep-2020	BENGALURU	66	HV2	AGALAKOTE	12:00	13:10	01:10	TRANSFORMER FAULT
44	22-Sep-2020	BENGALURU	66	JAKKASANDRA - ADUGODI	NO STATION AFFECTED	23:04(21/09/2020)			LINE OPEN, LINE FAULT
45	22-Sep-2020	BENGALURU	66	KORAMANGALA 220 - ADUGODI	NO STATION AFFECTED	22:34(21/09/2020)	1:47(22/09/2020)	3:13HRS	LINE CHARGED
46	22-Sep-2020	BENGALURU	66	SHOBHA CITY - HENNUR CROSS	SHOBHA CITY	13:40	13:46	00:06	LOAD CHANGE OVER
47	22-Sep-2020	BENGALURU	66	SHOBHA CITY - MANYATHA TECH PARK 220	SHOBHA CITY	12:11	12:24	00:13	LOAD CHANGE OVER
48	22-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
49	22-Sep-2020	GULBARGA	110	CHITAGUPPA-HUMNABAD	CHITAGUPPA_110,NIRNA_110	09:35	09:40	00:05	LINE FAULT
50	22-Sep-2020	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	13:02	13:39	00:37	MAIN SUPPLY FAILURE
51	22-Sep-2020	GULBARGA	110	HUMNABAD-MANEKHALI	MANEKHALI_110	16:49(19.09.2020)			LINE OPEN, LINE CLEAR AVAILED
52	22-Sep-2020	GULBARGA	110	HV2	CHITAGUPPA_110	13:25	13:30	00:05	TRANSFORMER FAULT
53	22-Sep-2020	GULBARGA	110	HV3	SINDHANOOR_110	11:51	14:11	02:20	LINE CLEAR AVAILED
54	22-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
55	22-Sep-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	16:08	17:30	01:22	LINE CLEAR AVAILED
56	22-Sep-2020	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	14:35	15:00	00:25	LINE FAULT
57	22-Sep-2020	GULBARGA	220	HV1	LINGASUGUR_220	13:02	13:30	00:28	LINE CLEAR AVAILED
58	22-Sep-2020	GULBARGA	220	HV2	LINGASUGUR_220	13:02	13:39	00:37	LINE CLEAR AVAILED
59	22-Sep-2020	GULBARGA	220	LINGAPUR-SINDHANOOR	LINGAPUR_220	09:33	14:06	04:33	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
60	22-Sep-2020	GULBARGA	220	LINGASUGUR-BBAGEWADI1	B.BAGEWADI_220	13:02	13:32	00:30	LINE CLEAR AVAILED
61	22-Sep-2020	GULBARGA	220	LINGASUGUR-BBAGEWADI2	B.BAGEWADI_220	13:02	13:33	00:31	LINE CLEAR AVAILED
62	22-Sep-2020	GULBARGA	220	LINGASUGUR-KUSHTAGI	KUSHTAGI_220	13:02	13:29	00:27	LINE CLEAR AVAILED
63	22-Sep-2020	GULBARGA	220	LINGASUGUR-MALLAT	MALLAT_220	13:02	13:25	00:23	LINE CLEAR AVAILED
64	22-Sep-2020	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	12:57	13:27	00:30	LINE FAULT
65	22-Sep-2020	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	13:02	13:16	00:14	LINE FAULT
66	22-Sep-2020	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	13:01	13:21	00:20	LINE FAULT
67	22-Sep-2020	GULBARGA	220	LINGASUGUR-SINDHANOOR	SINDHANOOR_220	13:02	13:33	00:31	LINE CLEAR AVAILED
68	22-Sep-2020	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	23:25(15.09.2020)	15:46(22.09.2020)	160:11 HRS	LINE CHARGED
69	22-Sep-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	04:19	04:34	00:15	LINE FAULT
70	22-Sep-2020	HASSAN	66	ATTICHO-CRPATNA	ATTICHOWDENAHALLY_66	09:05	12:05	03:00	LINE CLEAR AVAILED
71	22-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN, LINE CLEAR AVAILED
72	22-Sep-2020	HASSAN	66	HIREAN-CHIKAMANGALUR	HIREMANGALUR_66	10:35	14:35	04:00	LINE CLEAR AVAILED
73	22-Sep-2020	HASSAN	66	HIREMAN-RDL	HIREMANGALUR_66	10:40	13:22	02:42	LINE CLEAR AVAILED
74	22-Sep-2020	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	08:40	18:50	10:10	LINE FAULT
75	22-Sep-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	09:05	12:05	03:00	LINE CLEAR AVAILED
76	22-Sep-2020	HASSAN	66	HV1	CHIKMAGALUR_66	10:30	14:34	04:04	LINE CLEAR AVAILED
77	22-Sep-2020	HASSAN	66	HV1	HIREMANGALUR_66	10:00	15:40	05:40	LINE CLEAR AVAILED
78	22-Sep-2020	HASSAN	66	HV1	HNPURA_66	08:50	08:55	00:05	TRANSFORMER FAULT
79	22-Sep-2020	HASSAN	66	HV1	HNPURA_66	18:40	18:52	00:12	MAIN SUPPLY FAILURE
80	22-Sep-2020	HASSAN	66	HV1	MALLAPURA_66	10:05	16:50	06:45	LINE CLEAR AVAILED
81	22-Sep-2020	HASSAN	66	HV2	BASAVAGHATTA_66	11:40	12:37	00:57	LINE CLEAR AVAILED
82	22-Sep-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	11:15	13:20	02:05	LINE CLEAR AVAILED
83	22-Sep-2020	HASSAN	66	HV2	CHIKMAGALUR_66	10:30	14:34	04:04	LINE CLEAR AVAILED
84	22-Sep-2020	HASSAN	66	HV2	HNPURA_66	18:40	18:52	00:12	MAIN SUPPLY FAILURE
85	22-Sep-2020	HASSAN	66	HV2	MALLAPURA_66	10:05	16:50	06:45	LINE CLEAR AVAILED
86	22-Sep-2020	HASSAN	66	HV2	MALLAPURA_66	17:30	18:20	00:50	LINE CLEAR AVAILED
87	22-Sep-2020	HASSAN	66	MALLAPUR-SHIMOGA	MALLAPURA_66	10:05	16:50	06:45	LINE CLEAR AVAILED
88	22-Sep-2020	HASSAN	110	HV1	BHADRAVATHI_110	10:11(21.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
89	22-Sep-2020	HASSAN	110	HV1	ESSUR_110	10:59	17:07	06:08	LINE CLEAR AVAILED
90	22-Sep-2020	HASSAN	110	HV1	KADUR_220	10:20	13:20	03:00	LINE CLEAR AVAILED
91	22-Sep-2020	HASSAN	110	HV1	KONDENALU_110	12:15	13:15	01:00	LINE CLEAR AVAILED
92	22-Sep-2020	HASSAN	110	HV2	ESSUR_110	17:07	19:18	02:11	LINE CLEAR AVAILED
93	22-Sep-2020	HASSAN	110	HV2	PUTTUR_110	09:44	11:34	01:50	LINE CLEAR AVAILED
94	22-Sep-2020	HASSAN	110	JOG110-AMBTR1	JOG_110	17:51 (22.09.2020)			LINE OPEN, LINE FAULT
95	22-Sep-2020	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	11:20 (20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
96	22-Sep-2020	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	12:14	13:52	01:38	LINE CLEAR AVAILED
97	22-Sep-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:04(20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
98	22-Sep-2020	HASSAN	110	LV1	MSEZ_220	15:34	15:39	00:05	HAND TRIPPED
99	22-Sep-2020	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	13:14	13:17	00:03	HAND TRIPPED
100	22-Sep-2020	HASSAN	400	HASSAN40-UPCL1	HASSAN_400	17:15(12.09.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
101	22-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:02 (16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
102	22-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:15 (12.09.2020)	7:27 (22.09.2020)	230:11 hrs	LINE CHARGED
103	22-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	20:15 (20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
104	22-Sep-2020	MYSURU	66	ANEGOLA-HUYGONAHALLI	ANEGOLAL_66	11:55	15:33	03:38	LINE CLEAR AVAILED
105	22-Sep-2020	MYSURU	66	BEGUR 220KV-BEGUR-2	NO STATIONS EFFECTED	12:20	12:53	00:33	LINE CLEAR AVAILED
106	22-Sep-2020	MYSURU	66	BEGUR 220KV-HARVEY	NO STATIONS EFFECTED	11:27	12:16	00:49	LINE CLEAR AVAILED
107	22-Sep-2020	MYSURU	66	BEGUR 220KV-HARVEY	HARVEY_66	03:45	04:27	00:42	LINE FAULT
108	22-Sep-2020	MYSURU	66	BG PURA-CHANDALLY	NO STATIONS EFFECTED	14:55	15:20	00:25	LINE CLEAR AVAILED
109	22-Sep-2020	MYSURU	66	BG PURA-SFC	NO STATIONS EFFECTED	15:23	15:47	00:23	LINE CLEAR AVAILED
110	22-Sep-2020	MYSURU	66	CR NAGARA-BADANKUPPE -2	BADANAGUPPE_66	09:39	18:07	08:28	LINE CLEAR AVAILED
111	22-Sep-2020	MYSURU	66	HV1	BASARALU_66	11:45	12:10	00:25	LINE CLEAR AVAILED
112	22-Sep-2020	MYSURU	66	HV1	BGPURA_66	14:55	15:24	00:29	LINE CLEAR AVAILED
113	22-Sep-2020	MYSURU	66	HV2	BGPURA_66	15:50	16:00	00:10	LINE CLEAR AVAILED
114	22-Sep-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	22:57	23:04	00:06	LINE FAULT
115	22-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 1	NO STATIONS EFFECTED	10:10 (19/9/2020)			LINE OPEN, LINE CLEAR AVAILED
116	22-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 2	NO STATIONS EFFECTED	10:10 (19/9/2020)			LINE OPEN, LINE CLEAR AVAILED
117	22-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
118	22-Sep-2020	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	13:08	19:35	06:27	LINE CLEAR AVAILED
119	22-Sep-2020	TUMKUR	220	NEELAGUNDA220kv- GUTTUR 220kv	NEELAGUNDA_220	10:41:57 AM(21.09.2020)			LINE OPEN, LINE FAULT
120	22-Sep-2020	TUMKUR	220	TR-1	ANCHEPALYA_220	12:01	14:07	02:05	LINE CLEAR AVAILED
121	22-Sep-2020	TUMKUR	220	TR-2	ANCHEPALYA_220	14:42	17:20	02:38	LINE CLEAR AVAILED
122	22-Sep-2020	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	09:39	10:04	00:25	LINE FAULT
123	23-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
124	23-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
125	23-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
126	23-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
127	23-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING) GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
128	23-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
129	23-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
130	23-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
131	23-Sep-2020	BAGALKOT	110	KAVALWADA(AMBEWADI)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	15:34 (13.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
132	23-Sep-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
133	23-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
134	23-Sep-2020	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
135	23-Sep-2020	BAGALKOT	220	SIRSI-HUBLI 1&2	STATION NOT AFFECTED SIRSI_220	14:08 (21.09.2020)	17:00 (23.09.2020)	56:22hrs	LINE CHARGED
136	23-Sep-2020	BAGALKOT	110	SIRSI220-SIRSI2	STATION NOT AFFECTED SIRSI_110	21:24 (21.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
137	23-Sep-2020	BAGALKOT	110	HUBLI- KALGHATAGI	STATION NOT AFFECTED KALGHATAGI_110	20:35 (22.09.2020)	13:43 (23.09.2020)	17:08hrs	LINE CHARGED
138	23-Sep-2020	BAGALKOT	110	110/11KV,HV1&2	AREMALLAPUR_110	19:25	19:58	0:33	TRANSFORMER FAULT
139	23-Sep-2020	BAGALKOT	110	ATHARGA-KN SOLAR	ATHARGA_110	21:33	22:40	1:07	LINE CLEAR AVOIDED
140	23-Sep-2020	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	14:07	18:45	4:38	LINE FAULT
141	23-Sep-2020	BAGALKOT	220	ATHANI-MAHALINGAPUR	ATHANI_220	5:44	11:43	5:59	LINE FAULT
142	23-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	10:14	10:30	0:16	HAND TRIPPED
143	23-Sep-2020	BAGALKOT	220	NANDIHAL 1&2-BIJAPUR	BIJAPUR_220	12:52	12:56	0:04	HAND TRIPPED
144	23-Sep-2020	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	15:44	16:05	0:21	HAND TRIPPED
145	23-Sep-2020	BAGALKOT	110	HAVERI-TILUVALLI	TILUVALLI_110	12:54	17:27	4:33	LINE CLEAR AVOIDED
146	23-Sep-2020	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	12:30	17:16	4:46	LINE CLEAR AVOIDED
147	23-Sep-2020	BAGALKOT	110	110/11KV,HV1	KALAGHATGI_110	12:42	15:10	2:28	LINE CLEAR AVOIDED
148	23-Sep-2020	BAGALKOT	220	NAGJHARI1&2- HUBLI	HUBLI_220	17:18	17:57	0:39	LOAD CURTAILMENT
149	23-Sep-2020	BAGALKOT	110	HUBLI- TARIHAL1&2	TARIHAL_110	11:29	18:07	6:38	LINE CLEAR AVOIDED
150	23-Sep-2020	BAGALKOT	110	SODATTI220- RAMDURGA2	RAMDURGA_110	11:35	16:52	5:17	LINE CLEAR AVOIDED
151	23-Sep-2020	BAGALKOT	110	SODATTI220- MUNAVALLI	MUNAVALLI_110	10:02	17:45	7:43	LINE CLEAR AVOIDED
152	23-Sep-2020	BAGALKOT	110	110/11KV, HV2	PG HUNSHYAL_110	17:04	18:34	1:30	LINE CLEAR AVOIDED
153	23-Sep-2020	BAGALKOT	110	SHARAVATHY1&2- SIRSI	SIRSI_220	18:18	18:22	0:04	HAND TRIPPED
154	23-Sep-2020	BAGALKOT	110	110/11KV, HV2	MUDDEBIHAL_110	15:55	16:05	0:10	TRANSFORMER FAULT
155	23-Sep-2020	BAGALKOT	110	110/11KV, HV2	MALGHAN(S)_110	12:48	13:05	0:17	LINE CLEAR AVOIDED
156	23-Sep-2020	BAGALKOT	110	MAHALINGAPUR- GSML1	MAHALINGAPUR_220	1:44	2:15	0:31	LINE FAULT
157	23-Sep-2020	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	15:36	15:39	00:03	LINE FAULT
158	23-Sep-2020	BENGALURU	66	HV1	KORAMANGALA 220	11:42	11:45	00:03	LINE CLEAR AVOIDED
159	23-Sep-2020	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	10:45	10:48	00:03	LINE CLEAR AVOIDED
160	23-Sep-2020	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66, ISKON	12:24	12:34	00:10	LOAD CHANGE OVER
161	23-Sep-2020	BENGALURU	66	HV2	TELECOM LAYOUT	11:45	11:55	00:10	TRANSFORMER FAULT
162	23-Sep-2020	BENGALURU	66	HV1	L R BANDE	15:25	15:30	00:05	LINE CLEAR AVOIDED
163	23-Sep-2020	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE,MATHIKERE	12:15	13:05	00:50	LINE CLEAR AVOIDED
164	23-Sep-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	11:01	11:13	00:12	LOAD CHANGE OVER
165	23-Sep-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	14:33	14:37	00:04	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
166	23-Sep-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	11:01	11:13	00:12	LOAD CHANGE OVER
167	23-Sep-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	14:33	14:37	00:04	LOAD CHANGE OVER
168	23-Sep-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	11:01	11:13	00:12	LOAD CHANGE OVER
169	23-Sep-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	14:33	14:37	00:04	LOAD CHANGE OVER
170	23-Sep-2020	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	05:46	05:57	00:10	LINE FAULT
171	23-Sep-2020	BENGALURU	66	BAIRAKUR - KOLAR 220	BAIRAKUR	06:35	06:55	00:20	LINE FAULT
172	23-Sep-2020	BENGALURU	66	HV1	DEVANAHALLI	11:20	12:45	01:25	LINE CLEAR AVAILED
173	23-Sep-2020	BENGALURU	66	HV2	DEVANAHALLI	12:54	13:40	00:45	LINE CLEAR AVAILED
174	23-Sep-2020	BENGALURU	66	HV1	MULBAGLU	15:17	17:13	01:56	LINE CLEAR AVAILED
175	23-Sep-2020	BENGALURU	66	HV1	VOLVO	10:07	10:16	00:08	TRANSFORMER FAULT
176	23-Sep-2020	BENGALURU	66	JAKKASANDRA - ADUGODI	NO STATION AFFECTED	23:04(21/09/2020)			LINE OPEN, LINE FAULT
177	23-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
178	23-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
179	23-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
180	23-Sep-2020	GULBARGA	110	HUMNABAD-MANEKHALI	MANEKHALI_110	16:49(19.09.2020)			LINE OPEN, LINE CLEAR AVAILED
181	23-Sep-2020	GULBARGA	220	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	23:13(23.9.2020)			LINE OPEN, LINE FAULT
182	23-Sep-2020	GULBARGA	220	KUSHTAGI-OPDWIND	KUSHTAGI_220	09:05	09:39	00:34	LOAD CURTAILMENT
183	23-Sep-2020	GULBARGA	220	KUSHTAGI-SUZLON WIND2	KUSHTAGI_220	09:05	09:36	00:31	LOAD CURTAILMENT
184	23-Sep-2020	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	04:19	04:45	00:26	LINE FAULT
185	23-Sep-2020	GULBARGA	220	BBM ISPAT-ITTAGI	ITTAGI_220	15:30	15:40	00:10	LINE FAULT
186	23-Sep-2020	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	23:13(23.09.2020)			LINE OPEN, LINE FAULT
187	23-Sep-2020	GULBARGA	220	HV1	SHAHAPUR_220	05:50	06:10	00:20	TRANSFORMER FAULT
188	23-Sep-2020	GULBARGA	220	KUSHTAGI-LINGASUGUR	LINGSUGUR_220	23:15(23.09.2020)			LINE OPEN, LINE FAULT
189	23-Sep-2020	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMANAL_110,HANUMASAGAR_110,HIREGONNAGAR_110	09:15	09:40	00:25	LOAD CURTAILMENT
190	23-Sep-2020	GULBARGA	110	SINDHANOOR-SIRIGUPPA	SIRIGUPPA_110,TEKKALKOTE_110,DHADESUGUR_110	03:48	03:58	00:10	LINE FAULT
191	23-Sep-2020	GULBARGA	110	SINDHANOOR-SIRIGUPPA	SIRIGUPPA_110,TEKKALKOTE_110,DHADESUGUR_110	08:35	14:15	05:40	LINE CLEAR AVAILED
192	23-Sep-2020	GULBARGA	110	HATTI-SOMANAMARDI_IPP	HATTI_110	23:12	23:25	00:13	LINE FAULT
193	23-Sep-2020	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	23:12	23:14	00:02	MAIN SUPPLY FAILURE
194	23-Sep-2020	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	17:40	18:15	00:35	LINE CLEAR AVAILED
195	23-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	05:50	06:14	00:24	LINE FAULT
196	23-Sep-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	18:21	18:36	00:15	LINE FAULT
197	23-Sep-2020	HASSAN	110	JOG110-AMBTR1	JOG_110	17:51 (22.09.2020)	12:34(23.09.2020)	18:42 hrs	LINE CHARGED
198	23-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:02 (16.09.2020)	7:49 (23.09.2020)	152:46 hrs	LINE CHARGED
199	23-Sep-2020	HASSAN	110	HV1	BHADRAVATHI_110	10:11(21.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
200	23-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
201	23-Sep-2020	HASSAN	400	HASSAN40-UPCL1	HASSAN_400	17:15(12.09.2020)			LINE OPEN, LINE CLEAR AVAILED
202	23-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	20:15 (20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
203	23-Sep-2020	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	11:20 (20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
204	23-Sep-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:04(20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
205	23-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:13 (23.09.2020)			LINE OPEN, LINE CLEAR AVAILED
206	23-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	00:35	06:49	06:14	LINE CLEAR AVAILED
207	23-Sep-2020	HASSAN	110	HV1	ANAVATTI_110	17:37	17:41	00:04	HAND TRIPPED
208	23-Sep-2020	HASSAN	110	HV2	ANAVATTI_110	17:37	17:41	00:04	HAND TRIPPED
209	23-Sep-2020	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	10:27	10:28	00:01	HAND TRIPPED
210	23-Sep-2020	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	11:34	11:36	00:02	HAND TRIPPED
211	23-Sep-2020	HASSAN	110	JOG110-AMBTR2	JOG_110	12:48	13:02	00:14	HAND TRIPPED
212	23-Sep-2020	HASSAN	110	KEMAR-Manipal2	KEMAR_220	10:11	13:05	02:54	LINE CLEAR AVAILED
213	23-Sep-2020	HASSAN	110	HV1	KONAJE_110	10:17	12:51	02:34	LINE CLEAR AVAILED
214	23-Sep-2020	HASSAN	110	HV2	KONAJE_110	10:17	11:44	01:27	LINE CLEAR AVAILED
215	23-Sep-2020	HASSAN	110	HV2	KONAJE_110	12:52	16:52	04:00	LINE CLEAR AVAILED
216	23-Sep-2020	HASSAN	110	HV3	KONAJE_110	10:17	12:36	02:19	LINE CLEAR AVAILED
217	23-Sep-2020	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:25	10:29	00:04	HAND TRIPPED
218	23-Sep-2020	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	15:03	15:13	00:10	HAND TRIPPED
219	23-Sep-2020	HASSAN	66	HV1	BAGUR_66	08:14	09:46	01:32	LINE CLEAR AVAILED
220	23-Sep-2020	HASSAN	66	HV2	BAGUR_66	08:14	09:30	01:16	LINE CLEAR AVAILED
221	23-Sep-2020	HASSAN	66	CHANNARA-SHETTIHALLY	CHANNARAYAPATNA_66	05:48	05:59	00:11	LINE FAULT
222	23-Sep-2020	HASSAN	66	HV2	CHIKMAGALUR_66	11:55	12:13	00:18	LINE CLEAR AVAILED
223	23-Sep-2020	HASSAN	66	HV2	MALLAPURA_66	10:52	13:46	02:54	LINE CLEAR AVAILED
224	23-Sep-2020	MYSURU	66	BILIKERE-KR NAGARA	BILIKERE_66	10:08	17:16	7:08	LINE CLEAR AVAILED
225	23-Sep-2020	MYSURU	66	BILIKERE-GV GUDI	GVGUDI_66	10:09	17:05	6:55	LINE CLEAR AVAILED
226	23-Sep-2020	MYSURU	66	BILIKERE-KHB	DMG_HALLI_66	10:20	17:25	7:05	LINE CLEAR AVAILED
227	23-Sep-2020	MYSURU	66	DATTAGALLI-HOOTAGALLI	NO STATIONS EFFECTED	11:26	13:44	2:17	NFBC ISSUED
228	23-Sep-2020	MYSURU	66	DATTAGALLI-RK NAGARA	NO STATIONS EFFECTED	13:44	15:25	1:41	NFBC ISSUED
229	23-Sep-2020	MYSURU	66	HV2	HAMPAPURA_66	1:00	1:14	0:13	TRANSFORMER FAULT
230	23-Sep-2020	MYSURU	66	HV1	HULLAHALLI_66	12:03	12:54	0:51	LINE CLEAR AVAILED
231	23-Sep-2020	MYSURU	66	HV2	HULLAHALLI_66	14:00	14:21	0:21	LINE CLEAR AVAILED
232	23-Sep-2020	MYSURU	66	KUSHALNAGARA 220-BYLKUPPE	BYLUKUPPE_66	12:43	12:49	0:06	LINE FAULT
233	23-Sep-2020	MYSURU	66	TUBINKERE-MC-2	NO STATIONS EFFECTED	5:52	5:58	0:05	LINE FAULT
234	23-Sep-2020	MYSURU	66	TUBINKERE-MC-2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66 KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	12:37	12:45	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
235	23-Sep-2020	MYSURU	66	TUBINKERE-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66 KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	12:37	12:45	0:08	LINE FAULT
236	23-Sep-2020	MYSURU	66	MANDYA-M1(TK HALLI)	KIADBMANDYA_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	10:50	12:45	1:55	NFBC ISSUED
237	23-Sep-2020	MYSURU	66	BEGUR 220KV-HARVEY	HARVEY_66	3:45	4:27	0:42	LINE FAULT
238	23-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 1	NO STATIONS EFFECTED	10:10 (19/9/2020)			LINE OPEN, LINE CLEAR AVAILED
239	23-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 2	NO STATIONS EFFECTED	10:10 (19/9/2020)			LINE OPEN, LINE CLEAR AVAILED
240	23-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
241	23-Sep-2020	TUMKUR	220	NEELAGUNDA220KV- GUTTUR 220kV	NEELAGUNDA_220	10:41:57 (21.09.2020)	18:49:22(23.09.2020)	56:08hrs	LINE CHARGED
242	23-Sep-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	13:15	18:41	5:26	LINE CLEAR AVAILED
243	23-Sep-2020	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	13:14	18:40	5:26	LINE CLEAR AVAILED
244	23-Sep-2020	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	18:36	18:56	0:19	LINE FAULT
245	23-Sep-2020	TUMKUR	110	HONNAVALLI 110-ADAN SOLAR	ADAN SOLAR_IPP_66	17:39	22:03	4:23	LINE CLEAR AVAILED
246	23-Sep-2020	TUMKUR	110	TR-1	KALLUR_110	11:03	15:24	4:21	LINE CLEAR AVAILED
247	23-Sep-2020	TUMKUR	110	TR-1	MAYASANDRA_110	12:27	14:01	1:33	LINE CLEAR AVAILED
248	23-Sep-2020	TUMKUR	110	TR-2	MAYASANDRA_110	12:27	14:01	1:34	LINE CLEAR AVAILED
249	23-Sep-2020	TUMKUR	110	TR-1	TIMMANAHALLI_110	8:17	8:34	0:17	HAND TRIPPED
250	23-Sep-2020	TUMKUR	66	TR-1	BELADARA_66	12:11	12:30	0:19	LINE CLEAR AVAILED
251	23-Sep-2020	TUMKUR	66	TR-2	BELLAVI_66	16:04	16:48	0:44	LINE CLEAR AVAILED
252	23-Sep-2020	TUMKUR	66	TR-1	HALURAMESHWARA_66	9:45	10:08	0:22	TRANSFORMER FAULT
253	23-Sep-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	8:33	8:40	0:07	LINE FAULT
254	23-Sep-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	10:23	10:41	0:18	LINE FAULT
255	23-Sep-2020	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	17:52	19:22	1:29	LINE CLEAR AVAILED
256	23-Sep-2020	TUMKUR	66	HONNALLI 220KV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	6:37	6:47	0:09	LINE FAULT
257	23-Sep-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	14:21	14:31	0:10	LINE FAULT
258	23-Sep-2020	TUMKUR	66	TR-2	KOLALA_66	10:43	16:54	6:11	LINE CLEAR AVAILED
259	23-Sep-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:34	9:44	0:09	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
260	23-Sep-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	17:01	17:12	0:10	LINE FAULT
261	23-Sep-2020	TUMKUR	66	TR-2	KUNIGAL_66	10:50	11:48	0:57	LINE CLEAR AVAILED
262	23-Sep-2020	TUMKUR	66	MADHUGIRI 220KV- PULAMAGATTA	PULAMG_66	18:43	18:53	0:09	LINE FAULT
263	23-Sep-2020	TUMKUR	66	TR-2	MANGALWADA_66	14:58	15:02	0:04	TRANSFORMER FAULT
264	23-Sep-2020	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	AVNTI_SLR_IPP_66	13:31	13:44	0:13	HAND TRIPPED
265	23-Sep-2020	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	14:32	14:52	0:19	HAND TRIPPED
266	23-Sep-2020	TUMKUR	66	TR-1	MATHOD_66	9:14	9:20	0:05	TRANSFORMER FAULT
267	23-Sep-2020	TUMKUR	66	TR-1	NYAMATHI_66	15:05	16:31	1:25	LINE CLEAR AVAILED
268	23-Sep-2020	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	5:51	6:00	0:08	LINE FAULT
269	23-Sep-2020	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	RANGENAHALLI_66	5:51	5:59	0:08	LINE FAULT
270	23-Sep-2020	TUMKUR	66	RANGANATHAPURA- WLSPNSOLAR1	WELSPUN SOLAR_IPP_66	17:44	19:36	1:52	LINE CLEAR AVAILED
271	23-Sep-2020	TUMKUR	66	RANGANATHAPURA- WLSPNSOLAR2	WELSPUN SOLAR_IPP_66	17:44	19:36	1:52	LINE CLEAR AVAILED
272	24-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
273	24-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
274	24-Sep-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
275	24-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
276	24-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING) GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
277	24-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
278	24-Sep-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
279	24-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
280	24-Sep-2020	BAGALKOT	110	KAVALWADA(AMBEWADI)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	15:34 (13.09.2020)			LINE OPEN, LINE CLEAR AVAILED
281	24-Sep-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
282	24-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
283	24-Sep-2020	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN, LINE CLEAR AVAILED
284	24-Sep-2020	BAGALKOT	110	SIRSI220-SIRSI2	STATION NOT AFFECTED SIRSI_110	21:24 (21.09.2020)			LINE OPEN, LINE CLEAR AVAILED
285	24-Sep-2020	BAGALKOT	220	SIRSI- HUBLI1&2	SIRSI_220	18:22 (23.09.2020)			LINE OPEN, LINE CLEAR AVAILED
286	24-Sep-2020	BAGALKOT	220	SIRSI- HUBLI1&2	SIRSI_220	18:22 (23.09.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
287	24-Sep-2020	BAGALKOT	110	110/11KV HV1&2	AREMALLAPUR_110	3:00	3:14	0:14	TRANSFORMER FAULT
288	24-Sep-2020	BAGALKOT	110	110/11KV HV1&2	AREMALLAPUR_110	11:53	13:07	1:14	TRANSFORMER FAULT
289	24-Sep-2020	BAGALKOT	110	NAGJHARI 1-AMBEWADI_220	AMBEWADI_220	1:54	4:38	2:44	LINE CLEAR AVAILED
290	24-Sep-2020	BAGALKOT	220	BAGLKOT-GADAG 1	BAGALKOT_220	17:54	18:19	0:25	HAND TRIPPED
291	24-Sep-2020	BAGALKOT	220	BAGLAKOT-GADAG 2	BAGALKOT_220	18:03 (24.09.2020)			LINE OPEN, LINE CLEAR AVAILED
292	24-Sep-2020	BAGALKOT	110	BAGALKOT220- NEERBUDIHAL,BAGALKOT 2,KERUR,NAVANAGAR1&2,GU LEDGUDD&LOKAPUR	NEERBUDIHAL_110,BAGALKOT_110 ,KERUR_110, NAVANAGAR_110, GULEDGUDDA_110, LOKAPUR_110	17:54	17:58	0:04	HAND TRIPPED
293	24-Sep-2020	BAGALKOT	110	110/33KV,HV3	BAGALKOT_220, KATAGERI_33, GADDANAKERI_33	17:54	17:59	0:05	HAND TRIPPED
294	24-Sep-2020	BAGALKOT	220	NAGJHARI 2-BIDNAL_220	BIDNAL_220	2:00	5:48	3:48	LOAD CURTAILMENT
295	24-Sep-2020	BAGALKOT	220	220/110KV,HV1&LV1	GADAG_220	13:05 (24.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
296	24-Sep-2020	BAGALKOT	220	GADAG-BAGALKOT 2	GADAG_220	16:28 (24.09.2020)			LINE OPEN, LINE CLEAR AVAILED
297	24-Sep-2020	BAGALKOT	110	110/11KV,HV1	HALIYAL_110	16:37	16:41	0:04	TRANSFORMER FAULT
298	24-Sep-2020	BAGALKOT	110	110/33KV,HV2	HUNGUND_110 &AMINAGAD&KARADI_33	9:59	10:06	0:07	TRANSFORMER FAULT
299	24-Sep-2020	BAGALKOT	110	HUBLI-KALAGHATGI	KALAGHATGI_110	13:41	13:46	0:05	LINE FAULT
300	24-Sep-2020	BAGALKOT	110	KUMATA-SIRSI 1	KUMATA_110	4:43 (24.09.2020)			LINE OPEN, LINE FAULT
301	24-Sep-2020	BAGALKOT	110	220/110KV,LV 2	MK HUBLI_220	0:19	8:44	8:25	LINE CLEAR AVAILED
302	24-Sep-2020	BAGALKOT	110	RANEENNUR- TUMMINAKATTI	TUMMINAKATTI_110	10:09	17:07	6:58	LINE CLEAR AVAILED
303	24-Sep-2020	BAGALKOT	220	NAGJHARI1-HUBLI	HUBLI_220	1:52	5:10	3:18	LOAD CURTAILMENT
304	24-Sep-2020	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	13:37	14:14	0:37	LINE CLEAR AVAILED
305	24-Sep-2020	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	15:36	16:08	0:32	LINE CLEAR AVAILED
306	24-Sep-2020	BENGALURU	66	A STATION 220 - A STATION 1	A STATION 1	23:38	23:59	00:21	LINE FAULT
307	24-Sep-2020	BENGALURU	66	A STATION 220 - C STATION	NO STATION AFFECTED	23:38	23:59	00:21	LINE FAULT
308	24-Sep-2020	BENGALURU	66	HEBBALA 220 - L R BANDE	L R BANDE	19:49	20:18	00:29	LINE FAULT
309	24-Sep-2020	BENGALURU	220	SOMANAHALLI 220 - YARANDANAHALLI 220	JIGANI 220, YARANDANAHALLI 220	10:00	10:18	00:18	LINE FAULT
310	24-Sep-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	10:00	10:20	00:20	MAIN SUPPLY FAILURE
311	24-Sep-2020	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	10:00	10:20	00:20	MAIN SUPPLY FAILURE
312	24-Sep-2020	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66,JIGANI LINK ROAD	10:00	10:20	00:20	MAIN SUPPLY FAILURE
313	24-Sep-2020	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI	10:00	10:20	00:20	MAIN SUPPLY FAILURE
314	24-Sep-2020	BENGALURU	66	JIGANI 220 - BAGGANADODDI	BAGGANADODDI	10:00	10:20	00:20	MAIN SUPPLY FAILURE
315	24-Sep-2020	BENGALURU	66	HBR LAYOUT - L R BANDE	HBR LAYOUT	19:48	19:58	00:10	LINE FAULT
316	24-Sep-2020	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	18:35	19:00	00:25	LINE FAULT
317	24-Sep-2020	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1 & 2	TUBUGERE, CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	09:38	09:44	00:06	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
318	24-Sep-2020	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	09:38	09:44	00:06	LOAD CHANGE OVER
319	24-Sep-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	09:38	09:44	00:06	LOAD CHANGE OVER
320	24-Sep-2020	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1 & 2	TUBUGERE, CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	13:22	13:34	00:12	LOAD CHANGE OVER
321	24-Sep-2020	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	13:22	13:34	00:12	LOAD CHANGE OVER
322	24-Sep-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	13:22	13:34	00:12	LOAD CHANGE OVER
323	24-Sep-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	13:32	13:40	00:08	LOAD CHANGE OVER
324	24-Sep-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	13:32	13:40	00:08	LOAD CHANGE OVER
325	24-Sep-2020	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	13:32	13:40	00:08	LOAD CHANGE OVER
326	24-Sep-2020	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	13:32	13:40	00:08	LOAD CHANGE OVER
327	24-Sep-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	16:22	16:28	00:06	LOAD CHANGE OVER
328	24-Sep-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	16:22	16:28	00:06	LOAD CHANGE OVER
329	24-Sep-2020	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	16:22	16:28	00:06	LOAD CHANGE OVER
330	24-Sep-2020	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	16:22	16:58	00:36	LOAD CHANGE OVER
331	24-Sep-2020	BENGALURU	66	YELDUR - DALASANUR	YELDUR	22:10	23:15	01:05	LINE CLEAR AVAILED
332	24-Sep-2020	BENGALURU	66	A STATION 220 - A STATION 1	A STATION 1	23:38(24/09/2020)			LINE OPEN, LINE FAULT
333	24-Sep-2020	BENGALURU	66	A STATION 220 - C STATION	NO STATION AFFECTED	23:38(24/09/2020)			LINE OPEN, LINE FAULT
334	24-Sep-2020	BENGALURU	66	JAKKASANDRA - ADUGODI	NO STATION AFFECTED	23:04(21/09/2020)			LINE OPEN, LINE FAULT
335	24-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
336	24-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
337	24-Sep-2020	GULBARGA	400	RTPS-GDHALLI	MUNIRABAD_400	11:03(24.09.2020)			LINE OPEN, LINE FAULT
338	24-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
339	24-Sep-2020	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	16:49(19.09.2020)			LINE OPEN, LINE CLEAR AVAILED
340	24-Sep-2020	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	15:17	15:32	00:15	LINE FAULT
341	24-Sep-2020	GULBARGA	220	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	23:13(23.9.2020)	00:10(24.09.2020)	0:57 HRS	LINE CHARGED
342	24-Sep-2020	GULBARGA	220	KUSHTAGI-LINGASUGUR	LINGSUGUR_220	23:15(23.09.2020)	00:14(24.09.2020)	1:01 HRS	LINE CHARGED
343	24-Sep-2020	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	23:13(23.09.2020)	10:48(24.09.2020)	11:35 HRS	LINE CHARGED
344	24-Sep-2020	GULBARGA	220	HV1	SHAHAPUR_220	20:55	21:13	00:18	TRANSFORMER FAULT
345	24-Sep-2020	GULBARGA	110	SINDHANOOR-SUZLON1	SINDHANOOR_220	01:14	01:24	00:10	LINE FAULT
346	24-Sep-2020	GULBARGA	110	HV1	SANKLAPUR_110	10:15	10:20	00:05	TRANSFORMER FAULT
347	24-Sep-2020	GULBARGA	110	HV1	SANKLAPUR_110	10:15	10:20	00:05	TRANSFORMER FAULT
348	24-Sep-2020	GULBARGA	110	HV1	KUDITINI_110	08:22	08:37	00:15	TRANSFORMER FAULT
349	24-Sep-2020	GULBARGA	110	HV1	KUDITINI_110	22:25	22:35	00:10	TRANSFORMER FAULT
350	24-Sep-2020	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	17:40	17:45	00:05	LOAD CURTAILMENT
351	24-Sep-2020	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	17:40	17:45	00:05	LOAD CURTAILMENT
352	24-Sep-2020	GULBARGA	110	HV1,HV2	NALWAR_110	17:30	17:50	00:20	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
353	24-Sep-2020	GULBARGA	110	NALWAR-CLN SOLAR, WARDHA SOLAR	NALWAR_110	17:35	17:50	00:15	LOAD CURTAILMENT
354	24-Sep-2020	GULBARGA	110	TEKKELKOTE-ABMN_SLR	TEKKELKOTE_110	19:25(24.09.2020)			LINE OPEN, LINE CLEAR AVAILED
355	24-Sep-2020	GULBARGA	110	TEKKELKOTE-RENEW_SLR	TEKKELKOTE_110	19:25	21:45	02:20	LINE CLEAR AVAILED
356	24-Sep-2020	GULBARGA	110	TEKKELKOTE-ABMN_SLR	TEKKELKOTE_110	19:25(24.09.2020)	00:35(25.09.2020)	5:10 HRS	LINE CHARGED
357	24-Sep-2020	GULBARGA	66	ITTAGI-HADAGALI1	HIREHADAGALI_66	05:57	06:33	00:36	LINE FAULT
358	24-Sep-2020	GULBARGA	66	LV1	ITTAGI_220	05:57	06:02	00:05	TRANSFORMER FAULT
359	24-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:13 (23.09.2020)	7:14 (24.09.2020)	10:00 hrs	LINE CHARGED
360	24-Sep-2020	HASSAN	110	HV1	BHADRAVATHI_110	10:11(21.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
361	24-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN, LINE CLEAR AVAILED
362	24-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	20:15 (20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
363	24-Sep-2020	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	11:20 (20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
364	24-Sep-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:04(20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
365	24-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:11 (24.09.2020)			LINE OPEN, LINE CLEAR AVAILED
366	24-Sep-2020	HASSAN	110	HV3	BHADRAVATHI_110	18:08	19:34	01:26	LINE CLEAR AVAILED
367	24-Sep-2020	HASSAN	110	HV1	HOSUR_110	16:00	18:32	02:32	LINE CLEAR AVAILED
368	24-Sep-2020	HASSAN	110	JOGJST1	mghejog_gen	13:50	14:20	00:30	LINE FAULT
369	24-Sep-2020	HASSAN	110	MRSSHM-BADRAVATY1	MRS MG_220	09:30	09:40	00:10	HAND TRIPPED
370	24-Sep-2020	HASSAN	110	MRSSHM-BADRAVATY1	MRS MG_220	10:20	10:30	00:10	HAND TRIPPED
371	24-Sep-2020	HASSAN	110	MRSSHM-BADRAVATY2	MRS MG_220	09:30	09:40	00:10	HAND TRIPPED
372	24-Sep-2020	HASSAN	110	MRSSHM-BADRAVATY2	MRS MG_220	10:20	10:30	00:10	HAND TRIPPED
373	24-Sep-2020	HASSAN	110	SAGARA-JST1	SAGARA_110	14:15	14:20	00:05	HAND TRIPPED
374	24-Sep-2020	HASSAN	66	HV1	KUDLIGERE_66	11:15	11:30	00:15	HAND TRIPPED
375	24-Sep-2020	HASSAN	66	HV1	KUDLIGERE_66	11:55	13:00	01:05	LINE CLEAR AVAILED
376	24-Sep-2020	HASSAN	66	HV1	KUDLIGERE_66	13:45	14:05	00:20	HAND TRIPPED
377	24-Sep-2020	HASSAN	66	HV1	KUDLIGERE_66	14:45	14:50	00:05	HAND TRIPPED
378	24-Sep-2020	MYSURU	66	BG NAGARA-NAGMANGALA	BGNAGARA_66	17:05	18:56	1:51	NFBC ISSUED
379	24-Sep-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	16:55	18:46	1:51	LINE CLEAR AVAILED
380	24-Sep-2020	MYSURU	66	G UKKADA-PANDAVAPURA	NO STATIONS EFFECTED	10:30	16:50	6:19	LINE CLEAR AVAILED
381	24-Sep-2020	MYSURU	66	G UKKADA-TUBINKERE	GARUDANAU KADDA_66	10:30	16:30	5:59	LINE CLEAR AVAILED
382	24-Sep-2020	MYSURU	66	G UKKADA-SR PATNA	NO STATIONS EFFECTED	10:25	16:50	6:25	LINE CLEAR AVAILED
383	24-Sep-2020	MYSURU	66	METAGALLI-SR PATNA	NO STATIONS EFFECTED	10:22	10:27	0:05	HAND TRIPPED
384	24-Sep-2020	MYSURU	66	HV1	HARVEY_66	12:10	14:11	2:01	LINE CLEAR AVAILED
385	24-Sep-2020	MYSURU	66	HV2	HARVEY_66	14:11	15:30	1:19	LINE CLEAR AVAILED
386	24-Sep-2020	MYSURU	66	KADAKOLA-SARGUR 2	NO STATIONS EFFECTED	18:28	18:39	0:10	LINE FAULT
387	24-Sep-2020	MYSURU	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	18:28	18:39	0:10	LINE FAULT
388	24-Sep-2020	MYSURU	66	HV2	SATHEGALA_66	12:05	14:05	2:00	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
389	24-Sep-2020	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	7:30	7:35	0:05	LINE FAULT
390	24-Sep-2020	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	7:37	7:49	0:12	LINE FAULT
391	24-Sep-2020	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	11:17	11:27	0:10	LINE FAULT
392	24-Sep-2020	MYSURU	66	VAJMANGALA-KADAKOLA 1	MARADIHUNDI_66 AYRALLI_66	5:45	5:54	0:09	LINE FAULT
393	24-Sep-2020	MYSURU	66	HV1	VAJAMANGALA_220	16:01	17:51	1:50	TRANSFORMER FAULT
394	24-Sep-2020	MYSURU	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66 ATTIGULIPURA_66	12:50	13:52	1:02	LINE CLEAR AVAILED
395	24-Sep-2020	MYSURU	66	BEGUR 220-SARGUR	NO STATIONS EFFECTED	6:15	6:27	0:12	LINE FAULT
396	24-Sep-2020	MYSURU	220	HV1	BEGUR_220	14:55	17:18	2:23	LINE CLEAR AVAILED
397	24-Sep-2020	MYSURU	220	KUSHALNAGRA-BASTIPURA	NO STATIONS EFFECTED	10:44	16:10	5:26	LINE CLEAR AVAILED
398	24-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 1	NO STATIONS EFFECTED	10:10 (19/9/2020)			LINE OPEN, LINE CLEAR AVAILED
399	24-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 2	NO STATIONS EFFECTED	10:10 (19/9/2020)			LINE OPEN, LINE CLEAR AVAILED
400	24-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
401	24-Sep-2020	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR IPP_66	AZURE POWER SOLAR_IPP_66	18:00:10 (24.09.2020)			LINE OPEN, LINE CLEAR AVAILED
402	24-Sep-2020	TUMKUR	66	TR-1	BANUVALLI_66	10:14	17:00	6:45	LINE CLEAR AVAILED
403	24-Sep-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	10:03	10:16	0:13	LINE FAULT
404	24-Sep-2020	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	22:51	23:00	0:08	LINE FAULT
405	24-Sep-2020	TUMKUR	66	TR-1	HONNALLI_66	17:40	17:45	0:04	LINE CLEAR AVAILED
406	24-Sep-2020	TUMKUR	66	TR-3	HONNALLI_66	13:58	14:06	0:08	LINE CLEAR AVAILED
407	24-Sep-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGU NDA_66	3:50	4:02	0:12	LINE FAULT
408	24-Sep-2020	TUMKUR	66	MEDIGESHI- MADHUGIRI	MEDIGESHI_66	17:53	18:06	0:13	MAIN SUPPLY FAILURE
409	24-Sep-2020	TUMKUR	66	PAVAGADA220-MIDIGESHI	MEDIGESHI_66	12:27	17:42	5:15	LINE FAULT
410	25-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
411	25-Sep-2020	BAGALKOT	110	110/11KV, HV2	NIDAGUNDI_110	21:27	21:45	00:18	TRANSFORMER FAULT
412	25-Sep-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
413	25-Sep-2020	BAGALKOT	110	110/11KV,HV1	BIJAPUR CITY_110	10:22	10:50	00:28	TRANSFORMER FAULT
414	25-Sep-2020	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR	06:40	06:53	00:13	LOAD CURTAILMENT
415	25-Sep-2020	BAGALKOT	110	220/110KV,LV2	STATION NOT AFFECTED MK HUBLI_220	00:22	08:11	07:49	LOAD CURTAILMENT
416	25-Sep-2020	BAGALKOT	110	220/110KV,LV2	STATION NOT AFFECTED MK HUBLI_220	21:07 (25.09.2020)			LOAD CURTAILMENT
417	25-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
418	25-Sep-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
419	25-Sep-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
420	25-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING) GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
421	25-Sep-2020	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA 110	15:34 (13.09.2020)			LINE OPEN, LINE CLEAR AVAILED
422	25-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
423	25-Sep-2020	BAGALKOT	110	KUMATA-SIRSI 1	STATION NOT AFFECTED KUMATA 110	4:43 (24.09.2020)	16:0 (25.09.2020)	11:17 hrs	LINE CHARGED
424	25-Sep-2020	BAGALKOT	110	SIRSI220-SIRSI1&2	STATION NOT AFFECTED SIRSI 220	21:24 (21.09.2020)	13:08 (25.09.2020)	15:44 hrs	LINE CHARGED
425	25-Sep-2020	BAGALKOT	110	SIRSI220-SIRSI1&2	STATION NOT AFFECTED SIRSI 110	16:50 (25.09.2020)			LINE OPEN, LINE CLEAR AVAILED
426	25-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR 110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
427	25-Sep-2020	BAGALKOT	220	220/110KV,HV1&LV1	STATION NOT AFFECTED GADAG 220	13:05 (24.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
428	25-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT 220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
429	25-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI 220	16:28 (16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
430	25-Sep-2020	BAGALKOT	220	BAGLAKOT-GADAG 2	STATION NOT AFFECTED BAGALKOT 220	18:03 (24.09.2020)			LINE OPEN, LINE CLEAR AVAILED
431	25-Sep-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM 220	11:12	13:11	01:59	LINE CLEAR AVAILED
432	25-Sep-2020	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL 220	06:16	15:26	09:10	LINE FAULT
433	25-Sep-2020	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI 220	10:29 (21.09.2020)			LINE OPEN, LINE CLEAR AVAILED
434	25-Sep-2020	BAGALKOT	220	GADAG-BAGALKOT 2	STATION NOT AFFECTED GADAG 220	16:28 (24.09.2020)			LINE OPEN, LINE CLEAR AVAILED
435	25-Sep-2020	BAGALKOT	220	SIRSI- HUBLI1&2	STATION NOT AFFECTED SIRSI 220	18:22 (23.09.2020)	4:31 (25.09.2020)	10:09 hrs	LINE CHARGED
436	25-Sep-2020	BAGALKOT	220	SIRSI-HUBLI1	SIRSI 220	05:13	17:08	11:55	LOAD CURTAILMENT
437	25-Sep-2020	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI 220	5:13 (25.09.2020)			LOAD CURTAILMENT
438	25-Sep-2020	BAGALKOT	220	SIRSI-SHARAVATHY2	STATION NOT AFFECTED SIRSI 220	22:52 (25.09.2020)			LINE OPEN, LINE FAULT
439	25-Sep-2020	BENGALURU	66	A STATION 220 - A STATION 1	A STATION 1	23:38(24/09/2020)	00:38:00(25/09/2020)	1:00 hrs	LINE CHARGED
440	25-Sep-2020	BENGALURU	66	A STATION 220 - C STATION	NO STATION AFFECTED	23:38(24/09/2020)	00:40:00(25/09/2020)	1:02 hrs	LINE CHARGED
441	25-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
442	25-Sep-2020	BENGALURU	66	BOODIGERE - HOSKOTE 220	BOODIGERE	06:50	07:00	00:10	LOAD CHANGE OVER
443	25-Sep-2020	BENGALURU	66	HV1	KUNDANA	15:10	15:15	00:05	LINE CLEAR AVAILED
444	25-Sep-2020	BENGALURU	66	HV2	HOSOR RAMAPURA	11:45	12:25	00:40	LINE CLEAR AVAILED
445	25-Sep-2020	BENGALURU	66	HV2	HOSOR RAMAPURA	21:27	21:45	00:17	TRANSFORMER FAULT
446	25-Sep-2020	BENGALURU	66	HV2	HOSOR RAMAPURA	23:00	23:15	00:14	TRANSFORMER FAULT
447	25-Sep-2020	BENGALURU	66	HV2	KUNDANA	11:55	12:00	00:05	LINE CLEAR AVAILED
448	25-Sep-2020	BENGALURU	66	HV2	MAHALAKSHMI LAYOUT	10:35	10:39	00:04	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
449	25-Sep-2020	BENGALURU	66	JAKKASANDRA - ADUGODI	NO STATION AFFECTED	23:04(21/09/2020)			LINE OPEN, LINE FAULT
450	25-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
451	25-Sep-2020	GULBARGA	66	HV3	KUDLIGI_66	06:45	06:55	00:10	TRANSFORMER FAULT
452	25-Sep-2020	GULBARGA	110	HATTI-GAMESHAWIND_IPP	HATTI_110	04:42	05:04	00:22	LINE FAULT
453	25-Sep-2020	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	04:42	04:46	00:04	MAIN SUPPLY FAILURE
454	25-Sep-2020	GULBARGA	110	HATTI-SOMANMARADI_IPP	HATTI_110	06:07	06:22	00:15	LINE FAULT
455	25-Sep-2020	GULBARGA	110	HUMNABAD220-HALLIKHED	HALLIKHED_110	15:20	15:35	00:15	LINE FAULT
456	25-Sep-2020	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	16:49(19.09.2020)			LINE OPEN, LINE CLEAR AVAILED
457	25-Sep-2020	GULBARGA	110	HV1	NIRNA_110	09:00	09:05	00:05	TRANSFORMER FAULT
458	25-Sep-2020	GULBARGA	110	HV1	KURKUNTA_110	06:40	06:55	00:15	LOAD CURTAILMENT
459	25-Sep-2020	GULBARGA	110	HV2	JEWARGI_110	06:45	06:55	00:10	LOAD CURTAILMENT
460	25-Sep-2020	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HANUMANAL_110,HIREGONNAGAR_110	17:55	18:10	00:15	LINE FAULT
461	25-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
462	25-Sep-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	DEODURGA_110,GABUR_110	18:06	18:15	00:09	LINE FAULT
463	25-Sep-2020	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110	23:24	23:30	00:06	LINE FAULT
464	25-Sep-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	00:40	00:46	00:06	LINE FAULT
465	25-Sep-2020	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	18:37	18:50	00:13	LINE CLEAR AVAILED
466	25-Sep-2020	GULBARGA	110	SEDAM-VICATASAGAR CEMENTS IPP	VICATASAGAR CEMENTS_IPP	22:20	22:46	00:26	LINE FAULT
467	25-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR_IPP,A SKI_110,HUNSAGI_110	18:53	19:04	00:11	LINE FAULT
468	25-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_110, ASKI_110, HUNSAGI_110	11:49	13:01	01:12	LINE CLEAR AVAILED
469	25-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_110	11:40	14:48	03:08	LINE CLEAR AVAILED
470	25-Sep-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPS WATERWORKS	00:15	00:25	00:10	LINE FAULT
471	25-Sep-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN, LINE CLEAR AVAILED
472	25-Sep-2020	GULBARGA	110	TEKKALKOTE-SHAHISOLAR_IPP	TEKKALKOTE_110	00:00	00:35	00:35	LINE CLEAR AVAILED
473	25-Sep-2020	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	23:28(25.9.2020)			LINE OPEN, LINE CLEAR AVAILED
474	25-Sep-2020	GULBARGA	220	HV2	KUSHTAGI_220	23:00	23:20	00:20	TRANSFORMER FAULT
475	25-Sep-2020	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	06:07	06:33	00:26	LINE CLEAR AVAILED
476	25-Sep-2020	GULBARGA	400	RTPS-GDHALLI	MUNIRABAD_400	11:03(24.09.2020)			LINE OPEN, LINE FAULT
477	25-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN, LINE CLEAR AVAILED
478	25-Sep-2020	HASSAN	66	HV1	HALLIMYSORE_66	11:20	16:40	05:20	LINE CLEAR AVAILED
479	25-Sep-2020	HASSAN	110	HV1	BHADRAVATHI_110	10:11(21.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
480	25-Sep-2020	HASSAN	110	HV1	BRAHMAVARA_110	12:10	12:53	00:43	LINE CLEAR AVAILED
481	25-Sep-2020	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	11:20 (20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
482	25-Sep-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:04(20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
483	25-Sep-2020	HASSAN	110	NANDIKU-MULKE	NANDIKUR_110	10:30	10:37	00:07	HAND TRIPPED
484	25-Sep-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	09:30	16:34	07:04	LINE CLEAR AVAILED
485	25-Sep-2020	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	20:52 (25.09.2020)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
486	25-Sep-2020	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	09:30	16:34	07:04	LINE CLEAR AVAILED
487	25-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:11 (24.09.2020)			LINE OPEN, LINE CLEAR AVAILED
488	25-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	20:15 (20.09.2020)	7:26 (25.09.2020)	107:10 hrs	LINE CHARGED
489	25-Sep-2020	MYSURU	66	HADLI-TUBINKERE	HADLI_66	10:16	14:15	03:58	LINE CLEAR AVAILED
490	25-Sep-2020	MYSURU	66	HV1	BGPURA_66	06:40	07:01	00:21	LOAD CURTAILMENT
491	25-Sep-2020	MYSURU	66	HV1	DODDINADUVADI_66	14:10	15:30	01:20	LINE CLEAR AVAILED
492	25-Sep-2020	MYSURU	66	HV1	DODDINADUVADI_66	14:05	15:28	01:23	LINE CLEAR AVAILED
493	25-Sep-2020	MYSURU	66	HV1	PANDAVAPURA_66	06:44	06:53	00:09	LOAD CURTAILMENT
494	25-Sep-2020	MYSURU	66	HV1	VAJAMANGALA_220	14:54	17:15	02:21	LINE CLEAR AVAILED
495	25-Sep-2020	MYSURU	66	HV2	ADDIHALLI_66	06:40	06:51	00:11	LOAD CURTAILMENT
496	25-Sep-2020	MYSURU	66	HV2	BOOKANAKERE_66	06:40	06:51	00:11	LOAD CURTAILMENT
497	25-Sep-2020	MYSURU	66	HV2	HONNALLY_MYS_66	12:30	15:22	02:52	LINE CLEAR AVAILED
498	25-Sep-2020	MYSURU	66	HV2	KIRUGAVALU_66	06:42	07:03	00:21	LOAD CURTAILMENT
499	25-Sep-2020	MYSURU	66	HV2	VAJAMANGALA_220	16:47	17:08	00:21	TRANSFORMER FAULT
500	25-Sep-2020	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	12:14	12:38	00:24	LINE CLEAR AVAILED
501	25-Sep-2020	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	03:42	03:53	00:10	LINE FAULT
502	25-Sep-2020	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	16:01	16:20	00:19	LINE CLEAR AVAILED
503	25-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 1	NO STATIONS EFFECTED	10:10 (19/9/2020)			LINE OPEN, LINE CLEAR AVAILED
504	25-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 2	NO STATIONS EFFECTED	10:10 (19/9/2020)			LINE OPEN, LINE CLEAR AVAILED
505	25-Sep-2020	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	9:32	18:51	9:19	LINE CLEAR AVAILED
506	25-Sep-2020	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	11:25	18:49	7:24	LINE CLEAR AVAILED
507	25-Sep-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	11:08	11:33	0:24	LINE FAULT
508	25-Sep-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:31	6:32	0:01	LINE FAULT
509	25-Sep-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGU NDA_66	2:59	3:00	0:01	LINE FAULT
510	25-Sep-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGU NDA_66	5:17	5:34	0:17	LINE FAULT
511	25-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS 1	INFOSYS-1	13:25	13:29	0:03	LINE FAULT
512	25-Sep-2020	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	11:17	13:51	2:33	LINE CLEAR AVAILED
513	25-Sep-2020	TUMKUR	66	SANIKERE- CHALLAKERE	SANIKERE_66	8:03	11:08	3:05	LINE CLEAR AVAILED
514	25-Sep-2020	TUMKUR	66	SANIKERE- CHALLAKERE	SANIKERE_66	15:33	16:32	0:58	HAND TRIPPED
515	25-Sep-2020	TUMKUR	66	THALLAK 220kV- CHALLAKERE- 2	CHALLAKERE_66, SANIKERE_66	10:57	15:38	4:41	LINE CLEAR AVAILED
516	25-Sep-2020	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	11:15	11:24	0:08	HAND TRIPPED
517	25-Sep-2020	TUMKUR	66	TR-1	BALENAHALLI_66	9:32	18:52	9:20	LINE CLEAR AVAILED
518	25-Sep-2020	TUMKUR	66	TR-1	HOLALKERE_66	15:57	16:10	0:12	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
519	25-Sep-2020	TUMKUR	66	TR-1	HOSADURGA_66	13:49	16:09	2:20	LINE CLEAR AVAILED
520	25-Sep-2020	TUMKUR	66	TR-1	KOLALA_66	9:29	18:22	8:52	LINE CLEAR AVAILED
521	25-Sep-2020	TUMKUR	66	TR-1	PAVAGADA_220	12:34	12:39	0:05	TRANSFORMER FAULT
522	25-Sep-2020	TUMKUR	66	TR-2	BALENAHALLI_66	9:32	18:52	9:20	LINE CLEAR AVAILED
523	25-Sep-2020	TUMKUR	66	TR-2	HOSADURGA_66	10:34	13:49	3:14	LINE CLEAR AVAILED
524	25-Sep-2020	TUMKUR	66	TR-2	NYAMATHI_66	14:59	17:29	2:29	LINE CLEAR AVAILED
525	25-Sep-2020	TUMKUR	110	TR-1	MAYASANDRA_110	10:15	11:31	1:15	TRANSFORMER FAULT
526	25-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
527	25-Sep-2020	TUMKUR	110	TR-2	MAYASANDRA_110	07:22	08:53	01:30	TRANSFORMER FAULT
528	25-Sep-2020	TUMKUR	110	TR-2	NITTUR_220	13:10	14:51	01:41	LINE CLEAR AVAILED
529	25-Sep-2020	TUMKUR	220	CHITRADURGA 220KV- THALLAK 220	CHITRADURGA_220	10:18	17:47	07:28	LINE CLEAR AVAILED
530	25-Sep-2020	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR IPP_66	AZURE POWER SOLAR_IPP_66	18:00:10 (24.09.2020)	6:41:57 AM(25.09.2020)	12:13 hrs	LINE CHARGED
531	25-Sep-2020	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR IPP_66	AZURE POWER SOLAR_IPP_66	18:44	23:08	04:24	LINE CLEAR AVAILED
532	25-Sep-2020	TUMKUR	220	THALLAK 220KV- CHITRADURGA	THALLAKK_220	10:17	17:40	07:23	LINE CLEAR AVAILED
533	26-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
534	26-Sep-2020	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	06:50	09:00	02:10	TRANSFORMER FAULT
535	26-Sep-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
536	26-Sep-2020	BAGALKOT	110	220/110KV/LV2	STATION NOT AFFECTED MK HUBLI_220	21:07 (25.09.2020)	9:11 (26.09.2020)	12:04 hrs	LINE CHARGED
537	26-Sep-2020	BAGALKOT	110	220/110KV/LV2	STATION NOT AFFECTED MK HUBLI_220	21:22 (26.09.2020)			LOAD CURTAILMENT
538	26-Sep-2020	BAGALKOT	110	BAGALKOT220-BAGALKOT2	BAGALKOT_110	03:50	04:11	00:21	LINE FAULT
539	26-Sep-2020	BAGALKOT	110	BAGALKOT220-BAGALKOT2	BAGALKOT_110	05:26	05:51	00:25	LINE FAULT
540	26-Sep-2020	BAGALKOT	110	BAGALKOT220-BAGALKOT2	BAGALKOT_110	07:01	11:10	04:09	LINE FAULT
541	26-Sep-2020	BAGALKOT	110	BELGAUM SOLAR- MAMADAPUR(B)	MAMADAPUR(B)_110	18:39	18:58	00:19	LINE FAULT
542	26-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
543	26-Sep-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
544	26-Sep-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
545	26-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING) GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
546	26-Sep-2020	BAGALKOT	110	HAVERI220-HANAGAL	HANAGAL_110	18:34	18:49	00:15	LINE FAULT
547	26-Sep-2020	BAGALKOT	110	HAVERI220-SAVANUR	STATION NOT AFFECTED SAVANUR_110	13:0 (26.09.02020)			LINE OPEN, LINE FAULT
548	26-Sep-2020	BAGALKOT	110	KAVALWADA(AMBEWADI)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	15:34 (13.09.2020)			LINE OPEN, LINE CLEAR AVAILED
549	26-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
550	26-Sep-2020	BAGALKOT	110	MAMADAPUR(B)-SHIRBUR	SHIRBUR_110	18:39	18:42	00:03	HAND TRIPPED
551	26-Sep-2020	BAGALKOT	110	RANEBENNUR220-RATTIHALLI(TUMMINKATTI)	TUMMINKATTI_110	06:30	06:46	00:16	LINE FAULT
552	26-Sep-2020	BAGALKOT	110	SIGIKERI-ACHANUR	ACHANUR_110	08:15	10:28	02:13	LINE CLEAR AVAILED
553	26-Sep-2020	BAGALKOT	110	SIRSI220-SIRSI1&2	STATION NOT AFFECTED SIRSI_110	16:50 (25.09.2020)			LINE OPEN, LINE CLEAR AVAILED
554	26-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
555	26-Sep-2020	BAGALKOT	220	220/110KV,HV1&LV1	STATION NOT AFFECTED GADAG_220	13:05 (24.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
556	26-Sep-2020	BAGALKOT	220	220/110KV,HV1&LV1	NO STATION AFFECTED NARENDRA_220	12:16	14:16	02:00	LINE CLEAR AVAILED
557	26-Sep-2020	BAGALKOT	220	220/110KV,HV2&LV2	NO STATION AFFECTED NARENDRA_220	14:21	16:42	02:21	LINE CLEAR AVAILED
558	26-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
559	26-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
560	26-Sep-2020	BAGALKOT	220	BAGLAKOT-GADAG 2	STATION NOT AFFECTED BAGALKOT_220	18:03 (24.09.2020)			LINE OPEN, LINE CLEAR AVAILED
561	26-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA1	BELGAUM_220	02:01	08:46	06:45	LOAD CURTAILMENT
562	26-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	20:08 (26.09.2020)			LOAD CURTAILMENT
563	26-Sep-2020	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN, LINE CLEAR AVAILED
564	26-Sep-2020	BAGALKOT	220	GADAG-BAGALKOT 2	STATION NOT AFFECTED GADAG_220	16:28 (24.09.2020)			LINE OPEN, LINE CLEAR AVAILED
565	26-Sep-2020	BAGALKOT	220	HUBLI-NAGJHARI1	HUBLI_220	00:34	06:00	05:26	LOAD CURTAILMENT
566	26-Sep-2020	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	14:15	14:35	00:20	LINE FAULT
567	26-Sep-2020	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	10:49	15:22	04:33	LOAD CURTAILMENT
568	26-Sep-2020	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	21:37 (26.09.2020)			LINE OPEN, LINE CLEAR AVAILED
569	26-Sep-2020	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	5:13 (25.09.2020)			LOAD CURTAILMENT
570	26-Sep-2020	BAGALKOT	220	SIRSI-SHARAVATY2	STATION NOT AFFECTED SIRSI_220	22:52 (25.09.2020)			LINE OPEN, LINE FAULT
571	26-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
572	26-Sep-2020	BENGALURU	66	HV1	DEVANAHALLI	18:30	18:40	00:10	TRANSFORMER FAULT
573	26-Sep-2020	BENGALURU	66	JAKKASANDRA - ADUGODI	NO STATION AFFECTED	23:04(21/09/2020)			LINE OPEN, LINE FAULT
574	26-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
575	26-Sep-2020	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	16:49(19.09.2020)			LINE OPEN, LINE CLEAR AVAILED
576	26-Sep-2020	GULBARGA	110	HV1	SHAHAPUR_220	10:10	12:05	01:55	LINE CLEAR AVAILED
577	26-Sep-2020	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HANUMANAL 110,HIREGONNAGAR_110	22:50	23:04	00:14	LINE FAULT
578	26-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
579	26-Sep-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	DEODURGA_110,GABUR_110	00:01	00:07	00:06	LINE FAULT
580	26-Sep-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	DEODURGA_110,GABUR_110	04:47	04:54	00:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
581	26-Sep-2020	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110	04:53	05:00	00:07	LINE FAULT
582	26-Sep-2020	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110	00:53	01:01	00:08	LINE FAULT
583	26-Sep-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110,KORAWAR TEMPLE_110	01:37	01:47	00:10	LINE FAULT
584	26-Sep-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110,KORAWAR TEMPLE_110	22:30	22:40	00:10	LINE FAULT
585	26-Sep-2020	GULBARGA	110	SEDAM-VASVADATTA CEMENTS_IPP	VASVADATTA CEMENTS_IPP	00:04	21:42	21:38	LINE FAULT
586	26-Sep-2020	GULBARGA	110	SEDAM-VICATASAGAR CEMENTS_IPP	VICATASAGAR CEMENTS_IPP	06:25	06:40	00:15	LINE FAULT
587	26-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HUNSAGI_110,UGAR SUGAR_IPP	02:48	02:59	00:11	LINE FAULT
588	26-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HUNSAGI_110,UGAR SUGAR_IPP	04:24	04:30	00:06	LINE FAULT
589	26-Sep-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,CORE GREEN SUGAR_IPP,SANNATHI_IPP	19:15	19:37	00:22	LINE FAULT
590	26-Sep-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,KONKAL_110	00:34	01:06	00:32	LINE FAULT
591	26-Sep-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKKUNDA_110,KAMPLI_110,YERADONA_110,SREERAMANAGAR_110,MALLAPUR_110	04:25	04:50	00:25	LINE FAULT
592	26-Sep-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	00:25	01:05	00:40	LINE FAULT
593	26-Sep-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	02:00	02:10	00:10	LINE FAULT
594	26-Sep-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	02:40	04:50	02:10	LINE FAULT
595	26-Sep-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	05:10	09:30	04:20	LINE FAULT
596	26-Sep-2020	GULBARGA	110	SINDHANOOR-SIRIGUPPA	SIRIGUPPA_110,DHADESUGUR_110,TEKKALKOTE_110	03:35	05:50	02:15	LINE FAULT
597	26-Sep-2020	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	23:28(25.9.2020)	7:10(26.9.2020)	8:42HRS	LINE CHARGED
598	26-Sep-2020	GULBARGA	220	HUMNABAD-KAPNOOR2	HUMNABAD_220	03:40	07:11	03:31	LINE CLEAR AVAILED
599	26-Sep-2020	GULBARGA	220	HV1	RAICHUR_220	11:48	11:53	00:05	LINE CLEAR AVAILED
600	26-Sep-2020	GULBARGA	220	HV1	RAICHUR_220	11:53(26.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
601	26-Sep-2020	GULBARGA	220	HV2	SHAHAPUR_220	03:46	04:18	00:32	TRANSFORMER FAULT
602	26-Sep-2020	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	00:32	07:20	06:48	LINE CLEAR AVAILED
603	26-Sep-2020	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	22:45(26.9.2020)			LINE OPEN, LINE CLEAR AVAILED
604	26-Sep-2020	GULBARGA	220	SINDHANOOR-LINGAPUR	SINDHANOOR_220	02:35	05:10	02:35	LINE FAULT
605	26-Sep-2020	GULBARGA	400	RTPS-GDHALLI	MUNIRABAD_400	11:03(24.09.2020)	7:30(26.09.2020)	42:33HRS	LINE CHARGED
606	26-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN, LINE CLEAR AVAILED
607	26-Sep-2020	HASSAN	110	HV1	BHADRAVATHI_110	10:11(21.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
608	26-Sep-2020	HASSAN	110	HV2	ESSUR_110	22:35	22:55	00:20	TRANSFORMER FAULT
609	26-Sep-2020	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	11:20 (20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
610	26-Sep-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:04(20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
611	26-Sep-2020	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	20:52 (25.09.2020)			LINE OPEN, LINE FAULT
612	26-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:11 (24.09.2020)	10:08 (26.09.2020)	35:56 hrs	LINE CHARGED
613	26-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:38 (26.09.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
614	26-Sep-2020	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	17:45	17:50	00:05	LINE FAULT
615	26-Sep-2020	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	13:45	14:36	00:51	LINE CLEAR AVAILED
616	26-Sep-2020	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	14:27	14:55	00:27	LINE CLEAR AVAILED
617	26-Sep-2020	MYSURU	66	KOLLEGALA-THALKADU	NO STATIONS EFFECTED	15:07	15:35	00:28	LINE CLEAR AVAILED
618	26-Sep-2020	MYSURU	66	KUSHALNAGARA-MYSORE 1	MIRLE_66	14:32	15:12	00:40	LINE FAULT
619	26-Sep-2020	MYSURU	66	MANDGERE-HOLENARSIPURA	MANDGERE_66	18:35	18:40	00:05	MAIN SUPPLY FAILURE
620	26-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 1	NO STATIONS EFFECTED	10:10 (19/9/2020)			LINE OPEN, LINE CLEAR AVAILED
621	26-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 2	NO STATIONS EFFECTED	10:10 (19/9/2020)			LINE OPEN, LINE CLEAR AVAILED
622	26-Sep-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	07:10	09:29	02:18	LINE FAULT
623	26-Sep-2020	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	12:42	13:04	00:21	MAIN SUPPLY FAILURE
624	26-Sep-2020	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	12:42	13:01	00:19	MAIN SUPPLY FAILURE
625	26-Sep-2020	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	12:44	13:07	00:22	HAND TRIPPED
626	26-Sep-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:26	13:40	00:14	LINE FAULT
627	26-Sep-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:17	18:31	00:14	LINE FAULT
628	26-Sep-2020	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	13:26	13:37	00:10	LINE FAULT
629	26-Sep-2020	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	18:17	18:29	00:12	LINE FAULT
630	26-Sep-2020	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	16:11	16:25	00:13	LINE FAULT
631	26-Sep-2020	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	18:17	18:33	00:15	LINE FAULT
632	26-Sep-2020	TUMKUR	66	TR-1	HALURAMESHWARA_66	16:15	18:32	02:17	LINE CLEAR AVAILED
633	26-Sep-2020	TUMKUR	66	TR-1	PAVAGADA_220	09:02	09:06	00:03	TRANSFORMER FAULT
634	26-Sep-2020	TUMKUR	66	TR-2	BALENAHALLI_66	14:02	14:14	00:11	TRANSFORMER FAULT
635	26-Sep-2020	TUMKUR	66	TR-2	BUKKAPATNA_66	08:11	08:14	00:03	TRANSFORMER FAULT
636	26-Sep-2020	TUMKUR	66	TR-2	HALURAMESHWARA_66	16:15	17:16	01:01	LINE CLEAR AVAILED
637	26-Sep-2020	TUMKUR	66	TR-2	HALUVAGALU_66	01:09	01:14	00:05	TRANSFORMER FAULT
638	26-Sep-2020	TUMKUR	66	TR-2	HALUVAGALU_66	16:24	16:36	00:11	TRANSFORMER FAULT
639	26-Sep-2020	TUMKUR	66	TR-2	HARIYABBE_66	12:42	13:02	00:19	MAIN SUPPLY FAILURE
640	26-Sep-2020	TUMKUR	66	TR-2	KOLALA_66	10:24	10:43	00:19	LINE CLEAR AVAILED
641	26-Sep-2020	TUMKUR	66	TR-2	KOLALA_66	12:00	15:56	03:56	LINE CLEAR AVAILED
642	26-Sep-2020	TUMKUR	66	TR-2	PATTANAYAKANAHALLI_66	21:53	22:05	00:11	TRANSFORMER FAULT
643	26-Sep-2020	TUMKUR	66	TR-2	PAVAGADA_220	12:10	12:11	00:01	TRANSFORMER FAULT
644	26-Sep-2020	TUMKUR	110	TR-1	DODDAGUNI_110	12:21	12:50	00:29	LINE CLEAR AVAILED
645	26-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
646	27-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
647	27-Sep-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL 110	14:14 (16.09.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
648	27-Sep-2020	BAGALKOT	110	220/110KV/LV2	STATION NOT AFFECTED MK HUBLI 220	21:22 (26.09.2020)			LOAD CURTAILMENT
649	27-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAY OUT	KANABARGI LAY OUT_110	09:53	18:40	08:47	LINE CLEAR AVAILED
650	27-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM 110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
651	27-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA 110	19:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
652	27-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA 110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
653	27-Sep-2020	BAGALKOT	110	HATTARGI-DADDI	DADDI 110	13:44	13:56	00:12	LINE FAULT
654	27-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING) GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
655	27-Sep-2020	BAGALKOT	110	HAVERI220-SAVANUR	STATION NOT AFFECTED SAVANUR 110	13:00 (26.09.02020)	15:30 (27.09.2020)	2:30 hrs	LINE CHARGED
656	27-Sep-2020	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA 110	15:34 (13.09.2020)			LINE OPEN, LINE CLEAR AVAILED
657	27-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
658	27-Sep-2020	BAGALKOT	110	SIRSI220-SIRSI1&2	STATION NOT AFFECTED SIRSI 110	16:50 (25.09.2020)			LINE OPEN, LINE CLEAR AVAILED
659	27-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR 110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
660	27-Sep-2020	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MK HUBLI 220	8:02 (27.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
661	27-Sep-2020	BAGALKOT	220	220/110KV,HV1,LV1, HV2& LV2	KARAWAR_220	16:37	18:24	01:47	LINE CLEAR AVAILED
662	27-Sep-2020	BAGALKOT	220	220/110KV,HV2 & LV2	BAGALKOT_220	13:52	14:40	00:48	TRANSFORMER FAULT
663	27-Sep-2020	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED GADAG 220	13:05 (24.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
664	27-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT 220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
665	27-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI 220	16:28 (16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
666	27-Sep-2020	BAGALKOT	220	BAGLAKOT-GADAG 2	STATION NOT AFFECTED BAGALKOT 220	18:03 (24.09.2020)			LINE OPEN, LINE CLEAR AVAILED
667	27-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM 220	20:08 (26.09.2020)	7:34( 27.09.2020)	11:42 hrs	LINE CHARGED
668	27-Sep-2020	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI 220	10:29 (21.09.2020)			LINE OPEN, LINE CLEAR AVAILED
669	27-Sep-2020	BAGALKOT	220	GADAG-BAGALKOT 2	STATION NOT AFFECTED GADAG 220	16:28 (24.09.2020)			LINE OPEN, LINE CLEAR AVAILED
670	27-Sep-2020	BAGALKOT	220	MKHUBLI- NARENDRA1	STATION NOT AFFECTED MK HUBLI 220	8:02 (27.09.2020)			LINE OPEN, LINE FAULT
671	27-Sep-2020	BAGALKOT	220	MKHUBLI- NARENDRA2	STATION NOT AFFECTED MK HUBLI 220	8:02 (27.09.2020)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
672	27-Sep-2020	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	10:49	11:13	00:24	LINE FAULT
673	27-Sep-2020	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	12:20 (27.09.2020)			LINE OPEN, LINE CLEAR AVOID
674	27-Sep-2020	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	21:37 (26.09.2020)	9:37 (27.09.2020)	12:00 hrs	LINE CHARGED
675	27-Sep-2020	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	5:13 (25.09.2020)			LOAD CURTAILMENT
676	27-Sep-2020	BAGALKOT	220	SIRSI-SHARAVATY1	SIRSI_220	09:37	12:19	02:42	LINE CLEAR AVOID
677	27-Sep-2020	BAGALKOT	220	SIRSI-SHARAVATY2	STATION NOT AFFECTED SIRSI_220	22:52 (25.09.2020)	12:21 (27.09.2020)	14:20 hrs	LINE CHARGED
678	27-Sep-2020	BAGALKOT	220	SIRSI-SHARAVATY2	SIRSI_220	12:59	14:18	01:19	LINE CLEAR AVOID
679	27-Sep-2020	BENGALURU	66	ALUR - NELAMANGALA 66	0	13:53	14:02	00:08	LOAD CHANGE OVER
680	27-Sep-2020	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR, NELAMANGALA 66	12:19	12:29	00:10	LOAD CHANGE OVER
681	27-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
682	27-Sep-2020	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	23:22	23:29	00:06	LINE FAULT
683	27-Sep-2020	BENGALURU	66	HV1	NANDINI LAYOUT	07:12	07:15	00:03	LINE CLEAR AVOID
684	27-Sep-2020	BENGALURU	66	HV1	RR NAGAR	16:32	16:35	00:02	MAIN SUPPLY FAILURE
685	27-Sep-2020	BENGALURU	66	HV1	BTM 4TH PHASE	10:58	11:10	00:12	LOAD CHANGE OVER
686	27-Sep-2020	BENGALURU	66	HV1	BG ROAD	13:00	13:56	00:56	LINE CLEAR AVOID
687	27-Sep-2020	BENGALURU	66	HV2	RR NAGAR	16:32	16:35	00:02	MAIN SUPPLY FAILURE
688	27-Sep-2020	BENGALURU	66	HV2	BTM 4TH PHASE	10:58	11:10	00:12	LOAD CHANGE OVER
689	27-Sep-2020	BENGALURU	66	HV2	BYADRAHALLI	14:18	14:19	00:01	LINE CLEAR AVOID
690	27-Sep-2020	BENGALURU	66	HV2	BG ROAD	13:00	13:56	00:56	LINE CLEAR AVOID
691	27-Sep-2020	BENGALURU	66	ISRO LAYOUT - SUBRAMANYAPURA 220	ISRO LAYOUT	15:50	16:05	00:15	MAIN SUPPLY FAILURE
692	27-Sep-2020	BENGALURU	66	ISRO LAYOUT - SUBRAMANYAPURA 220	ISRO LAYOUT	16:32	16:38	00:06	MAIN SUPPLY FAILURE
693	27-Sep-2020	BENGALURU	66	JAKKASANDRA - ADUGODI	NO STATION AFFECTED	23:04(21/09/2020)			LINE OPEN, LINE FAULT
694	27-Sep-2020	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	11:04	11:12	00:08	LINE CLEAR AVOID
695	27-Sep-2020	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	11:20	12:04	00:43	LINE FAULT
696	27-Sep-2020	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	12:21	12:29	00:08	LINE FAULT
697	27-Sep-2020	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	13:53	14:47	00:53	LINE FAULT
698	27-Sep-2020	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	HALAGUR, HONNIGANAHALLI, DODDALAHALLI, SATHNUR (ACHLU)	16:25	16:53	00:27	LINE FAULT
699	27-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
700	27-Sep-2020	GULBARGA	66	ITTAGGI-HIREHADAGALLI1	HIREHADAGALLI_66,GIRIYAPURA_6 6,SOVENHALLI_66,MAGALA_66	18:25	18:45	00:20	LINE FAULT
701	27-Sep-2020	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,GIRIYAPURA_6 6,SOVENHALLI_66,MAGALA_66	06:35	06:41	00:06	LINE FAULT
702	27-Sep-2020	GULBARGA	110	HUMNABAD-MANEKHALI	MANEKHALI_110	16:49(19.09.2020)			LINE OPEN, LINE CLEAR AVOID
703	27-Sep-2020	GULBARGA	110	HV1,HV2	CHINCHOLI_110	03:45	04:15	00:30	LINE CLEAR AVOID
704	27-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVOID
705	27-Sep-2020	GULBARGA	110	RAICHUR-SHAHAPUR1	GOOGLE_110	06:55	07:10	00:15	LINE CLEAR AVOID

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
706	27-Sep-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110,KORAWAR TEMPLE_110	02:26	02:45	00:19	LINE FAULT
707	27-Sep-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110,KORAWAR TEMPLE_110	02:56	03:12	00:16	LINE FAULT
708	27-Sep-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110,KORAWAR TEMPLE_110	04:55	05:10	00:15	LINE FAULT
709	27-Sep-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110,KORAWAR TEMPLE_110	13:35	13:50	00:15	LINE FAULT
710	27-Sep-2020	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	17:40	17:55	00:15	LINE FAULT
711	27-Sep-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,W ADAGERA_110,CORE GREEN SUGAR IPP,SANNATHI IPP	00:35	00:46	00:11	LINE FAULT
712	27-Sep-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKKUNDA_110,KAMPLI_110,YER ADONA_110,SREERAMANAGAR_110,MALLAPUR_110	04:25	04:35	00:10	LINE FAULT
713	27-Sep-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN, LINE CLEAR AVAILED
714	27-Sep-2020	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	23:10(27.9.2020)			LINE OPEN, LINE CLEAR AVAILED
715	27-Sep-2020	GULBARGA	220	HV1	RAICHUR_220	11:53(26.09.2020)	17:03(27.09.2020)	29:10 HRS	TRANSFORMER CHARGED
716	27-Sep-2020	GULBARGA	220	RAICHUR-JURALA2	RAICHUR_220	02:26	15:06	12:40	LINE FAULT
717	27-Sep-2020	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	22:45(26.9.2020)	6:32(27.9.2020)	8:47 HRS	LINE CHARGED
718	27-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN, LINE CLEAR AVAILED
719	27-Sep-2020	HASSAN	110	HV1	BHADRAVATHI_110	10:11(21.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
720	27-Sep-2020	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	11:20 (20.09.2020)	12:37 (27.09.2020)	169:16 hrs	LINE CHARGED
721	27-Sep-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:04(20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
722	27-Sep-2020	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	09:37	12:19	02:42	LINE CLEAR AVAILED
723	27-Sep-2020	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	20:52 (25.09.2020)	12:21 (27.09.2020)	39:28 hrs	LINE CHARGED
724	27-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:38 (26.09.2020)			LINE OPEN, LINE CLEAR AVAILED
725	27-Sep-2020	MYSURU	66	HV1	MANDGERE_66	16:42	16:50	00:07	TRANSFORMER FAULT
726	27-Sep-2020	MYSURU	66	HV2	SFCSHIVA_66	16:25	16:43	00:17	TRANSFORMER FAULT
727	27-Sep-2020	MYSURU	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	07:45	11:01	03:16	LINE FAULT
728	27-Sep-2020	MYSURU	66	KM DODDI-KK DODDI	KMDODDI_66 KOLKARANADODDI_66	07:50	07:58	00:08	MAIN SUPPLY FAILURE
729	27-Sep-2020	MYSURU	66	KM DODDI-KK DODDI	KOLKARANADODDI_66	09:31	10:55	01:24	LINE CLEAR AVAILED
730	27-Sep-2020	MYSURU	66	KR NAGARA-BILIKERE	BILIKERE_66 DMG_HALLI_66 GVGUDI_66	16:40	17:00	00:19	LINE FAULT
731	27-Sep-2020	MYSURU	66	KR PETE -BOOKANAKERE	BANANGADI_66 BOOKANAKERE_66 CHINAKURALI_66 GANJIGERE_66 SHEELUNERE_66	14:20	14:25	00:05	LINE FAULT
732	27-Sep-2020	MYSURU	66	KUSHALNAGARA 220-MYSORE 1	MIRLE_66	16:41	16:49	00:08	LINE FAULT
733	27-Sep-2020	MYSURU	66	SFC SIVA-ATRIA	NO STATIONS EFFECTED	16:25	20:05	03:40	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
734	27-Sep-2020	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	16:25	16:48	00:22	LINE FAULT
735	27-Sep-2020	MYSURU	66	SINDUVALLIPURA-NANJANGUDU	NO STATIONS EFFECTED	05:50	06:12	00:22	LINE FAULT
736	27-Sep-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	15:30	15:38	00:08	LINE FAULT
737	27-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 1	NO STATIONS EFFECTED	10:10 (19/9/2020)			LINE OPEN, LINE CLEAR AVAILED
738	27-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 2	NO STATIONS EFFECTED	10:10 (19/9/2020)			LINE OPEN, LINE CLEAR AVAILED
739	27-Sep-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	07:21	07:32	00:10	LINE FAULT
740	27-Sep-2020	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:10	14:27	00:17	LINE FAULT
741	27-Sep-2020	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	14:10	14:25	00:15	LINE FAULT
742	27-Sep-2020	TUMKUR	66	KUNDUR- HONNALI	KUNDUR_66	22:24	22:43	00:18	LINE FAULT
743	27-Sep-2020	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	10:29:40 PM(27.09.2020)			LINE OPEN, LINE FAULT
744	27-Sep-2020	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	16:45	16:57	00:11	LINE FAULT
745	27-Sep-2020	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	17:09	17:43	00:33	LINE FAULT
746	27-Sep-2020	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	19:12	20:48	01:35	LINE FAULT
747	27-Sep-2020	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	21:10	22:24	01:14	LINE FAULT
748	27-Sep-2020	TUMKUR	66	TR-1	RAMPURA_66	06:28	06:42	00:14	TRANSFORMER FAULT
749	27-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
750	28-Sep-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
751	28-Sep-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
752	28-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
753	28-Sep-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
754	28-Sep-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING) GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
755	28-Sep-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
756	28-Sep-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
757	28-Sep-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
758	28-Sep-2020	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	15:34 (13.09.2020)			LINE OPEN, LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
759	28-Sep-2020	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
760	28-Sep-2020	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN, LINE CLEAR AVAILED
761	28-Sep-2020	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN, LINE CLEAR AVAILED
762	28-Sep-2020	BAGALKOT	220	BAGLAKOT-GADAG 2	STATION NOT AFFECTED BAGALKOT_220	18:03 (24.09.2020)			LINE OPEN, LINE CLEAR AVAILED
763	28-Sep-2020	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED GADAG_220	13:05 (24.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
764	28-Sep-2020	BAGALKOT	220	GADAG-BAGALKOT 2	STATION NOT AFFECTED GADAG_220	16:28 (24.09.2020)			LINE OPEN, LINE CLEAR AVAILED
765	28-Sep-2020	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	5:13 (25.09.2020)			LOAD CURTAILMENT
766	28-Sep-2020	BAGALKOT	110	SIRSI220-SIRSI1&2	STATION NOT AFFECTED SIRSI_110	16:50 (25.09.2020)			LINE OPEN, LINE CLEAR AVAILED
767	28-Sep-2020	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	12:20 (27.09.2020)			LINE OPEN, LINE CLEAR AVAILED
768	28-Sep-2020	BAGALKOT	220	MKHUBLI- NARENDRA1	STATION NOT AFFECTED MK HUBLI_220	8:02 (27.09.2020)	23:40 (28.09.2020)	39:38HRS	LINE CHARGED
769	28-Sep-2020	BAGALKOT	220	MKHUBLI- NARENDRA2	STATION NOT AFFECTED MK HUBLI_220	8:02 (27.09.2020)			LINE OPEN, LINE FAULT
770	28-Sep-2020	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED MK HUBLI_220	8:02 (27.09.2020)	0:08 (28.09.2020)	16:06HRS	LINE CHARGED
771	28-Sep-2020	BAGALKOT	110	220/110KV,LV2	STATION NOT AFFECTED MK HUBLI_220	21:22 (26.09.2020)	22:0 (27.09.2020)	24:38HRS	LINE CHARGED
772	28-Sep-2020	BAGALKOT	110	220/110KV,LV1	STATION NOT AFFECTED MK HUBLI_220	8:02 (27.09.2020)	22:0 (27.09.2020)	37:58HRS	LINE CHARGED
773	28-Sep-2020	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN, LINE CLEAR AVAILED
774	28-Sep-2020	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	18:43	18:57	0:14	LOAD CURTAILMENT
775	28-Sep-2020	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	19:00	19:02	0:02	LOAD CURTAILMENT
776	28-Sep-2020	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	18:44	19:01	0:17	LOAD CURTAILMENT
777	28-Sep-2020	BAGALKOT	110	110/11KV,HV2	GOPPANAKOPPA_110	13:10	14:16	1:06	LINE CLEAR AVAILED
778	28-Sep-2020	BAGALKOT	110	110/11KV,HV2	GAJENDRAGAD_110	18:44	19:01	0:17	LOAD CURTAILMENT
779	28-Sep-2020	BAGALKOT	220	AMBEWADI-PONDA1	STATION NOT AFFECTED AMBEWADI_220	12:31	15:03	2:32	LINE FAULT
780	28-Sep-2020	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	0:27	6:29	6:02	LOAD CURTAILMENT
781	28-Sep-2020	BAGALKOT	220	ATHANI-MAHALINGAPUR	STATION NOT AFFECTED ATHANI_220	4:43	7:41	2:58	LINE FAULT
782	28-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM_220	14:50	15:12	0:22	LINE FAULT
783	28-Sep-2020	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	0:22	6:39	6:17	LOAD CURTAILMENT
784	28-Sep-2020	BAGALKOT	110	110/11KV,HV1	HALIYAL_110	10:55	11:03	0:08	TRANSFORMER FAULT
785	28-Sep-2020	BAGALKOT	110	110/33KV,HV1	HANAGAL_110,PALA_33,BASAPUR_33	18:44	18:54	0:10	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
786	28-Sep-2020	BAGALKOT	110	110/33KV,HV1	HANAGAL_110,PALA_33,BASAPUR_33	18:57	19:16	0:19	LOAD CURTAILMENT
787	28-Sep-2020	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	14:34 (28.09.2020)			LINE OPEN, LINE FAULT
788	28-Sep-2020	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	22:12	22:31	0:19	LINE FAULT
789	28-Sep-2020	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110	18:44	18:49	0:05	LOAD CURTAILMENT
790	28-Sep-2020	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110	18:58	19:05	0:07	LOAD CURTAILMENT
791	28-Sep-2020	BAGALKOT	110	ILKAL1-HUNGUND	STATION NOT AFFECTED HUNGUND_110	18:55 (28.09.2020)			LINE OPEN, LINE FAULT
792	28-Sep-2020	BAGALKOT	110	ILKAL2-HUNGUND	STATION NOT AFFECTED HUNGUND_110	18:55	19:20	0:25	LINE FAULT
793	28-Sep-2020	BAGALKOT	110	110/11KV, HV3	JAMAKHANDI_110	16:45	17:45	1:00	LINE CLEAR AVAILED
794	28-Sep-2020	BAGALKOT	110	110/11KV, HV1A	JAMAKHANDI_110	16:45	17:44	0:59	LINE CLEAR AVAILED
795	28-Sep-2020	BAGALKOT	220	KARWAR-KADRA1	STATION NOT AFFECTED KARWAR_220	11:12	11:16	0:04	LINE CLEAR AVAILED
796	28-Sep-2020	BAGALKOT	220	220/110KV,HV1,LV1	KARWAR_220	11:18	11:24	0:06	LINE CLEAR AVAILED
797	28-Sep-2020	BAGALKOT	110	LOKAPUR-SALAHALLI	SALAHALLI_110	10:12	16:05	5:53	LINE CLEAR AVAILED
798	28-Sep-2020	BAGALKOT	110	MAMADAPUR-BAGEWADI1	STATION NOT AFFECTED MAMADAPUR(B)_110	15:14	15:35	0:21	LINE CLEAR AVAILED
799	28-Sep-2020	BAGALKOT	110	110/33KV,HV3	MAMADAPUR(B)_110,LINGADALLI_110,DEVARAGENNUR_33	16:41	17:47	1:06	LINE CLEAR AVAILED
800	28-Sep-2020	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	23:46 (28.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
801	28-Sep-2020	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	23:47 (28.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
802	28-Sep-2020	BAGALKOT	66	66/33KV, HV4	STATION NOT EFFECTED HARIHAR HOSPET_66	18:44	19:07	0:23	LOAD CURTAILMENT
803	28-Sep-2020	BAGALKOT	110	110/11, HV1	TODALBAGI_110	18:17	18:50	0:33	LOAD CURTAILMENT
804	28-Sep-2020	BAGALKOT	110	110/11, HV1	TODALBAGI_110	18:54	19:18	0:24	LOAD CURTAILMENT
805	28-Sep-2020	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	15:06	19:08	4:02	LINE FAULT
806	28-Sep-2020	BAGALKOT	220	HUBLI-SIRS1	STATION NOT AFFECTED HUBLI_220	12:23	19:14	6:51	LINE CLEAR AVAILED
807	28-Sep-2020	BAGALKOT	110	110/33KV, HV2	HUBLI_220, VRL_33, INDUSTRIAL ESTATE_33	11:43	15:52	4:09	LINE CLEAR AVAILED
808	28-Sep-2020	BAGALKOT	110	110/11KV, HV2	SHIRGOAN_110	10:05	17:04	6:59	LINE CLEAR AVAILED
809	28-Sep-2020	BAGALKOT	110	110/11KV, HV1	SHIRGOAN_110	10:06	17:04	6:58	LINE CLEAR AVAILED
810	28-Sep-2020	BAGALKOT	110	110/11KV, HV2	SAVALAGI_110	10:10	16:00	5:50	LINE CLEAR AVAILED
811	28-Sep-2020	BAGALKOT	110	110/11KV, HV2	SAVALAGI_110	18:44	19:04	0:20	LOAD CURTAILMENT
812	28-Sep-2020	BAGALKOT	110	110/11KV, HV1	SALAHALLI_110	10:20	16:50	6:30	LINE CLEAR AVAILED
813	28-Sep-2020	BAGALKOT	110	110/11KV, HV2	SALAHALLI_110	10:20	17:05	6:45	LINE CLEAR AVAILED
814	28-Sep-2020	BAGALKOT	110	110/33KV, HV3	SALAHALLI_110, HULAKUND_33	10:20	16:15	5:55	LINE CLEAR AVAILED
815	28-Sep-2020	BAGALKOT	110	SALAHALLI-GMNAVAR	SALAHALLI_110, GMNAVAR_IPP	9:52	17:07	7:15	LINE CLEAR AVAILED
816	28-Sep-2020	BAGALKOT	110	110/11KV, HV1	RANNABELAGALI_110	8:25	9:57	1:32	LINE CLEAR AVAILED
817	28-Sep-2020	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	8:25	9:58	1:33	LINE CLEAR AVAILED
818	28-Sep-2020	BAGALKOT	110	110/11KV, HV2	RAIBAG_110	18:17	18:57	0:40	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
819	28-Sep-2020	BAGALKOT	110	110/11KV, HV1	MUDAGANUR_110	18:44	18:55	0:11	LOAD CURTAILMENT
820	28-Sep-2020	BAGALKOT	110	110/11KV, HV1	MUDAGANUR_110	18:57	19:08	0:11	LOAD CURTAILMENT
821	28-Sep-2020	BAGALKOT	220	MAHALINGAPUR- VAJARAMATTI2	STATION NOT AFFECTED MAHALINGAPUR_220	15:23 (28.09.2020)			LINE OPEN, LINE FAULT
822	28-Sep-2020	BENGALURU	66	KORAMANGALA 220 - HAL 1	NO STATION AFFECTED	5:55	6:00	0:05	LINE FAULT
823	28-Sep-2020	BENGALURU	66	HV2	NRS 220	11:07	11:11	0:04	LOAD CHANGE OVER
824	28-Sep-2020	BENGALURU	66	NRS 220 - VIJAY NGR MY2	VIJAYANAGARA	14:43	15:50	1:07	LINE FAULT
825	28-Sep-2020	BENGALURU	66	HV2	SHRIGANDADA KAVALU	11:13	11:20	0:07	LINE CLEAR AVAILED
826	28-Sep-2020	BENGALURU	220	HV2	T K HALLI	15:09	15:18	0:09	TRANSFORMER FAULT
827	28-Sep-2020	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	15:09	15:21	0:12	LINE FAULT
828	28-Sep-2020	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:09	15:21	0:12	LINE FAULT
829	28-Sep-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:09	15:21	0:12	LINE FAULT
830	28-Sep-2020	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	T K HALLI 220	15:09	15:21	0:12	LINE FAULT
831	28-Sep-2020	BENGALURU	66	TK HALLI 220 - SHIMSHA 2	T K HALLI 220	15:09	15:21	0:12	LINE FAULT
832	28-Sep-2020	BENGALURU	66	HV2	VIJAYANAGARA	14:50	14:54	0:04	MAIN SUPPLY FAILURE
833	28-Sep-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	18:54	19:24	0:30	LOAD CURTAILMENT
834	28-Sep-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	18:26	18:54	0:27	LOAD CURTAILMENT
835	28-Sep-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALI, BAIRAKURU, NANGALI	18:26	18:54	0:28	LOAD CURTAILMENT
836	28-Sep-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	18:42	19:15	0:33	LOAD CURTAILMENT
837	28-Sep-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	19:24	19:25	0:01	LOAD CURTAILMENT
838	28-Sep-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	19:54	19:55	0:01	LOAD CURTAILMENT
839	28-Sep-2020	BENGALURU	66	HV1	SIDDALAGATTA	10:43	11:07	0:23	LINE CLEAR AVAILED
840	28-Sep-2020	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	3:43	4:05	0:22	MAIN SUPPLY FAILURE
841	28-Sep-2020	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	3:43	4:05	0:22	MAIN SUPPLY FAILURE
842	28-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	3:43	4:05	0:22	MAIN SUPPLY FAILURE
843	28-Sep-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	3:43	4:05	0:22	MAIN SUPPLY FAILURE
844	28-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA	3:43	4:05	0:22	MAIN SUPPLY FAILURE
845	28-Sep-2020	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 1	MITTEMARI 220	3:43	4:05	0:22	LINE FAULT
846	28-Sep-2020	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	MITTEMARI 220	3:43	4:05	0:22	MAIN SUPPLY FAILURE
847	28-Sep-2020	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	MITTEMARI 220	19:46	22:13	2:27	LINE FAULT
848	28-Sep-2020	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 1	MITTEMARI 220	23:21	23:42	0:21	MAIN SUPPLY FAILURE
849	28-Sep-2020	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	MITTEMARI 220	23:21	23:42	0:21	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
850	28-Sep-2020	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	23:21	23:46	0:25	LOAD CHANGE OVER
851	28-Sep-2020	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	23:21	23:46	0:25	MAIN SUPPLY FAILURE
852	28-Sep-2020	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	23:21	23:46	0:25	MAIN SUPPLY FAILURE
853	28-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	23:21	23:46	0:25	MAIN SUPPLY FAILURE
854	28-Sep-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	23:21	23:46	0:25	MAIN SUPPLY FAILURE
855	28-Sep-2020	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA	23:21	23:46	0:25	MAIN SUPPLY FAILURE
856	28-Sep-2020	BENGALURU	66	JAKKASANDRA - ADUGODI	NO STATION AFFECTED	23:04(21/09/2020)			LINE OPEN, LINE FAULT
857	28-Sep-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
858	28-Sep-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN, LINE FAULT
859	28-Sep-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN, LINE CLEAR AVAILED
860	28-Sep-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
861	28-Sep-2020	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	16:49(19.09.2020)			LINE OPEN, LINE CLEAR AVAILED
862	28-Sep-2020	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	21:55(28.9.2020)			LINE OPEN, LINE CLEAR AVAILED
863	28-Sep-2020	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	23:50(28.9.2020)			LINE OPEN, LINE CLEAR AVAILED
864	28-Sep-2020	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	23:10(27.9.2020)	7:16(28.9.2020)	8:06HRS	LINE CHARGED
865	28-Sep-2020	GULBARGA	220	HUMNABAD-SEDAM2	SEDAM_220	16:15	17:17	01:02	LINE CLEAR AVAILED
866	28-Sep-2020	GULBARGA	220	LINGASUGUR-BBGAEWADI2	B.BAGEWADI_220	13:48	16:14	02:26	LINE FAULT
867	28-Sep-2020	GULBARGA	110	LV1	HUMNABAD_220	10:15	10:35	00:20	TRANSFORMER FAULT
868	28-Sep-2020	GULBARGA	110	HV3	HANUMASAGAR_110	15:05	16:18	01:13	TRANSFORMER FAULT
869	28-Sep-2020	GULBARGA	110	HUMNABAD-SASTHAPUR	SASTHAPUR,RAJESHWAR_110,MAN THAL_110	18:42	18:54	00:12	LINE CLEAR AVAILED
870	28-Sep-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	16:20	16:38	00:18	MAIN SUPPLY FAILURE
871	28-Sep-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	17:29	21:30	04:01	MAIN SUPPLY FAILURE
872	28-Sep-2020	GULBARGA	110	HV1	CHINCHOLI_110	21:33	21:39	00:06	LINE CLEAR AVAILED
873	28-Sep-2020	GULBARGA	110	HV2	ALAND_110	18:20	20:00	01:40	LOAD CURTAILMENT
874	28-Sep-2020	GULBARGA	110	HV3	CHICKSUGUR_110	19:43	19:55	00:12	LOAD CURTAILMENT
875	28-Sep-2020	GULBARGA	110	HV1	GABUR_110	18:55	19:00	00:05	LOAD CURTAILMENT
876	28-Sep-2020	GULBARGA	110	HV1	CJHALLI_66	18:20	18:25	00:05	LOAD CURTAILMENT
877	28-Sep-2020	GULBARGA	110	HV2	JEWARGI_110	18:20	18:30	00:10	LOAD CURTAILMENT
878	28-Sep-2020	GULBARGA	110	SHAHABAD-JEWARGI	JEWARGI_110	18:45	18:50	00:05	MAIN SUPPLY FAILURE
879	28-Sep-2020	GULBARGA	110	HV3	KAMPLI_GLB_110	18:10	19:10	01:00	LOAD CURTAILMENT
880	28-Sep-2020	GULBARGA	110	KOLHAR-NSSK	JANAWADA_110,NSSK SUGAR FACTORY IPP	18:55	20:30	01:35	LINE CLEAR AVAILED
881	28-Sep-2020	GULBARGA	110	HV1	KURKUNTA_110	18:20	19:00	00:40	LOAD CURTAILMENT
882	28-Sep-2020	GULBARGA	110	HV2	HATTI_110	18:43	18:49	00:06	LOAD CURTAILMENT
883	28-Sep-2020	GULBARGA	110	HV3	HATTI_110	09:53	10:01	00:08	TRANSFORMER FAULT
884	28-Sep-2020	GULBARGA	110	KUSHTAGI-ILKAL1	ILKAL_110	18:53	20:18	01:25	LINE FAULT
885	28-Sep-2020	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	15:45	17:20	01:35	LINE CLEAR AVAILED
886	28-Sep-2020	GULBARGA	110	HV1	MAHAGOAN_110	18:19	18:35	00:16	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
887	28-Sep-2020	GULBARGA	110	HV1	MAHAGOAN_110	18:54	18:59	00:05	TRANSFORMER FAULT
888	28-Sep-2020	GULBARGA	110	HV2	SHORAPUR_110	18:19	18:25	00:06	TRANSFORMER FAULT
889	28-Sep-2020	GULBARGA	110	HV1	PD_HALLI_110	18:20	18:25	00:05	LOAD CURTAILMENT
890	28-Sep-2020	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110	01:27	01:35	00:08	LINE FAULT
891	28-Sep-2020	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110	06:27	06:40	00:13	LINE FAULT
892	28-Sep-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	DEODURGA_110,GABUR_110	14:31	14:36	00:05	LINE FAULT
893	28-Sep-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	DEODURGA_110,GABUR_110	21:56	22:08	00:12	LINE FAULT
894	28-Sep-2020	GULBARGA	110	HV1	SANKLAPUR_110	14:25	22:22	07:57	LINE CLEAR AVAILED
895	28-Sep-2020	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	12:20	16:30	04:10	LINE CLEAR AVAILED
896	28-Sep-2020	GULBARGA	110	SEDAM-VICATASAGAR CEMENTS IPP	VICATASAGAR CEMENTS_IPP	05:35	05:43	00:08	LINE FAULT
897	28-Sep-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	16:20	16:28	00:08	LINE FAULT
898	28-Sep-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	17:29	21:30	04:01	LINE FAULT
899	28-Sep-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	22:50	23:20	00:30	LINE FAULT
900	28-Sep-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110ASKI_110,HUNSAGI_110,UGAR SUGAR IPP	18:45	19:04	00:19	LINE CLEAR AVAILED
901	28-Sep-2020	GULBARGA	110	HV1	TEKKALKOTE_110	18:19	18:24	00:05	LOAD CURTAILMENT
902	28-Sep-2020	GULBARGA	110	HV3	YELBURGA_110	21:20(28.9.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
903	28-Sep-2020	GULBARGA	66	BENNEHALLI-KOTTUR	KOTTUR_66,UJJAINI_66	05:45	06:08	00:23	MAIN SUPPLY FAILURE
904	28-Sep-2020	GULBARGA	66	ITTAGGI-KOGALI	KOGALI_66,KUDLIGI_66	05:50	06:00	00:10	MAIN SUPPLY FAILURE
905	28-Sep-2020	GULBARGA	66	HV1	SOVENAHALLI_66	18:30	18:35	00:05	TRANSFORMER FAULT
906	28-Sep-2020	GULBARGA	66	HV1	SOVENAHALLI_66	18:50	18:55	00:05	TRANSFORMER FAULT
907	28-Sep-2020	HASSAN	110	HV1	BHADRAVATHI_110	10:11(21.09.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
908	28-Sep-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN, LINE CLEAR AVAILED
909	28-Sep-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:04(20.09.2020)			LINE OPEN, LINE CLEAR AVAILED
910	28-Sep-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:29 (28.09.2020)			LINE OPEN, LINE CLEAR AVAILED
911	28-Sep-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:04 (28.09.2020)			LINE OPEN, LINE CLEAR AVAILED
912	28-Sep-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	8:30 (26.09.2020)			LINE OPEN, LINE CLEAR AVAILED
913	28-Sep-2020	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	8:30 (26.09.2020)			LINE OPEN, LINE CLEAR AVAILED
914	28-Sep-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:38 (26.09.2020)	9:54 (28.09.2020)	34:12 hrs	LINE CHARGED
915	28-Sep-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	8:30 (26.09.2020)	20:07 (28.09.2020)	59:36 hrs	LINE CHARGED
916	28-Sep-2020	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	8:30 (26.09.2020)	20:07 (28.09.2020)	59:36 hrs	LINE CHARGED
917	28-Sep-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	16:49	20:21	03:32	LINE CLEAR AVAILED
918	28-Sep-2020	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	09:30	14:00	04:30	LINE CLEAR AVAILED
919	28-Sep-2020	HASSAN	220	MRSSHM-VARAH11	MRSMSG_220	17:49	23:01	05:12	LINE CLEAR AVAILED
920	28-Sep-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	17:49	23:01	05:12	LINE CLEAR AVAILED
921	28-Sep-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	17:49	23:01	05:12	LINE CLEAR AVAILED
922	28-Sep-2020	HASSAN	110	MRSSHM-SS2	MRSMSG_220	10:34	16:17	05:43	LINE CLEAR AVAILED
923	28-Sep-2020	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	09:33	13:57	04:24	NFBC ISSUED
924	28-Sep-2020	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	12:31	13:16	00:45	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
925	28-Sep-2020	HASSAN	110	ANANDA-SHIMOGA	ANANDAPURA_110	10:40	16:20	05:40	NFBC ISSUED
926	28-Sep-2020	HASSAN	110	HV2	GANDASI_110	18:53	19:23	00:30	LOAD CURTAILMENT
927	28-Sep-2020	HASSAN	110	HV2	GERUMARA_110	18:53	19:10	00:17	LOAD CURTAILMENT
928	28-Sep-2020	HASSAN	110	HV1	JAVAGAL_110	18:53	19:03	00:10	LOAD CURTAILMENT
929	28-Sep-2020	HASSAN	110	HV1	KALLUSADARAHALLY_110	11:10	17:00	05:50	LINE CLEAR AVAILED
930	28-Sep-2020	HASSAN	110	KALLUSA-KADUR	KALLUSADARAHALLY_110	11:10	17:00	05:50	LINE CLEAR AVAILED
931	28-Sep-2020	HASSAN	110	KMS110-MRS-ANDPR	KUMSI_110	14:12	16:43	02:31	LINE CLEAR AVAILED
932	28-Sep-2020	HASSAN	110	HV2	KONAJE_110	11:16	16:23	05:07	LINE CLEAR AVAILED
933	28-Sep-2020	HASSAN	110	HV1	KONDENALU_110	18:57	19:06	00:09	LOAD CURTAILMENT
934	28-Sep-2020	HASSAN	110	HV2	PUTTUR_110	09:06	13:25	04:19	LINE CLEAR AVAILED
935	28-Sep-2020	HASSAN	110	JOG-JST1	mghejog_gen	10:05	10:10	00:05	LINE FAULT
936	28-Sep-2020	HASSAN	110	SAGARA-JST1	SAGARA_110	10:19	10:21	00:02	HAND TRIPPED
937	28-Sep-2020	HASSAN	110	HV1	SHIRALKOPPA_220	10:21	17:36	07:15	LINE CLEAR AVAILED
938	28-Sep-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	11:12	12:35	01:23	MAIN SUPPLY FAILURE
939	28-Sep-2020	HASSAN	66	HV2	BASAVAGHATTA_66	18:53	19:05	00:12	LOAD CURTAILMENT
940	28-Sep-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	18:43	18:48	00:05	LOAD CURTAILMENT
941	28-Sep-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	18:53	19:01	00:08	LOAD CURTAILMENT
942	28-Sep-2020	HASSAN	66	HV1	HALLIMYSORE_66	18:17	18:22	00:05	LOAD CURTAILMENT
943	28-Sep-2020	HASSAN	66	HV1	HALLIMYSORE_66	18:53	19:00	00:07	LOAD CURTAILMENT
944	28-Sep-2020	HASSAN	66	HV1	HANGARANAHALLY_66	18:17	18:26	00:09	LOAD CURTAILMENT
945	28-Sep-2020	HASSAN	66	HV1	HANGARANAHALLY_66	18:54	19:10	00:16	LOAD CURTAILMENT
946	28-Sep-2020	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	10:25	11:00	00:35	LINE CLEAR AVAILED
947	28-Sep-2020	HASSAN	66	MALALI-CRPATNA	MALALI_66	11:10	12:35	01:25	LINE CLEAR AVAILED
948	28-Sep-2020	HASSAN	66	MALALI-HASSAN	MALALI_66	11:10	12:35	01:25	LINE CLEAR AVAILED
949	28-Sep-2020	HASSAN	66	HV1	MALALI_66	09:26	12:35	03:09	LINE CLEAR AVAILED
950	28-Sep-2020	HASSAN	66	HV1	MOSALEHOSAHALLI_66	10:53	11:15	00:22	LINE CLEAR AVAILED
951	28-Sep-2020	HASSAN	66	HV2	RAMESHWARNAGAR_66	18:17	18:35	00:18	LOAD CURTAILMENT
952	28-Sep-2020	HASSAN	66	HV2	RAMESHWARNAGAR_66	18:56	19:15	00:19	LOAD CURTAILMENT
953	28-Sep-2020	MYSURU	66	HV2	ADDIHALLI_66	10:50	11:42	0:52	LINE CLEAR AVAILED
954	28-Sep-2020	MYSURU	66	HV2	ADDIHALLI_66	18:43	18:49	0:06	LOAD CURTAILMENT
955	28-Sep-2020	MYSURU	66	HV2	ADDIHALLI_66	18:53	18:56	0:03	LOAD CURTAILMENT
956	28-Sep-2020	MYSURU	66	HV2	AKKIHEBBAL_66	18:43	18:50	0:07	LOAD CURTAILMENT
957	28-Sep-2020	MYSURU	66	HV2	AKKIHEBBAL_66	18:53	19:04	0:11	LOAD CURTAILMENT
958	28-Sep-2020	MYSURU	66	HV1	BGPURA_66	18:43	19:13	0:30	LOAD CURTAILMENT
959	28-Sep-2020	MYSURU	66	HV1	BILIKERE_66	18:53	19:01	0:08	LOAD CURTAILMENT
960	28-Sep-2020	MYSURU	66	HV2	BOOKANAKERE_66	18:43	18:52	0:08	LOAD CURTAILMENT
961	28-Sep-2020	MYSURU	66	HV2	BOOKANAKERE_66	18:53	19:03	0:10	LOAD CURTAILMENT
962	28-Sep-2020	MYSURU	66	HV2	CHINAKURALI_66	18:53	19:08	0:14	LOAD CURTAILMENT
963	28-Sep-2020	MYSURU	66	CHUNCHANAKATTE- RAVANDUR	CHUNCHUNKATTE_66	10:00	16:03	6:03	LINE CLEAR AVAILED
964	28-Sep-2020	MYSURU	66	CHUNCHANAKATTE-KR NAGARA	CHUNCHUNKATTE_66	9:58	16:01	6:03	LINE CLEAR AVAILED
965	28-Sep-2020	MYSURU	66	HV1	DATTAGALLY_66	13:10	14:26	1:16	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
966	28-Sep-2020	MYSURU	66	HV2	DATTAGALLY_66	11:26	13:22	1:55	LINE CLEAR AVAILED
967	28-Sep-2020	MYSURU	66	HV2	ELAVALA_66	18:53	18:57	0:03	LOAD CURTAILMENT
968	28-Sep-2020	MYSURU	66	HV1	HALAGUR_66	15:10	15:19	0:08	HAND TRIPPED
969	28-Sep-2020	MYSURU	66	HV1	HANAGODU_66	18:53	19:37	0:44	LOAD CURTAILMENT
970	28-Sep-2020	MYSURU	66	HV2	HDKOTE_66	19:30	19:46	0:16	LOAD CURTAILMENT
971	28-Sep-2020	MYSURU	66	HV2	JAIPUR_66	18:17	18:51	0:33	LOAD CURTAILMENT
972	28-Sep-2020	MYSURU	66	HV2	JAIPUR_66	18:54	18:59	0:05	LOAD CURTAILMENT
973	28-Sep-2020	MYSURU	66	KABHALLY-CLEAN SOLAR	NO STATIONS EFFECTED	10:31	13:00	2:28	NFBC ISSUED
974	28-Sep-2020	MYSURU	66	KADAKOLA-DK MAIDANA	DKMAIDANA_66	15:13	15:17	0:04	LINE FAULT
975	28-Sep-2020	MYSURU	66	HV2	KIRUGAVALU_66	18:56	19:16	0:20	LOAD CURTAILMENT
976	28-Sep-2020	MYSURU	66	HV1	KIADBMANDYA_66	15:10	15:23	0:13	HAND TRIPPED
977	28-Sep-2020	MYSURU	66	HV2	KMDODDI_66	18:54	19:12	0:18	LOAD CURTAILMENT
978	28-Sep-2020	MYSURU	66	HV1	KOLLEGALA_66	11:57	12:28	0:31	LINE CLEAR AVAILED
979	28-Sep-2020	MYSURU	66	HV2	KOLLEGALA_66	11:03	11:57	0:54	LINE CLEAR AVAILED
980	28-Sep-2020	MYSURU	66	HV2	KOLLEGALA_66	18:17	18:21	0:03	LOAD CURTAILMENT
981	28-Sep-2020	MYSURU	66	HV2	KOLLEGALA_66	18:55	18:57	0:02	LOAD CURTAILMENT
982	28-Sep-2020	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	5:49	6:10	0:20	LINE FAULT
983	28-Sep-2020	MYSURU	66	HV2	KRPET_66	10:07	10:51	0:43	LINE CLEAR AVAILED
984	28-Sep-2020	MYSURU	220	HV1	KUSHALNAGARA_220	15:38	16:15	0:36	LINE CLEAR AVAILED
985	28-Sep-2020	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	18:23	0:00	5:36	LINE FAULT
986	28-Sep-2020	MYSURU	66	HV1	NAGAMANGALA_66	18:17	18:25	0:07	LOAD CURTAILMENT
987	28-Sep-2020	MYSURU	66	HV1	NAGAMANGALA_66	18:54	19:00	0:06	LOAD CURTAILMENT
988	28-Sep-2020	MYSURU	66	HV1	PANDAVAPURA_66	18:56	19:02	0:06	LOAD CURTAILMENT
989	28-Sep-2020	MYSURU	66	HV1	SATHEGALA_66	18:54	18:59	0:05	LOAD CURTAILMENT
990	28-Sep-2020	MYSURU	66	HV2	SANTHEBACHALLI_66	3:56	4:02	0:05	TRANSFORMER FAULT
991	28-Sep-2020	MYSURU	66	HV2	SANTHEMARAHALLI_66	18:54	0:00	5:05	LOAD CURTAILMENT
992	28-Sep-2020	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	18:21	0:00	5:38	LINE FAULT
993	28-Sep-2020	MYSURU	66	SFC SIVA-HEBBANI-2	NO STATIONS EFFECTED	18:21	18:50	0:29	LINE FAULT
994	28-Sep-2020	MYSURU	66	SFC SIVA-10MW	NO STATIONS EFFECTED	18:21	18:35	0:13	LINE FAULT
995	28-Sep-2020	MYSURU	66	SFC SIVA-5MW	NO STATIONS EFFECTED	18:21	18:36	0:14	LINE FAULT
996	28-Sep-2020	MYSURU	66	TUBINKERE-NAGMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 KESLAGERE_66	5:41	5:47	0:06	LINE FAULT
997	28-Sep-2020	MYSURU	66	HV1	VAJAMANGALA_220	10:43	11:44	1:01	LINE CLEAR AVAILED
998	28-Sep-2020	MYSURU	220	HV1	VAJAMANGALA_220	11:00	14:39	3:39	LINE CLEAR AVAILED
999	28-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 1	NO STATIONS EFFECTED	10:10 (19/9/2020)			LINE OPEN, LINE CLEAR AVAILED
1000	28-Sep-2020	MYSURU	220	TUBINKERE-KOTTIPURA 2	NO STATIONS EFFECTED	10:10 (19/9/2020)			LINE OPEN, LINE CLEAR AVAILED
1001	28-Sep-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1002	28-Sep-2020	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	22:29:40 (27.09.2020)	00:18:04(28.09.2020)	1:49HRS	LINE CHARGED
1003	28-Sep-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	13:18	14:52	1:33	LINE CLEAR AVAILED
1004	28-Sep-2020	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	13:57	14:56	0:58	LINE CLEAR AVAILED
1005	28-Sep-2020	TUMKUR	110	TR-1	SAMPIGE_110	9:55	12:04	2:08	LINE CLEAR AVAILED
1006	28-Sep-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	18:19	19:45	1:25	LOAD CURTAILMENT
1007	28-Sep-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	18:33	19:45	1:12	LOAD CURTAILMENT
1008	28-Sep-2020	TUMKUR	66	BENNEHALLI-ITTAGI	BENNEHALLI_66	5:48	6:04	0:16	LINE FAULT
1009	28-Sep-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:33	10:46	0:12	LINE FAULT
1010	28-Sep-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	13:27	13:39	0:11	LINE FAULT
1011	28-Sep-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:50	13:58	0:08	LINE FAULT
1012	28-Sep-2020	TUMKUR	66	TR-1	HALURAMESHWARA_66	16:14	18:07	1:52	LINE CLEAR AVAILED
1013	28-Sep-2020	TUMKUR	66	TR-1	HANAGAL_66	10:15	18:07	7:51	LINE CLEAR AVAILED
1014	28-Sep-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	13:07	13:16	0:09	LINE FAULT
1015	28-Sep-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS 1	INFOSYS-1	11:53	11:55	0:01	LINE FAULT
1016	28-Sep-2020	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	7:15	10:41	3:25	LINE FAULT
1017	28-Sep-2020	TUMKUR	66	TR-2	NAYAKANAHATTI_66	16:35	17:31	0:55	LINE CLEAR AVAILED
1018	28-Sep-2020	TUMKUR	66	TR-2	NYAMATHI_66	12:14	17:13	4:58	LINE CLEAR AVAILED
1019	28-Sep-2020	TUMKUR	66	PAVAGADA66-VENKATAPURA	VENKATAPURA_66	7:22	7:40	0:17	LINE FAULT
1020	28-Sep-2020	TUMKUR	66	PAVAGADA66-MADHUGIRI	PAVAGADA_66	7:22	7:33	0:10	LINE FAULT
1021	28-Sep-2020	TUMKUR	66	TR-1	RAMPURA_66	10:29	11:19	0:49	LINE CLEAR AVAILED
1022	28-Sep-2020	TUMKUR	66	TR-2	RAMPURA_66	10:53	11:19	0:26	LINE CLEAR AVAILED
1023	28-Sep-2020	TUMKUR	66	TR-1	RANGANATHAPURA_66	13:02	14:01	0:59	LINE CLEAR AVAILED
1024	28-Sep-2020	TUMKUR	66	TR-2	URDIGERE_66	17:27	18:21	0:54	LINE CLEAR AVAILED