

400/220/110/66 kV TRANSMISSION INTERRUPTIONS DUE TO LC, LS AND FAULTS : 1 to 5 MAY 22

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	3-May-22	BENGALURU	66	HV1	BIDADI 220	2:58	3:06	0:08	TRANSFORMER FAULT
2	3-May-22	BENGALURU	220	HV2	BIDADI 220	2:50	3:08	0:18	TRANSFORMER FAULT
3	3-May-22	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	2:50	3:10	0:20	LINE CLEAR AVAILED
4	3-May-22	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	2:50	3:10	0:20	LINE CLEAR AVAILED
5	3-May-22	BENGALURU	66	ELECTRONIC CITY - ELETRONIC CITY P2 S1	ELECTRONIC CITY	12:11	12:52	0:41	LOAD CHANGEOVER
6	3-May-22	BENGALURU	66	HULIMANGALA - NAGANATHPURA 220	HULIMANGALA	12:10	12:31	0:21	MAIN SUPPLY FAILURE
7	3-May-22	BENGALURU	66	HULIMANGALA - NAGANATHPURA 220	HULIMANGALA	12:32	12:50	0:18	LOAD CHANGEOVER
8	3-May-22	BENGALURU	220	KANAKAPURA 220 - SOMANAHALLI 220	KANAKAPURA 220	18:48	19:05	0:17	MAIN SUPPLY FAILURE
9	3-May-22	BENGALURU	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	18:48	19:10	0:22	LINE CLEAR AVAILED
10	3-May-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBEL, BIJJALALLI	18:48	19:10	0:22	LINE CLEAR AVAILED
11	3-May-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	DODDALAHALLI	18:48	19:10	0:22	LINE CLEAR AVAILED
12	3-May-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 3	HONNIGANAHALLI, ACHALU, HALAGURU	18:48	19:10	0:22	LINE CLEAR AVAILED
13	3-May-22	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU	18:48	19:10	0:22	LINE CLEAR AVAILED
14	3-May-22	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	18:48	19:10	0:22	LINE CLEAR AVAILED
15	3-May-22	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	18:48	19:10	0:22	LINE CLEAR AVAILED
16	3-May-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBEL, BIJJALALLI	20:01	20:17	0:16	LINE FAULT
17	3-May-22	BENGALURU	220	HV2	NAGANATHPURA 220	12:11	17:02	4:51	TRANSFORMER FAULT
18	3-May-22	BENGALURU	220	HV1	NAGANATHPURA 220	12:12	12:21	0:09	TRANSFORMER FAULT
19	3-May-22	BENGALURU	220	HV2	NAGANATHPURA 220	17:26	19:48	2:22	TRANSFORMER FAULT
20	3-May-22	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA, HUSKUR	12:11	12:30	0:19	LINE CLEAR AVAILED
21	3-May-22	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1, INFOSYS(EHT), HULIMANGALA	12:11	12:30	0:19	LINE CLEAR AVAILED
22	3-May-22	BENGALURU	66	HV1	RR NAGAR	16:46	16:48	0:02	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
23	3-May-22	BENGALURU	66	HV2	RR NAGAR	16:46	16:48	0:02	LINE CLEAR AVAILED
24	3-May-22	BENGALURU	66	HV2	REMCO	9:55	9:59	0:04	LOAD CHANGEOVER
25	3-May-22	BENGALURU	66	RMV - TATA INSTITUTE (EHT)	TATA INSTITUTE (EHT)	4:15	4:41	0:26	LINE FAULT
26	3-May-22	BENGALURU	66	HV2	RMV	2:35	2:45	0:10	TRANSFORMER FAULT
27	3-May-22	BENGALURU	66	HV2	RMV	8:08	8:12	0:04	LOAD CHANGEOVER
28	3-May-22	BENGALURU	220	SOMANAHALLI 220 - HAROHALLI BWSSB (EHT)	HAROHALLI BWSSB (EHT), KANAKAPURA 220	18:48	19:02	0:14	LINE FAULT
29	3-May-22	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	14:49	15:04	0:15	LINE FAULT
30	3-May-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	0:00	6:23	6:23	LINE CLEAR AVAILED
31	3-May-22	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	11:14	11:37	0:23	LINE FAULT
32	3-May-22	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:45	12:04	0:19	LINE FAULT
33	3-May-22	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	11:45	13:27	1:42	LINE FAULT
34	3-May-22	BENGALURU	66	HV2	TK HALLI 220	18:57	19:02	0:05	TRANSFORMER FAULT
35	3-May-22	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	21:15	21:47	0:32	LINE FAULT
36	3-May-22	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	21:47	22:04	0:17	LINE FAULT
37	3-May-22	BENGALURU	66	HBR LAYOUT 66 - KONDASPURA	KONDASPURA, ARMY WELFARE ORGANISATION	11:23	11:45	0:22	LINE FAULT
38	3-May-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	8:37	9:04	0:27	LINE FAULT
39	3-May-22	BENGALURU	66	HV2	KODIHALLI HAROBELE	17:26	17:59	0:33	LINE CLEAR AVAILED
40	3-May-22	BENGALURU	66	SANKALGERE - CHANNAPATNA 220	SANKALGERE(BAIRPATNA)	19:58	20:18	0:20	MAIN SUPPLY FAILURE
41	3-May-22	BENGALURU	66	SANKALGERE - CHANNAPATNA 220	SANKALGERE(BAIRPATNA)	9:55	10:00	0:05	MAIN SUPPLY FAILURE
42	3-May-22	BENGALURU	66	HV1	MULABAGALU	10:23	10:39	0:15	TRANSFORMER FAULT
43	3-May-22	BENGALURU	220	HV2	MAGADI 220	12:32	16:14	3:41	LINE CLEAR AVAILED
44	3-May-22	BENGALURU	66	HV1	ANEKAL	18:21	18:35	0:13	TRANSFORMER FAULT
45	3-May-22	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	6:19	6:35	0:15	LINE FAULT
46	3-May-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	14:59	15:29	0:29	LINE FAULT
47	3-May-22	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	18:18	18:29	0:11	LINE FAULT
48	3-May-22	BENGALURU	66	HV1	ATTIBELE	11:10	11:15	0:05	LOAD CHANGEOVER
49	4-May-22	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	17:02	22:30	5:28	LINE FAULT
50	4-May-22	BENGALURU	66	BIDADI 220 - BOSCH (EHT)	BOSCH (EHT)	17:02	17:20	0:18	LINE CLEAR AVAILED
51	4-May-22	BENGALURU	66	BIDADI 220 - EPIPL (EHT)	EPIPL (EHT)	17:02	17:20	0:18	LINE CLEAR AVAILED
52	4-May-22	BENGALURU	66	HV3	BIDADI 220	17:02	17:20	0:18	LINE CLEAR AVAILED
53	4-May-22	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 220	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	6:14	6:18	0:04	LOAD CHANGEOVER
54	4-May-22	BENGALURU	66	KADUGODI - EPIP 220	KADUGODI	8:20	8:23	0:03	LINE FAULT
55	4-May-22	BENGALURU	66	KADUGODI - ARMY WELFARE ORGANISATION	ARMY WELFARE ORGANISATION	8:20	8:40	0:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
56	4-May-22	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	17:06	18:09	1:03	LINE FAULT
57	4-May-22	BENGALURU	220	KANAKAPURA 220 - SOMANAHALLI 220	KANAKAPURA 220	17:15	17:35	0:20	MAIN SUPPLY FAILURE
58	4-May-22	BENGALURU	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	17:15	17:36	0:21	LINE CLEAR AVAILED
59	4-May-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALALLI	17:15	17:36	0:21	LINE CLEAR AVAILED
60	4-May-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	DODDALAHALLI	17:15	17:36	0:21	LINE CLEAR AVAILED
61	4-May-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 3	HONNIGANAHALLI, ACHALU, HALAGURU	17:15	17:36	0:21	LINE CLEAR AVAILED
62	4-May-22	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU	17:15	17:36	0:21	LINE CLEAR AVAILED
63	4-May-22	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	17:15	17:36	0:21	LINE CLEAR AVAILED
64	4-May-22	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	17:15	17:36	0:21	LINE CLEAR AVAILED
65	4-May-22	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	11:10	11:24	0:14	LINE CLEAR AVAILED
66	4-May-22	BENGALURU	66	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	2:22	2:47	0:25	LINE FAULT
67	4-May-22	BENGALURU	66	HV1	TK HALLI 220	11:12	11:15	0:03	TRANSFORMER FAULT
68	4-May-22	BENGALURU	220	NAGANATHPURA 220 - MYLASANDRA 400	NAGANATHPURA 220	14:53	15:11	0:18	LINE FAULT
69	4-May-22	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1, INFOSYS(EHT), HULIMANGALA	14:53	15:13	0:20	LINE CLEAR AVAILED
70	4-May-22	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), HUSKUR	14:53	15:13	0:20	LINE CLEAR AVAILED
71	4-May-22	BENGALURU	66	HV1	NAGANATHPURA 220	14:53	15:13	0:20	LINE CLEAR AVAILED
72	4-May-22	BENGALURU	66	HV2	NAGANATHPURA 220	14:53	15:13	0:20	LINE CLEAR AVAILED
73	4-May-22	BENGALURU	66	HV3	NAGANATHPURA 220	14:53	15:13	0:20	LINE CLEAR AVAILED
74	4-May-22	BENGALURU	220	YARANDANAHALLI 220 - HOSUR 220	YARANDANAHALLI 220	16:06	16:45	0:39	LINE FAULT
75	4-May-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	16:06	16:27	0:21	LINE CLEAR AVAILED
76	4-May-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	16:06	16:27	0:21	LINE CLEAR AVAILED
77	4-May-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	19:10	19:13	0:03	LOAD CHANGEOVER
78	4-May-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	19:10	19:13	0:03	LOAD CHANGEOVER
79	4-May-22	BENGALURU	66	YARANDANAHALLI 220 - JIGANI 66	NO STATION AFFECTED	4:50	6:37	1:47	LINE FAULT
80	4-May-22	BENGALURU	220	HSR LAYOUT 220 - EPIP 220	NO STATION AFFECTED	16:15	18:04	1:49	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
81	4-May-22	BENGALURU	220	SOMANAHALLI 220 - HAROHALLI BWSSB (EHT)	HAROHALLI BWSSB (EHT), KANAKAPURA 220	17:15	17:32	0:17	LINE FAULT
82	4-May-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	15:32	16:00	0:28	LINE FAULT
83	4-May-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	17:18	17:28	0:10	LINE FAULT
84	4-May-22	BENGALURU	220	VRISHABHAVATHI 220 - TATAGUNI 220(EHT)	VRISHABHAVATHI 220	16:44	17:12	0:28	MAIN SUPPLY FAILURE
85	4-May-22	BENGALURU	66	VRISHABHAVATHI 220 - BANASHANKARI	BANASHANKARI	16:44	16:53	0:09	LINE CLEAR AVAILED
86	4-May-22	BENGALURU	66	VRISHABHAVATHI 220 - SIR MV LAYOUT	KNGERI SATELLITE TOWN, SIR MV LAYOUT	16:44	17:12	0:28	LINE CLEAR AVAILED
87	4-May-22	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	REMCO	16:44	17:12	0:28	LINE CLEAR AVAILED
88	4-May-22	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	17:43	17:46	0:03	LOAD CHANGEOVER
89	4-May-22	BENGALURU	66	HV1	M GOLAHALLI	11:42	13:19	1:37	LINE CLEAR AVAILED
90	4-May-22	BENGALURU	220	LV1	DABUSPETE 220	11:27	11:43	0:16	TRANSFORMER FAULT
91	4-May-22	BENGALURU	220	LV2	DABUSPETE 220	11:27	11:40	0:13	TRANSFORMER FAULT
92	4-May-22	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	11:27	11:48	0:21	MAIN SUPPLY FAILURE
93	4-May-22	BENGALURU	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	11:27	11:41	0:14	MAIN SUPPLY FAILURE
94	4-May-22	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	11:27	11:45	0:18	MAIN SUPPLY FAILURE
95	4-May-22	BENGALURU	66	DABUSPET 220 - SK STEEL (EHT)	SK STEEL (EHT)	11:27	11:48	0:21	MAIN SUPPLY FAILURE
96	4-May-22	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	11:27	11:45	0:18	MAIN SUPPLY FAILURE
97	4-May-22	BENGALURU	66	DABUSPET 220 - AVERAHALLI	AVERAHALLI	11:27	11:57	0:30	MAIN SUPPLY FAILURE
98	4-May-22	BENGALURU	66	DABUSPET 220 - SK STEEL (EHT)	SK STEEL (EHT)	13:03	18:17	5:14	LINE CLEAR AVAILED
99	4-May-22	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	18:46	19:42	0:56	LINE FAULT
100	4-May-22	BENGALURU	66	YELAHANKA 220 - LINE 7	KANASWADI	6:30	6:35	0:05	LINE FAULT
101	4-May-22	BENGALURU	66	CHELUR - MITTEMARI 220	CHELUR	16:10	16:30	0:20	LINE FAULT
102	4-May-22	BENGALURU	66	ARMY WELFARE ORGANISATION - KONDASPURA	ARMY WELFARE ORGANISATION	8:59	9:01	0:02	LOAD CHANGEOVER
103	4-May-22	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	16:22	16:58	0:36	LINE FAULT
104	4-May-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	16:40	17:01	0:21	LINE FAULT
105	4-May-22	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	14:55	15:08	0:13	LINE FAULT
106	4-May-22	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, PALLICHERLU	20:06	20:11	0:05	LINE FAULT
107	4-May-22	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, PALLICHERLU	20:06	20:11	0:05	LINE FAULT
108	4-May-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	NO STATION AFFECTED	14:24	14:34	0:10	LINE FAULT
109	4-May-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR	16:14	16:22	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
110	4-May-22	BENGALURU	220	HV1	BIDADI 220	17:02(04/05/2022)			TRANSFOMER OPEN:TRANSFORMER FAULT
111	5-May-22	BENGALURU	66	KOTHIPURA 220 - MELLAHALLI	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, URAGAHALLI	14:45	18:58	4:13	LINE FAULT
112	5-May-22	BENGALURU	66	SRS PEENYA 220 - DG1	NO STATION AFFECTED	20:04	23:32	3:28	LINE FAULT
113	5-May-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	6:37	6:51	0:14	LINE FAULT
114	5-May-22	BENGALURU	220	MYLASANDRA 400 - HSR LAYOUT 220 2	KORAMANGALA 220	12:48	13:21	0:33	LINE FAULT
115	5-May-22	BENGALURU	66	HV3	HSR LAYOUT 220	13:45	14:19	0:34	LINE CLEAR AVAILED
116	5-May-22	BENGALURU	220	HV2	HSR LAYOUT 220	14:38	15:10	0:32	TRANSFORMER FAULT
117	5-May-22	BENGALURU	66	HV1	HSR LAYOUT 220	14:38	15:10	0:32	LINE CLEAR AVAILED
118	5-May-22	BENGALURU	66	HV2	HSR LAYOUT 220	14:38	15:10	0:32	LINE CLEAR AVAILED
119	5-May-22	BENGALURU	66	HV3	HSR LAYOUT 220	14:38	15:40	1:02	LINE CLEAR AVAILED
120	5-May-22	BENGALURU	66	KORMANGALA 220 - AMARJYOTHI	AMARJYOTHI	12:48	13:06	0:18	LINE CLEAR AVAILED
121	5-May-22	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	12:48	13:22	0:34	LINE CLEAR AVAILED
122	5-May-22	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI	14:41	15:29	0:48	LINE FAULT
123	5-May-22	BENGALURU	66	ABBIGERE - WELCASTE	WELCASTE	12:07	12:12	0:05	LINE FAULT
124	5-May-22	BENGALURU	220	HOODY 400 - SOMANAHALLI 220	NO STATION AFFECTED	14:09	15:46	1:37	LINE FAULT
125	5-May-22	BENGALURU	66	PRIMAL - VIKAS TECH PARK 220	PRIMAL	11:20	11:50	0:30	LINE FAULT
126	5-May-22	BENGALURU	66	HV1	PERESANDRA	15:00	15:15	0:15	TRANSFORMER FAULT
127	5-May-22	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	18:40	18:56	0:16	LINE FAULT
128	5-May-22	BENGALURU	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	18:40	19:00	0:20	LINE FAULT
129	5-May-22	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	4:21	4:28	0:07	LINE FAULT
130	5-May-22	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	13:39	14:16	0:37	LINE FAULT
131	5-May-22	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	14:18	14:58	0:40	LINE FAULT
132	5-May-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1	SARJAPURA 220, VIKAS TECH PARK 220	11:21	11:41	0:20	LINE FAULT
133	5-May-22	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:21	11:46	0:25	MAIN SUPPLY FAILURE
134	5-May-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:21	11:52	0:31	MAIN SUPPLY FAILURE
135	5-May-22	BENGALURU	66	HV2	ATTIBELE	11:21	11:47	0:26	MAIN SUPPLY FAILURE
136	5-May-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	12:20	12:30	0:10	LINE FAULT
137	5-May-22	BENGALURU	66	HV1	MITTEMARI 220	18:50	19:24	0:34	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
138	5-May-22	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	14:44	15:14	0:30	LINE FAULT
139	5-May-22	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	17:30	17:35	0:05	LOAD CHANGE OVER
140	5-May-22	BENGALURU	66	ALUR - NELAMANGALA 66	NO STATION AFFECTED	12:58	16:13	3:15	LINE FAULT
141	5-May-22	BENGALURU	220	HV1	BIDADI 220	17:02(04/05/2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
142	03-May-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
143	03-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
144	03-May-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED BABALESHWAR_110	18:04 (16.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
145	03-May-22	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED BELGAUM_220	10:34 (24.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
146	03-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHVAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
147	03-May-22	BAGALKOT	220	SIRSI-SHARAVATI1	SIRSI_220	18:06 (01.05.2022)			LINE OPEN:LINE CLEAR AVAILED
148	03-May-22	BAGALKOT	220	SIRSI-SHARAVATI2	SIRSI_220	18:06 (01.05.2022)			LINE OPEN:LINE CLEAR AVAILED
149	3-May-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	2:32	2:35	0:03	TRANSFORMER FAULT
150	3-May-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	5:59	8:08	2:09	TRANSFORMER FAULT
151	3-May-22	BAGALKOT	110	BIDNAL-GADAG	GADAG_110	5:59	9:35	3:36	LINE FAULT
152	3-May-22	BAGALKOT	110	110/11KV, HV1	HIEMASALI_110	7:12	7:16	0:04	TRANSFORMER FAULT
153	3-May-22	BAGALKOT	110	110/11KV, HV1	HIEMASALI_110	12:02	12:05	0:03	TRANSFORMER FAULT
154	3-May-22	BAGALKOT	220	MK HUBLI- NARENDRA1	MK HUBLI_220	23:46 (03.05.2022)			LINE OPEN:LINE FAULT
155	3-May-22	BAGALKOT	110	110/11KV,HV1	TOLAMATTI_110	19:06	19:08	0:02	TRANSFORMER FAULT
156	3-May-22	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	04:30	5:30	1:00	LINE FAULT
157	03-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
158	3-May-22	BAGALKOT	220	220/110KV, HV2	MK HUBLI_220	22:12	22:41	0:29	TRANSFORMER FAULT
159	3-May-22	BAGALKOT	110	SIRSI220- SIRSI1	SIRSI_220	22:14	23:01	0:47	LINE FAULT
160	3-May-22	BAGALKOT	110	110/11KV, HV2	MANTUR(B)_110	05:56	6:02	0:06	TRANSFORMER FAULT
161	3-May-22	BAGALKOT	220	GADAG-BAGALKOT1	GADAG_220	22:40 (03.05.2022)			LINE OPEN:LINE CLEAR AVAILED
162	3-May-22	BAGALKOT	110	BELGAUM220- MACHE	MACHE_110	14:55	15:18	0:23	LINE FAULT
163	4-May-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
164	4-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
165	4-May-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED BABALESHWAR_110	18:04 (16.04.2022)	18:59 (04.05.2022)	432:55:00	TRANSFORMER CHARGED
166	4-May-22	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED BELGAUM_220	10:34 (24.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
167	4-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHVAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
168	4-May-22	BAGALKOT	220	SIRSI-SHARAVATI1	STATION NOT AFFECTED SIRSI_220	18:06 (01.05.2022)	13:20 (04.05.2022)	67:14:00	LINE CHARGED
169	4-May-22	BAGALKOT	220	SIRSI-SHARAVATI2	STATION NOT AFFECTED SIRSI_220	18:06 (01.05.2022)	13:21 (04.05.2022)	67:15:00	LINE CHARGED
170	4-May-22	BAGALKOT	220	MK HUBLI- NARENDRA1	STATION NOT AFFECTED MK HUBLI_220	23:46 (03.05.2022)	10:46 (04.05.2022)	11:00	LINE CHARGED
171	4-May-22	BAGALKOT	110	ALMEL-KPR SUGAR	KPR SUGARS_110 STATION NOT AFFECTED ALAMEL_110	7:48	10:57	3:09	LINE CLEAR AVAILED
172	4-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED ALAMEL_110	9:25	9:42	0:17	HAND TRIPPED
173	4-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED ALAMEL_110	18:56	19:00	0:04	TRANSFORMER FAULT
174	4-May-22	BAGALKOT	110	BIDNAL220-PH COMPOUND	STATION NOT AFFECTED BIDNAL_220	17:43 (04.05.2022)			LINE OPEN:LINE FAULT
175	4-May-22	BAGALKOT	110	BIJAPUR KIADB-BHUTANAL	BHUTANAL_110	2:07	2:12	0:05	LINE FAULT
176	4-May-22	BAGALKOT	110	THORVI-TAKKALAKI(TIKOTA)	TAKKALAKI_110	5:27	10:50	5:23	LINE CLEAR AVAILED
177	4-May-22	BAGALKOT	110	GAJENDRAGAD-RON1&2	GAJENDRAGAD_110	21:30	21:42	0:12	HAND TRIPPED
178	4-May-22	BAGALKOT	110	WARADA-TAKKALAKI	TAKKALAKI_110	2:10	2:13	0:03	HAND TRIPPED
179	4-May-22	BAGALKOT	110	WARADA-TAKKALAKI	TAKKALAKI_110	10:24	10:38	0:14	HAND TRIPPED
180	4-May-22	BAGALKOT	110	WARADA-TAKKALAKI	TAKKALAKI_110	10:51	10:52	0:01	HAND TRIPPED
181	4-May-22	BAGALKOT	110	KN SOLAR-TAKKALAKI	TAKKALAKI_110	2:11	2:13	0:02	HAND TRIPPED
182	4-May-22	BAGALKOT	110	KN SOLAR-TAKKALAKI	TAKKALAKI_110	10:24	10:38	0:14	HAND TRIPPED
183	4-May-22	BAGALKOT	110	KN SOLAR-TAKKALAKI	TAKKALAKI_110	10:51	10:52	0:01	HAND TRIPPED
184	4-May-22	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	12:01	12:38	0:37	NFBC ISSUED
185	4-May-22	BAGALKOT	110	110/33KV,HV3	KALKERI_33,GOLAGERI_33,MYTRA SOLAR_33 SINDAGI_110	20:21	21:17	0:56	LINE CLEAR AVAILED
186	4-May-22	BAGALKOT	110	SHIRAHATTI-BPCL1	SHIRAHATTI_110	23:35	23:55	0:20	HAND TRIPPED
187	4-May-22	BAGALKOT	110	SIRAHATTI-LAXMESHWA	SHIRAHATTI_110	23:57 (04.05.2022)			LINE OPEN:LINE FAULT
188	4-May-22	BAGALKOT	110	AIGALI-SAVALAGI	SAVALAGI_110	8:50	18:42	9:52	LINE CLEAR AVAILED
189	4-May-22	BAGALKOT	110	RON-NAREGAL	RON_110,NAREGAL_110	21:59	22:48	0:49	HAND TRIPPED
190	4-May-22	BAGALKOT	110	RON-GAMESHA	RON_110	21:59	22:43	0:44	HAND TRIPPED
191	4-May-22	BAGALKOT	110	110/11KV,HV2	RON_110	21:59	22:39	0:40	TRANSFORMER FAULT
192	4-May-22	BAGALKOT	110	110/33KV,HV3	MUSTIGERI_33 RON_110	21:59	22:38	0:39	TRANSFORMER FAULT
193	4-May-22	BAGALKOT	110	110/11KV,HV3(HV2)	MUNDARGI_110	11:51	11:58	0:07	TRANSFORMER FAULT
194	4-May-22	BAGALKOT	110	110/11KV,HV1	MANTUR(GHP)_110	10:00	10:11	0:11	TRANSFORMER FAULT
195	4-May-22	BAGALKOT	110	110/11KV,HV2	MANTUR(GHP)_110	10:00	10:11	0:11	TRANSFORMER FAULT
196	4-May-22	BAGALKOT	110	110/33KV,HV2	CHINCHALI_33 KUDUCHI_110	16:29	17:25	0:56	TRANSFORMER FAULT
197	4-May-22	BAGALKOT	110	110/11KV,HV1	KUDAL SANGAM_110	16:39	16:51	0:12	HAND TRIPPED
198	4-May-22	BAGALKOT	110	220/110KV,HV3,LV3	KUDUCHI_220	10:55	12:56	2:01	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
199	4-May-22	BAGALKOT	110	KUDUCHI-TERDAL(MORAB)	KUDUCHI_220	15:05	16:59	1:54	LINE CLEAR AVAILED
200	4-May-22	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	KIRUVATTI_110	7:17	18:56	11:39	LINE CLEAR AVAILED
201	4-May-22	BAGALKOT	110	110/11KV, HV2	KALAGATAGI_110	11:59	13:38	1:39	LINE CLEAR AVAILED
202	4-May-22	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED CHIKKODI_220	10:40	13:28	2:48	LINE CLEAR AVAILED
203	4-May-22	BAGALKOT	220	BAGALKOT - GADAG2	STATION NOT AFFECTED BAGALKOT_220	12:36	17:53	5:17	LINE CLEAR AVAILED
204	4-May-22	BAGALKOT	110	KARWAR220- ARGA(KUMATA)	KARWAR_220	9:19	9:24	0:05	LINE FAULT
205	4-May-22	BAGALKOT	110	KARWAR220- ARGA(KUMATA)	KARWAR_220	18:29	18:35	0:06	LINE FAULT
206	4-May-22	BAGALKOT	110	KARWAR220- ARGA(KUMATA)	KARWAR_220	19:57	20:02	0:05	LINE FAULT
207	4-May-22	BAGALKOT	110	GHATAPRABHA220- SHIRGOAN	GHATAPRABHA_220	7:56	8:12	0:16	LINE FAULT
208	4-May-22	BAGALKOT	110	GADAG220- BETAGERI(ROH)	STATION NOT AFFECTED GADAG_220	21:10 (04.05.2022)			LINE OPEN:LINE FAULT
209	4-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVAILED
210	4-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVAILED
211	4-May-22	BAGALKOT	220	SOUDATTI- BIDNAL	STATION NOT AFFECTED SOUDATTI_220	17:25	19:09	1:44	LINE CLEAR AVAILED
212	4-May-22	BAGALKOT	220	DHONI- LINGAPUR1 (HALAVARTI2)	STATION NOT AFFECTED DHONI_400	20:59 (04.05.2022)			LINE OPEN:LINE FAULT
213	4-May-22	BAGALKOT	220	BIDNAL- NAGJHARI2	STATION NOT AFFECTED BIDNAL_220	17:45	20:38	2:53	LINE FAULT
214	4-May-22	BAGALKOT	220	BIDNAL- NAGJHARI2	STATION NOT AFFECTED BIDNAL_220	22:06	22:17	0:11	HAND TRIPPED
215	4-May-22	BAGALKOT	220	BIDNAL- NAGJHARI2	BIDNAL_220	22:34 (04.05.2022)			LINE OPEN:LINE CLEAR AVAILED
216	4-May-22	BAGALKOT	110	KAVALWADA- HALIYAL	HALIYAL_110	7:27	7:50	0:23	HAND TRIPPED
217	4-May-22	BAGALKOT	110	AMBEWADI- NK2(KAVALWAD)	AMBEWADI_220	7:37	7:48	0:11	HAND TRIPPED
218	4-May-22	BAGALKOT	110	HAVERI220- BYADAGI	STATION NOT AFFECTED HAVERI_220	20:09 (04.06.2022)			LINE OPEN:LINE FAULT
219	4-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
220	4-May-22	BAGALKOT	220	GADAG-BAGALKOT1	GADAG_220	22:40 (03.05.2022)	17:52 (04.05.2022)	19:12	LINE CHARGED
221	4-May-22	BAGALKOT	110	110/11KV, HV2	KATARKI_110	15:30	17:35	2:05	LINE CLEAR AVAILED
222	4-May-22	BAGALKOT	110	110/11KV, HV4	ANKALI_110	15:05	15:30	0:25	TRANSFORMER FAULT
223	4-May-22	BAGALKOT	220	220/110KV, HV4	STATION NOT AFFECTED GADAG_220	11:12	17:56	6:44	LINE CLEAR AVAILED
224	4-May-22	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	12:30	17:53	5:23	LINE CLEAR AVAILED
225	4-May-22	BAGALKOT	110	GADAG220- BETAGERI(ROH)	STATION NOT AFFECTED GADAG_220	21:10 (04.05.2022)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
226	4-May-22	BAGALKOT	110	NARENDRA220- UAS	STATION NOT AFFECTED NARENDRA_220	10:17	14:35	4:18	LINE CLEAR AVAILED
227	5-May-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
228	5-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
229	5-May-22	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED BELGAUM_220	10:34 (24.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
230	5-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFOMER OPEN:TRANSFORMER FAULT
231	5-May-22	BAGALKOT	110	BIDNAL220-PH COMPOUND	STATION NOT AFFECTED BIDNAL_220	17:43 (04.05.2022)	14:58 (05.05.2022)	21:15	LINE CHARGED
232	5-May-22	BAGALKOT	110	SIRAHATTI-LAXMESHWAR	STATION NOT AFFECTED SHIRAHATTI_110	23:57 (04.05.2022)	11:27 (05.05.2022)	11:30	LINE CHARGED
233	5-May-22	BAGALKOT	110	GADAG220- BETAGERI(ROH)	STATION NOT AFFECTED GADAG_220	21:10 (04.05.2022)			LINE OPEN:LINE FAULT
234	5-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVAILED
235	5-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVAILED
236	5-May-22	BAGALKOT	220	DHONI- LINGAPUR1 (HALAVARTI2)	STATION NOT AFFECTED DHONI_400	20:59 (04.05.2022)	9:51 (05.05.2022)	12:52	LINE CHARGED
237	5-May-22	BAGALKOT	220	BIDNAL- NAGJHARI2	STATION NOT AFFECTED BIDNAL_220	22:34 (04.05.2022)	9:11 (05.05.2022)	10:37	LINE CHARGED
238	5-May-22	BAGALKOT	110	HAVERI220- BYADAGI	STATION NOT AFFECTED HAVERI_220	20:09 (04.06.2022)	15:06 (05.05.2022)	18:57	LINE CHARGED
239	5-May-22	BAGALKOT	110	THORVI-TAKKALAKI(TIKOTA)	TAKKALAKI_110	5:58	9:04	3:06	LINE CLEAR AVAILED
240	5-May-22	BAGALKOT	110	DAMBAL-SUZLON(L2)	DAMBAL_110	16:32	20:44	4:12	LINE FAULT
241	5-May-22	BAGALKOT	110	110/11KV,HV1	GULEDGUDDA_110	16:13	16:45	0:32	LINE CLEAR AVAILED
242	5-May-22	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	16:06	17:24	1:18	LINE CLEAR AVAILED
243	5-May-22	BAGALKOT	110	HALIYAL-GMR	HALIYAL_110	11:12	19:59	8:47	LINE CLEAR AVAILED
244	5-May-22	BAGALKOT	110	110/11KV,HV2	ITANAL_110	16:46	19:13	2:27	LINE CLEAR AVAILED
245	5-May-22	BAGALKOT	110	110/11KV,HV1	BABALESHWAR_110	16:02	19:03	3:01	LINE CLEAR AVAILED
246	5-May-22	BAGALKOT	220	NAGJHARI2-BIDNAL	STATION NOT AFFECTED BIDNAL_220	9:54	10:28	0:34	LINE CLEAR AVAILED
247	5-May-22	BAGALKOT	220	BIDNAL-HARTI2	STATION NOT AFFECTED BIDNAL_220	17:11	21:01	3:50	LINE FAULT
248	5-May-22	BAGALKOT	220	BIDNAL-HARTI1	STATION NOT AFFECTED BIDNAL_220	17:30	21:39	4:09	LINE FAULT
249	5-May-22	BAGALKOT	220	BIDNAL-SOUDATTI	STATION NOT AFFECTED BIDNAL_220	17:20 (05.04.2022)			LINE OPEN:LINE FAULT
250	5-May-22	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110 (STATION NOT AFFECTED)	17:03 (05.05.2022)			LINE OPEN:LINE FAULT
251	5-May-22	BAGALKOT	110	BIDNAL-ANNIGERI	NAVALGUND_110 (STATION NOT AFFECTED)	17:13 (05.05.2022)			LINE OPEN:LINE FAULT
252	5-May-22	BAGALKOT	110	SIRSI-KUMTA1	SIRSI_110	2:10	11:20	9:10	LINE FAULT
253	5-May-22	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	2:14	11:19	9:05	LINE FAULT
254	5-May-22	BAGALKOT	110	AIGALI-SAVALAGI	SAVALAGI_110	9:01	18:42	9:41	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
255	5-May-22	BAGALKOT	110	RANNABELAGALI-MUDHOL(UTTUR)	RANNABELAGALI_110	4:28	6:20	1:52	LINE FAULT
256	5-May-22	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	17:38 (05.05.2022)			LINE OPEN:LINE FAULT
257	5-May-22	BAGALKOT	110	110/11KV,HV2	MUNAVALI_110	10:13	10:22	0:09	TRANSFORMER FAULT
258	5-May-22	BAGALKOT	110	MR NAGAR-GOPPANAKOPPA1	MR NAGAR_110	18:05 (05.05.2022)			LINE OPEN:LINE CLEAR AVAILED
259	5-May-22	BAGALKOT	110	110/11KV,HV1	KUDALASANGAM_110	14:10	14:32	0:22	LINE CLEAR AVAILED
260	5-May-22	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	KIRUVATTI_110	06:50	17:01	10:11	LINE CLEAR AVAILED
261	5-May-22	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	KIRUVATTI_110	18:21 (05.05.2022)			LINE OPEN:LINE CLEAR AVAILED
262	5-May-22	BAGALKOT	110	110/11KV,HV2	KALAGATAGI_110	16:35	17:29	0:54	LINE CLEAR AVAILED
263	5-May-22	BAGALKOT	110	110/11KV,HV2	KALAGATAGI_110	19:40	19:46	0:06	TRANSFORMER FAULT
264	5-May-22	BAGALKOT	220	SOUDATTI- BIDNAL	STATION NOT AFFECTED SOUDATTI_220	17:20 (05.05.2022)			LINE OPEN:LINE FAULT
265	5-May-22	BAGALKOT	110	ATHANI220- AIGALI	AIGALI_110,KAKMARI_110,ALBAL_110,YA LLAMANWADI_110,SAVALAGI_110,TODA LAGI_110	05:47	5:56	0:10	LINE FAULT
266	5-May-22	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	17:58	22:14	4:16	LINE FAULT
267	5-May-22	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	8:27	8:52	0:25	HAND TRIPPED
268	5-May-22	BAGALKOT	110	AMBEWADI- NK2 (KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	17:22	17:26	0:04	HAND TRIPPED
269	5-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
270	5-May-22	BAGALKOT	110	110/11KV, HV2	KATARAKI_110	11:37	13:00	1:23	LINE CLEAR AVAILED
271	5-May-22	BAGALKOT	110	110/11KV, HV1	HALAKI_110	14:00	14:30	0:30	HAND TRIPPED
272	5-May-22	BAGALKOT	110	AMBEWADI- HALIYAL	HALIYAL_110	11:10	19:55	8:45	LINE CLEAR AVAILED
273	5-May-22	BAGALKOT	220	NARENDRA- HUBLI1	STATION NOT AFFECTED NARENDRA_220	17:58	22:14	4:16	LINE FAULT
274	5-May-22	BAGALKOT	110	RANEBENNUR- HONNATTI	RANEBENNUR_220	0:08	0:50	0:42	LINE FAULT
275	5-May-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED SIRSI_220	2:16	2:26	0:10	TRANSFORMER FAULT
276	5-May-22	BAGALKOT	220	CHIKKODI- TALANDAGE	STATION NOT AFFECTED CHIKKODI_220	13:53	20:32	6:39	NFBC ISSUED
277	3/May/2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFOMER OPEN:TRANSFORMER FAULT
278	3/May/2022	GULBARGA	110	HUMNABAD-HUMNABAD_2	HUMNABAD_110	15:06(26/04/2022)			LINE OPEN:LINE CLEAR AVAILED
279	3/May/2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAG ERA_110,SANNATHI_IPP,COREGREENSUG ARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
280	3/May/2022	GULBARGA	110	HV2	SREERAMANAGAR_110	17:55	18:22	0:27	TRANSFORMER FAULT
281	3/May/2022	GULBARGA	110	HV3	VALKAMDINNI_110	5:30	5:35	0:05	TRANSFORMER FAULT
282	3/May/2022	GULBARGA	110	HV3	VALKAMDINNI_110	6:10	6:15	0:05	TRANSFORMER FAULT
283	3/May/2022	GULBARGA	110	HV3	VALKAMDINNI_110	16:35	16:39	0:04	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
284	3/May/2022	GULBARGA	110	HV3	VALKAMDINNI_110	20:10	20:20	0:10	TRANSFORMER FAULT
285	3/May/2022	GULBARGA	110	HV2	NIRNA_110	11:00	11:05	0:05	TRANSFORMER FAULT
286	3/May/2022	GULBARGA	110	HV2	MATAMARI_110	21:35	21:40	0:05	TRANSFORMER FAULT
287	3/May/2022	GULBARGA	110	HV1	METRI_110	15:30	15:34	0:04	TRANSFORMER FAULT
288	3/May/2022	GULBARGA	110	AURAD-DONGARGOAN	DONGARGOAN_110	15:05	15:15	0:10	LINE FAULT
289	3/May/2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	13:25	13:35	0:10	LINE FAULT
290	3/May/2022	GULBARGA	110	SINDHANOOR-ADAVI AMARESHWAR	MANVI_110,MADLAPUR_110,KURDICROSS_110,ADAVI AMARESHWAR_110	23:05	23:15	0:10	LINE FAULT
291	3/May/2022	GULBARGA	110	LINGASUGUR-KPRL	KAREPOWER_IPP,CHAYADEVI_IPP	5:48	6:06	0:18	LINE FAULT
292	3/May/2022	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	21:25	23:58	2:33	LINE FAULT
293	3/May/2022	GULBARGA	110	NIRNA-RENEW SOLAR	NIRNA_110	15:55	16:15	0:20	LINE FAULT
294	3/May/2022	GULBARGA	110	YAPALDINI-VADAVATTI	YAPALDINI_110	19:15	19:20	0:05	MAIN SUPPLY FAILURE
295	3/May/2022	GULBARGA	110	MYLAR-RANIBENNUR	MYLAR_110	21:35	21:40	0:05	MAIN SUPPLY FAILURE
296	3/May/2022	GULBARGA	66	HV1	TELAGI_66	18:05	18:45	0:40	LINE CLEAR AVAILED
297	3/May/2022	GULBARGA	66	HALVAGALU-HARVI	HARVI_66	3:50	3:55	0:05	LINE FAULT
298	3/May/2022	GULBARGA	66	MUNIRABAD-MHDLIN	VENKATAPUR_66,UPANAYAKANAHALLI_66,HAGARIBOMMANAHALLI_66,RR STEELS_IPP	12:35	15:35	3:00	LINE FAULT
299	3/May/2022	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66,UCHCHANGIDURGA_66	19:05	19:35	0:30	LINE FAULT
300	4/May/2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
301	4/May/2022	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	3:53	4:18	0:25	LINE FAULT
302	4/May/2022	GULBARGA	220	RAICHUR-JURLA LINE1	RAICHUR_220	4:55	5:50	0:55	LINE FAULT
303	4/May/2022	GULBARGA	220	LINGAPUR-GANGAVATHI2	LINGAPUR_220	8:37	13:53	5:16	LINE CLEAR AVAILED
304	4/May/2022	GULBARGA	220	LINGASUGUR-SHAHAPUR2	SHAHAPUR_220	3:54	4:23	0:29	LINE FAULT
305	4/May/2022	GULBARGA	220	NEELGUNDA-GUTTUR	NEELGUNDA_220	12:44	13:38	0:54	LINE FAULT
306	4/May/2022	GULBARGA	220	SEDAM-HUMNABAD	HUMNABAD_220	17:05	17:45	0:40	LINE FAULT
307	4/May/2022	GULBARGA	220	ITTAGI-NEELGUNDA	NEELGUNDA_220	12:43	13:38	0:55	LINE FAULT
308	4/May/2022	GULBARGA	110	HUMNABAD-HUMNABAD_2	HUMNABAD_110	15:06(26/04/2022)			LINE OPEN:LINE CLEAR AVAILED
309	4/May/2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
310	4/May/2022	GULBARGA	110	HV2	NIRNA	0:55	1:10	0:15	TRANSFORMER FAULT
311	4/May/2022	GULBARGA	110	HV2	NIRNA	4:55	5:20	0:25	TRANSFORMER FAULT
312	4/May/2022	GULBARGA	110	HV1	CHOWDAPUR_110	10:50	10:55	0:05	TRANSFORMER FAULT
313	4/May/2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	1:50	1:57	0:07	LINE FAULT
314	4/May/2022	GULBARGA	110	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110,,VALAKAMADINNI_110,	5:05	5:15	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
315	4/May/2022	GULBARGA	110	KUSTAGI-KANAKGIRI	GANDAL_110	3:55	4:05	0:10	LINE FAULT
316	4/May/2022	GULBARGA	110	LINGASUGUR-KPRL	CHAYADEVI_IPP,KHAREPOWER_IPP	3:54	4:17	0:23	LINE FAULT
317	4/May/2022	GULBARGA	110	HALAWARTHI-DONI2	HALAWARTHI_220	20:59(04.05.2022)	9:56(05.05.2022)	12:57HRS	LINE CHARGED
318	4/May/2022	GULBARGA	110	HALBARGA-HUMNABAD	HUMNABAD_110	0:39	0:50	0:11	LINE FAULT
319	4/May/2022	GULBARGA	110	HALBARGA-HUMNABAD	HUMNABAD_110	17:41	18:02	0:21	LINE FAULT
320	4/May/2022	GULBARGA	110	GHATTARGA-AFZALPUR	AFZALPUR_110	5:04	5:07	0:03	LINE FAULT
321	4/May/2022	GULBARGA	66	HV3	HALVAGALU_66	11:10	11:40	0:30	LINE CLEAR AVAILED
322	4/May/2022	GULBARGA	66	PUNABGHATA-NEELAGUNA	PUNABGHATA_66,UCHCHANGIDURGA_66	6:00	6:10	0:10	LINE FAULT
323	4/May/2022	GULBARGA	66	MUNIRABAD-TIE LINE_IPP	MUNIRABD_220	12:15	14:39	2:24	LINE CLEAR AVAILED
324	4/May/2022	GULBARGA	66	KUDLIGI-BANVIKAL	BANVIKAL_66	21:05	21:45	0:40	LINE CLEAR AVAILED
325	5/May/2022	GULBARGA	400	RTPS-BTPS	RTPS_400	11:41	15:50	4:09	LINE FAULT
326	5/May/2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFOMER OPEN:TRANSFORMER FAULT
327	5/May/2022	GULBARGA	220	HV2	KUSATGI_220	15:38	16:02	0:24	TRANSFORMER FAULT
328	5/May/2022	GULBARGA	220	HV1 & HV2	NEELGUNDA_220	15:49	17:08	1:19	LINE CLEAR AVAILED
329	5/May/2022	GULBARGA	220	KUSTAGI-SULEKAL	KUSATGI_220	15:35	15:53	0:18	LINE FAULT
330	5/May/2022	GULBARGA	220	NEELGUNDA-GUTTUR	NEELGUNDA_220	13:12	13:59	0:47	HAND TRIPPED
331	5/May/2022	GULBARGA	220	HUMNABAD-SEDAM 2	HUMNABAD_220	9:48	10:15	0:27	LINE FAULT
332	5/May/2022	GULBARGA	220	HUMNABAD-KAPNOOR 2	HUMNABAD_220	9:48	10:18	0:30	LINE FAULT
333	5/May/2022	GULBARGA	220	HUMNABAD-HALBARGA 2	HUMNABAD_220	9:48	10:20	0:32	LINE FAULT
334	5/May/2022	GULBARGA	110	HUMNABAD-HUMNABAD_2	HUMNABAD_110	15:06(26/04/2022)			LINE OPEN:LINE CLEAR AVAILED
335	5/May/2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
336	5/May/2022	GULBARGA	110	HV1	SHAHAPUR_220	1:45	2:25	0:40	TRANSFORMER FAULT
337	5/May/2022	GULBARGA	110	HV2	SIRIGERICORSS_110	15:09	15:18	0:09	TRANSFORMER FAULT
338	5/May/2022	GULBARGA	110	HV2	SHAHAPUR_220	18:37	18:52	0:15	TRANSFORMER FAULT
339	5/May/2022	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	21:02	21:08	0:06	LINE FAULT
340	5/May/2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	11:22	13:30	2:08	LINE CLEAR AVAILED
341	5/May/2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	22:06	22:14	0:08	LINE FAULT
342	5/May/2022	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	18:02	18:03	0:01	LINE FAULT
343	5/May/2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	3:50	3:57	0:07	LINE FAULT
344	5/May/2022	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	5:26	5:42	0:16	LINE FAULT
345	5/May/2022	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	6:50	6:58	0:08	LINE FAULT
346	5/May/2022	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	4:40	4:50	0:10	MAIN SUPPLY FAILURE
347	5/May/2022	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	20:15	20:20	0:05	MAIN SUPPLY FAILURE
348	5/May/2022	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	20:40	20:50	0:10	MAIN SUPPLY FAILURE
349	5/May/2022	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	15:14	15:25	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
350	5/May/2022	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	15:14	15:25	0:11	LINE FAULT
351	5/May/2022	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGURS_IPP,ASKI_IPP,HUNSAGI_110	20:09	20:16	0:07	LINE FAULT
352	5/May/2022	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGURS_IPP,ASKI_IPP,HUNSAGI_110	20:36	20:47	0:11	LINE FAULT
353	5/May/2022	GULBARGA	110	KUSTAGI-SULEKAL	VAJRABANDI_110,YELBURGA_110,KUKN OOR_110	15:38	16:20	0:42	LINE FAULT
354	5/May/2022	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	18:50	19:03	0:13	LINE FAULT
355	5/May/2022	GULBARGA	66	ITTAGI-HAGRIBOMMANHALLI	HB HALLI_66,UP HALLI_66	6:33	6:44	0:11	LINE FAULT
356	3-May-2022	MYSURU	66	HV2	BETTADHAPURA_66	14:10	15:31	1:21	LINE CLEAR AVAILED
357	3-May-2022	MYSURU	66	KUNTHUR-DR PETE	MUGUR_66 JANNUR_66 TNARASIPURA_66THAYUR_66	1:14	1:20	0:05	LINE FAULT
358	3-May-2022	MYSURU	66	KUNTHUR-DR PETE	MUGUR_66 JANNUR_66 TNARASIPURA_66THAYUR_66	22:35	22:40	0:05	LINE FAULT
359	3-May-2022	MYSURU	66	MANDYA-KK HALLI	NO STATIONS EFFECTED	16:24	17:09	0:44	LINE CLEAR AVAILED
360	3-May-2022	MYSURU	66	HV2	METAGALLY_66	20:50	21:53	1:03	TRANSFORMER FAULT
361	3-May-2022	MYSURU	66	HOOTGALLY-RBI	NO STATIONS EFFECTED	9:04	14:43	5:39	LINE CLEAR AVAILED
362	3-May-2022	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	11:17	11:34	0:17	LINE FAULT
363	3-May-2022	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	11:43	12:17	0:34	LINE FAULT
364	3-May-2022	MYSURU	66	HEBBANI-SHIMSA	NO STATIONS EFFECTED	21:27	21:36	0:09	LINE FAULT
365	3-May-2022	MYSURU	66	KUSHALNAGARA-PERIYAPATNA1	PERIYAPATNA_66, PONNAMPET_66, VIRAJPET_66, HANAGODU_66 KAMPALAPURA_66	22:33	22:45	0:12	LINE FAULT
366	3-May-2022	MYSURU	66	KUSHALNAGARA-PERIYAPATNA2	BYLUKUPPE_66	22:33	22:45	0:12	LINE FAULT
367	3-May-2022	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	0:05	0:09	0:04	LINE FAULT
368	3-May-2022	MYSURU	66	MADHUVANAHALLI- LOKKANAHALLI	PG PALYA_66LOKKANAHALLI_66	22:38	22:45	0:07	LINE FAULT
369	3-May-2022	MYSURU	66	KADAKOLA-SARAGUR 1	JAIPUR_66HAMPAPURA(K)_66	10:03	10:08	0:05	LINE FAULT
370	3-May-2022	MYSURU	66	KADAKOLAMYSORE SOUTH	MYSORESOUTH_66	20:41	20:47	0:06	LINE FAULT
371	3-May-2022	MYSURU	66	KADAKOLADEV NANJANGUD	DEVANOORNGUDU_66SUTTUR_66	21:04	21:10	0:05	LINE FAULT
372	3-May-2022	MYSURU	66	KADAKOLA-NANJANGUDU 1	NO STATIONS EFFECTED	21:35	21:46	0:11	LINE FAULT
373	3-May-2022	MYSURU	66	KADAKOLA-THANDYA	THANDYA_66	21:35	21:46	0:11	LINE FAULT
374	3-May-2022	MYSURU	66	KADAKOLA-SARGUR2	DOORA_66HULLAHALLI_66HURA_66	21:35	21:48	0:12	LINE FAULT
375	3-May-2022	MYSURU	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66BANANGADI_66BELA GOLA_66	20:55	21:15	0:20	LINE FAULT
376	3-May-2022	MYSURU	66	TUBINKERE-ARAKERE	TARIPURA_66 GAMANAHALLY_66 ARAKERE_66	22:58	23:15	0:17	LINE FAULT
377	3-May-2022	MYSURU	66	SFC -PGL	NO STATIONS EFFECTED	21:28	21:31	0:03	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
378	3-May-2022	MYSURU	66	KM DODDI-MANDYA	KKDODDI_66 KIADBMANDYA_66 SOMANAHALLI_66 TUMBEKERE _66MADDUR_66	21:15:10 (3/5/2022)			LINE OPEN:LINE FAULT
379	3-May-2022	MYSURU	66	KADAKOLAMYSORE SOUTH	MYSORESOUTH_66	20:47:00 (3/5/2022)			LINE OPEN:LINE FAULT
380	3-May-2022	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/5/2022)			LINE OPEN:LINE CLEAR AVAILED
381	3-May-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22.04.2022)			LINE OPEN:LINE CLEAR AVAILED
382	3-May-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00(8/12/2021)			LINE OPEN:LINE CLEAR AVAILED
383	3-May-2022	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN:LINE CLEAR AVAILED
384	3-May-2022	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN:LINE CLEAR AVAILED
385	3-May-2022	MYSURU	66	MYSORE SOUTH -KADAKOLA	NO STATIONS EFFECTED	21:21:12 (3/5/2022)			LINE OPEN:LINE CLEAR AVAILED
386	3-May-2022	MYSURU	66	PERIYAPATNA-HANGODU	PONNAMPET_66, VIRAJPET_66, HANAGODU_66	22:46:52 (3/5/2022)			LINE OPEN:LINE FAULT
387	4-May-2022	MYSURU	66	ADDIHALLI-BG NAGARA	ADICHUNCHANAGIRI_66 BGNAGARA_66 VADERALLI_66	18:38	18:48	0:10	LINE FAULT
388	4-May-2022	MYSURU	66	HV2	GAMANAHALLY_66	9:30	11:00	1:30	LINE CLEAR AVAILED
389	4-May-2022	MYSURU	66	G UKKADA-TUBINAKERE	GARUDANAUKADDA_66 SRIRANGAPATNA_66	19:00	19:15	0:15	LINE FAULT
390	4-May-2022	MYSURU	66	HV2	HAMPAPURA_66	11:58	12:01	0:03	TRANSFORMER FAULT
391	4-May-2022	MYSURU	66	HEBBANI-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	19:33	19:47	0:14	LINE FAULT
392	4-May-2022	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	NO STATIONS EFFECTED	11:55	12:30	0:35	LINE CLEAR AVAILED
393	4-May-2022	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57			LINE OPEN:LINE CLEAR AVAILED
394	4-May-2022	MYSURU	66	HV1	KOLLEGALA_66	11:41	13:45	2:03	LINE CLEAR AVAILED
395	4-May-2022	MYSURU	66	KUNTHUR-DR PETE	NO STATIONS EFFECTED	2:09	2:15	0:05	LINE FAULT
396	4-May-2022	MYSURU	66	PONNAMPETE-HANAGODU	PONNAMPET_66, VIRAJPET_66	0:10	16:30	16:19	LINE CLEAR AVAILED
397	4-May-2022	MYSURU	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	18:49	19:07	0:18	LINE FAULT
398	4-May-2022	MYSURU	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	19:11			LINE OPEN:LINE FAULT
399	4-May-2022	MYSURU	66	TUBINAKERE-NAGAMANGALA -1	BASARALU_66 HARADANAHALLI(JAK)_66 KESLAGERE_66	19:59	20:06	0:07	LINE FAULT
400	4-May-2022	MYSURU	66	TUBINAKERE-NAGAMANGALA -2	SHIVALLY_66	19:59	20:06	0:07	LINE FAULT
401	4-May-2022	MYSURU	66	KM DODDI-MANDYA	KKDODDI_66 KIADBMANDYA_66 SOMANAHALLI_66 TUMBEKERE _66MADDUR_66	21:15:10 (03/05/2022)	17:09	19:54 Hrs	LINE FAULT
402	4-May-2022	MYSURU	66	KADAKOLA_MYSORE SOUTH	MYSORESOUTH_66	20:47:00 (03/05/2022)	10:38	13:51 Hrs	LINE FAULT
403	4-May-2022	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
404	4-May-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
405	4-May-2022	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
406	4-May-2022	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
407	4-May-2022	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
408	4-May-2022	MYSURU	66	MYSORE SOUTH -KADAKOLA	NO STATIONS EFFECTED	21:21:12 (03/05/2022)	10:41	13:20 HRs	HAND TRIPPED
409	4-May-2022	MYSURU	66	PERIYAPATNA-HANGODU	PONNAMPET_66, VIRAJPET_66, HANAGODU_66	22:46:52 (03/05/2022)	16:27	17:40 HRs	LINE FAULT
410	5-May-2022	MYSURU	66	BG NAGARA-VADERALLI	ADICHUNCHANAGIRI_66VADERALLI_66	15:42	15:49	0:06	LINE FAULT
411	5-May-2022	MYSURU	66	BEGUR-B MATGERE	NO STATIONS EFFECTED	12:50	13:07	0:17	LINE FAULT
412	5-May-2022	MYSURU	66	HV1	CHUNCHUNKATTE_66	10:30	10:34	0:04	HAND TRIPPED
413	5-May-2022	MYSURU	66	HV2	HAMPAPURA_66	15:49	15:59	0:10	TRANSFORMER FAULT
414	5-May-2022	MYSURU	66	HANNUR-AMP SOLAR	NO STATIONS EFFECTED	17:30	18:13	0:43	LINE FAULT
415	5-May-2022	MYSURU	66	HV1	KHBCOLONY_66	11:05	13:20	2:15	LINE CLEAR AVAILED
416	5-May-2022	MYSURU	66	KR PETE 22-KRPETE 1	KRPET_66KIKKERI_66AKKIHEBBAL_66	15:59	16:07	0:07	LINE FAULT
417	5-May-2022	MYSURU	66	KR PETE 22-KRPETE 2	NO STATIONS EFFECTED	15:59	16:07	0:08	LINE FAULT
418	5-May-2022	MYSURU	66	KUNTHUR-DODDRAIPET	JANNUR_66MUGUR_66THAYUR_66TNAR ASIPURA_66	21:14	21:21	0:06	LINE FAULT
419	5-May-2022	MYSURU	66	HV1	MALAVALLI_66	12:43	12:49	0:06	MAIN SUPPLY FAILURE
420	5-May-2022	MYSURU	66	HV2	MEGALAPURA_66	15:51	16:54	1:02	LINE CLEAR AVAILED
421	5-May-2022	MYSURU	66	HV1	MEGALAPURA_66	15:20	15:45	0:25	LINE CLEAR AVAILED
422	5-May-2022	MYSURU	66	SFC SIVA-10MW	SFCSHIVA_66	5:40	5:51	0:11	LINE FAULT
423	5-May-2022	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66TARIPURA_66GAMANAHALL Y_66	11:35	12:44	1:09	LINE CLEAR AVAILED
424	5-May-2022	MYSURU	66	HEBBANIVADKEPURA	MALIYURU_66KIRUGAVALU_66VADKEPU RA_66	5:45	5:56	0:11	LINE FAULT
425	5-May-2022	MYSURU	66	KADAKOLAVAJMANGALA 2	NO STATIONS EFFECTED	11:00	12:05	1:05	LINE CLEAR AVAILED
426	5-May-2022	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57:05 (4/5/2022)			LINE OPEN:LINE CLEAR AVAILED
427	5-May-2022	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
428	5-May-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
429	5-May-2022	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
430	5-May-2022	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
431	5-May-2022	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
432	3-May-2022	TUMKUR	110	BILCHODU-PALLAGATTE	PALLAGATTE_66	19:00	19:40	0:40	MAIN SUPPLY FAILURE
433	3-May-2022	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 1_IPP_66	17:41	18:53	1:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
434	3-May-2022	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	4:00	4:07	0:07	LINE FAULT
435	4-May-2022	TUMKUR	220	ANTHRASANAHALI 220kV- SHIMOGA	ANTHRASANAHALI_220	18:08	18:38	0:30	LINE FAULT
436	4-May-2022	TUMKUR	220	TR-1(HV SIDE)	CHITRADURGA_220	8:38	13:11	4:33	LINE CLEAR AVAILED
437	4-May-2022	TUMKUR	220	TR-2(HV SIDE)	CHITRADURGA_220	13:14	16:39	3:25	LINE CLEAR AVAILED
438	4-May-2022	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	17:03	17:35	0:32	MAIN SUPPLY FAILURE
439	4-May-2022	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	13:56	14:24	0:28	LINE FAULT
440	4-May-2022	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	12:41	13:32	0:51	LINE FAULT
441	4-May-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	8:29	8:38	0:09	LINE FAULT
442	4-May-2022	TUMKUR	66	HIRIYUR220-MATHOD 2	MATHOD_66,HINDASGHATTA_66,KANCHIPURA_66,GARAGA_66,PANCHANAHALLI_66,HOSADURGA_66	17:26	17:40	0:14	LINE FAULT
443	4-May-2022	TUMKUR	66	THALLAK 220-PR PURA	THALLAK_220	14:23	14:27	0:04	LINE FAULT
444	4-May-2022	TUMKUR	66	THALLAK 220kV- SEI VENUS _IPP_66	SEI VENUS _IPP_66	18:20	21:48	3:28	LINE CLEAR AVAILED
445	4-May-2022	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR _IPP_66	SEI DIAMOND SOLAR _IPP_66	18:32	21:43	3:11	LINE CLEAR AVAILED
446	5-May-2022	TUMKUR	220	TR-2(HV SIDE)	ANCHEPALYA_220	6:43	8:25	1:42	LINE CLEAR AVAILED
447	5-May-2022	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	15:09	15:42	0:33	LINE FAULT
448	5-May-2022	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	14:52	15:47	0:55	LINE FAULT
449	5-May-2022	TUMKUR	66	ANTHRASANAHALI 220KV- KORA	KORA_66, THOVINAKERE_66	14:58	15:16	0:18	LINE FAULT
450	5-May-2022	TUMKUR	66	ANTHRASANAHALI 220KV- BELLAVI66	BELLAVI_66	15:06	15:46	0:40	LINE FAULT
451	5-May-2022	TUMKUR	66	TR-1	ANTHRASANAHALI_220	15:15	16:28	1:13	TRANSFORMER FAULT
452	5-May-2022	TUMKUR	66	CHITRADURGA 220kV- CHITRADURGA 1	CHITRADURGA_220	15:05	15:20	0:15	LINE FAULT
453	5-May-2022	TUMKUR	66	CHITRADURGA 220kV- CHITRADURGA2	CHITRADURGA_220	15:05	16:18	1:13	LINE FAULT
454	5-May-2022	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 4	CHITRADURGA_66	15:05	17:27	2:22	LINE FAULT
455	5-May-2022	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 4	CHITRADURGA_66	17:27	18:48	1:21	LINE FAULT
456	5-May-2022	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	12:46	12:56	0:10	LINE FAULT
457	5-May-2022	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	2:10	2:23	0:13	LINE FAULT
458	3-May-2022	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
459	3-May-2022	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
460	3-May-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
461	3-May-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
462	3-May-2022	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFOMER OPEN:TRANSFORMER FAULT
463	3-May-2022	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	14:25(30.05.202)			LINE OPEN:LINE CLEAR AVAILED
464	3-May-2022	HASSAN	220	MRSSMG-SHARAVATHY3	MRSMG_220	22:57(03.05.2022)			LINE OPEN:LINE FAULT
465	3-May-2022	HASSAN	220	SHRAVTY-SHIMOGA3	gen_sharavthy	22:57(03.05.2022)			LINE OPEN:LINE FAULT
466	3-May-2022	HASSAN	66	HV	CHIKABOMMENAHALLI_66	17:30(03.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
467	3-May-2022	HASSAN	110	HV2	BAIKAMPADI_110	11:00(03.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
468	3-May-2022	HASSAN	110	HV1	MRSMG_220	15:55	17:43	1:48	TRANSFORMER FAULT
469	3-May-2022	HASSAN	220	KEMAR-Varahi1	KEMAR_220	11:47	18:48	7:01	LINE FAULT
470	3-May-2022	HASSAN	220	VARAHI-KEMAR1	gen_varahi	11:47	18:49	7:02	LINE FAULT
471	3-May-2022	HASSAN	110	KAVOOR-AMR	KAVOOR_220	3:10	6:45	3:35	LINE FAULT
472	3-May-2022	HASSAN	66	HV1	SAKALESHPURA_66	9:05	18:30	9:25	LINE CLEAR AVAILED
473	3-May-2022	HASSAN	66	HV2	SAKALESHPURA_66	10:55	11:15	0:20	TRANSFORMER FAULT
474	3-May-2022	HASSAN	66	HV2	SAKALESHPURA_66	15:10	15:20	0:10	HAND TRIPPED
475	3-May-2022	HASSAN	66	SALAGAM-AGRA	SALAGAME_66	11:00	12:10	1:10	LINE CLEAR AVAILED
476	4-May-2022	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	22:57(03.05.2022)	13:40(04.05.2022)	14:42 hrs	LINE CHARGED
477	4-May-2022	HASSAN	220	SHRAVTY-SHIMOGA3	gen_sharavthy	22:57(03.05.2022)	13:40(04.05.2022)	14:42 hrs	LINE CHARGED
478	4-May-2022	HASSAN	110	HV2	BAIKAMPADI_110	11:00(03.05.2022)	15:25(04.05.2022)	28:24 hrs	TRANSFORMER CHARGED
479	4-May-2022	HASSAN	66	HV	CHIKABOMMENAHALLI_66	17:30(03.04.2022)	15:40(4.05.2022)	22:09 hrs	TRANSFORMER CHARGED
480	4-May-2022	HASSAN	66	RAMNATHPURA_66	RAMNAT-KATTEPURA_MINIH	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
481	4-May-2022	HASSAN	110	mghejog_gen	JOG-NK2	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
482	4-May-2022	HASSAN	400	TALAGUPPA_400	TALAGU-NELAMANGALA#2	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
483	4-May-2022	HASSAN	110	JOG_110	HV3	10:55(05.04.2022)			LINE OPEN:LINE CLEAR AVAILED
484	4-May-2022	HASSAN	220	KAVOOR_220	HV3	19:55(30.05.2022)			LINE OPEN:LINE FAULT
485	4-May-2022	HASSAN	66	RAMNATHPURA_66	RAMNAT-BNDSTHL	14:25(30.05.202)			LINE OPEN:LINE CLEAR AVAILED
486	4-May-2022	HASSAN	110	HV1	SHIVAPURA_110	20:55(04.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
487	4-May-2022	HASSAN	110	ARSK2-GERUMARA	ARSIKERE_220	18:32	19:57	1:25	LINE FAULT
488	4-May-2022	HASSAN	220	KADUR-DABUSET	KADUR_220	18:44	19:36	0:52	LINE FAULT
489	4-May-2022	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	10:41	11:40	0:59	LINE CLEAR AVAILED
490	4-May-2022	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	12:34	13:32	0:58	LINE CLEAR AVAILED
491	4-May-2022	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	16:30	16:51	0:21	LINE FAULT
492	4-May-2022	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	16:29	17:02	0:33	LINE FAULT
493	4-May-2022	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	16:29	17:02	0:33	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
494	4-May-2022	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	18:10	18:38	0:28	LINE FAULT
495	4-May-2022	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	18:25	18:51	0:26	LINE FAULT
496	4-May-2022	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	17:03	17:35	0:32	LINE FAULT
497	4-May-2022	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	12:31	13:32	1:01	LINE CLEAR AVAILED
498	4-May-2022	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	12:10	13:25	1:15	LINE FAULT
499	4-May-2022	HASSAN	110	HV2	BAIKAMPADI_110	14:22	14:38	0:16	LINE CLEAR AVAILED
500	4-May-2022	HASSAN	110	HV3	BAIKAMPADI_110	10:30	15:30	5:00	LINE CLEAR AVAILED
501	4-May-2022	HASSAN	110	GURUPUR-MDBDRE	GURUPURA_110	16:29	16:45	0:16	MAIN SUPPLY FAILURE
502	4-May-2022	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	16:29	17:02	0:33	LINE FAULT
503	4-May-2022	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	16:29	17:02	0:33	LINE FAULT
504	4-May-2022	HASSAN	110	KARAYA-PUTTUR	KARAYA_110	14:45	15:32	0:47	MAIN SUPPLY FAILURE
505	4-May-2022	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	14:44	14:53	0:09	MAIN SUPPLY FAILURE
506	4-May-2022	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	16:30	16:36	0:06	MAIN SUPPLY FAILURE
507	4-May-2022	HASSAN	110	HV4	KAVOOR_220	3:09	3:19	0:10	MAIN SUPPLY FAILURE
508	4-May-2022	HASSAN	110	KAVOOR-AMR	KAVOOR_220	16:30	16:36	0:06	MAIN SUPPLY FAILURE
509	4-May-2022	HASSAN	110	KITTADA-BLGAVE	KITTADAHALLI_110	19:40	20:30	0:50	MAIN SUPPLY FAILURE
510	4-May-2022	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	16:28	16:50	0:22	LINE FAULT
511	4-May-2022	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	19:38	20:28	0:50	LINE CLEAR AVAILED
512	4-May-2022	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	17:54	18:20	0:26	LINE FAULT
513	4-May-2022	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	18:21	20:27	2:06	LINE FAULT
514	4-May-2022	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:04	12:08	2:04	LINE CLEAR AVAILED
515	4-May-2022	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:04	12:08	2:04	LINE CLEAR AVAILED
516	4-May-2022	HASSAN	66	BELUR66- HASSAN	BELUR_66	17:30	18:30	1:00	MAIN SUPPLY FAILURE
517	4-May-2022	HASSAN	66	BELUR66-HASSAN	BELUR_66	22:45	22:50	0:05	MAIN SUPPLY FAILURE
518	4-May-2022	HASSAN	66	HV1	BELUR_66	17:30	18:30	1:00	MAIN SUPPLY FAILURE
519	4-May-2022	HASSAN	66	HV2	BELUR_66	17:30	18:30	1:00	MAIN SUPPLY FAILURE
520	4-May-2022	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	17:30	18:30	1:00	MAIN SUPPLY FAILURE
521	4-May-2022	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	18:30	22:40	4:10	LINE FAULT
522	4-May-2022	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	22:50	22:55	0:05	MAIN SUPPLY FAILURE
523	4-May-2022	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	22:45	22:50	0:05	LINE FAULT
524	4-May-2022	HASSAN	66	GENDEHA-BELUR	GENDEHALLI_66	17:40	22:45	5:05	MAIN SUPPLY FAILURE
525	4-May-2022	HASSAN	66	HV1	MALLIPATNA-66	18:20	18:30	0:10	TRANSFORMER FAULT
526	4-May-2022	HASSAN	66	HV1	MOSALEHOSAHALL_66	19:50	20:40	0:50	MAIN SUPPLY FAILURE
527	4-May-2022	HASSAN	66	HV1	SAKALESH PURA_66	9:10	17:50	8:40	LINE CLEAR AVAILED
528	4-May-2022	HASSAN	66	SAKALE-IPCL2	SAKALESH PURA_66	14:15	14:25	0:10	LINE FAULT
529	4-May-2022	HASSAN	66	HV1	SIGEBAGE_66	8:50	8:55	0:05	HAND TRIPPED
530	5-May-2022	HASSAN	66	RAMNATH PURA_66	RAMNAT-BNDSTHL	14:25(30.05.202)	3:00 (5.05.2022)	108:34 hrs	LINE CHARGED
531	5-May-2022	HASSAN	110	HV1	110kV	20:55(04.05.2022)	00:12(05.05.2022)	3:16 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
532	5-May-2022	HASSAN	66	RAMNATHPURA_66	RAMNAT-KATTEPURA_MINIH	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
533	5-May-2022	HASSAN	110	mghejog_gen	JOG-NK2	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
534	5-May-2022	HASSAN	400	TALAGUPPA_400	TALAGU-NELAMANGALA#2	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
535	5-May-2022	HASSAN	110	JOG_110	HV3	10:55(05.04.2022)			LINE OPEN:LINE CLEAR AVAILED
536	5-May-2022	HASSAN	220	KAVOOR_220	HV3	19:55(30.05.2022)			LINE OPEN:LINE FAULT
537	5-May-2022	HASSAN	110	LPH-MGHE 2	lph_gen	13:55 (05.05.2022)			LINE OPEN:LINE FAULT
538	5-May-2022	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	16:40(05.05.2022)			LINE OPEN:LINE FAULT
539	5-May-2022	HASSAN	220	HV2	MSEZ_220	15:09 (5.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
540	5-May-2022	HASSAN	110	LV2	MSEZ_220	15:09 (5.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
541	5-May-2022	HASSAN	110	mghejog_gen	JOG-JLT4	1:55 (5.05.2022)			LINE OPEN:LINE FAULT
542	5-May-2022	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	7:11	7:52	0:41	LINE FAULT
543	5-May-2022	HASSAN	110	GURURVA-KEMAR1	GURUVAYANKERE_110	12:06	13:30	1:24	NFBC ISSUED
544	5-May-2022	HASSAN	110	KAVOOR-AMR	KAVOOR_220	9:18	9:20	0:02	MAIN SUPPLY FAILURE
545	5-May-2022	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	9:18	9:20	0:02	MAIN SUPPLY FAILURE
546	5-May-2022	HASSAN	110	HV	KITTADAHALLI_66	19:30	20:30	1:00	TRANSFORMER FAULT
547	5-May-2022	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	9:15	9:20	0:05	LINE FAULT
548	5-May-2022	HASSAN	110	HV 5	PUTTUR_220	3:50	4:26	0:36	TRANSFORMER FAULT
549	5-May-2022	HASSAN	110	GURUPUR-MDBDRE	GURUPURA_110	19:15	19:20	0:05	MAIN SUPPLY FAILURE
550	5-May-2022	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	6:00	6:10	0:10	MAIN SUPPLY FAILURE
551	5-May-2022	HASSAN	66	BHADRA-LINGADAHALLI	gen_bhadra	0:10	8:00	7:50	LINE FAULT
552	5-May-2022	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	12:30	12:40	0:10	LINE FAULT
553	5-May-2022	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	12:30	12:40	0:10	LINE FAULT
554	5-May-2022	HASSAN	66	GENDEHA-MARVATHI	GENDEHALLI_66	1:35	2:10	0:35	LINE CLEAR AVAILED
555	5-May-2022	HASSAN	66	GENDEHA-BELUR	GENDEHALLI_66	6:00	6:15	0:15	MAIN SUPPLY FAILURE
556	5-May-2022	HASSAN	66	HV1	HALEBEEDU_66	12:53	13:51	0:58	LINE CLEAR AVAILED
557	5-May-2022	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	14:49	15:55	1:06	LINE CLEAR AVAILED
558	5-May-2022	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	9:55	10:00	0:05	LOAD CHANGEOVER
559	5-May-2022	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	15:13	15:20	0:07	LOAD CHANGEOVER
560	5-May-2022	HASSAN	66	HV2	RAMNATHPURA_66	14:49	15:09	0:20	HAND TRIPPED
561	5-May-2022	HASSAN	66	HV1	RAMNATHPURA_66	14:49	15:09	0:20	HAND TRIPPED
562	5-May-2022	HASSAN	66	HV1	SAKALESHPURA_66	9:10	18:40	9:30	LINE CLEAR AVAILED
563	5-May-2022	HASSAN	66	HV2	SAKALESHPURA_66	10:55	11:15	0:20	TRANSFORMER FAULT
564	5-May-2022	HASSAN	66	HV2	SAKALESHPURA_66	9:10	9:30	0:20	HAND TRIPPED
565	5-May-2022	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	11:35	17:45	6:10	LINE CLEAR AVAILED
566	5-May-2022	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	11:35	17:45	6:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
567	5-May-2022	HASSAN	66	IDLE	TAVARECHATNAHALLI_66	2:15	2:20	0:05	LINE FAULT
568	5-May-2022	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	12:30	12:35	0:05	MAIN SUPPLY FAILURE
569	5-May-2022	HASSAN	66	HV2	UDAYAPURA_66	12:00	12:10	0:10	HAND TRIPPED
570	5-May-2022	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	12:25	12:55	0:30	LINE CLEAR AVAILED
571	5-May-2022	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	12:30	12:35	0:05	MAIN SUPPLY FAILURE
572	5-May-2022	HASSAN	220	ARSK2-SHMG	ARSIKERE_220	17:30	17:44	0:14	LINE FAULT
573	5-May-2022	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	7:11	7:52	0:41	LINE FAULT
574	5-May-2022	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	12:06	13:30	1:24	LINE CLEAR AVAILED
575	5-May-2022	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	9:52	13:39	3:47	NFBC ISSUED
576	5-May-2022	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	20:19	21:42	1:23	LINE FAULT
577	5-May-2022	HASSAN	220	MRSSHM-VARAH3	MRSMSG_220	2:26	11:21	8:55	LINE FAULT
578	5-May-2022	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	9:09	11:20	2:11	NFBC ISSUED
579	5-May-2022	HASSAN	220	HV1	MSEZ_220	10:56	15:03	4:07	LINE CLEAR AVAILED
580	5-May-2022	HASSAN	110	LV1	MSEZ_220	10:56	15:03	4:07	LINE CLEAR AVAILED
581	5-May-2022	HASSAN	220	SHRAVTY-SHIMOGA3	gen_sharavthy	9:52	13:39	3:47	LINE CLEAR AVAILED
582	5-May-2022	HASSAN	220	SHRAVTY-SHIMOGA3	gen_sharavthy	20:19	21:42	1:23	LINE FAULT
583	5-May-2022	HASSAN	220	VARAH-SHMG3	gen_varahi	2:26	11:22	8:56	LINE FAULT
584	5-May-2022	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	13:10	13:15	0:05	HAND TRIPPED
585	5-May-2022	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	14:00	14:10	0:10	HAND TRIPPED
586	5-May-2022	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	2:20	2:35	0:15	LINE FAULT
587	5-May-2022	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	9:00	11:20	2:20	NFBC ISSUED
588	6-May-22	BAGALKOT	110	110/11KV, HV1	MANTUR(B)_110	13:50	14:10	0:20	HAND TRIPPED
589	6-May-22	BAGALKOT	110	110/11KV, HV1	NARAGUND_110	12:35	12:45	0:10	MAIN SUPPLY FAILURE
590	6-May-22	BAGALKOT	110	110/11KV, HV2	MANTUR(B)_110	13:10	13:45	0:35	HAND TRIPPED
591	6-May-22	BAGALKOT	110	110/11KV,HV1	BABALESHWAR_110	13:25	14:31	1:06	LINE CLEAR AVAILED
592	6-May-22	BAGALKOT	110	110/11KV,HV1	GANDIGWADA_33,ACME SOLAR_33 MK HUBLI_110	16:21	16:36	0:15	TRANSFORMER FAULT
593	6-May-22	BAGALKOT	110	110/11KV,HV1	MAMADAPUR(B)_110	16:23	19:02	2:39	LINE CLEAR AVAILED
594	6-May-22	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	15:02	17:46	2:44	LINE CLEAR AVAILED
595	6-May-22	BAGALKOT	110	110/11KV,HV2	BABALESHWAR_110	7:27	8:19	0:52	HAND TRIPPED
596	6-May-22	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	16:47	17:15	0:28	LINE CLEAR AVAILED
597	6-May-22	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	8:57	9:10	0:13	TRANSFORMER FAULT
598	6-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFOMER OPEN:TRANSFORMER FAULT
599	6-May-22	BAGALKOT	110	110/33KV,HV2	HULGUR_33 SAVANUR_110	12:35	15:28	2:53	LINE CLEAR AVAILED
600	6-May-22	BAGALKOT	110	110/33KV,HV3	KALKERI_33,GOLAGERI_33,HALKI_33 SINDAGI_110 SINDAGI_110	10:10	10:29	0:19	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
601	6-May-22	BAGALKOT	110	110/33KV,HV3	KALKERI_33,GOLAGERI_33,HALKI_33 SINDAGI_110 SINDAGI_110	14:14	14:23	0:09	TRANSFORMER FAULT
602	6-May-22	BAGALKOT	110	220/110KV, LV1	KARWAR_220	16:26	16:54	0:28	HAND TRIPPED
603	6-May-22	BAGALKOT	110	BAGEWADI- MAMADAPUR1	MAMADAPUR(B)_110	10:20	10:37	0:17	MAIN SUPPLY FAILURE
604	6-May-22	BAGALKOT	110	BAGEWADI- MAMADAPUR2	MAMADAPUR(B)_110	10:20	10:37	0:17	MAIN SUPPLY FAILURE
605	6-May-22	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR(B)_110	10:20	10:37	0:17	LINE FAULT
606	6-May-22	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	5:34	6:02	0:28	HAND TRIPPED
607	6-May-22	BAGALKOT	110	BELLATTI-ENERCON2	BELLATTI_110	5:34	6:03	0:29	HAND TRIPPED
608	6-May-22	BAGALKOT	110	BIDNAL-ANNIGERI	NAVALGUND_110 (STATION NOT AFFECTED)	17:13 (05.05.2022)	8:34 (06.05.2022)	15:21	LINE CHARGED
609	6-May-22	BAGALKOT	110	BIDNAL-NAVALGUND	BIDNAL_220	17:38 (05.05.2022)	8:35 (06.05.2022)	14:57	LINE CHARGED
610	6-May-22	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110 (STATION NOT AFFECTED)	17:03 (05.05.2022)	12:54 (06.05.2022)	19:51	LINE CHARGED
611	6-May-22	BAGALKOT	110	GADAG220- BETAGERI(ROn)	STATION NOT AFFECTED GADAG_220	21:10 (04.05.2022)			LINE OPEN:LINE FAULT
612	6-May-22	BAGALKOT	110	HALIYAL-GMR	HALIYAL_110	11:47	11:50	0:03	LINE FAULT
613	6-May-22	BAGALKOT	110	KARWAR220- SOLARIS(BINAGA)	KARWAR_220	16:27	16:55	0:28	HAND TRIPPED
614	6-May-22	BAGALKOT	110	LAXMESHVAR-BELLATTI	BELLATTI_110	5:10	5:56	0:46	LINE FAULT
615	6-May-22	BAGALKOT	110	MAMADAPUR-BABALESHWAR	BABALESHWAR_110	10:41	10:42	0:01	HAND TRIPPED
616	6-May-22	BAGALKOT	110	MR NAGARA-NARENDRA1	STATION NOT AFFECTED MR NAGARA_110	11:41	12:23	0:42	LINE CLEAR AVAILED
617	6-May-22	BAGALKOT	110	MR NAGAR-GOPPANAKOPPA1	MR NAGAR_110	18:05 (05.05.2022)	11:01 (06.05.2022)	16:56	LINE CHARGED
618	6-May-22	BAGALKOT	110	NARENDRA- BELUR1	STATION NOT AFFECTED NARENDRA_220	15:30	16:27	0:57	LINE CLEAR AVAILED
619	6-May-22	BAGALKOT	110	NARENDRA- BELUR2	STATION NOT AFFECTED NARENDRA_220	16:27	16:56	0:29	LINE CLEAR AVAILED
620	6-May-22	BAGALKOT	110	NARENDRA- UAS DHARWAD	STATION NOT AFFECTED NARENDRA_220	12:24	15:14	2:50	LINE CLEAR AVAILED
621	6-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
622	6-May-22	BAGALKOT	110	RANNABELAGALI- MUDHOL(UTTUR)	RANNABELAGALI_110	4:57	5:02	0:05	LINE FAULT
623	6-May-22	BAGALKOT	110	RON-GAMESH	RON_110	14:11	14:19	0:08	HAND TRIPPED
624	6-May-22	BAGALKOT	110	SAVALAGI-AIGALI	STATION NOT AFFECTED SAVALAGI_110	9:13	18:23	9:10	LINE CLEAR AVAILED
625	6-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
626	6-May-22	BAGALKOT	110	SOUDATTI- MUNAVALLY	MUNAVALLI_110	12:25	13:05	0:40	LINE CLEAR AVAILED
627	6-May-22	BAGALKOT	110	THORVI-TAKKALAKI	TAKKALAKI_110	5:30	11:00	5:30	LINE CLEAR AVAILED
628	6-May-22	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED BELGAUM_220	10:34 (24.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
629	6-May-22	BAGALKOT	220	220/110KV, LV1	STATION NOT AFFECTED VAJRAMATTI_220	6:22	7:42	1:22	LINE CLEAR AVOIDED
630	6-May-22	BAGALKOT	220	BIDNAL- HUBLI3	STATION NOT AFFECTED BIDNAL_220	12:39	16:46	4:07	LINE FAULT
631	6-May-22	BAGALKOT	220	BIDNAL-SOUDATTI	STATION NOT AFFECTED BIDNAL_220	17:20 (05.04.2022)	8:58 (06.05.2022)	15:38	LINE CHARGED
632	6-May-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVOIDED
633	6-May-22	BAGALKOT	220	HAVERI- GUTTUR2	STATION NOT AFFECTED HAVERI_220	17:29 (06.05.2022)			LINE OPEN: MAIN SUPPLY FAILURE
634	6-May-22	BAGALKOT	220	HUBLI- BIDNAL2	STATION NOT AFFECTED HUBLI_220	12:40	16:46	4:06	LINE FAULT
635	6-May-22	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTED HUBLI_220	11:06	13:58	4:16	NFBC ISSUED
636	6-May-22	BAGALKOT	220	HUBLI- SIRSI1	STATION NOT AFFECTED HUBLI_220	11:29	19:18	7:49	LINE FAULT
637	6-May-22	BAGALKOT	220	RANEBENNUR- GUTTUR	RANEBENNUR_220	12:24	18:40	6:16	NFBC ISSUED
638	6-May-22	BAGALKOT	220	RANEBENNUR- SHIRALKOPPA (BALLIGAVI)	RANEBENNUR_220	12:59	14:31	1:32	MAIN SUPPLY FAILURE
639	6-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
640	6-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
641	6-May-22	BAGALKOT	220	SOUDATTI- BIDNAL	STATION NOT AFFECTED SOUDATTI_220	17:20 (05.05.2022)	8:58 (06.05.2022)	15:38	LINE CHARGED
642	6-May-22	BENGALURU	66	AGALAKOTE - KEMPAHALI	AGALAKOTE, MATHIKERE	8:49	9:05	0:16	LINE FAULT
643	6-May-22	BENGALURU	66	CHINTAMANI 66 - SM MANGALA	SM MANGALA	5:03	5:25	0:22	LINE FAULT
644	6-May-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	18:05	18:06	0:01	LINE CLEAR AVOIDED
645	6-May-22	BENGALURU	66	HEBBALA 220 - BANASAWADI	BANASAWADI	7:05	7:15	0:10	LINE FAULT
646	6-May-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	17:13	17:45	0:31	LINE FAULT
647	6-May-22	BENGALURU	66	HV1	BANASAWADI	7:05	7:15	0:10	MAIN SUPPLY FAILURE
648	6-May-22	BENGALURU	66	HV1	BANASAWADI	10:40	10:45	0:05	LOAD CHANGE OVER
649	6-May-22	BENGALURU	66	HV1	CHELUR	19:10	19:30	0:20	LINE CLEAR AVOIDED
650	6-May-22	BENGALURU	66	HV1	CHINTAMANI 66	7:13	7:45	0:31	LINE CLEAR AVOIDED
651	6-May-22	BENGALURU	66	HV1	EPIP 220kV	8:02	8:12	0:10	TRANSFORMER FAULT
652	6-May-22	BENGALURU	66	HV1	MUDIYANUR	15:33	17:49	2:15	LINE CLEAR AVOIDED
653	6-May-22	BENGALURU	66	HV2	BANASHANKARI	13:37	13:39	0:02	LINE CLEAR AVOIDED
654	6-May-22	BENGALURU	66	HV2	GUNDAMGERE	13:00	13:05	0:04	LINE CLEAR AVOIDED
655	6-May-22	BENGALURU	66	HV2	HSR LAYOUT 220	14:53	14:55	0:02	LINE CLEAR AVOIDED
656	6-May-22	BENGALURU	66	HV2	NANDAGUDI	13:17	13:44	0:27	LINE CLEAR AVOIDED
657	6-May-22	BENGALURU	66	HV2	WELCAST STEEL	12:26	13:33	1:07	LINE CLEAR AVOIDED
658	6-May-22	BENGALURU	66	HV2	YEDUMADU	21:22	21:41	0:19	TRANSFORMER FAULT
659	6-May-22	BENGALURU	66	HV3	BANASAWADI	7:05	7:15	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
660	6-May-22	BENGALURU	66	HV3	BANASAWADI	10:40	10:45	0:05	LOAD CHANGEOVER
661	6-May-22	BENGALURU	66	KANASWADI - DB PURA 220	KANASWADI	22:00	22:05	0:05	LOAD CHANGEOVER
662	6-May-22	BENGALURU	66	Kengeri SATELLITE TOWN - KUMBALAGODU	CHANDRAPPA CIRCLE	17:27	20:05	2:38	LINE FAULT
663	6-May-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	15:03	15:11	0:07	LINE FAULT
664	6-May-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	16:49	20:23	3:34	LINE FAULT
665	6-May-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	20:23	21:05	0:42	LINE FAULT
666	6-May-22	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	16:56	17:03	0:07	MAIN SUPPLY FAILURE
667	6-May-22	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	14:40	15:04	0:24	LINE FAULT
668	6-May-22	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	16:23	16:47	0:24	MAIN SUPPLY FAILURE
669	6-May-22	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	16:23	16:49	0:26	MAIN SUPPLY FAILURE
670	6-May-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	16:23	16:48	0:25	MAIN SUPPLY FAILURE
671	6-May-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	17:17	17:41	0:23	LINE FAULT
672	6-May-22	BENGALURU	66	SOLDEVANAHALLI - SRS PEENYA 220	SOLDEVANAHALLI	7:46	7:53	0:07	LOAD CHANGEOVER
673	6-May-22	BENGALURU	66	SOLDEVANAHALLI - YELAHANKA 220	SOLDEVANAHALLI	5:56	6:20	0:24	MAIN SUPPLY FAILURE
674	6-May-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	16:55	19:58	3:03	LINE FAULT
675	6-May-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	16:55	17:03	0:08	LINE FAULT
676	6-May-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	20:16	20:24	0:08	LINE FAULT
677	6-May-22	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	20:16	20:25	0:09	LINE FAULT
678	6-May-22	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	16:21	16:46	0:25	LINE CLEAR AVAILED
679	6-May-22	BENGALURU	66	VIKAS TECH PARK 220 - EXORA	EXORA	16:21	16:46	0:25	LINE CLEAR AVAILED
680	6-May-22	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	16:21	16:46	0:25	LINE CLEAR AVAILED
681	6-May-22	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	16:21	16:46	0:25	LINE CLEAR AVAILED
682	6-May-22	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	5:56	6:20	0:23	LINE FAULT
683	6-May-22	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	17:40	18:05	0:24	LINE FAULT
684	6-May-22	BENGALURU	66	YELAHANKA 220 - LINE7	NO STATION AFFECTED	17:57	22:05	4:07	LINE CLEAR AVAILED
685	6-May-22	BENGALURU	220	HV1	BIDADI 220	17:02(04/05/2022)			TRANSFOMER OPEN:TRANSFORMER FAULT
686	6-May-22	BENGALURU	220	MALUR 220 - SOMANAHALLI 1	SARJAPURA 220, VIKAS TECH PARK 220	16:21	16:43	0:21	LINE FAULT
687	6-May-22	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	16:21	16:45	0:24	MAIN SUPPLY FAILURE
688	6-May-22	GULBARGA	66	HV2	BENNEHALLI_66	14:00	14:45	0:45	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
689	6-May-22	GULBARGA	66	KUDLIGI-BANVIKAL	BANVIKAL_66	14:55	19:10	4:15	LINE FAULT
690	6-May-22	GULBARGA	66	NEELGUNDA-HALAVAGALU	HALAVAGALU_66	17:30	17:48	0:18	LINE FAULT
691	6-May-22	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCHCHANGIDURGA_66	15:34	15:41	0:07	LINE FAULT
692	6-May-22	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCHCHANGIDURGA_66	17:55	18:09	0:14	LINE FAULT
693	6-May-22	GULBARGA	66	NEELGUNDA-TELIGI	TELIGI_66,KURBHALLI_66,YEREGUNT A_66	17:19	18:09	0:50	LINE FAULT
694	6-May-22	GULBARGA	66	NEELGUNDA-TELIGI	TELIGI_66,KURBHALLI_66,YEREGUNT A_66	18:18	19:46	1:28	LINE FAULT
695	6-May-22	GULBARGA	66	NEELGUNDA-TELIGI	TELIGI_66,KURBHALLI_66,YEREGUNT A_66	20:25	21:52	1:27	LINE FAULT
696	6-May-22	GULBARGA	66	TELIGI-KURBHALLI	KURBHALLI_66	22:05(06.05.2022)			LINE OPEN:LINE FAULT
697	6-May-22	GULBARGA	66	TELIGI-NEELAGUNDA	TELIGI_66,YARAGUNTA_66,KURBHALLI I_66	22:10	23:59:00	1:49	LINE CLEAR AVAILED
698	6-May-22	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	4:50	4:56	0:06	LINE FAULT
699	6-May-22	GULBARGA	110	HUMNABAD-HUMNABAD_2	HUMNABAD_110	15:06(26/04/2022)			LINE OPEN:LINE CLEAR AVAILED
700	6-May-22	GULBARGA	110	HV1	SIRIGERICROSS_110	13:01	13:06	0:05	TRANSFORMER FAULT
701	6-May-22	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONNAGAR_ 110,HANUMANAL_110	13:45	13:55	0:10	LINE FAULT
702	6-May-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	3:20	3:35	0:15	LINE FAULT
703	6-May-22	GULBARGA	110	NAND00R-SHAHABAD2	NAND00R_110	3:03	7:28	4:25	LINE FAULT
704	6-May-22	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	21:10	21:20	0:10	LINE FAULT
705	6-May-22	GULBARGA	110	SEDAM-CLEANMAX_IPP	SEDAM_220	14:55	19:10	4:15	LINE FAULT
706	6-May-22	GULBARGA	110	SHAHABAD-CHITAPUR	KORAWAR TEMPLE_110	3:01	3:04	0:03	LINE FAULT
707	6-May-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	10:04	16:34	6:30	LINE CLEAR AVAILED
708	6-May-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGURS_IPP,ASKI_IPP,HUNSAGI_110	10:04	16:37	6:33	LINE CLEAR AVAILED
709	6-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAG ERA_110,SANNATHI_IPP,COREGREENSUG ARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
710	6-May-22	GULBARGA	110	SINDHANOOR-ADAVI AMARESHWAR	JEWALAGERA_110,ADAVI AMARESHWAR_110	12:50	16:50	4:00	LINE CLEAR AVAILED
711	6-May-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_ 110,SRNAGAR_110,MALLAPURA_110	14:55	15:05	0:10	LINE FAULT
712	6-May-22	GULBARGA	110	SIRIGERICROSS-ALIPUR	SIRIGERICROSS_110	7:38	8:13	0:35	LINE CLEAR AVAILED
713	6-May-22	GULBARGA	220	HV2	RAICHUR_220	11:20	12:30	1:10	LINE CLEAR AVAILED
714	6-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFOMER OPEN:TRANSFORMER FAULT
715	6-May-22	GULBARGA	220	LINGAPUR-JVSL1	LINGAPUR_220	8:40	11:52	3:12	LINE CLEAR AVAILED
716	6-May-22	GULBARGA	220	RAICHUR-JURLA LINE1	RAICHUR_220	19:47(06.05.2022)			LINE OPEN:LINE FAULT
717	6-May-22	HASSAN	66	HV1	SAKALESHWAR_66	9:10	17:50	8:40	LINE CLEAR AVAILED
718	6-May-22	HASSAN	66	HV2	ARAKALGUD_66	10:35	10:55	0:20	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
719	6-May-22	HASSAN	66	HV2	BAGUR_66	16:45	16:55	0:10	TRANSFORMER FAULT
720	6-May-22	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	12:15	12:21	0:06	HAND TRIPPED
721	6-May-22	HASSAN	66	LV1	CRPATNA	10:48	12:10	1:22	LINE CLEAR AVAILED
722	6-May-22	HASSAN	66	RAMNATHPURA_66	RAMNAT-KATTEPURA_MINIH	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
723	6-May-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	10:30	19:05	8:35	LINE CLEAR AVAILED
724	6-May-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	10:30	19:05	8:35	LINE CLEAR AVAILED
725	6-May-22	HASSAN	66	UDDURKO-SUZLON2	UDDURKOPPLU_66	12:15	14:40	2:25	LINE FAULT
726	6-May-22	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	17:55	18:20	0:25	LINE FAULT
727	6-May-22	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	16:48	18:24	1:36	MAIN SUPPLY FAILURE
728	6-May-22	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	16:48	18:18	1:30	MAIN SUPPLY FAILURE
729	6-May-22	HASSAN	110	GURUVA-SLVPWR	GURUVAYANKERE_110	9:44	18:18	8:34	LINE CLEAR AVAILED
730	6-May-22	HASSAN	110	GURUVA-SLVPWR	GURUVAYANKERE_110	16:48	18:18	1:30	MAIN SUPPLY FAILURE
731	6-May-22	HASSAN	110	HV1	KADUR_220	10:58	11:39	0:41	TRANSFORMER FAULT
732	6-May-22	HASSAN	110	HV2	ANANDAPURA_110	19:25	19:50	0:25	TRANSFORMER FAULT
733	6-May-22	HASSAN	110	HV2	MANIPAL_110	10:06	12:51	2:45	TRANSFORMER FAULT
734	6-May-22	HASSAN	110	JOG_110	HV3	10:55(05.04.2022)			LINE OPEN:LINE CLEAR AVAILED
735	6-May-22	HASSAN	110	JOG110-LPH	JOG_110	18:25	19:25	1:00	MAIN SUPPLY FAILURE
736	6-May-22	HASSAN	110	JOG110-MGHE	JOG_110	18:25(06.05.2022)			LINE OPEN:LINE FAULT
737	6-May-22	HASSAN	110	JOG-JLT3	gen_mghe	18:20 (6.05.2022)			LINE OPEN:LINE FAULT
738	6-May-22	HASSAN	110	KARAYA-PUTTUR	KARAYA_110	15:53	16:15	0:22	MAIN SUPPLY FAILURE
739	6-May-22	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:48	18:24	2:36	LINE FAULT
740	6-May-22	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	16:48	18:17	1:29	LINE FAULT
741	6-May-22	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	15:56	16:34	0:38	MAIN SUPPLY FAILURE
742	6-May-22	HASSAN	110	LPH-MGHE 1	lph_mghe	18:24	19:23	0:59	LINE FAULT
743	6-May-22	HASSAN	110	LPH-MGHE 2	lph_mghe	1:55 (05.05.2022)	15:19(06.05.2022)	22:23 hrs	LINE CHARGED
744	6-May-22	HASSAN	110	LV2	MSEZ_220	15:09 (5.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
745	6-May-22	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	9:56	13:10	3:14	NFBC ISSUED
746	6-May-22	HASSAN	110	mghejog_gen	JOG-NK2	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
747	6-May-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	9:30 (06.05.2022)			LINE OPEN:LINE CLEAR AVAILED
748	6-May-22	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	16:40(05.05.2022)	9:28(06.05.2022)	16:48 hrs	LINE CHARGED
749	6-May-22	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	17:20	18:15	0:55	LINE FAULT
750	6-May-22	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	15:54	16:16	0:22	LINE FAULT
751	6-May-22	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	15:53	16:21	0:28	LINE FAULT
752	6-May-22	HASSAN	110	PUTTUR-VITLA	PUTTUR_220	15:55	16:15	0:20	LINE FAULT
753	6-May-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	19:04	19:50	0:46	LINE FAULT
754	6-May-22	HASSAN	110	VITTAL-PUTR_SLTUR	VITTALA_110	15:54	16:15	0:21	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
755	6-May-22	HASSAN	220	HV1	CRPATNA	10:48	12:10	1:22	LINE CLEAR AVAILED
756	6-May-22	HASSAN	220	HV2	MSEZ_220	15:09 (5.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
757	6-May-22	HASSAN	220	KADUR-SHIMOGA	KADUR_220	10:10	11:14	1:04	LINE FAULT
758	6-May-22	HASSAN	220	KAVOOR_220	HV3	19:55(30.05.2022)			LINE OPEN:LINE FAULT
759	6-May-22	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	12:25	13:35	1:10	LINE CLEAR AVAILED
760	6-May-22	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	6:10	8:50	2:40	LINE FAULT
761	6-May-22	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	10:10	11:14	1:04	LINE FAULT
762	6-May-22	HASSAN	220	PUTTUR-KEMAR1	PUTTUR_220	12:15	13:35	1:20	NFBC ISSUED
763	6-May-22	HASSAN	220	SHRAVTY-TALAGUPPA1	SHRAVTY	20:22(06.05.2022)			LINE OPEN:LINE FAULT
764	6-May-22	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	20:22(06.05.2022)			LINE OPEN:LINE FAULT
765	6-May-22	HASSAN	400	TALAGUPPA_400	TALAGU-NELAMANGALA#2	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
766	6-May-22	MYSURU	66	K R PETE 220-MAHADESHWARAPURA	G MALLIGERE_66JAKKANAHALLY_66MADESWARAPURA_66	17:02	17:09	0:07	LINE FAULT
767	6-May-22	MYSURU	66	BILIKERE-GV GUDI	GVGUDI_66	12:59	13:09	0:09	LINE FAULT
768	6-May-22	MYSURU	66	DR PETE-KUNTHUR	SANTHEMARAHALLI_66	10:58	12:36	1:38	NFBC ISSUED
769	6-May-22	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
770	6-May-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
771	6-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
772	6-May-22	MYSURU	66	HV1	HULLAHALLI_66	16:40	17:38	0:57	LINE CLEAR AVAILED
773	6-May-22	MYSURU	66	HV1	KIADBMANDYA_66	20:16	20:26	0:10	MAIN SUPPLY FAILURE
774	6-May-22	MYSURU	66	HV1	MADIKERI_66	15:21	17:40	2:18	LINE CLEAR AVAILED
775	6-May-22	MYSURU	66	HV1	MALAVALLI_66	8:25	8:45	0:20	HAND TRIPPED
776	6-May-22	MYSURU	66	HV1	MALAVALLI_66	9:32	9:34	0:01	HAND TRIPPED
777	6-May-22	MYSURU	66	HV2	BGNAGARA_66	9:06:15 (6/5/2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
778	6-May-22	MYSURU	66	HV2	HAMPAPURA_66	11:23	12:27	1:04	LINE CLEAR AVAILED
779	6-May-22	MYSURU	66	HV2	HAMPAPURA_66	16:43	17:06	0:23	LINE CLEAR AVAILED
780	6-May-22	MYSURU	66	HV2	MADIKERI_66	15:21	15:32	0:10	HAND TRIPPED
781	6-May-22	MYSURU	66	HV2	MYSORESOUTH_66	11:09	11:15	0:06	TRANSFORMER FAULT
782	6-May-22	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57:05 (4/5/2022)			LINE OPEN:LINE CLEAR AVAILED
783	6-May-22	MYSURU	66	KUSHALNAGARA-HARANGI	NO STATIONS EFFECTED	12:31	12:39	0:08	LINE CLEAR AVAILED
784	6-May-22	MYSURU	66	KUSHALNAGARA-MADIKERI	NO STATIONS EFFECTED	14:19	14:24	0:05	HAND TRIPPED
785	6-May-22	MYSURU	66	KUSHALNAGARA-MADIKERI1	MADIKERI_66	12:08	12:35	0:27	HAND TRIPPED
786	6-May-22	MYSURU	66	KUSHALNAGARA-MADIKERI2	SUNTIKOPPA_66	12:08	12:35	0:27	HAND TRIPPED
787	6-May-22	MYSURU	66	KUSHALNAGARA-MYSORE 1	NO STATIONS EFFECTED	14:19	14:22	0:02	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
788	6-May-22	MYSURU	66	KUSHALNAGARA-MYSORE 1	NO STATIONS EFFECTED	15:08	15:16	0:07	HAND TRIPPED
789	6-May-22	MYSURU	66	KUSHALNAGARA-MYSORE 2	NO STATIONS EFFECTED	11:39	14:01	2:22	LINE CLEAR AVAILED
790	6-May-22	MYSURU	66	SFC SIVA5MW	NO STATIONS EFFECTED	18:10	18:27	0:17	HAND TRIPPED
791	6-May-22	MYSURU	66	SFC SIVA5MW	NO STATIONS EFFECTED	20:05:00 (6/5/2022)			LINE OPEN:LINE CLEAR AVAILED
792	6-May-22	MYSURU	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66BANANGADI_66BELA GOLA_66	19:05	19:17	0:12	LINE FAULT
793	6-May-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
794	6-May-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
795	6-May-22	MYSURU	220	HV1	TUBINAKERE_220	11:13	16:20	5:06	LINE CLEAR AVAILED
796	6-May-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	6:09	6:21	0:12	HAND TRIPPED
797	6-May-22	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAGALUR_66	4:01	4:37	0:36	MAIN SUPPLY FAILURE
798	6-May-22	TUMKUR	66	CHITRADURGA 66KV- PANDARAHALLI 2	PANDARAHALLI_66	10:41	11:47	1:05	LINE CLEAR AVAILED
799	6-May-22	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	19:25	20:45	1:20	LINE CLEAR AVAILED
800	6-May-22	TUMKUR	66	DODDASARANGI-ANCHEPALYA	DODDASARANGI_66	21:14	22:00	0:45	MAIN SUPPLY FAILURE
801	6-May-22	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	16:05	21:33	5:28	LINE CLEAR AVAILED
802	6-May-22	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	1:50	1:56	0:05	LINE FAULT
803	6-May-22	TUMKUR	66	MADHUGIRI 220KV- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	18:24	18:51	0:26	HAND TRIPPED
804	6-May-22	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	19:03	19:31	0:27	HAND TRIPPED
805	6-May-22	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	19:03	19:31	0:27	HAND TRIPPED
806	6-May-22	TUMKUR	66	MADHUGIRI 220KV- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	18:24	18:58	0:34	HAND TRIPPED
807	6-May-22	TUMKUR	66	MADHUGIRI 220kv-NITRAHALI	NITRAHALI_66	17:55	20:35	2:40	LINE FAULT
808	6-May-22	TUMKUR	66	TR-2	BALENAHALI_66	17:55	18:00	0:05	TRANSFORMER FAULT
809	6-May-22	TUMKUR	66	TR-2	BALENAHALI_66	19:57	20:04	0:06	TRANSFORMER FAULT
810	6-May-22	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	6:09	6:20	0:11	TRANSFORMER FAULT
811	6-May-22	TUMKUR	66	TR-2(LV SIDE)	MADHUGIRI_220	17:56	18:49	0:53	LINE CLEAR AVAILED
812	6-May-22	TUMKUR	66	TR-3(LV SIDE)	ANTHRASANAHALLI_220	6:09	6:20	0:11	TRANSFORMER FAULT
813	6-May-22	TUMKUR	220	ANTHRASANAHALLI 220KV- SHIMOGA	ANTHRASANAHALLI_220	6:49	8:49	2:00	LINE FAULT
814	6-May-22	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHARASAPURA 1	ANTHRASANAHALLI_220	11:43	15:34	3:51	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
815	6-May-22	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	17:28	18:14	0:46	LINE FAULT
816	6-May-22	TUMKUR	220	MADHUGIRI 220kV- GOWRIBIDANUR220	MADHUGIRI 220kV	17:54	20:41	2:47	LINE FAULT
817	6-May-22	TUMKUR	220	TR-2(HV SIDE)	ANCHEPALYA_220	11:05	13:53	2:48	LINE CLEAR AVAILED
818	6-May-22	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	6:09	6:20	0:11	TRANSFORMER FAULT
819	6-May-22	TUMKUR	220	TR-2(HV SIDE)	MADHUGIRI 220kV	17:56	18:45	0:48	TRANSFORMER FAULT
820	6-May-22	TUMKUR	220	TR-3(HV SIDE)	ANTHRASANAHALLI_220	6:09	6:20	0:11	TRANSFORMER FAULT
821	6-May-22	TUMKUR	400	KAIGA LINE-2	GUTTURU-400	1:14	2:15	1:01	LINE FAULT
822	7-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED GIRISAGAR_110	9:40 (05.05.2022)			TRANSFOMER OPEN:TRANSFORMER FAULT
823	7-May-22	BAGALKOT	110	110/11KV,HV1	HALIYAL_110	9:00	19:05	10:05	LINE CLEAR AVAILED
824	7-May-22	BAGALKOT	110	110/11KV,HV1	YADAWAD_110	11:45	12:00	0:15	LINE CLEAR AVAILED
825	7-May-22	BAGALKOT	110	110/11KV,HV2	HALIYAL_110	9:00	15:10	6:10	LINE CLEAR AVAILED
826	7-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHVAR_110	17:55 (28.04.2022)			TRANSFOMER OPEN:TRANSFORMER FAULT
827	7-May-22	BAGALKOT	110	AMBEWADI-NK-1(HALIYAL)	HALIYAL_110	9:00	12:30	3:30	LINE CLEAR AVAILED
828	7-May-22	BAGALKOT	110	AMBEWADI-NK-1(HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	9:00	12:32	3:32	LINE CLEAR AVAILED
829	7-May-22	BAGALKOT	110	BELGAUM-MACHE	MACHE_110	8:52	11:21	2:29	LINE FAULT
830	7-May-22	BAGALKOT	110	BELGAUM-VADAGOAN	VADAGOAN_110	8:35	8:48	0:13	LINE FAULT
831	7-May-22	BAGALKOT	110	BELGAUM-VADAGOAN	VADAGOAN_110	8:52	11:21	2:29	LINE FAULT
832	7-May-22	BAGALKOT	110	GADAG220- BETAGERI(ROH)	STATION NOT AFFECTED GADAG_220	21:10 (04.05.2022)	16:25 (07.05.2022)	67:15 hrs	LINE CHARGED
833	7-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
834	7-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
835	7-May-22	BAGALKOT	110	VADAGOAN-MACHE	MACHE_110	8:35	8:48	0:13	LINE FAULT
836	7-May-22	BAGALKOT	110	VAJRAMATTI-JK CEMENT	VAJRAMATTI_220	7:25	10:49	3:24	LINE CLEAR AVAILED
837	7-May-22	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED BELGAUM_220	10:34 (24.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
838	7-May-22	BAGALKOT	220	ATHANI- KUDACHI	STATION NOT AFFECTED ATHANI_220	11:11	19:37	8:26	LINE CLEAR AVAILED
839	7-May-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
840	7-May-22	BAGALKOT	220	HAVERI- GUTTUR2	STATION NOT AFFECTED HAVERI_220	17:29 (06.05.2022)	14:25 (07.05.2022)	20:56	LINE CHARGED
841	7-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVAILED
842	7-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVAILED
843	7-May-22	BAGALKOT	220	SOUDATTI- BIDNAL	SOUDATTI_220	15:09	17:42	2:33	LINE FAULT
844	7-May-22	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	JAKKASANDRA	17:15	17:44	0:29	LOAD CHANGEOVER
845	7-May-22	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI, BOSCH (EHT)	17:15	17:44	0:29	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
846	7-May-22	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	17:15	17:48	0:33	LOAD CHANGEVER
847	7-May-22	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS WOOD	ST. JOHNS WOOD	17:15	17:44	0:29	LOAD CHANGEVER
848	7-May-22	BENGALURU	66	HV1	MAGADI 220	2:03	4:14	2:11	LINE CLEAR AVAILED
849	7-May-22	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66	2:24	2:43	0:19	LINE FAULT
850	7-May-22	BENGALURU	66	VIDYANAGARA - HENNUR CROSS	NO STATION AFFECTED	18:13	19:27	1:14	LINE FAULT
851	7-May-22	GULBARGA	66	HV2	HALVAGALU_66	18:05	18:10	0:05	TRANSFORMER FAULT
852	7-May-22	GULBARGA	66	HV2	HALVAGALU_66	23:20	23:25	0:05	TRANSFORMER FAULT
853	7-May-22	GULBARGA	66	HV2	MUNIRABAD_220	8:35	11:20	2:45	LINE CLEAR AVAILED
854	7-May-22	GULBARGA	66	NEELAGUNDA-PUNABGHATA	PUNABGHATA_66,UCHCHANGIDURGA_66	15:30	15:40	0:10	MAIN SUPPLY FAILURE
855	7-May-22	GULBARGA	66	NEELAGUNDA-PUNABGHATA	PUNABGHATA_66,UCHCHANGIDURGA_66	17:50	18:05	0:15	MAIN SUPPLY FAILURE
856	7-May-22	GULBARGA	66	NEELGUNDA-TELIGI	TELIGI_66,KURBHAHALI_66,YEREGUNT A_66	0:10	0:27	0:17	LINE FAULT
857	7-May-22	GULBARGA	66	NEELGUNDA-TELIGI	TELIGI_66,KURBHAHALI_66,YEREGUNT A_66	0:10	0:27	0:17	LINE FAULT
858	7-May-22	GULBARGA	66	TELIGI-KURBARHALLI	KURBARHALLI_66	22:05(06.05.2022)	18:45(07.05.2022)	20:40 hrs	LINE CHARGED
859	7-May-22	GULBARGA	110	CHOWDAPUR-AFZALPUR	CHOWDAPUR_110	7:55	17:10	9:15	LINE CLEAR AVAILED
860	7-May-22	GULBARGA	110	CHOWDAPUR-AFZALPUR	CHOWDAPUR_110	8:18	11:30	3:12	LINE CLEAR AVAILED
861	7-May-22	GULBARGA	110	HUMNABAD-HUMNABAD_2	HUMNABAD_110	15:06(26/04/2022)			LINE OPEN:LINE CLEAR AVAILED
862	7-May-22	GULBARGA	110	HUMNABAD-HUMNABAD_2	HUMNABAD_110	15:06(26/04/2022)			LINE OPEN:LINE CLEAR AVAILED
863	7-May-22	GULBARGA	110	HV1	CHOWDAPUR_110	9:45	9:50	0:05	LOAD CURTAILMENT
864	7-May-22	GULBARGA	110	HV1	CHOWDAPUR_110	11:45	12:00	0:15	LOAD CURTAILMENT
865	7-May-22	GULBARGA	110	HV2	MUNIRABAD_220	17:10	17:18	0:08	TRANSFORMER FAULT
866	7-May-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS	11:46	11:56	0:10	LINE CLEAR AVAILED
867	7-May-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	3:20	3:35	0:15	LINE FAULT
868	7-May-22	GULBARGA	110	NEELGUNDA-HARAPANAHALLI	HARAPANAHALLI_110	23:41	23:46	0:05	LINE FAULT
869	7-May-22	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110	17:56(08.05.2022)			LINE OPEN:LINE FAULT
870	7-May-22	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110	17:06	17:17	0:11	LINE FAULT
871	7-May-22	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110	17:20	18:38	1:18	LINE FAULT
872	7-May-22	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	17:27	17:56	0:29	LINE CLEAR AVAILED
873	7-May-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	9:32	9:44	0:12	LINE FAULT
874	7-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAG ERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
875	7-May-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	17:15	17:25	0:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
876	7-May-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	20:10	20:20	0:10	LINE CLEAR AVAILED
877	7-May-22	GULBARGA	220	HV1	NEELGUNDA_220	9:50	15:40	5:50	LINE CLEAR AVAILED
878	7-May-22	GULBARGA	220	HV2	KAPNOOR_220	7:29	16:46	9:17	LINE CLEAR AVAILED
879	7-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFOMER OPEN:TRANSFORMER FAULT
880	7-May-22	GULBARGA	220	RAICHUR-JURLA LINE1_IPP[RAICHUR_220	19:47(06.05.2022)	13:18(07.05.2022)	17:31HRS	LINE CHARGED
881	7-May-22	GULBARGA	220	RAICHUR-JURLA LINE2_IPP	RAICHUR_220	16:24	19:07	2:43	LINE FAULT
882	7-May-22	HASSAN	66	BHADRA-LINGADAHALLI	gen_bhadra	22:40	23:15	0:35	MAIN SUPPLY FAILURE
883	7-May-22	HASSAN	66	BHADRA-SHMGGA 1	gen_bhadra	22:40	23:15	0:35	MAIN SUPPLY FAILURE
884	7-May-22	HASSAN	66	BHADRA-SHMGGA 2	gen_bhadra	22:40	23:15	0:35	MAIN SUPPLY FAILURE
885	7-May-22	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	7:30	7:53	0:23	LINE FAULT
886	7-May-22	HASSAN	66	HNPURA-HNPURA	HNPURA_66	11:50 (07.05.2022)			LINE OPEN:LINE CLEAR AVAILED
887	7-May-22	HASSAN	66	HNPURA-KADVINAKOTE	HNPURA_66	23:50 (07.05.2022)			LINE OPEN: MAIN SUPPLY FAILURE
888	7-May-22	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	23:50 (07.05.2022)			LINE OPEN: MAIN SUPPLY FAILURE
889	7-May-22	HASSAN	66	HV1	SAKALESHPURA_66	8:40	17:55	9:15	LINE CLEAR AVAILED
890	7-May-22	HASSAN	66	HV2	RAMPURA_66	12:05	12:55	0:50	LINE CLEAR AVAILED
891	7-May-22	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	21:51	23:30	1:39	NFBC ISSUED
892	7-May-22	HASSAN	66	MRSSHM-BD-1	MRSMG_220	22:41	23:23	0:42	LINE FAULT
893	7-May-22	HASSAN	66	MRSSHM-BD-2	MRSMG_220	22:41	23:28	0:47	LINE FAULT
894	7-May-22	HASSAN	66	MRSSHM-DVG2	MRSMG_220	22:41	23:24	0:43	LINE FAULT
895	7-May-22	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	22:41	23:24	0:43	LINE FAULT
896	7-May-22	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	13:45	13:53	0:08	MAIN SUPPLY FAILURE
897	7-May-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
898	7-May-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	9:30	19:50	10:20	LINE CLEAR AVAILED
899	7-May-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	9:40	18:25	8:45	LINE CLEAR AVAILED
900	7-May-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	9:30	19:50	10:20	LINE CLEAR AVAILED
901	7-May-22	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	21:22	23:35	2:13	LINE CLEAR AVAILED
902	7-May-22	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	20:50	21:22	0:32	LINE FAULT
903	7-May-22	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPPLU_66	12:15	14:40	2:25	LINE FAULT
904	7-May-22	HASSAN	110	ANAVATI-BARANGI	ANAVATTI_110	12:00 (7.05.2022)			LINE OPEN:LINE CLEAR AVAILED
905	7-May-22	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	12:00	19:50	7:50	MAIN SUPPLY FAILURE
906	7-May-22	HASSAN	110	BARANG-ANVATTI	BARANGI_110	19:27(07.05.2022)			LINE OPEN:LINE FAULT
907	7-May-22	HASSAN	110	BARANG-ANVATTI	BARANGI_110	12:03	19:00	6:57	LINE CLEAR AVAILED
908	7-May-22	HASSAN	110	BRAHMAV-NITTUR	BRAHMAVARA_110	10:41	12:15	1:34	LINE CLEAR AVAILED
909	7-May-22	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	22:40	23:20	0:40	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
910	7-May-22	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	10:22	12:11	1:49	NFBC ISSUED
911	7-May-22	HASSAN	110	HV1	BANAVARA_110	13:15	14:35	1:20	LINE CLEAR AVAILED
912	7-May-22	HASSAN	110	HV1	KADUR_220	4:45	7:00	2:15	TRANSFORMER FAULT
913	7-May-22	HASSAN	110	HV1	MRSMSG_220	22:41	22:48	0:07	TRANSFORMER FAULT
914	7-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
915	7-May-22	HASSAN	110	HV5	KAVOOR_220	9:25	18:48	9:23	LINE CLEAR AVAILED
916	7-May-22	HASSAN	110	HV5	MRSMSG_220	22:41	22:49	0:08	TRANSFORMER FAULT
917	7-May-22	HASSAN	110	JOG110-MGHE	JOG_110	18:25(06.05.2022)	14:27(07.05.2022)	20:01 hrs	LINE CHARGED
918	7-May-22	HASSAN	110	JOG-JLT3	gen_mghe	18:20 (6.05.2022)	14:34(07.05.2022)	20:13 hrs	LINE CHARGED
919	7-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
920	7-May-22	HASSAN	110	KADUR-TNGL	KADUR_220	11:40	11:45	0:05	LINE FAULT
921	7-May-22	HASSAN	110	KEMAR-BELMAN	KEMAR_220	11:05	12:50	1:45	LINE CLEAR AVAILED
922	7-May-22	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:22	12:11	1:49	LINE CLEAR AVAILED
923	7-May-22	HASSAN	110	LV1	MRSMSG_220	22:41	23:11	0:30	TRANSFORMER FAULT
924	7-May-22	HASSAN	110	LV2	MRSMSG_220	22:41	23:08	0:27	TRANSFORMER FAULT
925	7-May-22	HASSAN	110	LV3	MRSMSG_220	22:41	23:07	0:26	TRANSFORMER FAULT
926	7-May-22	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	10:33	10:43	0:10	LOAD CHANGEOVER
927	7-May-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	9:30 (06.05.2022)	18:50(07.05.2022)	23:19 hrs	LINE CHARGED
928	7-May-22	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	9:10	18:50	9:40	LINE CLEAR AVAILED
929	7-May-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	22:41	23:21	0:40	LINE FAULT
930	7-May-22	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	22:41	23:21	0:40	LINE FAULT
931	7-May-22	HASSAN	110	MRSSHM-BADRAVATY3	MRSMSG_220	22:41	23:21	0:40	LINE FAULT
932	7-May-22	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	22:41	23:25	0:44	LINE FAULT
933	7-May-22	HASSAN	110	MRSSHM-MPM	MRSMSG_220	22:41	23:24	0:43	LINE FAULT
934	7-May-22	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	22:41	23:24	0:43	LINE FAULT
935	7-May-22	HASSAN	110	MRSSHM-SS1	MRSMSG_220	22:41	23:22	0:41	LINE FAULT
936	7-May-22	HASSAN	110	MRSSHM-SS2	MRSMSG_220	22:41	23:22	0:41	LINE FAULT
937	7-May-22	HASSAN	110	VITTAL-PUTR_SLTUR	VITALA_110	12:57	13:56	0:59	LINE CLEAR AVAILED
938	7-May-22	HASSAN	220	HV1	MRSMSG_220	22:41	23:11	0:30	TRANSFORMER FAULT
939	7-May-22	HASSAN	220	HV2	MRSMSG_220	22:41	23:08	0:27	TRANSFORMER FAULT
940	7-May-22	HASSAN	220	HV2	MSEZ_220	22:41(07.05.2022)			TRANSFOMER OPEN:TRANSFORMER FAULT
941	7-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
942	7-May-22	HASSAN	220	HV3	MRSMSG_220	22:41	23:08	0:27	TRANSFORMER FAULT
943	7-May-22	HASSAN	220	KADUR-DABUSET	KADUR_220	6:19	9:45	3:26	NFBC ISSUED
944	7-May-22	HASSAN	220	LV2	MSEZ_220	22:41(07.05.2022)			TRANSFOMER OPEN:TRANSFORMER FAULT
945	7-May-22	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	22:41	23:03	0:22	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
946	7-May-22	HASSAN	220	MRSSHM-CHMLR	MRSMSG_220	22:41	23:16	0:35	LINE FAULT
947	7-May-22	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	22:41	23:01	0:20	LINE FAULT
948	7-May-22	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	22:41	23:27	0:46	LINE FAULT
949	7-May-22	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	22:41	23:29	0:48	LINE FAULT
950	7-May-22	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	22:41	23:01	0:20	LINE FAULT
951	7-May-22	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	22:41	23:16	0:35	LINE FAULT
952	7-May-22	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	22:41	23:16	0:35	LINE FAULT
953	7-May-22	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	22:41	23:15	0:34	LINE FAULT
954	7-May-22	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	22:41	23:14	0:33	LINE FAULT
955	7-May-22	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	22:41	23:14	0:33	LINE FAULT
956	7-May-22	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	22:41	23:33	0:52	LINE FAULT
957	7-May-22	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	22:41	23:18	0:37	LINE FAULT
958	7-May-22	HASSAN	220	SHRAVITY-TALAGUPPA1	gen_shravty	20:22(06.05.2022)	9:26 (07.05.2022)	13:03 hrs	LINE CHARGED
959	7-May-22	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	20:22(06.05.2022)	9:21(07.05.2022)	12:58 hrs	LINE CHARGED
960	7-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
961	7-May-22	MYSURU	66	DEVANUR NANJANGUDU-KADAKOLA	DEVANOORNGUDU_66 SUTTUR_66	19:18	19:28	0:10	LINE FAULT
962	7-May-22	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
963	7-May-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
964	7-May-22	MYSURU	66	HEBBANI-VADAKEPURA	VADKEPURA_66	11:41	11:59	0:18	HAND TRIPPED
965	7-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
966	7-May-22	MYSURU	66	HV2	ADDIHALLI_66	13:35	14:35	1:00	LINE CLEAR AVAILED
967	7-May-22	MYSURU	66	HV2	BGNAGARA_66	9:06:15 (6/5/2022)	11:50:00 (7/5/2022)	2:43 hrs	LINE CHARGED
968	7-May-22	MYSURU	66	KADAKOLA-NANJANGUDU 1	NO STATIONS EFFECTED	1:34:00 PM (07/05/2022)			LINE OPEN:LINE FAULT
969	7-May-22	MYSURU	66	KADAKOLA-THANDYA	THANDYA_66	13:34	14:06	0:32	LINE FAULT
970	7-May-22	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57:05 (4/5/2022)			LINE OPEN:LINE CLEAR AVAILED
971	7-May-22	MYSURU	66	KUSHALANAGARA-BETTADAPURA	NO STATIONS EFFECTED	23:21	23:33	0:12	LINE FAULT
972	7-May-22	MYSURU	66	SANTHESARGUR-SHUBASH 1	NO STATIONS EFFECTED	19:33	19:45	0:12	LINE FAULT
973	7-May-22	MYSURU	66	SANTHESARGUR-SHUBASH 2	NO STATIONS EFFECTED	16:52	17:07	0:15	LINE FAULT
974	7-May-22	MYSURU	66	SANTHESARGUR-SHUBASH 2	NO STATIONS EFFECTED	19:33	19:45	0:12	LINE FAULT
975	7-May-22	MYSURU	66	SFC SIVA5MW	NO STATIONS EFFECTED	20:05:00 (6/5/2022)	6:06:00 (7/5/2022)	10:01 hrs	HAND TRIPPED
976	7-May-22	MYSURU	66	VAJAMANGALA-HEBBANI	NO STATIONS EFFECTED	12:33	12:40	0:07	LINE FAULT
977	7-May-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
978	7-May-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
979	7-May-22	TUMKUR	66	ANCHEPALYA 220KV- ANCHEPALYA 66	ANCHEPALYA_66,BHAKTHARAHALLI_66	16:32	17:57	1:25	LINE CLEAR AVAIED
980	7-May-22	TUMKUR	66	ANCHEPALYA 220KV- HEBBUR_66	HEBBUR_66,THIMMASANDRA_66,HONN ENAHALLI_66	17:32	17:57	0:25	LINE FAULT
981	7-May-22	TUMKUR	66	ANTHRASANAHALLI 220KV- BELLAVI66	BELLAVI_66	9:24	10:44	1:20	LINE FAULT
982	7-May-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	6:45	8:05	1:20	LINE CLEAR AVAIED
983	7-May-22	TUMKUR	66	NAYAKANAHATTI66- HIREMALLANHOLE66	NAYAKANHATTI_66, HIREMALLANAHOLE_66	21:12	21:33	0:21	LINE FAULT
984	7-May-22	TUMKUR	66	NAYAKANAHATTI66- HIREMALLANHOLE66	NAYAKANHATTI_66, HIREMALLANAHOLE_66	22:10	22:25	0:15	LINE FAULT
985	7-May-22	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	13:08	17:12	4:04	LINE CLEAR AVAIED
986	7-May-22	TUMKUR	66	TR-2(LV SIDE)	ANCHEPALYA_220	9:25	13:06	3:41	LINE CLEAR AVAIED
987	7-May-22	TUMKUR	110	SAMPIGE- KB CROSS	SAMPIGE_110	11:25	11:50	0:25	MAIN SUPPLY FAILURE
988	7-May-22	TUMKUR	110	SAMPIGE- KB CROSS	SAMPIGE_110	22:40	23:10	0:30	MAIN SUPPLY FAILURE
989	7-May-22	TUMKUR	220	ANCHEPALYA 220kv- NELMANGALA-1	ANCHEPALYA_220	13:53	14:14	0:21	LINE CLEAR AVAIED
990	7-May-22	TUMKUR	220	ANTHRASANAHALLI 220kv- KB CROSS 220	KB CROSS_220	11:26	13:19	1:53	LINE FAULT
991	7-May-22	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 1	ANTHRASANAHALLI_220	11:26	11:51	0:25	HAND TRIPPED
992	7-May-22	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	11:26	11:51	0:25	HAND TRIPPED
993	7-May-22	TUMKUR	220	TR-1(HV SIDE)	ANCHEPALYA_220	13:08	17:12	4:04	LINE CLEAR AVAIED
994	7-May-22	TUMKUR	220	TR-2(HV SIDE)	ANCHEPALYA_220	9:25	13:06	3:41	LINE CLEAR AVAIED
995	7-May-22	TUMKUR	400	KAIGA LINE-2	GUTTURU-400	1:14:00 AM(04.05.2022)	13:58(07.05.2022)	62:72 hrs	LINE CHARGED
996	8-May-22	BAGALKOT	110	110/11KV, HV1	INDI_220	22:20	22:35	0:15	TRANSFORMER FAULT
997	8-May-22	BAGALKOT	110	110/11KV, HV1	INDI_220	17:33	18:58	0:15	TRANSFORMER FAULT
998	8-May-22	BAGALKOT	110	110/11KV, HV1	INDI_220	17:39	17:44	0:05	TRANSFORMER FAULT
999	8-May-22	BAGALKOT	110	110/11KV, HV2	SHIRAGUPPI_110	6:05	6:55	0:50	LINE CLEAR AVAIED
1000	8-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED GIRISAGAR_110	9:40 (05.05.2022)			TRANSFOMER OPEN:TRANSFORMER FAULT
1001	8-May-22	BAGALKOT	110	110/11KV,HV1	AMBEWADI_220	17:46	18:12	0:26	TRANSFORMER FAULT
1002	8-May-22	BAGALKOT	110	110/11KV,HV1	NIPPANI_110	14:55	16:50	1:55	LINE CLEAR AVAIED
1003	8-May-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED MUGALKHOD_220	10:20	10:28	0:08	TRANSFORMER FAULT
1004	8-May-22	BAGALKOT	110	110/11KV,HV2	NIPPANI_110	10:20	16:50	6:30	LINE CLEAR AVAIED
1005	8-May-22	BAGALKOT	110	110/11KV,HV2	NIPPANI_110	10:30	11:05	0:35	LINE CLEAR AVAIED
1006	8-May-22	BAGALKOT	110	110/11KV,HV2	NIPPANI_110	10:20	16:50	6:30	LINE CLEAR AVAIED
1007	8-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFOMER OPEN:TRANSFORMER FAULT
1008	8-May-22	BAGALKOT	110	ATHANI220- SATTI	STATION NOT AFFECTED ATHANI_220	11:19	12:42	1:23	LINE FAULT
1009	8-May-22	BAGALKOT	110	BELGAUM-ANKALAGI	ANKALAGI_110	16:53	16:56	0:03	MAIN SUPPLY FAILURE
1010	8-May-22	BAGALKOT	110	BELGAUM-HONAGA	HONAGA_110	16:53	16:56	0:03	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1011	8-May-22	BAGALKOT	110	BELGAUM-HUDALI	HUDALI_110	16:53	16:56	0:03	MAIN SUPPLY FAILURE
1012	8-May-22	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	KANABARGI LAYOUT_110	16:53	16:56	0:03	MAIN SUPPLY FAILURE
1013	8-May-22	BAGALKOT	110	BELGAUM-MACHE	MACHE_110	16:53	16:56	0:03	MAIN SUPPLY FAILURE
1014	8-May-22	BAGALKOT	110	BELGAUM-NEHARU NAGAR	NEHARU NAGAR_110	16:53	16:56	0:03	MAIN SUPPLY FAILURE
1015	8-May-22	BAGALKOT	110	BELGAUM-UDYAMBAG	UDYAMBAG_110	16:53	16:56	0:03	MAIN SUPPLY FAILURE
1016	8-May-22	BAGALKOT	110	BELGAUM-VADAGOAN	VADAGOAN_110	16:53	16:56	0:03	MAIN SUPPLY FAILURE
1017	8-May-22	BAGALKOT	110	HAVERI220- SAVANUR	STATION NOT AFFECTED HAVERI_220	18:28	20:19	1:51	LINE FAULT
1018	8-May-22	BAGALKOT	110	HUBLI-ANAND NAGAR	HUBLI_220	17:33	18:58	1:25	LINE CLEAR AVAILED
1019	8-May-22	BAGALKOT	110	MUGALKHOD-ITNAL2	STATION NOT AFFECTED MUGALKHOD_220	4:15	4:28	0:13	LINE FAULT
1020	8-May-22	BAGALKOT	110	NARENDRA-BELUR1&2	STATION NOT AFFECTED NARENDRA_220	16:33	18:43	2:10	LINE CLEAR AVAILED
1021	8-May-22	BAGALKOT	110	NARENDRA-SHEDBAL	NARENDRA_220	11:52	12:07	0:15	LINE FAULT
1022	8-May-22	BAGALKOT	110	NARENDRA-SHEDBAL	NARENDRA_220	16:33	18:43	2:10	LINE CLEAR AVAILED
1023	8-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1024	8-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
1025	8-May-22	BAGALKOT	110	VADAGOAN-MACHE	MACHE_110	16:53	16:56	0:03	MAIN SUPPLY FAILURE
1026	8-May-22	BAGALKOT	220	220/110KV, HV1, LV1, H2& LV2	INDI_220,DEVARAHIPPARAGI_110, ATHARGA_110,HIREMASALI_110, INDI_110,LACHYAN_110, HIREBEVANUR_110,RODAGI_110, ZALKI_110,CHADCHAN_110, INCHIGERI_110	11:19	12:42	1:23	TRANSFORMER FAULT
1027	8-May-22	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED BELGAUM_220	10:34 (24.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1028	8-May-22	BAGALKOT	220	220/110KV,HV1,LV1,HV2,LV2	INDI_220,DEVARAHIPPARAGI_110,ATHAR GA_110,HIREMASALI_110,INDI_110,LACH YAN_110,HIREBEVANUR_110,RODAGI_11 0,ZALKI_110,CHADCHAN_110,INCHIGERI _110	22:20	22:35	0:15	TRANSFORMER FAULT
1029	8-May-22	BAGALKOT	220	ATHANI-KAKMARI-2	STATION NOT AFFECTED ATHANI_220	11:19	12:42	1:23	LINE FAULT
1030	8-May-22	BAGALKOT	220	BAGEWADI- BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	8:00	17:53	9:53	NFBC ISSUED
1031	8-May-22	BAGALKOT	220	BAGEWADI- BIJAPUR2 (NANDIHAL2)	STATION NOT AFFECTED BAGEWADI_220	8:00	17:54	9:54	NFBC ISSUED
1032	8-May-22	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	7:26 (07.05.2022)	16:56 (08.05.2022)	33:30 hrs	LINE CHARGED
1033	8-May-22	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	16:56	17:34	0:41	LINE FAULT
1034	8-May-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1035	8-May-22	BAGALKOT	220	NARENDRA-BELGAUM1	STATION NOT AFFECTED NARENDRA_220	16:53	17:34	0:41	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1036	8-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1037	8-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1038	8-May-22	BENGALURU	66	ADUGODI - HSR LAYOUT 220	ADUGODI, JAKKASANDRA	15:20	15:25	0:05	LOAD CHANGEOVER
1039	8-May-22	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, JAKKASANDRA	19:40	19:45	0:05	LOAD CHANGEOVER
1040	8-May-22	BENGALURU	66	BEGUR 220 - BIAL 1	BIAL	18:58	19:04	0:06	LINE CLEAR AVAILED
1041	8-May-22	BENGALURU	66	BEGUR 220 - BIAL 2	BIAL	18:58	19:04	0:06	LINE CLEAR AVAILED
1042	8-May-22	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	18:54	19:10	0:16	LINE CLEAR AVAILED
1043	8-May-22	BENGALURU	66	BEGUR 220 - VIDYANAGARA	VIDYANAGARA	18:54	19:09	0:15	LINE CLEAR AVAILED
1044	8-May-22	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	17:53	18:01	0:08	LINE FAULT
1045	8-May-22	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	17:53	18:15	0:22	LINE FAULT
1046	8-May-22	BENGALURU	66	HBR LAYOUT - DG3	KONDASPURA	13:10	13:38	0:28	LINE FAULT
1047	8-May-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	17:30	18:35	1:05	LINE CLEAR AVAILED
1048	8-May-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	18:55	19:30	0:35	LINE CLEAR AVAILED
1049	8-May-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	17:22	18:35	1:13	LINE CLEAR AVAILED
1050	8-May-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	18:55	19:30	0:35	LINE CLEAR AVAILED
1051	8-May-22	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	17:22	18:35	1:13	LINE CLEAR AVAILED
1052	8-May-22	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	18:55	19:30	0:35	LINE CLEAR AVAILED
1053	8-May-22	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	17:22	18:35	1:13	LINE CLEAR AVAILED
1054	8-May-22	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	18:55	19:30	0:35	LINE CLEAR AVAILED
1055	8-May-22	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	17:22	18:35	1:13	LINE CLEAR AVAILED
1056	8-May-22	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	18:55	19:30	0:35	LINE CLEAR AVAILED
1057	8-May-22	BENGALURU	66	HV1	BIAL BEGUR 220	18:54	19:02	0:08	LINE CLEAR AVAILED
1058	8-May-22	BENGALURU	66	HV1	GUDEMARANAHALLI	20:38	20:49	0:11	TRANSFORMER FAULT
1059	8-May-22	BENGALURU	66	HV1	HSR LAYOUT 220	17:47	18:22	0:35	TRANSFORMER FAULT
1060	8-May-22	BENGALURU	66	HV1	JAKKASANDRA	17:19	17:24	0:05	LINE CLEAR AVAILED
1061	8-May-22	BENGALURU	66	HV1	JAKKASANDRA	14:35	14:40	0:05	LINE CLEAR AVAILED
1062	8-May-22	BENGALURU	66	HV1	JIGANI 220	15:20	15:55	0:35	LOAD CHANGEOVER
1063	8-May-22	BENGALURU	66	HV1	KENGERI SATELLITE TOWN	18:56	19:36	0:40	TRANSFORMER FAULT
1064	8-May-22	BENGALURU	66	HV2	BIAL BEGUR 220	18:54	19:02	0:08	LINE CLEAR AVAILED
1065	8-May-22	BENGALURU	66	HV2	GUNDAMGERE	17:40	18:09	0:29	TRANSFORMER FAULT
1066	8-May-22	BENGALURU	66	HV2	HUKUNDA	22:00	22:05	0:05	TRANSFORMER FAULT
1067	8-May-22	BENGALURU	66	HV2	JIGANI 220	15:20	15:55	0:35	LOAD CHANGEOVER
1068	8-May-22	BENGALURU	66	HV2	YEDUMADU	19:34	19:37	0:03	TRANSFORMER FAULT
1069	8-May-22	BENGALURU	66	HV3	ELECTRONIC CITY	20:20	21:01	0:41	LINE CLEAR AVAILED
1070	8-May-22	BENGALURU	66	ISKON - SOMANAHALLI 220	ISKON	19:23	19:33	0:10	MAIN SUPPLY FAILURE
1071	8-May-22	BENGALURU	66	ISKON - SUBRAMANYAPURA 220	ISKON	22:21	22:28	0:07	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1072	8-May-22	BENGALURU	66	JAKKASANDRA - ADUGODI 1	JAKKASANDRA	11:37	12:19	0:42	LINE CLEAR AVAILED
1073	8-May-22	BENGALURU	66	JAYADEVA - ADUGODI 1	NO STATION AFFECTED	18:04	20:46	2:42	LINE FAULT
1074	8-May-22	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	15:20	17:05	1:45	MAIN SUPPLY FAILURE
1075	8-May-22	BENGALURU	66	KENGERI SATELLITE TOWN - CHANDRAPPA CIRCLE	CHANDRAPPA CIRCLE	18:46	19:37	0:51	LINE FAULT
1076	8-May-22	BENGALURU	66	KENGERI SATELLITE TOWN - CHANDRAPPA CIRCLE	CHANDRAPPA CIRCLE	19:37	23:59	4:22	LINE FAULT
1077	8-May-22	BENGALURU	66	KENGERI SATELLITE TOWN - VRISHABHAVATHI 220	KENGERI SATELLITE TOWN	20:28	21:28	1:00	MAIN SUPPLY FAILURE
1078	8-May-22	BENGALURU	66	KONDASPURA - EPIP 220	KONDASPURA	14:25	14:30	0:05	LOAD CHANGEOVER
1079	8-May-22	BENGALURU	66	MAGADI 220 - MAGADI 66	GUDEMARANAHALLI, MAGADI 66, HOSPALYA	19:33	19:50	0:17	LINE FAULT
1080	8-May-22	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1, INFOSYS(EHT),ELECTRONIC CITY, HULIMANGALA	18:14	19:14	1:00	LINE CLEAR AVAILED
1081	8-May-22	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), HUSKUR	18:14	18:52	0:38	LINE CLEAR AVAILED
1082	8-May-22	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	19:24	19:27	0:03	LOAD CHANGEOVER
1083	8-May-22	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	18:21	18:31	0:10	MAIN SUPPLY FAILURE
1084	8-May-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	17:44	18:28	0:44	LINE FAULT
1085	8-May-22	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, KIRLOSKAR(EHT)	18:38	19:04	0:26	LINE FAULT
1086	8-May-22	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	6:46	7:01	0:15	LINE FAULT
1087	8-May-22	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	18:45	19:33	0:48	LINE FAULT
1088	8-May-22	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	19:33	23:59	4:26	LINE FAULT
1089	8-May-22	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON	19:23	19:33	0:10	LINE FAULT
1090	8-May-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	18:21	18:35	0:14	LINE CLEAR AVAILED
1091	8-May-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	18:21	18:32	0:11	LINE CLEAR AVAILED
1092	8-May-22	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	18:21	18:32	0:11	LINE CLEAR AVAILED
1093	8-May-22	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	18:21	18:32	0:11	LINE CLEAR AVAILED
1094	8-May-22	BENGALURU	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	16:20	16:40	0:20	LINE FAULT
1095	8-May-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	16:22	16:41	0:19	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1096	8-May-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	17:00	17:51	0:51	LINE FAULT
1097	8-May-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	17:51	18:10	0:19	LINE FAULT
1098	8-May-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	18:10	19:57	1:47	LINE CLEAR AVAILED
1099	8-May-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	19:57	20:50	0:53	LINE FAULT
1100	8-May-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	20:50	22:37	1:47	LINE CLEAR AVAILED
1101	8-May-22	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	0:15	1:00	0:45	LINE FAULT
1102	8-May-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	2:55	3:07	0:12	LINE FAULT
1103	8-May-22	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	12:05	12:38	0:33	LINE FAULT
1104	8-May-22	BENGALURU	66	VRISHABHAVATHI 220 - SIR MV LAYOUT	KENGERI SATELLITE TOWN, SIR MV LAYOUT	20:50	21:28	0:38	LINE CLEAR AVAILED
1105	8-May-22	BENGALURU	220	BIAL BEGUR 220 - HOODY 220	BIAL BEGUR 220	18:58	19:03	0:05	MAIN SUPPLY FAILURE
1106	8-May-22	BENGALURU	220	BIAL BEGUR 220 - KIADB 1 220	BIAL BEGUR 220	18:54	19:03	0:09	LINE FAULT
1107	8-May-22	BENGALURU	220	BIAL BEGUR 220 - KIADB 1 220	NO STATION AFFECTED	17:29	18:21	0:52	LINE CLEAR AVAILED
1108	8-May-22	BENGALURU	220	BIAL BEGUR 220 - KIADB 2 220	BIAL BEGUR 220	18:54	19:03	0:09	LINE FAULT
1109	8-May-22	BENGALURU	220	BIAL BEGUR 220 - KIADB 2 220	NO STATION AFFECTED	17:24	18:38	1:14	LINE FAULT
1110	8-May-22	BENGALURU	220	DEVANAHALLI 400 - KIADB HARDWARE PARK 1 220	KIADB HARDWARE PARK 220	17:22	18:24	1:02	LINE FAULT
1111	8-May-22	BENGALURU	220	DEVANAHALLI 400 - KIADB HARDWARE PARK 1 220	KIADB HARDWARE PARK 220	18:54	19:21	0:27	LINE FAULT
1112	8-May-22	BENGALURU	220	DEVANAHALLI 400 - KIADB HARDWARE PARK 2 220	KIADB HARDWARE PARK 220	17:22	18:24	1:02	LINE FAULT
1113	8-May-22	BENGALURU	220	DEVANAHALLI 400 - KIADB HARDWARE PARK 2 220	KIADB HARDWARE PARK 220	18:54	19:21	0:27	LINE FAULT
1114	8-May-22	BENGALURU	220	HOODY 220 - BIAL BEGUR 220	NO STATION AFFECTED	18:58	19:03	0:05	LINE FAULT
1115	8-May-22	BENGALURU	220	HOSKOTE 220 - KIADB 220	HOSKOTE 220	17:22	18:30	1:08	MAIN SUPPLY FAILURE
1116	8-May-22	BENGALURU	220	HOSKOTE 220 - KIADB 220	HOSKOTE 220	18:55	19:25	0:30	MAIN SUPPLY FAILURE
1117	8-May-22	BENGALURU	220	HV1	BIAL BEGUR 220	18:58	19:03	0:05	LINE CLEAR AVAILED
1118	8-May-22	BENGALURU	220	HV1	JIGANI 220	8:10	8:12	0:02	LOAD CHANGE OVER
1119	8-May-22	BENGALURU	220	HV1	NAGANATHPURA 220	18:14	18:51	0:37	LINE CLEAR AVAILED
1120	8-May-22	BENGALURU	220	HV2	BIAL BEGUR 220	18:58	19:03	0:05	LINE CLEAR AVAILED
1121	8-May-22	BENGALURU	220	HV2	JIGANI 220	8:13	8:15	0:02	LOAD CHANGE OVER
1122	8-May-22	BENGALURU	220	HV2	NAGANATHPURA 220	18:14	18:51	0:37	LINE CLEAR AVAILED
1123	8-May-22	BENGALURU	220	HV2	TK HALLI 220	12:05	12:20	0:15	TRANSFORMER FAULT
1124	8-May-22	BENGALURU	220	KHODAYS 220 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 220	18:21	18:32	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1125	8-May-22	BENGALURU	220	KIADB HARDWARE PARK 220 - DEVANAHALLI 1 400	KIADB HARDWARE PARK 220	17:22	18:26	1:04	LINE FAULT
1126	8-May-22	BENGALURU	220	KIADB HARDWARE PARK 220 - DEVANAHALLI 2 400	KIADB HARDWARE PARK 220	18:54	19:24	0:30	LINE FAULT
1127	8-May-22	BENGALURU	220	LV2	JIGANI 220	15:20	17:05	1:45	LINE CLEAR AVAILED
1128	8-May-22	BENGALURU	220	MYLASANDRA 400 - NAGANATHPURA 220	NAGANATHPURA 220	18:14	18:36	0:22	LINE FAULT
1129	8-May-22	BENGALURU	220	NAGANATHPURA 220 - MYLASANDRA 400	NAGANATHPURA 220	18:14	18:36	0:22	LINE FAULT
1130	8-May-22	BENGALURU	220	SUBRAMANYAPURA 220 - KHODAYS 220	SUBRAMANYAPURA 220	18:21	18:32	0:11	LINE FAULT
1131	8-May-22	GULBARGA	66	HV2	HALVAGALU_66	6:15	6:20	0:05	TRANSFORMER FAULT
1132	8-May-22	GULBARGA	66	HV2	HALVAGALU_66	9:15	9:20	0:05	TRANSFORMER FAULT
1133	8-May-22	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	17:00	17:18	0:18	LINE FAULT
1134	8-May-22	GULBARGA	66	KUDLIGI-ITTAGI	KUDLIGI_220	17:25	17:40	0:15	LINE FAULT
1135	8-May-22	GULBARGA	66	TELAGI-KURBARHALLI	KURBARHALLI_66	13:35	14:45	1:10	LINE FAULT
1136	8-May-22	GULBARGA	110	GABBUR-RAICHUR	GABBUR_110	17:35	17:40	0:05	MAIN SUPPLY FAILURE
1137	8-May-22	GULBARGA	110	HUMNABAD-HUMNABAD_2	HUMNABAD_110	15:06(26/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1138	8-May-22	GULBARGA	110	HUMNABAD-MARGUTTI	MARGUTTI_110,MAHAGOAN_110	10:16	10:57	0:41	LINE FAULT
1139	8-May-22	GULBARGA	110	HV1	GABBUR_110	17:45	18:35	0:50	NFBC ISSUED
1140	8-May-22	GULBARGA	110	HV1	MATAMARI_110	11:20(08.05.2022)			TRANSFOMER OPEN:TRANSFORMER FAULT
1141	8-May-22	GULBARGA	110	HV1	MUNIRABAD_220	15:55	16:54	0:59	TRANSFORMER FAULT
1142	8-May-22	GULBARGA	110	HV2	MUNIRABAD_220	15:55	16:54	0:59	TRANSFORMER FAULT
1143	8-May-22	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGUTTI_110	18:15	18:50	0:35	LINE CLEAR AVAILED
1144	8-May-22	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGUTTI_110	18:15	18:50	0:35	LINE FAULT
1145	8-May-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	5:45	5:50	0:05	LINE FAULT
1146	8-May-22	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	3:15	3:25	0:10	LINE FAULT
1147	8-May-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	20:07	20:17	0:10	LINE FAULT
1148	8-May-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	11:55	12:04	0:09	LINE FAULT
1149	8-May-22	GULBARGA	110	MARGUTTI-KAPNOOR	MARGUTTI_110,MAHAGOAN_110	13:05	18:40	5:35	LINE CLEAR AVAILED
1150	8-May-22	GULBARGA	110	MUNIRABAD-HAGRI	HAGRI_110,SANKLAPUR_110,RBSNS,KAMALAPUR_110	19:10	19:29	0:19	LINE FAULT
1151	8-May-22	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KEREHALLI_110,MALLAPUR_110	15:29	18:48	3:19	LINE FAULT
1152	8-May-22	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110	17:56(08.05.2022)	08:01(09.05.2022)	14:05HRS	LINE CHARGED
1153	8-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
1154	8-May-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	15:28	17:18	1:50	LINE FAULT
1155	8-May-22	GULBARGA	110	YAPALDINI-VADAVATTI	YAPALDINI_110	15:25	15:35	0:10	MAIN SUPPLY FAILURE
1156	8-May-22	GULBARGA	220	HV2	KAPNOOR_220	8:25	11:25	3:00	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1157	8-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1158	8-May-22	GULBARGA	220	KUDLIGI-HIREMALLANAHALLI 1&2	KUDLIGI_220	17:25(08.05.2022)			LINE OPEN:LINE FAULT
1159	8-May-22	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	8:55	9:15	0:20	LINE FAULT
1160	8-May-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN:LINE FAULT
1161	8-May-22	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	9:45	10:05	0:20	LINE FAULT
1162	8-May-22	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	17:00	17:15	0:15	LINE FAULT
1163	8-May-22	HASSAN	66	HNPURA-HNPURA	HNPURA_66	11:50 (07.05.2022)	10:00(08.05.2022)	22:09 hrs	LINE CHARGED
1164	8-May-22	HASSAN	66	HNPURA-KADVINAKOTE	HNPURA_66	23:50 (07.05.2022)	10:40 (08.05.2022)	10:49 hrs	LINE CHARGED
1165	8-May-22	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	23:50 (07.05.2022)	0:50(08.05.2022)	0:59 hrs	LINE CHARGED
1166	8-May-22	HASSAN	66	HV2	HOLALUR_66	10:35	12:05	1:30	LINE CLEAR AVAILED
1167	8-May-22	HASSAN	66	HV2	KIADB_66	13:15	15:05	1:50	LINE CLEAR AVAILED
1168	8-May-22	HASSAN	66	MATTNAV-HIRISAVE	MATTANAVILE_66	5:05	5:10	0:05	LINE FAULT
1169	8-May-22	HASSAN	66	MATTNAV-HNHALLY	MATTANAVILE_66	3:05	3:10	0:05	LINE FAULT
1170	8-May-22	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	7:58	8:10	0:12	LINE FAULT
1171	8-May-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1172	8-May-22	HASSAN	66	RAMPUR-BAGUR	RAMPURA_66	9:45	10:05	0:20	MAIN SUPPLY FAILURE
1173	8-May-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	9:40	18:25	8:45	LINE CLEAR AVAILED
1174	8-May-22	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPPLU_66	8:00	16:00	8:00	LINE FAULT
1175	8-May-22	HASSAN	110	ANAVATI-BARANGI	ANAVATTI_110	12:00 (7.05.2022)	14:55 (8.05.2022)	24:54 hrs	LINE CHARGED
1176	8-May-22	HASSAN	110	BARANG-ANVATTI	BARANGI_110	19:27(07.05.2022)	14:48(08.05.2022)	19:20 hrs	LINE CHARGED
1177	8-May-22	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	11:55	12:55	1:00	MAIN SUPPLY FAILURE
1178	8-May-22	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	14:20	15:55	1:35	NFBC ISSUED
1179	8-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1180	8-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1181	8-May-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	8:57	18:23	9:26	LINE CLEAR AVAILED
1182	8-May-22	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	8:58	18:23	9:25	LINE CLEAR AVAILED
1183	8-May-22	HASSAN	110	MRSSHM-GAJNUR	MRSMG_220	12:47	15:52	3:05	LINE CLEAR AVAILED
1184	8-May-22	HASSAN	220	HV2	MSEZ_220	22:41(07.05.2022)	10:58(08.05.02022)	12:16 hrs	TRANSFORMER CHARGED
1185	8-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1186	8-May-22	HASSAN	220	LV2	MSEZ_220	22:41(07.05.2022)	10:59(08.05.2022)	12:17 hrs	LINE CHARGED
1187	8-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1188	8-May-22	MYSURU	66	BG NAGARA-NAGMAGALA	BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KADABALLY_66	17:49	18:22	0:32	LINE FAULT
1189	8-May-22	MYSURU	66	BG NAGARA-YEDIYUR	ADICHUNCHANAGIRI_66 VADERALLI_66	17:10	17:24	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1190	8-May-22	MYSURU	66	CR NAGARA-D R PETE 1	NO STATIONS EFFECTED	8:34	19:42	11:08	LINE CLEAR AVAILED
1191	8-May-22	MYSURU	66	CR NAGARA-D R PETE 2	NO STATIONS EFFECTED	8:34:11 (8.5.2022)			LINE OPEN:LINE CLEAR AVAILED
1192	8-May-22	MYSURU	66	DODDINADUWADI-KOTTANUR	NO STATIONS EFFECTED	1:45	1:55	0:10	LINE FAULT
1193	8-May-22	MYSURU	66	DODDINADUWADI-KOTTANUR	NO STATIONS EFFECTED	4:15	4:25	0:10	LINE FAULT
1194	8-May-22	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1195	8-May-22	MYSURU	66	HANNUR-COWDALLI	COWDALLI_66 AJJIPURA_66 BANDAHALLI_66 RAMAPURA_MYS_66MARTAHALLI_66	20:02	20:20	0:17	LINE FAULT
1196	8-May-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1197	8-May-22	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	12:21	16:45	4:24	LINE FAULT
1198	8-May-22	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	16:45	18:53	2:08	NFBC ISSUED
1199	8-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1200	8-May-22	MYSURU	66	HOOTGALLY-BOGHADI	BOGADHI_66	6:24	6:39	0:15	LINE FAULT
1201	8-May-22	MYSURU	66	KADAKOLA-NANJANGUDU 1	NO STATIONS EFFECTED	1:34:00 PM (07/05/2022)	11:12:00 (8.5.2022)	21:38 hrs	LINE CHARGED
1202	8-May-22	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57:05 (4/5/2022)			LINE OPEN:LINE CLEAR AVAILED
1203	8-May-22	MYSURU	66	MADHUVANHALLI-HEBBANI	NO STATIONS EFFECTED	16:06	16:11	0:04	LINE FAULT
1204	8-May-22	MYSURU	66	MALLAVALLI-HV1	MALAVALLI_66 HADLI_66	9:33	9:40	0:07	HAND TRIPPED
1205	8-May-22	MYSURU	66	MALLAVALLI-HV1	MALAVALLI_66 HADLI_66	9:51	9:53	0:02	HAND TRIPPED
1206	8-May-22	MYSURU	66	MALLAVALLI-HV1	MALAVALLI_66 HADLI_66	12:33	12:37	0:04	HAND TRIPPED
1207	8-May-22	MYSURU	66	MALLAVALLI-HV1	MALAVALLI_66 HADLI_66	13:05	13:09	0:03	HAND TRIPPED
1208	8-May-22	MYSURU	66	MUGUR-MADHUVANAHALLI	MUGUR_66 JANNUR_66 THAYURU_66 TNARASIPURA_66	8:40	8:55	0:15	HAND TRIPPED
1209	8-May-22	MYSURU	66	NAGAMANGALA 220-GUDDENAHALLI	GUDDENAHALLI_66 BOGADHI MANDYA_66	18:10	18:17	0:07	LINE FAULT
1210	8-May-22	MYSURU	66	SHEELUNERE-BOOKANKERE	BOOKANAKERE_66 CHINAKURALI_66 GANJIGERE_66	17:04	17:18	0:14	LINE FAULT
1211	8-May-22	MYSURU	66	THANDYA-NANJUNGUD	NANJAGUD_66	9:32	11:19	1:46	LINE CLEAR AVAILED
1212	8-May-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
1213	8-May-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
1214	8-May-22	TUMKUR	66	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	11:46	12:17	0:31	LINE CLEAR AVAILED
1215	8-May-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, BRAHMASANDRA_66,THOVINAKERE_66, ANKASANDRA_66	15:38	15:46	0:08	LINE FAULT
1216	8-May-22	TUMKUR	66	PAVAGADA220-SHYLAPURA_66	SHYLAPURA_66	3:30	3:40	0:10	LINE FAULT
1217	8-May-22	TUMKUR	66	TR-1	PAVAGADA_220	3:30	3:40	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1218	9-May-22	BAGALKOT	110	110/11KV, HV1	GADAG_110	11:05	11:19	0:14	TRANSFORMER FAULT
1219	9-May-22	BAGALKOT	110	110/11KV, HV1	HALKI_110	0:00	0:05	0:05	TRANSFORMER FAULT
1220	9-May-22	BAGALKOT	110	110/11KV, HV2	DEVANGOAN_110	15:52	15:58	0:06	TRANSFORMER FAULT
1221	9-May-22	BAGALKOT	110	110/11KV, HV2	KULIGOD_110	19:54	20:02	0:08	TRANSFORMER FAULT
1222	9-May-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED GIRISAGAR_110	9:40 (05.05.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
1223	9-May-22	BAGALKOT	110	110/11KV,HV1	UTTUR_110	19:27	19:31	0:04	TRANSFORMER FAULT
1224	9-May-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHVAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
1225	9-May-22	BAGALKOT	110	AMBEWADI- NK1 (KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	9:30 (09.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
1226	9-May-22	BAGALKOT	110	AMBEWADI- NK2 (HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	9:33 (09.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
1227	9-May-22	BAGALKOT	110	ANKOLA- KUMATA	ANKOLA_110	11:26	17:44	6:18	LINE CLEAR AVOIDED
1228	9-May-22	BAGALKOT	110	ATHANI220- AIGALI	AIGALI_110, KAKMARI_110, ALBAL_110, YALLAMANAWADI_110, SAVALAGI_110, TODALBAGI_110	4:58	5:15	0:17	LINE FAULT
1229	9-May-22	BAGALKOT	110	ATHANI220- AIGALI	AIGALI_110, KAKMARI_110, ALBAL_110, YALLAMANAWADI_110, SAVALAGI_110, TODALBAGI_110	6:57	7:10	0:13	LINE FAULT
1230	9-May-22	BAGALKOT	110	ATHANI220- ATHANI	STATION NOT AFFECTED ATHANI_220	12:07	12:10	0:03	LINE FAULT
1231	9-May-22	BAGALKOT	110	DAMBAL- AKHILAGYA SOLAR	DAMBAL_110	17:50	18:24	0:34	LINE FAULT
1232	9-May-22	BAGALKOT	110	KD JAMBAGI- MUDHOL	KD JAMBAGI_110	4:34	5:03	0:29	LINE FAULT
1233	9-May-22	BAGALKOT	110	KIADB BIJAPUR- BHUTNAL	KIADB BIJAPUR_110	15:53	15:59	0:06	LINE FAULT
1234	9-May-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVOIDED
1235	9-May-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
1236	9-May-22	BAGALKOT	110	SIRSI220- SIRSI2	SIRSI_220	15:43	19:05	3:22	NFBC ISSUED
1237	9-May-22	BAGALKOT	110	SIRSI220-SIRSI(KAWALWAD)	SIRSI_110	15:41	19:04	3:23	LINE CLEAR AVOIDED
1238	9-May-22	BAGALKOT	110	TIKOTA-TAKKALAKI	TAKKALAKI_110	5:30	12:38	7:08	LINE CLEAR AVOIDED
1239	9-May-22	BAGALKOT	110	TIKOTA-TAKKALAKI (BHUTANAL)	TAKKALAKI_110	12:30	12:48	0:18	LINE CLEAR AVOIDED
1240	9-May-22	BAGALKOT	220	220/110KV, HV1	KARWAR_220	13:40	14:45	1:05	LINE CLEAR AVOIDED
1241	9-May-22	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED BELGAUM_220	10:34 (24.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
1242	9-May-22	BAGALKOT	220	ATHANI- KAKMARI2	STATION NOT AFFECTED ATHANI_220	7:26 (09.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
1243	9-May-22	BAGALKOT	220	ATHANI-KAKMARI-1	STATION NOT AFFECTED ATHANI_220	9:04 (07.05.2022)		14:56	NFBC ISSUED
1244	9-May-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	9:18 (09.05.2022)			LINE OPEN:LINE CLEAR AVOIDED
1245	9-May-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1246	9-May-22	BAGALKOT	220	NARENDRA- BELGAUM2	STATION NOT AFFECTED NARENDRA_220	7:39 (07.05.2022)	15:10 (09.05.2022)	56:33 hrs	NFBC ISSUED
1247	9-May-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1248	9-May-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	13:20 (04.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1249	9-May-22	BENGALURU	66	Kengeri SATELLITE TOWN - CHANDRAPPA CIRCLE	CHANDRAPPA CIRCLE	0:00	0:55	0:55	LINE FAULT
1250	9-May-22	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT)	0:00	1:52	1:52	LINE FAULT
1251	9-May-22	GULBARGA	66	HV1	HALVAGALU_66	16:00	16:50	0:50	LINE CLEAR AVAILED
1252	9-May-22	GULBARGA	66	HV3	HALVAGALU_66	17:15	17:20	0:05	LINE CLEAR AVAILED
1253	9-May-22	GULBARGA	66	HV3	TELAGI_66	12:15	12:25	0:10	LINE CLEAR AVAILED
1254	9-May-22	GULBARGA	66	ITTAGI-KUDLIGI1	KOGALI_66,KUDLIGI_66,HANSI_66,CHOR NOOR_66,BANVIKAL_66	9:08	9:16	0:08	LINE FAULT
1255	9-May-22	GULBARGA	110	GALG-RAICHUR	GALAG_110	17:35	17:50	0:15	MAIN SUPPLY FAILURE
1256	9-May-22	GULBARGA	110	GUDEKOTE-KUDLIGI	GUDEKOTE_110	9:16	10:06	0:50	MAIN SUPPLY FAILURE
1257	9-May-22	GULBARGA	110	HUMNABAD-HUMNABAD_2	HUMNABAD_110	15:06(26/04/2022)	13:25(09.05.2022)	310:00HRS	LINE CHARGED
1258	9-May-22	GULBARGA	110	HV1	DEODURGA_110	17:20	17:30	0:10	TRANSFORMER FAULT
1259	9-May-22	GULBARGA	110	HV1	MATAMARI_110	11:20(08.05.2022)			TRANSFOMER OPEN:TRANSFORMER FAULT
1260	9-May-22	GULBARGA	110	HV1	SHAHAPUR_220	9:55	10:20	0:25	TRANSFORMER FAULT
1261	9-May-22	GULBARGA	110	HV3	VALKAMDINNI_110	10:50	11:02	0:12	TRANSFORMER FAULT
1262	9-May-22	GULBARGA	110	HV3	VALKAMDINNI_110	12:01	12:09	0:08	TRANSFORMER FAULT
1263	9-May-22	GULBARGA	110	KUSTAGI-TAWERGERE	TAWERGERE_110	9:56	15:35	5:39	LINE CLEAR AVAILED
1264	9-May-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	19:35	19:44	0:09	LINE FAULT
1265	9-May-22	GULBARGA	110	MUNIRABAD-HAGRI	HAGRI_110,SANKLAPUR_110,RBSNS,KAM ALAPUR_110	11:00	12:59	1:59	LINE FAULT
1266	9-May-22	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110	15:08	15:43	0:35	LINE FAULT
1267	9-May-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	5:50	5:58	0:08	LINE FAULT
1268	9-May-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAG ERA_110,SANNATHI_IPP,COREGREENSUG ARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
1269	9-May-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	23:57 (9.05.2022)			LINE OPEN:LINE FAULT
1270	9-May-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	5:46	5:52	0:06	LINE FAULT
1271	9-May-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	23:57 (9.05.2022)			LINE OPEN:LINE FAULT
1272	9-May-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	5:46	5:52	0:06	LINE FAULT
1273	9-May-22	GULBARGA	110	YAKATPUR-KAMTHANA	YAKATPUR_110	9:40	10:00	0:20	LINE CLEAR AVAILED
1274	9-May-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFOMER OPEN:TRANSFORMER FAULT
1275	9-May-22	GULBARGA	220	KUDLIGI-HIREMALLANAHALLI 1&2	KUDLIGI_220	17:25(08.05.2022)			LINE OPEN:LINE FAULT
1276	9-May-22	GULBARGA	220	RAICHUR-JURLA LINE1_IPP	RAICHUR_220	11:46	18:25	6:39	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1277	9-May-22	GULBARGA	400	BTPSG-HIRIYUR1	HIRIYUR_400	16:12(08.05.2022)	18:50(09.05.2022)	26:48HRS	LINE CHARGED
1278	9-May-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN:LINE FAULT
1279	9-May-22	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	10:45	11:05	0:20	LINE FAULT
1280	9-May-22	HASSAN	66	HASSN22-HN PURA	HASSAN_220	12:46	13:49	1:03	LINE CLEAR AVAILED
1281	9-May-22	HASSAN	66	HV1	DUDDA_66	15:40	16:55	1:15	LINE CLEAR AVAILED
1282	9-May-22	HASSAN	66	HV1	HOLEHONNUR_66	14:51	15:05	0:14	HAND TRIPPED
1283	9-May-22	HASSAN	66	HV1	MOSALEHOSAHALLI_66	12:55	14:05	1:10	LINE CLEAR AVAILED
1284	9-May-22	HASSAN	66	HV1	RAMESHWARNAGAR_66	11:35	12:45	1:10	LINE CLEAR AVAILED
1285	9-May-22	HASSAN	66	HV1	SAKALESH PURA_66	9:10	9:25	0:15	LINE CLEAR AVAILED
1286	9-May-22	HASSAN	66	HV2	HOLALUR_66	12:35	12:55	0:20	LINE CLEAR AVAILED
1287	9-May-22	HASSAN	66	HV2	HOLALUR_66	15:10	16:45	1:35	LINE CLEAR AVAILED
1288	9-May-22	HASSAN	66	HV2	HOLALUR_66	16:50	17:15	0:25	LINE CLEAR AVAILED
1289	9-May-22	HASSAN	66	HV2	RAMNATH PURA_66	15:59	16:02	0:03	LOAD CHANGE OVER
1290	9-May-22	HASSAN	66	HV2	SAKALESH PURA_66	9:10	17:49	8:39	LINE CLEAR AVAILED
1291	9-May-22	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	12:55	14:05	1:10	LINE CLEAR AVAILED
1292	9-May-22	HASSAN	66	MRSSHM-DVG1	MRS MG_220	7:58	8:10	0:12	LINE FAULT
1293	9-May-22	HASSAN	66	MRSSHM-DVG1	MRS MG_220	8:50	9:44	0:54	HAND TRIPPED
1294	9-May-22	HASSAN	66	RAMNAT-BNDSTHL	RAMNATH PURA_66	15:59	16:02	0:03	LOAD CHANGE OVER
1295	9-May-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATH PURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1296	9-May-22	HASSAN	66	SAKALE-IPCL1	SAKALESH PURA_66	9:54 (9.05.2022)			LINE OPEN:LINE CLEAR AVAILED
1297	9-May-22	HASSAN	66	SAKALE-IPCL2	SAKALESH PURA_66	9:54	20:16	10:22	LINE CLEAR AVAILED
1298	9-May-22	HASSAN	110	BARANG-SHR220	BARANGI_110	16:24	16:29	0:05	HAND TRIPPED
1299	9-May-22	HASSAN	110	BARANG-SHR220	BARANGI_110	16:56	17:56	1:00	LINE CLEAR AVAILED
1300	9-May-22	HASSAN	110	GURUVA-SLVPWR	GURUVAYANKERE_110	9:48	16:45	6:57	LINE CLEAR AVAILED
1301	9-May-22	HASSAN	110	HV2	KONAJE_110	10:46	10:51	0:05	LOAD CHANGE OVER
1302	9-May-22	HASSAN	110	HV2	KONAJE_110	13:28	13:32	0:04	LOAD CHANGE OVER
1303	9-May-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1304	9-May-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1305	9-May-22	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	10:35	13:05	2:30	LOAD CHANGE OVER
1306	9-May-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	9:07	18:29	9:22	LINE CLEAR AVAILED
1307	9-May-22	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	9:07	18:29	9:22	LINE CLEAR AVAILED
1308	9-May-22	HASSAN	110	SHIRAL-SANDA	SHIRALKOPPA_220	11:15	19:10	7:55	LINE CLEAR AVAILED
1309	9-May-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1310	9-May-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1311	9-May-22	MYSURU	66	AJJIPURA-COWDALLI	COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	4:05	4:30	0:25	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1312	9-May-22	MYSURU	66	BEGUR 220-GUNDLUPETE 2	NO STATIONS EFFECTED	18:53	19:04	0:11	LINE FAULT
1313	9-May-22	MYSURU	66	CR NAGARA-D R PETE 2	NO STATIONS EFFECTED	8:34:11 (8.5.2022)	18:32:00 (9.5.2022)	33:57 hrs	LINE CHARGED
1314	9-May-22	MYSURU	66	CR NAGAR-DR PETE1	NO STATIONS EFFECTED	10:55	18:32	7:36	LINE CLEAR AVAILED
1315	9-May-22	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36:34 (30/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1316	9-May-22	MYSURU	66	GUNDALPETE-BEGUR	NO STATIONS EFFECTED	18:54	19:09	0:15	LINE FAULT
1317	9-May-22	MYSURU	66	GUNDALPETE-KABBALLI	NO STATIONS EFFECTED	6:02	6:24	0:22	LINE FAULT
1318	9-May-22	MYSURU	66	HANNUR-MADHUVANAHALLI2	NO STATIONS EFFECTED	3:46	3:51	0:05	LINE FAULT
1319	9-May-22	MYSURU	66	HARADANAHALLI(JAK)-LAXJEET	NO STATIONS EFFECTED	7:58	8:06	0:07	LINE FAULT
1320	9-May-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1321	9-May-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1322	9-May-22	MYSURU	66	HV1	BG NAGAR_66	22:55	23:40	0:44	LINE CLEAR AVAILED
1323	9-May-22	MYSURU	66	HV1	BILIKERE_66	12:35	14:32	1:57	LINE CLEAR AVAILED
1324	9-May-22	MYSURU	66	HV1	CHUNCHUNKATTE_66	11:43	13:12	1:28	LINE CLEAR AVAILED
1325	9-May-22	MYSURU	66	HV1	COWDALLI_66	4:10	5:30	1:20	TRANSFORMER FAULT
1326	9-May-22	MYSURU	66	HV1	COWDALLI_66	14:55	15:25	0:30	LINE CLEAR AVAILED
1327	9-May-22	MYSURU	66	HV1	MADIKERI-66	12:31	13:35	1:03	LINE CLEAR AVAILED
1328	9-May-22	MYSURU	66	HV2	BG NAGAR_66	22:54	23:40	0:45	LINE CLEAR AVAILED
1329	9-May-22	MYSURU	66	HV2	CHIKKAMANDYA_66	12:30	12:47	0:17	LINE CLEAR AVAILED
1330	9-May-22	MYSURU	66	HV2	COWDALLI_66	14:55	15:25	0:30	LINE CLEAR AVAILED
1331	9-May-22	MYSURU	66	HV2	HONNALLY_66	12:13	16:06	3:52	LINE CLEAR AVAILED
1332	9-May-22	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	10:57:05 (4/5/2022)			LINE OPEN:LINE CLEAR AVAILED
1333	9-May-22	MYSURU	66	MUGUR-MADHUVANAHALLI	NO STATIONS EFFECTED	10:31	18:49	8:17	LINE CLEAR AVAILED
1334	9-May-22	MYSURU	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	19:05	19:14	0:09	LINE FAULT
1335	9-May-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
1336	9-May-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20/03/2022)			LINE OPEN:LINE CLEAR AVAILED
1337	9-May-22	MYSURU	220	NAGAMANGALA 220-HV 1	NAGAMANGALA_220 GUDDENAHALLI_66 KOPPA_66 BOGADHI MANDYA_66 DUNDANAHALLI_66 BESAGARAHALLI_66	20:54	21:12	0:18	HAND TRIPPED
1338	9-May-22	MYSURU	220	NAGAMANGALA 220HV 2	NO STATIONS EFFECTED	20:54	21:12	0:18	HAND TRIPPED
1339	9-May-22	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLTEGERE	KOLTEGERE,CHIKKATOTLUKERE_66, BELADARA_66	18:43	19:01	0:42	LINE FAULT
1340	9-May-22	TUMKUR	66	ANTHRASANAHALLI 220KV-TUMKUR	TUMKUR_66	10:30	11:12	0:18	LINE CLEAR AVAILED
1341	9-May-22	TUMKUR	66	HIRIYUR 220KV-P R PURA	P R PURA_66	19:30	20:55	0:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1342	9-May-22	TUMKUR	66	NAGALAMADIKE-RNS INFRA SOLAR_IPP_66	RNS INFRA SOLAR_IPP_66	18:45	20:15	3:00	MAIN SUPPLY FAILURE
1343	9-May-22	TUMKUR	66	PDKOTE66-HIRIYUR_66	PD KOTE_66	19:27	21:12	0:42	MAIN SUPPLY FAILURE
1344	9-May-22	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEI DIAMOND SOLAR_IPP_66	18:28	21:10	2:42	LINE CLEAR AVAILED
1345	9-May-22	TUMKUR	66	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	18:28	21:10	1:25	LINE CLEAR AVAILED
1346	9-May-22	TUMKUR	66	TR-1	KIADB V N PURA_220	11:22	15:58	2:42	LINE CLEAR AVAILED
1347	9-May-22	TUMKUR	110	TR-1	SHETYKERE_110	12:30	15:30	4:36	LINE CLEAR AVAILED

