

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM:03.03.2020 TO 09.03.2020

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	3-Mar-2020	BAGALKOT	110	110/11KV,HV 2	AMBEWADI_220	10:10	13:54	3:44	LINE CLEAR AVAILED
2	3-Mar-2020	BAGALKOT	110	110/11KV,HV1	BILAGI_110	8:14	8:18	0:04	TRANSFORMER FAULT
3	3-Mar-2020	BAGALKOT	110	110/11KV,HV 1	GULEDGUDDA_110	12:09	12:28	0:19	LINE CLEAR AVAILED
4	3-Mar-2020	BAGALKOT	110	110/33KV,HV 2	GULEDGUDDA_110,SHIRUR_33,KAMATAGI_33	13:33	13:50	0:17	LINE CLEAR AVAILED
5	3-Mar-2020	BAGALKOT	110	110/11KV,HV 1	GUTTAL_110	10:58	11:34	0:36	HAND TRIPPED
6	3-Mar-2020	BAGALKOT	110	110/33KV,HV 2	HUNGUND-110 &33KV KARADI	12:11	12:14	0:03	TRANSFORMER FAULT
7	3-Mar-2020	BAGALKOT	110	AMBEWADI-KAVALAWAD	KAVALWAD_110	10:04	13:43	3:39	LINE CLEAR AVAILED
8	3-Mar-2020	BAGALKOT	110	110/11KV,HV 1	KUMATA_110	16:30	17:30	1:00	LINE CLEAR AVAILED
9	3-Mar-2020	BAGALKOT	220	RAVIURJA 1&2-ATHANI	ATHANI_220	0:00	8:53	8:53	LINE CLEAR AVAILED
10	3-Mar-2020	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	3:18	3:36	0:18	LINE FAULT
11	3-Mar-2020	BAGALKOT	220	CHIKKODI-KUDACHI	CHIKKODI_220	12:32	14:40	2:08	NFBC ISSUED
12	3-Mar-2020	BAGALKOT	110	110/33KV,HV 3	GHATAPRABHA_110&GOKAK MILL&KALLOLLI	12:16	12:20	0:04	TRANSFORMER FAULT
13	3-Mar-2020	BAGALKOT	110	110/33KV,HV 3	GHATAPRABHA_110&GOKAK MILL&KALLOLLI	14:59	15:14	0:15	TRANSFORMER FAULT
14	3-Mar-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, HALSANGI_33, DHULKED_33	10:41	10:47	0:06	TRANSFORMER FAULT
15	3-Mar-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, HALSANGI_33, DHULKED_33	11:16	11:23	0:07	TRANSFORMER FAULT
16	3-Mar-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, HALSANGI_33, DHULKED_33	22:18	22:25	0:07	TRANSFORMER FAULT
17	3-Mar-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, HALSANGI_33, DHULKED_33	22:56	23:02	0:06	TRANSFORMER FAULT
18	3-Mar-2020	BAGALKOT	110	110/11KV, HV2	VAJRAMATTI_110	15:44	16:23	0:39	TRANSFORMER FAULT
19	3-Mar-2020	BAGALKOT	110	110/11KV, HV2	VAJRAMATTI_110	17:10	17:59	0:49	LINE CLEAR AVAILED
20	3-Mar-2020	BAGALKOT	110	110/11KV, HV3	YARGATTI_110	17:40	17:49	0:09	LINE CLEAR AVAILED
21	3-Mar-2020	BAGALKOT	110	110/11KV, HV2	YARGATTI_110	17:26	17:49	0:23	LINE CLEAR AVAILED
22	3-Mar-2020	BAGALKOT	110	110/33KV,HV1	YARGATTI_110, SHIVAPURA_33, CHINCHNURLIS_33, BOSH SOLAR_33	17:49	18:02	0:13	LINE CLEAR AVAILED
23	3-Mar-2020	BAGALKOT	110	NOKAR SOLAR-UDIKERI	UDIKERI_110	18:51	21:16	2:25	LINE CLEAR AVAILED
24	3-Mar-2020	BAGALKOT	110	SOUDATTI220-RAMDURGA2	RAMDURGA_110	10:03	16:27	6:24	LINE CLEAR AVAILED
25	3-Mar-2020	BAGALKOT	110	SOUDATTI220-RAMDURGA1	RAMDURGA_110	14:12	16:26	2:14	LINE CLEAR AVAILED
26	3-Mar-2020	BAGALKOT	220	SHARAVATHY1-SIRSI	SIRSI_220	18:49	23:59	5:10	LINE CLEAR AVAILED
27	3-Mar-2020	BAGALKOT	220	SHARAVATHY2-SIRSI	SIRSI_220	18:50	23:59	5:09	LINE CLEAR AVAILED
28	3-Mar-2020	BAGALKOT	110	110/11KV, HV2	SINDAGI_110	13:59	15:15	1:16	LINE CLEAR AVAILED
29	3-Mar-2020	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:46	14:38	1:52	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
30	3-Mar-2020	BAGALKOT	110	110/11KV, HV1	SHIRGUPPI_110	11:41	12:58	1:17	LINE CLEAR AVAILED
31	3-Mar-2020	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	10:59	11:26	0:27	LINE CLEAR AVAILED
32	3-Mar-2020	BAGALKOT	110	RANEENNUR-RATTIHALLI (HONNATTI)	HONNATTI_110	15:46	16:15	0:29	HAND TRIPPED
33	3-Mar-2020	BAGALKOT	110	RANEENNUR-AREMALLAPUR (TUMMINKATTI)	TUMMINKATTI_110	15:45	16:15	0:30	HAND TRIPPED
34	3-Mar-2020	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110	15:46	16:22	0:36	HAND TRIPPED
35	3-Mar-2020	BAGALKOT	220	KUDACHI-GHATAPRABHA	KUDACHI_220	11:00	14:41	3:41	LINE CLEAR AVAILED
36	3-Mar-2020	BENGALURU	66	HV1	VOLVO	17:36	18:08	0:31	TRANSFORMER FAULT
37	3-Mar-2020	BENGALURU	220	HV1	SARJAPURA 220	9:40	15:29	5:49	LINE CLEAR AVAILED
38	3-Mar-2020	BENGALURU	220	HV2	SARJAPURA 220	15:30	19:30	4:00	LINE CLEAR AVAILED
39	3-Mar-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	9:32	9:40	0:08	LINE CLEAR AVAILED
40	3-Mar-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	15:23	15:38	0:15	LINE CLEAR AVAILED
41	3-Mar-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	15:22	15:39	0:17	LINE CLEAR AVAILED
42	3-Mar-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	19:16	19:32	0:15	LINE CLEAR AVAILED
43	3-Mar-2020	BENGALURU	66	HV2	MULBALGLU	7:15	7:25	0:10	TRANSFORMER FAULT
44	3-Mar-2020	BENGALURU	66	SRS PEENYA 220 - NELAKADRINAHALLI	NELAKADRINAHALLI	9:38	10:46	1:08	LINE FAULT
45	3-Mar-2020	BENGALURU	220	HSR 220 - SOMANAHALLI 220	HSR 220	20:36	21:18	0:42	LINE FAULT
46	3-Mar-2020	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	20:36	21:30	0:54	LINE CLEAR AVAILED
47	3-Mar-2020	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI, BOSCH (EHT)	20:36	21:30	0:54	LINE CLEAR AVAILED
48	3-Mar-2020	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	20:36	21:24	0:48	LINE CLEAR AVAILED
49	3-Mar-2020	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	20:36	23:21	2:45	LINE FAULT
50	3-Mar-2020	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	20:36	21:26	0:50	LINE CLEAR AVAILED
51	3-Mar-2020	BENGALURU	220	HV1	HSR 220	20:36	21:20	0:44	LINE CLEAR AVAILED
52	3-Mar-2020	BENGALURU	220	HV3	HSR 220	20:36	21:20	0:44	LINE CLEAR AVAILED
53	3-Mar-2020	BENGALURU	66	HSR 220 - CESSNA	KADUBISANAHALLI,CESSNA	20:36	23:10	2:34	LINE CLEAR AVAILED
54	3-Mar-2020	BENGALURU	66	HV1	KHODAYS 220	23:47	23:59	0:12	TRANSFORMER FAULT
55	3-Mar-2020	BENGALURU	220	HV2	NRS 220	23:56	23:59	0:03	LINE CLEAR AVAILED
56	3-Mar-2020	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1 & 2	TELECOM LAYOUT	23:56	23:59	0:03	LINE CLEAR AVAILED
57	3-Mar-2020	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	23:56	23:59	0:03	LINE CLEAR AVAILED
58	3-Mar-2020	BENGALURU	66	NRS 220 - VIJAY NGR MY2	VIJAYANAGARA	23:56	23:59	0:03	LINE CLEAR AVAILED
59	3-Mar-2020	BENGALURU	66	VICTORIA - NRS 220	VICTORIA	0:15	0:18	0:03	LOAD CHANGE OVER
60	3-Mar-2020	BENGALURU	220	SOMANAHALLI 220 - HSR LAYOUT 220	HSR LAYOUT 220	20:36	21:10	0:34	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
61	3-Mar-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	20:39	20:48	0:09	LINE FAULT
62	3-Mar-2020	BENGALURU	66	HV2	HONNIGANAHALLI	2:51	3:20	0:29	TRANSFORMER FAULT
63	3-Mar-2020	BENGALURU	66	HV2	HONNIGANAHALLI	23:45	23:55	0:10	TRANSFORMER FAULT
64	3-Mar-2020	GULBARGA	220	HV4	KUSTIGI_220	13:53	14:15	0:22	LINE CLEAR AVAILED
65	3-Mar-2020	GULBARGA	220	SEDAM-RTPS1	SEDAM-220	15:55	16:20	0:25	LINE FAULT
66	3-Mar-2020	GULBARGA	220	SEDAM-RTPS2	SEDAM-220	15:55	17:25	1:30	LINE FAULT
67	3-Mar-2020	GULBARGA	220	SEDAM-RTPS1	SEDAM-220	16:20	17:20	1:00	LINE FAULT
68	3-Mar-2020	GULBARGA	220	SEDAM-RTPS1	SEDAM-220	17:20	18:10	0:50	LINE CLEAR AVAILED
69	3-Mar-2020	GULBARGA	220	SEDAM-RTPS2	SEDAM-220	17:25	18:30	1:05	LINE CLEAR AVAILED
70	3-Mar-2020	GULBARGA	220	SEDAM-RTPS2	SEDAM-220	18:30	23:59	5:29	NFBC ISSUED
71	3-Mar-2020	GULBARGA	110	MALLAT 220-BYAGAWAT	BYAGAWAT_110	4:12	4:27	0:15	LINE FAULT
72	3-Mar-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_IPP	4:18	4:26	0:08	LINE FAULT
73	3-Mar-2020	GULBARGA	110	MALLAT 220-BYAGAWAT	BYAGAWAT_110	4:34	4:46	0:12	LINE FAULT
74	3-Mar-2020	GULBARGA	110	MALLAT 220-BYAGAWAT	BYAGAWAT_110	4:50	5:00	0:10	LINE FAULT
75	3-Mar-2020	GULBARGA	110	MALLAT 220-BYAGAWAT	BYAGAWAT_110	5:09	5:20	0:11	LINE FAULT
76	3-Mar-2020	GULBARGA	110	MALLAT 220-BYAGAWAT	BYAGAWAT_110	5:28	7:22	1:54	LINE FAULT
77	3-Mar-2020	GULBARGA	110	HV3	BEVOOR_110	5:41	7:29	1:48	LINE CLEAR AVAILED
78	3-Mar-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_IPP	6:01	6:07	0:06	LINE FAULT
79	3-Mar-2020	GULBARGA	110	HV1	TAMBRAHALLI_66	13:50	13:55	0:05	TRANSFORMER FAULT
80	3-Mar-2020	GULBARGA	110	KUSTAGI-INRSLR_IPP	KUSTIGI_220	18:16	22:30	4:14	LINE CLEAR AVAILED
81	3-Mar-2020	GULBARGA	110	KUDITINI-BELLARY	BELLARY_110	18:20	18:45	0:25	LINE FAULT
82	3-Mar-2020	GULBARGA	110	VALKAMDINI-SIDHANOOR	VALKAMDINI_110	20:05	20:13	0:08	MAIN SUUPPLY FAILURE
83	3-Mar-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KEMBHAVI_110,HUNASIGI_110,ASKI_110	22:23	22:28	0:05	LINE FAULT
84	3-Mar-2020	GULBARGA	66	ITTAGI-HIREHADAGALLI-1	HIREHADAGALLI_66	1:52	2:05	0:13	LINE FAULT
85	3-Mar-2020	GULBARGA	66	ITTAGI-KUDALIGI-1	KOGALI_66,KUDLIGI_66,HANASI_66,	6:13	6:25	0:12	HAND TRIPPED
86	3-Mar-2020	GULBARGA	66	ITTAGI-KUDALIGI-2	CJ HALLI_66,GUDEKOTE_66,HOSAHALLI_66,BAN VEKAL_66,CHORNOOR_66	6:13	6:25	0:12	HAND TRIPPED
87	3-Mar-2020	GULBARGA	66	ITTAGI-HIREHADAGALLI-1	HIREHADAGALLI_66	9:58	10:18	0:20	LINE FAULT
88	3-Mar-2020	GULBARGA	66	ITTAGI-HIREHADAGALLI-1	HIREHADAGALLI_66	10:25	10:28	0:03	LINE FAULT
89	3-Mar-2020	HASSAN	400	HASSAN4-NLM400	HASSAN_400	17:10	19:11	2:01	LINE CLEAR AVAILED
90	3-Mar-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:50	19:27	2:37	NFBC ISSUED
91	3-Mar-2020	HASSAN	220	ARSK2-HSN	ARASIKERE_220	0:00	19:22	19:22	NFBC ISSUED
92	3-Mar-2020	HASSAN	220	KADUR-DABUSET	KADUR_220	0:00	19:49	19:49	NFBC ISSUED
93	3-Mar-2020	HASSAN	220	HV1	MSEZ_220	10:06	14:39	4:33	LINE CLEAR AVAILED
94	3-Mar-2020	HASSAN	110	HV1	KADUR_220	10:11	13:55	3:44	LINE CLEAR AVAILED
95	3-Mar-2020	HASSAN	110	LV1	MSEZ_220	10:05	14:40	4:35	LINE CLEAR AVAILED
96	3-Mar-2020	HASSAN	110	HV1	HALADY_110	11:31	12:07	0:36	LINE CLEAR AVAILED
97	3-Mar-2020	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	9:43	9:44	0:01	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
98	3-Mar-2020	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	17:37	18:07	0:30	HAND TRIPPED
99	3-Mar-2020	HASSAN	110	HV1	BRAHMAVARA_110	9:42	18:07	8:25	LINE CLEAR AVOIDED
100	3-Mar-2020	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	16:28	17:21	0:53	HAND TRIPPED
101	3-Mar-2020	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	17:24	17:30	0:06	HAND TRIPPED
102	3-Mar-2020	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	6:58	7:07	0:09	LINE FAULT
103	3-Mar-2020	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	16:28	16:46	0:18	HAND TRIPPED
104	3-Mar-2020	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	8:30	13:53	5:23	LINE CLEAR AVOIDED
105	3-Mar-2020	HASSAN	66	BANDISH-HNPURA	BANDISHETTYHALLI_66	8:30	13:53	5:23	LINE CLEAR AVOIDED
106	3-Mar-2020	HASSAN	66	HV1	BANDISHETTYHALLI_66	8:30	13:53	5:23	LINE CLEAR AVOIDED
107	3-Mar-2020	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	8:30	13:53	5:23	LINE CLEAR AVOIDED
108	3-Mar-2020	HASSAN	66	HV1	BYACHANAHALLI_66	11:22	12:03	0:41	LINE CLEAR AVOIDED
109	3-Mar-2020	HASSAN	66	HV2	CHIKKAKONDAGOLA_66	6:49	11:37	4:48	LINE CLEAR AVOIDED
110	3-Mar-2020	HASSAN	66	HV1	DODDAKADANUR_66	16:33	17:19	0:46	LINE CLEAR AVOIDED
111	3-Mar-2020	HASSAN	66	DUDDA-CKNDGL	DUDDA_66	11:02	13:31	2:29	LINE CLEAR AVOIDED
112	3-Mar-2020	HASSAN	66	HV1	DUDDA_66	11:02	13:32	2:30	LINE CLEAR AVOIDED
113	3-Mar-2020	HASSAN	66	HV1	HANBALU_66	12:32	12:40	0:08	NFBC ISSUED
114	3-Mar-2020	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	12:25	12:45	0:20	NFBC ISSUED
115	3-Mar-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	11:33	11:49	0:16	LINE CLEAR AVOIDED
116	3-Mar-2020	HASSAN	66	MALALI-CRPATNA	MALALI_66	17:32	18:01	0:29	LINE FAULT
117	3-Mar-2020	HASSAN	66	MSALEH-HNPRA	MOSALEHOSAHALLI_66	11:02	13:42	2:40	NFBC ISSUED
118	3-Mar-2020	HASSAN	66	HV1	MOSALEHOSAHALLI_66	11:01	13:42	2:41	NFBC ISSUED
119	3-Mar-2020	HASSAN	66	MRSSHM-DVG2	MRSMG_220	8:34	8:39	0:05	LINE FAULT
120	3-Mar-2020	HASSAN	66	MRSSHM-DVG2	MRSMG_220	15:52	16:00	0:08	LINE FAULT
121	3-Mar-2020	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	15:52	16:00	0:08	LINE FAULT
122	3-Mar-2020	HASSAN	66	SAKALE-HANBAL	SAKLESHPUR_66	11:29	11:37	0:08	HAND TRIPPED
123	3-Mar-2020	HASSAN	66	SAKALE-HANBAL	SAKLESHPUR_66	12:15	12:43	0:28	LINE CLEAR AVOIDED
124	3-Mar-2020	HASSAN	66	SAKALE-HANBAL	SAKLESHPUR_66	16:05	16:16	0:11	LINE FAULT
125	3-Mar-2020	HASSAN	66	SAKALE-HASSAN	SAKLESHPUR_66	11:41	11:49	0:08	HAND TRIPPED
126	3-Mar-2020	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	6:48	7:01	0:13	LINE FAULT
127	3-Mar-2020	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	6:48	7:03	0:15	LINE FAULT
128	3-Mar-2020	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	6:48	7:10	0:22	LINE FAULT
129	3-Mar-2020	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	6:58	7:12	0:14	LINE FAULT
130	3-Mar-2020	MYSORE	66	HV1	BANNUR_66	9:26	9:37	0:11	TRANSFORMER FAULT
131	3-Mar-2020	MYSORE	66	HV2	COWDALLI_66	12:05	12:12	0:06	TRANSFORMER FAULT
132	3-Mar-2020	MYSORE	66	GUNDLUPETE-BEGUR	BEGUR_66	6:34	16:39	10:04	NFBC ISSUED
133	3-Mar-2020	MYSORE	66	HV1	GUNDULPET_66	12:20	12:28	0:07	HAND TRIPPED
134	3-Mar-2020	MYSORE	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66, HOSURGATE_66	10:13	14:59	4:46	NFBC ISSUED
135	3-Mar-2020	MYSORE	66	HUNSUR-HOOTAGALLI	BANNIKUPPE_66, HOSURGATE_66	10:15	16:54	6:39	NFBC ISSUED
136	3-Mar-2020	MYSORE	66	MADHUVANALLI-PG PALYA	PGPALYA_66	10:45	10:51	0:05	LINE FAULT
137	3-Mar-2020	MYSORE	66	HV1	MADIKERI_66	9:57	12:00	2:03	LINE CLEAR AVOIDED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
138	3-Mar-2020	MYSORE	66	HV1	MADIKERI_66	13:19	13:33	0:13	TRANSFORMER FAULT
139	3-Mar-2020	MYSORE	66	HV2	MADIKERI_66	12:00	13:19	1:19	LINE CLEAR AVAILED
140	3-Mar-2020	MYSORE	66	NANJANAGUDU-BEGUR	SINDHUVALLI_66	17:03	17:15	0:12	LINE FAULT
141	3-Mar-2020	MYSORE	66	PANDAVAPURA-TUBINKERE	DODDABYADARAHALLI_66, GARUDANAUKADDA_66, PANDAVAPURA_66, SRIRANGAPATNA_66	13:18	13:58	0:40	HAND TRIPPED
142	3-Mar-2020	MYSORE	66	HV2	SATHEGALA_66	17:36	18:30	0:53	LINE CLEAR AVAILED
143	3-Mar-2020	MYSORE	66	SINDUVALLI-KADAKOLA	SINDHUVALLI_66	17:08	17:56	0:48	LINE CLEAR AVAILED
144	3-Mar-2020	MYSORE	66	TARIPURA-TUBINAKERE	TARIPURA_66	13:42	13:54	0:11	LINE FAULT
145	3-Mar-2020	MYSORE	66	TARIPURA-TUBINAKERE	TARIPURA_66	18:46	18:54	0:08	LINE FAULT
146	3-Mar-2020	MYSORE	66	TN PURA-THAYUR	TNARASIPURA_66	17:05	17:10	0:04	HAND TRIPPED
147	3-Mar-2020	TUMKUR	400	TR-1(HV SIDE)	GUTUR_400	15:46	16:20	0:33	HAND TRIPPED
148	3-Mar-2020	TUMKUR	220	TR-1	CHITRADURGA_220	10:12	15:08	4:56	LINE CLEAR AVAILED
149	3-Mar-2020	TUMKUR	220	TR-2	KBCROSS_220	15:35	15:52	0:17	LINE CLEAR AVAILED
150	3-Mar-2020	TUMKUR	220	TR-1	KBCROSS_220	15:58	16:12	0:13	LINE CLEAR AVAILED
151	3-Mar-2020	TUMKUR	110	HONNAVALLI 110-ADAN SOLAR_	ADAN SOLAR_IPP_66	16:14	16:24	0:09	HAND TRIPPED
152	3-Mar-2020	TUMKUR	110	HONNAVALLI 110-DMKURKE	DMKURKE_110	16:14	16:27	0:13	HAND TRIPPED
153	3-Mar-2020	TUMKUR	110	HONNAVALLI 110- KADUR	HONNAVALLI_110	16:17	16:23	0:06	HAND TRIPPED
154	3-Mar-2020	TUMKUR	110	HONNAVALLI 110- KADUR	HONNAVALLI_110	18:18	18:21	0:03	HAND TRIPPED
155	3-Mar-2020	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	16:02	18:33	2:30	LINE CLEAR AVAILED
156	3-Mar-2020	TUMKUR	110	TR-1	BIDARE_110	12:24	12:39	0:14	LINE CLEAR AVAILED
157	3-Mar-2020	TUMKUR	110	TR-2	SAMPIGE_110	12:34	14:14	1:40	LINE CLEAR AVAILED
158	3-Mar-2020	TUMKUR	110	TR-1	SHETYKERE_110	15:24	15:43	0:19	LINE CLEAR AVAILED
159	3-Mar-2020	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	17:13	17:23	0:09	LINE FAULT
160	3-Mar-2020	TUMKUR	66	TR-2	CHITRADURGA_220	10:58	11:12	0:14	LINE CLEAR AVAILED
161	3-Mar-2020	TUMKUR	66	TR-2	CHITRADURGA_220	23:37	23:45	0:07	LINE CLEAR AVAILED
162	3-Mar-2020	TUMKUR	66	TR-1(LV1 SIDE)	CHITRADURGA_220	10:12	15:09	4:56	LINE CLEAR AVAILED
163	3-Mar-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	10:07	11:35	1:27	LINE CLEAR AVAILED
164	3-Mar-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	10:11	10:47	0:35	HAND TRIPPED
165	3-Mar-2020	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	11:34	11:51	0:17	HAND TRIPPED
166	3-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	9:40	9:51	0:10	LINE FAULT
167	3-Mar-2020	TUMKUR	66	TR-1	GARAGA_66	16:53	18:50	1:56	LINE CLEAR AVAILED
168	3-Mar-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	8:18	9:04	0:45	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
169	3-Mar-2020	TUMKUR	66	TR-1	HONNALI_66	15:11	17:49	2:37	LINE CLEAR AVAILED
170	3-Mar-2020	TUMKUR	66	TR-3	HONNALI_66	10:46	15:35	4:48	LINE CLEAR AVAILED
171	3-Mar-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	4:01	4:30	0:29	LINE FAULT
172	3-Mar-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	9:39	9:48	0:09	LINE FAULT
173	3-Mar-2020	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:58	14:09	2:11	LINE CLEAR AVAILED
174	3-Mar-2020	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	15:51	16:06	0:15	LINE FAULT
175	3-Mar-2020	TUMKUR	66	TR-1	TAVAREKERE(C)_66	18:50	19:04	0:13	MAIN SUUPPLY FAILURE
176	4-Mar-2020	BAGALKOT	110	110/11KV,HV 2	AMBEWADI_220	10:07	18:30	8:23	LINE CLEAR AVAILED
177	4-Mar-2020	BAGALKOT	110	110/11KV,HV1	ANKOLA_110	10:05	12:40	2:35	LINE CLEAR AVAILED
178	4-Mar-2020	BAGALKOT	110	110/33KV,HV2	ANKOLA_110 &33KV MASTIKATTA & SEABIRD	13:03	13:23	0:20	LINE CLEAR AVAILED
179	4-Mar-2020	BAGALKOT	110	110/11KV,HV 2	BABLESHWAR_110	8:25	8:40	0:15	HAND TRIPPED
180	4-Mar-2020	BAGALKOT	110	110/11KV,HV 2	BABLESHWAR_110	11:03	11:08	0:05	HAND TRIPPED
181	4-Mar-2020	BAGALKOT	110	110/11KV,HV 1	BABLESHWAR_110	11:04	11:08	0:04	HAND TRIPPED
182	4-Mar-2020	BAGALKOT	110	110/11KV,HV 2	BANAHATTI_110	11:07	13:33	2:26	LINE CLEAR AVAILED
183	4-Mar-2020	BAGALKOT	110	110/11KV,HV 2	BANAHATTI_110	15:33	16:05	0:32	LINE CLEAR AVAILED
184	4-Mar-2020	BAGALKOT	110	DAMBAL-EILS(L1)	DAMBAL_110	13:13	17:24	4:11	NFBC ISSUED
185	4-Mar-2020	BAGALKOT	110	110/33KV,HV2	HANAGAL_110	12:00	12:11	0:11	TRANSFORMER FAULT
186	4-Mar-2020	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	17:31	17:34	0:03	HAND TRIPPED
187	4-Mar-2020	BAGALKOT	110	110/11KV,HV 2	HIDIKAL DAM_110	14:15	14:38	0:23	HAND TRIPPED
188	4-Mar-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, ALSANGI_33, NEVARGI_33, DHILKED_33	12:34	16:56	4:22	LINE CLEAR AVAILED
189	4-Mar-2020	BAGALKOT	220	SOUDATTI220-SOUDATTI1	SOUDATTI_110	11:07	13:17	2:10	LINE CLEAR AVAILED
190	4-Mar-2020	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	15:53	16:18	0:25	LINE FAULT
191	4-Mar-2020	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	16:26	23:59	7:33	LINE FAULT
192	4-Mar-2020	BAGALKOT	220	SHARAVAHTY1-SIRSI	SIRSI_220	0:00	13:55	13:55	LINE CLEAR AVAILED
193	4-Mar-2020	BAGALKOT	220	SHARAVAHTY2-SIRSI	SIRSI_220	0:00	13:56	13:56	LINE CLEAR AVAILED
194	4-Mar-2020	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	13:02	14:55	1:53	LINE CLEAR AVAILED
195	4-Mar-2020	BAGALKOT	110	110/11KV, HV1&HV2	NIDAGUNDI_110	10:38	22:29	11:51	LINE CLEAR AVAILED
196	4-Mar-2020	BAGALKOT	110	110/11KV, HV2	NAVALGUND_110	10:29	15:59	5:30	LINE CLEAR AVAILED
197	4-Mar-2020	BAGALKOT	110	MUKARTIHAL-NIDAGUNDI(BAGEWADI2)	NIDAGUNDI_110	12:26	20:10	7:44	LINE CLEAR AVAILED
198	4-Mar-2020	BAGALKOT	220	NARENDRA-BIDNAL	NARENDRA_220	11:40	15:54	4:14	LINE CLEAR AVAILED
199	4-Mar-2020	BAGALKOT	220	220/110KV, HV2&LV2	MK HUBLI_220	11:50	16:04	4:14	LINE CLEAR AVAILED
200	4-Mar-2020	BAGALKOT	110	MKHUBLI220-MKHUBLI	MK HUBLI_110	10:38	22:09	11:31	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
201	4-Mar-2020	BAGALKOT	220	KUDACHI-CHIKKODI	KUDACHI_220	12:55	15:46	2:51	LINE CLEAR AVAILED
202	4-Mar-2020	BAGALKOT	110	110/11KV, HV4	KERUR_110	12:26	12:51	0:25	LINE CLEAR AVAILED
203	4-Mar-2020	BAGALKOT	110	110/11KV, HV4	KERUR_110	14:33	14:54	0:21	LINE CLEAR AVAILED
204	4-Mar-2020	BENGALURU	66	HV1	SARJAPURA 220	11:15	11:20	0:04	LINE CLEAR AVAILED
205	4-Mar-2020	BENGALURU	66	HV2	MANCHENAHALLI	11:01	11:08	0:07	TRANSFORMER FAULT
206	4-Mar-2020	BENGALURU	66	HV2	MANCHENAHALLI	15:00	15:09	0:09	TRANSFORMER FAULT
207	4-Mar-2020	BENGALURU	66	HV1	VOLVO	8:37	10:27	1:49	TRANSFORMER FAULT
208	4-Mar-2020	BENGALURU	66	HV2	BAGEPALLI	12:27	12:32	0:04	LINE CLEAR AVAILED
209	4-Mar-2020	BENGALURU	66	HV2	HONNIGANAHALLI	4:06	4:15	0:08	TRANSFORMER FAULT
210	4-Mar-2020	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	5:18	5:25	0:07	LOAD CHANGE OVER
211	4-Mar-2020	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	17:35	17:56	0:21	LINE FAULT
212	4-Mar-2020	BENGALURU	66	WELCAST STEEL - DG 3	WELCAST STEEL	11:11	11:18	0:07	LOAD CHANGE OVER
213	4-Mar-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:10	11:16	0:05	LINE CLEAR AVAILED
214	4-Mar-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	13:54	13:59	0:05	LINE CLEAR AVAILED
215	4-Mar-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	5:30	5:36	0:05	LOAD CHANGE OVER
216	4-Mar-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	10:50	10:52	0:02	LOAD CHANGE OVER
217	4-Mar-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	5:52	5:59	0:06	LINE FAULT
218	4-Mar-2020	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, BEVOOR, SANKALGERE	16:39	16:50	0:11	LINE FAULT
219	4-Mar-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	10:13	10:45	0:31	LOAD CURTAILMENT
220	4-Mar-2020	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	9:07	9:44	0:37	LOAD CURTAILMENT
221	4-Mar-2020	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASANUR	9:44	10:13	0:29	LOAD CURTAILMENT
222	4-Mar-2020	BENGALURU	66	ADUGODI - HSR 1 & 2	ADUGODI, BOSCH (EHT)	13:55	14:00	0:05	LOAD CHANGE OVER
223	4-Mar-2020	BENGALURU	66	ADUGODI - HSR 1 & 2	ADUGODI, BOSCH (EHT)	10:00	10:17	0:17	LOAD CHANGE OVER
224	4-Mar-2020	BENGALURU	66	BYADRAHALLI - T G HALLI	KODIGENAHALLI, TAVAREKERE	13:07	14:57	1:50	LINE CLEAR AVAILED
225	4-Mar-2020	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-2	14:12	14:18	0:06	TRANSFORMER FAULT
226	4-Mar-2020	BENGALURU	66	HV2	ELECTRONIC CITY PH-2 SEC-2	0:22	0:35	0:13	TRANSFORMER FAULT
227	4-Mar-2020	BENGALURU	66	HV1	KHODAYS 220	0:00	0:20	0:20	TRANSFORMER FAULT
228	4-Mar-2020	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	5:45	5:50	0:05	LOAD CHANGE OVER
229	4-Mar-2020	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	13:40	14:02	0:22	LOAD CHANGE OVER

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
230	4-Mar-2020	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1 & 2	TELECOM LAYOUT	0:00	2:30	2:30	LINE CLEAR AVAILED
231	4-Mar-2020	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	0:00	2:30	2:30	LINE CLEAR AVAILED
232	4-Mar-2020	BENGALURU	66	NRS 220 - VIJAY NGR MY2	VIJAYANAGARA	0:00	2:30	2:30	LINE CLEAR AVAILED
233	4-Mar-2020	BENGALURU	220	HV2	NRS 220	0:00	2:30	2:30	LINE CLEAR AVAILED
234	4-Mar-2020	BENGALURU	66	PLATINUM CITY - SRS 220	PLATINUM CITY	5:20	5:35	0:15	LOAD CHANGE OVER
235	4-Mar-2020	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	11:20	11:25	0:05	LOAD CHANGE OVER
236	4-Mar-2020	BENGALURU	66	HV1	SOBHA APARTMENT	20:37	20:50	0:13	LOAD CHANGE OVER
237	4-Mar-2020	BENGALURU	66	HV2	SOBHA APARTMENT	20:37	20:51	0:14	LOAD CHANGE OVER
238	4-Mar-2020	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66, ISKON	9:35	9:43	0:08	LOAD CHANGE OVER
239	4-Mar-2020	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66, ISKON	17:44	17:51	0:07	LOAD CHANGE OVER
240	4-Mar-2020	BENGALURU	66	HV1	T K HALLI	15:47	16:30	0:43	LINE CLEAR AVAILED
241	4-Mar-2020	GULBARGA	220	SIDHANOOR220-LINGASUGUR	SIDHANOOR_220	14:04	14:39	0:35	LINE FAULT
242	4-Mar-2020	GULBARGA	110	HV1	ALIPUR_220	10:44	10:56	0:12	LINE CLEAR AVAILED
243	4-Mar-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	11:10	11:20	0:10	LINE FAULT
244	4-Mar-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	11:32	11:50	0:18	LINE FAULT
245	4-Mar-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	11:59	12:20	0:21	LINE FAULT
246	4-Mar-2020	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110	12:37	12:42	0:05	LINE FAULT
247	4-Mar-2020	GULBARGA	110	KEMBHAVI-UGARSUGAR_IPP	KEMBHAVI_110,HUNASIGI_110,ASKI_110	4:02	6:31	2:29	LINE FAULT
248	4-Mar-2020	GULBARGA	110	HV2	KUSHTAGI_220	8:47	10:33	1:46	LINE CLEAR AVAILED
249	4-Mar-2020	GULBARGA	66	HV2	TAMBRAHALLI_66	11:48	12:07	0:19	LINE CLEAR AVAILED
250	4-Mar-2020	GULBARGA	66	HV1	TAMBRAHALLI_66	13:00	13:10	0:10	LINE CLEAR AVAILED
251	4-Mar-2020	GULBARGA	66	ITTAGI-TAMBRAHALLI	HAMPSAGAR_66,MORGERE_66,TAMBRAHAL LI_66	7:00	7:20	0:20	LOAD CURTAILMENT
252	4-Mar-2020	GULBARGA	66	ITTAGI-HIREHADAGALLI-1,2	HIREHADAGALLI_66,GIRYAPUR_66,MAGALA_66,SOVENHALLI_66	8:05	8:45	0:40	LOAD CURTAILMENT
253	4-Mar-2020	GULBARGA	66	ITTAGI-HIREHADAGALLI-1	HIREHADAGLLI_66	16:55	16:58	0:03	LINE FAULT
254	4-Mar-2020	GULBARGA	66	ITTAGI-HIREHADAGALLI-1	HIREHADAGLLI_66	16:59	17:06	0:07	LINE FAULT
255	4-Mar-2020	GULBARGA	66	ITTAGI-TAMBRAHALLI	HAMPSAGAR_66,MORGERE_66,TAMBRAHAL LI_66	17:59	18:06	0:07	LINE FAULT
256	4-Mar-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	6:06	23:59	17:53	LINE FAULT
257	4-Mar-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	18:33	19:05	0:32	MAIN SUUPPLY FAILURE
258	4-Mar-2020	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	18:33	19:05	0:32	MAIN SUUPPLY FAILURE
259	4-Mar-2020	HASSAN	110	HV2	ARASIKERE_110	12:32	13:24	0:52	LINE CLEAR AVAILED
260	4-Mar-2020	HASSAN	110	HV1	ARASIKERE_220	12:05	12:43	0:38	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
261	4-Mar-2020	HASSAN	110	HV1	ARASIKERE_220	14:17	14:39	0:22	LINE CLEAR AVAILED
262	4-Mar-2020	HASSAN	110	HV1	BIRUR_110	12:04	15:01	2:57	LINE CLEAR AVAILED
263	4-Mar-2020	HASSAN	110	HV1	GANDSI_110	15:58	16:50	0:52	LINE CLEAR AVAILED
264	4-Mar-2020	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	15:30	17:38	2:08	LINE CLEAR AVAILED
265	4-Mar-2020	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	12:39	13:32	0:53	LINE CLEAR AVAILED
266	4-Mar-2020	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	18:59	19:02	0:03	MAIN SUUPPLY FAILURE
267	4-Mar-2020	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	19:01	19:04	0:03	MAIN SUUPPLY FAILURE
268	4-Mar-2020	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	19:01	19:03	0:02	MAIN SUUPPLY FAILURE
269	4-Mar-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:53	8:17	0:24	LINE FAULT
270	4-Mar-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	8:17	11:53	3:36	MAIN SUUPPLY FAILURE
271	4-Mar-2020	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	7:53	8:17	0:24	MAIN SUUPPLY FAILURE
272	4-Mar-2020	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	8:35	11:47	3:12	MAIN SUUPPLY FAILURE
273	4-Mar-2020	HASSAN	66	HV1	ALDUR_66	8:35	11:51	3:16	MAIN SUUPPLY FAILURE
274	4-Mar-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	7:53	8:17	0:24	LINE FAULT
275	4-Mar-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	8:36	11:46	3:10	LINE CLEAR AVAILED
276	4-Mar-2020	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	16:36	16:51	0:15	LINE FAULT
277	4-Mar-2020	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	14:41	14:45	0:04	HAND TRIPPED
278	4-Mar-2020	MYSORE	66	HV2	CHANDAKAVADI_66	13:14	13:51	0:37	LINE CLEAR AVAILED
279	4-Mar-2020	MYSORE	66	HALAGURU-HONAGANALLI	HONAGANALLI_66	17:25	17:40	0:15	LINE FAULT
280	4-Mar-2020	MYSORE	220	HV1	MADHUVANAHALLI_220	17:28	17:49	0:21	HAND TRIPPED
281	4-Mar-2020	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	17:19	18:09	0:50	LINE FAULT
282	4-Mar-2020	MYSORE	66	HV1	MALAVALLI_66	14:35	15:22	0:46	LINE CLEAR AVAILED
283	4-Mar-2020	MYSORE	66	HV1	NAGAMANGALA_66	14:29	15:41	1:11	LINE CLEAR AVAILED
284	4-Mar-2020	MYSORE	66	HV2	NAGAMANGALA_66	9:08	10:31	1:22	LINE CLEAR AVAILED
285	4-Mar-2020	MYSORE	66	HV2	NAGAMANGALA_66	14:29	15:41	1:11	LINE CLEAR AVAILED
286	4-Mar-2020	TUMKUR	220	TR-3	CHITRADURGA_220	8:25	15:18	6:53	LINE CLEAR AVAILED
287	4-Mar-2020	TUMKUR	220	HARAPPANAHALLI-SUZLON 1	SUZLON_IPP_66	11:26	19:12	7:46	LINE CLEAR AVAILED
288	4-Mar-2020	TUMKUR	220	HARAPPANAHALLI-SUZLON 2	SUZLON_IPP_66	11:26	19:13	7:46	LINE CLEAR AVAILED
289	4-Mar-2020	TUMKUR	220	TR-1	KBCROSS_220	0:14	0:46	0:32	LINE CLEAR AVAILED
290	4-Mar-2020	TUMKUR	220	TR-1	KBCROSS_220	16:07	18:02	1:54	LINE CLEAR AVAILED
291	4-Mar-2020	TUMKUR	220	TR-2	KBCROSS_220	0:18	0:57	0:39	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
292	4-Mar-2020	TUMKUR	110	KB CROSS 220kv- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	13:05	15:58	2:52	LINE CLEAR AVAILED
293	4-Mar-2020	TUMKUR	110	TR-1(HV SIDE)	KBCROSS_220	13:31	13:33	0:01	LINE CLEAR AVAILED
294	4-Mar-2020	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	0:14	0:46	0:32	LINE CLEAR AVAILED
295	4-Mar-2020	TUMKUR	110	TR-2(LV2)	KBCROSS_220	16:07	18:02	1:54	LINE CLEAR AVAILED
296	4-Mar-2020	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	0:20	1:07	0:47	LINE CLEAR AVAILED
297	4-Mar-2020	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	13:23	13:39	0:15	LINE CLEAR AVAILED
298	4-Mar-2020	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	16:07	16:11	0:04	LINE CLEAR AVAILED
299	4-Mar-2020	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	18:02	18:04	0:02	LINE CLEAR AVAILED
300	4-Mar-2020	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	8:25	9:24	0:59	HAND TRIPPED
301	4-Mar-2020	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	15:06	15:23	0:16	HAND TRIPPED
302	4-Mar-2020	TUMKUR	66	TR-4	CHITRADURGA_220	8:31	15:21	6:49	LINE CLEAR AVAILED
303	4-Mar-2020	TUMKUR	66	CHITRADURGA 220kv- SUZLON 1	SUZLON1_IPP_66	8:25	9:24	0:59	HAND TRIPPED
304	4-Mar-2020	TUMKUR	66	CHITRADURGA 220kv- SUZLON 2	SUZLON1_IPP_66	15:06	15:23	0:16	HAND TRIPPED
305	4-Mar-2020	TUMKUR	66	TR-4(HV SIDE)	CHITRADURGA_220	8:31	15:21	6:49	LINE CLEAR AVAILED
306	4-Mar-2020	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	8:24	9:23	0:59	HAND TRIPPED
307	4-Mar-2020	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	15:04	15:22	0:17	HAND TRIPPED
308	4-Mar-2020	TUMKUR	66	TR-2	CHITRADURGA_66	15:21	16:33	1:12	LINE CLEAR AVAILED
309	4-Mar-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	21:53	22:21	0:28	LINE FAULT
310	4-Mar-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	21:53	22:21	0:28	TRANSFORMER FAULT
311	4-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:23	14:33	0:10	LINE FAULT
312	4-Mar-2020	TUMKUR	66	TR-2	GARAGA_66	14:59	15:08	0:09	LINE CLEAR AVAILED
313	4-Mar-2020	TUMKUR	66	TR-1	HDPURA_66	10:03	10:07	0:04	LINE CLEAR AVAILED
314	4-Mar-2020	TUMKUR	66	TR-1	HDPURA_66	19:00	19:07	0:06	LINE CLEAR AVAILED
315	4-Mar-2020	TUMKUR	66	HINDASGHATTA-HIRIYUR1	HINDASGHATTA_66	10:55	11:00	0:05	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
316	4-Mar-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	21:53	22:02	0:08	LINE FAULT
317	4-Mar-2020	TUMKUR	66	TR-2	HULIYURDURGA_66	10:55	11:25	0:29	TRANSFORMER FAULT
318	4-Mar-2020	TUMKUR	66	TR-1	KUNIGAL_66	10:12	10:17	0:05	TRANSFORMER FAULT
319	4-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	8:27	8:41	0:14	LINE FAULT
320	4-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	10:32	10:45	0:12	LINE FAULT
321	4-Mar-2020	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	1:16	2:21	1:04	LINE CLEAR AVAILED
322	4-Mar-2020	TUMKUR	66	SIRA- KALLAMBELLA	SIRA_66	1:53	2:21	0:27	LINE CLEAR AVAILED
323	4-Mar-2020	TUMKUR	66	SIRA- MADHUGIRI 1	SIRA_66	2:14	14:27	12:13	LINE CLEAR AVAILED
324	4-Mar-2020	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	1:16	2:19	1:02	LINE FAULT
325	4-Mar-2020	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	14:09	14:27	0:18	HAND TRIPPED
326	4-Mar-2020	TUMKUR	66	SOKKE-JAGLUR	JAGALUR_66	10:14	18:06	7:52	LINE CLEAR AVAILED
327	4-Mar-2020	TUMKUR	66	TR-2	THOVINAKERE_66	9:43	9:47	0:03	LINE CLEAR AVAILED
328	4-Mar-2020	TUMKUR	66	TR-1	VENKATAPUR_66	14:35	15:29	0:54	LINE CLEAR AVAILED
329	5-Mar-2020	BAGALKOT	110	110/11KV,HV 2	AMBEWADI_220	8:49	18:47	9:58	LINE CLEAR AVAILED
330	5-Mar-2020	BAGALKOT	110	BIJAPUR-BAGEWADI(ENERCON IPP)	BIJAPUR_220	6:41	6:52	0:11	LINE FAULT
331	5-Mar-2020	BAGALKOT	110	CHIKKODI-DKSCCOGEN	CHIKKODI_220	11:36	14:07	2:31	NFBC ISSUED
332	5-Mar-2020	BAGALKOT	110	110/11KV,HV 3	HIDIKAL_110	11:57	12:03	0:06	HAND TRIPPED
333	5-Mar-2020	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	12:19	12:23	0:04	TRANSFORMER FAULT
334	5-Mar-2020	BAGALKOT	110	110/33KV,HV 2	HUNAGUND_110&33KV KARADI	15:44	16:24	0:40	HAND TRIPPED
335	5-Mar-2020	BAGALKOT	110	110/11KV,HV 1	HUNAGUND_110	16:30	17:55	1:25	LINE CLEAR AVAILED
336	5-Mar-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	11:20	11:23	0:03	TRANSFORMER FAULT
337	5-Mar-2020	BAGALKOT	110	110/11KV, HV1	UTTUR_110	18:20	18:31	0:11	LINE CLEAR AVAILED
338	5-Mar-2020	BAGALKOT	110	NOKAR SOLAR- UDIKERI	UDIKERI_110	18:34	19:14	0:40	LINE CLEAR AVAILED
339	5-Mar-2020	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	0:00	13:34	13:34	LINE CLEAR AVAILED
340	5-Mar-2020	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	10:49	23:59	13:10	LINE CLEAR AVAILED
341	5-Mar-2020	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	9:27	9:31	0:04	TRANSFORMER FAULT
342	5-Mar-2020	BAGALKOT	110	110/11KV, HV2	KUMATA_110	8:00	8:45	0:45	LINE CLEAR AVAILED
343	5-Mar-2020	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	9:53	23:59	14:06	LINE CLEAR AVAILED
344	5-Mar-2020	BENGALURU	66	HV1	GOKULA	9:30	9:35	0:05	LOAD CHANGE OVER
345	5-Mar-2020	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	10:43	13:38	2:55	LINE CLEAR AVAILED
346	5-Mar-2020	BENGALURU	66	KADUGODI - EPIP 220	KADUGODI,KONDASPURA	13:15	13:20	0:05	LINE FAULT
347	5-Mar-2020	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	SUBRAMANYAPURA 66, ISKON	5:05	5:34	0:29	LINE FAULT
348	5-Mar-2020	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66, ISKON	13:38	13:46	0:08	LOAD CHANGE OVER
349	5-Mar-2020	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	19:49	19:57	0:08	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
350	5-Mar-2020	BENGALURU	66	HV1	T K HALLI 220	21:04	21:07	0:03	TRANSFORMER FAULT
351	5-Mar-2020	BENGALURU	220	HV1	YARANDANAHALLI 220	13:25	14:07	0:42	MAIN SUUPPLY FAILURE
352	5-Mar-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	13:25	14:15	0:50	MAIN SUUPPLY FAILURE
353	5-Mar-2020	BENGALURU	66	HV2	YARANDANAHALLI 220	13:25	14:15	0:50	MAIN SUUPPLY FAILURE
354	5-Mar-2020	BENGALURU	66	HV1	CHANDAPURA	6:44	6:52	0:07	LOAD CHANGE OVER
355	5-Mar-2020	BENGALURU	66	HV2	CHANDAPURA	6:44	6:52	0:08	LOAD CHANGE OVER
356	5-Mar-2020	BENGALURU	66	HV1	D CROSS	15:22	16:06	0:43	LINE CLEAR AVAILED
357	5-Mar-2020	BENGALURU	66	HV2	D CROSS	15:22	16:06	0:43	LINE CLEAR AVAILED
358	5-Mar-2020	BENGALURU	66	HV2	M GOLLAHALLI	13:06	17:40	4:33	LINE CLEAR AVAILED
359	5-Mar-2020	BENGALURU	66	HV2	VIJAYAPURA	13:51	14:04	0:13	LINE CLEAR AVAILED
360	5-Mar-2020	BENGALURU	66	HV1	NANGALI	15:04	15:52	0:48	LINE CLEAR AVAILED
361	5-Mar-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	18:02	18:09	0:07	LINE FAULT
362	5-Mar-2020	BENGALURU	66	TEKAL - MALUR	REKAL, BUDIKOTE	14:10	14:30	0:19	LINE FAULT
363	5-Mar-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	16:09	16:42	0:32	LINE FAULT
364	5-Mar-2020	GULBARGA	220	SEDAM-RTPS2	SEDAM-220	0:00	11:41	11:41	LINE CLEAR AVAILED
365	5-Mar-2020	GULBARGA	220	LINGASUGUR-B-BAGEWADI1	B-BAGEWADI_220	9:50	23:59	14:09	NFBC ISSUED
366	5-Mar-2020	GULBARGA	220	RAICHUR-JURALA 1,2	RAICHUR_220	16:47	23:59	7:12	LINE CLEAR AVAILED
367	5-Mar-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADONA_11 0,SREERAMANAGAR_110,MALLAPURA_110	1:01	1:11	0:10	LINE FAULT
368	5-Mar-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADONA_11 0,SREERAMANAGAR_110,MALLAPURA_110	2:53	3:03	0:10	LINE FAULT
369	5-Mar-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	10:50	11:08	0:18	LINE FAULT
370	5-Mar-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	11:55	12:00	0:05	LINE FAULT
371	5-Mar-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	19:55	20:03	0:08	LINE FAULT
372	5-Mar-2020	GULBARGA	110	SINDHANOOR-SUZLON1_IPP	SINDHANOOR_220	13:39	19:20	5:41	LINE CLEAR AVAILED
373	5-Mar-2020	GULBARGA	110	HV2	KAVITAL_110	18:25	19:34	1:09	TRANSFORMER FAULT
374	5-Mar-2020	GULBARGA	110	KOLHAR-NSSK	JANAWADA_110,NSSK SUGAR FACTORY_IPP	16:23	16:25	0:02	LINE FAULT
375	5-Mar-2020	GULBARGA	110	HALBARGA-LADHA	LADHA_110	7:20	7:45	0:25	MAIN SUUPPLY FAILURE
376	5-Mar-2020	GULBARGA	66	ITTAGI-HANASI	HANASI_110	11:10	11:15	0:05	LINE FAULT
377	5-Mar-2020	GULBARGA	66	ITTAGI-HANASI	HANASI_110	11:30	11:35	0:05	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
378	5-Mar-2020	GULBARGA	66	ITTAGI-HANASI	HANASI_110	12:30	13:05	0:35	MAIN SUUPPLY FAILURE
379	5-Mar-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	17:36	18:00	0:24	HAND TRIPPED
380	5-Mar-2020	HASSAN	220	VARAHI-KEMAR3	varahi_gen	10:16	13:15	2:59	LINE CLEAR AVAILED
381	5-Mar-2020	HASSAN	110	VARAHI-BARNGI	ANAVATTI_110	12:29	12:36	0:07	LINE FAULT
382	5-Mar-2020	HASSAN	110	HV1	BIRUR_110	8:33	16:41	8:08	LINE CLEAR AVAILED
383	5-Mar-2020	HASSAN	110	HV1	BIRUR_110	17:12	17:36	0:24	LINE CLEAR AVAILED
384	5-Mar-2020	HASSAN	110	HV1	GANDASI_110	20:27	20:43	0:16	LINE CLEAR AVAILED
385	5-Mar-2020	HASSAN	110	HV2	KADUR_220	11:18	13:42	2:24	LINE CLEAR AVAILED
386	5-Mar-2020	HASSAN	66	HV2	CHIKMAGALORE_66	13:05	14:36	1:31	LINE CLEAR AVAILED
387	5-Mar-2020	HASSAN	66	HV1	DODDAKADANUR_66	12:08	12:10	0:02	TRANSFORMER FAULT
388	5-Mar-2020	HASSAN	66	HV2	HALEBEEDU_66	15:00	17:54	2:54	LINE CLEAR AVAILED
389	5-Mar-2020	HASSAN	66	HV1	MAGGE_66	11:10	11:18	0:08	TRANSFORMER FAULT
390	5-Mar-2020	MYSORE	66	HV1	DUNDANAHALLI_66	10:26	11:02	0:36	LINE CLEAR AVAILED
391	5-Mar-2020	MYSORE	66	HV1	DUNDANAHALLI_66	17:57	18:14	0:17	TRANSFORMER FAULT
392	5-Mar-2020	MYSORE	66	HV2	DUNDANAHALLI_66	14:16	14:19	0:02	HAND TRIPPED
393	5-Mar-2020	MYSORE	66	HV2	HOOTAGALLY_220	12:12	12:58	0:46	TRANSFORMER FAULT
394	5-Mar-2020	MYSORE	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66, SUTTUR_66	9:20	9:29	0:09	LINE FAULT
395	5-Mar-2020	MYSORE	66	HV2	KMDODDI_66	13:04	13:16	0:12	TRANSFORMER FAULT
396	5-Mar-2020	MYSORE	66	HV2	KMDODDI_66	19:42	20:34	0:51	TRANSFORMER FAULT
397	5-Mar-2020	MYSORE	66	HV1	KMDODDI_66	19:42	20:34	0:51	TRANSFORMER FAULT
398	5-Mar-2020	MYSORE	66	HV1	KUNTHUR_66	18:58	19:06	0:07	HAND TRIPPED
399	5-Mar-2020	MYSORE	66	HV1	MEGALAPURA_66	11:39	19:46	8:07	LINE CLEAR AVAILED
400	5-Mar-2020	TUMKUR	220	TR-1(HV SIDE)	KBCROSS_220	15:09	18:06	2:56	LINE CLEAR AVAILED
401	5-Mar-2020	TUMKUR	220	TR-2(HV SIDE))	KBCROSS_220	10:31	11:16	0:44	LINE CLEAR AVAILED
402	5-Mar-2020	TUMKUR	220	TR-2(HV SIDE))	KBCROSS_220	18:08	19:21	1:12	LINE CLEAR AVAILED
403	5-Mar-2020	TUMKUR	110	TURUVEKERE_110	TURUVEKERE_110	14:36	14:51	0:15	LINE FAULT
404	5-Mar-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	14:56	15:07	0:11	HAND TRIPPED
405	5-Mar-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	10:27	10:30	0:02	HAND TRIPPED
406	5-Mar-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	14:56	15:09	0:12	HAND TRIPPED
407	5-Mar-2020	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	15:09	17:00	1:50	LINE CLEAR AVAILED
408	5-Mar-2020	TUMKUR	110	TR-2(LV2 SIDE)	KBCROSS_220	10:31	11:17	0:46	LINE CLEAR AVAILED
409	5-Mar-2020	TUMKUR	110	TR-2(LV2 SIDE)	KBCROSS_220	18:04	19:21	1:17	LINE CLEAR AVAILED
410	5-Mar-2020	TUMKUR	66	CHAWDANKUPPE-ANCHEPALYA	CHAWANAKUPPE_66	14:04	14:15	0:11	MAIN SUUPPLY FAILURE
411	5-Mar-2020	TUMKUR	66	HARAPPANAHALLI-TELAGI	HARAPPANAHALLI_66	8:05	9:02	0:57	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
412	5-Mar-2020	TUMKUR	66	TR-2	HARAPPANAHALLI_66	0:31	0:39	0:08	TRANSFORMER FAULT
413	5-Mar-2020	TUMKUR	66	TR-2	HARAPPANAHALLI_66	11:40	11:55	0:14	TRANSFORMER FAULT
414	5-Mar-2020	TUMKUR	66	TR-2	HARAPPANAHALLI_66	12:14	12:23	0:09	TRANSFORMER FAULT
415	5-Mar-2020	TUMKUR	66	TR-1	HDPURA_66	6:54	6:58	0:04	HAND TRIPPED
416	5-Mar-2020	TUMKUR	66	TR-1	HDPURA_66	18:26	18:29	0:03	HAND TRIPPED
417	5-Mar-2020	TUMKUR	66	TR-1	HIRIYUR_66	13:57	14:31	0:34	LINE CLEAR AVAILED
418	5-Mar-2020	TUMKUR	66	HULIYURDURGA- ANCHEPALYA	HULIYURDURGA_66	14:05	14:14	0:09	MAIN SUUPPLY FAILURE
419	5-Mar-2020	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	12:03	12:07	0:03	HAND TRIPPED
420	5-Mar-2020	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	12:35	12:36	0:01	HAND TRIPPED
421	5-Mar-2020	TUMKUR	66	TR-1	MATHOD_66	1:49	1:53	0:04	TRANSFORMER FAULT
422	6-Mar-2020	BAGALKOT	110	110/11KV,HV 2	AIGALI_110	23:21	23:32	0:11	TRANSFORMER FAULT
423	6-Mar-2020	BAGALKOT	110	110/11KV,HV 2	AMBEWADI_220	11:40	23:59	12:19	LINE CLEAR AVAILED
424	6-Mar-2020	BAGALKOT	110	ANNIGERI-GADAG	ANNIGERI_110	16:03	16:05	0:02	HAND TRIPPED
425	6-Mar-2020	BAGALKOT	110	ATHANI-SATTI	SATTI_110	5:50	10:38	4:48	LINE FAULT
426	6-Mar-2020	BAGALKOT	110	220/110KV,HV 1&LV 1	BAGALKOT_220	15:20	19:10	3:50	LINE CLEAR AVAILED
427	6-Mar-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	0:00	12:09	12:09	LINE CLEAR AVAILED
428	6-Mar-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	12:23	12:33	0:10	HAND TRIPPED
429	6-Mar-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	12:48	15:33	2:45	NFBC ISSUED
430	6-Mar-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	15:47	16:03	0:16	HAND TRIPPED
431	6-Mar-2020	BAGALKOT	110	110/11KV,HV 1	ARAGA_110	12:18	12:26	0:08	HAND TRIPPED
432	6-Mar-2020	BAGALKOT	110	GADAG 1(L5)-DAMBAL	DAMBAL_110	16:16	18:02	1:46	NFBC ISSUED
433	6-Mar-2020	BAGALKOT	110	DAMBAL-SUZLON 1(L3)	DAMBAL_110	16:16	18:04	1:48	LINE CLEAR AVAILED
434	6-Mar-2020	BAGALKOT	110	DAMBAL-SUZLON 2(L2)	DAMBAL_110	16:16	18:04	1:48	LINE CLEAR AVAILED
435	6-Mar-2020	BAGALKOT	110	DAMBAL-EILS(L1)	DAMBAL_110	16:16	18:08	1:52	LINE CLEAR AVAILED
436	6-Mar-2020	BAGALKOT	110	DAMBAL-MUNDARAGI	MUNDARAGI_110	16:17	18:02	1:45	LINE CLEAR AVAILED
437	6-Mar-2020	BAGALKOT	110	GADAG-SAMBAPUR ROAD	SAMBAPUR ROAD_110	14:28	18:27	3:59	LINE FAULT
438	6-Mar-2020	BAGALKOT	110	GADAG-DAMBAL	DAMBAL_110	16:20	17:59	1:39	LINE CLEAR AVAILED
439	6-Mar-2020	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	15:49	15:54	0:05	HAND TRIPPED
440	6-Mar-2020	BAGALKOT	220	NANDIHAL1-BAGEWADI	BAGEWADI_220	12:03	19:13	7:10	LINE CLEAR AVAILED
441	6-Mar-2020	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	18:42	18:47	0:05	TRANSFORMER FAULT
442	6-Mar-2020	BAGALKOT	110	110/11KV,HV1	KADANAKOPPA_110	11:56	14:02	2:06	LINE CLEAR AVAILED
443	6-Mar-2020	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	6:55	8:48	1:53	LINE FAULT
444	6-Mar-2020	BAGALKOT	110	KAVVALWADA-KADANAKOPPA	KADANAKOPPA_110	8:48	23:59	15:11	LINE CLEAR AVAILED
445	6-Mar-2020	BAGALKOT	110	110/11KV,HV1	UTTUR_110	10:15	11:53	1:38	LINE CLEAR AVAILED
446	6-Mar-2020	BAGALKOT	110	110/11KV,HV2	ITANAL_110	14:50	14:57	0:07	TRANSFORMER FAULT
447	6-Mar-2020	BAGALKOT	110	110/11KV,HV2	ITANAL_110	22:34	22:40	0:06	TRANSFORMER FAULT
448	6-Mar-2020	BAGALKOT	110	ILKAL1&2-HUNGUND	HUNGUND_110	10:59	11:11	0:12	LINE CLEAR AVAILED
449	6-Mar-2020	BAGALKOT	110	ILKAL1&2-HUNGUND	HUNGUND_110	11:23	11:35	0:12	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
450	6-Mar-2020	BAGALKOT	110	JINDAL-HUNGUND	HUNGUND_110	10:58	11:35	0:37	LINE CLEAR AVAILED
451	6-Mar-2020	BAGALKOT	110	KPJNL-HUNGUND	HUNGUND_110	10:58	11:35	0:37	LINE CLEAR AVAILED
452	6-Mar-2020	BAGALKOT	110	KPJNL-HUNGUND	HUNGUND_110	15:23	15:33	0:10	HAND TRIPPED
453	6-Mar-2020	BAGALKOT	110	BAGEWADI-HUNGUND	HUNGUND_110	10:59	11:36	0:37	LINE CLEAR AVAILED
454	6-Mar-2020	BAGALKOT	220	VAJRAMATTI-KAVATAGI_LIS	VAJRAMATTI_220	12:22	12:25	0:03	HAND TRIPPED
455	6-Mar-2020	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	14:33	14:40	0:07	TRANSFORMER FAULT
456	6-Mar-2020	BAGALKOT	110	JAMKHANDI SUGARS- TODALBAGI	TODALBAGI_110	3:24	3:35	0:11	LINE FAULT
457	6-Mar-2020	BAGALKOT	110	110/11KV, HV1	SIRSI_110	22:23	22:29	0:06	TRANSFORMER FAULT
458	6-Mar-2020	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	13:05	14:09	1:04	LINE CLEAR AVAILED
459	6-Mar-2020	BAGALKOT	110	110/11KV, HV1&HV2	SHIRGOAN_110	14:13	14:17	0:04	HAND TRIPPED
460	6-Mar-2020	BAGALKOT	110	110/11KV, HV1	RATTIHALL_110	11:09	12:50	1:41	TRANSFORMER FAULT
461	6-Mar-2020	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	17:07	17:18	0:11	LINE CLEAR AVAILED
462	6-Mar-2020	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	7:08	7:23	0:15	LINE CLEAR AVAILED
463	6-Mar-2020	BAGALKOT	220	220/110KV, HV2&LV2	MAHALINGAPUR_220, BANAHATTI_110	15:03	15:12	0:09	HAND TRIPPED
464	6-Mar-2020	BAGALKOT	220	220/110KV, HV3&LV3	MAHALINGAPUR_220	7:00	7:24	0:24	TRANSFORMER FAULT
465	6-Mar-2020	BAGALKOT	110	MAHALINGAPUR-RABKAVI	RABKAVI_110	7:00	8:36	1:36	LINE FAULT
466	6-Mar-2020	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	7:00	7:38	0:38	LINE FAULT
467	6-Mar-2020	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110, ITANAL_110	7:18	7:42	0:24	HAND TRIPPED
468	6-Mar-2020	BAGALKOT	110	110/11KV, HV1	KONNUR_110	12:17	17:46	5:29	LINE CLEAR AVAILED
469	6-Mar-2020	BAGALKOT	220	220/110KV, HV1&LV1	HUBLI_220, KALGHATAGI_110, KADANKOPPA_110, PH COMPOUND_110, TARIHAL_110	6:38	7:07	0:29	TRANSFORMER FAULT
470	6-Mar-2020	BAGALKOT	220	220/110KV, HV2&LV2	HUBLI_220, KALGHATAGI_110, KADANKOPPA_110, PH COMPOUND_110, TARIHAL_110	6:38	7:07	0:29	TRANSFORMER FAULT
471	6-Mar-2020	BAGALKOT	220	220/110KV, HV1,LV1,HV2&LV2	HUBLI_220, KALGHATAGI_110, KADANKOPPA_110, PH COMPOUND_110, TARIHAL_110	7:21	7:55	0:34	TRANSFORMER FAULT
472	6-Mar-2020	BAGALKOT	110	HUBLI-TARIHAL1	TARIHAL_110	6:37	17:59	11:22	LINE FAULT
473	6-Mar-2020	BAGALKOT	110	HUBLI-TARIHAL2	TARIHAL_110	12:21	18:00	5:39	LINE CLEAR AVAILED
474	6-Mar-2020	BENGALURU	66	HV1	VOLVO	11:57	13:23	1:25	LINE CLEAR AVAILED
475	6-Mar-2020	BENGALURU	66	HV2	VOLVO	13:13	13:24	0:11	LINE CLEAR AVAILED
476	6-Mar-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	6:02	6:07	0:04	LINE FAULT
477	6-Mar-2020	BENGALURU	66	MALLASANDRA - DALASANUR	DALASANUR, YELDUR	9:07	9:43	0:35	LOAD CURTAILMENT
478	6-Mar-2020	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASANUR, YELDUR	10:30	11:50	1:20	LOAD CURTAILMENT
479	6-Mar-2020	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASANUR, YELDUR	15:20	16:20	1:00	LOAD CURTAILMENT
480	6-Mar-2020	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	22:40	23:15	0:35	LINE FAULT
481	6-Mar-2020	BENGALURU	66	HV1	KONDASAPURA	8:00	8:16	0:16	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
482	6-Mar-2020	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	11:37	13:10	1:33	LOAD CURTAILMENT
483	6-Mar-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	9:04	9:32	0:28	LOAD CURTAILMENT
484	6-Mar-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	14:16	14:35	0:19	LOAD CURTAILMENT
485	6-Mar-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	15:05	15:16	0:11	LOAD CURTAILMENT
486	6-Mar-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	17:30	18:05	0:35	LOAD CURTAILMENT
487	6-Mar-2020	BENGALURU	66	KOLAR 220 - BANGARPETE 2	BANGARPETE 2	13:17	13:25	0:08	LOAD CURTAILMENT
488	6-Mar-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	13:17	13:30	0:13	LOAD CURTAILMENT
489	6-Mar-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	13:50	13:55	0:05	LINE FAULT
490	6-Mar-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	16:18	17:21	1:02	LOAD CURTAILMENT
491	6-Mar-2020	BENGALURU	66	TEKAL - MALUR	TEKAL, BUDIKOTE	12:14	12:21	0:07	LINE FAULT
492	6-Mar-2020	BENGALURU	66	HV2	M GOLAHALLI	10:40	12:15	1:35	LINE CLEAR AVAILED
493	6-Mar-2020	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT)	10:53	10:57	0:04	LOAD CHANGE OVER
494	6-Mar-2020	BENGALURU	66	HV1	BYADARHALLI	0:15	0:50	0:35	TRANSFORMER FAULT
495	6-Mar-2020	BENGALURU	66	HV1	BYADARHALLI	21:53	21:55	0:02	LOAD CHANGE OVER
496	6-Mar-2020	BENGALURU	66	B YADARHALLI - T G HALLI	KODIGENAHALLI,TAVAREKERE	8:14	9:38	1:24	LINE CLEAR AVAILED
497	6-Mar-2020	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	21:13	22:17	1:04	LINE FAULT
498	6-Mar-2020	BENGALURU	66	HOODY 220 - GRAPHITE INDIA (EHT)	GRAPHITE INDIA (EHT)	21:31	23:59	2:28	LINE CLEAR AVAILED
499	6-Mar-2020	BENGALURU	66	HOODY 220 - HOSKOTE	HOSKOTE 66	21:33	22:14	0:41	LINE FAULT
500	6-Mar-2020	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	10:20	11:07	0:47	LINE FAULT
501	6-Mar-2020	BENGALURU	220	HV2	HSR 220	12:34	12:50	0:16	TRANSFORMER FAULT
502	6-Mar-2020	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	21:05	21:35	0:30	LINE FAULT
503	6-Mar-2020	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	7:05	7:20	0:15	LINE FAULT
504	6-Mar-2020	BENGALURU	220	HV1	KHODAYS 220	10:50	10:55	0:05	LINE CLEAR AVAILED
505	6-Mar-2020	BENGALURU	220	HV1	KHODAYS 220	13:35	13:39	0:04	LOAD CHANGE OVER
506	6-Mar-2020	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	10:50	10:55	0:05	LOAD CHANGE OVER
507	6-Mar-2020	BENGALURU	66	KHODAYS 220 - SOUTH CITY	SOUTH CITY	10:50	10:55	0:05	LOAD CHANGE OVER
508	6-Mar-2020	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	13:36	13:39	0:03	LOAD CHANGE OVER
509	6-Mar-2020	BENGALURU	66	KHODAYS 220 - SOUTH CITY	SOUTH CITY	13:36	13:39	0:03	LOAD CHANGE OVER
510	6-Mar-2020	BENGALURU	66	HV1	KHODAYS 220	10:50	10:55	0:05	LOAD CHANGE OVER
511	6-Mar-2020	BENGALURU	66	HV1	KHODAYS 220	13:36	13:39	0:03	LOAD CHANGE OVER
512	6-Mar-2020	BENGALURU	66	HV2	KHODAYS 220	13:36	13:39	0:03	LOAD CHANGE OVER
513	6-Mar-2020	BENGALURU	66	HV2	KHODAYS 220	10:50	10:55	0:05	LOAD CHANGE OVER

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
514	6-Mar-2020	BENGALURU	66	HV1	SOBHA APARTMENT	10:43	10:47	0:04	MAIN SUUPPLY FAILURE
515	6-Mar-2020	BENGALURU	66	HV2	SOBHA APARTMENT	10:43	10:47	0:04	MAIN SUUPPLY FAILURE
516	6-Mar-2020	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1 & 2	ADUGODI, BOSCH (EHT),ST JOHN WOOD	12:35	13:02	0:27	MAIN SUUPPLY FAILURE
517	6-Mar-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	12:05	12:17	0:12	LINE FAULT
518	6-Mar-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	13:30	13:39	0:09	LINE FAULT
519	6-Mar-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	13:45	14:03	0:18	LINE FAULT
520	6-Mar-2020	BENGALURU	66	DALASNUR - SRINIVASPURA	YELDUR	10:56	11:47	0:51	LOAD CURTAILMENT
521	6-Mar-2020	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	9:23	9:44	0:21	LINE FAULT
522	6-Mar-2020	BENGALURU	66	DABUSPET 220 - S K STEEL(EHT)	S K STEEL(EHT),KOLLALA	6:24	8:56	2:32	LINE FAULT
523	6-Mar-2020	GULBARGA	220	HV2	ALIPUR_220	12:47	13:28	0:41	HAND TRIPPED
524	6-Mar-2020	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110	11:00	12:37	1:37	LINE CLEAR AVAILED
525	6-Mar-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	10:10	11:15	1:05	LINE FAULT
526	6-Mar-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	13:20	13:35	0:15	LINE FAULT
527	6-Mar-2020	GULBARGA	110	HV2	DEODURGA_110	11:27	11:40	0:13	TRANSFORMER FAULT
528	6-Mar-2020	GULBARGA	110	HV2	HATTI_110	9:38	9:40	0:02	TRANSFORMER FAULT
529	6-Mar-2020	GULBARGA	110	MALLAT 220-VALKAMDINI	VALKAMDINI_110	3:52	4:00	0:08	MAIN SUUPPLY FAILURE
530	6-Mar-2020	GULBARGA	110	HV1	VALKAMDINI_110	9:40	17:38	7:58	LINE CLEAR AVAILED
531	6-Mar-2020	GULBARGA	220	RTPS-SHAHAPUR2	SHAHAPUR_220	11:00	11:59	0:59	HAND TRIPPED
532	6-Mar-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KEMBHAVI_110,HUNASIGI_110,ASKI_110	6:18	6:23	0:05	LINE FAULT
533	6-Mar-2020	GULBARGA	220	HV1	SHAHAPUR_220	11:30	11:45	0:15	HAND TRIPPED
534	6-Mar-2020	GULBARGA	110	ALIPUR-BELARYSOUTH	BELLARY_110	17:15	17:23	0:08	HAND TRIPPED
535	6-Mar-2020	GULBARGA	220	HUMNABAD-ALAND	ALAND_110	10:50	12:25	1:35	LINE CLEAR AVAILED
536	6-Mar-2020	GULBARGA	110	ITTAGGI-HIREHADAGALI1	HIREHADAGALI_110	9:07	9:15	0:08	LINE FAULT
537	6-Mar-2020	GULBARGA	110	ITTAGGI-HIREHADAGALI1	HIREHADAGALI_110	9:20	9:32	0:12	LINE FAULT
538	6-Mar-2020	GULBARGA	220	LINGASUGUR-B-BAGEWADI1	B-BAGEWADI_220	0:00	15:58	15:58	LINE CLEAR AVAILED
539	6-Mar-2020	GULBARGA	220	RAICHUR-JURALA 1,2	RAICHUR_220	0:00	12:29	12:29	LINE CLEAR AVAILED
540	6-Mar-2020	GULBARGA	110	BETAGERA-KSHVCMNT_SLR	BETAGERA_110	16:15	18:14	1:59	MAIN SUUPPLY FAILURE
541	6-Mar-2020	GULBARGA	110	HV2	HANUMNAL_110	7:30	9:00	1:30	LINE CLEAR AVAILED
542	6-Mar-2020	GULBARGA	110	JEWARGI-SHAHABAD	JEWARGI_110	3:00	3:20	0:20	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
543	6-Mar-2020	GULBARGA	110	HV1	JEWARGI_110	3:00	16:38	13:38	TRANSFORMER FAULT
544	6-Mar-2020	GULBARGA	110	HV2	JEWARGI_110	3:00	3:25	0:25	TRANSFORMER FAULT
545	6-Mar-2020	GULBARGA	110	HV2	JEWARGI_110	5:45	6:25	0:40	TRANSFORMER FAULT
546	6-Mar-2020	GULBARGA	220	SEDAM-TANDUR	TANDUR_220	8:40	11:33	2:53	LINE FAULT
547	6-Mar-2020	GULBARGA	110	HV2	RAICHUR_220	13:15	14:16	1:01	LINE CLEAR AVAILED
548	6-Mar-2020	GULBARGA	110	HV2	RAICHUR_220	23:05	23:23	0:18	TRANSFORMER FAULT
549	6-Mar-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	23:07	23:35	0:28	LINE FAULT
550	6-Mar-2020	GULBARGA	110	SIDHANOOR220-TURVIHAL	TURVIHAL_110	4:15	4:25	0:10	LINE FAULT
551	6-Mar-2020	GULBARGA	220	RTPS-SHAHAPUR1	SHAHAPUR_220	12:05	19:30	7:25	LINE CLEAR AVAILED
552	6-Mar-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	18:25	18:25	LINE FAULT
553	6-Mar-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	8:25	23:59	15:34	LINE FAULT
554	6-Mar-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	12:10	15:06	2:56	LINE CLEAR AVAILED
555	6-Mar-2020	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	12:20	14:57	2:37	LINE CLEAR AVAILED
556	6-Mar-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	18:36	20:46	2:10	LINE CLEAR AVAILED
557	6-Mar-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	14:06	14:22	0:16	HAND TRIPPED
558	6-Mar-2020	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	12:19	14:56	2:37	LINE CLEAR AVAILED
559	6-Mar-2020	HASSAN	220	VARAHI-KEMAR2	varahi_gen	11:14	13:07	1:53	NFBC ISSUED
560	6-Mar-2020	HASSAN	220	GOPALAP-BASTIPURA	GOPALAPURA_220	15:46	16:29	0:43	LINE FAULT
561	6-Mar-2020	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	6:24	6:45	0:21	LINE FAULT
562	6-Mar-2020	HASSAN	66	BANDISH-ADANI	BANDISHETTIHALLY_66	15:47	16:31	0:44	MAIN SUUPPLY FAILURE
563	6-Mar-2020	HASSAN	66	HV1	BANDISHETTIHALLY_66	15:47	16:33	0:46	MAIN SUUPPLY FAILURE
564	6-Mar-2020	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTIHALLY_66	15:52	16:28	0:36	MAIN SUUPPLY FAILURE
565	6-Mar-2020	HASSAN	66	HV2	CHIKMAGALUR_66	15:12	15:38	0:26	LINE CLEAR AVAILED
566	6-Mar-2020	HASSAN	66	HV1	HANUBALU_66	13:01	14:24	1:23	MAIN SUUPPLY FAILURE
567	6-Mar-2020	HASSAN	66	HANUBAL-SAKLESPUR	HANUBALU_66	3:06	14:24	11:18	MAIN SUUPPLY FAILURE
568	6-Mar-2020	HASSAN	66	HV2	RAMPURA_66	9:04	12:56	3:52	LINE CLEAR AVAILED
569	6-Mar-2020	HASSAN	66	SAKALE-HANBAL	SAKLESHPURA_66	13:03	14:20	1:17	LINE CLEAR AVAILED
570	6-Mar-2020	HASSAN	66	SAKALE-HASSAN	SAKLESHPURA_66	13:00	14:40	1:40	LINE CLEAR AVAILED
571	6-Mar-2020	HASSAN	66	HV1	SAKLESHPURA_66	13:04	14:21	1:17	LINE CLEAR AVAILED
572	6-Mar-2020	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	13:03	14:27	1:24	LINE CLEAR AVAILED
573	6-Mar-2020	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	13:03	14:40	1:37	LINE CLEAR AVAILED
574	6-Mar-2020	MYSORE	66	HV1	HDKOTE_66	15:08	15:15	0:07	LINE CLEAR AVAILED
575	6-Mar-2020	MYSORE	66	HV2	HDKOTE_66	15:16	15:24	0:08	TRANSFORMER FAULT
576	6-Mar-2020	MYSORE	66	HV1	KOLLEGALA_66	18:01	18:12	0:11	TRANSFORMER FAULT
577	6-Mar-2020	MYSORE	66	HV2	KOPPA_66	10:31	11:13	0:42	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
578	6-Mar-2020	MYSORE	66	HV1	KUNTHUR_66	8:03	13:48	5:44	LINE CLEAR AVAILED
579	6-Mar-2020	MYSORE	66	HV5	SFCSHIVA_66	0:41	23:59	23:17	LINE CLEAR AVAILED
580	6-Mar-2020	MYSORE	66	HV2	THALAKADU_66	10:10	10:40	0:29	LINE CLEAR AVAILED
581	6-Mar-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	17:26	17:31	0:05	LINE FAULT
582	6-Mar-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	18:51	18:56	0:05	LINE FAULT
583	6-Mar-2020	TUMKUR	220	THALLAK 220kV-HIRIYUR	THALLAKK_220	11:32	13:07	1:35	LINE CLEAR AVAILED
584	6-Mar-2020	TUMKUR	220	THALLAK 220kV-HIRIYUR	THALLAKK_220	16:20	18:52	2:32	LINE CLEAR AVAILED
585	6-Mar-2020	TUMKUR	110	DODDAGUNI- NITTUR	DODDAGUNI_110	13:00	14:57	1:56	LINE CLEAR AVAILED
586	6-Mar-2020	TUMKUR	110	TR-1	KALLUR_110	2:21	3:00	0:39	TRANSFORMER FAULT
587	6-Mar-2020	TUMKUR	110	NITTUR 220kV- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	12:59	14:57	1:58	LINE CLEAR AVAILED
588	6-Mar-2020	TUMKUR	110	SAMPIGE- DODDAGUNI	DODDAGUNI_110,AMMASANDRA_110,SAMP IGE_110	13:03	16:55	3:52	MAIN SUUPPLY FAILURE
589	6-Mar-2020	TUMKUR	110	TR-1	SAMPIGE_110	13:04	16:55	3:51	MAIN SUUPPLY FAILURE
590	6-Mar-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:04	16:55	3:51	MAIN SUUPPLY FAILURE
591	6-Mar-2020	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	13:32	16:55	3:23	MAIN SUUPPLY FAILURE
592	6-Mar-2020	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	ANCHEPALYA_220	5:55	6:00	0:04	LINE FAULT
593	6-Mar-2020	TUMKUR	66	TR-2	BEVINAHALLI_66	10:27	10:32	0:05	TRANSFORMER FAULT
594	6-Mar-2020	TUMKUR	66	CHITRADURGA 220kV- SUZLON 1	SUZLON1_IPP_66	11:24	18:37	7:12	LINE CLEAR AVAILED
595	6-Mar-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	16:10	17:10	1:00	LINE CLEAR AVAILED
596	6-Mar-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	22:08	22:35	0:27	MAIN SUUPPLY FAILURE
597	6-Mar-2020	TUMKUR	66	DEVARAHALLI_66	TR-1	16:10	17:10	1:00	LINE CLEAR AVAILED
598	6-Mar-2020	TUMKUR	66	DEVARAHALLI_66	TR-1	22:08	22:35	0:27	MAIN SUUPPLY FAILURE
599	6-Mar-2020	TUMKUR	66	TR-1	GOWRASAMUDRA_66	18:31	18:50	0:18	LINE CLEAR AVAILED
600	6-Mar-2020	TUMKUR	66	TR-2	HIRIYUR_66	10:25	17:02	6:36	LINE CLEAR AVAILED
601	6-Mar-2020	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	15:13	15:31	0:18	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
602	6-Mar-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	1:42	1:50	0:07	LINE FAULT
603	6-Mar-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	3:38	4:02	0:24	LINE FAULT
604	6-Mar-2020	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDURGA_66,JAGALUR_66,PALLAGATTE_66	12:15	12:27	0:12	HAND TRIPPED
605	6-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	9:43	9:57	0:14	LINE FAULT
606	6-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	10:43	10:54	0:11	LINE FAULT
607	6-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	17:13	17:24	0:10	LINE FAULT
608	7-Mar-2020	BAGALKOT	110	SUPA 2-AMBEWADI	AMBEWADI_220	9:55	23:59	14:04	LINE CLEAR AVAILED
609	7-Mar-2020	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	0:00	16:47	16:47	LINE CLEAR AVAILED
610	7-Mar-2020	BAGALKOT	220	BAGEWADI-NANDIHAL 1	BAGEWADI_220	12:16	19:50	7:34	LINE CLEAR AVAILED
611	7-Mar-2020	BAGALKOT	220	BAGEWADI-LINGASGUR 2	BAGEWADI_220	16:30	18:35	2:05	LINE CLEAR AVAILED
612	7-Mar-2020	BAGALKOT	110	110/33KV ,HV2	BAGEWADI_220	10:50	17:40	6:50	LINE CLEAR AVAILED
613	7-Mar-2020	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	0:00	18:35	18:35	LINE CLEAR AVAILED
614	7-Mar-2020	BAGALKOT	110	110/33KV ,HV2	GULEDGUDDA_110 &33KV SIRUR ,KAMATAGI	10:11	10:29	0:18	TRANSFORMER FAULT
615	7-Mar-2020	BAGALKOT	110	110/11KV,HV 2	HANAGALL_110	4:32	4:46	0:14	TRANSFORMER FAULT
616	7-Mar-2020	BAGALKOT	110	110/33KV,HV3	HANAGALL_110 33KV BELAGAL PET, AKKIALUR,BOMMANALLI, LAXMIPUR	10:53	11:04	0:11	TRANSFORMER FAULT
617	7-Mar-2020	BAGALKOT	220	NANDIHAL 2-BIJAPUR	BIJAPUR_220	11:45	16:32	4:47	LINE CLEAR AVAILED
618	7-Mar-2020	BAGALKOT	220	NANDIHAL 2-BIJAPUR	BIJAPUR_220	16:40	20:16	3:36	LINE CLEAR AVAILED
619	7-Mar-2020	BAGALKOT	110	110/11KV, HV2	TODALBAGI_110	0:06	0:14	0:08	TRANSFORMER FAULT
620	7-Mar-2020	BAGALKOT	110	110/11KV, HV2	SIDDAPUR_110	13:32	15:03	1:31	LINE CLEAR AVAILED
621	7-Mar-2020	BAGALKOT	110	SOUDATTI220-NARAGUND (SOUDATTI2)	SOUDATTI_110	9:41	12:23	2:42	LINE CLEAR AVAILED
622	7-Mar-2020	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	10:03	12:55	2:52	LINE CLEAR AVAILED
623	7-Mar-2020	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	17:41	17:47	0:06	HAND TRIPPED
624	7-Mar-2020	BAGALKOT	110	RANEENNUR-HIREKERUR	HIREKERUR_110	17:41	17:53	0:12	HAND TRIPPED
625	7-Mar-2020	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110	17:41	17:53	0:12	HAND TRIPPED
626	7-Mar-2020	BAGALKOT	110	RANEENNUR-RATTIHALI	RATTIHALI_110	17:41	17:50	0:09	HAND TRIPPED
627	7-Mar-2020	BAGALKOT	110	RANEENNUR-AREMALLAPUR	AREMALLAPUR_110	17:41	17:50	0:09	HAND TRIPPED
628	7-Mar-2020	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	8:45	9:11	0:26	LINE FAULT
629	7-Mar-2020	BAGALKOT	110	110/33KV, HV3	SANKESHWAR_110, HEBBAL_33, KANAGALA_33	9:15	9:21	0:06	LINE CLEAR AVAILED
630	7-Mar-2020	BENGALURU	66	HOODY 220 - GRAPHITE INDIA (EHT)	GRAPHITE INDIA (EHT)	0:00	3:28	3:28	LINE CLEAR AVAILED
631	7-Mar-2020	BENGALURU	66	HV1	MELLEHALI	13:15	13:42	0:27	LINE CLEAR AVAILED
632	7-Mar-2020	BENGALURU	66	HV1	VICTORIA	14:01	14:03	0:02	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
633	7-Mar-2020	BENGALURU	66	HV2	VICTORIA	15:46	15:47	0:01	LINE CLEAR AVAILED
634	7-Mar-2020	BENGALURU	66	VRISHBHAVATHI 220 - REMCO	REMCO	4:46	5:08	0:22	LINE FAULT
635	7-Mar-2020	BENGALURU	220	HV1	YARENDANAHALLI 220	3:15	3:32	0:17	TRANSFORMER FAULT
636	7-Mar-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	3:15	3:45	0:30	LINE CLEAR AVAILED
637	7-Mar-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	3:49	4:05	0:15	LINE FAULT
638	7-Mar-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	4:05	9:19	5:13	LINE FAULT
639	7-Mar-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	7:25	9:35	2:09	LINE CLEAR AVAILED
640	7-Mar-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	11:20	11:30	0:10	LINE CLEAR AVAILED
641	7-Mar-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	14:20	14:30	0:10	LINE CLEAR AVAILED
642	7-Mar-2020	BENGALURU	66	KGF - BEML (EHT)	BEML (EHT)	4:43	5:50	1:07	LINE FAULT
643	7-Mar-2020	BENGALURU	66	KGF - KAMASAMUDRA	KAMASAMUDRA	4:43	5:56	1:13	LINE CLEAR AVAILED
644	7-Mar-2020	BENGALURU	66	KGF - KYASAMBALLI	KYASAMBALLI	4:43	5:50	1:07	LINE CLEAR AVAILED
645	7-Mar-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	4:30	4:59	0:29	MAIN SUUPPLY FAILURE
646	7-Mar-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	4:30	5:00	0:30	MAIN SUUPPLY FAILURE
647	7-Mar-2020	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	4:30	4:58	0:28	LINE FAULT
648	7-Mar-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	4:30	5:00	0:30	MAIN SUUPPLY FAILURE
649	7-Mar-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	4:30	4:59	0:29	MAIN SUUPPLY FAILURE
650	7-Mar-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	4:30	4:59	0:29	MAIN SUUPPLY FAILURE
651	7-Mar-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	4:30	4:59	0:29	MAIN SUUPPLY FAILURE
652	7-Mar-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	4:30	4:58	0:28	MAIN SUUPPLY FAILURE
653	7-Mar-2020	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	1:29	1:39	0:09	LINE FAULT
654	7-Mar-2020	BENGALURU	66	HV1	CHELUR	16:01	16:22	0:20	LINE CLEAR AVAILED
655	7-Mar-2020	BENGALURU	66	HV1	DODDABELAVANGALA	10:15	10:25	0:10	TRANSFORMER FAULT
656	7-Mar-2020	BENGALURU	66	HV1	KGF	4:43	5:57	1:14	TRANSFORMER FAULT
657	7-Mar-2020	BENGALURU	66	HV2	KGF	4:43	5:58	1:15	TRANSFORMER FAULT
658	7-Mar-2020	BENGALURU	66	HV3	KGF	4:43	5:51	1:08	TRANSFORMER FAULT
659	7-Mar-2020	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	9:53	18:29	8:36	NFBC ISSUED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
660	7-Mar-2020	GULBARGA	220	LINGASUGUR-SIDHANOOR	SIDHANOOR_220	7:58	19:12	11:14	LINE CLEAR AVAILED
661	7-Mar-2020	GULBARGA	220	RTPS-SHAHAPUR1	SHAHAPUR_220	10:38	10:57	0:19	LINE FAULT
662	7-Mar-2020	GULBARGA	220	RTPS-SHAHAPUR2	SHAHAPUR_220	11:45	18:49	7:04	NFBC ISSUED
663	7-Mar-2020	GULBARGA	220	HUMNBAD-KAPNOOR 1,2	KAPNOOR_220	10:30	10:40	0:10	LINE FAULT
664	7-Mar-2020	GULBARGA	220	RTPS-SHAHAPUR2	SHAHAPUR_220	6:14	6:27	0:13	LINE FAULT
665	7-Mar-2020	GULBARGA	220	SHAHAPUR-LINGASUGUR	LINGASUGUR_220	9:47	18:22	8:35	LINE CLEAR AVAILED
666	7-Mar-2020	GULBARGA	220	SHAHAPUR-RTPS 1	SHAHAPUR_220	10:27	10:56	0:29	LINE FAULT
667	7-Mar-2020	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHAPUR_220	10:27	11:05	0:38	LINE FAULT
668	7-Mar-2020	GULBARGA	220	HV1	SHAHAPUR_220	14:08	15:16	1:08	LINE CLEAR AVAILED
669	7-Mar-2020	GULBARGA	220	LINGASUGUR-BAGEWADI2	BAGEWADI_220	16:25	18:12	1:47	LINE CLEAR AVAILED
670	7-Mar-2020	GULBARGA	220	HUMNABAD-KAPNOOR2	KAPNOOR_220	18:45	19:11	0:26	NFBC ISSUED
671	7-Mar-2020	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	19:30	19:51	0:21	NFBC ISSUED
672	7-Mar-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	10:50	11:00	0:10	LINE FAULT
673	7-Mar-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	12:35	12:55	0:20	LINE FAULT
674	7-Mar-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	13:25	13:35	0:10	LINE FAULT
675	7-Mar-2020	GULBARGA	110	GULBARGANORTH-GULBARGA UNIVERSITY	GULBARGA UNIVERSITY	10:30	10:40	0:10	MAIN SUUPPLY FAILURE
676	7-Mar-2020	GULBARGA	110	HV2	HATTI_110	9:30	9:36	0:06	TRANSFORMER FAULT
677	7-Mar-2020	GULBARGA	110	HV1	JEEWARGI_110	15:30	15:40	0:10	HAND TRIPPED
678	7-Mar-2020	GULBARGA	110	HV2	KAVITAL_110	14:15	15:00	0:45	LINE CLEAR AVAILED
679	7-Mar-2020	GULBARGA	110	ALLIPUR-BELLARY NORTH	SOMASAMUNDRA_110,BELLARY NORTH_110,MOKAp_110,P.D HALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEEL ACC	9:08	9:16	0:08	LINE FAULT
680	7-Mar-2020	GULBARGA	110	HV2	ALLIPUR_110	13:32	15:34	2:02	TRANSFORMER FAULT
681	7-Mar-2020	GULBARGA	110	HV2	SHORAPUR_110	16:15	16:20	0:05	TRANSFORMER FAULT
682	7-Mar-2020	GULBARGA	110	HV3	BEVOOR_110	16:10	17:45	1:35	LINE CLEAR AVAILED
683	7-Mar-2020	GULBARGA	110	CHINCHOLI-RNWWIND_IPP	CHINCHOLI_110	18:35	20:45	2:10	LINE CLEAR AVAILED
684	7-Mar-2020	GULBARGA	110	KUDITINI-ALIPUR	KUDITINI_110	18:18	18:23	0:05	LINE FAULT
685	7-Mar-2020	GULBARGA	110	HV2	MANTHAL_110	10:30	14:50	4:20	LINE CLEAR AVAILED
686	7-Mar-2020	GULBARGA	110	HV2	MANTHAL_110	15:40	18:10	2:30	LINE CLEAR AVAILED
687	7-Mar-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	3:17	3:27	0:10	LINE FAULT
688	7-Mar-2020	GULBARGA	66	HV1	HANASI_66	11:00	11:45	0:45	HAND TRIPPED
689	7-Mar-2020	GULBARGA	66	ITTAGI-HANASI	HANASI_66	12:15	12:30	0:15	HAND TRIPPED
690	7-Mar-2020	HASSAN	400	HASSAN4-NLM400	HASSAN_400	14:57	18:13	3:16	LINE CLEAR AVAILED
691	7-Mar-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	18:32	18:32	LINE FAULT
692	7-Mar-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	19:01	23:59	4:58	LINE CLEAR AVAILED
693	7-Mar-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	8:56	23:59	15:03	LINE CLEAR AVAILED
694	7-Mar-2020	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	8:56	23:59	15:03	LINE CLEAR AVAILED
695	7-Mar-2020	HASSAN	220	HV2	MSEZ_220	9:46	14:11	4:25	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
696	7-Mar-2020	HASSAN	110	LV2	MSEZ_220	9:46	14:11	4:25	LINE CLEAR AVAILED
697	7-Mar-2020	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	8:56	23:59	15:03	NFBC ISSUED
698	7-Mar-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	8:56	23:59	15:03	NFBC ISSUED
699	7-Mar-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	9:05	9:10	0:05	LINE FAULT
700	7-Mar-2020	HASSAN	110	HV1	GANDSI_110	12:03	12:39	0:36	LINE CLEAR AVAILED
701	7-Mar-2020	HASSAN	110	KADUR-NGNHL	KADUR_220	7:09	23:18	16:09	LINE CLEAR AVAILED
702	7-Mar-2020	HASSAN	110	KADUR-NGNHL	KADUR_220	10:52	23:18	12:26	LINE CLEAR AVAILED
703	7-Mar-2020	HASSAN	110	KITTADA-BLGAVE	KITTADAHALLI_110	10:23	19:27	9:04	LINE CLEAR AVAILED
704	7-Mar-2020	HASSAN	110	HV	KITTADAHALLI_110	10:23	19:27	9:04	LINE CLEAR AVAILED
705	7-Mar-2020	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	10:33	11:34	1:01	NFBC ISSUED
706	7-Mar-2020	HASSAN	66	HV1	ARKD_66	12:08	13:36	1:28	LINE CLEAR AVAILED
707	7-Mar-2020	HASSAN	66	HV1	HANGARANAHALLY_66	9:55	10:24	0:29	TRANSFORMER FAULT
708	7-Mar-2020	HASSAN	66	HV1	KANDLI_66	18:23	18:33	0:10	TRANSFORMER FAULT
709	7-Mar-2020	HASSAN	66	HV1	KANDLI_66	10:51	10:55	0:04	TRANSFORMER FAULT
710	7-Mar-2020	HASSAN	66	HV1	MAGGE_66	10:42	10:49	0:07	TRANSFORMER FAULT
711	7-Mar-2020	HASSAN	66	RAMPUR-BEGUR	RAMPURA_66	12:51	18:19	5:28	MAIN SUUPPLY FAILURE
712	7-Mar-2020	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	8:02	8:11	0:09	LINE FAULT
713	7-Mar-2020	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	8:24	8:29	0:05	LINE FAULT
714	7-Mar-2020	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	11:59	12:11	0:12	LINE FAULT
715	7-Mar-2020	HASSAN	66	HV1	MALLAPURA_66	18:16	18:30	0:14	TRANSFORMER FAULT
716	7-Mar-2020	MYSORE	66	AKIHEBBAL-KR PET1	AKKIHEBBAL_66	23:50	23:55	0:05	LINE FAULT
717	7-Mar-2020	MYSORE	66	AKIHEBBAL-KRPET2	AKKIHEBBAL_66	23:50	23:55	0:05	LINE FAULT
718	7-Mar-2020	MYSORE	66	CR NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	5:32	5:57	0:24	LINE FAULT
719	7-Mar-2020	MYSORE	66	CR NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	7:23	7:30	0:07	LINE FAULT
720	7-Mar-2020	MYSORE	66	CR NAGARA-HONNALLY	HONNALLY_MYS_66 ATTIGULIPURA_66	5:32	5:56	0:23	LINE FAULT
721	7-Mar-2020	MYSORE	66	CR NAGARA-HONNALLY	HONNALLY_MYS_66 ATTIGULIPURA_66	7:23	7:31	0:08	LINE FAULT
722	7-Mar-2020	MYSORE	66	CR NAGARA-YALANDUR	YELANDUR_66	5:32	5:56	0:23	LINE FAULT
723	7-Mar-2020	MYSORE	66	CR NAGARA-YALANDUR	YELANDUR_66	7:23	7:29	0:06	LINE FAULT
724	7-Mar-2020	MYSORE	66	HV1	DUNDANAHALLI_66	17:44	17:51	0:06	TRANSFORMER FAULT
725	7-Mar-2020	MYSORE	66	HV1	FTS_66	20:54	22:03	1:09	LINE CLEAR AVAILED
726	7-Mar-2020	MYSORE	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	6:30	6:36	0:06	LINE FAULT
727	7-Mar-2020	MYSORE	66	HUNSUR-HOOTAGALLI	BANNIKUPPE_66 HOSURGATE_66	9:13	9:35	0:22	LINE FAULT
728	7-Mar-2020	MYSORE	66	KADAKOLA-SARGUR 2	DOORA_66 HULLAHALLI_66 HURA_66 CHANDRAVADI_66 SANTHESARAGUR_66 B MATKERE_66	10:30	10:37	0:06	LINE FAULT
729	7-Mar-2020	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66	10:30	10:37	0:06	LINE FAULT
730	7-Mar-2020	MYSORE	220	HV1	MADHUVANAHALLI_220	15:10	16:45	1:35	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
731	7-Mar-2020	MYSORE	66	HV2	MALAVALLI_66	0:14	0:21	0:07	TRANSFORMER FAULT
732	7-Mar-2020	MYSORE	66	HV1	MEGALAPURA_66	14:31	15:55	1:23	LINE CLEAR AVAILED
733	7-Mar-2020	MYSORE	66	HV2	MEGALAPURA_66	14:31	15:55	1:23	LINE CLEAR AVAILED
734	7-Mar-2020	MYSORE	66	HV3	PONNAMPET_66	8:56	9:15	0:18	TRANSFORMER FAULT
735	7-Mar-2020	MYSORE	66	HV5	SFCSHIVA_66	8:55	23:59	15:04	LINE CLEAR AVAILED
736	7-Mar-2020	MYSORE	66	TUBINKERE-ARAKERE	GAMANAHALLY_66 TARIPURA_66 ARAKERE_66	22:54	23:42	0:47	LINE FAULT
737	7-Mar-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	15:36	19:45	4:09	LINE CLEAR AVAILED
738	7-Mar-2020	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	15:52	19:45	3:53	LINE CLEAR AVAILED
739	7-Mar-2020	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	10:43	14:17	3:33	LINE CLEAR AVAILED
740	7-Mar-2020	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	15:55	19:43	3:48	LINE CLEAR AVAILED
741	7-Mar-2020	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	10:37	15:44	5:07	LINE CLEAR AVAILED
742	7-Mar-2020	TUMKUR	220	NEELAGUNDA- GUTTUR	NEELAGUNDA_220	10:36	15:44	5:07	LINE CLEAR AVAILED
743	7-Mar-2020	TUMKUR	220	THALLAK 220kV-HIRIYUR	THALLAKK_220	8:25	12:06	3:41	LINE CLEAR AVAILED
744	7-Mar-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	15:08	15:13	0:05	TRANSFORMER FAULT
745	7-Mar-2020	TUMKUR	66	TR-2	CHIKKABANAGERE_66	10:55	11:44	0:48	LINE CLEAR AVAILED
746	7-Mar-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	16:01	16:12	0:10	MAIN SUUPPLY FAILURE
747	7-Mar-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	17:24	17:36	0:12	MAIN SUUPPLY FAILURE
748	7-Mar-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	16:01	16:12	0:10	MAIN SUUPPLY FAILURE
749	7-Mar-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	17:24	17:36	0:12	MAIN SUUPPLY FAILURE
750	7-Mar-2020	TUMKUR	66	TR-1	GOWRASAMUDRA_66	11:19	13:04	1:45	LINE CLEAR AVAILED
751	7-Mar-2020	TUMKUR	66	TR-1	HALURAMESHWARA_66	14:30	15:43	1:12	LINE CLEAR AVAILED
752	7-Mar-2020	TUMKUR	66	TR-2	HARAPPANAHALLI_66	11:00	11:10	0:09	TRANSFORMER FAULT
753	7-Mar-2020	TUMKUR	66	TR-2	HARAPPANAHALLI_66	16:05	16:22	0:16	TRANSFORMER FAULT
754	7-Mar-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	16:01	16:11	0:10	LINE FAULT
755	7-Mar-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	17:24	17:36	0:12	LINE FAULT
756	7-Mar-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	2:22	2:29	0:07	LINE FAULT
757	7-Mar-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	14:09	16:00	1:51	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
758	7-Mar-2020	TUMKUR	66	TR-1	MADHUGIRI_220	16:52	17:29	0:36	TRANSFORMER FAULT
759	7-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	1:43	1:58	0:15	LINE FAULT
760	7-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	6:39	8:38	1:59	LINE FAULT
761	7-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	10:23	11:31	1:08	LINE FAULT
762	7-Mar-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	3:21	3:25	0:04	TRANSFORMER FAULT
763	7-Mar-2020	TUMKUR	66	TR-1	TAVAREKERE(C)_66	17:39	17:42	0:03	TRANSFORMER FAULT
764	7-Mar-2020	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	5:19	10:28	5:09	LINE CLEAR AVAILED
765	8-Mar-2020	BAGALKOT	110	ATHANI-AIGALI	AIGALI_110	7:43	7:58	0:15	LINE FAULT
766	8-Mar-2020	BAGALKOT	110	MK HUBLI-BAILHONGAL	BAILHONGAL_110 &33KV SAMPAGOAN,NEGINAL,MURGOD	10:01	16:23	6:22	LINE CLEAR AVAILED
767	8-Mar-2020	BAGALKOT	110	110/11KV,HV1	BETAGERI_110	9:09	14:29	5:20	LINE CLEAR AVAILED
768	8-Mar-2020	BAGALKOT	110	CHIKKODI-SADALAGA	SADALAGA_110	18:53	19:40	0:47	LINE FAULT
769	8-Mar-2020	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	13:57	19:45	5:48	LINE FAULT
770	8-Mar-2020	BAGALKOT	110	110/11KV, HV2	MUNDARGI_110	20:04	23:59	3:55	TRANSFORMER FAULT
771	8-Mar-2020	BAGALKOT	220	220/110KV, HV3&LV3	MAHALINGAPUR_220, RABKAVI_110, HIDIKAL_110, ITANAL_110	6:05	6:29	0:24	TRANSFORMER FAULT
772	8-Mar-2020	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	6:05	6:33	0:28	LINE FAULT
773	8-Mar-2020	BAGALKOT	220	KUDACHI-MAHALINGAPUR	KUDACHI_220	13:14	13:40	0:26	LINE FAULT
774	8-Mar-2020	BAGALKOT	220	220/110KV,HV1&LV1	KARWAR_220	16:31	17:30	0:59	LINE CLEAR AVAILED
775	8-Mar-2020	BAGALKOT	110	110/33KV,HV1	JAMKHANDI_110, HIPARGI_33	7:22	7:26	0:04	TRANSFORMER FAULT
776	8-Mar-2020	BAGALKOT	110	ITANAL-RAIBAG2	ITANAL_110	6:36	9:28	2:52	LINE FAULT
777	8-Mar-2020	BAGALKOT	110	110/33KV,HV1	ITANAL_110	23:09	23:32	0:23	TRANSFORMER FAULT
778	8-Mar-2020	BENGALURU	66	HV2	AUSTIN TOWN	4:35	14:20	9:45	TRANSFORMER FAULT
779	8-Mar-2020	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	23:21	23:38	0:17	LOAD CHANGE OVER
780	8-Mar-2020	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	23:21	23:38	0:17	LOAD CHANGE OVER
781	8-Mar-2020	BENGALURU	66	KHODAYS 220 - SOUTH CITY	SOUTH CITY	23:21	23:38	0:17	LOAD CHANGE OVER
782	8-Mar-2020	BENGALURU	66	HV1	NAGANATHPURA 220	21:15	22:40	1:25	TRANSFORMER FAULT
783	8-Mar-2020	BENGALURU	66	HV2	NATIONAL COLLEGE	10:58	11:00	0:02	LOAD CHANGE OVER
784	8-Mar-2020	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	8:15	8:20	0:05	LOAD CHANGE OVER
785	8-Mar-2020	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	17:20	17:25	0:05	LOAD CHANGE OVER
786	8-Mar-2020	BENGALURU	66	SIR M V LAYOUT - VRISHABHAVATHI 220	SIR M V LAYOUT,KENGERI SATELLITE TOWN	11:28	11:35	0:07	LINE FAULT
787	8-Mar-2020	BENGALURU	66	SIR M V LAYOUT - VRISHABHAVATHI 220	SIR M V LAYOUT,KENGERI SATELLITE TOWN	13:40	13:45	0:05	LINE FAULT
788	8-Mar-2020	BENGALURU	66	SOMANAHALLI 220 - B G ROAD	B G ROAD,JIGANI,JIGANI LINK ROAD	6:42	7:10	0:28	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
789	8-Mar-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:05	14:38	3:33	LINE CLEAR AVAILED
790	8-Mar-2020	BENGALURU	66	KGF - KAMASAMUDRA	KAMASAMUDRA	17:13	18:05	0:52	LINE FAULT
791	8-Mar-2020	BENGALURU	66	WELCAST STEEL - DG 3	WELCAST STEEL	8:09	8:16	0:06	LOAD CHANGE OVER
792	8-Mar-2020	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	17:11	17:18	0:07	LOAD CHANGE OVER
793	8-Mar-2020	BENGALURU	66	RANGANDODDI - SOMANAHALLI 220	RANGANDODDI	12:30	13:23	0:53	LINE CLEAR AVAILED
794	8-Mar-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	17:12	17:15	0:02	LOAD CHANGE OVER
795	8-Mar-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	19:45	19:56	0:11	MAIN SUUPPLY FAILURE
796	8-Mar-2020	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, JULLUPALYA	19:45	19:56	0:11	MAIN SUUPPLY FAILURE
797	8-Mar-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	9:13	9:15	0:01	LOAD CHANGE OVER
798	8-Mar-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	17:12	17:15	0:02	LOAD CHANGE OVER
799	8-Mar-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	9:13	9:15	0:01	LOAD CHANGE OVER
800	8-Mar-2020	BENGALURU	66	HV1	DODDABELAVANGALA	16:35	16:40	0:05	TRANSFORMER FAULT
801	8-Mar-2020	BENGALURU	220	HV2	MITTEMARI 220	20:28	20:43	0:14	TRANSFORMER FAULT
802	8-Mar-2020	BENGALURU	66	HV2	CHAKAVELU	19:01	19:39	0:38	TRANSFORMER FAULT
803	8-Mar-2020	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	TUBUGERE	11:10	13:55	2:44	LINE CLEAR AVAILED
804	8-Mar-2020	HASSAN	400	HASSAN4-NLM400	HASSAN_400	17:41	21:17	3:36	LINE CLEAR AVAILED
805	8-Mar-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	22:03	22:03	LINE CLEAR AVAILED
806	8-Mar-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	8:56	14:28	5:32	LINE CLEAR AVAILED
807	8-Mar-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	14:28	17:08	2:40	LINE FAULT
808	8-Mar-2020	HASSAN	110	HV2	MSEZ_220	19:22	19:29	0:07	TRANSFORMER FAULT
809	8-Mar-2020	HASSAN	110	HV1	ANAVATTI_110	7:16	7:22	0:06	TRANSFORMER FAULT
810	8-Mar-2020	HASSAN	110	HV2	ANAVATTI_110	7:16	7:22	0:06	TRANSFORMER FAULT
811	8-Mar-2020	HASSAN	110	HV2	ESSUR_110	13:01	13:55	0:54	LINE CLEAR AVAILED
812	8-Mar-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	22:23	23:49	1:26	LINE CLEAR AVAILED
813	8-Mar-2020	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	22:23	23:46	1:23	LINE FAULT
814	8-Mar-2020	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	7:25	7:39	0:14	LINE FAULT
815	8-Mar-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	22:26	23:43	1:17	LINE CLEAR AVAILED
816	8-Mar-2020	HASSAN	66	HV1	HANGARANAHALLY_66	8:40	8:52	0:12	TRANSFORMER FAULT
817	8-Mar-2020	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	14:36	18:51	4:15	LINE FAULT
818	8-Mar-2020	HASSAN	66	HV1	SINGAPURA_66	14:38	18:51	4:13	LINE CLEAR AVAILED
819	8-Mar-2020	HASSAN	66	HV2	SINGAPURA_66	14:38	18:51	4:13	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
820	8-Mar-2020	MYSORE	66	BILIKERE-GV GUDI	GVGUDI_66	6:13	6:18	0:05	LINE FAULT
821	8-Mar-2020	MYSORE	66	HV1	DUNDANAHALLI_66	14:27	14:37	0:09	TRANSFORMER FAULT
822	8-Mar-2020	MYSORE	66	HV1	DUNDANAHALLI_66	15:26	15:34	0:07	TRANSFORMER FAULT
823	8-Mar-2020	MYSORE	66	HV1	DUNDANAHALLI_66	15:45	15:51	0:05	TRANSFORMER FAULT
824	8-Mar-2020	MYSORE	66	HV1	NANJANGUDU_66	9:20	11:11	1:51	LINE CLEAR AVAILED
825	8-Mar-2020	MYSORE	66	TUBINKERE-ARAKERE	GAMANAHALLY_66 TARIPURA_66 ARAKERE_66	10:03	10:07	0:03	LINE FAULT
826	8-Mar-2020	GULBARGA	220	BTPSG-LINGAPUR	BTPS_220,ALIPUR_220	11:36	14:13	2:37	LINE FAULT
827	8-Mar-2020	GULBARGA	220	HV2	ITTAGI_220	6:20	6:50	0:30	TRANSFORMER FAULT
828	8-Mar-2020	GULBARGA	220	HV1	ITTAGI_220	6:26	6:40	0:14	TRANSFORMER FAULT
829	8-Mar-2020	GULBARGA	220	HV2	ITTAGI_220	20:02	20:48	0:46	TRANSFORMER FAULT
830	8-Mar-2020	GULBARGA	220	HV1	ITTAGI_220	20:02	20:50	0:48	TRANSFORMER FAULT
831	8-Mar-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	1:51	1:58	0:07	LINE FAULT
832	8-Mar-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110,ASKI_110	5:29	5:36	0:07	LINE FAULT
833	8-Mar-2020	GULBARGA	110	SHAHAPUR-WARADA SOLAR	WARADA SOLAR_IPP	2:24	3:34	1:10	LINE FAULT
834	8-Mar-2020	GULBARGA	110	HV3	BEVOOR_110	0:15	0:20	0:05	TRANSFORMER FAULT
835	8-Mar-2020	GULBARGA	110	BETAGERA-KSHVCMNT_IPP	BETAGERA_110	19:46	19:54	0:08	LINE FAULT
836	8-Mar-2020	GULBARGA	110	GABBUR-BPSLR	GABBUR_110	5:05	5:10	0:05	LINE FAULT
837	8-Mar-2020	GULBARGA	110	HV2	JEEWARG110	12:10	13:55	1:45	LINE CLEAR AVAILED
838	8-Mar-2020	GULBARGA	110	HV1 & HV2	YELBURGA_110	19:05	22:43	3:38	LINE CLEAR AVAILED
839	8-Mar-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	0:26	0:35	0:09	LINE FAULT
840	8-Mar-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	0:45	0:56	0:11	LINE FAULT
841	8-Mar-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	0:59	1:19	0:20	LINE FAULT
842	8-Mar-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	8:10	8:40	0:30	LINE FAULT
843	8-Mar-2020	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	17:34	17:42	0:08	LINE FAULT
844	8-Mar-2020	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	10:46	11:07	0:21	LINE FAULT
845	8-Mar-2020	GULBARGA	110	KAPNOOR-GULBARGAWEST	GULBARGAWEST_110,GULBARGASOUTH_110	10:10	14:15	4:05	LINE CLEAR AVAILED
846	8-Mar-2020	GULBARGA	110	GULBARGAWEST- GULBARGASOUTH	GULBARGASOUTH_110	10:10	14:15	4:05	LINE CLEAR AVAILED
847	8-Mar-2020	GULBARGA	66	GUDEKOTE-ITTAGI	GUDEKOTE_66	6:20	8:00	1:40	MAIN SUUPPLY FAILURE
848	8-Mar-2020	GULBARGA	66	GUDEKOTE-ITTAGI	GUDEKOTE_66	19:55	20:40	0:45	MAIN SUUPPLY FAILURE
849	8-Mar-2020	GULBARGA	66	ITTAGI-HANASI	HANASI_66	6:20	6:25	0:05	MAIN SUUPPLY FAILURE
850	8-Mar-2020	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	14:16	14:26	0:10	LINE FAULT
851	8-Mar-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	15:27	15:48	0:21	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
852	8-Mar-2020	TUMKUR	66	TR-3	AVAREGERE_66	8:23	8:30	0:07	TRANSFORMER FAULT
853	8-Mar-2020	TUMKUR	66	AVAREGERE 66KV-DAVANGERE SRS	AVAREGERE_66	8:23	8:30	0:07	MAIN SUUPPLY FAILURE
854	8-Mar-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	8:43	8:49	0:06	TRANSFORMER FAULT
855	8-Mar-2020	TUMKUR	66	TR-2	CHIKKABANAGERE_66	16:05	17:30	1:25	LINE CLEAR AVAILED
856	8-Mar-2020	TUMKUR	66	TR-2(HV SIDE)	CHITRADURGA_220	8:23	8:31	0:08	TRANSFORMER FAULT
857	8-Mar-2020	TUMKUR	66	TR-1	GOWRASAMUDRA_66	11:46	14:14	2:27	LINE CLEAR AVAILED
858	8-Mar-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	6:52	7:09	0:16	LINE FAULT
859	8-Mar-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	5:19	5:31	0:11	LINE FAULT
860	8-Mar-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	19:57	20:02	0:04	LINE FAULT
861	8-Mar-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:37	11:47	0:09	LINE FAULT
862	8-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	8:15	8:23	0:08	LINE FAULT
863	8-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	10:02	10:13	0:10	LINE FAULT
864	8-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	10:27	10:35	0:08	LINE FAULT
865	8-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	15:37	15:46	0:08	LINE FAULT
866	8-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	16:05	16:15	0:10	LINE FAULT
867	8-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	16:25	16:37	0:12	LINE FAULT
868	8-Mar-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	17:17	17:25	0:07	LINE FAULT
869	8-Mar-2020	TUMKUR	110	TR-1	TURUVEKERE_110	8:59	9:30	0:31	TRANSFORMER FAULT
870	9-Mar-2020	BAGALKOT	220	220/110KV,HV 2&LV2	BAGALKOT_220	12:31	17:31	5:00	LINE CLEAR AVAILED
871	9-Mar-2020	BAGALKOT	110	BAGALKOT-LOKAPUR 1	LOKAPUR_110	12:30	12:32	0:02	HAND TRIPPED
872	9-Mar-2020	BAGALKOT	110	HAVERI-HANAGAL	HANAGAL_110	22:06	22:34	0:28	LINE FAULT
873	9-Mar-2020	BAGALKOT	220	SHARAVATI 1&2-SIRSI	SIRSI_220	14:04	17:54	3:50	LINE CLEAR AVAILED
874	9-Mar-2020	BAGALKOT	220	SIRSI-HUBLI 1	SIRSI_220	0:00	14:05	14:05	LINE CLEAR AVAILED
875	9-Mar-2020	BAGALKOT	220	SIRSI-HUBLI 1 & 2	SIRSI_220	17:55	23:59	6:04	LINE CLEAR AVAILED
876	9-Mar-2020	BAGALKOT	110	110/11KV, HV1	BILAGI_110	8:35	8:40	0:05	TRANSFORMER FAULT
877	9-Mar-2020	BAGALKOT	110	110/33KV,HV2	HANGAL_110, BOMMANHALLI_33, BELAGALPET_33	10:21	10:37	0:16	TRANSFORMER FAULT
878	9-Mar-2020	BAGALKOT	110	110/33KV,HV2	HANGAL_110, BOMMANHALLI_33, BELAGALPET_33	10:42	10:55	0:13	TRANSFORMER FAULT
879	9-Mar-2020	BAGALKOT	110	110/11KV, HV4	HUKKERI_110	15:08	15:12	0:04	TRANSFORMER FAULT
880	9-Mar-2020	BAGALKOT	110	110/11KV, HV2	ITANAL_110	7:54	8:00	0:06	TRANSFORMER FAULT
881	9-Mar-2020	BAGALKOT	110	SIRSI(AMBEWADI)-KIRUVATTI	KIRUVATTI_110	0:00	13:45	13:45	LINE CLEAR AVAILED
882	9-Mar-2020	BAGALKOT	110	MANALI SUGARS-MALGHAN(S)	MALGHAN(S)_110	12:17	12:43	0:26	LINE FAULT
883	9-Mar-2020	BAGALKOT	110	VIJAYNAGAR SUGARS- MUNDARGI	MUNDARGI_110	4:18	4:44	0:26	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
884	9-Mar-2020	BAGALKOT	110	110/11KV, HV2	MUNDARGI_110	0:00	14:40	14:40	LINE CLEAR AVAILED
885	9-Mar-2020	BAGALKOT	110	110/11KV, HV2	TODALBAGI_110	16:26	16:38	0:12	TRANSFORMER FAULT
886	9-Mar-2020	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	7:53	8:04	0:11	TRANSFORMER FAULT
887	9-Mar-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110, ALSANGI_33, DHULKED_33, NEVARGI_33	14:15	14:17	0:02	TRANSFORMER FAULT
888	9-Mar-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110, ALSANGI_33, DHULKED_33, NEVARGI_33	14:40	14:47	0:07	TRANSFORMER FAULT
889	9-Mar-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110, ALSANGI_33, DHULKED_33, NEVARGI_33	15:03	15:13	0:10	TRANSFORMER FAULT
890	9-Mar-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110, ALSANGI_33, DHULKED_33, NEVARGI_33	15:45	15:47	0:02	TRANSFORMER FAULT
891	9-Mar-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110, ALSANGI_33, DHULKED_33, NEVARGI_33	16:45	16:50	0:05	TRANSFORMER FAULT
892	9-Mar-2020	BENGALURU	220	HV2	EPIP 220	14:22	14:48	0:26	TRANSFORMER FAULT
893	9-Mar-2020	BENGALURU	66	EPIP 220 - SHAMARAJU TECH PARK	SHAMARAJU TECH PARK	14:22	14:50	0:28	LINE CLEAR AVAILED
894	9-Mar-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	16:52	16:57	0:05	LINE FAULT
895	9-Mar-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	16:35	18:50	2:15	LINE CLEAR AVAILED
896	9-Mar-2020	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	12:36	12:41	0:05	LOAD CHANGE OVER
897	9-Mar-2020	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	12:36	12:41	0:05	LOAD CHANGE OVER
898	9-Mar-2020	BENGALURU	66	KHODAYS 220 - SOUTH CITY	SOUTH CITY	12:36	12:41	0:05	LOAD CHANGE OVER
899	9-Mar-2020	BENGALURU	66	LEELA VENTURE - HAL 220	LEELA VENTURE	12:10	12:57	0:47	LINE CLEAR AVAILED
900	9-Mar-2020	BENGALURU	66	HV1	LEELA VENTURE	11:45	12:57	1:12	LINE CLEAR AVAILED
901	9-Mar-2020	BENGALURU	66	HV1	NAGANATHPURA 220	14:17	15:04	0:47	LINE CLEAR AVAILED
902	9-Mar-2020	BENGALURU	66	ST JOHN WOOD - ADUGODI	ST JOHN WOOD	6:23	6:28	0:05	LOAD CHANGE OVER
903	9-Mar-2020	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	16:24	16:29	0:05	LOAD CHANGE OVER
904	9-Mar-2020	BENGALURU	220	HV2	T K HALLI 220	21:29	21:53	0:24	TRANSFORMER FAULT
905	9-Mar-2020	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	21:29	21:56	0:27	LINE CLEAR AVAILED
906	9-Mar-2020	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 1	HALAGUR	21:29	22:04	0:35	LINE CLEAR AVAILED
907	9-Mar-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	21:29	21:54	0:25	LINE CLEAR AVAILED
908	9-Mar-2020	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	21:29	21:54	0:25	LINE CLEAR AVAILED
909	9-Mar-2020	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	21:29	22:00	0:31	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
910	9-Mar-2020	BENGALURU	66	HV2	T K HALLI 220	21:29	21:54	0:25	LINE CLEAR AVAILED
911	9-Mar-2020	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	HONNIGANAHALLI,DODDALAHALLI	21:29	21:54	0:25	LINE CLEAR AVAILED
912	9-Mar-2020	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A-2	TUBGERE	8:36	8:43	0:07	LINE FAULT
913	9-Mar-2020	BENGALURU	66	YELAHANKA 220 - LINE 8	RAJANKUNTE	1:29	1:44	0:14	LINE FAULT
914	9-Mar-2020	BENGALURU	66	HV2	SOMAYAJANAHALLI	22:00	22:11	0:11	TRANSFORMER FAULT
915	9-Mar-2020	BENGALURU	220	MITTEMARI 220 - GOWRINBIDANUR 220	MITTEMARI 220	12:30	18:25	5:55	LINE CLEAR AVAILED
916	9-Mar-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	12:30	18:25	5:55	MAIN SUUPPLY FAILURE
917	9-Mar-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI, SOMNATHPURA	12:30	18:25	5:55	MAIN SUUPPLY FAILURE
918	9-Mar-2020	BENGALURU	66	HV2	HBR LAYOUT	12:59	13:13	0:14	LINE CLEAR AVAILED
919	9-Mar-2020	BENGALURU	66	HV1	DEVANAHALLI	12:16	12:35	0:18	LINE CLEAR AVAILED
920	9-Mar-2020	BENGALURU	66	HV2	DODDABELAVANGALA	7:47	7:54	0:06	TRANSFORMER FAULT
921	9-Mar-2020	BENGALURU	66	HV2	DODDABELAVANGALA	16:23	16:30	0:06	TRANSFORMER FAULT
922	9-Mar-2020	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, DIBURAHALLI, PALLICHERLU, SADLI, JULUPALYA	11:01	12:50	1:49	LINE CLEAR AVAILED
923	9-Mar-2020	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, DIBURAHALLI, PALLICHERLU, SADLI, JULUPALYA	11:01	12:50	1:49	LINE CLEAR AVAILED
924	9-Mar-2020	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, DIBURAHALLI, PALLICHERLU, SADLI, JULUPALYA	15:02	15:14	0:12	LINE FAULT
925	9-Mar-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	18:28	18:31	0:02	LINE CLEAR AVAILED
926	9-Mar-2020	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	2:14	12:10	9:56	LINE FAULT
927	9-Mar-2020	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	4:47	11:08	6:21	LINE FAULT
928	9-Mar-2020	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	4:50	18:19	13:29	LINE FAULT
929	9-Mar-2020	GULBARGA	220	HV1,HV2	ITTAGI_220	7:15	8:05	0:50	HAND TRIPPED
930	9-Mar-2020	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	14:43	15:25	0:42	NFBC ISSUED
931	9-Mar-2020	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	15:00	15:34	0:34	LINE CLEAR AVAILED
932	9-Mar-2020	GULBARGA	220	KAPNOOR-HUMNABAD2	KAPNOOR_220	15:34	16:03	0:29	NFBC ISSUED
933	9-Mar-2020	GULBARGA	220	HUMNABAD-KAPNOOR2	KAPNOOR_220	15:40	16:20	0:40	LINE CLEAR AVAILED
934	9-Mar-2020	GULBARGA	220	HUMNABAD-HALBURGA1	HALBURGA_220	16:30	17:20	0:50	LINE CLEAR AVAILED
935	9-Mar-2020	GULBARGA	220	HUMNABAD-HALBURGA2	HALBURGA_220	17:25	18:20	0:55	LINE CLEAR AVAILED
936	9-Mar-2020	GULBARGA	220	HUMNABAD-HALBURGA1	HALBURGA_220	19:05	19:25	0:20	LINE CLEAR AVAILED
937	9-Mar-2020	GULBARGA	110	BETAGERA-KSHVCMNT_IPP	BETAGERA_110	4:18	4:27	0:09	LINE FAULT
938	9-Mar-2020	GULBARGA	110	SEDAM-SHAHABAD	CHITAPUR_110, KORWARTEMPLE_110, RAJSHREECEMENTS_110	4:18	8:05	3:47	LINE FAULT
939	9-Mar-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	4:47	4:54	0:07	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
940	9-Mar-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	5:55	6:10	0:15	LINE FAULT
941	9-Mar-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110,SAIDAPUR_110,CORE GREEN SUGAR_IPP,SANNATHI_IPP	6:11	6:22	0:11	LINE FAULT
942	9-Mar-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110,NIRNA_110	11:22	11:30	0:08	LINE FAULT
943	9-Mar-2020	GULBARGA	110	HV1	MANTHAL_110	13:20	13:45	0:25	LINE CLEAR AVAILED
944	9-Mar-2020	GULBARGA	110	HV2	MANTHAL_110	13:45	14:11	0:26	LINE CLEAR AVAILED
945	9-Mar-2020	GULBARGA	110	HV2	HATTI_110	14:56	15:01	0:05	TRANSFORMER FAULT
946	9-Mar-2020	GULBARGA	110	HV2	HATTI_110	16:05	17:01	0:56	TRANSFORMER FAULT
947	9-Mar-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,HUNASIGI_110,ASKI_110	21:35	21:42	0:07	LINE FAULT
948	9-Mar-2020	GULBARGA	66	HV2	TAMBRAHALLI_66	9:11	9:26	0:15	TRANSFORMER FAULT
949	9-Mar-2020	GULBARGA	66	HV2	TAMBRAHALLI_66	9:41	9:45	0:04	TRANSFORMER FAULT
950	9-Mar-2020	GULBARGA	66	ITTAGI-CLEANMAX1,2	ITTAGI_220	12:52	13:15	0:23	LINE FAULT
951	9-Mar-2020	GULBARGA	66	ITTAGI-TAMBRAHALLI	TAMBRAHALLI_66,HAMPASAGAR_66,MORAGERE_66	12:52	13:15	0:23	LINE FAULT
952	9-Mar-2020	GULBARGA	66	GUDEKOTE-HANGAL	GUDEKOTE_66	13:10	13:40	0:30	MAIN SUUPPLY FAILURE
953	9-Mar-2020	GULBARGA	66	ITTAGI-CLEANMAX1,2	ITTAGI_220	13:20	13:34	0:14	LINE FAULT
954	9-Mar-2020	GULBARGA	66	ITTAGI-TAMBRAHALLI	TAMBRAHALLI_66,HAMPASAGAR_66,MORAGERE_66	13:20	13:34	0:14	LINE FAULT
955	9-Mar-2020	GULBARGA	66	HV2	TAMBRAHALLI_66	17:30	18:40	1:10	LINE CLEAR AVAILED
956	9-Mar-2020	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	14:07	17:23	3:16	NFBC ISSUED
957	9-Mar-2020	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	14:07	17:23	3:16	NFBC ISSUED
958	9-Mar-2020	HASSAN	110	HV1	BARANGI_110	12:59	13:38	0:39	LINE CLEAR AVAILED
959	9-Mar-2020	HASSAN	110	HV2	ESSUR_110	12:32	14:30	1:58	LINE CLEAR AVAILED
960	9-Mar-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	17:34	17:43	0:09	LINE FAULT
961	9-Mar-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	7:33	7:38	0:05	LINE FAULT
962	9-Mar-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	7:48	7:50	0:02	LINE FAULT
963	9-Mar-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	12:00	12:06	0:06	LINE FAULT
964	9-Mar-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	12:36	12:42	0:06	LINE FAULT
965	9-Mar-2020	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	6:59	11:38	4:39	LINE FAULT
966	9-Mar-2020	HASSAN	66	HV2	HOLEHONNUR_66	11:27	12:14	0:47	LINE CLEAR AVAILED
967	9-Mar-2020	HASSAN	66	HV1	HANGARANAHALLY_66	15:39	15:52	0:13	TRANSFORMER FAULT
968	9-Mar-2020	MYSORE	66	BILIKERE-GV GUDI	GVGUDI_66	6:18	6:26	0:07	LINE FAULT
969	9-Mar-2020	MYSORE	66	BILIKERE-GV GUDI	GVGUDI_66	12:43	13:02	0:19	LINE FAULT
970	9-Mar-2020	MYSORE	66	BILIKERE-GV GUDI	GVGUDI_66	14:52	14:55	0:03	LINE FAULT
971	9-Mar-2020	MYSORE	66	HV1	KOPPA_66	10:34	10:40	0:06	HAND TRIPPED
972	9-Mar-2020	MYSORE	66	HV2	KOPPA_66	10:34	10:40	0:06	HAND TRIPPED
973	9-Mar-2020	MYSORE	66	HV1	MADDUR_66	21:29	21:56	0:27	HAND TRIPPED
974	9-Mar-2020	MYSORE	66	HV2	MADDUR_66	21:29	21:56	0:27	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
975	9-Mar-2020	MYSORE	220	HV1	MADHUVANAHALLI_220	11:50	18:24	6:33	LINE CLEAR AVAILED
976	9-Mar-2020	MYSORE	66	HV1	MADHUVANAHALLI_220	10:17	12:27	2:09	LINE CLEAR AVAILED
977	9-Mar-2020	MYSORE	220	HV2	MADHUVANAHALLI_220	9:01	11:40	2:39	LINE CLEAR AVAILED
978	9-Mar-2020	MYSORE	66	HV2	MALAVALLI_66	10:06	10:13	0:06	TRANSFORMER FAULT
979	9-Mar-2020	MYSORE	66	HV1	THANDYA_66	9:06	9:21	0:15	TRANSFORMER FAULT
980	9-Mar-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	17:36	17:41	0:05	LINE FAULT
981	9-Mar-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	17:56	18:03	0:07	LINE FAULT
982	9-Mar-2020	TUMKUR	110	TR-1	TURUVEKERE_110	9:37	14:35	4:57	LINE CLEAR AVAILED
983	9-Mar-2020	TUMKUR	110	TR-1	TURUVEKERE_110	19:32	20:00	0:27	TRANSFORMER FAULT
984	9-Mar-2020	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	16:32	16:40	0:08	TRANSFORMER FAULT
985	9-Mar-2020	TUMKUR	110	TR-2	HULIYAR_110	13:51	14:01	0:10	LINE CLEAR AVAILED
986	9-Mar-2020	TUMKUR	110	TR-2	HULIYAR_110	15:20	15:26	0:06	LINE CLEAR AVAILED
987	9-Mar-2020	TUMKUR	110	SAMPIGE- DODDAGUNI	DODDAGUNI_110,AMMASANDRA_110,SAMP IGE_110	12:23	12:41	0:17	LINE CLEAR AVAILED
988	9-Mar-2020	TUMKUR	110	SAMPIGE- DODDAGUNI	DODDAGUNI_110,AMMASANDRA_110,SAMP IGE_110	17:06	17:28	0:22	LINE CLEAR AVAILED
989	9-Mar-2020	TUMKUR	110	TR-1	SAMPIGE_110	12:23	12:42	0:19	LINE CLEAR AVAILED
990	9-Mar-2020	TUMKUR	110	TR-1	SAMPIGE_110	17:06	17:29	0:23	LINE CLEAR AVAILED
991	9-Mar-2020	TUMKUR	110	TR-2	SAMPIGE_110	7:19	7:33	0:13	TRANSFORMER FAULT
992	9-Mar-2020	TUMKUR	110	TR-2	SAMPIGE_110	12:23	12:42	0:19	LINE CLEAR AVAILED
993	9-Mar-2020	TUMKUR	110	TR-2	SAMPIGE_110	16:00	17:46	1:45	LINE CLEAR AVAILED
994	9-Mar-2020	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	12:23	12:41	0:18	LINE CLEAR AVAILED
995	9-Mar-2020	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	17:06	17:32	0:26	LINE CLEAR AVAILED
996	9-Mar-2020	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	9:10	9:15	0:04	LINE FAULT
997	9-Mar-2020	TUMKUR	66	BUKKAPATNA_66	TR-1	14:46	17:35	2:48	LINE CLEAR AVAILED
998	9-Mar-2020	TUMKUR	66	BUKKAPATNA_66	TR-2	14:32	14:40	0:08	LINE CLEAR AVAILED
999	9-Mar-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	6:33	7:18	0:45	LINE FAULT
1000	9-Mar-2020	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	CHITRADURGA_66	6:33	6:58	0:25	LINE FAULT
1001	9-Mar-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	9:05	9:18	0:12	HAND TRIPPED
1002	9-Mar-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	9:05	9:18	0:12	HAND TRIPPED
1003	9-Mar-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	17:22	17:29	0:07	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1004	9-Mar-2020	TUMKUR	66	HANAGAL-AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	13:15	13:31	0:16	LINE CLEAR AVAILED
1005	9-Mar-2020	TUMKUR	66	HANAGAL- B G KERE	BGKERE_66,GUDEKOTE_66	13:08	13:31	0:23	LINE CLEAR AVAILED
1006	9-Mar-2020	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	13:15	13:28	0:12	LINE CLEAR AVAILED
1007	9-Mar-2020	TUMKUR	66	TR-1	HANAGAL_66	13:14	13:31	0:16	LINE CLEAR AVAILED
1008	9-Mar-2020	TUMKUR	66	TR-2	HANAGAL_66	13:14	13:30	0:16	LINE CLEAR AVAILED
1009	9-Mar-2020	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	13:08	13:30	0:22	LINE CLEAR AVAILED
1010	9-Mar-2020	TUMKUR	66	TR-1	HARAPPANAHALLI_66	12:14	17:18	5:03	LINE CLEAR AVAILED
1011	9-Mar-2020	TUMKUR	66	TR-1	HARAPPANAHALLI_66	18:18	18:33	0:14	LINE CLEAR AVAILED
1012	9-Mar-2020	TUMKUR	66	TR-2	HIREGUNTANUR_66	11:19	13:02	1:43	LINE CLEAR AVAILED
1013	9-Mar-2020	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	16:15	16:47	0:32	HAND TRIPPED
1014	9-Mar-2020	TUMKUR	66	TR-1(L SIDE)	HIRIYUR_220	15:51	16:45	0:54	HAND TRIPPED
1015	9-Mar-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	15:47	17:03	1:16	LINE CLEAR AVAILED
1016	9-Mar-2020	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	16:15	16:51	0:36	HAND TRIPPED
1017	9-Mar-2020	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	16:15	16:51	0:36	HAND TRIPPED
1018	9-Mar-2020	TUMKUR	66	HIRIYURkv 220kv- SUZLON 2	SUZLON1_IPP_66	18:10	18:13	0:02	HAND TRIPPED
1019	9-Mar-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	17:49	17:52	0:02	LINE FAULT
1020	9-Mar-2020	TUMKUR	66	NEELAGUNDA-HARPANAHALLI-1	HARAPPANAHALLI_66	7:51	8:01	0:10	LINE FAULT
1021	9-Mar-2020	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	14:40	16:01	1:21	LINE CLEAR AVAILED
1022	9-Mar-2020	TUMKUR	66	SHYLAPURA-PR PURA	SHYLAPURA_66	16:01	16:07	0:06	HAND TRIPPED