

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 30.04.2019 to 06.05.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	30-Apr-19	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	12:17	18:42	6:25	LINE CLEAR AVAILED
2	30-Apr-19	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	0:00	19:04	19:04	LINE CLEAR AVAILED
3	30-Apr-19	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	11:11	19:45	8:34	LINE CLEAR AVAILED
4	30-Apr-19	BAGALKOT	110	BAGALKOT-NEERBUDIHAL(KATARAKI)	NEERBUDIHAL_110	0:00	1:16	1:16	LINE CLEAR AVAILED
5	30-Apr-19	BAGALKOT	110	110/33KV, HV1	MKHUBLI_110, DANDIGAWAD_33	15:03	15:15	0:12	LINE CLEAR AVAILED
6	30-Apr-19	BAGALKOT	110	110/33KV, HV4	LAKMANAHALLI_110, ALNAVAR_33	2:07	2:14	0:07	TRANSFORMER FAULT
7	30-Apr-19	BAGALKOT	110	110/11KV, HV2	KHANAPUR_110	16:07	16:48	0:41	LINE CLEAR AVAILED
8	30-Apr-19	BAGALKOT	110	INDI220-INDI	INDI_110	7:36	8:21	0:45	LINE FAULT
9	30-Apr-19	BANGALORE	66	HV1	SOMAHALLI 220	23:00	23:15	0:15	TRANSFORMER FAULT
10	30-Apr-19	BANGALORE	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	16:40	17:58	1:18	LINE FAULT
11	30-Apr-19	BANGALORE	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	16:20	16:39	0:19	LINE FAULT
12	30-Apr-19	BANGALORE	66	SUBRAMANYAPURA 220 - SUBRAMANYAPURA 1	SUBRAMANYAPURA 66, ISKON	17:34	17:37	0:03	LINE FAULT
13	30-Apr-19	BANGALORE	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66, ISKON	17:42	18:36	0:54	MAIN SUPPLY FAILURE
14	30-Apr-19	BANGALORE	66	SUBRAMANYAPURA 220 - SOMANAHALLI 2	SHOBHA FOREST, BRIGADE MEDOWS	20:24	22:21	1:57	LINE FAULT
15	30-Apr-19	BANGALORE	66	SOMANAHALLI 220 - KANAKAPURA 1	HANUMANTHAGAR, YEDUMADU	16:35	18:45	2:10	LINE FAULT
16	30-Apr-19	BANGALORE	220	SOMANAHALLI 220 - HAROHALLI (EHT)	HAROHALLI (EHT), KANAKAPURA 220	16:32	16:53	0:21	LINE FAULT
17	30-Apr-19	BANGALORE	220	HV2	KHODAYS 220	21:06	21:21	0:15	TRANSFORMER FAULT
18	30-Apr-19	BANGALORE	220	HV2	KANAKAPURA 220	16:32	16:53	0:20	MAIN SUPPLY FAILURE
19	30-Apr-19	BANGALORE	220	HV1	KANAKAPURA 220	16:32	16:53	0:20	MAIN SUPPLY FAILURE
20	30-Apr-19	BANGALORE	66	VRISHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	16:57	17:17	0:20	LINE FAULT
21	30-Apr-19	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	17:21	19:07	1:45	LINE FAULT
22	30-Apr-19	BANGALORE	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	18:08	18:55	0:46	LINE FAULT
23	30-Apr-19	BANGALORE	66	HV2	TAVAREKERE	20:32	20:34	0:02	TRANSFORMER FAULT
24	30-Apr-19	BANGALORE	66	SRS PEENYA 220 - NANDINI LAYOUT	NANDINI LAYOUT	20:01	20:33	0:31	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
25	30-Apr-19	BANGALORE	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	21:14	21:18	0:04	LOAD CHANGEOVER
26	30-Apr-19	BANGALORE	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	21:08	21:21	0:12	LOAD CHANGEOVER
27	30-Apr-19	BANGALORE	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	16:32	17:00	0:27	MAIN SUPPLY FAILURE
28	30-Apr-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	16:32	17:09	0:37	MAIN SUPPLY FAILURE
29	30-Apr-19	BANGALORE	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	16:32	17:07	0:35	MAIN SUPPLY FAILURE
30	30-Apr-19	BANGALORE	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	16:32	20:48	4:15	MAIN SUPPLY FAILURE
31	30-Apr-19	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	16:32	17:03	0:30	MAIN SUPPLY FAILURE
32	30-Apr-19	BANGALORE	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	0:00	21:37	21:37	LINE FAULT
33	30-Apr-19	BANGALORE	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	22:09	23:59	1:49	LINE FAULT
34	30-Apr-19	BANGALORE	66	HV2	HOODY 220	11:37	11:55	0:17	TRANSFORMER FAULT
35	30-Apr-19	BANGALORE	66	HV2	HOODY 220	21:28	21:40	0:12	TRANSFORMER FAULT
36	30-Apr-19	BANGALORE	66	HV1	BOODIGERE	17:32	17:37	0:05	TRANSFORMER FAULT
37	30-Apr-19	BANGALORE	66	HV1	BOODIGERE	18:21	18:35	0:13	TRANSFORMER FAULT
38	30-Apr-19	BANGALORE	66	HV1	BOODIGERE	19:29	19:37	0:08	LOAD CHANGEOVER
39	30-Apr-19	BANGALORE	66	HV2	MATHIKERE	14:50	15:50	1:00	LINE CLEAR AVAILED
40	30-Apr-19	BANGALORE	66	BAGHMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	19:44	20:28	0:44	LINE FAULT
41	30-Apr-19	BANGALORE	66	DB PURA 220 - DG 1	AIR (EHT)	19:42	19:48	0:05	LINE FAULT
42	30-Apr-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	23:55	23:59	0:04	LINE FAULT
43	30-Apr-19	BANGALORE	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	16:34	18:12	1:38	LINE FAULT
44	30-Apr-19	BANGALORE	66	YELAHANKA 220 - LINE 8	RAJANAKUNTE	19:48	20:13	0:24	LINE FAULT
45	30-Apr-19	BANGALORE	66	SADALI - JULUPALYA	SADALI	17:40	17:50	0:10	LINE FAULT
46	30-Apr-19	BANGALORE	66	BAGEPALLI - GOWRIBIDANUR 1	PATHPALYA, THIMAMPALLI, SOMANATHAPURA	23:25	23:53	0:28	LINE FAULT
47	30-Apr-19	BANGALORE	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHAPURA	23:25	23:55	0:30	LINE FAULT
48	30-Apr-19	BANGALORE	66	ABBIGERE - ATTUR YELAHANKA	ABBIGERE	22:40	22:44	0:04	LOAD CHANGEOVER
49	30-Apr-19	BANGALORE	66	ITI - HEBBAL 1	BANASWADI	19:54	20:52	0:58	LINE FAULT
50	30-Apr-19	BANGALORE	66	HV2	ITI	12:01	12:30	0:29	LINE CLEAR AVAILED
51	30-Apr-19	GULBARGA	400	JSWVL400-GUTTUR	GUTTUR_400	0:00	14:27	14:27	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
52	30-Apr-19	GULBARGA	220	HV2	HALBURGA_220	1:30	1:36	0:06	TRANSFORMER FAULT
53	30-Apr-19	GULBARGA	220	BTPSG-LINGAPUR	LINGAPUR_220	0:00	7:19	7:19	LINE FAULT
54	30-Apr-19	GULBARGA	220	LLINGAPUR-SINDHANOOR	LINGAPUR_220	0:00	13:57	13:57	LINE FAULT
55	30-Apr-19	GULBARGA	220	HV2	ITTAGI_220	5:40	5:42	0:02	TRANSFORMER FAULT
56	30-Apr-19	GULBARGA	220	HV2	ITTAGI_220	8:19	8:26	0:07	TRANSFORMER FAULT
57	30-Apr-19	GULBARGA	220	KAPNOOR-HUMNABAD2	KAPNOOR_220	17:30	19:22	1:52	LINE CLEAR AVAILED
58	30-Apr-19	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	18:21	18:46	0:25	LINE FAULT
59	30-Apr-19	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110, DONGRAGOA_110, KAMALNAGAR_110	1:30	1:40	0:10	LINE FAULT
60	30-Apr-19	GULBARGA	110	HV2	KAMPLI_GLB_110	9:08	9:15	0:07	TRANSFORMER FAULT
61	30-Apr-19	GULBARGA	110	HV1	TAMBRAHALLI_66	12:25	12:30	0:05	LINE CLEAR AVAILED
62	30-Apr-19	GULBARGA	110	HV1	KUSTAGI_220	13:20	13:30	0:10	TRANSFORMER FAULT
63	30-Apr-19	GULBARGA	110	HV3	KUSTAGI_220	7:37	8:13	0:36	LINE CLEAR AVAILED
64	30-Apr-19	GULBARGA	110	KUDTINI-BELLARY	KUDITINI_110,TORANGALLU_110	12:15	12:35	0:20	LINE CLEAR AVAILED
65	30-Apr-19	GULBARGA	110	KUDTINI-BELLARY	KUDITINI_110,TORANGALLU_110	13:15	13:20	0:05	LINE CLEAR AVAILED
66	30-Apr-19	GULBARGA	110	KUDTINI-BELLARY	KUDITINI_110,TORANGALLU_110	13:30	14:20	0:50	LINE CLEAR AVAILED
67	30-Apr-19	GULBARGA	110	HV1	KUDITINI_110	14:35	14:45	0:10	LINE CLEAR AVAILED
68	30-Apr-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	19:03	19:14	0:11	LINE FAULT
69	30-Apr-19	GULBARGA	66	HANASI-KUDALIGI	HANASI_66	12:40	12:50	0:10	LINE FAULT
70	30-Apr-19	GULBARGA	66	HV1	HAMPASAGAR_66	11:46	12:30	0:44	LINE CLEAR AVAILED
71	30-Apr-19	GULBARGA	66	HV1	HAMPASAGAR_66	6:27	6:33	0:06	TRANSFORMER FAULT
72	30-Apr-19	GULBARGA	66	ITTAGGI-RENEWSOLAR2	ITTAGI_220	0:00	3:00	3:00	LINE FAULT
73	30-Apr-19	GULBARGA	66	ITTAGGI-RENEWSOLAR2	ITTAGI_220	5:40	15:12	9:32	LINE FAULT
74	30-Apr-19	GULBARGA	66	ITTAGGI-HBHALLI	HAGARIBOMMANAHALLI_66,UPAN AYAKANAHALLI_66	8:19	15:16	6:57	LINE FAULT
75	30-Apr-19	GULBARGA	66	ITTAGGI-RENEWSOLAR1	ITTAGI_220	10:35	10:38	0:03	LINE FAULT
76	30-Apr-19	GULBARGA	66	ITTAGGI-RENEWSOLAR1	ITTAGI_220	10:40	10:48	0:08	LINE FAULT
77	30-Apr-19	GULBARGA	66	ITTAGGI-HBHALLI	HAGARIBOMMANAHALLI_66,UPAN AYAKANAHALLI_66	15:22	16:18	0:56	LOAD CHANGE OVER
78	30-Apr-19	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALI_66GIRIYAPURA_66, SOVENAHALLI_66,MAGALA_66,TUN GABHADRA_IPP	19:00	19:05	0:05	LINE FAULT
79	30-Apr-19	HASSAN	110	HV4	PUTTUR_110	10:29	10:40	0:11	LINE CLEAR AVAILED
80	30-Apr-19	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	9:06	16:18	7:12	LINE CLEAR AVAILED
81	30-Apr-19	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	9:06	16:18	7:12	LINE CLEAR AVAILED
82	30-Apr-19	HASSAN	110	HV4	MANIPAL_110	11:31	15:39	4:08	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
83	30-Apr-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	16:15	16:23	0:08	LOAD CURTAILMENT
84	30-Apr-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	20:28	20:35	0:07	LOAD CURTAILMENT
85	30-Apr-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	20:27	20:30	0:03	LOAD CURTAILMENT
86	30-Apr-19	HASSAN	66	L1-ALDUR	CHIKMAGALUR_66	16:14	16:20	0:06	LINE FAULT
87	30-Apr-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	0:00	0:11	0:11	LINE FAULT
88	30-Apr-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	0:00	0:12	0:12	LINE FAULT
89	30-Apr-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	0:56	1:38	0:42	LINE FAULT
90	30-Apr-19	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	16:25	16:55	0:30	LOAD CURTAILMENT
91	30-Apr-19	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	20:10	21:15	1:05	LOAD CURTAILMENT
92	30-Apr-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	7:43	18:30	10:47	LINE CLEAR AVAILED
93	30-Apr-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	7:43	18:30	10:47	LINE CLEAR AVAILED
94	30-Apr-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	16:25	16:54	0:29	LINE FAULT
95	30-Apr-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	20:14	21:17	1:03	LINE CLEAR AVAILED
96	30-Apr-19	MYSORE	66	HV2	BG NAGARA-	13:30	13:59	0:29	LINE CLEAR AVAILED
97	30-Apr-19	MYSORE	66	HV1	CHIKKMANDYA	10:46	23:59	13:12	LINE CLEAR AVAILED
98	30-Apr-19	MYSORE	66	HV1	ELAVALA	11:02	12:36	1:34	LINE CLEAR AVAILED
99	30-Apr-19	MYSORE	66	HV2	ELAVALA	11:38	13:25	1:46	LINE CLEAR AVAILED
100	30-Apr-19	MYSORE	66	HAMPAPURA-BASARALU	BESGRALLI & KOPPA	16:47	16:57	0:10	LINE FAULT
101	30-Apr-19	MYSORE	66	HV1	HANNUR	10:10	14:30	4:19	LINE CLEAR AVAILED
102	30-Apr-19	MYSORE	66	HANNUR-KOTTANUR	KOTTANUR	12:25	12:37	0:12	LINE FAULT
103	30-Apr-19	MYSORE	220	HV3	HOOTAGALLI-	19:58	21:26	1:27	TRANSFORMER FAULT
104	30-Apr-19	MYSORE	66	HUNSUR-HOOTAGALLI	BANNIKUPPE & HOSUR GATE	21:39	21:57	0:17	LINE FAULT
105	30-Apr-19	MYSORE	66	HV1	JYOTHINAGARA	10:47	18:05	7:18	LINE CLEAR AVAILED
106	30-Apr-19	MYSORE	66	HV1	JYOTHINAGARA	18:22	18:30	0:07	LINE CLEAR AVAILED
107	30-Apr-19	MYSORE	66	HV1	JYOTHINAGARA	21:09	23:59	2:49	LINE CLEAR AVAILED
108	30-Apr-19	MYSORE	66	HV1	K HONNALAGERE-	18:47	19:09	0:22	HAND TRIPPED
109	30-Apr-19	MYSORE	66	HV2	K HONNALAGERE-	17:58	19:10	1:11	LINE CLEAR AVAILED
110	30-Apr-19	MYSORE	66	KR PETE 220-SANTHEBACHALLI	SANTHE BACHALLI	19:25	19:33	0:08	LINE FAULT
111	30-Apr-19	MYSORE	66	KR PETE 220-SANTHEBACHALLI	SANTHE BACHALLI	19:49	21:02	1:12	LINE FAULT
112	30-Apr-19	MYSORE	66	KUSHALANAGARA 220-MYSORE-1	BILIKERE, BHERYA, DMG HALLI, KHB STATION, GV GUDI, MIRLE & KR NAGARA	10:10	10:21	0:11	LINE FAULT
113	30-Apr-19	MYSORE	66	KUSHALANAGARA 220-MYSORE-1	BILIKERE, BHERYA, DMG HALLI, KHB STATION, GV GUDI, MIRLE & KR NAGARA	11:10	16:45	5:35	LINE CLEAR AVAILED
114	30-Apr-19	MYSORE	66	KUSHALANAGARA 220-BETTADAPURA	BETTADAPURA, CHUNCHUNKATTE, KITTUR & RAVANDUR	22:03	22:23	0:19	LINE FAULT
115	30-Apr-19	MYSORE	66	MIRLE-KR NAGARA	MIRLE	11:10	17:24	6:14	NFBC ISSUED
116	30-Apr-19	MYSORE	66	HV1	SANTHE SARAGUR-	13:05	13:45	0:40	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
117	30-Apr-19	MYSORE	66	HV1	SANTHE SARAGUR-	13:47	14:35	0:47	TRANSFORMER FAULT
118	30-Apr-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	AC GIRI, ADDIHALLI, BASARALU, BG NAGARA, HARADANAHALLI (JAK), KESLAGERE, SHIVALLI & VADERALLI	18:16	18:25	0:08	LINE FAULT
119	30-Apr-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	AC GIRI, ADDIHALLI, BASARALU, BG NAGARA, HARADANAHALLI (JAK), KESLAGERE, SHIVALLI & VADERALLI	18:25	18:36	0:10	LINE FAULT
120	30-Apr-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	AC GIRI, ADDIHALLI, BASARALU, BG NAGARA, HARADANAHALLI (JAK), KESLAGERE, SHIVALLI & VADERALLI	18:37	19:12	0:35	LINE FAULT
121	30-Apr-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	AC GIRI, ADDIHALLI, BASARALU, BG NAGARA, HARADANAHALLI (JAK), KESLAGERE, SHIVALLI & VADERALLI	20:00	20:11	0:10	LINE FAULT
122	30-Apr-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	AC GIRI, ADDIHALLI, BASARALU, BG NAGARA, HARADANAHALLI (JAK), KESLAGERE, SHIVALLI & VADERALLI	21:48	21:52	0:03	LINE FAULT
123	30-Apr-19	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_22	10:23	16:37	6:14	LINE CLEAR AVAILED
124	30-Apr-19	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	21:09	21:40	0:31	LOAD CHANGEOVER
125	30-Apr-19	TUMKUR	110	K G TEMPLE-UNGRDLI	UNGRA_110	12:41	13:47	1:06	LINE FAULT
126	30-Apr-19	TUMKUR	110	K G TEMPLE-UNGRDLI	UNGRA_110	18:18	18:29	0:11	LINE FAULT
127	30-Apr-19	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	17:44	18:25	0:41	LINE FAULT
128	30-Apr-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	21:18	22:08	0:49	LINE FAULT
129	30-Apr-19	TUMKUR	66	TR-2	CHANNAGIRI_66	16:31	17:01	0:29	TRANSFORMER FAULT
130	30-Apr-19	TUMKUR	66	TR-2	HONNALLI_66	15:40	16:53	1:13	LINE CLEAR AVAILED
131	30-Apr-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	18:20	18:27	0:06	LINE FAULT
132	30-Apr-19	TUMKUR	66	TR-2	HULIYURDURGA_66	17:47	18:28	0:41	TRANSFORMER FAULT
133	30-Apr-19	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	1:24	1:37	0:12	MAIN SUPPLY FAILURE
134	30-Apr-19	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	19:34	21:23	1:48	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
135	30-Apr-19	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	22:00	22:36	0:35	LINE FAULT
136	30-Apr-19	TUMKUR	66	TR-1 & TR-2	MAVINAKATTE_66	11:38	11:39	0:01	LINE CLEAR AVAILED
137	30-Apr-19	TUMKUR	66	MAVINAKATTE-LINGADAHALLI	MAVINAKATTE_66	11:38	11:47	0:09	LINE CLEAR AVAILED
138	30-Apr-19	TUMKUR	66	TR-2	TAVAREKERE(C)_66	0:59	1:03	0:03	TRANSFORMER FAULT
139	30-Apr-19	TUMKUR	66	TR-1	TUMKUR_66	10:12	10:29	0:16	TRANSFORMER FAULT
140	1-May-19	BAGALKOT	220	AMBEWADI-NARENDRA 1	NARENDRA_220	0:00	18:17	18:17	LINE CLEAR AVAILED
141	1-May-19	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	11:02	18:16	7:14	LINE CLEAR AVAILED
142	1-May-19	BAGALKOT	110	110/11KV,HV-2	ANANAD NAGAR_110	10:20	15:28	5:08	LINE CLEAR AVAILED
143	1-May-19	BAGALKOT	110	110/33KV,HV-3	BAGALKOT_220&KATAGERI_33	12:22	14:29	2:07	LINE CLEAR AVAILED
144	1-May-19	BAGALKOT	110	BAGALKOT-NEERBUDIHAI(KATARAKI)	NEERBUDIHAI_110	12:22	15:18	2:56	LINE CLEAR AVAILED
145	1-May-19	BAGALKOT	110	BAGALKOT-LOKAPUR 1	LOKAPUR_110	12:22	15:09	2:47	LINE CLEAR AVAILED
146	1-May-19	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	12:22	14:29	2:07	LINE CLEAR AVAILED
147	1-May-19	BAGALKOT	110	BAGALKOT-GULEDGUDD	GULEDGUDD_110	12:22	14:29	2:07	LINE CLEAR AVAILED
148	1-May-19	BAGALKOT	110	BAGALKOT- NAVANAGAR 1&2	NAVANAGAR_110	12:22	14:29	2:07	LINE CLEAR AVAILED
149	1-May-19	BAGALKOT	110	220/110KV,LV-1	BAGALKOT_220	12:24	14:29	2:05	LINE CLEAR AVAILED
150	1-May-19	BAGALKOT	110	UGAR SUGARS-UGARKHUD	UGARKHUD_110	9:46	9:50	0:04	LINE FAULT
151	1-May-19	BAGALKOT	110	110/11KV, HV3	SOUDATTI_110	15:45	16:07	0:22	TRANSFORMER FAULT
152	1-May-19	BAGALKOT	110	110/11KV, HV2	MUKARTIHAI_110	9:08	9:16	0:08	TRANSFORMER FAULT
153	1-May-19	BAGALKOT	110	KUDACHI220-MORAB	MORAB_110	13:03	14:09	1:06	LINE CLEAR AVAILED
154	1-May-19	BAGALKOT	110	KARWAR220-BINAGA	BINAGA_110_EHT	17:33	23:59	6:26	LINE FAULT
155	1-May-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	12:15	12:20	0:05	LINE FAULT
156	1-May-19	BAGALKOT	110	KONNUR-KERUR	KERUR_110	10:55	14:45	3:50	LINE CLEAR AVAILED
157	1-May-19	BAGALKOT	110	KADANKOPPA-KAVALWADA	KAVALWADA_110	7:34	7:54	0:20	LINE FAULT
158	1-May-19	BAGALKOT	110	KADANKOPPA-KAVALWADA	KAVALWADA_110	12:15	12:23	0:08	LINE FAULT
159	1-May-19	BAGALKOT	110	110/11KV, HV2	BAGALKOT_110	13:01	13:35	0:34	LINE CLEAR AVAILED
160	1-May-19	BENGALURU	66	HV2	TAVAREKERE	3:22	3:28	0:06	TRANSFORMER FAULT
161	1-May-19	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	NO RELAY OPERATED	15:37	16:01	0:23	LINE FAULT
162	1-May-19	BENGALURU	66	TK HALLI 220 - SHIMSHA 2	NO RELAY OPERATED	15:37	15:54	0:16	LINE FAULT
163	1-May-19	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	10:08	10:13	0:04	LOAD CHANGEOVER
164	1-May-19	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	15:42	15:47	0:05	LOAD CHANGEOVER
165	1-May-19	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	10:45	15:49	5:04	LOAD CHANGEOVER
166	1-May-19	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	10:29	10:35	0:05	LOAD CHANGEOVER
167	1-May-19	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	16:55	17:05	0:10	LOAD CHANGEOVER
168	1-May-19	BENGALURU	66	APPARAL PARK - DB PURA 220	APPARAL PARK	10:33	10:37	0:04	LOAD CHANGEOVER
169	1-May-19	BENGALURU	66	HV2	BG ROAD	16:18	16:20	0:01	LINE CLEAR AVAILED
170	1-May-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	RBI	11:59	12:10	0:11	LOAD CHANGEOVER
171	1-May-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	RBI	14:23	14:35	0:12	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
172	1-May-19	BENGALURU	66	HV3	ELECTRONIC CITY	1:14	1:26	0:11	TRANSFORMER FAULT
173	1-May-19	BENGALURU	66	HV2	ELECTRONIC CITY P2 S2	17:06	17:11	0:05	TRANSFORMER FAULT
174	1-May-19	BENGALURU	66	HV1	KEMGERI SATELLITE TOWN	1:37	2:04	0:27	TRANSFORMER FAULT
175	1-May-19	BENGALURU	66	HV1	KEMGERI SATELLITE TOWN	3:21	3:35	0:14	TRANSFORMER FAULT
176	1-May-19	BENGALURU	66	HV1	KEMGERI SATELLITE TOWN	8:03	8:17	0:13	LINE CLEAR AVAILED
177	1-May-19	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	6:13	6:30	0:17	LOAD CHANGE OVER
178	1-May-19	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	14:35	14:40	0:05	LOAD CHANGE OVER
179	1-May-19	BENGALURU	66	ATTUR YELAHANKA - DG 4	ATTUR YELAHANKA	15:16	15:20	0:03	LOAD CHANGE OVER
180	1-May-19	BENGALURU	220	VRISHBHAVATHI 220 - TATAGUNI (EHT)	VRISHBHAVATHI 220	0:42	1:09	0:27	LINE FAULT
181	1-May-19	BENGALURU	66	VRISHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	0:42	1:17	0:35	MAIN SUPPLY FAILURE
182	1-May-19	BENGALURU	66	VRISHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	0:42	1:17	0:35	MAIN SUPPLY FAILURE
183	1-May-19	BENGALURU	66	VRISHBHAVATHI 220 - REMCO	REMCO	0:42	1:13	0:31	MAIN SUPPLY FAILURE
184	1-May-19	BENGALURU	66	VRISHBHAVATHI 220 - SIR MV LAYOUT	KNGERI SATELLITE TOWN, SIR MV LAYOUT	0:42	1:16	0:34	MAIN SUPPLY FAILURE
185	1-May-19	BENGALURU	66	HV1	KHB	0:10	0:30	0:19	TRANSFORMER FAULT
186	1-May-19	BENGALURU	66	KHB - YELAHANKA 220	KHB	9:50	9:55	0:05	LOAD CHANGE OVER
187	1-May-19	BENGALURU	66	KHB - SRS PEENYA 220	KHB	13:38	13:49	0:11	LOAD CHANGE OVER
188	1-May-19	BENGALURU	66	HV1	BRINDAVAN	10:35	11:42	1:07	LINE CLEAR AVAILED
189	1-May-19	BENGALURU	66	HV2	BRINDAVAN	11:49	12:25	0:36	LINE CLEAR AVAILED
190	1-May-19	BENGALURU	66	HV3	BRINDAVAN	12:32	13:15	0:43	LINE CLEAR AVAILED
191	1-May-19	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66, ISKON	16:22	16:28	0:06	LOAD CHANGE OVER
192	1-May-19	BENGALURU	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	11:56	12:12	0:16	LOAD CHANGE OVER
193	1-May-19	BENGALURU	66	SOMANAHALLI 220 - KANAKAPURA 1	HANUMANTHNAGAR, YEDUMADU	11:57	12:13	0:16	LOAD CHANGE OVER
194	1-May-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	11:58	12:12	0:14	LOAD CHANGE OVER
195	1-May-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	14:23	14:33	0:10	LOAD CHANGE OVER
196	1-May-19	BENGALURU	66	HV1	CHANNAPATNA	16:59	17:18	0:18	LINE CLEAR AVAILED
197	1-May-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	16:10	16:14	0:04	LINE FAULT
198	1-May-19	BENGALURU	220	HV1	KIADB DB PURA 220	2:01	3:40	1:38	TRANSFORMER FAULT
199	1-May-19	BENGALURU	220	HV2	KIADB DB PURA 220	2:00	3:56	1:55	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
200	1-May-19	BENGALURU	66	KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	2:00	2:30	0:29	LINE FAULT
201	1-May-19	BENGALURU	66	KIADB DB PURA 220 - HSS (EHT)	HSS (EHT)	2:01	3:41	1:39	MAIN SUPPLY FAILURE
202	1-May-19	BENGALURU	66	APPAREL PARK - DB PURA 220	APPAREL PARK	10:30	10:35	0:05	LOAD CHANGEOR
203	1-May-19	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHAPURA	12:57	13:10	0:13	LINE FAULT
204	1-May-19	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 2	BAGEPALLI	12:57	13:10	0:12	LINE FAULT
205	1-May-19	BENGALURU	66	HV1	HULLENAHALLI	12:03	12:12	0:09	TRANSFORMER FAULT
206	1-May-19	BENGALURU	66	HV3	KGF	10:58	12:06	1:08	TRANSFORMER FAULT
207	1-May-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:53	9:58	0:05	LINE FAULT
208	1-May-19	BENGALURU	66	ABBIGERE - WELCAST STEEL	ABBIGERE	15:30	15:34	0:04	LOAD CHANGEOR
209	1-May-19	BENGALURU	66	YELAHANKA 220 - LINE 8	RAJANAKUNTE	3:02	3:44	0:42	LINE FAULT
210	1-May-19	BENGALURU	66	MANYATA TECH PARK - ATTUR YELAHANKA	MANYATA TECH PARK	14:27	15:20	0:53	LINE CLEAR AVAILED
211	1-May-19	BENGALURU	66	SAHAKARINAGARA - ATTUR YELAHANKA	SAHAKARINAGARA	13:50	14:05	0:15	LOAD CHANGEOR
212	1-May-19	BENGALURU	66	SAHAKARINAGARA - PLATINUM CITY	SAHAKARINAGARA	14:25	14:30	0:05	LOAD CHANGEOR
213	1-May-19	GULBARGA	220	HV2	KUSTAGI_220	11:49	12:04	0:15	TRANSFORMER FAULT
214	1-May-19	GULBARGA	220	HV2	KUSTAGI_220	12:38	12:51	0:13	TRANSFORMER FAULT
215	1-May-19	GULBARGA	220	HV2	KUSTAGI_220	13:48	14:06	0:18	TRANSFORMER FAULT
216	1-May-19	GULBARGA	110	HV1	BISIHALLI_110	8:28	10:41	2:13	TRANSFORMER FAULT
217	1-May-19	GULBARGA	110	HV2	BISIHALLI_110	10:39	10:52	0:13	TRANSFORMER FAULT
218	1-May-19	GULBARGA	110	KUSTAGI-ILKAL1,2	ILKAL_110	11:49	12:16	0:27	LINE FAULT
219	1-May-19	GULBARGA	110	KUSTAGI-ILKAL1,2	ILKAL_110	12:38	12:56	0:18	LINE FAULT
220	1-May-19	GULBARGA	110	KUSTAGI-ILKAL1,2	ILKAL_110	13:48	14:17	0:29	LINE FAULT
221	1-May-19	GULBARGA	110	KUSTAGI-ILKAL1,2	ILKAL_110	15:30	15:42	0:12	LINE FAULT
222	1-May-19	GULBARGA	110	KUSTAGI-KANAKAGIRI	GANADAL_110, KANAKAGIRI_110	15:30	15:42	0:12	LINE FAULT
223	1-May-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,KAVITAL_110	10:13	10:20	0:07	LINE FAULT
224	1-May-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,KAVITAL_110	8:20	8:25	0:05	LINE FAULT
225	1-May-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,KAVITAL_110	9:46	9:52	0:06	LINE FAULT
226	1-May-19	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	20:43	21:00	0:17	LINE CLEAR AVAILED
227	1-May-19	GULBARGA	110	HV1	SIRWAR_110	13:50	14:05	0:15	TRANSFORMER FAULT
228	1-May-19	GULBARGA	110	HV1	SIRWAR_110	18:05	18:20	0:15	TRANSFORMER FAULT
229	1-May-19	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADALAPURA_110(ID LE LINE)	12:29	12:42	0:13	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
230	1-May-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	KARTAGI_110, GANGAVATHI_110, SRERAMANAGAR_110, VENKATAGIRI_110	12:15	12:30	0:15	LINE CLEAR AVAILED
231	1-May-19	GULBARGA	110	HV1	YELBURGA_110	18:56	19:07	0:11	TRANSFORMER FAULT
232	1-May-19	GULBARGA	66	HV1	HAMPASAGAR_66	15:31	15:34	0:03	TRANSFORMER FAULT
233	1-May-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	1:05	12:21	11:16	LINE CLEAR AVAILED
234	1-May-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	2:31	23:59	21:28	LINE CLEAR AVAILED
235	1-May-19	HASSAN	110	HV3	BANTWAL_110	9:30	10:02	0:32	LINE CLEAR AVAILED
236	1-May-19	HASSAN	110	HV1	KEMAR_220	16:23	17:27	1:04	LINE CLEAR AVAILED
237	1-May-19	HASSAN	110	MRSSHM-MYSORE	MRSMG_220	10:02	12:36	2:34	LINE CLEAR AVAILED
238	1-May-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	7:48	7:55	0:07	LINE FAULT
239	1-May-19	HASSAN	66	HASSN22-MALLALI	HASSAN_220	2:33	2:51	0:18	LINE FAULT
240	1-May-19	HASSAN	66	BANDISHE-ADANI	BANDISHETTYHALLI_66	13:52	14:05	0:13	MAIN SUPPLY FAILURE
241	1-May-19	HASSAN	66	HIREMAN-RDL	HIREMANGALUR_66	9:59	20:28	10:29	LINE CLEAR AVAILED
242	1-May-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	13:57	14:01	0:04	HAND TRIPPED
243	1-May-19	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	14:15	15:20	1:05	LINE CLEAR AVAILED
244	1-May-19	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	14:15	15:20	1:05	LINE CLEAR AVAILED
245	1-May-19	HASSAN	66	HV2	RAMPURA_66	3:05	3:17	0:12	TRANSFORMER FAULT
246	1-May-19	HASSAN	66	HV2	RAMPURA_66	6:15	6:47	0:32	LINE CLEAR AVAILED
247	1-May-19	MYSORE	66	HV1	DODDABYADARAHALLI_66	11:50	12:24	0:33	LINE CLEAR AVAILED
248	1-May-19	MYSORE	66	HAMPAPURA-MANDYA	CHIKKA_MANDYA_66	9:28	23:59	14:30	LINE FAULT
249	1-May-19	MYSORE	66	MANDYA-CHIKKAMANDYA	CHIKKA_MANDYA_66 BESAGARAHALLI_66 HAMPAPURA_66 KOPPA_66	8:36	10:04	1:28	NFBC ISSUED
250	1-May-19	MYSORE	66	MANDYA-M2	HADLI_66 MALAVALLI_66	8:53	10:00	1:07	LINE CLEAR AVAILED
251	1-May-19	MYSORE	66	HV2	SALIGRAMA_66	11:06	11:11	0:05	TRANSFORMER FAULT
252	1-May-19	MYSORE	66	HV1	SANTHESARAGUR_66	13:24	13:35	0:11	TRANSFORMER FAULT
253	1-May-19	MYSORE	66	HV1	SANTHESARAGUR_66	18:13	18:21	0:07	TRANSFORMER FAULT
254	1-May-19	MYSORE	66	TUBINAKERE-MC-2	MANDYA_66	8:47	9:48	1:00	LINE CLEAR AVAILED
255	1-May-19	MYSORE	66	TUBINAKERE-MC-4	MANDYA_66	8:48	9:48	1:00	LINE CLEAR AVAILED
256	1-May-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 BASARALU_66 KESLAGERE_66 SHIVALLY_66 VADERALLI_66	1:06	1:12	0:05	LINE FAULT
257	1-May-19	TUMKUR	220	TR-3	HIRIYUR_220	1:08	6:45	5:36	TRANSFORMER FAULT
258	1-May-19	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA_220 1	MADHUGIRI 220kV	7:34	9:05	1:31	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
259	1-May-19	TUMKUR	220	MADHUGIRI 220kV-GOWRIBIDANUR220	MADHUGIRI 220kV	1:01	7:31	6:30	LINE FAULT
260	1-May-19	TUMKUR	220	TR-1 & TR-2	MADHUGIRI 220kV	1:18	7:51	6:33	TRANSFORMER FAULT
261	1-May-19	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	10:24	10:46	0:21	LINE FAULT
262	1-May-19	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	12:28	12:37	0:09	LINE FAULT
263	1-May-19	TUMKUR	66	TR-2	BEVINAHALLI_66	15:49	16:34	0:45	LINE CLEAR AVAILED
264	1-May-19	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	1:41	2:20	0:39	LINE FAULT
265	1-May-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	9:03	10:58	1:55	LINE CLEAR AVAILED
266	1-May-19	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	1:59	5:41	3:42	LINE FAULT
267	1-May-19	TUMKUR	66	HANGAL66-RAMPURA	NAGASAMUDRA_66,RAMPURA_66	4:32	4:34	0:01	LINE FAULT
268	1-May-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	1:36	3:03	1:26	LINE FAULT
269	1-May-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	7:13	7:22	0:08	LINE FAULT
270	1-May-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	1:36	3:03	1:26	LINE CLEAR AVAILED
271	1-May-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	7:13	7:22	0:08	HAND TRIPPED
272	1-May-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	1:36	7:24	5:48	LINE CLEAR AVAILED
273	1-May-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	14:18	14:31	0:12	LINE FAULT
274	1-May-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	12:39	12:49	0:09	LINE FAULT
275	1-May-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	6:12	6:21	0:09	LINE FAULT
276	1-May-19	TUMKUR	66	LINGADAHALLI- SHYLAPURA	SHYLAPURA_66,, MANGALWADA_66, YNHOSKOTE_66	3:36	9:11	5:35	LINE CLEAR AVAILED
277	1-May-19	TUMKUR	66	TR-1 & TR-2	MADHUGIRI_220	1:18	7:54	6:36	TRANSFORMER FAULT
278	1-May-19	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	0:26	8:34	8:07	LINE CLEAR AVAILED
279	1-May-19	TUMKUR	66	TR-1	MAYAKONDA_66	5:59	6:04	0:04	TRANSFORMER FAULT
280	1-May-19	TUMKUR	66	TR-1	NAGASAMUDRA_66	1:48	2:02	0:14	LINE CLEAR AVAILED
281	1-May-19	TUMKUR	66	TR-1	NAGASAMUDRA_66	12:18	16:24	4:06	LINE CLEAR AVAILED
282	1-May-19	TUMKUR	66	TR-2	NAYAKANAHATTI_66	12:31	19:02	6:30	MAIN SUPPLY FAILURE
283	1-May-19	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	0:46	0:47	0:01	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
284	1-May-19	TUMKUR	66	SHYLAPURA-PR PURA	YNHOSKOTE_66, MANGALWADA_66,LINGDHALLI_66	7:40	9:07	1:27	LINE CLEAR AVAILED
285	1-May-19	TUMKUR	66	TR-2	YEDIYUR_66	1:09	1:24	0:14	TRANSFORMER FAULT
286	2-May-19	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	12:12	18:38	6:26	LINE FAULT
287	2-May-19	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	19:01	21:58	2:57	LINE CLEAR AVAILED
288	2-May-19	BAGALKOT	110	110/11KV,HV-1	ANAND NAGAR_110	10:17	14:51	4:34	LINE CLEAR AVAILED
289	2-May-19	BAGALKOT	110	110/33KV,HV-3	GAJENDRAGAD_110 &WIND 1&2_33KV	11:37	11:51	0:14	LINE CLEAR AVAILED
290	2-May-19	BAGALKOT	220	BAGALKOT-ALAMATTI 2	BAGALKOT_220	10:53	16:53	6:00	LINE CLEAR AVAILED
291	2-May-19	BAGALKOT	220	CHIKKODI-MUDASHINGI(KOLHAPUR 2)	CHIKKODI_220	0:00	12:12	12:12	LINE CLEAR AVAILED
292	2-May-19	BAGALKOT	110	KARAWAR-KUMATA(ARAGA)	KUMATA_110	6:58	9:46	2:48	LINE CLEAR AVAILED
293	2-May-19	BAGALKOT	110	KARAWAR-BINAGA(ARAGA)	BINAGA 110_EHT	0:00	9:46	9:46	LINE CLEAR AVAILED
294	2-May-19	BAGALKOT	110	MMCL-SOUDATTI	SOUDATTI_220	17:50	18:01	0:11	LINE CLEAR AVAILED
295	2-May-19	BAGALKOT	220	SIRSI_220-SHARAVATHI1	SIRSI-220	16:43	18:21	1:38	LINE FAULT
296	2-May-19	BAGALKOT	220	SIRSI_220-SHARAVATHI2	SIRSI-220	12:57	18:33	5:36	LINE CLEAR AVAILED
297	2-May-19	BAGALKOT	110	110/33KV,HV3	SALAHALLI_110,HULKUND_33KV	17:10	17:54	0:44	LINE CLEAR AVAILED
298	2-May-19	BAGALKOT	110	110/11KV,HV1	SALAHALLI_110	17:57	18:51	0:54	LINE CLEAR AVAILED
299	2-May-19	BAGALKOT	110	NARENDRA-MRUTHYUNJAY NAGAR2	MRUTHYUNJAY NAGAR_110	10:47	23:59	13:12	LINE CLEAR AVAILED
300	2-May-19	BAGALKOT	110	DODDANAVAR-NANADI	NANADI_110	16:08	23:59	7:51	LINE CLEAR AVAILED
301	2-May-19	BAGALKOT	110	CHIKKODI220-NANADI	NANADI_110	16:51	17:21	0:30	LINE CLEAR AVAILED
302	2-May-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	16:49	18:59	2:10	LINE CLEAR AVAILED
303	2-May-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	20:23	20:30	0:07	TRANSFORMER FAULT
304	2-May-19	BAGALKOT	110	110/33KV,HV3	MUNAVALLI_110,MUNAVALLI_33K V,MALLUR_33KV	17:46	18:37	0:51	LINE CLEAR AVAILED
305	2-May-19	BAGALKOT	110	110/33KV,HV1	MK HUBLI_110,GANDIGAWAD_33KV	10:01	13:47	3:46	LINE CLEAR AVAILED
306	2-May-19	BAGALKOT	110	110/33KV,HV1	MK HUBLI_110,GANDIGAWAD_33KV	14:20	15:24	1:04	LINE CLEAR AVAILED
307	2-May-19	BAGALKOT	110	110/11KV,HV2	MAMADAPUR_110	12:05	12:20	0:15	LINE CLEAR AVAILED
308	2-May-19	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	9:57	23:59	14:02	LINE CLEAR AVAILED
309	2-May-19	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	10:30	10:34	0:04	LOAD CHANGE OVER
310	2-May-19	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	10:28	10:35	0:07	LOAD CHANGE OVER
311	2-May-19	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	13:42	14:46	1:04	LINE CLEAR AVAILED
312	2-May-19	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	11:49	14:46	2:56	LINE FAULT
313	2-May-19	BENGALURU	66	HV2	DEVANGONDHI	4:26	4:35	0:08	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
314	2-May-19	BENGALURU	66	GANJIGUNTE - DIBBURAHALLI	DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	9:14	11:17	2:02	LINE CLEAR AVAILED
315	2-May-19	BENGALURU	66	GANJIGUNTE - DIBBURAHALLI	DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	17:10	18:22	1:11	LINE CLEAR AVAILED
316	2-May-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	16:26	17:56	1:29	LINE FAULT
317	2-May-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	14:20	16:44	2:24	LINE CLEAR AVAILED
318	2-May-19	BENGALURU	66	HV2	Y HUNSENAHALLI	15:25	16:45	1:20	LINE CLEAR AVAILED
319	2-May-19	GULBARGA	220	HUMNABAD220-SEDAM1	SEDAM_220	12:11	12:21	0:10	LINE CLEAR AVAILED
320	2-May-19	GULBARGA	220	SHAHPUR-LINGASUGUR	LINGASUGUR_220	0:00	16:00	16:00	LINE CLEAR AVAILED
321	2-May-19	GULBARGA	110	YELBURGA-PARAMPOOJYASLR_IPP	YELBURGA_110	11:06	11:16	0:10	LINE CLEAR AVAILED
322	2-May-19	GULBARGA	110	SINDHANOOR220-PGLR_WIND	SIDHANOOR_220	23:52	23:59	0:07	LINE FAULT
323	2-May-19	GULBARGA	110	SINDHANOOR220-PGLR_WIND	SIDHANOOR_220	0:00	0:15	0:15	LINE FAULT
324	2-May-19	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	SINDHANOOR_110	15:23	15:38	0:15	LINE FAULT
325	2-May-19	GULBARGA	110	KUSTAGI-KANKAGIRI	KANAKAGIRI_110, GANADAL_110	11:52	12:23	0:31	LINE CLEAR AVAILED
326	2-May-19	GULBARGA	110	KUSTAGI-ILKAL	ILKAL_110	12:05	12:13	0:08	LINE CLEAR AVAILED
327	2-May-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	13:01	13:08	0:07	LINE FAULT
328	2-May-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARAGUTTI_110	12:02	12:19	0:17	LINE FAULT
329	2-May-19	GULBARGA	110	HV2	KAMPLI_GLB_110	20:48	20:58	0:10	TRANSFORMER FAULT
330	2-May-19	GULBARGA	66	ITTAGGI-RENEWSOLAR1,2	ITTAGI_220	9:43	9:52	0:09	LINE CLEAR AVAILED
331	2-May-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	3:38	3:38	LINE CLEAR AVAILED
332	2-May-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:17	23:59	5:42	LINE CLEAR AVAILED
333	2-May-19	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	16:41	18:20	1:39	NFBC ISSUED
334	2-May-19	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	12:56	18:35	5:39	NFBC ISSUED
335	2-May-19	HASSAN	66	HV1	BYACHANAHALLY_66	8:26	8:34	0:08	TRANSFORMER FAULT
336	2-May-19	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	15:03	15:06	0:03	LINE FAULT
337	2-May-19	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	15:16	15:17	0:01	LINE FAULT
338	2-May-19	HASSAN	66	HV1	DODDAKADANUR_66	11:08	11:14	0:06	HAND TRIPPED
339	2-May-19	HASSAN	66	HV1	DODDAKADANUR_66	15:03	15:06	0:03	TRANSFORMER FAULT
340	2-May-19	HASSAN	66	HV1	DODDAKADANUR_66	15:16	15:18	0:02	TRANSFORMER FAULT
341	2-May-19	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	15:03	15:06	0:03	LINE FAULT
342	2-May-19	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	15:16	15:17	0:01	LINE FAULT
343	2-May-19	HASSAN	66	HV1	HARIHARAPURA_66	16:33	16:47	0:14	MAIN SUPPLY FAILURE
344	2-May-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	7:44	19:37	11:53	LINE CLEAR AVAILED
345	2-May-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	7:44	19:37	11:53	LINE CLEAR AVAILED
346	2-May-19	HASSAN	400	HASSAN4-UPCL2	SHANTHIGRAMA_400	23:48	23:59	0:11	HAND TRIPPED
347	2-May-19	HASSAN	220	MRSSHM-HONNALLI	MRS MG_220	12:41	13:05	0:24	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
348	2-May-19	HASSAN	66	HADAVAN-HNPURA	HADAVANAHALLY_66	16:30	16:45	0:15	HAND TRIPPED
349	2-May-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	11:00	15:45	4:45	LINE CLEAR AVAILED
350	2-May-19	MYSORE	66	HV1	GUDDENAHALLI_66	12:35	13:27	0:51	LINE CLEAR AVAILED
351	2-May-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	2:08	2:11	0:02	LINE FAULT
352	2-May-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	4:50	4:56	0:05	LINE FAULT
353	2-May-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	5:50	5:56	0:05	LINE FAULT
354	2-May-19	MYSORE	66	HV1	SANTHESARAGUR_66	12:42	14:15	1:33	LINE CLEAR AVAILED
355	2-May-19	MYSORE	66	HV1	THANDYA_66	11:44	13:01	1:17	LINE CLEAR AVAILED
356	2-May-19	MYSORE	66	HV1	THANDYA_66	13:08	13:20	0:11	TRANSFORMER FAULT
357	2-May-19	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	15:27	15:50	0:22	HAND TRIPPED
358	2-May-19	TUMKUR	110	TIPTUR110- HONNAVALI	HALKURKE_110, HUNSEGHATTA_110, KEREKODI_110,HONNAVALI_110	16:11	16:14	0:02	HAND TRIPPED
359	2-May-19	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	ANCHEPALYA_220	3:45	4:14	0:28	LINE FAULT
360	2-May-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	14:15	14:34	0:18	LINE FAULT
361	2-May-19	TUMKUR	66	CHIKKABANAGERE- GLOBAL TECKPARK	GLOBAL TECKPARK_IPP_66	8:46	8:55	0:08	HAND TRIPPED
362	2-May-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, CHIKKAJAJUR_66, MAYAKONDA_66, SASALUHALLA_66	13:48	15:20	1:31	LINE CLEAR AVAILED
363	2-May-19	TUMKUR	66	TR-2	HONNALI_66	12:43	13:16	0:33	LINE CLEAR AVAILED
364	2-May-19	TUMKUR	66	TR-1	HULIYURDURGA_66	3:03	3:07	0:03	TRANSFORMER FAULT
365	2-May-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:52	10:54	0:01	LINE FAULT
366	2-May-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	5:47	6:02	0:15	LINE FAULT
367	2-May-19	TUMKUR	66	TR-1	MAVINAKATTE_66	8:13	8:25	0:12	LINE CLEAR AVAILED
368	2-May-19	TUMKUR	66	NAGASAMUDRA- IPP_SOLAR	WELSPUN_IPP_SOLAR_66	12:32	13:02	0:29	MAIN SUPPLY FAILURE
369	2-May-19	TUMKUR	66	TR-1	RAMPURA_66	9:06	9:18	0:12	TRANSFORMER FAULT
370	2-May-19	TUMKUR	66	TR-1	SAVALANGA_66	12:58	13:08	0:10	MAIN SUPPLY FAILURE
371	2-May-19	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	12:17	12:54	0:37	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
372	2-May-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	13:02	15:20	2:18	LINE FAULT
373	3-May-19	BAGALKOT	110	110/11KV,HV-2	AINAPUR_110	19:25	19:32	0:07	LOAD CURTAILMENT
374	3-May-19	BAGALKOT	110	110/11KV,HV-1	ANANDNAGAR_110	9:24	12:09	2:45	LINE CLEAR AVAILED
375	3-May-19	BAGALKOT	110	110/11KV,HV-1	ATHARGA_110	19:25	19:36	0:11	LOAD CURTAILMENT
376	3-May-19	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	12:37	15:59	3:22	LINE FAULT
377	3-May-19	BAGALKOT	110	BIJAPUR-ENERCON(BAGEWADI)	ENERCON_110	11:25	18:51	7:26	LINE CLEAR AVAILED
378	3-May-19	BAGALKOT	110	110/11KV,HV-4	GAJENDRAGAD_110	19:25	20:03	0:38	LOAD CURTAILMENT
379	3-May-19	BAGALKOT	110	110/33KV,HV3	TILUVALI_110, KALKERI_33	12:42	12:47	0:05	TRANSFORMER FAULT
380	3-May-19	BAGALKOT	110	SOUDATTI220-RAMDURG	RAMDURG_110	12:50	12:57	0:07	LINE CLEAR AVAILED
381	3-May-19	BAGALKOT	110	SOUDATTI220-MMCL	SOUDATTI_220	15:19	17:12	1:53	LINE CLEAR AVAILED
382	3-May-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	15:39	23:59	8:20	LINE FAULT
383	3-May-19	BAGALKOT	110	SIRSI-KUMTA1	SIRSI_110	14:07	14:29	0:22	LINE CLEAR AVAILED
384	3-May-19	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	18:12	18:19	0:07	TRANSFORMER FAULT
385	3-May-19	BAGALKOT	110	110/33KV,HV3	RON_110	8:41	9:33	0:52	TRANSFORMER FAULT
386	3-May-19	BAGALKOT	110	NARENDRA-MRUTHYUNJAY NAGAR2	MRUTHYUNJAY NAGAR_110	0:00	15:50	15:50	LINE CLEAR AVAILED
387	3-May-19	BAGALKOT	110	CHIKKODI110-NANADI	NANADI_110	6:51	7:30	0:39	LINE CLEAR AVAILED
388	3-May-19	BAGALKOT	110	DODDANAVAR-NANADI	NANADI_110	0:00	7:49	7:49	LINE CLEAR AVAILED
389	3-May-19	BAGALKOT	110	110/11KV,HV1	MACHE_110	17:45	18:19	0:34	LINE CLEAR AVAILED
390	3-May-19	BAGALKOT	110	110/11KV,HV1	HANGAL_110	19:25	19:37	0:12	LOAD CURTAILMENT
391	3-May-19	BAGALKOT	110	110/11KV,HV2	KHANAPUR_110	12:39	16:26	3:47	LINE CLEAR AVAILED
392	3-May-19	BAGALKOT	110	110/33KV,HV3	GOPPANAKOPPA_110, KUSUGAL_33	12:59	13:46	0:47	LINE CLEAR AVAILED
393	3-May-19	BAGALKOT	110	110/11KV,HV1	GOKAK_110	13:03	14:48	1:45	MAIN SUPPLY FAILURE
394	3-May-19	BAGALKOT	110	110/11KV,HV2	GOKAK_110	13:03	14:49	1:46	MAIN SUPPLY FAILURE
395	3-May-19	BAGALKOT	110	110/33KV,HV3	GOKAK_110, MURAGOD_33, KOLAVI SUGAR_33	13:55	14:52	0:57	MAIN SUPPLY FAILURE
396	3-May-19	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	8:19	13:59	5:40	LINE FAULT
397	3-May-19	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	8:19	8:30	0:11	MAIN SUPPLY FAILURE
398	3-May-19	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	14:07	14:09	0:01	MAIN SUPPLY FAILURE
399	3-May-19	BENGALURU	66	HOODY 220 - HOSKOTE	HOSKOTE 66	10:14	10:56	0:41	LINE FAULT
400	3-May-19	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	12:29	12:34	0:04	LOAD CHANGEOVER
401	3-May-19	BENGALURU	66	SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	16:58	17:15	0:17	LINE FAULT
402	3-May-19	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	15:30	15:36	0:05	LOAD CHANGEOVER
403	3-May-19	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	18:25	18:33	0:07	LOAD CHANGEOVER
404	3-May-19	BENGALURU	66	HV1	AREHALLI	12:07	12:15	0:07	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
405	3-May-19	BENGALURU	66	HV1	BRIGADE METROPOLIS	11:08	11:10	0:01	LINE CLEAR AVAILED
406	3-May-19	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	8:19	13:59	5:40	LINE FAULT
407	3-May-19	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	8:19	8:30	0:11	MAIN SUPPLY FAILURE
408	3-May-19	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	14:07	14:09	0:01	MAIN SUPPLY FAILURE
409	3-May-19	BENGALURU	66	HOODY 220 - HOSKOTE	HOSKOTE 66	10:14	10:56	0:41	LINE FAULT
410	3-May-19	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	12:29	12:34	0:04	LOAD CHANGEOVER
411	3-May-19	BENGALURU	66	SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	16:58	17:15	0:17	LINE FAULT
412	3-May-19	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	15:30	15:36	0:05	LOAD CHANGEOVER
413	3-May-19	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	18:25	18:33	0:07	LOAD CHANGEOVER
414	3-May-19	BENGALURU	66	HV1	AREHALLI	12:07	12:15	0:07	LINE CLEAR AVAILED
415	3-May-19	BENGALURU	66	HV1	BRIGADE METROPOLIS	11:08	11:10	0:01	LINE CLEAR AVAILED
416	3-May-19	GULBARGA	400	JSWVL-GUTTUR	JSWVL_400	5:21	6:26	1:05	LINE FAULT
417	3-May-19	GULBARGA	220	HV1, HV2, BUS COUPLER	HALBURGA_220	11:17	11:25	0:08	TRANSFORMER FAULT
418	3-May-19	GULBARGA	220	HALBURGA-HUMNABAD1	HALBURGA_220	11:46	12:16	0:30	LINE FAULT
419	3-May-19	GULBARGA	220	HALBURGA-HUMNABAD2	HALBURGA_220	11:46	21:05	9:19	LINE FAULT
420	3-May-19	GULBARGA	220	HUMNABAD220-SEDAM1	HUMNABAD_220	16:00	16:30	0:30	LINE CLEAR AVAILED
421	3-May-19	GULBARGA	220	HUMNABAD220-HALBURGA2	HALBURGA_220	16:02	21:01	4:59	NFBC ISSUED
422	3-May-19	GULBARGA	220	SEDAM-RTPS1,2	SEDAM_220	16:38	16:43	0:05	LINE CLEAR AVAILED
423	3-May-19	GULBARGA	110	HV1	MASKI_110	10:43	12:33	1:50	LINE CLEAR AVAILED
424	3-May-19	GULBARGA	110	HV1	YELBURGA_110	13:15	14:10	0:55	LINE CLEAR AVAILED
425	3-May-19	GULBARGA	110	MALLT-BYGWT-2	MADALAPURA_110,MANVI_110	4:27	4:55	0:28	LINE FAULT
426	3-May-19	GULBARGA	110	MALLT-BYGWT-2	MADALAPURA_110,MANVI_110	5:00	5:10	0:10	LINE FAULT
427	3-May-19	GULBARGA	110	GURGUNTA-KHEL_IPP	KHEL_IPP	15:00	15:15	0:15	LINE CLEAR AVAILED
428	3-May-19	GULBARGA	110	HV2	KOLHAR_110	19:24	19:35	0:11	LOAD CURTAILMENT
429	3-May-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	19:03	19:11	0:08	LINE FAULT
430	3-May-19	GULBARGA	110	HV1	CHINCHOLI_110	19:24	19:36	0:12	LOAD CURTAILMENT
431	3-May-19	GULBARGA	66	ITTAGGI-HIREHADAGALI1	HIREHADAGALI_66	9:04	12:39	3:35	LINE CLEAR AVAILED
432	3-May-19	GULBARGA	66	ITTAGGI-HIREHADAGALI2	HIREHADAGALI_66, GIRIYAPURA_110,MAGALA_66,SOV ENAHALLI_66,TUNGABHADRA_IPP	9:04	18:00	8:56	LINE CLEAR AVAILED
433	3-May-19	GULBARGA	66	ITTAGGI-HUVINAHADAGALLI	HUVINA_HADAGALLI_66	18:49	19:00	0:11	LINE FAULT
434	3-May-19	GULBARGA	66	HV1	CJHALLI_66	19:24	19:32	0:08	LOAD CURTAILMENT
435	3-May-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	9:30	9:50	0:20	LINE CLEAR AVAILED
436	3-May-19	HASSAN	400	HASSAN40-UPCL2	SHANTHIGRAMA_400	0:00	7:59	7:59	LINE CLEAR AVAILED
437	3-May-19	HASSAN	400	HASSAN40-UPCL2	SHANTHIGRAMA_400	23:36	23:59	0:23	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
438	3-May-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	7:59	7:59	LINE CLEAR AVAILED
439	3-May-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:36	23:59	0:23	HAND TRIPPED
440	3-May-19	HASSAN	220	HV1	HOLENARASIPURA_220	11:14	13:45	2:31	LINE CLEAR AVAILED
441	3-May-19	HASSAN	110	HV2	GERUMARA_110	19:24	19:44	0:20	LOAD CURTAILMENT
442	3-May-19	HASSAN	110	HV1	SALATHUR_110	10:57	11:07	0:10	HAND TRIPPED
443	3-May-19	HASSAN	66	Lv1	HOLENARASIPURA_220	11:13	13:48	2:35	LINE CLEAR AVAILED
444	3-May-19	HASSAN	66	HV2	BASAVAGHATTA_66	19:24	19:34	0:10	LOAD CURTAILMENT
445	3-May-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	13:05	13:11	0:06	LOAD CURTAILMENT
446	3-May-19	HASSAN	66	HV1	HANGRANAHALLY_66	19:24	19:35	0:11	LOAD CURTAILMENT
447	3-May-19	HASSAN	66	HASSN220-HSN66	HASSAN_220	12:51	16:36	3:45	LINE CLEAR AVAILED
448	3-May-19	HASSAN	66	HV1	HASSAN_66	10:28	16:34	6:06	LINE CLEAR AVAILED
449	3-May-19	HASSAN	66	HV2	HASSAN_66	10:30	16:34	6:04	LINE CLEAR AVAILED
450	3-May-19	HASSAN	66	HV2	HOLALUR_66	10:06	10:39	0:33	LINE CLEAR AVAILED
451	3-May-19	HASSAN	66	HV2	RAMPURA_66	11:31	11:52	0:21	LINE CLEAR AVAILED
452	3-May-19	HASSAN	66	HV2	RAMESHWARNAGARA_66	19:25	19:34	0:09	LOAD CURTAILMENT
453	3-May-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	7:31	19:57	12:26	LINE CLEAR AVAILED
454	3-May-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	7:31	19:57	12:26	LINE CLEAR AVAILED
455	3-May-19	HASSAN	66	HV2	SALGAME_66	19:26	19:33	0:07	LOAD CURTAILMENT
456	3-May-19	HASSAN	66	HV1	SATHENAHALLY_66	19:26	19:31	0:05	LOAD CURTAILMENT
457	3-May-19	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	7:55	18:10	10:15	MAIN SUPPLY FAILURE
458	3-May-19	HASSAN	66	HV1	SINGAPURA_66	7:55	18:10	10:15	MAIN SUPPLY FAILURE
459	3-May-19	HASSAN	66	HV2	SINGAPURA_66	7:55	18:10	10:15	MAIN SUPPLY FAILURE
460	3-May-19	MYSORE	66	HV2	ADDIHALLI_66	19:24	19:27	0:02	LOAD CURTAILMENT
461	3-May-19	MYSORE	66	HV1	BGNAGARA_66	19:24	23:59	4:34	LOAD CURTAILMENT
462	3-May-19	MYSORE	66	HV2	BOOKANAKERE_66	19:24	19:35	0:10	LOAD CURTAILMENT
463	3-May-19	MYSORE	66	HV2	CHINAKURALI_66	19:24	19:51	0:27	LOAD CURTAILMENT
464	3-May-19	MYSORE	66	HV2	DODDARAYAPET_66	19:24	19:35	0:10	LOAD CURTAILMENT
465	3-May-19	MYSORE	66	HV2	ELAVALA_66	19:24	19:35	0:10	LOAD CURTAILMENT
466	3-May-19	MYSORE	66	HV1	HANAGODU_66	19:25	20:01	0:36	LOAD CURTAILMENT
467	3-May-19	MYSORE	66	HV1	HUNSUR_66	13:02	14:56	1:54	LINE CLEAR AVAILED
468	3-May-19	MYSORE	66	HV1	HUNSUR_66	15:00	16:18	1:18	LINE CLEAR AVAILED
469	3-May-19	MYSORE	66	HV2	HUNSUR_66	19:24	19:55	0:30	LOAD CURTAILMENT
470	3-May-19	MYSORE	220	HV3	HOOTAGALLY_220	10:32	13:40	3:07	LINE CLEAR AVAILED
471	3-May-19	MYSORE	66	HV2	JAIPUR_66	19:24	19:41	0:16	LOAD CURTAILMENT
472	3-May-19	MYSORE	66	KIRUGAVLU-SFC	KIRUGAVALU_66	9:00	18:40	9:40	NFBC ISSUED
473	3-May-19	MYSORE	66	HV2	KIRUGAVALU_66	19:25	19:45	0:19	LOAD CURTAILMENT
474	3-May-19	MYSORE	66	HV1	KUSHALNAGARA_220	19:24	19:40	0:15	LOAD CURTAILMENT
475	3-May-19	MYSORE	66	HV2	KMDODDI_66	9:24	9:34	0:09	TRANSFORMER FAULT
476	3-May-19	MYSORE	66	HV2	KMDODDI_66	19:25	19:41	0:15	LOAD CURTAILMENT
477	3-May-19	MYSORE	66	M2	MANDYA_66	6:50	12:20	5:30	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
478	3-May-19	MYSORE	66	HV1	PANDAVAPURA_66	19:25	19:35	0:10	LOAD CURTAILMENT
479	3-May-19	MYSORE	66	HV1	SANTHEBACHALLI_66	10:05	17:15	7:10	LINE CLEAR AVAILED
480	3-May-19	MYSORE	66	HV2	SANTHEBACHALLI_66	10:15	17:15	6:59	LINE CLEAR AVAILED
481	3-May-19	MYSORE	66	HV1	SFCSHIVA_66	15:09	18:25	3:15	LINE CLEAR AVAILED
482	3-May-19	MYSORE	66	HV2	SFCSHIVA_66	15:09	18:25	3:15	LINE CLEAR AVAILED
483	3-May-19	MYSORE	66	HV3	SFCSHIVA_66	15:17	18:25	3:07	LINE CLEAR AVAILED
484	3-May-19	MYSORE	66	HV4	SFCSHIVA_66	15:09	18:25	3:15	LINE CLEAR AVAILED
485	3-May-19	MYSORE	66	SFC SIVA-MEGHALAPURA	CHIDRAVALLI_66 THUMLA_66	8:20	11:05	2:45	LINE CLEAR AVAILED
486	3-May-19	TUMKUR	220	ANTHRASANAHALLI 220kV- NELAMANGALA	ANTHRASANAHALLI_220	11:40	15:19	3:38	LINE CLEAR AVAILED
487	3-May-19	TUMKUR	220	TR-1	ANTHRASANAHALLI_220	12:32	13:53	1:20	LINE CLEAR AVAILED
488	3-May-19	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	12:39	13:44	1:04	LINE CLEAR AVAILED
489	3-May-19	TUMKUR	110	TR-1 & TR-3	GUBBI_110	16:33	17:30	0:56	LINE CLEAR AVAILED
490	3-May-19	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	12:32	13:53	1:21	LINE CLEAR AVAILED
491	3-May-19	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	16:16	17:00	0:43	LINE CLEAR AVAILED
492	3-May-19	TUMKUR	66	DODDASARANGI-ANCHEPALYA220	DODDASARANGI_66	13:00	14:19	1:19	LINE CLEAR AVAILED
493	3-May-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:32	14:23	1:50	LINE CLEAR AVAILED
494	3-May-19	TUMKUR	66	HEGGERE- MALLASANDRA	MALLASANDRA_66	12:23	13:41	1:17	LOAD CURTAILMENT
495	3-May-19	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-2	INFOSYS1_EHT_66	10:58	13:51	2:52	LINE CLEAR AVAILED
496	3-May-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:27	10:38	0:10	LINE FAULT
497	3-May-19	TUMKUR	66	TR-2	PULAMG_66	16:08	16:39	0:31	TRANSFORMER FAULT
498	3-May-19	TUMKUR	66	TR-2	PUNABHAGHATTA_66	13:41	14:22	0:41	LINE CLEAR AVAILED
499	4-May-19	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	16:49	16:54	0:05	LOAD CURTAILMENT
500	4-May-19	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	18:45	18:58	0:13	LOAD CURTAILMENT
501	4-May-19	BAGALKOT	110	110/11KV,HV1	ANANDNAGAR_110	8:20	13:20	5:00	LINE CLEAR AVAILED
502	4-May-19	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	16:49	16:57	0:08	LOAD CURTAILMENT
503	4-May-19	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	18:53	19:01	0:08	LOAD CURTAILMENT
504	4-May-19	BAGALKOT	110	ENERCON-BIJAPUR	BIJAPUR_220	10:28	18:30	8:02	LINE CLEAR AVAILED
505	4-May-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	16:49	17:15	0:26	LOAD CURTAILMENT
506	4-May-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	18:55	19:10	0:15	LOAD CURTAILMENT
507	4-May-19	BAGALKOT	110	110/33KV,HV1	HANGAL_110	16:49	17:00	0:11	LOAD CURTAILMENT
508	4-May-19	BAGALKOT	110	110/33KV,HV1	HANGAL_110	18:50	18:58	0:08	LOAD CURTAILMENT
509	4-May-19	BAGALKOT	66	110/33KV,HV4	HARIHAR HOSPET_66	14:42	15:19	0:37	LOAD CURTAILMENT
510	4-May-19	BAGALKOT	66	110/33KV,HV4	HARIHAR HOSPET_66	18:18	21:21	3:03	LOAD CURTAILMENT
511	4-May-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	0:00	9:43	9:43	LINE CLEAR AVAILED
512	4-May-19	BAGALKOT	110	HUBLI-KALGHATAGI	KALGHATAGI_110	19:16	19:51	0:35	LOAD CURTAILMENT
513	4-May-19	BAGALKOT	110	HUBLI-RAMANKOPPA	RAMANKOPPA_110	19:16	20:15	0:59	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
514	4-May-19	BAGALKOT	110	110/11KV,HV1	SIRSI_220	10:08	12:03	1:55	LINE CLEAR AVAILED
515	4-May-19	BAGALKOT	220	220/110KV,HV1	SIRSI_220	0:00	18:35	18:35	LINE CLEAR AVAILED
516	4-May-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	18:30	20:23	1:53	LOAD CURTAILMENT
517	4-May-19	BAGALKOT	110	110/11KV,HV1	LAXMESHWAR_110	18:10	19:08	0:58	LOAD CURTAILMENT
518	4-May-19	BAGALKOT	110	110/33KV,HV3	KULIGOD_110,AREMALATTI_33KV,TIGADI_33KV	18:22	18:35	0:13	TRANSFORMER FAULT
519	4-May-19	BENGALURU	66	HV1	ATTIBELE	16:39	16:43	0:04	TRANSFORMER FAULT
520	4-May-19	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1	PATHPALYA, THIMAMPALLI, SOMANATHAPURA	10:29	10:34	0:05	LINE FAULT
521	4-May-19	BENGALURU	66	HV2	CHAKKAVELU	16:13	16:23	0:09	TRANSFORMER FAULT
522	4-May-19	BENGALURU	66	HV2	DEVAGUNDI	14:50	15:01	0:11	TRANSFORMER FAULT
523	4-May-19	BENGALURU	66	CHIKKABALLAPURA IND AREA-CHIKKABALLAPURA URBUN	CHIKKABALLAPURA URBUN	16:00	17:45	1:45	LINE CLEAR AVAILED
524	4-May-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	16:53	17:15	0:22	LOAD CURTAILMENT
525	4-May-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	19:58	20:44	0:45	LOAD CURTAILMENT
526	4-May-19	BENGALURU	66	HV1	KIADB DB PURA 220	10:47	11:32	0:45	LINE CLEAR AVAILED
527	4-May-19	BENGALURU	66	HV2	KIADB DB PURA 220	10:47	11:32	0:45	LINE CLEAR AVAILED
528	4-May-19	BENGALURU	66	KIADB DB PURA 220-HIMAT SINGH FACTORY	HIMAT SINGH FACTORY	11:32	12:50	1:18	LINE CLEAR AVAILED
529	4-May-19	BENGALURU	66	HV1	DEVANAHALLI	6:40	6:45	0:05	TRANSFORMER FAULT
530	4-May-19	BENGALURU	66	DB PURA-DG2	DODDABELAVANGALA, APPAREL PARK	11:02	11:06	0:04	LOAD CHANGEOVER
531	4-May-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1 & 2	KUNDANA, DEVANAHALLI	16:55	17:11	0:15	LOAD CURTAILMENT
532	4-May-19	BENGALURU	66	GOWRIBIDANUR - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHPURA	17:34	17:56	0:22	LOAD CURTAILMENT
533	4-May-19	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	16:56	17:33	0:37	LOAD CURTAILMENT
534	4-May-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	10:42	14:11	3:29	LINE CLEAR AVAILED
535	4-May-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	14:34	14:36	0:01	LINE CLEAR AVAILED
536	4-May-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	13:11	14:10	0:59	LINE CLEAR AVAILED
537	4-May-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	16:54	17:32	0:38	LOAD CURTAILMENT
538	4-May-19	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	18:31	18:38	0:06	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
539	4-May-19	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	22:24	22:36	0:11	LOAD CURTAILMENT
540	4-May-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	9:43	9:48	0:04	LOAD CHANGEOVER
541	4-May-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	20:00	20:06	0:06	LOAD CURTAILMENT
542	4-May-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	10:53	11:39	0:45	LINE CLEAR AVAIED
543	4-May-19	BENGALURU	66	HV2	SULLIBELE	13:00	14:30	1:30	LINE CLEAR AVAIED
544	4-May-19	BENGALURU	66	HV1	THYAMAGONDLU	9:30	9:50	0:20	LINE CLEAR AVAIED
545	4-May-19	BENGALURU	66	HV1	AMARJYOTHI	12:19	12:22	0:03	LOAD CHANGEOVER
546	4-May-19	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	8:30	8:34	0:04	LOAD CHANGEOVER
547	4-May-19	BENGALURU	66	GOKULA - SRS PEENYA 220	GOKULA, BEL (EHT), HMT (EHT)	5:59	6:07	0:07	LOAD CHANGEOVER
548	4-May-19	BENGALURU	66	GOKULA - HMT (EHT)	HMT (EHT)	12:28	14:03	1:35	LINE CLEAR AVAIED
549	4-May-19	BENGALURU	66	GOKULA - BEL (EHT)	BEL (EHT)	12:27	13:59	1:32	LINE CLEAR AVAIED
550	4-May-19	BENGALURU	66	HOODY 220 - HAL 1 & 2	BAGMANE WORLD TECH PARK, NGEF, NGEF (EHT)	12:05	14:21	2:16	LINE CLEAR AVAIED
551	4-May-19	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	8:16	8:40	0:23	LINE CLEAR AVAIED
552	4-May-19	BENGALURU	66	HOSKOTE 66 - MALUR 220	HOSKOTE 66	20:35	21:00	0:25	LOAD CHANGEOVER
553	4-May-19	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT)	12:14	12:24	0:10	LOAD CHANGEOVER
554	4-May-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI, BOSCH (EHT)	13:06	13:47	0:40	LINE CLEAR AVAIED
555	4-May-19	BENGALURU	66	HSR LAYOUT 220 - KORMANGALA	KORMANGALA, K & C VALLEY, NAL (EHT)	12:06	12:10	0:04	LOAD CHANGEOVER
556	4-May-19	BENGALURU	66	HSR LAYOUT 220 - KORMANGALA	KORMANGALA, K & C VALLEY, NAL (EHT)	13:29	13:31	0:01	LOAD CHANGEOVER
557	4-May-19	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	5:35	5:40	0:05	LOAD CHANGEOVER
558	4-May-19	BENGALURU	66	APPAREL PARK - DB PURA 220	APPAREL PARK	18:30	18:35	0:05	LOAD CHANGEOVER
559	4-May-19	BENGALURU	66	HV2	MEI LAYOUT	13:15	15:35	2:20	LINE CLEAR AVAIED
560	4-May-19	BENGALURU	66	HV1	NRS 220	0:56	2:28	1:31	LINE CLEAR AVAIED
561	4-May-19	BENGALURU	66	HV2	NRS 220	0:56	2:28	1:31	LINE CLEAR AVAIED
562	4-May-19	BENGALURU	66	HV3	NRS 220	0:56	2:28	1:31	LINE CLEAR AVAIED
563	4-May-19	BENGALURU	66	HV4	NRS 220	0:56	2:28	1:31	LINE CLEAR AVAIED
564	4-May-19	BENGALURU	66	HV5	NRS 220	0:56	2:28	1:31	LINE CLEAR AVAIED
565	4-May-19	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1 & 2	TELECOM LAYOUT	0:57	2:28	1:30	LINE CLEAR AVAIED
566	4-May-19	BENGALURU	66	NRS 220 - VIJAY NGR MY2	VIJAYANAGARA	0:57	2:28	1:30	LINE CLEAR AVAIED
567	4-May-19	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	0:57	2:28	1:30	LINE CLEAR AVAIED
568	4-May-19	BENGALURU	66	HV1	TELECOM LAYOUT	13:57	14:06	0:09	TRANSFORMER FAULT
569	4-May-19	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	5:23	5:28	0:05	LOAD CHANGEOVER
570	4-May-19	BENGALURU	66	HV2	YARANADANAHALLI 220	9:09	9:14	0:05	LOAD CHANGEOVER
571	4-May-19	BENGALURU	66	IISC - HEBBAL 220	IISC	2:50	2:58	0:08	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
572	4-May-19	GULBARGA	400	JVSL-BPS3	BPS_400	11:15	12:08	0:53	LINE FAULT
573	4-May-19	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110, KURUGOD_110, SHATAVANA_IPP, AGARWAL_IPP, SUZLON_IPP, KAMALAPUT_110	5:21	5:36	0:15	LINE FAULT
574	4-May-19	GULBARGA	110	HV1,HV2	YELBURGA_110	13:40	14:00	0:20	LOAD CURTAILMENT
575	4-May-19	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	19:58	21:51	1:53	LOAD CURTAILMENT
576	4-May-19	GULBARGA	110	TEKALKOTE-RNWSLR	RNWSLR_IPP	18:55	22:25	3:30	LINE CLEAR AVAILED
577	4-May-19	GULBARGA	110	HV3	YELBURGA_110	14:40	15:00	0:20	LOAD CURTAILMENT
578	4-May-19	GULBARGA	110	HV3	YELBURGA_110	18:18	18:33	0:15	LOAD CURTAILMENT
579	4-May-19	GULBARGA	110	HV4	YELBURGA_110	18:17	20:19	2:02	LOAD CURTAILMENT
580	4-May-19	GULBARGA	66	HV1	CJHALLI_66	16:45	16:55	0:10	TRANSFORMER FAULT
581	4-May-19	GULBARGA	66	HV1	CJHALLI_66	19:10	20:35	1:25	TRANSFORMER FAULT
582	4-May-19	HASSAN	400	HASSAN4-UPCL2	HASSAN_400	0:00	2:48	2:48	LINE CLEAR AVAILED
583	4-May-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:14	13:34	2:20	LINE CLEAR AVAILED
584	4-May-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	2:48	2:48	LINE CLEAR AVAILED
585	4-May-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:33	23:59	5:26	LINE CLEAR AVAILED
586	4-May-19	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	12:09	15:56	3:47	LINE CLEAR AVAILED
587	4-May-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	5:35	10:03	4:28	LINE FAULT
588	4-May-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	10:42	12:05	1:23	LINE CLEAR AVAILED
589	4-May-19	HASSAN	110	MRSSHM-SS2	MRSMSG_220	10:23	21:26	11:03	LINE CLEAR AVAILED
590	4-May-19	HASSAN	220	SHRAVTHY-SHIMOGA3	sharavathy_gen	12:09	15:56	3:47	NFBC ISSUED
591	4-May-19	HASSAN	220	AHRAVTY-SHIMOGA4	sharavathy_gen	5:35	10:03	4:28	LINE FAULT
592	4-May-19	HASSAN	220	AHRAVTY-SHIMOGA4	sharavathy_gen	10:42	12:05	1:23	NFBC ISSUED
593	4-May-19	HASSAN	110	HV1	HALADY_110	16:49	17:05	0:16	LOAD CURTAILMENT
594	4-May-19	HASSAN	110	HV1	HALADY_110	18:20	18:30	0:10	LOAD CURTAILMENT
595	4-May-19	HASSAN	110	ANANDA-SHIMOGA	ANANDAPURA_110	10:25	21:28	11:03	LINE CLEAR AVAILED
596	4-May-19	HASSAN	110	HV1	BAIKAMPADI_110	12:55	14:23	1:28	LINE CLEAR AVAILED
597	4-May-19	HASSAN	110	HV2	BAIKAMPADI_110	12:55	14:23	1:28	LINE CLEAR AVAILED
598	4-May-19	HASSAN	110	HV2	BAIKAMPADI_110	12:55	14:23	1:28	LINE CLEAR AVAILED
599	4-May-19	HASSAN	110	HV5	BAIKAMPADI_110	12:55	14:23	1:28	LINE CLEAR AVAILED
600	4-May-19	HASSAN	110	HV1	BIRUR_110	16:49	17:06	0:17	LOAD CURTAILMENT
601	4-May-19	HASSAN	110	HV1	BIRUR_110	18:20	18:35	0:15	LOAD CURTAILMENT
602	4-May-19	HASSAN	110	HV2	GERUMARA_110	16:48	17:04	0:16	LOAD CURTAILMENT
603	4-May-19	HASSAN	110	HV2	GERUMARA_110	18:18	19:58	1:40	LOAD CURTAILMENT
604	4-May-19	HASSAN	110	MRS-ANDPR	KUMSI_110	10:30	21:35	11:05	LINE CLEAR AVAILED
605	4-May-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	19:43	20:30	0:47	LOAD CURTAILMENT
606	4-May-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	21:19	22:04	0:45	LOAD CURTAILMENT
607	4-May-19	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	21:22	22:07	0:45	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
608	4-May-19	HASSAN	66	HV2	ARKD_66	11:10	11:25	0:15	TRANSFORMER FAULT
609	4-May-19	HASSAN	66	BJADRA-LINGADAHALLI	bhadra_gen	8:30	8:37	0:07	LINE FAULT
610	4-May-19	HASSAN	66	HV1	HANGARANAHALLY_66	16:48	16:59	0:11	LOAD CURTAILMENT
611	4-May-19	HASSAN	66	HV1	HANGARANAHALLY_66	18:17	18:29	0:12	LOAD CURTAILMENT
612	4-May-19	HASSAN	66	HV1	HANGARANAHALLY_66	19:04	20:00	0:56	LOAD CURTAILMENT
613	4-May-19	HASSAN	66	HV2	RAMESHWARNAGAR_66	16:49	16:56	0:07	LOAD CURTAILMENT
614	4-May-19	HASSAN	66	HV2	RAMESHWARNAGAR_66	18:19	18:27	0:08	LOAD CURTAILMENT
615	4-May-19	HASSAN	66	HV2	RAMESHWARNAGAR_66	19:46	19:57	0:11	LOAD CURTAILMENT
616	4-May-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	7:42	18:35	10:53	LINE CLEAR AVAILED
617	4-May-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	7:42	18:35	10:53	LINE CLEAR AVAILED
618	4-May-19	HASSAN	66	HV2	SALAGAME_66	16:49	16:54	0:05	LOAD CURTAILMENT
619	4-May-19	HASSAN	66	HV2	SALAGAME_66	18:18	18:21	0:03	LOAD CURTAILMENT
620	4-May-19	HASSAN	66	HV2	SALAGAME_66	19:05	19:25	0:20	LOAD CURTAILMENT
621	4-May-19	HASSAN	66	HV2	SALAGAME_66	19:46	19:55	0:09	LOAD CURTAILMENT
622	4-May-19	HASSAN	66	HV2	SALAGAME_66	19:20	19:25	0:05	LOAD CURTAILMENT
623	4-May-19	HASSAN	66	HV2	SATHENAHALLY_66	18:18	18:21	0:03	LOAD CURTAILMENT
624	4-May-19	HASSAN	66	HV2	SATHENAHALLY_66	18:52	19:45	0:53	LOAD CURTAILMENT
625	4-May-19	HASSAN	66	HV2	SATHENAHALLY_66	19:50	20:00	0:10	LOAD CURTAILMENT
626	4-May-19	HASSAN	66	HV2	SINGAPURA_66	18:18	18:32	0:14	LOAD CURTAILMENT
627	4-May-19	HASSAN	66	HV2	SINGAPURA_66	19:12	19:32	0:20	LOAD CURTAILMENT
628	4-May-19	HASSAN	66	HV2	SINGAPURA_66	19:45	20:15	0:30	LOAD CURTAILMENT
629	4-May-19	HASSAN	66	HV2	BASAVAGHATTA_66	14:41	14:55	0:14	LOAD CURTAILMENT
630	4-May-19	HASSAN	66	HV2	BASAVAGHATTA_66	18:18	18:28	0:10	LOAD CURTAILMENT
631	4-May-19	HASSAN	66	HV2	BASAVAGHATTA_66	19:05	19:35	0:30	LOAD CURTAILMENT
632	4-May-19	HASSAN	66	HV2	BASAVAGHATTA_66	19:40	20:10	0:30	LOAD CURTAILMENT
633	4-May-19	MYSORE	66	HV2	ADDIHALLI_66	13:15	13:39	0:24	LINE CLEAR AVAILED
634	4-May-19	MYSORE	66	HV2	ADDIHALLI_66	14:41	23:59	9:17	LOAD CURTAILMENT
635	4-May-19	MYSORE	66	HV2	ADDIHALLI_66	18:17	18:21	0:04	LOAD CURTAILMENT
636	4-May-19	MYSORE	66	HV2	ADDIHALLI_66	19:05	19:30	0:24	LOAD CURTAILMENT
637	4-May-19	MYSORE	66	HV2	ADDIHALLI_66	19:40	19:58	0:18	LOAD CURTAILMENT
638	4-May-19	MYSORE	66	HV1	BESAGARAHALLI_66	14:40	14:50	0:09	LOAD CURTAILMENT
639	4-May-19	MYSORE	66	HV1	BGNAGARA_66	14:41	14:45	0:03	LOAD CURTAILMENT
640	4-May-19	MYSORE	66	HV1	BGNAGARA_66	18:17	18:24	0:06	LOAD CURTAILMENT
641	4-May-19	MYSORE	66	HV1	BILIKERE_66	14:41	15:00	0:18	LOAD CURTAILMENT
642	4-May-19	MYSORE	66	HV2	BOOKANAKERE_66	14:40	14:45	0:04	LOAD CURTAILMENT
643	4-May-19	MYSORE	66	HV2	BOOKANAKERE_66	18:16	18:31	0:14	LOAD CURTAILMENT
644	4-May-19	MYSORE	66	HV2	BOOKANAKERE_66	18:40	18:50	0:10	LOAD CURTAILMENT
645	4-May-19	MYSORE	66	HV2	BOOKANAKERE_66	19:35	19:45	0:10	LOAD CURTAILMENT
646	4-May-19	MYSORE	66	HV2	CHINAKURALI_66	18:17	18:40	0:22	LOAD CURTAILMENT
647	4-May-19	MYSORE	66	HV1	DUNDANAHALLI_66	14:30	14:35	0:05	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
648	4-May-19	MYSORE	66	HV2	DODDARAYAPET_66	14:41	14:50	0:08	LOAD CURTAILMENT
649	4-May-19	MYSORE	66	HV2	DODDARAYAPET_66	18:17	18:30	0:12	LOAD CURTAILMENT
650	4-May-19	MYSORE	66	HV2	DODDARAYAPET_66	19:04	19:20	0:15	LOAD CURTAILMENT
651	4-May-19	MYSORE	66	DR PETE-KUNTHUR	MUGUR_66 SANTHEMARAHALLI_66 THAYURU_66 TNARASIPURA_66	2:03	2:09	0:05	LINE FAULT
652	4-May-19	MYSORE	66	HV2	ELAVALA_66	14:41	14:50	0:08	LOAD CURTAILMENT
653	4-May-19	MYSORE	66	HV2	ELAVALA_66	18:17	18:33	0:16	LOAD CURTAILMENT
654	4-May-19	MYSORE	66	HV2	ELAVALA_66	18:43	18:52	0:09	LOAD CURTAILMENT
655	4-May-19	MYSORE	66	HV2	ELAVALA_66	19:33	20:36	1:03	LOAD CURTAILMENT
656	4-May-19	MYSORE	66	HV1	HANAGODU_66	14:41	15:00	0:18	LOAD CURTAILMENT
657	4-May-19	MYSORE	66	HV1	HANAGODU_66	18:17	18:45	0:27	LOAD CURTAILMENT
658	4-May-19	MYSORE	66	HV1	HANAGODU_66	19:35	20:05	0:30	LOAD CURTAILMENT
659	4-May-19	MYSORE	66	HV2	HANNUR_66	16:48	17:20	0:31	LOAD CURTAILMENT
660	4-May-19	MYSORE	66	HV2	HANNUR_66	18:17	18:40	0:22	LOAD CURTAILMENT
661	4-May-19	MYSORE	66	HV2	HDKOTE_66	16:48	17:20	0:31	LOAD CURTAILMENT
662	4-May-19	MYSORE	66	HV2	HDKOTE_66	18:17	18:45	0:27	LOAD CURTAILMENT
663	4-May-19	MYSORE	66	HV1	GARUDANAUKADDA_66	14:20	15:40	1:20	LINE CLEAR AVAILED
664	4-May-19	MYSORE	66	HV1	HUNSUR_66	11:49	11:55	0:05	LINE CLEAR AVAILED
665	4-May-19	MYSORE	66	HV2	HUNSUR_66	11:38	11:49	0:10	LINE CLEAR AVAILED
666	4-May-19	MYSORE	66	HV2	JAIPUR_66	16:48	17:05	0:17	LOAD CURTAILMENT
667	4-May-19	MYSORE	66	HV2	JAIPUR_66	18:17	18:30	0:12	LOAD CURTAILMENT
668	4-May-19	MYSORE	66	HV2	JAIPUR_66	19:04	19:15	0:10	LOAD CURTAILMENT
669	4-May-19	MYSORE	66	HV2	JAIPUR_66	19:30	19:49	0:19	LOAD CURTAILMENT
670	4-May-19	MYSORE	66	KADAKOLA-SARAGUR 1	ANTHARSANTHE_66 HAMPAPURA(K)_66 HDKOTE_66 JAIPUR_66	4:57	5:11	0:13	LINE FAULT
671	4-May-19	MYSORE	66	HV2	KIRUGAVALU_66	16:48	0:00	7:11	LOAD CURTAILMENT
672	4-May-19	MYSORE	66	HV2	KIRUGAVALU_66	18:18	18:47	0:28	LOAD CURTAILMENT
673	4-May-19	MYSORE	66	HV2	KIRUGAVALU_66	19:34	19:53	0:19	LOAD CURTAILMENT
674	4-May-19	MYSORE	66	HV2	KMDODDI_66	16:48	17:04	0:15	LOAD CURTAILMENT
675	4-May-19	MYSORE	66	HV2	KMDODDI_66	18:17	18:27	0:09	LOAD CURTAILMENT
676	4-May-19	MYSORE	66	HV2	KMDODDI_66	19:05	19:15	0:09	LOAD CURTAILMENT
677	4-May-19	MYSORE	66	HV1	KUSHALNAGARA_220	14:41	0:00	9:18	LOAD CURTAILMENT
678	4-May-19	MYSORE	66	HV1	KUSHALNAGARA_220	18:17	0:00	5:42	LOAD CURTAILMENT
679	4-May-19	MYSORE	66	HV1	KUSHALNAGARA_220	19:38	19:52	0:13	LOAD CURTAILMENT
680	4-May-19	MYSORE	66	HV1	NAGAMANGALA_66	16:48	16:55	0:06	LOAD CURTAILMENT
681	4-May-19	MYSORE	66	HV1	PANDAVAPURA_66	16:48	17:05	0:16	LOAD CURTAILMENT
682	4-May-19	MYSORE	66	HV1	PANDAVAPURA_66	18:17	18:43	0:25	LOAD CURTAILMENT
683	4-May-19	MYSORE	66	HV1	PANDAVAPURA_66	19:35	20:22	0:47	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
684	4-May-19	MYSORE	66	HV1	SATHEGALA_66	18:18	18:25	0:06	LOAD CURTAILMENT
685	4-May-19	MYSORE	66	HV1	SATHEGALA_66	19:12	23:59	4:46	LOAD CURTAILMENT
686	4-May-19	MYSORE	66	HV1	SATHEGALA_66	19:45	19:50	0:04	TRANSFORMER FAULT
687	4-May-19	MYSORE	66	HV2	SANTHESARAGUR_66	16:48	16:54	0:05	LOAD CURTAILMENT
688	4-May-19	MYSORE	66	HV2	SANTHESARAGUR_66	18:17	18:35	0:17	LOAD CURTAILMENT
689	4-May-19	MYSORE	66	HV2	SANTHESARAGUR_66	19:12	19:20	0:07	LOAD CURTAILMENT
690	4-May-19	MYSORE	66	HV2	SANTHESARAGUR_66	19:45	19:57	0:11	LOAD CURTAILMENT
691	4-May-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	18:18	18:29	0:11	LOAD CURTAILMENT
692	4-May-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	19:12	19:25	0:12	LOAD CURTAILMENT
693	4-May-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	19:45	20:17	0:32	LOAD CURTAILMENT
694	4-May-19	MYSORE	66	HV1	SRIRANGAPATNA_66	11:27	12:41	1:14	LINE CLEAR AVAILED
695	4-May-19	MYSORE	66	HV2	SRIRANGAPATNA_66	12:42	14:09	1:26	LINE CLEAR AVAILED
696	4-May-19	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	22:29	22:41	0:12	LOAD CURTAILMENT
697	4-May-19	TUMKUR	66	TR-1	CHANNAGIRI_66	15:30	15:31	0:01	TRANSFORMER FAULT
698	4-May-19	TUMKUR	66	TR-1 & TR-2	GARAGA_66	10:02	13:35	3:32	LINE CLEAR AVAILED
699	5-May-19	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	16:07	16:12	0:05	LOAD CURTAILMENT
700	5-May-19	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	19:05	19:10	0:05	LOAD CURTAILMENT
701	5-May-19	BAGALKOT	110	SUPA1-AMBEWADI	AMBEWADI_220	14:32	15:18	0:46	LINE CLEAR AVAILED
702	5-May-19	BAGALKOT	110	SUPA2-AMBEWADI	AMBEWADI_220	14:33	15:16	0:43	LINE CLEAR AVAILED
703	5-May-19	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	16:08	16:21	0:13	LOAD CURTAILMENT
704	5-May-19	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	19:20	19:44	0:24	LOAD CURTAILMENT
705	5-May-19	BAGALKOT	220	220/110KV,HV1&LV1	BELGAUM_220	10:08	14:02	3:54	LINE CLEAR AVAILED
706	5-May-19	BAGALKOT	220	220/110KV,HV2&LV2	BELGAUM_220	15:18	18:22	3:04	LINE CLEAR AVAILED
707	5-May-19	BAGALKOT	220	BELGAUM-NARENDRA 2	BELGAUM_220	18:34	19:21	0:47	LINE CLEAR AVAILED
708	5-May-19	BAGALKOT	110	BELGAUM220-UCHAGOAN	UCHAGOAN_110	11:19	11:20	0:01	HAND TRIPPED
709	5-May-19	BAGALKOT	110	BELGAUM220-UCHAGOAN	UCHAGOAN_110	12:48	13:28	0:40	LINE CLEAR AVAILED
710	5-May-19	BAGALKOT	110	BELGAUM220-ANKALAGI	ANKALAGI_110	11:20	13:20	2:00	LINE CLEAR AVAILED
711	5-May-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	16:07	16:20	0:13	LOAD CURTAILMENT
712	5-May-19	BAGALKOT	110	110/33KV,HV1	HANGAL_110	19:03	19:11	0:08	LOAD CURTAILMENT
713	5-May-19	BAGALKOT	110	110/33KV,HV1	HANGAL_110	19:15	19:37	0:22	LOAD CURTAILMENT
714	5-May-19	BAGALKOT	110	HIDIKAL DAM-ANKALAGI	ANKALAGI_110	0:00	10:09	10:09	LINE CLEAR AVAILED
715	5-May-19	BAGALKOT	110	HIDIKAL DAM-ANKALAGI	ANKALAGI_110	19:40	23:59	4:19	LINE CLEAR AVAILED
716	5-May-19	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,KARADI_33,AMING AD_33,MYTRA_IPP	17:11	17:14	0:03	LINE CLEAR AVAILED
717	5-May-19	BAGALKOT	110	JINDAL-HUNGUND	HUNGUND_110	17:11	17:12	0:01	LINE CLEAR AVAILED
718	5-May-19	BAGALKOT	110	RAIBAG 1-ITANAL	ITANAL_110	19:42	19:51	0:09	LINE FAULT
719	5-May-19	BAGALKOT	110	110/11KV,HV1	JAMBAGI_110	19:57	20:36	0:39	MAIN SUPPLY FAILURE
720	5-May-19	BAGALKOT	110	JAMBAGI-HALKI(MUDHOL)	HALKI_110	19:57	20:38	0:41	MAIN SUPPLY FAILURE
721	5-May-19	BAGALKOT	66	110/33KV,HV4	HARIHAR HOSPET_66	19:04	20:08	1:04	LOAD CURTAILMENT
722	5-May-19	BAGALKOT	220	VAJRAMATTI-KAVATAGI LIS	VAJRAMATTI_220	18:12	18:15	0:03	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
723	5-May-19	BAGALKOT	110	BELGAUM220-VADAGOAN	VADAGOAN_110	9:47	20:43	10:56	LINE CLEAR AVAILED
724	5-May-19	BAGALKOT	110	110/11KV,HV2	SHIROL_110	22:10	22:29	0:19	TRANSFORMER FAULT
725	5-May-19	BAGALKOT	110	HUNAGUND-KUDALSANGAM	KUDALSANGAM_110	10:45	18:30	7:45	LINE CLEAR AVAILED
726	5-May-19	BAGALKOT	110	RAMPUR-KUDALSANGAM	RAMPUR_110	18:12	23:59	5:47	LINE CLEAR AVAILED
727	5-May-19	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	13:55	14:21	0:26	LINE FAULT
728	5-May-19	BENGALURU	66	CHIKKABALLAPURA IND AREA- CHIKKABALLAPURA URBUN	CHIKKABALLAPURA URBUN	12:00	12:55	0:55	LINE CLEAR AVAILED
729	5-May-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	20:01	20:14	0:13	LOAD CURTAILMENT
730	5-May-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	19:18	20:01	0:42	LOAD CURTAILMENT
731	5-May-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	7:02	7:35	0:32	LINE FAULT
732	5-May-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	17:57	18:08	0:11	LINE FAULT
733	5-May-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	18:08	18:44	0:35	LINE FAULT
734	5-May-19	BENGALURU	66	HBR LAYOUT-HOSKOTE 220	HBR LAYOUT, BELL CERAMICS (EHT)	22:16	22:26	0:10	LOAD CHANGEOVER
735	5-May-19	BENGALURU	66	HV1	HULLENAHALLI	11:47	12:16	0:29	TRANSFORMER FAULT
736	5-May-19	BENGALURU	66	HV1	HULLENAHALLI	15:09	17:01	1:52	TRANSFORMER FAULT
737	5-May-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	0:52	1:02	0:09	LINE FAULT
738	5-May-19	BENGALURU	66	HV1	NARASAPURA	12:56	15:56	2:59	LINE CLEAR AVAILED
739	5-May-19	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	19:25	20:15	0:50	LOAD CURTAILMENT
740	5-May-19	BENGALURU	66	GOWRIBIDANUR 220 - MANCHENAHALLI	MANCHENAHALLI,GUNDAMGERE	20:15	20:30	0:15	LOAD CURTAILMENT
741	5-May-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	9:00	13:49	4:49	LINE CLEAR AVAILED
742	5-May-19	BENGALURU	66	VIDHURASHWATHA - GOWRIBIDANUR 220	BAGEPALLI, GUNDLU KOTTUR, VIDHURASHWATHA	23:00	23:10	0:10	LINE FAULT
743	5-May-19	BENGALURU	66	HV1	C STATION	9:51	9:53	0:01	LINE CLEAR AVAILED
744	5-May-19	BENGALURU	66	HV1	C STATION	16:43	16:45	0:02	LINE CLEAR AVAILED
745	5-May-19	BENGALURU	66	HV2	C STATION	16:47	16:53	0:05	LOAD CHANGEOVER
746	5-May-19	BENGALURU	66	GOKULA - MATHIKERE	GOKULA, BEL (EHT), HMT (EHT)	3:56	4:30	0:33	LINE FAULT
747	5-May-19	BENGALURU	66	GOKULA - RMV	GOKULA, BEL (EHT), HMT (EHT)	6:17	7:56	1:38	LINE CLEAR AVAILED
748	5-May-19	BENGALURU	66	GOKULA - MATHIKERE	GOKULA, BEL (EHT), HMT (EHT)	9:35	9:39	0:04	LOAD CHANGEOVER
749	5-May-19	BENGALURU	66	HEBBAL 220 - MATHIKERE	MATHIKERE	3:56	7:40	3:44	LINE FAULT
750	5-May-19	BENGALURU	66	HEBBAL 220 - RMV	RMV, TATA INSTITUTE (EHT)	6:16	7:37	1:21	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
751	5-May-19	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	3:56	7:40	3:43	LINE FAULT
752	5-May-19	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	9:54	10:04	0:09	LOAD CHANGEOVER
753	5-May-19	BENGALURU	220	HV2	NIMHANS 220	8:55	13:51	4:56	TRANSFORMER FAULT
754	5-May-19	BENGALURU	66	HV2	PADMANABHANAGARA	12:28	12:35	0:07	LINE CLEAR AVAILED
755	5-May-19	BENGALURU	66	HV2	PADMANABHANAGARA	13:35	13:38	0:03	LINE CLEAR AVAILED
756	5-May-19	BENGALURU	66	SRS PEENYA 220 - NRS 1	NANDINI LAYOUT	12:38	13:03	0:24	LINE FAULT
757	5-May-19	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	13:42	13:47	0:05	LOAD CHANGEOVER
758	5-May-19	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	9:57	10:01	0:04	LOAD CHANGEOVER
759	5-May-19	BENGALURU	66	HV1	YARANDANAHALLI 220	11:20	12:25	1:05	LINE CLEAR AVAILED
760	5-May-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	RBI, SOUTH CITY	9:29	9:44	0:15	LINE FAULT
761	5-May-19	GULBARGA	220	KUSHTAGI-LINGAPUR	BEVOOR_110	8:00	23:59	15:59	LINE CLEAR AVAILED
762	5-May-19	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	20:07	20:09	0:02	LINE FAULT
763	5-May-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARAGUTTI_110	19:02	19:07	0:05	LINE FAULT
764	5-May-19	GULBARGA	110	HUMNABAD-RAJESHWAR	RAJESHWAR_110	12:10	12:20	0:10	LINE FAULT
765	5-May-19	GULBARGA	110	HV1,HV2	RAJESHWAR_110	16:10	16:30	0:20	LOAD CURTAILMENT
766	5-May-19	GULBARGA	110	HV1,HV2	RAJESHWAR_110	19:10	19:30	0:20	LOAD CURTAILMENT
767	5-May-19	GULBARGA	110	HV1	TEKALKOTE_110	16:05	16:15	0:10	TRANSFORMER FAULT
768	5-May-19	GULBARGA	110	HV1	TEKALKOTE_110	19:00	19:20	0:20	TRANSFORMER FAULT
769	5-May-19	GULBARGA	110	HV4	YELBURGA_110	16:06	16:28	0:22	LOAD CURTAILMENT
770	5-May-19	GULBARGA	110	HV3	YELBURGA_110	16:07	16:36	0:29	LOAD CURTAILMENT
771	5-May-19	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGAR_IPP	9:25	17:50	8:25	LINE CLEAR AVAILED
772	5-May-19	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL_IPP	9:25	23:59	14:34	LINE CLEAR AVAILED
773	5-May-19	GULBARGA	66	HV1	CJHALLI_66	16:00	16:20	0:20	TRANSFORMER FAULT
774	5-May-19	HASSAN	400	HASSAN4-UPCL2	HASSAN_400	18:33	23:59	5:26	LINE CLEAR AVAILED
775	5-May-19	HASSAN	400	HASSAN4-UPCL2	HASSAN_400	0:00	2:32	2:32	LINE CLEAR AVAILED
776	5-May-19	HASSAN	400	HASSAN4-UPCL2	HASSAN_400	18:54	23:59	5:05	LINE CLEAR AVAILED
777	5-May-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	2:32	2:32	LINE CLEAR AVAILED
778	5-May-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:54	23:59	5:05	LINE CLEAR AVAILED
779	5-May-19	HASSAN	110	MRSSHM-SS2	MRSMG_220	14:07	18:47	4:40	LINE CLEAR AVAILED
780	5-May-19	HASSAN	110	ANANDA-SHIMOGA	ANANDAPURA_110	14:08	18:50	4:42	LINE CLEAR AVAILED
781	5-May-19	HASSAN	110	HV2	GERUMARA_110	16:07	16:33	0:26	LOAD CURTAILMENT
782	5-May-19	HASSAN	110	KADUR-NGNHL	KADUR_220	19:30	20:30	1:00	LOAD CURTAILMENT
783	5-May-19	HASSAN	110	KADUR-TNGL	KADUR_220	19:30	20:30	1:00	LOAD CURTAILMENT
784	5-May-19	HASSAN	110	KADUR-YGTI	KADUR_220	19:30	20:30	1:00	LOAD CURTAILMENT
785	5-May-19	HASSAN	110	KADUR-TNGL	KADUR_220	1:27	1:46	0:19	LOAD CURTAILMENT
786	5-May-19	HASSAN	110	HV1	KAVOOR_220	9:36	11:07	1:31	LINE CLEAR AVAILED
787	5-May-19	HASSAN	110	LV1	KAVOOR_220	9:36	11:07	1:31	LINE CLEAR AVAILED
788	5-May-19	HASSAN	110	MRS-ANDPR	KUMSI_110	13:55	19:05	5:10	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
789	5-May-19	HASSAN	110	HV1	KONAJE_110	9:33	9:37	0:04	HAND TRIPPED
790	5-May-19	HASSAN	110	HV1	KONAJE_110	11:13	11:16	0:03	HAND TRIPPED
791	5-May-19	HASSAN	110	HV2	KONAJE_110	9:32	9:37	0:05	HAND TRIPPED
792	5-May-19	HASSAN	110	HV2	KONAJE_110	11:12	11:16	0:04	HAND TRIPPED
793	5-May-19	HASSAN	110	HV3	KONAJE_110	9:33	9:36	0:03	HAND TRIPPED
794	5-May-19	HASSAN	110	HV3	KONAJE_110	11:12	11:15	0:03	HAND TRIPPED
795	5-May-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	1:34	1:46	0:12	LOAD CURTAILMENT
796	5-May-19	HASSAN	66	HV2	ARKD_66	17:30	17:58	0:28	TRANSFORMER FAULT
797	5-May-19	HASSAN	66	BJADRA-LINGADAHALLI	bhadra_gen	6:46	6:51	0:05	LINE FAULT
798	5-May-19	HASSAN	66	HV1	BYACHANAHALLI_66	6:43	6:49	0:06	TRANSFORMER FAULT
799	5-May-19	HASSAN	66	HV1	GORUR_66	16:50	18:35	1:45	LINE CLEAR AVAILED
800	5-May-19	HASSAN	66	HV1	HANGARANAHALLY_66	16:17	19:44	3:27	LOAD CURTAILMENT
801	5-May-19	HASSAN	66	HV2	RAMESHWARNAGAR_66	19:00	20:00	1:00	LOAD CURTAILMENT
802	5-May-19	HASSAN	66	SAKALE-HANBAL	SAKLESHPURA_66	4:08	4:16	0:08	LINE FAULT
803	5-May-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	7:34	19:01	11:27	LINE CLEAR AVAILED
804	5-May-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	7:34	19:01	11:27	LINE CLEAR AVAILED
805	5-May-19	HASSAN	66	HV2	SALAGAME_66	19:35	19:45	0:10	LOAD CURTAILMENT
806	5-May-19	HASSAN	66	HV2	SATHENAHALLY_66	19:15	19:25	0:10	LOAD CURTAILMENT
807	5-May-19	HASSAN	66	HV2	SATHENAHALLY_66	19:30	19:40	0:10	LOAD CURTAILMENT
808	5-May-19	HASSAN	66	HV2	SINGAPURA_66	19:04	19:20	0:16	LOAD CURTAILMENT
809	5-May-19	HASSAN	66	HV2	SINGAPURA_66	19:31	19:40	0:09	LOAD CURTAILMENT
810	5-May-19	HASSAN	66	HV2	BASAVAGHATTA_66	16:07	16:18	0:11	LOAD CURTAILMENT
811	5-May-19	HASSAN	66	HV2	BASAVAGHATTA_66	19:30	19:43	0:13	LOAD CURTAILMENT
812	5-May-19	MYSORE	66	HV2	ADDIHALLI_66	16:06	16:09	0:03	LOAD CURTAILMENT
813	5-May-19	MYSORE	66	HV2	ADDIHALLI_66	19:30	23:59	4:29	LOAD CURTAILMENT
814	5-May-19	MYSORE	66	HV1	BESAGARAHALLI_66	19:02	19:10	0:07	LOAD CURTAILMENT
815	5-May-19	MYSORE	66	HV1	BILIKERE_66	16:06	16:25	0:18	LOAD CURTAILMENT
816	5-May-19	MYSORE	66	HV2	BOOKANAKERE_66	19:02	19:05	0:02	LOAD CURTAILMENT
817	5-May-19	MYSORE	66	HV2	BOOKANAKERE_66	19:30	19:40	0:10	LOAD CURTAILMENT
818	5-May-19	MYSORE	66	CR NAGARA-DR PET 1	DODDARAYAPET_66	11:27	17:27	6:00	LINE CLEAR AVAILED
819	5-May-19	MYSORE	66	CR NAGARA-DR PET 2	DODDARAYAPET_66	14:15	17:26	3:11	LINE CLEAR AVAILED
820	5-May-19	MYSORE	66	DR PETE-KUNTHUR	MUGUR_66 SANTHEMARAHALLI_66 THAYURU_66 TNARASIPURA_66	6:56	7:02	0:06	LINE FAULT
821	5-May-19	MYSORE	66	HV2	ELAVALA_66	19:03	19:07	0:04	LOAD CURTAILMENT
822	5-May-19	MYSORE	66	HV2	ELAVALA_66	19:30	19:37	0:07	LOAD CURTAILMENT
823	5-May-19	MYSORE	66	HV1	HANAGODU_66	19:03	19:47	0:43	LOAD CURTAILMENT
824	5-May-19	MYSORE	66	HV2	HDKOTE_66	16:06	16:20	0:13	LOAD CURTAILMENT
825	5-May-19	MYSORE	66	HV2	JAIPUR_66	16:06	16:20	0:13	LOAD CURTAILMENT
826	5-May-19	MYSORE	66	HV2	JAIPUR_66	19:30	19:47	0:17	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
827	5-May-19	MYSORE	66	KIRUGAVLU-SFC	KIRUGAVALU_66	8:30	18:15	9:45	NFBC ISSUED
828	5-May-19	MYSORE	66	HV2	KIRUGAVALU_66	19:03	19:20	0:16	LOAD CURTAILMENT
829	5-May-19	MYSORE	66	HV2	KIRUGAVALU_66	19:30	19:45	0:15	LOAD CURTAILMENT
830	5-May-19	MYSORE	66	HV2	KMDODDI_66	16:06	16:24	0:18	LOAD CURTAILMENT
831	5-May-19	MYSORE	66	HV2	KMDODDI_66	19:32	19:50	0:18	LOAD CURTAILMENT
832	5-May-19	MYSORE	66	HV1	KUSHALNAGARA_220	16:06	16:25	0:18	LOAD CURTAILMENT
833	5-May-19	MYSORE	66	HV1	KUSHALNAGARA_220	19:33	19:45	0:12	LOAD CURTAILMENT
834	5-May-19	MYSORE	66	HV1	PANDAVAPURA_66	19:03	19:19	0:15	LOAD CURTAILMENT
835	5-May-19	MYSORE	66	HV1	PANDAVAPURA_66	19:31	20:05	0:34	LOAD CURTAILMENT
836	5-May-19	MYSORE	66	HV1	SATHEGALA_66	11:15	12:00	0:45	LINE CLEAR AVAILED
837	5-May-19	MYSORE	66	HV1	SATHEGALA_66	19:03	19:10	0:06	LOAD CURTAILMENT
838	5-May-19	MYSORE	66	HV1	SANTHESARAGUR_66	11:02	11:12	0:09	TRANSFORMER FAULT
839	5-May-19	MYSORE	66	HV2	SANTHESARAGUR_66	19:03	19:12	0:08	LOAD CURTAILMENT
840	5-May-19	MYSORE	66	HV2	SANTHESARAGUR_66	19:35	19:41	0:06	LOAD CURTAILMENT
841	5-May-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	19:03	19:12	0:08	LOAD CURTAILMENT
842	5-May-19	MYSORE	66	HV5	SFCSHIVA_66	11:48	20:40	8:51	LINE CLEAR AVAILED
843	5-May-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	9:59	11:49	1:49	LINE CLEAR AVAILED
844	5-May-19	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	8:32	19:44	11:11	LINE CLEAR AVAILED
845	5-May-19	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	MRSMG_220	8:32	19:44	11:11	LINE CLEAR AVAILED
846	5-May-19	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	13:57	14:17	0:19	LINE CLEAR AVAILED
847	5-May-19	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	5:49	7:20	1:30	LOAD CURTAILMENT
848	5-May-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	13:31	13:45	0:13	LINE FAULT
849	5-May-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:39	9:50	0:10	LINE FAULT
850	5-May-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	10:54	11:02	0:07	LINE FAULT
851	5-May-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	11:22	11:38	0:16	LINE FAULT
852	5-May-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	7:47	8:07	0:20	LINE FAULT
853	5-May-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	18:30	18:31	0:01	TRANSFORMER FAULT
854	6-May-19	BAGALKOT	110	110/11KV,HV 1	ACHANUR_110	15:12	17:05	1:53	LINE CLEAR AVAILED
855	6-May-19	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	11:12	20:15	9:03	LINE CLEAR AVAILED
856	6-May-19	BAGALKOT	110	BAGEWADI- MUDDEBIHAL(ACHANUR)	MUDDEBIHAL_110	17:21	17:30	0:09	HAND TRIPPED
857	6-May-19	BAGALKOT	110	GADAG-SAMBAPUR ROAD (DAMBAL 1)	SAMBAPUR ROAD_220	9:41	17:17	7:36	LINE CLEAR AVAILED
858	6-May-19	BAGALKOT	110	110/11KV,HV4	GHATAPRABHA_110	6:48	6:53	0:05	TRANSFORMER FAULT
859	6-May-19	BAGALKOT	110	110/11KV,HV2	GOKAK_110	13:07	13:31	0:24	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
860	6-May-19	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	12:20	12:30	0:10	TRANSFORMER FAULT
861	6-May-19	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	11:15	12:36	1:21	LINE CLEAR AVAILED
862	6-May-19	BAGALKOT	110	11/11KV,HV 1	KALADAGI_110	11:34	12:14	0:40	LINE CLEAR AVAILED
863	6-May-19	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	12:04	12:16	0:12	TRANSFORMER FAULT
864	6-May-19	BAGALKOT	110	110/11KV,HV1	SIRSI_110	10:04	18:58	8:54	LINE CLEAR AVAILED
865	6-May-19	BAGALKOT	110	110/11KV,HV2	SHIROL_110	12:12	13:07	0:55	LINE CLEAR AVAILED
866	6-May-19	BAGALKOT	220	VAJRAMATTI-KAVATAGI LIS	VARJAMATTI_220	13:04	13:08	0:04	HAND TRIPPED
867	6-May-19	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	19:30	19:33	0:03	TRANSFORMER FAULT
868	6-May-19	BAGALKOT	110	110/11KV,HV1	NAVANAGAR(H)_110	4:52	20:35	15:43	TRANSFORMER FAULT
869	6-May-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	21:56	22:01	0:05	TRANSFORMER FAULT
870	6-May-19	BAGALKOT	110	110/33KV,HV3	MUNAVALLI_110,MUNAVALLI_33, MALLUR_33	23:02	23:41	0:39	TRANSFORMER FAULT
871	6-May-19	BAGALKOT	110	110/33KV,HV3	MUNAVALLI_110,MUNAVALLI_33, MALLUR_33	23:48	23:55	0:07	TRANSFORMER FAULT
872	6-May-19	BAGALKOT	110	BALAJI SUGARS-MUDDEBIHAL	MUDDEBIHAL_110	14:10	14:21	0:11	LINE FAULT
873	6-May-19	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	13:03	13:36	0:32	MAIN SUPPLY FAILURE
874	6-May-19	BENGALURU	220	BEGUR 220 - DB PURA 220	BEGUR 220	13:03	13:18	0:14	LINE FAULT
875	6-May-19	BENGALURU	220	BEGUR 220 - HOODY 220	BEGUR 220	13:03	14:26	1:22	LINE FAULT
876	6-May-19	BENGALURU	220	BEGUR 220 - HOSKOTE 220	HOSKOTE 220	13:03	13:32	0:29	MAIN SUPPLY FAILURE
877	6-May-19	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	13:03	13:25	0:21	MAIN SUPPLY FAILURE
878	6-May-19	BENGALURU	66	BEGUR 220 - BIAL 1 (EHT)	BIAL (EHT)	13:03	13:19	0:15	MAIN SUPPLY FAILURE
879	6-May-19	BENGALURU	66	BEGUR 220 - BIAL 2 (EHT)	BIAL (EHT)	13:03	13:19	0:15	MAIN SUPPLY FAILURE
880	6-May-19	BENGALURU	66	HV1	BEGUR 220	13:03	13:23	0:19	MAIN SUPPLY FAILURE
881	6-May-19	BENGALURU	66	HV2	BEGUR 220	13:03	13:23	0:19	MAIN SUPPLY FAILURE
882	6-May-19	BENGALURU	220	HV1	HOSKOTE 220	13:03	13:35	0:32	MAIN SUPPLY FAILURE
883	6-May-19	BENGALURU	220	HV2	HOSKOTE 220	13:03	13:33	0:30	MAIN SUPPLY FAILURE
884	6-May-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	VIDYANAGARA, HENNUR CROSS, GRIND WELL (EHT)	13:03	13:38	0:35	MAIN SUPPLY FAILURE
885	6-May-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	13:03	13:37	0:34	MAIN SUPPLY FAILURE
886	6-May-19	BENGALURU	66	HOSKOTE 220 - PILAGUMPA	PILAGUMPA	13:03	13:39	0:36	MAIN SUPPLY FAILURE
887	6-May-19	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	13:03	13:39	0:36	MAIN SUPPLY FAILURE
888	6-May-19	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	13:03	13:38	0:34	MAIN SUPPLY FAILURE
889	6-May-19	BENGALURU	66	HV1	HOSKOTE 220	13:03	13:36	0:33	MAIN SUPPLY FAILURE
890	6-May-19	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	16:42	16:44	0:01	LINE CLEAR AVAILED
891	6-May-19	BENGALURU	66	GOWRIBIDANUR 220 - DB 1	MANCHENAHALLI, GUNDAMGERE	15:20	15:29	0:09	LINE FAULT
892	6-May-19	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	17:52	18:03	0:10	LINE FAULT
893	6-May-19	BENGALURU	66	CHIKKABALLAPURA I/A - CHIKKABALLAPURA URBAN	CHIKKABALLAPURA URBAN	13:30	14:45	1:15	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
894	6-May-19	BENGALURU	66	HV1	HULLENAHALLI	12:02	12:30	0:27	LINE CLEAR AVAILED
895	6-May-19	BENGALURU	66	HV1	HULLENAHALLI	17:55	18:00	0:05	LINE CLEAR AVAILED
896	6-May-19	BENGALURU	66	KGF - BEML (EHT)	BEML (EHT)	16:42	16:57	0:15	LINE FAULT
897	6-May-19	BENGALURU	66	HV1	NANGLI	17:50	17:55	0:05	LINE CLEAR AVAILED
898	6-May-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	17:15	17:45	0:30	LINE CLEAR AVAILED
899	6-May-19	BENGALURU	66	HV2	SULIBELE	2:26	2:37	0:10	TRANSFORMER FAULT
900	6-May-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI	8:05	8:16	0:10	LINE CLEAR AVAILED
901	6-May-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	8:05	9:43	1:37	LINE CLEAR AVAILED
902	6-May-19	GULBARGA	220	HV1	KUSTAGI_220	9:40	10:05	0:25	LINE CLEAR AVAILED
903	6-May-19	GULBARGA	110	HANUMASAGAR-KUSTAGI	HANUMASAGAR_110, HIREGONNAGAR_110, HANUMANAL_110	9:45	10:13	0:28	MAIN SUPPLY FAILURE
904	6-May-19	GULBARGA	110	SHAHPUR220-KHANAPUR	KHANAPUR_GLB_110,SAIDAPUR_G LB_110,WADAGERA_110,SANNATI_IPP,COREGREEN_IPP, NALWAR_110	11:19	12:29	1:10	LINE CLEAR AVAILED
905	6-May-19	GULBARGA	66	ITTAGI-HUVINAHADAGALLI	HUVINAHADAGALLI_66,HOLAGUND I_66	11:10	13:15	2:05	LINE CLEAR AVAILED
906	6-May-19	GULBARGA	66	ITTAGI-SUZLON2	ITTAGI_220	12:40	13:40	1:00	LINE CLEAR AVAILED
907	6-May-19	GULBARGA	66	ITTAGI-HIREHADAGALLI1	HIREHADAGALLI_66	16:00	16:15	0:15	LINE FAULT
908	6-May-19	GULBARGA	66	ITTAGI-HIREHADAGALLI1	HIREHADAGALLI_66	16:15	21:30	5:15	LINE FAULT
909	6-May-19	GULBARGA	220	KUSTAGI-SUZLON2	KUSTAGI_220	9:41	20:25	10:44	LINE CLEAR AVAILED
910	6-May-19	GULBARGA	220	KUSHTAGI-LINGAPUR	LINGAPUR_220	0:00	20:56	20:56	LINE CLEAR AVAILED
911	6-May-19	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL_IPP	0:00	17:25	17:25	LINE CLEAR AVAILED
912	6-May-19	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGAR_IPP	14:55	17:20	2:25	LINE CLEAR AVAILED
913	6-May-19	GULBARGA	220	HV1	KUSTAGI_220	19:20	20:35	1:15	LINE CLEAR AVAILED
914	6-May-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	7:15	7:15	LINE CLEAR AVAILED
915	6-May-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	10:50	12:32	1:42	LINE CLEAR AVAILED
916	6-May-19	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	10:48	12:30	1:42	NFBC ISSUED
917	6-May-19	HASSAN	110	KADUR-NGNHL	KADUR_220	19:30	20:30	1:00	LOAD CURTAILMENT
918	6-May-19	HASSAN	110	KADUR-TNGL	KADUR_220	19:30	20:30	1:00	LOAD CURTAILMENT
919	6-May-19	HASSAN	110	KADUR-YGTI	KADUR_220	19:30	20:30	1:00	LOAD CURTAILMENT
920	6-May-19	HASSAN	110	HV2	KUNDAPURA_110	10:18	13:52	3:34	LINE CLEAR AVAILED
921	6-May-19	HASSAN	66	HV1	HARIHARAPURA_66	12:55	13:25	0:30	LINE CLEAR AVAILED
922	6-May-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	13:35	18:10	4:35	LINE FAULT
923	6-May-19	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	17:34	18:40	1:06	LINE FAULT
924	6-May-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	7:33	19:54	12:21	LINE CLEAR AVAILED
925	6-May-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	7:33	19:54	12:21	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
926	6-May-19	HASSAN	66	HV2	SATHENAHALLY_66	18:05	18:08	0:03	LOAD CURTAILMENT
927	6-May-19	MYSORE	66	CR NAGARA-HONNALLY	HONNALLY_MYS_66 ATTIGULIPURA_66	14:22	14:36	0:13	HAND TRIPPED
928	6-May-19	MYSORE	66	JYOTHINAGARA-DK MAIDANA	JYOTHINAGARA_66	12:31	16:24	3:52	NFBC ISSUED
929	6-May-19	MYSORE	66	JYOTHINAGARA-FTS	JYOTHINAGARA_66	12:31	16:32	4:00	NFBC ISSUED
930	6-May-19	MYSORE	66	KADAKOLA-SARGUR 2	HURA_66, HULLAHALLI_66, DOORA_66,	14:03	14:32	0:28	HAND TRIPPED
931	6-May-19	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66	14:03	14:32	0:28	HAND TRIPPED
932	6-May-19	MYSORE	66	HV2	KHBCOLONY_66	11:26	13:17	1:50	LINE CLEAR AVAILED
933	6-May-19	MYSORE	66	HV1	SANTHESARAGUR_66	13:18	13:30	0:11	TRANSFORMER FAULT
934	6-May-19	MYSORE	66	HV1	SANTHESARAGUR_66	15:44	15:53	0:09	TRANSFORMER FAULT
935	6-May-19	MYSORE	66	HV1	SANTHESARAGUR_66	15:54	17:48	1:53	TRANSFORMER FAULT
936	6-May-19	MYSORE	66	HV5	SFCSHIVA_66	14:55	21:35	6:40	TRANSFORMER FAULT
937	6-May-19	MYSORE	66	TUBINKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 SHIVALLY_66	20:25	20:31	0:05	LINE FAULT
938	6-May-19	MYSORE	66	VAJMANGALA-JYOTHINAGARA	JYOTHINAGARA_66	13:00	15:22	2:22	LINE CLEAR AVAILED
939	6-May-19	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	9:39	13:02	3:23	LINE CLEAR AVAILED
940	6-May-19	TUMKUR	220	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEL DIAMOND SOLAR_IPP_66	12:56	13:03	0:07	HAND TRIPPED
941	6-May-19	TUMKUR	110	TR-1	KBCROSS_220	9:43	20:27	10:44	LINE CLEAR AVAILED
942	6-May-19	TUMKUR	66	TR-1	BRAHMASANDRA_66	11:07	11:42	0:35	LINE CLEAR AVAILED
943	6-May-19	TUMKUR	66	TR-2	BRAHMASANDRA_66	11:24	11:42	0:18	LINE CLEAR AVAILED
944	6-May-19	TUMKUR	66	TR-2	CHANNAGIRI_66	13:29	14:27	0:58	LINE CLEAR AVAILED
945	6-May-19	TUMKUR	66	TR-2	DAVANAGERE_66	21:34	21:40	0:05	TRANSFORMER FAULT
946	6-May-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	14:19	14:32	0:12	LINE FAULT
947	6-May-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	10:30	11:36	1:05	LINE CLEAR AVAILED