

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 04.06.2019 to 10.06.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	4-Jun-19	BAGALKOT	220	SHARAVATHY1-SIRSI	SIRSI_220	0:27	16:05	15:38	LINE FAULT
2	4-Jun-19	BAGALKOT	220	SHARAVATHY1-SIRSI	SIRSI_220	23:17	23:59	0:42	LINE FAULT
3	4-Jun-19	BAGALKOT	220	SHARAVATHY2-SIRSI	SIRSI_220	0:09	17:54	17:45	LINE FAULT
4	4-Jun-19	BAGALKOT	110	SIRSI-KUMTA1&2	SIRSI_110	0:00	12:20	12:20	LINE CLEAR AVAILED
5	4-Jun-19	BAGALKOT	110	SINDAGI-ALMEL	ALMEL_110	9:41	9:46	0:05	HAND TRIPPED
6	4-Jun-19	BAGALKOT	110	HONNAVAR-MURDESHWAR	MURDESHWAR_110	0:29	9:42	9:13	MAIN SUPPLY FAILURE
7	4-Jun-19	BAGALKOT	110	HUKKERI-HATTARAGI	HATTARAGI_110	10:34	12:14	1:40	LINE CLEAR AVAILED
8	4-Jun-19	BAGALKOT	110	110/33KV,HV3	ZALAKI_110&HORTI_33	0:00	5:57	5:57	LINE CLEAR AVAILED
9	4-Jun-19	BAGALKOT	220	RAVI URJA 1-ATHANI	ATHANI_220	15:32	18:01	2:29	LINE CLEAR AVAILED
10	4-Jun-19	BAGALKOT	220	RAVI URJA 2-ATHANI	ATHANI_220	0:00	18:01	18:01	LINE CLEAR AVAILED
11	4-Jun-19	BAGALKOT	220	ALMATTI 2-BAGEWADI	BAGEWADI_220	10:53	23:59	13:06	LINE CLEAR AVAILED
12	4-Jun-19	BAGALKOT	110	SUPA 1-AMBEWADI	AMBEWADI_220	19:36	20:25	0:49	LINE FAULT
13	4-Jun-19	BAGALKOT	220	220/110KV,HV1&LV1	CHIKKODI_220	10:00	11:27	1:27	LINE CLEAR AVAILED
14	4-Jun-19	BAGALKOT	220	220/110KV,HV1&LV1	KARWAR_220	15:26	17:38	2:12	LINE CLEAR AVAILED
15	4-Jun-19	BAGALKOT	220	KADRA 1-KARWAR	KARWAR_220	17:40	18:28	0:48	LINE CLEAR AVAILED
16	4-Jun-19	BAGALKOT	110	AMBEWADI220-KIRUVATTI	KIRUVATTI_110	21:52	22:05	0:13	HAND TRIPPED
17	4-Jun-19	BAGALKOT	110	UMMACHAGI-KIRUVATTI	KIRUVATTI_110	22:05	22:06	0:01	HAND TRIPPED
18	4-Jun-19	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)-RANEENNUR	RANEENNUR_220	0:00	16:14	16:14	LINE CLEAR AVAILED
19	4-Jun-19	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	19:13	19:25	0:12	LOAD CURTAILMENT
20	4-Jun-19	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	15:13	15:53	0:40	LINE CLEAR AVAILED
21	4-Jun-19	BAGALKOT	110	BALAJI SUGARS-MUDDEBIHAL	MUDDEBIHAL_110	0:00	0:55	0:55	HAND TRIPPED
22	4-Jun-19	BAGALKOT	110	JAMKHANDI-SHIROL	SHIROL_110	0:00	18:07	18:07	LINE CLEAR AVAILED
23	4-Jun-19	BAGALKOT	110	MANTUR-SHIROL	SHIROL_110	18:07	23:59	5:52	LINE CLEAR AVAILED
24	4-Jun-19	BAGALKOT	220	220/110KV,HV1,LV1	VAJRAMATTI_220,BILAGI_110,LOKAPUR_110,MUDHOL_110,KATARKI_110,MANTUR1&2_110,VAJRAMATTI_110,JK CEMENT_110	0:00	10:41	10:41	LINE CLEAR AVAILED
25	4-Jun-19	BAGALKOT	220	220/110KV,HV2,LV2	VAJRAMATTI_220,BILAGI_110,LOKAPUR_110,MUDHOL_110,KATARKI_110,MANTUR1&2_110,VAJRAMATTI_110,JK CEMENT_110	0:00	2:57	2:57	LINE CLEAR AVAILED
26	4-Jun-19	BENGALURU	66	GOKULA - BEL (EH)	BEL (EHT)	6:20	7:55	1:35	MAIN SUPPLY FAILURE
27	4-Jun-19	BENGALURU	66	GOKULA - RMV	RMV, TATA INSTITUTE (EHT)	6:20	6:26	0:05	MAIN SUPPLY FAILURE
28	4-Jun-19	BENGALURU	66	GOKULA - MATHIKERE	MATHIKERE	6:20	7:06	0:45	MAIN SUPPLY FAILURE
29	4-Jun-19	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	6:20	7:53	1:33	LINE FAULT
30	4-Jun-19	BENGALURU	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT), HMT (EHT)	6:32	7:53	1:21	LINE FAULT
31	4-Jun-19	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	8:09	8:16	0:07	LOAD CHANGE OVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
32	4-Jun-19	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	6:20	7:44	1:23	LINE FAULT
33	4-Jun-19	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	6:20	7:44	1:24	LINE FAULT
34	4-Jun-19	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	6:20	7:44	1:24	LINE FAULT
35	4-Jun-19	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	11:40	12:45	1:05	LINE FAULT
36	4-Jun-19	BENGALURU	66	HV1	EPIP 220	10:20	14:10	3:50	TRANSFORMER FAULT
37	4-Jun-19	BENGALURU	66	HV1	NANDINI LAYOUT	11:15	11:19	0:04	LINE CLEAR AVAILED
38	4-Jun-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	0:03	0:07	0:04	LOAD CHANGEOVER
39	4-Jun-19	BENGALURU	66	NELAMANGALA 66 - ALUR	ALUR	0:00	12:10	12:10	LOAD CHANGEOVER
40	4-Jun-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	8:27	8:30	0:03	LOAD CHANGEOVER
41	4-Jun-19	BENGALURU	66	NELAMANGALA 66 - ALUR	ALUR	8:27	8:34	0:07	LOAD CHANGEOVER
42	4-Jun-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	15:21	15:31	0:10	LINE CLEAR AVAILED
43	4-Jun-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	17:08	17:17	0:09	LINE CLEAR AVAILED
44	4-Jun-19	BENGALURU	66	HV2	NELAMANGALA 66	15:21	15:24	0:03	LINE CLEAR AVAILED
45	4-Jun-19	BENGALURU	66	HV2	NELAMANGALA 66	17:18	17:19	0:01	LINE CLEAR AVAILED
46	4-Jun-19	BENGALURU	66	SURYANAGAR - YARANDANAHALLI 220	SURYANAGAR	12:00	12:25	0:25	LINE CLEAR AVAILED
47	4-Jun-19	BENGALURU	66	HV1	SURYANAGAR	12:00	12:30	0:30	LINE CLEAR AVAILED
48	4-Jun-19	BENGALURU	66	HV2	SURYANAGAR	12:00	12:30	0:30	LINE CLEAR AVAILED
49	4-Jun-19	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	7:54	8:02	0:08	LINE FAULT
50	4-Jun-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA , ADDAGAL, SOMAYAJANAHALLI	19:12	19:55	0:43	LOAD CURTAILMENT
51	4-Jun-19	BENGALURU	66	HV1	KOLAR 220	11:08	16:06	4:58	LINE CLEAR AVAILED
52	4-Jun-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	13:03	15:13	2:10	LINE CLEAR AVAILED
53	4-Jun-19	BENGALURU	66	GOWRIBIDANUR 220 - DB 2	MANCHENAHALLI	11:44	11:54	0:10	LINE CLEAR AVAILED
54	4-Jun-19	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	11:53	15:33	3:40	LINE CLEAR AVAILED
55	4-Jun-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	14:35	14:42	0:07	LOAD CHANGEOVER
56	4-Jun-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	16:10	16:15	0:05	LOAD CHANGEOVER
57	4-Jun-19	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	14:35	14:42	0:07	LOAD CHANGEOVER
58	4-Jun-19	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	16:10	16:15	0:05	LOAD CHANGEOVER
59	4-Jun-19	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	14:35	14:42	0:07	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
60	4-Jun-19	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	16:10	16:15	0:05	LOAD CHANGEOVER
61	4-Jun-19	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	0:00	10:00	10:00	LINE CLEAR AVAILED
62	4-Jun-19	GULBARGA	220	KAPNOOR-SHAHPUR1	KAPNOOR_220	0:00	7:00	7:00	LINE CLEAR AVAILED
63	4-Jun-19	GULBARGA	220	HUMNABAD-HALBARGA1	HALBARGA_220	0:00	9:37	9:37	LINE CLEAR AVAILED
64	4-Jun-19	GULBARGA	220	HV1	KAPNOOR_220	8:50	12:25	3:35	LINE CLEAR AVAILED
65	4-Jun-19	GULBARGA	220	HV2	KAPNOOR_220	13:02	16:55	3:53	LINE CLEAR AVAILED
66	4-Jun-19	GULBARGA	220	HV1	KUSHTAGI_220	0:40	0:53	0:13	TRANSFORMER FAULT
67	4-Jun-19	GULBARGA	220	HV2	KUSHTAGI_220	10:40	10:50	0:10	TRANSFORMER FAULT
68	4-Jun-19	GULBARGA	110	HV3	BEVOOR_110	0:17	0:46	0:29	LINE CLEAR AVAILED
69	4-Jun-19	GULBARGA	110	HV3	BEVOOR_110	9:37	10:05	0:28	LINE CLEAR AVAILED
70	4-Jun-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	1:33	12:03	10:30	LINE FAULT
71	4-Jun-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	10:41	13:25	2:44	LINE CLEAR AVAILED
72	4-Jun-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	10:41	13:25	2:44	LINE CLEAR AVAILED
73	4-Jun-19	HASSAN	220	HV1	PUTTUR_220	10:40	11:47	1:07	LINE CLEAR AVAILED
74	4-Jun-19	HASSAN	110	HV5	MRMG_220	9:46	15:19	5:33	LINE CLEAR AVAILED
75	4-Jun-19	HASSAN	110	HV2	HALADY_110	6:12	6:17	0:05	TRANSFORMER FAULT
76	4-Jun-19	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	9:10	17:15	8:05	LINE CLEAR AVAILED
77	4-Jun-19	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	9:10	17:15	8:05	LINE CLEAR AVAILED
78	4-Jun-19	HASSAN	66	HV1	HARIHARAPURA_66	9:08	12:50	3:42	LINE CLEAR AVAILED
79	4-Jun-19	HASSAN	66	HARIHAR-KADUVINKOTE	HARIHARAPURA_66	9:08	12:50	3:42	LINE CLEAR AVAILED
80	4-Jun-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:09	10:25	2:16	LINE CLEAR AVAILED
81	4-Jun-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	8:09	10:25	2:16	LINE CLEAR AVAILED
82	4-Jun-19	MYSORE	66	HV2	ADDIHALLI_66	18:54	18:59	0:04	LOAD CURTAILMENT
83	4-Jun-19	MYSORE	66	HV2	ADDIHALLI_66	19:12	23:59	4:46	LOAD CURTAILMENT
84	4-Jun-19	MYSORE	66	BILIKERE-KHB	DMG_HALLI_66	10:40	17:00	6:20	NFBC ISSUED
85	4-Jun-19	MYSORE	66	HV1	BILIKERE_66	18:54	19:10	0:16	LOAD CURTAILMENT
86	4-Jun-19	MYSORE	66	HV1	BILIKERE_66	19:12	20:13	1:01	LOAD CURTAILMENT
87	4-Jun-19	MYSORE	66	HV2	BOOKANAKERE_66	19:12	19:23	0:10	LOAD CURTAILMENT
88	4-Jun-19	MYSORE	66	HV2	CHINAKURALI_66	19:12	19:30	0:18	LOAD CURTAILMENT
89	4-Jun-19	MYSORE	220	HV1	CRNAGAR_220	13:13	14:16	1:03	LINE CLEAR AVAILED
90	4-Jun-19	MYSORE	66	HV2	DODDARAYAPET_66	18:53	19:13	0:20	LOAD CURTAILMENT
91	4-Jun-19	MYSORE	66	HV2	JAIPUR_66	18:55	19:06	0:10	LOAD CURTAILMENT
92	4-Jun-19	MYSORE	66	HV1	KADAKOLA_220	11:25	12:56	1:31	LINE CLEAR AVAILED
93	4-Jun-19	MYSORE	66	HV2	KADAKOLA_220	13:07	15:00	1:53	LINE CLEAR AVAILED
94	4-Jun-19	MYSORE	66	KHB STATION-HOOTAGALLI	KHBCOLONY_66	10:23	17:21	6:58	LINE CLEAR AVAILED
95	4-Jun-19	MYSORE	66	HV2	KMDODDI_66	18:54	19:09	0:15	LOAD CURTAILMENT
96	4-Jun-19	MYSORE	66	HV2	KMDODDI_66	19:12	19:39	0:26	LOAD CURTAILMENT
97	4-Jun-19	MYSORE	66	HV1	KRNAGARA_66	18:20	18:34	0:14	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
98	4-Jun-19	MYSORE	66	HV1	KRPET_66	10:40	18:19	7:39	LINE CLEAR AVAILED
99	4-Jun-19	MYSORE	66	HV2	SANTHESARAGUR_66	18:55	19:05	0:10	LOAD CURTAILMENT
100	4-Jun-19	MYSORE	66	HV2	SANTHESARAGUR_66	19:12	19:19	0:06	LOAD CURTAILMENT
101	4-Jun-19	MYSORE	66	HV1	SFCSHIVA_66	8:12	18:52	10:39	LINE CLEAR AVAILED
102	4-Jun-19	MYSORE	66	HV2	SFCSHIVA_66	8:15	18:53	10:38	LINE CLEAR AVAILED
103	4-Jun-19	MYSORE	66	HV3	SFCSHIVA_66	8:13	18:50	10:36	LINE CLEAR AVAILED
104	4-Jun-19	MYSORE	66	HV4	SFCSHIVA_66	8:13	18:51	10:38	LINE CLEAR AVAILED
105	4-Jun-19	MYSORE	66	HV5	SFCSHIVA_66	8:11	19:04	10:52	LINE CLEAR AVAILED
106	4-Jun-19	MYSORE	66	HV5	SFCSHIVA_66	3:01	6:16	3:14	LINE CLEAR AVAILED
107	4-Jun-19	MYSORE	66	SFC SIVA-PGL	SFCSHIVA_66	8:17	18:21	10:03	LINE CLEAR AVAILED
108	4-Jun-19	MYSORE	66	PPCL	SFCSHIVA_66	8:02	18:21	10:19	LINE CLEAR AVAILED
109	4-Jun-19	MYSORE	66	HV1	SINDHUVALI_66	10:03	16:49	6:45	LINE CLEAR AVAILED
110	4-Jun-19	MYSORE	66	SHV2	SINDHUVALI_66	10:00	16:49	6:49	LINE CLEAR AVAILED
111	4-Jun-19	MYSORE	66	HV1	SRIRANGAPATNA_66	13:19	13:30	0:10	TRANSFORMER FAULT
875	4-Jun-19	TUMKUR	66	TR-2	URDIGERE_66	7:34	8:17	0:42	LINE CLEAR AVAILED
876	4-Jun-19	TUMKUR	66	TR-2	MELKOTE_66	3:15	9:37	6:21	TRANSFORMER FAULT
877	4-Jun-19	TUMKUR	66	TR-2	MELKOTE_66	9:38	9:40	0:01	LINE CLEAR AVAILED
112	5-Jun-19	BAGALKOT	220	SHARAVATHY1-SIRSI	SIRSI_220	0:00	19:17	19:17	LINE CLEAR AVAILED
113	5-Jun-19	BAGALKOT	220	SHARAVATHY2-SIRSI	SIRSI_220	2:52	19:18	16:26	LINE FAULT
114	5-Jun-19	BAGALKOT	110	SIRSI-KUMTA1&2	SIRSI_110	5:34	7:21	1:47	LINE FAULT
115	5-Jun-19	BAGALKOT	110	110/33KV, HV3	SATTI_110, SATTI_33	17:22	17:36	0:14	TRANSFORMER FAULT
116	5-Jun-19	BAGALKOT	110	HONNAVAR-MURDESHWAR	MURDESHWAR_110	9:12	9:16	0:04	MAIN SUPPLY FAILURE
117	5-Jun-19	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)-RANEENNUR	RANEENNUR_220	6:29	23:59	17:30	LINE CLEAR AVAILED
118	5-Jun-19	BAGALKOT	110	ANKOLA-KUMATA(L2)	KUMATA_110	10:45	12:42	1:57	LINE CLEAR AVAILED
119	5-Jun-19	BAGALKOT	110	110/33KV,HV-2	ANKOLA_110&33KV SEA BIRD,ANKOLA,MASTIKATTI&VAJRAKOSHA	12:42	12:45	0:03	LINE CLEAR AVAILED
120	5-Jun-19	BENGALURU	66	HOODY 220 - ITI	ITI	18:53	19:02	0:09	LINE FAULT
121	5-Jun-19	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	18:53	19:03	0:10	LINE FAULT
122	5-Jun-19	BENGALURU	66	HV2	KADUGODI	20:09	20:32	0:22	TRANSFORMER FAULT
123	5-Jun-19	BENGALURU	66	HV2	BAGEPALLI	7:40	8:36	0:55	TRANSFORMER FAULT
124	5-Jun-19	BENGALURU	220	CHINTAMANI 220 - PGCIL 1	CHINTAMANI 220	18:54	20:18	1:24	MAIN SUPPLY FAILURE
125	5-Jun-19	BENGALURU	220	CHINTAMANI 220 - PGCIL 2	CHINTAMANI 220	18:54	23:59	5:05	MAIN SUPPLY FAILURE
126	5-Jun-19	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	18:54	20:25	1:31	MAIN SUPPLY FAILURE
127	5-Jun-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	18:54	20:25	1:31	MAIN SUPPLY FAILURE
128	5-Jun-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA	18:54	20:26	1:32	MAIN SUPPLY FAILURE
129	5-Jun-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	18:54	20:25	1:31	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
130	5-Jun-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	18:54	20:37	1:43	MAIN SUPPLY FAILURE
131	5-Jun-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	18:54	20:37	1:43	MAIN SUPPLY FAILURE
132	5-Jun-19	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	18:54	20:26	1:32	MAIN SUPPLY FAILURE
133	5-Jun-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	18:54	20:37	1:43	MAIN SUPPLY FAILURE
134	5-Jun-19	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66, SM MANGALA	18:54	20:26	1:32	MAIN SUPPLY FAILURE
135	5-Jun-19	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	18:54	20:44	1:50	MAIN SUPPLY FAILURE
136	5-Jun-19	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	18:54	23:59	5:05	MAIN SUPPLY FAILURE
137	5-Jun-19	BENGALURU	220	KOLAR 220 - RAILWAYS 1 & 2 (EHT)	BANGARPET RAILWAYS (EHT)	18:54	20:44	1:50	MAIN SUPPLY FAILURE
138	5-Jun-19	BENGALURU	66	KOLAR 220- - BANGARPET 1 & 2	BANGARPET	18:54	20:45	1:51	MAIN SUPPLY FAILURE
139	5-Jun-19	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	18:54	20:44	1:50	MAIN SUPPLY FAILURE
140	5-Jun-19	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	18:54	20:44	1:50	MAIN SUPPLY FAILURE
141	5-Jun-19	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	18:54	20:45	1:51	MAIN SUPPLY FAILURE
142	5-Jun-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	18:54	20:46	1:52	MAIN SUPPLY FAILURE
143	5-Jun-19	BENGALURU	66	KOLAR 220 - NARASAPURA	NARASAPURA	18:54	20:45	1:51	MAIN SUPPLY FAILURE
144	5-Jun-19	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	18:54	20:45	1:51	MAIN SUPPLY FAILURE
145	5-Jun-19	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	18:54	20:45	1:51	MAIN SUPPLY FAILURE
146	5-Jun-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	18:54	20:45	1:51	MAIN SUPPLY FAILURE
147	5-Jun-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	18:54	20:46	1:52	MAIN SUPPLY FAILURE
148	5-Jun-19	BENGALURU	66	HV1	MAASTHI	6:55	7:00	0:05	TRANSFORMER FAULT
149	5-Jun-19	BENGALURU	66	HV2	MAASTHI	7:00	7:05	0:05	TRANSFORMER FAULT
150	5-Jun-19	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	18:54	20:00	1:06	MAIN SUPPLY FAILURE
151	5-Jun-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	18:54	20:08	1:14	MAIN SUPPLY FAILURE
152	5-Jun-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	18:54	20:09	1:15	MAIN SUPPLY FAILURE
153	5-Jun-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	18:54	20:15	1:21	MAIN SUPPLY FAILURE
154	5-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	18:54	20:16	1:22	MAIN SUPPLY FAILURE
155	5-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	18:54	20:22	1:28	MAIN SUPPLY FAILURE
156	5-Jun-19	BENGALURU	66	MALUR 220 - SARJAPURA 220	VIKAS TECH PARK 220	18:54	22:01	3:07	MAIN SUPPLY FAILURE
157	5-Jun-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	16:21	20:08	3:46	LINE FAULT
158	5-Jun-19	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	18:01	18:37	0:35	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
159	5-Jun-19	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	18:46	19:35	0:48	LINE FAULT
160	5-Jun-19	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	18:54	20:35	1:41	MAIN SUPPLY FAILURE
161	5-Jun-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	22:05	22:21	0:16	LOAD CHANGEOVER
162	5-Jun-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	18:54	20:35	1:41	MAIN SUPPLY FAILURE
163	5-Jun-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	18:54	20:36	1:42	MAIN SUPPLY FAILURE
164	5-Jun-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	SARJAPURA 220	22:05	22:21	0:16	LOAD CHANGEOVER
165	5-Jun-19	BENGALURU	66	TG HALLI - ANCHEPALYA 220	TG HALLI	19:05	19:25	0:20	LOAD CHANGEOVER
166	5-Jun-19	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 2	RAILWAYS (EHT)	23:47	23:59	0:12	LINE FAULT
167	5-Jun-19	BENGALURU	66	HV1	KIADB DB PURA 220	18:46	19:02	0:16	TRANSFORMER FAULT
168	5-Jun-19	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	21:16	21:56	0:39	LINE FAULT
169	5-Jun-19	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	22:02	22:19	0:16	LINE CLEAR AVAILED
170	5-Jun-19	BENGALURU	66	HV2	DODDABELAVANGALA	1:41	2:31	0:50	LINE CLEAR AVAILED
171	5-Jun-19	BENGALURU	66	HV2	DODDABELAVANGALA	8:42	9:34	0:52	LINE CLEAR AVAILED
172	5-Jun-19	BENGALURU	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	0:58	1:09	0:11	LINE FAULT
173	5-Jun-19	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	20:06	20:57	0:51	LINE FAULT
174	5-Jun-19	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	20:06	20:57	0:51	LINE FAULT
175	5-Jun-19	GULBARGA	400	JVSWL400-GUTTUR	GUTTUR_400	18:27	23:59	5:32	LINE CLEAR AVAILED
176	5-Jun-19	GULBARGA	110	HV3	BEVOOR_110	20:57	21:06	0:09	TRANSFORMER FAULT
177	5-Jun-19	GULBARGA	110	HV1	HALBARGA_220	18:04	19:25	1:21	TRANSFORMER FAULT
178	5-Jun-19	GULBARGA	110	ALIPUR-KUDITINI	KUDITINI_110	21:01	21:14	0:13	LINE FAULT
179	5-Jun-19	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	23:59	23:59	0:00	LINE FAULT
180	5-Jun-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:24	23:59	0:35	HAND TRIPPED
181	5-Jun-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	9:18	11:55	2:37	NFBC ISSUED
182	5-Jun-19	HASSAN	220	MRSSM-SHARAVATHY4	MRMG_220	0:00	13:43	13:43	LINE CLEAR AVAILED
183	5-Jun-19	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	0:00	13:43	13:43	LINE CLEAR AVAILED
184	5-Jun-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	9:18	11:55	2:37	LINE CLEAR AVAILED
185	5-Jun-19	HASSAN	110	HV2	GANDASI_110	21:13	21:20	0:07	TRANSFORMER FAULT
186	5-Jun-19	HASSAN	110	SAGARA-JST1	SAGARA_110	2:38	2:46	0:08	LINE FAULT
187	5-Jun-19	HASSAN	110	SAGARA-LST4	SAGARA_110	3:50	4:10	0:20	LINE FAULT
188	5-Jun-19	HASSAN	66	HASSN22-BELUR	HASSAN_220	22:12	23:08	0:56	LINE FAULT
189	5-Jun-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	11:34	11:59	0:25	LINE FAULT
190	5-Jun-19	HASSAN	66	HADAVAN-HNPURA	HADAVANAHALLY_66	18:05	18:54	0:49	MAIN SUPPLY FAILURE
191	5-Jun-19	HASSAN	66	HV1	HARIHARAPURA_66	18:05	18:54	0:49	MAIN SUPPLY FAILURE
192	5-Jun-19	HASSAN	66	HV1	HASSAN_66	21:42	21:48	0:06	TRANSFORMER FAULT
193	5-Jun-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	18:04	23:59	5:55	LINE FAULT
194	5-Jun-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	18:25	18:45	0:20	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
195	5-Jun-19	HASSAN	66	HNPURA-SOMANAHALLI	HOLEHONNUR_66	18:26	18:36	0:10	LINE FAULT
196	5-Jun-19	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	21:43	22:30	0:47	LINE FAULT
197	5-Jun-19	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	21:55	22:33	0:38	LINE FAULT
198	5-Jun-19	HASSAN	66	HV1	SINGAPURA_66	20:30	23:45	3:15	TRANSFORMER FAULT
199	5-Jun-19	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	22:13	22:50	0:37	LINE FAULT
200	5-Jun-19	HASSAN	66	UDDURKO-CKNDGL	UDDURKOPLU_66	21:53	22:39	0:46	LINE FAULT
201	5-Jun-19	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	22:03	22:45	0:42	LINE FAULT
202	5-Jun-19	MYSORE	66	BILIKERE-GV GUDI	GVGUDI_66	23:02	23:17	0:15	LINE FAULT
203	5-Jun-19	MYSORE	66	COWDALLI-MARTALLI	MARTAHALLI_66 RAMAPURA_MYS_66	21:38	23:59	2:20	LINE FAULT
204	5-Jun-19	MYSORE	66	ELAVALA-HUNSUR	GAVADAGERE_66	22:59	23:41	0:42	LINE FAULT
205	5-Jun-19	MYSORE	66	HAMPAPURA-BASARALU	BESAGARAHALLI_66 KOPPA_66	20:35	20:39	0:03	LINE FAULT
206	5-Jun-19	MYSORE	66	HV1	JAKKANAHALLY_66	6:51	7:03	0:11	TRANSFORMER FAULT
207	5-Jun-19	MYSORE	66	HV1	JAKKANAHALLY_66	23:09	23:59	0:49	TRANSFORMER FAULT
208	5-Jun-19	MYSORE	66	HV1	SALIGRAMA_66	3:35	10:40	7:05	TRANSFORMER FAULT
209	5-Jun-19	MYSORE	66	HV2	SALIGRAMA_66	4:50	10:44	5:54	LINE CLEAR AVAILED
210	5-Jun-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 BASARALU_66 KESLAGERE_66 SHIVALLY_66 VADERALLI_66	20:33	20:43	0:09	LINE FAULT
211	5-Jun-19	MYSORE	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	22:58	23:14	0:15	LINE FAULT
212	5-Jun-19	MYSORE	66	HV1	VIRAJPET_66	15:06	15:55	0:48	HAND TRIPPED
213	5-Jun-19	MYSORE	66	HV2	VIRAJPET_66	15:06	15:55	0:49	HAND TRIPPED
878	5-Jun-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	17:39	17:44	0:04	LINE FAULT
879	5-Jun-19	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	17:39	17:40	0:00	LINE FAULT
880	5-Jun-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	14:31	14:41	0:10	LINE FAULT
881	5-Jun-19	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, CHIKKAJAJUR_66, MAYAKONDA_66, SASALUHALLA_66	23:02	23:46	0:44	LINE FAULT
214	6-Jun-19	BAGALKOT	110	110/11KV, HV1	BAGALKOT_110	2:51	3:27	0:36	TRANSFORMER FAULT
215	6-Jun-19	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	9:05	19:40	10:35	LINE CLEAR AVAILED
216	6-Jun-19	BAGALKOT	220	ADPH2-BAGEWADI	BAGEWADI_220	9:20	19:30	10:10	LINE CLEAR AVAILED
217	6-Jun-19	BAGALKOT	220	ATRIA1-BAGEWADI	BAGEWADI_220	9:20	19:35	10:15	LINE CLEAR AVAILED
218	6-Jun-19	BAGALKOT	220	FORTUNEFIVE1&2-BAGEWADI	BAGEWADI_220	9:21	19:37	10:16	LINE CLEAR AVAILED
219	6-Jun-19	BAGALKOT	220	BAGEWADI-BIJAPUR1	BAGEWADI_220	9:20	19:39	10:19	LINE CLEAR AVAILED
220	6-Jun-19	BAGALKOT	220	BAGEWADI-BIJAPUR2	BAGEWADI_220	9:20	19:47	10:27	LINE CLEAR AVAILED
221	6-Jun-19	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	BAGEWADI_220	9:04	19:30	10:26	LINE CLEAR AVAILED
222	6-Jun-19	BAGALKOT	110	BAGEWADI-MAMDAPUR1&2	MAMDAPUR(B)_110	9:04	19:44	10:40	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
223	6-Jun-19	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	9:04	23:59	14:55	LINE CLEAR AVAILED
224	6-Jun-19	BAGALKOT	110	110/11KV, HV2	BHUTNAL_110	22:21	22:25	0:04	TRANSFORMER FAULT
225	6-Jun-19	BAGALKOT	110	SUZLON-BYADAGI	BYADAGI_110	3:39	3:55	0:16	HAND TRIPPED
226	6-Jun-19	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	3:53	8:57	5:04	LINE FAULT
227	6-Jun-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	5:14	23:59	18:45	LINE FAULT
228	6-Jun-19	BAGALKOT	220	220/110KV, HV2&LV2	CHIKKODI_220	10:32	13:35	3:03	LINE CLEAR AVAILED
229	6-Jun-19	BAGALKOT	110	GHATAPRABHA220-PG HUNSYAL	PG HUNSYAL_110	3:03	4:20	1:17	LINE FAULT
230	6-Jun-19	BAGALKOT	110	110/11KV, HV2	GOKAK_110	8:46	8:54	0:08	TRANSFORMER FAULT
231	6-Jun-19	BAGALKOT	110	110/11KV, HV2	GOKAK_110	21:40	22:22	0:42	TRANSFORMER FAULT
232	6-Jun-19	BAGALKOT	220	HAVERI-GUTTUR 1	HAVERI_220	3:05	23:59	20:54	LINE FAULT
233	6-Jun-19	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	2:19	3:36	1:17	LINE FAULT
234	6-Jun-19	BAGALKOT	110	HAVERI-HANAGALL(TILUVALLI)	HANAGALL_110	2:38	3:32	0:54	LINE FAULT
235	6-Jun-19	BAGALKOT	110	HAVERI-HANAGALL(TILUVALLI)	HANAGALL_110	4:35	17:54	13:19	LINE FAULT
236	6-Jun-19	BAGALKOT	110	110/11KV,HV-4	HUKKERI_110	23:00	23:10	0:10	TRANSFORMER FAULT
237	6-Jun-19	BAGALKOT	110	110/11KV,HV2	RANNABELAGALI_110	13:01	13:20	0:19	TRANSFORMER FAULT
238	6-Jun-19	BAGALKOT	110	110/11KV,HV2	RANNABELAGALI_110	15:25	15:40	0:15	TRANSFORMER FAULT
239	6-Jun-19	BAGALKOT	110	BAGEWADI-MATTIHAL	MATTIHAL_110	9:10	19:45	10:35	LINE CLEAR AVAILED
240	6-Jun-19	BAGALKOT	110	BAGEWADI-MUKARTIHAL	MUKARTIHAL_110	9:37	11:25	1:48	LINE FAULT
241	6-Jun-19	BAGALKOT	110	MATRIX -MUKARTIHAL	MUKARTIHAL_110	13:07	13:21	0:14	LINE FAULT
242	6-Jun-19	BAGALKOT	110	SPV-MUKARTIHAL	MUKARTIHAL_110	13:07	13:22	0:15	LINE FAULT
243	6-Jun-19	BAGALKOT	400	DHONI-TIE BREAKER 2GUDADALLI	DHONI_400	2:01	2:27	0:26	LINE FAULT
244	6-Jun-19	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	VAJRAMATTI_220	3:23	12:57	9:34	LINE FAULT
245	6-Jun-19	BAGALKOT	220	VAJRAMATTI-BAGALKOT2	VAJRAMATTI_220	9:37	12:59	3:22	LINE CLEAR AVAILED
246	6-Jun-19	BAGALKOT	110	110/33KV,HV2	UTTUR_110	5:12	5:21	0:09	TRANSFORMER FAULT
247	6-Jun-19	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	3:45	6:27	2:42	LINE FAULT
248	6-Jun-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	3:14	17:23	14:09	LINE FAULT
249	6-Jun-19	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	4:42	6:28	1:46	LINE FAULT
250	6-Jun-19	BAGALKOT	220	220/110KV,HV1	SIRSI_220,KAVALWADA_110,SIRSI1&2_110,U MMACHAGI_110	4:42	6:31	1:49	TRANSFORMER FAULT
251	6-Jun-19	BAGALKOT	220	SIRSI-SHARAVATHI1	SIRSI_220	4:42	17:48	13:06	LINE FAULT
252	6-Jun-19	BAGALKOT	220	SIRSI-SHARAVATHI2	SIRSI_220	13:16	17:48	4:32	LINE CLEAR AVAILED
253	6-Jun-19	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	5:38	6:25	0:47	LINE FAULT
254	6-Jun-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	5:05	12:30	7:25	LINE FAULT
255	6-Jun-19	BAGALKOT	220	SHIIROLKOPPA(BALLIGAVI_- RANEBENNUR	RANEBENNUR_220	0:00	12:41	12:41	LINE CLEAR AVAILED
256	6-Jun-19	BAGALKOT	110	SIRSI-KAVALWADA	KAVALWADA_110	4:42	4:45	0:03	HAND TRIPPED
257	6-Jun-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	4:42	4:59	0:17	LINE FAULT
258	6-Jun-19	BAGALKOT	110	SIRSI-KUMTA1	SIRSI_110	4:42	6:55	2:13	LINE CLEAR AVAILED
259	6-Jun-19	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	4:42	6:55	2:13	LINE CLEAR AVAILED
260	6-Jun-19	BAGALKOT	110	SIRSI-KUMTA1	SIRSI_110	6:55	11:53	4:58	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
261	6-Jun-19	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	4:42	4:54	0:12	HAND TRIPPED
262	6-Jun-19	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	4:54	11:49	6:55	LINE FAULT
263	6-Jun-19	BAGALKOT	110	PG HUNSHYAL-MUDALAGI	MUDALAGI_110	13:10	14:18	1:08	LINE CLEAR AVAILED
264	6-Jun-19	BAGALKOT	110	110/11KV,HV2	NAVANAGAR_110	23:03	23:25	0:22	LINE CLEAR AVAILED
265	6-Jun-19	BAGALKOT	110	BALAJI SUGAR-MUDDEBIHAL	MUDDEBIHAL_110	12:00	20:17	8:17	LINE CLEAR AVAILED
266	6-Jun-19	BAGALKOT	110	KNMSLR-MUDDEBIHAL	MUDDEBIHAL_110	10:45	19:58	9:13	LINE CLEAR AVAILED
267	6-Jun-19	BAGALKOT	110	BAGEWADI1&2-MAMADAPUR	MAMADAPUR_110	11:55	20:04	8:09	LINE CLEAR AVAILED
268	6-Jun-19	BAGALKOT	110	MAMADAPUR-BABALESHWAR	BABALESHWAR_110	11:55	19:50	7:55	LINE CLEAR AVAILED
269	6-Jun-19	BAGALKOT	110	MAMADAPUR-SHIRBUR	SHIRBUR_110	11:55	19:52	7:57	LINE CLEAR AVAILED
270	6-Jun-19	BAGALKOT	110	BLGM_SLR-MAMADAPUR	MAMADAPUR(B)_110	12:59	19:50	6:51	LINE CLEAR AVAILED
271	6-Jun-19	BAGALKOT	110	TODALBAGI-MAMADAPUR	MAMADAPUR(B)_110	9:10	11:55	2:45	LINE CLEAR AVAILED
272	6-Jun-19	BAGALKOT	110	TODALBAGI-MAMADAPUR	MAMADAPUR(B)_110	20:04	23:59	3:55	LINE CLEAR AVAILED
273	6-Jun-19	BAGALKOT	110	MAHALINGAPUR-RABKAVI	RABAKAVI_110	16:01	16:45	0:44	LINE CLEAR AVAILED
274	6-Jun-19	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	12:52	16:40	3:48	LINE CLEAR AVAILED
275	6-Jun-19	BAGALKOT	110	110/33KV,HV3	LOKAPUR_110	3:21	5:21	2:00	TRANSFORMER FAULT
276	6-Jun-19	BAGALKOT	220	KUDUCHI-CHIKKODI	KUDUCHI_220	9:28	9:57	0:29	LINE FAULT
277	6-Jun-19	BAGALKOT	220	KUDUCHI-CHIKKODI	KUDUCHI_220	15:28	15:32	0:04	HAND TRIPPED
278	6-Jun-19	BAGALKOT	110	GAMESHA-KULIGOD	KULIGOD_110	13:08	14:31	1:23	LINE CLEAR AVAILED
279	6-Jun-19	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	23:00	23:10	0:10	TRANSFORMER FAULT
280	6-Jun-19	BAGALKOT	110	INDI 220-INDI	INDI_110	13:39	14:22	0:43	LINE CLEAR AVAILED
281	6-Jun-19	BAGALKOT	110	110/11KV,HV3	INDI_110	13:39	14:22	0:43	TRANSFORMER FAULT
282	6-Jun-19	BAGALKOT	220	KARDA 2-KARWAR	KARWAR_220	4:18	23:59	19:41	LINE FAULT
283	6-Jun-19	BAGALKOT	110	110/33KV,HV3	TILUVALLI_110,KALAKERI_33,KNML_33,SHES AGIRI_33	7:40	9:45	2:05	TRANSFORMER FAULT
284	6-Jun-19	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110	4:44	5:01	0:17	LINE FAULT
285	6-Jun-19	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	22:17	23:24	1:07	LINE FAULT
286	6-Jun-19	BENGALURU	66	HV1	ABBIGERE	11:58	12:11	0:12	LINE CLEAR AVAILED
287	6-Jun-19	BENGALURU	66	HV1	AMARJYOTHI	6:53	6:59	0:05	LOAD CHANGE OVER
288	6-Jun-19	BENGALURU	66	INFOSY	ELECTRONIC CIT	7:42	7:47	0:04	MAIN SUPPLY FAILURE
289	6-Jun-19	BENGALURU	66	HV1	EPIP 220	13:52	14:15	0:22	LINE CLEAR AVAILED
290	6-Jun-19	BENGALURU	66	HV1	HEBBAL 220	21:49	22:25	0:35	MAIN SUPPLY FAILURE
291	6-Jun-19	BENGALURU	66	HV2	HEBBAL 220	21:49	22:25	0:35	MAIN SUPPLY FAILURE
292	6-Jun-19	BENGALURU	66	HV3	HEBBAL 220	21:49	22:25	0:35	MAIN SUPPLY FAILURE
293	6-Jun-19	BENGALURU	220	HV1	HEBBAL 220	21:50	22:13	0:22	MAIN SUPPLY FAILURE
294	6-Jun-19	BENGALURU	220	HV2	HEBBAL 220	21:50	22:13	0:23	MAIN SUPPLY FAILURE
295	6-Jun-19	BENGALURU	66	HV1	MEI LAYOUT	12:50	12:53	0:03	LINE CLEAR AVAILED
296	6-Jun-19	BENGALURU	66	HV1	ATTUR YELAHANKA	6:19	6:51	0:32	TRANSFORMER FAULT
297	6-Jun-19	BENGALURU	66	HEBBAL 220 - C STATION 1	C STATION	21:49	22:15	0:25	MAIN SUPPLY FAILURE
298	6-Jun-19	BENGALURU	66	HEBBAL 220 - C STATION 2	C STATION	21:49	22:15	0:26	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
299	6-Jun-19	BENGALURU	66	HEBBAL 220 - IISC	IISC	21:49	22:32	0:43	MAIN SUPPLY FAILURE
300	6-Jun-19	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	21:49	22:25	0:35	MAIN SUPPLY FAILURE
301	6-Jun-19	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	21:49	22:25	0:35	MAIN SUPPLY FAILURE
302	6-Jun-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	22:18	22:51	0:33	LINE FAULT
303	6-Jun-19	BENGALURU	220	HOODY 220 - HEBBAL 220	HEBBAL 220	21:35	22:12	0:36	LINE FAULT
304	6-Jun-19	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	7:35	7:40	0:05	LOAD CHANGEOVER
305	6-Jun-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	7:31	7:40	0:08	LOAD CHANGEOVER
306	6-Jun-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	7:31	7:40	0:08	LOAD CHANGEOVER
307	6-Jun-19	BENGALURU	66	CHINTAMANI 220 -NANDIGANAHALLI	NANDIGANAHALLI	7:31	7:40	0:08	LOAD CHANGEOVER
308	6-Jun-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	22:32	22:40	0:08	LINE FAULT
309	6-Jun-19	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	11:31	13:05	1:33	LINE CLEAR AVAILED
310	6-Jun-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	11:35	13:04	1:29	LINE CLEAR AVAILED
311	6-Jun-19	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	23:43	23:51	0:08	LINE FAULT
312	6-Jun-19	BENGALURU	66	HV1	KONADASAPURA	21:46	22:08	0:21	TRANSFORMER FAULT
313	6-Jun-19	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	4:05	4:20	0:15	LINE FAULT
314	6-Jun-19	BENGALURU	66	HV1	KYALANUR	4:05	4:25	0:20	TRANSFORMER FAULT
315	6-Jun-19	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	4:26	4:40	0:14	LINE FAULT
316	6-Jun-19	BENGALURU	66	HV1	KYALANUR	4:26	4:55	0:29	TRANSFORMER FAULT
317	6-Jun-19	BENGALURU	220	HV1	MALUR 220	7:35	8:00	0:25	LOAD CHANGEOVER
318	6-Jun-19	BENGALURU	220	HV2	MALUR 220	7:35	7:49	0:14	LOAD CHANGEOVER
319	6-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	7:35	7:54	0:19	LOAD CHANGEOVER
320	6-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	7:35	8:04	0:29	LOAD CHANGEOVER
321	6-Jun-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	7:35	8:03	0:28	LOAD CHANGEOVER
322	6-Jun-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	7:35	8:02	0:27	LOAD CHANGEOVER
323	6-Jun-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	7:35	7:50	0:15	LOAD CHANGEOVER
324	6-Jun-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	7:35	7:53	0:18	LOAD CHANGEOVER
325	6-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	18:34	18:53	0:19	LINE FAULT
326	6-Jun-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	18:44	18:55	0:11	LINE FAULT
327	6-Jun-19	BENGALURU	66	TG HALLI - BYADRAHALLI	TG HALLI	10:35	10:50	0:15	LOAD CHANGEOVER
328	6-Jun-19	BENGALURU	66	YELAHANKA 220 - LINE 7	KANASWADI	21:25	22:21	0:55	LINE FAULT
329	6-Jun-19	BENGALURU	66	YELAHANKA 220 - LINE 7	KANASWADI	22:21	22:30	0:09	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
330	6-Jun-19	BENGALURU	66	VIDHURASHWATHA - BAGEPALLI	BAGEPALLI, GUNDLU KOTTUR	17:00	17:15	0:15	LINE FAULT
331	6-Jun-19	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	7:42	7:46	0:04	LOAD CHANGEOVER
332	6-Jun-19	GULBARGA	220	LINGAPUR-JVSL2	JINDAL_IPP	10:00	14:37	4:37	LINE CLEAR AVAILED
333	6-Jun-19	GULBARGA	220	SINDHANOOR-LINGASUGUR	SIDHANOOR_220	3:46	4:12	0:26	LINE FAULT
334	6-Jun-19	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	20:01	23:59	3:58	LINE FAULT
335	6-Jun-19	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	3:21	10:40	7:19	LINE FAULT
336	6-Jun-19	GULBARGA	110	HATTI-GAMESHA_IPP	HATTI_110	3:21	3:25	0:04	LINE FAULT
337	6-Jun-19	GULBARGA	110	PDHALLI-BASAI_IPP	PD_HALLI_110	5:45	6:06	0:21	LINE FAULT
338	6-Jun-19	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	10:55	11:46	0:51	MAIN SUPPLY FAILURE
339	6-Jun-19	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGAR_IPP	1:00	1:05	0:05	LINE FAULT
340	6-Jun-19	GULBARGA	110	SHAHPUR-SHAHPUR2	SHAHPUR_110	10:50	12:58	2:08	LINE CLEAR AVAILED
341	6-Jun-19	GULBARGA	110	BETAGERA-KESHAVCEMENTS	BETAGERA_110	5:49	6:40	0:51	LINE FAULT
342	6-Jun-19	GULBARGA	110	SINDHANOOR220-PGLR_WIND_IPP	SIDHANOOR_220	23:55	23:59	0:04	LINE FAULT
343	6-Jun-19	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGWAT_110,VA LKAMDINNI_110	21:19	23:59	2:40	LINE FAULT
344	6-Jun-19	GULBARGA	110	SINDHANOOR220-RAICHUR2	MANVI_110, MADALAPURA_110	18:15	18:30	0:15	LINE FAULT
345	6-Jun-19	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	MUKUNDA_110, KAMPLI_GLB_110, BTPS_WATERWORKS	18:56	19:11	0:15	LINE FAULT
346	6-Jun-19	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	MUKUNDA_110, KAMPLI_GLB_110, BTPS_WATERWORKS	21:53	22:22	0:29	LINE FAULT
347	6-Jun-19	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	SINDHANOR_110	19:20	19:35	0:15	LINE FAULT
348	6-Jun-19	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	SINDHANOR_110	20:53	21:53	1:00	LINE FAULT
349	6-Jun-19	GULBARGA	66	ITTAGI-KUDLIGI2	CJHALLI_66,GUDEKOTE_66,HOSAHALLI_66,B ANAVEKAL_66,CHORNOOR_66	1:10	23:59	22:49	LINE FAULT
350	6-Jun-19	GULBARGA	66	ITTAGI-SUZLON1,2, HADAGALI1,RENEWSOLAR1,2,CLEANS OLAR1,2	ITTAGI_220,HIREHADAGALI_66	1:23	2:18	0:55	HAND TRIPPED
351	6-Jun-19	GULBARGA	66	ITTAGI-RENWSLR2	ITTAGI_220	10:24	10:31	0:07	LINE CLEAR AVAILED
352	6-Jun-19	GULBARGA	66	BANAVEKAL-SLRYS	BANAVEKAL_66	10:50	14:59	4:09	LINE CLEAR AVAILED
353	6-Jun-19	GULBARGA	66	BANAVEKAL-SLRYS	BANAVEKAL_66	15:05	23:59	8:54	LINE CLEAR AVAILED
354	6-Jun-19	GULBARGA	66	HV1	HAMPASAGAR_66	12:25	12:30	0:05	TRANSFORMER FAULT
355	6-Jun-19	GULBARGA	66	HV1	HAMPASAGAR_66	12:48	12:54	0:06	TRANSFORMER FAULT
356	6-Jun-19	GULBARGA	66	MUNIRABAD-HANASI	HANASI_66	1:05	3:08	2:03	LINE CLEAR AVAILED
357	6-Jun-19	GULBARGA	66	KUDILIGI-HANASI	HANASI_66	8:45	8:58	0:13	LINE CLEAR AVAILED
358	6-Jun-19	GULBARGA	66	KOTTUR-BENNEHALLI	KOTTUR_66	1:15	2:40	1:25	MAIN SUPPLY FAILURE
359	6-Jun-19	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	0:00	0:32	0:32	LINE FAULT
360	6-Jun-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	9:22	9:22	LINE CLEAR AVAILED
361	6-Jun-19	HASSAN	220	GER SOPA-TALGUPA1	gerusoppa_gen	12:27	14:40	2:13	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
362	6-Jun-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	22:22	23:59	1:37	LINE FAULT
363	6-Jun-19	HASSAN	220	KEMAR-BAJPE1	KEMAR_220	10:01	18:52	8:51	LINE CLEAR AVAILED
364	6-Jun-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	10:58	12:10	1:12	LINE CLEAR AVAILED
365	6-Jun-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	1:51	2:18	0:27	LINE FAULT
366	6-Jun-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSSHM_220	12:27	14:40	2:13	LINE FAULT
367	6-Jun-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSSHM_220	22:22	23:59	1:37	LINE FAULT
368	6-Jun-19	HASSAN	220	MRSSHM-SHARAVATHY3	MRSSHM_220	10:55	12:27	1:32	LINE CLEAR AVAILED
369	6-Jun-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	10:01	18:52	8:51	NFBC ISSUED
370	6-Jun-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	10:58	12:11	1:13	NFBC ISSUED
371	6-Jun-19	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	10:55	12:27	1:32	NFBC ISSUED
372	6-Jun-19	HASSAN	110	HV1	BAIKAMPADY_110	13:39	14:03	0:24	LINE CLEAR AVAILED
373	6-Jun-19	HASSAN	110	BANTWAKAVOOR	BANTWAL_110	0:13	1:26	1:13	LINE FAULT
374	6-Jun-19	HASSAN	110	HV1	GURUVAYANAKERE_110	20:19	20:30	0:11	TRANSFORMER FAULT
375	6-Jun-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	1:26	2:18	0:52	LINE FAULT
376	6-Jun-19	HASSAN	110	KAVOOR-AMR	KAVOOR_220	0:48	1:26	0:38	LINE FAULT
377	6-Jun-19	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	0:48	1:19	0:31	LINE FAULT
378	6-Jun-19	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	0:48	1:19	0:31	LINE FAULT
379	6-Jun-19	HASSAN	110	HV1	KONAJE_110	0:50	1:27	0:37	MAIN SUPPLY FAILURE
380	6-Jun-19	HASSAN	110	HV2	KONAJE_110	0:50	1:27	0:37	MAIN SUPPLY FAILURE
381	6-Jun-19	HASSAN	110	HV3	KONAJE_110	0:50	1:27	0:37	MAIN SUPPLY FAILURE
382	6-Jun-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	0:27	1:06	0:39	MAIN SUPPLY FAILURE
383	6-Jun-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	5:38	6:05	0:27	LINE FAULT
384	6-Jun-19	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	0:58	1:19	0:21	LINE FAULT
385	6-Jun-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	0:23	0:56	0:33	LINE FAULT
386	6-Jun-19	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	0:33	0:58	0:25	MAIN SUPPLY FAILURE
387	6-Jun-19	HASSAN	66	HV1	BELUR_66	14:27	14:49	0:22	LINE CLEAR AVAILED
388	6-Jun-19	HASSAN	66	HV1	HAGARE_66	8:20	11:39	3:19	TRANSFORMER FAULT
389	6-Jun-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	0:00	18:25	18:25	LINE FAULT
390	6-Jun-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	16:00	16:10	0:10	LINE FAULT
391	6-Jun-19	HASSAN	66	HV1	KANDLI_66	11:51	12:39	0:48	LINE CLEAR AVAILED
392	6-Jun-19	HASSAN	66	SAKALEIPCL1	SAKLESHAPURA_66	7:40	19:20	11:40	LINE CLEAR AVAILED
393	6-Jun-19	HASSAN	66	SAKALEIPCL2	SAKLESHAPURA_66	7:40	19:20	11:40	LINE CLEAR AVAILED
394	6-Jun-19	HASSAN	66	UDDURKO-CCKNDGL	UDDURKOPLU_66	11:49	13:07	1:18	LINE CLEAR AVAILED
395	6-Jun-19	MYSORE	66	HV1	ATTIGULIPURA_66	13:05	13:13	0:08	HAND TRIPPED
396	6-Jun-19	MYSORE	66	CR NAGARA-KABBHALLI	HARVEY_66	4:17	23:59	19:41	LINE FAULT
397	6-Jun-19	MYSORE	66	ELAVALA-HUNSUR	GAVADAGERE_66	4:22	4:34	0:12	LINE FAULT
398	6-Jun-19	MYSORE	66	HV1	HONNALLY_MYS_66	12:03	12:36	0:33	HAND TRIPPED
399	6-Jun-19	MYSORE	66	HOOTAGALLI-ELAVALA	ELAVALA_66	4:23	4:32	0:09	LINE FAULT
400	6-Jun-19	MYSORE	66	HV1	JAKKANAHALLY_66	12:35	13:00	0:24	LINE CLEAR AVAILED
401	6-Jun-19	MYSORE	66	HV2	MADIKERI_66	15:15	17:17	2:02	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
402	6-Jun-19	MYSORE	66	HV1	PANDAVAPURA_66	12:10	15:50	3:39	LINE CLEAR AVAILED
403	6-Jun-19	MYSORE	66	HV2	PANDAVAPURA_66	12:49	15:24	2:34	LINE CLEAR AVAILED
404	6-Jun-19	MYSORE	66	HV2	SATHEGALA_66	11:15	11:54	0:39	LINE CLEAR AVAILED
405	6-Jun-19	MYSORE	66	HV1	SANTHESARAGUR_66	21:21	21:30	0:08	HAND TRIPPED
406	6-Jun-19	MYSORE	66	HV5	SFCSHIVA_66	1:02	8:55	7:53	LINE CLEAR AVAILED
407	6-Jun-19	MYSORE	66	HV2	SUTTUR_66	12:54	15:29	2:34	LINE CLEAR AVAILED
408	6-Jun-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	6:30	6:39	0:09	LINE FAULT
409	6-Jun-19	TUMKUR	220	TR-1(HV SIDE)	ANCHEPALYA_220	11:40	12:46	1:05	LINE CLEAR AVAILED
410	6-Jun-19	TUMKUR	220	TR-2(HV SIDE)	ANCHEPALYA_220	13:29	13:45	0:15	LINE CLEAR AVAILED
411	6-Jun-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	0:08	6:22	6:14	LINE FAULT
412	6-Jun-19	TUMKUR	220	TR-1	MADHUGIRI_220	0:46	6:23	5:36	TRANSFORMER FAULT
413	6-Jun-19	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	11:40	12:47	1:06	LINE CLEAR AVAILED
414	6-Jun-19	TUMKUR	66	TR-2(LV SIDE)	ANCHEPALYA_220	13:29	13:47	0:18	LINE CLEAR AVAILED
415	6-Jun-19	TUMKUR	66	ANCHEPALYA 220KV- KUNIGAL	KUNIGAL_66	13:48	14:12	0:24	LINE CLEAR AVAILED
416	6-Jun-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	1:44	1:53	0:09	LINE FAULT
417	6-Jun-19	TUMKUR	66	TR-1	CHANNAGIRI_66	6:58	7:00	0:02	TRANSFORMER FAULT
418	6-Jun-19	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, CHIKKAJAJUR_66, MAYAKONDA_66, SASALUHALLA_66	11:26	11:57	0:30	LINE FAULT
419	6-Jun-19	TUMKUR	66	TR-2	DAVANAGERE_66	1:24	2:05	0:41	TRANSFORMER FAULT
420	6-Jun-19	TUMKUR	66	TR-2	DAVANAGERE_66	7:18	7:32	0:13	TRANSFORMER FAULT
421	6-Jun-19	TUMKUR	66	TR-2	DAVANAGERE_66	10:00	10:17	0:17	TRANSFORMER FAULT
422	6-Jun-19	TUMKUR	66	DODDASARANGI-BHAKTHARAHALLI 66	BHAKTHARAHALLI_66, THIMMASANDRA_66	6:33	7:23	0:49	LINE FAULT
423	6-Jun-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	13:00	15:32	2:32	LINE CLEAR AVAILED
424	6-Jun-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	0:10	0:20	0:10	HAND TRIPPED
425	6-Jun-19	TUMKUR	66	HIRIYUR 220kv- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	0:12	0:19	0:06	HAND TRIPPED
426	6-Jun-19	TUMKUR	66	HIRIYUR 220kv- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	2:32	3:28	0:55	LINE FAULT
427	6-Jun-19	TUMKUR	66	HIRIYUR 220kv- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	6:23	6:35	0:11	HAND TRIPPED
428	6-Jun-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	0:11	0:20	0:08	HAND TRIPPED
429	6-Jun-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	6:23	6:35	0:11	HAND TRIPPED
430	6-Jun-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	0:11	0:20	0:08	HAND TRIPPED
431	6-Jun-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	6:23	6:35	0:11	HAND TRIPPED
432	6-Jun-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	0:10	0:19	0:08	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
433	6-Jun-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	6:23	6:35	0:12	HAND TRIPPED
434	6-Jun-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	0:49	1:01	0:12	LINE FAULT
435	6-Jun-19	TUMKUR	66	TR-2	KUNIGAL_66	12:41	14:19	1:38	LINE CLEAR AVAILED
436	6-Jun-19	TUMKUR	66	TR-1	MADHUGIRI_220	0:46	6:23	5:36	TRANSFORMER FAULT
437	6-Jun-19	TUMKUR	66	NEELAGUNDA 220kv- HARAPPANAHALLI	HARAPPANAHALLI_66	1:57	3:20	1:23	LINE FAULT
438	6-Jun-19	TUMKUR	66	TR-2	RAMPURA_66	23:07	23:12	0:04	TRANSFORMER FAULT
439	6-Jun-19	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	1:18	7:09	5:50	MAIN SUPPLY FAILURE
440	6-Jun-19	TUMKUR	66	SIRA- KALLAMBELLA	KALLAMBELLA_66	1:19	6:53	5:33	MAIN SUPPLY FAILURE
441	6-Jun-19	TUMKUR	66	SIRA- MADHUGIRI 1	SIRA_66	1:18	6:50	5:31	MAIN SUPPLY FAILURE
442	6-Jun-19	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	1:18	6:52	5:33	MAIN SUPPLY FAILURE
443	7-Jun-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	0:18	0:22	0:04	LINE FAULT
444	7-Jun-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	0:37	23:59	23:22	LINE FAULT
445	7-Jun-19	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	2:09	2:20	0:11	TRANSFORMER FAULT
446	7-Jun-19	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	0:00	15:21	15:21	LINE CLEAR AVAILED
447	7-Jun-19	BAGALKOT	110	110/11KV, HV2	BHUTNAL_110	6:13	7:09	0:56	LINE CLEAR AVAILED
448	7-Jun-19	BAGALKOT	220	HARTI2-BIDNAL	BIDNAL_220	0:15	10:58	10:43	LINE FAULT
449	7-Jun-19	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	11:08	13:11	2:03	LINE CLEAR AVAILED
450	7-Jun-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:00	12:45	12:45	LINE CLEAR AVAILED
451	7-Jun-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	3:03	12:37	9:34	LINE CLEAR AVAILED
452	7-Jun-19	BAGALKOT	110	BAGALKOT220-KERUR	KERUR_110	22:24	23:21	0:57	LINE FAULT
453	7-Jun-19	BAGALKOT	220	GHATAPRABHA-NARENDRA2	GHATAPRABHA_220	17:03	18:44	1:41	LINE FAULT
454	7-Jun-19	BAGALKOT	110	110/11KV, HV2	GOKAK_110	10:09	10:38	0:29	HAND TRIPPED
455	7-Jun-19	BAGALKOT	110	110/33KV,HV2	GULEDGUDD_110& SIRUR_33KV &KAMATAGI_33	0:11	0:17	0:06	TRANSFORMER FAULT
456	7-Jun-19	BAGALKOT	110	110/33KV,HV2	GULEDGUDD_110& SIRUR_33KV &KAMATAGI_33	10:55	10:59	0:04	HAND TRIPPED
457	7-Jun-19	BAGALKOT	110	GMR-HALIYAL	HALIYAL_110	2:12	9:24	7:12	LINE FAULT
458	7-Jun-19	BAGALKOT	220	HAVERI-GUTTUR 1	HAVERI_220	0:00	17:22	17:22	LINE CLEAR AVAILED
459	7-Jun-19	BAGALKOT	220	HAVERI-GUTTUR 2	HAVERI_220	14:34	16:14	1:40	LINE CLEAR AVAILED
460	7-Jun-19	BAGALKOT	110	HUKKERI-HATTARAGI_110	HATTARAGI_110	15:42	15:45	0:03	LINE FAULT
461	7-Jun-19	BAGALKOT	110	BAGEWADI-MUKARTIHAL	MUKARTIHAL_110	11:25	15:25	4:00	LINE FAULT
462	7-Jun-19	BAGALKOT	220	VAJRAMATTI-BAGALKOT2	VAJRAMATTI_220	18:04	23:59	5:55	LINE FAULT
463	7-Jun-19	BAGALKOT	110	SUVARNA SOUDA-MACHE	MACHE_110	16:49	17:26	0:37	LINE FAULT
464	7-Jun-19	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	11:03	13:08	2:05	LINE CLEAR AVAILED
465	7-Jun-19	BAGALKOT	110	HUBLI-KALGHATAGI	HUBLI_220	2:56	11:54	8:58	LINE FAULT
466	7-Jun-19	BAGALKOT	220	SIRSI-SHARAVATHI1	SIRSI_220	2:31	16:40	14:09	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
467	7-Jun-19	BAGALKOT	220	SIRSI-SHARAVATHI2	SIRSI_220	14:25	16:40	2:15	LINE CLEAR AVAILED
468	7-Jun-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	2:46	3:40	0:54	LINE FAULT
469	7-Jun-19	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	2:55	3:37	0:42	LINE FAULT
470	7-Jun-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	3:43	16:32	12:49	LINE FAULT
471	7-Jun-19	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	11:20	13:17	1:57	LINE CLEAR AVAILED
472	7-Jun-19	BAGALKOT	110	SIRSI-KUMTA1	SIRSI_110	2:55	6:19	3:24	LINE FAULT
473	7-Jun-19	BAGALKOT	110	SIRSI-KUMTA1	SIRSI_110	6:19	14:54	8:35	LINE FAULT
474	7-Jun-19	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	2:57	6:19	3:22	LINE CLEAR AVAILED
475	7-Jun-19	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	10:40	14:54	4:14	LINE CLEAR AVAILED
476	7-Jun-19	BAGALKOT	110	JAMKHANDI-SHIROL	SHIROL_110	19:53	23:59	4:06	LINE CLEAR AVAILED
477	7-Jun-19	BAGALKOT	110	MANTUR-SHIROL	SHIROL_110	0:00	19:53	19:53	LINE CLEAR AVAILED
478	7-Jun-19	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	10:38	15:23	4:45	LINE CLEAR AVAILED
479	7-Jun-19	BAGALKOT	110	SATTI-RABKAVI	RABAKAVI_110	12:20	12:41	0:21	LINE CLEAR AVAILED
480	7-Jun-19	BAGALKOT	110	SATTI-RABKAVI	RABAKAVI_110	14:00	14:08	0:08	LINE CLEAR AVAILED
481	7-Jun-19	BAGALKOT	110	110/33KV,HV4	RANEBENNUR_220,KUPELLUR_33KV,RSNG_33KV	17:32	18:00	0:28	TRANSFORMER FAULT
482	7-Jun-19	BAGALKOT	110	110/11KV,HV1	MUNDAGANUR_110	0:33	0:41	0:08	TRANSFORMER FAULT
483	7-Jun-19	BAGALKOT	110	MAHALINGAPUR-RABKAVI	RABAKAVI_110	11:59	14:10	2:11	LINE CLEAR AVAILED
484	7-Jun-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	14:15	14:51	0:36	LINE CLEAR AVAILED
485	7-Jun-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	16:59	18:09	1:10	LINE CLEAR AVAILED
486	7-Jun-19	BAGALKOT	220	220/110KV,HV1&2,LV1	KUDUCHI_220,TERDAL_110,MORAB,_110,YEL LAPARATTI_110,AINAPUR_110,KUDUCHI_110,UGAR KHUD_110	0:09	0:13	0:04	TRANSFORMER FAULT
487	7-Jun-19	BAGALKOT	110	KUDUCHI220-MORAB	MORAB_110	0:00	0:31	0:31	LINE FAULT
488	7-Jun-19	BAGALKOT	110	HUBLI220-KALAGHATAGI	KALAGHATAGI_110	0:51	12:29	11:38	LINE FAULT
489	7-Jun-19	BAGALKOT	110	HUKKERI-HATTARGI	HATTARGI_110	15:42	15:45	0:03	LINE CLEAR AVAILED
490	7-Jun-19	BENGALURU	66	IISC - HEBBAL 220	IISC	21:19	21:24	0:05	LOAD CHANGE OVER
491	7-Jun-19	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	11:52	12:02	0:10	LINE CLEAR AVAILED
492	7-Jun-19	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	15:45	15:46	0:01	LOAD CHANGE OVER
493	7-Jun-19	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	13:00	13:02	0:02	LOAD CHANGE OVER
494	7-Jun-19	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	11:52	12:02	0:10	LINE CLEAR AVAILED
495	7-Jun-19	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	13:08	13:32	0:24	LINE CLEAR AVAILED
496	7-Jun-19	BENGALURU	66	RMV - TATA INSTITUTE (EHT)	TATA INSTITUTE (EHT)	13:09	13:32	0:23	LINE CLEAR AVAILED
497	7-Jun-19	BENGALURU	66	HV1	BANGARPET	15:53	16:23	0:29	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
498	7-Jun-19	BENGALURU	66	CHIKKABALLAPURA I/A - DB PURA 1	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	15:57	16:56	0:58	LINE FAULT
499	7-Jun-19	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	15:57	16:47	0:49	LINE FAULT
500	7-Jun-19	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	15:57	16:47	0:49	LINE FAULT
501	7-Jun-19	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	15:27	15:34	0:07	LINE FAULT
502	7-Jun-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	16:04	16:44	0:40	LINE FAULT
503	7-Jun-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	16:04	16:44	0:40	LINE FAULT
504	7-Jun-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	16:00	17:05	1:05	LINE FAULT
505	7-Jun-19	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	16:14	16:51	0:37	LINE CLEAR AVAILED
506	7-Jun-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	7:18	7:25	0:06	LINE FAULT
507	7-Jun-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	16:12	16:34	0:22	LINE FAULT
508	7-Jun-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	16:13	16:52	0:38	LINE FAULT
509	7-Jun-19	BENGALURU	220	LV2	CHINTAMANI 220 (NO LOAD AFFECTED)	16:13	16:44	0:30	TRANSFORMER FAULT
510	7-Jun-19	BENGALURU	66	HV1	KIADB DB PURA 220	21:17	21:43	0:25	TRANSFORMER FAULT
511	7-Jun-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	14:57	15:20	0:23	LINE FAULT
512	7-Jun-19	BENGALURU	66	HV2	KODIHALLI KANAKAPURA	12:12	13:59	1:47	LINE CLEAR AVAILED
513	7-Jun-19	BENGALURU	66	HV1	SIDLAGHATTA	15:39	17:03	1:24	TRANSFORMER FAULT
514	7-Jun-19	BENGALURU	66	HV1	SOMAYAJANAHALLI	17:04	17:27	0:22	TRANSFORMER FAULT
515	7-Jun-19	BENGALURU	66	WELCAST - SRS PEENYA 220	WELCAST	9:39	9:46	0:07	LOAD CHANGEOVER
516	7-Jun-19	BENGALURU	66	WELCAST - ABBIGERE	WELCAST	14:04	14:11	0:07	LOAD CHANGEOVER
517	7-Jun-19	BENGALURU	66	KANASWADI- DB PURA 220	KANASWADI	8:10	8:15	0:05	LOAD CHANGEOVER
518	7-Jun-19	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	9:15	9:20	0:05	LOAD CHANGEOVER
519	7-Jun-19	BENGALURU	66	RAJANKUNTE - YELAHANKA 220	RAJANKUNTE	0:39	0:45	0:05	LOAD CHANGEOVER
520	7-Jun-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	20:00	20:23	0:23	LINE FAULT
521	7-Jun-19	BENGALURU	66	PLATINUM CITY - DG 4	PLATINUM CITY	14:10	14:15	0:05	LOAD CHANGEOVER
522	7-Jun-19	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	7:50	7:55	0:05	LOAD CHANGEOVER
523	7-Jun-19	BENGALURU	66	HV2	ABBIGERE	7:42	7:52	0:09	TRANSFORMER FAULT
524	7-Jun-19	BENGALURU	66	HV1	BIDADI 220	11:49	12:16	0:26	TRANSFORMER FAULT
525	7-Jun-19	BENGALURU	66	HV1	KORMANGALA	13:03	13:34	0:30	LINE CLEAR AVAILED
526	7-Jun-19	BENGALURU	66	HV2	VRISHBHAVATHI 220	11:49	12:50	1:01	LOAD CHANGEOVER
527	7-Jun-19	BENGALURU	66	HV1	RMV	10:01	10:04	0:03	LINE CLEAR AVAILED
528	7-Jun-19	BENGALURU	66	HV2	RMV	11:00	13:32	2:32	LINE CLEAR AVAILED
529	7-Jun-19	GULBARGA	400	JVSWL400-GUTTUR	GUTTUR_400	0:00	18:27	18:27	LINE FAULT
530	7-Jun-19	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	0:00	3:12	3:12	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
531	7-Jun-19	GULBARGA	110	SINDHANOOR220-PGLR_WIND_IPP	SIDHANOOR_220	0:00	0:13	0:13	LINE FAULT
532	7-Jun-19	GULBARGA	110	HV3	YELBURGA_110	0:36	0:41	0:05	HAND TRIPPED
533	7-Jun-19	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGAR_IPP	1:07	1:25	0:18	LINE FAULT
534	7-Jun-19	GULBARGA	110	RAICHUR-SHAHPUR1	GABUR_110, DEODURGA_110	10:50	11:36	0:46	LINE CLEAR AVAILED
535	7-Jun-19	GULBARGA	110	HALBURGA-ACME_SOLAR_IPP	HALBARGA_220	8:02	8:07	0:05	LINE FAULT
536	7-Jun-19	GULBARGA	110	HALBURGA-HALLIKHED	HALIKHED_110	10:08	10:12	0:04	LINE FAULT
537	7-Jun-19	GULBARGA	110	HV3	BEVOOR_110	15:00	15:51	0:51	LINE CLEAR AVAILED
538	7-Jun-19	GULBARGA	110	LV1	SHAHPUR_220	16:54	17:03	0:09	LINE CLEAR AVAILED
539	7-Jun-19	GULBARGA	110	ALIPUR-BELLARYNORTH	BELLARYNORTH_110,SOMASAMUDRA_110,P D_HALLI_110,MOKA_110,BISIHALLI_110,ACC _IPP	7:30	7:50	0:20	LINE CLEAR AVAILED
540	7-Jun-19	GULBARGA	110	HV1	HAMPASAGAR_66	19:58	20:03	0:05	TRANSFORMER FAULT
541	7-Jun-19	GULBARGA	66	HV2	TAMBRAHALLI_66	0:00	0:10	0:10	TRANSFORMER FAULT
542	7-Jun-19	GULBARGA	66	TAMBRAHALLI-ITTAGI	TAMBRAHALLI_66	12:30	12:35	0:05	LINE FAULT
543	7-Jun-19	GULBARGA	66	LV1	ITTAGI_220	8:05	11:50	3:45	LINE CLEAR AVAILED
544	7-Jun-19	GULBARGA	66	LV2	ITTAGI_220	8:05	10:57	2:52	LINE CLEAR AVAILED
545	7-Jun-19	MYSORE	220	HV1	HOOTAGALLY_220 HUNSUR_66 HOSURGATE_66 ELAVALA_66 GAVADAGERE_66 BANNIKUPPE_66 KHBCOLONY_66 DATTAGALLY_66 BOGADHI_66 BELAGOLA_66	16:15	23:59	7:44	TRANSFORMER FAULT
546	7-Jun-19	MYSORE	220	HV2	HOOTAGALLY_220 HUNSUR_66 HOSURGATE_66 ELAVALA_66 GAVADAGERE_66 BANNIKUPPE_66 KHBCOLONY_66 DATTAGALLY_66 BOGADHI_66 BELAGOLA_66	16:13	16:49	0:36	TRANSFORMER FAULT
547	7-Jun-19	MYSORE	220	HV3	HOOTAGALLY_220 HUNSUR_66 HOSURGATE_66 ELAVALA_66 GAVADAGERE_66 BANNIKUPPE_66 KHBCOLONY_66 DATTAGALLY_66 BOGADHI_66 BELAGOLA_66	16:13	16:52	0:38	TRANSFORMER FAULT
548	7-Jun-19	MYSORE	66	HV1	HOOTAGALLY_220	16:13	16:50	0:37	TRANSFORMER FAULT
549	7-Jun-19	MYSORE	66	HV2	HOOTAGALLY_220	16:13	16:53	0:40	TRANSFORMER FAULT
550	7-Jun-19	MYSORE	66	KR NAGARA-BILIKERE	BILIKERE_66 GVGUDI_66	10:09	16:40	6:30	LINE CLEAR AVAILED
551	7-Jun-19	MYSORE	66	HV3	KUSHALNAGARA_220	17:47	18:04	0:16	TRANSFORMER FAULT
552	7-Jun-19	MYSORE	66	KUSHALANAGARA 220- RAMANATHPURA-1	ALUR SIDDAPUR_66 KANAGAL_66	16:46	17:01	0:15	LINE FAULT
553	7-Jun-19	MYSORE	66	KUSHALANAGARA 220-MERCERA-1	MADIKERI_66	17:20	17:35	0:14	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
554	7-Jun-19	MYSORE	66	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	17:20	17:36	0:15	LINE FAULT
555	7-Jun-19	MYSORE	66	HV1	MYSORESOUTH_66	10:06	17:40	7:34	LINE CLEAR AVAILED
556	7-Jun-19	MYSORE	66	HV2	MYSORESOUTH_66	10:06	17:40	7:34	LINE CLEAR AVAILED
557	7-Jun-19	MYSORE	66	HV1	THANDYA_66	10:00	17:55	7:54	LINE CLEAR AVAILED
558	7-Jun-19	MYSORE	66	HV2	THANDYA_66	10:00	17:55	7:54	LINE CLEAR AVAILED
559	7-Jun-19	TUMKUR	220	TR-2	ANCHEPALYA_220	13:06	14:34	1:27	LINE CLEAR AVAILED
560	7-Jun-19	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	10:03	12:18	2:14	LINE CLEAR AVAILED
561	7-Jun-19	TUMKUR	110	TR-2	KBCROSS_220	2:45	9:52	7:06	TRANSFORMER FAULT
562	7-Jun-19	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	12:01	12:13	0:12	LINE FAULT
563	7-Jun-19	TUMKUR	66	TR-2(LV SIDE)	ANCHEPALYA_220	13:06	14:37	1:30	LINE CLEAR AVAILED
564	7-Jun-19	TUMKUR	66	TR-2	BRAHMASANDRA_66	15:19	16:33	1:13	LINE CLEAR AVAILED
565	7-Jun-19	TUMKUR	66	TR-1 & TR-2	CHANNAGIRI_66	18:02	18:48	0:46	HAND TRIPPED
566	7-Jun-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:39	11:51	0:11	LINE FAULT
567	7-Jun-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	9:51	9:56	0:04	TRANSFORMER FAULT
568	7-Jun-19	TUMKUR	66	TR-1	HALUVAGALU_66	11:05	16:46	5:40	LINE CLEAR AVAILED
569	7-Jun-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	10:42	17:53	7:10	LINE CLEAR AVAILED
570	7-Jun-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	10:42	17:53	7:10	LINE CLEAR AVAILED
571	7-Jun-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	16:58	17:57	0:59	LINE FAULT
572	7-Jun-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	0:52	0:58	0:05	LINE FAULT
573	7-Jun-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	17:19	18:01	0:42	LINE FAULT
574	7-Jun-19	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	15:51	20:23	4:32	LINE CLEAR AVAILED
575	7-Jun-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:57	13:44	1:46	LINE FAULT
576	7-Jun-19	TUMKUR	66	TR-1	MADHUGIRI_220	0:51	9:48	8:57	LINE CLEAR AVAILED
577	8-Jun-19	BAGALKOT	110	ATHANI220-HALIYAL LIS	HALIYAL LIS_110	0:38	1:10	0:32	LINE FAULT
578	8-Jun-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	0:00	21:18	21:18	LINE CLEAR AVAILED
579	8-Jun-19	BAGALKOT	220	BAGLKOT-VAJRAMATTI 1	BAGALKOT_220	8:20	10:15	1:55	LINE CLEAR AVAILED
580	8-Jun-19	BAGALKOT	110	BAGALKOT220-BAGALKOT 2	BAGALKOT_110	0:53	1:12	0:19	LINE FAULT
581	8-Jun-19	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	14:28	14:38	0:10	HAND TRIPPED
582	8-Jun-19	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	2:52	3:02	0:10	LINE FAULT
583	8-Jun-19	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	6:46	7:04	0:18	LINE FAULT
584	8-Jun-19	BAGALKOT	110	110/11KV,HV2	BHUTANAL_110	4:44	4:48	0:04	TRANSFORMER FAULT
585	8-Jun-19	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	0:25	0:42	0:17	LINE FAULT
586	8-Jun-19	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	1:27	5:10	3:43	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
587	8-Jun-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	1:47	5:11	3:24	LINE CLEAR AVAILED
588	8-Jun-19	BAGALKOT	110	110/11KV,HV2A	JAMAKHANDI_110	8:10	8:56	0:46	HAND TRIPPED
589	8-Jun-19	BAGALKOT	110	110/11KV,HV2	MATTIHAL_110	1:25	1:34	0:09	TRANSFORMER FAULT
590	8-Jun-19	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	0:12	0:46	0:34	TRANSFORMER FAULT
591	8-Jun-19	BAGALKOT	110	110/33KV,HV2	SAVANUR_110,HULAGUR_33	21:46	22:05	0:19	TRANSFORMER FAULT
592	8-Jun-19	BAGALKOT	110	110/33KV,HV2	SADALAGA_110BHOJ_33	11:16	17:10	5:54	LINE CLEAR AVAILED
593	8-Jun-19	BAGALKOT	110	110/33KV,HV4	RANEENNUR_220,RSNG_33,KUPPELUR_33	11:06	11:11	0:05	TRANSFORMER FAULT
594	8-Jun-19	BAGALKOT	110	CHIKKODI-NANADI	NANADI_110	3:00	4:59	1:59	LINE FAULT
595	8-Jun-19	BAGALKOT	220	NARENDRA-AMBEWADI 1	NARENDRA_220	10:15	19:08	8:53	LINE CLEAR AVAILED
596	8-Jun-19	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	2:43	3:05	0:22	MAIN SUPPLY FAILURE
597	8-Jun-19	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	3:30	8:35	5:05	TRANSFORMER FAULT
598	8-Jun-19	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	14:32	15:10	0:38	LINE CLEAR AVAILED
599	8-Jun-19	BENGALURU	66	HV1	VIJAYANAGAR	15:53	17:12	1:19	LINE CLEAR AVAILED
600	8-Jun-19	BENGALURU	66	HV2	VIJAYANAGAR	15:53	17:12	1:19	LINE CLEAR AVAILED
601	8-Jun-19	BENGALURU	66	HV2	VIJAYANAGAR	19:10	19:20	0:10	MAIN SUPPLY FAILURE
602	8-Jun-19	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	15:40	16:03	0:22	MAIN SUPPLY FAILURE
603	8-Jun-19	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	15:40	16:02	0:21	MAIN SUPPLY FAILURE
604	8-Jun-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	15:40	16:02	0:21	MAIN SUPPLY FAILURE
605	8-Jun-19	BENGALURU	66	HV1	HSR LAYOUT 220	15:40	16:02	0:21	MAIN SUPPLY FAILURE
606	8-Jun-19	BENGALURU	66	HV2	HSR LAYOUT 220	15:40	16:02	0:21	MAIN SUPPLY FAILURE
607	8-Jun-19	BENGALURU	66	HV3	HSR LAYOUT 220	15:40	16:02	0:21	MAIN SUPPLY FAILURE
608	8-Jun-19	BENGALURU	220	SOMANAHALLI 220 - HSR LAYOUT 220	HSR LAYOUT 220	15:40	16:02	0:21	LINE FAULT
609	8-Jun-19	BENGALURU	66	ELITE PROMENEDE KHODAYS 220	ELITE PROMENEDE	11:07	11:22	0:15	LOAD CHANGEVER
610	8-Jun-19	BENGALURU	66	ELITE PROMENEDE KHODAYS 220	ELITE PROMENEDE	11:22	12:45	1:23	LOAD CHANGEVER
611	8-Jun-19	BENGALURU	66	ATTIBELE - SARAJAPURA 220	ATTIBELE	20:05	20:37	0:32	LOAD CHANGEVER
612	8-Jun-19	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	23:15	23:20	0:05	LOAD CHANGEVER
613	8-Jun-19	BENGALURU	220	CHINTAMANI 220 - PGCIL 1 & 2	CHINTAMANI 220	12:10	12:22	0:12	MAIN SUPPLY FAILURE
614	8-Jun-19	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66, SM MANGALA	12:10	12:22	0:12	MAIN SUPPLY FAILURE
615	8-Jun-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	12:10	12:22	0:12	MAIN SUPPLY FAILURE
616	8-Jun-19	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	12:10	12:22	0:12	MAIN SUPPLY FAILURE
617	8-Jun-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	12:10	12:22	0:12	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
618	8-Jun-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	12:10	12:22	0:12	MAIN SUPPLY FAILURE
619	8-Jun-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	12:10	12:22	0:12	MAIN SUPPLY FAILURE
620	8-Jun-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	SRINIVASPURA, KODIHALLI	12:10	12:22	0:12	MAIN SUPPLY FAILURE
621	8-Jun-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	12:10	12:22	0:12	MAIN SUPPLY FAILURE
622	8-Jun-19	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	12:10	12:22	0:12	MAIN SUPPLY FAILURE
623	8-Jun-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	19:27	20:00	0:33	LOAD CURTAILMENT
624	8-Jun-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	19:34	20:05	0:31	LOAD CURTAILMENT
625	8-Jun-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	20:00	20:20	0:20	LOAD CURTAILMENT
626	8-Jun-19	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	20:20	20:50	0:30	LOAD CURTAILMENT
627	8-Jun-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	21:30	22:00	0:30	LOAD CURTAILMENT
628	8-Jun-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	20:20	20:50	0:30	LOAD CURTAILMENT
629	8-Jun-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	14:00	14:16	0:15	LINE FAULT
630	8-Jun-19	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	20:14	21:45	1:31	LOAD CURTAILMENT
631	8-Jun-19	BENGALURU	220	KOLAR 220 - PGCIL 1 & 2	KOLAR 220	12:10	12:35	0:25	MAIN SUPPLY FAILURE
632	8-Jun-19	BENGALURU	220	KOLAR 220 - RAILWAYS 1 (EHT)	BANGARPET RAILWAYS (EHT)	12:10	12:35	0:25	MAIN SUPPLY FAILURE
633	8-Jun-19	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	12:10	12:35	0:25	MAIN SUPPLY FAILURE
634	8-Jun-19	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	12:10	12:35	0:25	MAIN SUPPLY FAILURE
635	8-Jun-19	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	12:10	12:35	0:25	MAIN SUPPLY FAILURE
636	8-Jun-19	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	12:10	12:44	0:34	MAIN SUPPLY FAILURE
637	8-Jun-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	12:10	12:44	0:34	MAIN SUPPLY FAILURE
638	8-Jun-19	BENGALURU	66	KOLAR 220 - NARASAPURA	NARASAPURA	12:10	12:42	0:32	MAIN SUPPLY FAILURE
639	8-Jun-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	12:10	12:42	0:32	MAIN SUPPLY FAILURE
640	8-Jun-19	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	12:10	12:44	0:34	MAIN SUPPLY FAILURE
641	8-Jun-19	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	12:10	12:44	0:34	MAIN SUPPLY FAILURE
642	8-Jun-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	12:10	12:43	0:33	MAIN SUPPLY FAILURE
643	8-Jun-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	12:10	12:46	0:36	MAIN SUPPLY FAILURE
644	8-Jun-19	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	12:35	13:28	0:53	LINE CLEAR AVAILED
645	8-Jun-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	22:28	23:08	0:40	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
646	8-Jun-19	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	12:10	12:39	0:29	MAIN SUPPLY FAILURE
647	8-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	12:10	12:45	0:35	MAIN SUPPLY FAILURE
648	8-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	12:10	12:47	0:37	MAIN SUPPLY FAILURE
649	8-Jun-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:10	12:46	0:36	MAIN SUPPLY FAILURE
650	8-Jun-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	12:10	12:48	0:38	MAIN SUPPLY FAILURE
651	8-Jun-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, LAKKUR, DEVANGONDHI	12:10	12:49	0:39	MAIN SUPPLY FAILURE
652	8-Jun-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	12:10	12:42	0:32	MAIN SUPPLY FAILURE
653	8-Jun-19	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	12:10	12:44	0:34	MAIN SUPPLY FAILURE
654	8-Jun-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:10	12:42	0:32	MAIN SUPPLY FAILURE
655	8-Jun-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:10	12:41	0:31	MAIN SUPPLY FAILURE
656	8-Jun-19	BENGALURU	66	GOWRIBIDANUR 220 - DB 2	THONDEBHAVI, MANCHENAHALLI	19:40	20:10	0:30	LOAD CURTAILMENT
657	8-Jun-19	BENGALURU	66	HV2	NAGNATHPURA 220	8:42	8:54	0:12	LINE CLEAR AVAILED
658	8-Jun-19	GULBARGA	400	JSWVL-GUTTUR	GUTTUR_400	12:58	15:34	2:36	LINE FAULT
659	8-Jun-19	GULBARGA	220	SHAHPUR-LINGASUGUR	SHAHPUR_220	2:02	18:22	16:20	LINE FAULT
660	8-Jun-19	GULBARGA	220	ITTAGI-NEELGUNDA	NEELGUNDA_220	4:25	23:59	19:34	LINE FAULT
661	8-Jun-19	GULBARGA	220	RTPS-SEDAM2	SEDAM_220	11:30	23:59	12:29	LINE FAULT
662	8-Jun-19	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	2:03	2:20	0:17	MAIN SUPPLY FAILURE
663	8-Jun-19	GULBARGA	110	HV1	GURGUNTA_110	1:05	1:10	0:05	TRANSFORMER FAULT
664	8-Jun-19	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	4:34	4:36	0:02	LINE FAULT
665	8-Jun-19	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGWAT_110,VA LKAMDINNI_110	14:10	23:59	9:49	LINE CLEAR AVAILED
666	8-Jun-19	GULBARGA	110	KUSTAGI-KANAKGIRI	KANAKGIRI_110	2:40	3:05	0:25	LINE FAULT
667	8-Jun-19	GULBARGA	110	KUSTAGI-YELBURGA	YELBURGA_110	2:40	3:10	0:30	LINE FAULT
668	8-Jun-19	GULBARGA	110	HV1	HANUMASAGAR_110	5:35	6:10	0:35	TRANSFORMER FAULT
669	8-Jun-19	GULBARGA	110	LADHA-SASTHAPUR	LADHA_110	15:30	15:55	0:25	LINE CLEAR AVAILED
670	8-Jun-19	GULBARGA	110	LADHA-SASTHAPUR	LADHA_110	16:30	16:50	0:20	LINE CLEAR AVAILED
671	8-Jun-19	GULBARGA	110	LADHA-SASTHAPUR	LADHA_110	17:15	17:30	0:15	LINE CLEAR AVAILED
672	8-Jun-19	GULBARGA	110	LADHA-RENEWSOLAR_IPP	LADHA_110	17:30	18:05	0:35	LINE CLEAR AVAILED
673	8-Jun-19	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGAR_IPP	2:03	2:22	0:19	LINE FAULT
674	8-Jun-19	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_GLB_110	4:32	4:42	0:10	LINE FAULT
675	8-Jun-19	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGAR_IPP	20:31	20:45	0:14	LINE FAULT
676	8-Jun-19	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADALAPURA_110	3:25	3:35	0:10	LINE FAULT
677	8-Jun-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_GLB_110,BTPS WATER WORKS	4:45	4:57	0:12	LINE FAULT
678	8-Jun-19	GULBARGA	66	HV1	HAMPASAGAR_66	19:58	20:04	0:06	TRANSFORMER FAULT
679	8-Jun-19	MYSORE	66	HV2	ADDIHALLI_66	22:14	22:26	0:12	LOAD CURTAILMENT
680	8-Jun-19	MYSORE	66	HV2	ADDIHALLI_66	22:30	22:35	0:05	LOAD CURTAILMENT
681	8-Jun-19	MYSORE	66	HV2	CHINAKURALI_66	22:14	22:41	0:27	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
682	8-Jun-19	MYSORE	66	HEBBAL-METAGALLY	HEBBAL_66 METAGALLY_66	8:07	17:54	9:47	NFBC ISSUED
683	8-Jun-19	MYSORE	66	HEBBAL-METAGALLY	HEBBAL_66 METAGALLY_66	20:46	20:52	0:05	HAND TRIPPED
684	8-Jun-19	MYSORE	66	HV1	HOOTAGALLY_220	8:54	20:33	11:39	LINE CLEAR AVAILED
685	8-Jun-19	MYSORE	66	HV2	HOOTAGALLY_220	8:54	20:36	11:42	LINE CLEAR AVAILED
686	8-Jun-19	MYSORE	220	HV1	HOOTAGALLY_220	8:55	20:31	11:36	LINE CLEAR AVAILED
687	8-Jun-19	MYSORE	220	HV2	HOOTAGALLY_220	8:54	20:36	11:42	LINE CLEAR AVAILED
688	8-Jun-19	MYSORE	220	HV3	HOOTAGALLY_220	8:41	21:25	12:43	LINE CLEAR AVAILED
689	8-Jun-19	MYSORE	66	HV2	KMDODDI_66	22:15	22:44	0:29	LOAD CURTAILMENT
690	8-Jun-19	MYSORE	66	HV3	KUSHALANAGARA_66	20:10	20:18	0:08	TRANSFORMER FAULT
691	8-Jun-19	MYSORE	66	HV3	KUSHALANAGARA_66	20:19	20:27	0:08	TRANSFORMER FAULT
692	8-Jun-19	MYSORE	66	MADHUVANAHALLI-YELANDURU	MAMBALLI_66 YELANDUR_66	11:41	11:48	0:07	LINE FAULT
693	8-Jun-19	MYSORE	66	HV2	RKNAGARA_66	11:16	11:32	0:15	LINE CLEAR AVAILED
694	8-Jun-19	TUMKUR	220	NEELAGUNDA- ITTAGI	NEELAGUNDA_220	18:02	18:08	0:05	LINE CLEAR AVAILED
695	8-Jun-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	5:48	6:04	0:16	LINE FAULT
696	8-Jun-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	6:02	6:11	0:08	LINE FAULT
697	9-Jun-19	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	6:41	6:44	0:03	TRANSFORMER FAULT
698	9-Jun-19	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	11:37	14:05	2:28	LINE CLEAR AVAILED
699	9-Jun-19	BAGALKOT	110	110/11KV,HV2	KHANAPUR_110	8:16	8:23	0:07	TRANSFORMER FAULT
700	9-Jun-19	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	18:55	21:46	2:51	LINE FAULT
701	9-Jun-19	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	MAHALINGAPUR_220	22:51	23:02	0:11	LINE FAULT
702	9-Jun-19	BAGALKOT	110	110/11KV,HV1	YELLAPARHATTI_110	12:24	13:15	0:51	LINE CLEAR AVAILED
703	9-Jun-19	BAGALKOT	110	110/11KV,HV1	YELLAPARHATTI_110	13:17	13:52	0:35	LINE CLEAR AVAILED
704	9-Jun-19	BAGALKOT	110	110/11KV,HV1	YARAGATTI_110,SHVAPURA_33,CHUNCHANUR_33,BOSCH SOLAR_33	15:35	15:39	0:04	LINE CLEAR AVAILED
705	9-Jun-19	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	15:35	15:39	0:04	LINE CLEAR AVAILED
706	9-Jun-19	BAGALKOT	110	110/11KV,HV3	YARAGATTI_110	15:35	15:43	0:08	LINE CLEAR AVAILED
707	9-Jun-19	BAGALKOT	110	YARAGATTI-KATAKOLA	KATAKOLA_110	21:00	21:02	0:02	HAND TRIPPED
708	9-Jun-19	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	14:15	14:43	0:28	TRANSFORMER FAULT
709	9-Jun-19	BAGALKOT	220	VARJAMATTI-MAHALINGAPUR	VARJAMATTI_220	22:51	23:01	0:10	LINE FAULT
710	9-Jun-19	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	18:39	21:45	3:06	LINE FAULT
711	9-Jun-19	BAGALKOT	110	HUBLI220-TARIHAL 1&2	TARIHAL_110	10:10	14:59	4:49	LINE CLEAR AVAILED
712	9-Jun-19	BAGALKOT	110	SOUDATTI220-MUNAVALLI	MUNAVALLI_110	19:08	20:46	1:38	LINE FAULT
713	9-Jun-19	BAGALKOT	110	SOUDATTI220-YARAGATTI	YARAGATTI_110	19:08	20:48	1:40	LINE FAULT
714	9-Jun-19	BAGALKOT	220	NARENDRA-AMBEWADI 1	NARENDRA_220	9:52	21:18	11:26	LINE CLEAR AVAILED
715	9-Jun-19	BAGALKOT	220	BELGAUM-KANABARGI1&2(NARENDRA 1&2)	BELGAUM_220	9:01	18:02	9:01	LINE CLEAR AVAILED
716	9-Jun-19	BENGALURU	66	SRS PEENYA 220 - WEL CAST	WEL CAST	6:27	6:30	0:03	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
717	9-Jun-19	BENGALURU	66	SRS PEENYA 220 - PLATINUM CITY	PLATIMUM CITY	6:40	6:49	0:09	LOAD CHANGEOVER
718	9-Jun-19	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	6:27	6:30	0:03	LOAD CHANGEOVER
719	9-Jun-19	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	6:31	6:35	0:04	LOAD CHANGEOVER
720	9-Jun-19	BENGALURU	66	HV2	YERANDANAHALLI 220	10:45	10:48	0:03	LOAD CHANGEOVER
721	9-Jun-19	BENGALURU	66	HV1	YERANDANAHALLI 220	19:10	19:50	0:40	TRANSFORMER FAULT
722	9-Jun-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	12:05	12:15	0:10	LOAD CHANGEOVER
723	9-Jun-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	13:38	13:43	0:05	LOAD CHANGEOVER
724	9-Jun-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	17:00	18:32	1:32	LINE CLEAR AVAILED
725	9-Jun-19	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	8:15	8:30	0:15	LINE FAULT
726	9-Jun-19	BENGALURU	66	HV2	MAASTHI	6:24	6:34	0:09	TRANSFORMER FAULT
727	9-Jun-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	6:52	7:01	0:09	LINE FAULT
728	9-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	10:05	18:52	8:47	LINE CLEAR AVAILED
729	9-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	10:05	18:49	8:44	LINE CLEAR AVAILED
730	9-Jun-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	10:05	18:49	8:44	LINE CLEAR AVAILED
731	9-Jun-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	10:05	18:51	8:46	LINE CLEAR AVAILED
732	9-Jun-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	10:05	18:50	8:45	LINE CLEAR AVAILED
733	9-Jun-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	10:05	18:46	8:41	LINE CLEAR AVAILED
734	9-Jun-19	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	10:05	18:42	8:37	LINE CLEAR AVAILED
735	9-Jun-19	BENGALURU	66	HV2	NARASAPURA	22:10	22:18	0:08	TRANSFORMER FAULT
736	9-Jun-19	BENGALURU	66	HV1	SIDDLAGHATTA	16:15	16:23	0:08	TRANSFORMER FAULT
737	9-Jun-19	BENGALURU	66	HV2	DALASNUR	10:39	11:34	0:54	LINE CLEAR AVAILED
738	9-Jun-19	GULBARGA	220	RTPS-SEDAM1	SEDAM_220	15:00	20:00	5:00	LINE CLEAR AVAILED
739	9-Jun-19	GULBARGA	220	RTPS-SEDAM2	SEDAM_220	0:00	20:58	20:58	LINE FAULT
740	9-Jun-19	GULBARGA	220	ITTAGI-NEELGUNDA	NEELGUNDA_220	13:14	17:58	4:44	NFBC ISSUED
741	9-Jun-19	GULBARGA	110	HV1	HANUMASAGAR_110	8:32	10:12	1:40	LINE CLEAR AVAILED
742	9-Jun-19	GULBARGA	110	HV1	GURGUNTA_110	20:35	21:40	1:05	TRANSFORMER FAULT
743	9-Jun-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	17:44	18:00	0:16	LINE FAULT
744	9-Jun-19	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,KAMALAPURA_110,METRI_110	23:28	23:40	0:12	LINE FAULT
745	9-Jun-19	GULBARGA	110	HV2	BELLARYSOUTH_110	9:08	17:50	8:42	LINE CLEAR AVAILED
746	9-Jun-19	GULBARGA	110	HV1	BELLARYSOUTH_110	9:09	17:53	8:44	LINE CLEAR AVAILED
747	9-Jun-19	GULBARGA	110	HV1	KUDITINI_110	23:17	23:31	0:14	TRANSFORMER FAULT
748	9-Jun-19	GULBARGA	110	RAICHUR-SHAHBAD2	GOOGLE_110	2:10	2:22	0:12	LINE FAULT
749	9-Jun-19	GULBARGA	110	RAICHUR-SHAHBAD2	GOOGLE_110	2:47	2:52	0:05	LINE FAULT
750	9-Jun-19	GULBARGA	66	HV1	ITTAGI_220	19:22	19:24	0:02	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
751	9-Jun-19	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENAHALLI_66,GIRIYA PURA_66,TUNGA_BHADRA_IPP,MAGALA_66	18:20	18:25	0:05	LINE FAULT
752	9-Jun-19	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENAHALLI_66,GIRIYA PURA_66,TUNGA_BHADRA_IPP,MAGALA_66	19:08	20:05	0:57	LINE FAULT
753	9-Jun-19	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENAHALLI_66,GIRIYA PURA_66,TUNGA_BHADRA_IPP,MAGALA_66	20:30	20:45	0:15	LINE CLEAR AVAILED
754	9-Jun-19	GULBARGA	66	ITTAGI-KUDLIGI2	CJHALLI_66,GUDEKOTE_66,HOSAHALLI_66,B ANAVEKAL_66,CHORNOOR_66	0:00	16:50	16:50	LINE FAULT
755	9-Jun-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:05	23:59	2:54	LINE CLEAR AVAILED
756	9-Jun-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	16:07	17:01	0:54	LINE FAULT
757	9-Jun-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	16:07	16:27	0:20	LINE FAULT
758	9-Jun-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	16:06	17:02	0:56	LINE FAULT
759	9-Jun-19	HASSAN	220	VARAHI-KEMAR2	VARAHI	16:06	16:25	0:19	LINE FAULT
760	9-Jun-19	HASSAN	220	VARAHI-KEMAR3	VARAHI	1:51	2:18	0:27	LINE FAULT
761	9-Jun-19	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	13:45	13:54	0:09	LINE FAULT
762	9-Jun-19	HASSAN	66	HASSN22-ARAKALGUD2	HASSAN_220	15:45	16:10	0:25	LINE FAULT
763	9-Jun-19	HASSAN	66	MRSSHM-DVG2	MRSSHM_220	10:35	19:20	8:45	LINE CLEAR AVAILED
764	9-Jun-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	18:27	18:38	0:11	LINE FAULT
765	9-Jun-19	HASSAN	66	HV1	MOSALEHOSAHALLY_66	6:10	11:00	4:50	TRANSFORMER FAULT
766	9-Jun-19	HASSAN	66	SAKALE-HANBAL	SAKLESHAPURA_66	16:13	16:25	0:12	LINE FAULT
767	9-Jun-19	HASSAN	66	SAKALE-IPCL1	SAKLESHAPURA_66	7:30	18:32	11:02	LINE CLEAR AVAILED
768	9-Jun-19	HASSAN	66	SAKALEIPCL2	SAKLESHAPURA_66	7:30	18:32	11:02	LINE CLEAR AVAILED
769	9-Jun-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAG_66	11:47	19:31	7:44	LINE CLEAR AVAILED
770	9-Jun-19	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAG_66	10:37	19:22	8:45	NFBC ISSUED
771	9-Jun-19	MYSORE	66	HEBBAL-METAGALLY	HEBBAL_66 METAGALLY_66	10:04	23:59	13:54	LINE CLEAR AVAILED
772	9-Jun-19	MYSORE	66	HEBBAL-METAGALLY	HEBBAL_66 METAGALLY_66	14:20	14:31	0:10	HAND TRIPPED
773	9-Jun-19	MYSORE	220	HOOTAGALLI-HV1	HOOTAGALLY_220	10:37	14:16	3:38	LINE CLEAR AVAILED
774	9-Jun-19	MYSORE	220	HOOTAGALLI-HV2	HOOTAGALLY_220	10:34	14:19	3:44	LINE CLEAR AVAILED
775	9-Jun-19	MYSORE	220	HOOTAGALLI-HV3	HOOTAGALLY_220	10:26	14:30	4:03	LINE CLEAR AVAILED
776	9-Jun-19	MYSORE	66	HV1	HOOTAGALLY_220	10:37	14:17	3:40	LINE CLEAR AVAILED
777	9-Jun-19	MYSORE	66	HV2	HOOTAGALLY_220	10:37	14:18	3:41	LINE CLEAR AVAILED
778	9-Jun-19	MYSORE	66	MAHADESHWARAPURA-JAKKANAHALLY	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 NAGAMANGALA_66	7:05	7:45	0:40	LINE FAULT
779	9-Jun-19	MYSORE	66	MAHADESHWARAPURA-JAKKANAHALLY	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 NAGAMANGALA_66	7:50	7:55	0:05	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
780	9-Jun-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	10:43	10:51	0:07	LINE FAULT
781	9-Jun-19	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	11:52	11:53	0:00	LINE FAULT
782	9-Jun-19	TUMKUR	66	TR-1	MYLANAHALLI_66	19:15	19:32	0:17	LINE CLEAR AVAILED
783	9-Jun-19	TUMKUR	66	THALLAK 220kv -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	20:50	21:35	0:45	HAND TRIPPED
784	10-Jun-19	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	17:53	18:35	0:42	LINE CLEAR AVAILED
785	10-Jun-19	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	12:05	14:05	2:00	NFBC ISSUED
786	10-Jun-19	BAGALKOT	110	GADAG-DAMBAL2	DAMBAL_110	4:56	11:29	6:33	LINE FAULT
787	10-Jun-19	BAGALKOT	110	GHATAPRABHA 220-GHATAPRABHA 2	GHATAPRABHA_110	20:07	20:21	0:14	LINE FAULT
788	10-Jun-19	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	11:50	12:45	0:55	LINE CLEAR AVAILED
789	10-Jun-19	BAGALKOT	110	KARAWAR-ARAGA	ARAGA_110	13:00	23:59	10:59	LINE FAULT
790	10-Jun-19	BAGALKOT	220	220/110KV, HV3&LV3	HUBLI_220	10:21	16:17	5:56	LINE CLEAR AVAILED
791	10-Jun-19	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:00	14:04	2:04	LINE CLEAR AVAILED
792	10-Jun-19	BAGALKOT	110	JAMKHANDI-SHIROL	SHIROL_110	13:52	23:59	10:07	LINE CLEAR AVAILED
793	10-Jun-19	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	8:35	9:43	1:08	LINE CLEAR AVAILED
794	10-Jun-19	BAGALKOT	220	SHARAVATHY1-SIRSI	SIRSI_220	11:09	13:15	2:06	LINE FAULT
795	10-Jun-19	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)-RANEENNUR	RANEENNUR_220	15:01	21:34	6:33	LINE CLEAR AVAILED
796	10-Jun-19	BAGALKOT	110	110/33KV,HV4	RANEENNUR_220, KUPPELUR_33, R.S.NAGAR_33	13:19	13:39	0:20	TRANSFORMER FAULT
797	10-Jun-19	BAGALKOT	110	VIJAYNAGAR SUGARS- MUNDARGI	MUNDARGI_110	4:56	5:17	0:21	LINE FAULT
798	10-Jun-19	BAGALKOT	220	MAHALINGAPUR-NARENDRA1	MAHALINGAPUR_220	18:14	22:14	4:00	LINE CLEAR AVAILED
799	10-Jun-19	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	11:03	13:47	2:44	LINE CLEAR AVAILED
800	10-Jun-19	BAGALKOT	110	110/11KV, HV1	LOKAPUR_110	18:20	18:35	0:15	TRANSFORMER FAULT
801	10-Jun-19	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	14:04	16:22	2:17	LINE CLEAR AVAILED
802	10-Jun-19	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	14:08	16:24	2:16	LINE CLEAR AVAILED
803	10-Jun-19	BENGALURU	66	HV2	BIDADI 220	16:45	17:43	0:57	LINE CLEAR AVAILED
804	10-Jun-19	BENGALURU	66	HV1	MEI LAYOUT	15:01	15:05	0:04	LINE CLEAR AVAILED
805	10-Jun-19	BENGALURU	66	HV1	KHB	1:21	4:01	2:39	LINE CLEAR AVAILED
806	10-Jun-19	BENGALURU	66	HV2	JANGAMAKOTE	20:58	23:19	2:21	TRANSFORMER FAULT
807	10-Jun-19	BENGALURU	66	HV2	KUNDANA	13:05	14:32	1:27	LINE CLEAR AVAILED
808	10-Jun-19	BENGALURU	66	HV1	KYALANUR	13:05	14:55	1:50	LINE CLEAR AVAILED
809	10-Jun-19	BENGALURU	66	HV2	KYALANUR	13:05	14:55	1:50	LINE CLEAR AVAILED
810	10-Jun-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	12:18	12:19	0:01	LINE CLEAR AVAILED
811	10-Jun-19	BENGALURU	66	HV1	BANGARPET	9:20	9:30	0:10	TRANSFORMER FAULT
812	10-Jun-19	GULBARGA	220	BTPSGLINGAPUR	LINGAPUR_220	2:08	3:48	1:40	LINE FAULT
813	10-Jun-19	GULBARGA	220	HV1	ALIPUR_220	16:02	17:15	1:13	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
814	10-Jun-19	GULBARGA	220	HV2	KUSTAGI_220	3:00	3:22	0:22	TRANSFORMER FAULT
815	10-Jun-19	GULBARGA	220	HV2	KUSTAGI_220	9:30	9:40	0:10	TRANSFORMER FAULT
816	10-Jun-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	3:00	3:20	0:20	LINE FAULT
817	10-Jun-19	GULBARGA	110	HV1	GURGUNTA_110	12:05	12:10	0:05	TRANSFORMER FAULT
818	10-Jun-19	GULBARGA	110	HV1	GURGUNTA_110	12:45	12:50	0:05	TRANSFORMER FAULT
819	10-Jun-19	GULBARGA	110	HV1	JANAWADA_110	7:35	7:40	0:05	TRANSFORMER FAULT
820	10-Jun-19	GULBARGA	110	HV2	TAMBRAHALLI_66	7:05	7:14	0:09	TRANSFORMER FAULT
821	10-Jun-19	GULBARGA	110	KUSTAGI-YELBURGA	YELBURGA_110	5:30	5:50	0:20	LINE FAULT
822	10-Jun-19	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI_110	1:28	3:00	1:32	LINE FAULT
823	10-Jun-19	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	5:20	6:12	0:52	MAIN SUPPLY FAILURE
824	10-Jun-19	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	9:30	9:45	0:15	MAIN SUPPLY FAILURE
825	10-Jun-19	GULBARGA	110	SHAKTHI NAGAR-RAICHURBIO	SHAKTINAGAR_110	1:20	1:25	0:05	LINE FAULT
826	10-Jun-19	GULBARGA	110	SHAHPUR-WARDHASOLAR_IPP	SHAHPUR_110	13:47	22:24	8:37	LINE FAULT
827	10-Jun-19	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENAHALLI_66,GIRIYA PURA_66,TUNGA_BHADRA_IPP,MAGALA_66	3:35	3:50	0:15	LINE FAULT
828	10-Jun-19	GULBARGA	66	ITTAGGI-BENNEHALLI	BENNEHALLI_66,KOTTUR_66,UJJANI_66	19:08	19:28	0:20	LINE FAULT
829	10-Jun-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:07	7:17	7:10	LINE CLEAR AVAILED
830	10-Jun-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	7:05	7:05	LINE CLEAR AVAILED
831	10-Jun-19	HASSAN	400	UPCL-KEMAR2	upcl_gen	8:37	23:59	15:22	LINE CLEAR AVAILED
832	10-Jun-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	9:29	13:43	4:14	LINE CLEAR AVAILED
833	10-Jun-19	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	0:00	14:21	14:21	NFBC ISSUED
834	10-Jun-19	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	0:00	14:21	14:21	LINE CLEAR AVAILED
835	10-Jun-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	9:29	13:44	4:15	NFBC ISSUED
836	10-Jun-19	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	11:10	15:43	4:33	LINE CLEAR AVAILED
837	10-Jun-19	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	11:00	15:43	4:43	NFBC ISSUED
838	10-Jun-19	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	13:01	14:30	1:29	LINE CLEAR AVAILED
839	10-Jun-19	HASSAN	110	HV2	KONAJE_110	12:38	13:18	0:40	LINE CLEAR AVAILED
840	10-Jun-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	14:14	16:57	2:43	LINE CLEAR AVAILED
841	10-Jun-19	HASSAN	66	HV1	HOLENARASIPURA_220	12:10	16:50	4:40	LINE CLEAR AVAILED
842	10-Jun-19	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	11:03	13:41	2:38	LINE CLEAR AVAILED
843	10-Jun-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	13:51	14:17	0:26	LINE CLEAR AVAILED
844	10-Jun-19	HASSAN	66	HV1	KANDLI_66	12:10	16:50	4:40	LINE CLEAR AVAILED
845	10-Jun-19	HASSAN	66	HV2	MATTNAVILE_66	6:38	6:43	0:05	TRANSFORMER FAULT
846	10-Jun-19	HASSAN	66	MOSALEH-NPRA	MOSALEHOSAHALLI_66	17:01	18:35	1:34	NFBC ISSUED
847	10-Jun-19	HASSAN	66	HV1	MOSALEHOSAHALLI_66	17:02	18:35	1:33	NFBC ISSUED
848	10-Jun-19	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	12:41	14:14	1:33	LINE CLEAR AVAILED
849	10-Jun-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:16	18:57	10:41	LINE CLEAR AVAILED
850	10-Jun-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	8:16	18:57	10:41	LINE CLEAR AVAILED
851	10-Jun-19	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	18:25	18:40	0:15	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
852	10-Jun-19	MYSORE	66	HV1	KIRUGAVALU_66	16:47	17:45	0:58	LINE CLEAR AVAILED
853	10-Jun-19	MYSORE	220	HV2	MADHUVANAHALLI_220	10:32	18:02	7:30	LINE CLEAR AVAILED
854	10-Jun-19	MYSORE	66	SFC SIVA-HV1	SFCSHIVA_66	14:06	16:32	2:26	LINE CLEAR AVAILED
855	10-Jun-19	MYSORE	66	SFC SIVA-HV2	SFCSHIVA_66	14:06	16:32	2:26	LINE CLEAR AVAILED
856	10-Jun-19	MYSORE	66	SFC SIVA-HV3	SFCSHIVA_66	14:06	16:23	2:17	LINE CLEAR AVAILED
857	10-Jun-19	MYSORE	66	SFC SIVA-HV4	SFCSHIVA_66	14:06	16:32	2:26	LINE CLEAR AVAILED
858	10-Jun-19	MYSORE	66	HV5	SFCSHIVA_66	14:15	16:38	2:23	LINE CLEAR AVAILED
859	10-Jun-19	MYSORE	220	HV2	VAJAMANGALA_220	12:02	15:14	3:11	LINE CLEAR AVAILED
860	10-Jun-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	11:48	15:24	3:35	LINE CLEAR AVAILED
861	10-Jun-19	MYSORE	66	VAJAMANGALA-KADAKOLA 2	AYRALLI_66 MARADIHUNDI_66	11:48	15:19	3:30	LINE CLEAR AVAILED
862	10-Jun-19	MYSORE	66	VAJAMANGALA-MEGHALAPURA	CHIDRAVALLI_66 MEGALAPURA_66 THUMLA_66	11:49	11:54	0:05	HAND TRIPPED
863	10-Jun-19	MYSORE	66	VAJAMANGALA-MEGHALAPURA	CHIDRAVALLI_66 MEGALAPURA_66 THUMLA_66	15:29	15:31	0:02	HAND TRIPPED
864	10-Jun-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	5:41	6:04	0:23	LINE FAULT
865	10-Jun-19	TUMKUR	66	TR-1	BRAHMASANDRA_66	5:44	6:10	0:25	MAIN SUPPLY FAILURE
866	10-Jun-19	TUMKUR	66	TR-2	BRAHMASANDRA_66	5:44	6:10	0:25	MAIN SUPPLY FAILURE
867	10-Jun-19	TUMKUR	66	TR-1	HIRIYUR_66	16:24	16:46	0:21	TRANSFORMER FAULT
868	10-Jun-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	8:57	9:13	0:15	HAND TRIPPED
869	10-Jun-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	12:01	12:16	0:14	HAND TRIPPED
870	10-Jun-19	TUMKUR	66	HIRIYUR 220kv- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	8:57	9:09	0:11	HAND TRIPPED
871	10-Jun-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	8:42	8:50	0:08	HAND TRIPPED
872	10-Jun-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	10:25	11:45	1:19	LINE CLEAR AVAILED
873	10-Jun-19	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	AVNTI_SLR_IPP_66	8:50	9:59	1:09	LINE CLEAR AVAILED
874	10-Jun-19	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	8:50	10:01	1:11	LINE CLEAR AVAILED