

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 22.06.21 to 28.06.21

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	22-Jun-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVALIED
2	22-Jun-21	BAGALKOT	110	110/11KV,HV2	KANABARGI LAYOUT_110	12:28	13:45	1:17	LINE CLEAR AVALIED
3	22-Jun-21	BAGALKOT	110	110/11KV,HV3	TIKOTA_110	11:41	12:29	0:48	LINE CLEAR AVALIED
4	22-Jun-21	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI 110	9:59	18:53	8:54	LINE CLEAR AVALIED
5	22-Jun-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI 220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVALIED
6	22-Jun-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI 220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVALIED
7	22-Jun-21	BAGALKOT	110	ATHANI220-HALIYAL	STATION NOT AFFECTED ATHANI 220	6:03	6:12	0:09	LINE FAULT
8	22-Jun-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI 110	13:19(20.04.2021)			LINE OPEN:LINE CLEAR AVALIED
9	22-Jun-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI 110	9:39(06.04.2021)			LINE OPEN:LINE CLEAR AVALIED
10	22-Jun-21	BAGALKOT	110	CHIKKODI220-GALATAGA(BHOJ)	GALATAGA_110	11:53	12:05	0:12	LINE FAULT
11	22-Jun-21	BAGALKOT	110	HAVERI220-BASAVANAKATTI	STATION NOT AFFECTED BASAVANAKATTI 110	12:22	16:09	3:47	LINE FAULT
12	22-Jun-21	BAGALKOT	110	KADANKOPPA-KAVALWADA	KADANAKOPPA_110	11:58 (21.06.2021)	9:59 (22.06.2021)	22:01 hrs	LINE CHARGED
13	22-Jun-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
14	22-Jun-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B) 110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVALIED
15	22-Jun-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
16	22-Jun-21	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON_110	17:30 (18.06.2021)			LINE OPEN:LINE CLEAR AVALIED
17	22-Jun-21	BAGALKOT	220	220/110KV,HV2	STATION NOT AFFECTED CHIKKODI 220	13:05	13:12	0:07	TRANSFORMER FAULT
18	22-Jun-21	BAGALKOT	220	220/110KV,HV2,LV2	NARENDRA 220	10:21	13:43	3:22	TRANSFORMER FAULT
19	22-Jun-21	BAGALKOT	220	AMBEWADI-NAGJHARI2	STATION NOT AFFECTED AMBEWADI 220	13:40	18:15	4:35	LINE FAULT
20	22-Jun-21	BAGALKOT	220	CHIKKODI220-KUDUCHI2(GHATAPRABHA2)	STATION NOT AFFECTED CHIKKODI 220	13:05	13:09	0:04	LINE FAULT
21	22-Jun-21	BAGALKOT	220	CHIKKODI220-KUDUCHI2(GHATAPRABHA2)	STATION NOT AFFECTED CHIKKODI 220	13:45	13:49	0:04	LINE FAULT
22	22-Jun-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVALIED
23	22-Jun-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
24	22-Jun-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI 220	13:15 (20.06.2021)			LINE OPEN:LINE CLEAR AVALIED
25	22-Jun-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI 220	21:02 (10.06.2021)			LINE OPEN:LINE CLEAR AVALIED
26	22-Jun-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
27	22-Jun-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVALIED
28	22-Jun-21	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	6:46	7:25	0:38	LOAD CURTAILMENT
29	22-Jun-21	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU	6:46	7:26	0:40	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
30	22-Jun-21	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	6:46	7:25	0:38	LOAD CURTAILMENT
31	22-Jun-21	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI	6:30	6:37	0:06	LOAD CURTAILMENT
32	22-Jun-21	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI	6:45	7:28	0:42	LOAD CURTAILMENT
33	22-Jun-21	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	6:46	7:22	0:36	LOAD CURTAILMENT
34	22-Jun-21	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	6:46	7:25	0:39	LOAD CURTAILMENT
35	22-Jun-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	6:46	7:18	0:32	LOAD CURTAILMENT
36	22-Jun-21	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLIC CROSS, YENNIGADALE, CHELUR, CHAKAVELU	6:46	7:19	0:33	LOAD CURTAILMENT
37	22-Jun-21	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	13:36	14:15	0:39	LINE FAULT
38	22-Jun-21	BENGALURU	66	HONNIGANAHALLI - HALAGUR	HONNIGANAHALLI	12:22	12:35	0:13	LOAD CHANGEOVER
39	22-Jun-21	BENGALURU	66	HONNIGANAHALLI - KANAKAPURA 220	HONNIGANAHALLI, HALGUR	8:25	8:35	0:10	LOAD CHANGEOVER
40	22-Jun-21	BENGALURU	66	HV1	NATIONAL COLLEGE	11:40	11:42	0:02	LINE CLEAR AVAILED
41	22-Jun-21	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	2:33	2:45	0:12	TRANSFORMER FAULT
42	22-Jun-21	BENGALURU	66	HV1	HOSKOTE 66	10:37	11:23	0:46	LINE CLEAR AVAILED
43	22-Jun-21	BENGALURU	66	HV1	JIGANI 66	5:34	15:52	10:18	TRANSFORMER FAULT
44	22-Jun-21	BENGALURU	66	HV1	MAGADI 66	11:02	11:36	0:33	LINE CLEAR AVAILED
45	22-Jun-21	BENGALURU	66	HV2	ITI 220	11:10	11:54	0:44	LINE CLEAR AVAILED
46	22-Jun-21	BENGALURU	66	HV2	KHODAYS 220	11:08	11:12	0:04	LOAD CHANGEOVER
47	22-Jun-21	BENGALURU	66	HV2	KHODAYS 220	15:57	16:00	0:03	LOAD CHANGEOVER
48	22-Jun-21	BENGALURU	66	HV2	SHOBHA APARTMENT	15:08	15:20	0:12	LINE CLEAR AVAILED
49	22-Jun-21	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
50	22-Jun-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	7:07	7:11	0:04	LOAD CURTAILMENT
51	22-Jun-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	HALAGURU, DODDALAHALLI, HONNIGANAHALLI	7:12	7:35	0:23	LOAD CURTAILMENT
52	22-Jun-21	BENGALURU	66	MANDIKAL - GOWRIBIDANUR 220	MANDIKAL	10:33	12:33	1:59	LINE CLEAR AVAILED
53	22-Jun-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	8:57	9:00	0:03	LOAD CURTAILMENT
54	22-Jun-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	8:57	9:00	0:03	LOAD CURTAILMENT
55	22-Jun-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13/06/2021)			LINE OPEN:LINE FAULT
56	22-Jun-21	BENGALURU	220	HV1	KANAKAPURA 220	18:25(21/06/2021)	11:26(22/06/2021)	17:01hrs	TRANSFORMER CHARGED
57	22-Jun-21	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	14:30:32(18-6-2021)			LINE OPEN:LINE FAULT
58	22-Jun-21	GULBARGA	66	HV2	TAMBRAHALLI_66	14:51	15:48	0:57	LINE CLEAR AVAILED
59	22-Jun-21	GULBARGA	66	ITTAGI-RENEWSOLAR1_IPP	ITTAGI_220	14:15	14:20	0:05	LINE CLEAR AVAILED
60	22-Jun-21	GULBARGA	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	16:45	17:00	0:15	LINE CLEAR AVAILED
61	22-Jun-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_ 110,DIGGI_110	0:45	0:51	0:06	LINE FAULT
62	22-Jun-21	GULBARGA	110	HV2	HANUMANAL_110	7:15	8:45	1:30	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
63	22-Jun-21	GULBARGA	110	HV2	DEODURGA_110	22:35	22:50	0:15	TRANSFORMER FAULT
64	22-Jun-21	GULBARGA	110	HV2	SINDHANOOR_110	7:58	8:08	0:10	TRANSFORMER FAULT
65	22-Jun-21	GULBARGA	110	HV3	TEKKALKOTE_110	14:56	15:39	0:43	LINE CLEAR AVAILED
66	22-Jun-21	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	5:20	5:26	0:06	LINE FAULT
67	22-Jun-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	11:18	11:28	0:10	LINE FAULT
68	22-Jun-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	11:47	11:57	0:10	LINE FAULT
69	22-Jun-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	20:17	20:23	0:06	LINE FAULT
70	22-Jun-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWAR_110	5:30	5:40	0:10	LINE CLEAR AVAILED
71	22-Jun-21	GULBARGA	110	YELBURGA-TALTSR	YELBURGA_110	20:08	23:57	3:49	LINE CLEAR AVAILED
72	22-Jun-21	GULBARGA	220	BMMISPAT_IPP-ITTAGI	ITTAGI_220	2:10	10:25	8:15	LINE CLEAR AVAILED
73	22-Jun-21	GULBARGA	220	RAICHUR-JURAL1	RAICHUR_220	12:56(22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
74	22-Jun-21	GULBARGA	220	RAICHUR-JURAL2	RAICHUR_220	11:00(22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
75	22-Jun-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	2:34	5:36	3:02	LINE CLEAR AVAILED
76	22-Jun-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	23:05(22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
77	22-Jun-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	0:04(19.06.2021)	9:14(22.06.2021)	81:00HRS	LINE CHARGED
78	22-Jun-21	GULBARGA	400	RTPS-MUNIRABAD(GD HALLI)	RTPS_400	00:53(19.06.2021)			LINE OPEN:LINE FAULT
79	22-Jun-21	HASSAN	66	CRPATNA-SBELAGOLA	CRPATNA_220	12:14	12:23	0:09	LINE FAULT
80	22-Jun-21	HASSAN	66	HV1	YESLUR_66	10:44	13:06	2:22	LINE CLEAR AVAILED
81	22-Jun-21	HASSAN	66	HV2	TAVARECHATANAHALLY_66	8:32	9:13	0:41	TRANSFORMER FAULT
82	22-Jun-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	1:45	2:00	0:15	LINE FAULT
83	22-Jun-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	2:00	2:15	0:15	LINE FAULT
84	22-Jun-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	2:15	8:51	6:36	LINE FAULT
85	22-Jun-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:51	9:02	0:11	LINE FAULT
86	22-Jun-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	9:02	12:29	3:27	LINE FAULT
87	22-Jun-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	13:03	13:06	0:03	HAND TRIPPED
88	22-Jun-21	HASSAN	110	HV1	SHIKARIPURA_110	15:20 (22.06.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
89	22-Jun-21	HASSAN	110	HV1	HOSANGADI_110	10:33	17:09	6:36	LINE CLEAR AVAILED
90	22-Jun-21	HASSAN	110	HV1	SHIKARIPURA_110	10:31	10:51	0:20	LINE CLEAR AVAILED
91	22-Jun-21	HASSAN	110	HV2	KADUR_220	16:19	17:03	0:44	TRANSFORMER FAULT
92	22-Jun-21	HASSAN	110	HV2	MANIPAL_110	12:12	15:53	3:41	LINE CLEAR AVAILED
93	22-Jun-21	HASSAN	110	HV3	MANIPAL_110	9:48	13:38	3:50	LINE CLEAR AVAILED
94	22-Jun-21	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN:LINE CLEAR AVAILED
95	22-Jun-21	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN:LINE CLEAR AVAILED
96	22-Jun-21	HASSAN	110	LV1	PUTTUR_220	9:22	16:50	7:28	LINE CLEAR AVAILED
97	22-Jun-21	HASSAN	110	LV1	SHIRALKOPPA_220	10:27	18:21	7:54	LINE CLEAR AVAILED
98	22-Jun-21	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	10:33	12:49	2:16	LINE CLEAR AVAILED
99	22-Jun-21	HASSAN	110	NERALA-TEREKERE	NERALAKERE_110	12:44	13:42	0:58	LINE CLEAR AVAILED
100	22-Jun-21	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:14	13:12	2:58	LINE CLEAR AVAILED
101	22-Jun-21	HASSAN	220	HV1	PUTTUR_220	9:23	16:50	7:27	LINE CLEAR AVAILED
102	22-Jun-21	HASSAN	220	HV1	SHIRALKOPPA_220	10:30	18:20	7:50	LINE CLEAR AVAILED
103	22-Jun-21	MYSURU	66	HANNUR-AJJIPURA	HANNUR_66 BANDALLI_66 AJJIPURA_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	16:22	16:41	0:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
104	22-Jun-21	MYSURU	66	HANNUR-MADHUVANAHALLI 1	HANNUR_66 BANDALLI_66 AJJIPURA_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	16:22	16:41	0:18	LINE FAULT
105	22-Jun-21	MYSURU	66	HANNUR-MADHUVANAHALLI 2	HANNUR_66 BANDALLI_66 AJJIPURA_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	16:22	16:41	0:18	LINE FAULT
106	22-Jun-21	MYSURU	66	HV1	DODDABYADARAHALLI_66	10:20	11:08	0:48	LINE CLEAR AVAILED
107	22-Jun-21	MYSURU	66	HV1	KADAKOLA_66	10:04	17:45	7:40	LINE CLEAR AVAILED
108	22-Jun-21	MYSURU	66	HV1	MADDUR_66	8:54	9:06	0:12	HAND TRIPPED
109	22-Jun-21	MYSURU	66	HV2	KADAKOLA_66	10:04	14:01	3:56	LINE CLEAR AVAILED
110	22-Jun-21	MYSURU	66	HV3	TUBINAKERE_66	12:45	13:35	0:50	LINE CLEAR AVAILED
111	22-Jun-21	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
112	22-Jun-21	MYSURU	66	KUSHALNAGARA 220-HARANGI	NO STATIONS EFFECTED	10:32	12:59	2:26	LINE CLEAR AVAILED
113	22-Jun-21	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
114	22-Jun-21	MYSURU	66	TUBINKERE-ARAKERE	GAMANAHALLY_66 ARAKERE_66 TARIPURA_66	18:23	18:30	0:07	LINE FAULT
115	22-Jun-21	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	6:43	7:17	0:34	LOAD CURTAILMENT
116	22-Jun-21	TUMKUR	66	ANCHEPALYA 220KV- AMRUTHUR	AMRUTHUR_66, SANTEMNAVATTUR_66,YEDAVANI_66	6:43	7:17	0:34	LOAD CURTAILMENT
117	22-Jun-21	TUMKUR	66	ANCHEPALYA 220KV- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66	16:42	17:11	0:29	LOAD CURTAILMENT
118	22-Jun-21	TUMKUR	66	ANCHEPALYA 220KV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	6:43	7:03	0:19	LOAD CURTAILMENT
119	22-Jun-21	TUMKUR	66	ANCHEPALYA 220KV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	6:43	6:50	0:07	LOAD CURTAILMENT
120	22-Jun-21	TUMKUR	66	ANCHEPALYA 66KV-HEBBUR66	HEBBUR_66,THIMMASANDRA_66, HONNENAHALLI_66	6:34	6:40	0:06	LOAD CURTAILMENT
121	22-Jun-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	6:30	7:28	0:57	LINE CLEAR AVAILED
122	22-Jun-21	TUMKUR	66	HONNALLI 220KV- (LINGADAHALLI)CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	6:58	7:27	0:28	LOAD CURTAILMENT
123	22-Jun-21	TUMKUR	66	HONNALLI 220KV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	7:07	7:27	0:20	LOAD CURTAILMENT
124	22-Jun-21	TUMKUR	66	HONNALLI 220KV- KUNDOOR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	6:59	7:27	0:28	LOAD CURTAILMENT
125	22-Jun-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	6:58	7:25	0:27	LOAD CURTAILMENT
126	22-Jun-21	TUMKUR	66	LINGADAHALLI-SHIMOGA(NALLUR)	LINGDHALLI_66	2:46	3:01	0:14	MAIN SUPPLY FAILURE
127	22-Jun-21	TUMKUR	66	LINGADAHALLI-SHIMOGA(NALLUR)	LINGDHALLI_66	9:42	9:52	0:10	MAIN SUPPLY FAILURE
128	22-Jun-21	TUMKUR	66	MADHUGIRI 66KV- BADAVANAHALLI	BADAVANAHALLI_66	17:00	17:02	0:01	HAND TRIPPED
129	22-Jun-21	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	5:30	8:49	3:18	LINE FAULT
130	22-Jun-21	TUMKUR	66	NAGASAMUDRA- RAMPUR	RAMPURA_66	7:43	8:00	0:17	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
131	22-Jun-21	TUMKUR	66	TR-1	DEVARAHALLI_66	13:00	13:31	0:31	HAND TRIPPED
132	22-Jun-21	TUMKUR	66	TR-1	MADADAKERE_66	9:42	9:46	0:03	TRANSFORMER FAULT
133	22-Jun-21	TUMKUR	66	TR-1	RAMAPURA_66	11:11	11:23	0:11	TRANSFORMER FAULT
134	22-Jun-21	TUMKUR	66	TR-1	RAMAPURA_66	12:34	12:52	0:17	TRANSFORMER FAULT
135	22-Jun-21	TUMKUR	66	TR-1	RAMAPURA_66	13:37	13:47	0:10	TRANSFORMER FAULT
136	22-Jun-21	TUMKUR	66	TR-1	RAMAPURA_66	14:14	15:31	1:17	TRANSFORMER FAULT
137	22-Jun-21	TUMKUR	66	TR-2	HOLALKERE_66	9:25	10:05	0:39	HAND TRIPPED
138	22-Jun-21	TUMKUR	66	TR-2	HOSKERE_66	10:03	10:13	0:09	TRANSFORMER FAULT
139	22-Jun-21	TUMKUR	66	TR-2	NIDISALE_66	6:54	7:33	0:39	MAIN SUPPLY FAILURE
140	22-Jun-21	TUMKUR	66	TR-3	HOLALKERE_66	10:05	11:20	1:15	LINE CLEAR AVAILED
141	23-Jun-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
142	23-Jun-21	BAGALKOT	110	110/11KV , HV1	STATION NOT AFFECTED TODALBAGI_110	14:15	14:41	0:26	HAND TRIPPED
143	23-Jun-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KALADAGI_110	13:16	13:33	0:17	LINE CLEAR AVAILED
144	23-Jun-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:27	15:23	5:56	LINE CLEAR AVAILED
145	23-Jun-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KANABARGI LAYOUT_110	16:46	17:32	0:46	LINE CLEAR AVAILED
146	23-Jun-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KANABARGI LAYOUT_110	19:09	19:28	0:19	LINE CLEAR AVAILED
147	23-Jun-21	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED SADALAGA_110	12:30	15:08	2:38	LINE CLEAR AVAILED
148	23-Jun-21	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED SADALAGA_110	16:08	17:00	0:52	TRANSFORMER FAULT
149	23-Jun-21	BAGALKOT	110	110/33KV, HV2	MASTIKATTA_33, SEABIRD_33 STATION NOT AFFECTED ANKOLA_110	10:10	12:21	2:11	LINE CLEAR AVAILED
150	23-Jun-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
151	23-Jun-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
152	23-Jun-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19(20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
153	23-Jun-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39(06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
154	23-Jun-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)	13:27 (23.06.2021)	17:46 hrs	LINE CHARGED
155	23-Jun-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	13:36 (23.06.2021)			LINE OPEN:LINE CLEAR AVAILED
156	23-Jun-21	BAGALKOT	110	KULIGOD-GAMESH IPP	GAMESH IPP_110 KULIGOD_110	5:30	5:35	0:05	HAND TRIPPED
157	23-Jun-21	BAGALKOT	110	LAKSHMESHVAR-BELLATTI	BELLATTI_110	0:09	0:34	0:25	LINE FAULT
158	23-Jun-21	BAGALKOT	110	MAHALINGAPUR220-BANAHATTI	BANAHATTI_110	17:25	17:41	0:16	LINE FAULT
159	23-Jun-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
160	23-Jun-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
161	23-Jun-21	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON_110	17:30 (18.06.2021)			LINE OPEN:LINE CLEAR AVAILED
162	23-Jun-21	BAGALKOT	110	SIRSI-UMMACHAGI	UMMACHAGI_110	11:11	12:42	1:31	LINE CLEAR AVAILED
163	23-Jun-21	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED HAVERI_220	10:28	12:31	2:03	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
164	23-Jun-21	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	11:30	19:11	7:41	LINE CLEAR AVAILED
165	23-Jun-21	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	11:30	19:12	7:42	LINE CLEAR AVAILED
166	23-Jun-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
167	23-Jun-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
168	23-Jun-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	13:15 (20.06.2021)			LINE OPEN:LINE CLEAR AVAILED
169	23-Jun-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	21:02 (10.06.2021)			LINE OPEN:LINE CLEAR AVAILED
170	23-Jun-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
171	23-Jun-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
172	23-Jun-21	BENGALURU	66	AVANI - MULBAGAL	MULBAGAL	6:29	7:12	0:43	LOAD CURTAILMENT
173	23-Jun-21	BENGALURU	66	BANASHANKARI - SUBRAMANYAPURA 220	BANSHANKARI	18:57	19:00	0:03	LOAD CHANGEOVER
174	23-Jun-21	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	6:46	7:18	0:32	LOAD CURTAILMENT
175	23-Jun-21	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	6:46	7:19	0:32	LOAD CURTAILMENT
176	23-Jun-21	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	11:08	11:15	0:07	LOAD CHANGEOVER
177	23-Jun-21	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	12:40	12:50	0:10	LOAD CHANGEOVER
178	23-Jun-21	BENGALURU	66	HBR LAYOUT - HEBBAL 220	HBR LAYOUT	21:45	21:48	0:02	LOAD CHANGEOVER
179	23-Jun-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	20:39	20:49	0:10	LINE FAULT
180	23-Jun-21	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	13:30	13:35	0:05	LOAD CHANGEOVER
181	23-Jun-21	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	16:00	16:05	0:05	LOAD CHANGEOVER
182	23-Jun-21	BENGALURU	66	HV1	MITTEMARI 220	7:10	7:15	0:05	TRANSFORMER FAULT
183	23-Jun-21	BENGALURU	66	HV1	MAGADI 66	0:26	1:21	0:54	TRANSFORMER FAULT
184	23-Jun-21	BENGALURU	66	HV1	KOLAR 220	9:30	13:43	4:13	TRANSFORMER FAULT
185	23-Jun-21	BENGALURU	66	HV2	BAIRAKURU	12:39	12:50	0:10	TRANSFORMER FAULT
186	23-Jun-21	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
187	23-Jun-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	6:30	7:12	0:42	LOAD CURTAILMENT
188	23-Jun-21	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	10:09	10:19	0:10	LINE FAULT
189	23-Jun-21	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	15:30	15:34	0:04	LOAD CHANGEOVER
190	23-Jun-21	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	20:12	20:17	0:05	LOAD CHANGEOVER
191	23-Jun-21	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	16:38	16:43	0:05	LOAD CHANGEOVER
192	23-Jun-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	16:45	16:50	0:05	LINE FAULT
193	23-Jun-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
194	23-Jun-21	BENGALURU	66	VRISHABHAVATHI 220 - BANASHANKARI	BANASHANKARI	13:11	13:22	0:10	LINE FAULT
195	23-Jun-21	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	14:30:32(18-6-2021)			LINE OPEN:LINE FAULT
196	23-Jun-21	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	7:40	7:50	0:10	LINE FAULT
197	23-Jun-21	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	7:52	8:02	0:10	LINE FAULT
198	23-Jun-21	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	11:44	11:49	0:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
199	23-Jun-21	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110,HABSIKOTE_110	7:52	7:58	0:06	LINE FAULT
200	23-Jun-21	GULBARGA	110	HV2	HANUMANAL_110	7:55	8:35	0:40	LINE CLEAR AVAILED
201	23-Jun-21	GULBARGA	110	HV2	CHIGUPPA_110	11:10	12:05	0:55	LINE CLEAR AVAILED
202	23-Jun-21	GULBARGA	110	HV2	KAVITAL_110	13:55	14:00	0:05	TRANSFORMER FAULT
203	23-Jun-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	6:14	6:30	0:16	LINE FAULT
204	23-Jun-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	6:50	6:59	0:09	LINE FAULT
205	23-Jun-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	7:53	8:12	0:19	LINE FAULT
206	23-Jun-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	9:53	10:45	0:52	LINE FAULT
207	23-Jun-21	GULBARGA	110	METRI-TORANGALLU	TORANGALLU_110	9:30	18:15	8:45	LINE CLEAR AVAILED
208	23-Jun-21	GULBARGA	110	RAICHUR -MALIYABAD	MALIYABAD_110,VADAVATI_110	11:18	12:51	1:33	LINE CLEAR AVAILED
209	23-Jun-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	23:40	23:45	0:05	LINE CLEAR AVAILED
210	23-Jun-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	23:10	23:20	0:10	LINE FAULT
211	23-Jun-21	GULBARGA	110	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110	17:54	18:03	0:09	LINE CLEAR AVAILED
212	23-Jun-21	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	0:20	0:36	0:16	MAIN SUPPLY FAILURE
213	23-Jun-21	GULBARGA	220	RAICHUR-JURAL1	RAICHUR_220	12:56(22.06.2021)	16:37(23.06.2021)	27:41HRS	LINE CHARGED
214	23-Jun-21	GULBARGA	220	RAICHUR-JURAL2	RAICHUR_220	11:00(22.06.2021)	16:38(23.06.2021)	29:38HRS	LINE CHARGED
215	23-Jun-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	23:05(22.06.2021)	7:34(23.06.2021)	8:29HRS	LINE CHARGED
216	23-Jun-21	GULBARGA	400	RTPS-MUNIRABAD(GD HALLI)	RTPS_400	00:53(19.06.2021)			LINE OPEN:LINE FAULT
217	23-Jun-21	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:09	9:16	0:07	HAND TRIPPED
218	23-Jun-21	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	14:53	15:31	0:38	HAND TRIPPED
219	23-Jun-21	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	9:09	9:16	0:07	HAND TRIPPED
220	23-Jun-21	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	14:53	15:29	0:36	HAND TRIPPED
221	23-Jun-21	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	9:09	9:16	0:07	HAND TRIPPED
222	23-Jun-21	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	14:53	15:29	0:36	HAND TRIPPED
223	23-Jun-21	HASSAN	66	CHANNARA-MALLALI	CHANNARAYAPATNA_66	12:00	12:14	0:14	LINE FAULT
224	23-Jun-21	HASSAN	66	HV1	BALLUPETE_66	15:15	15:54	0:39	LINE CLEAR AVAILED
225	23-Jun-21	HASSAN	66	HV1	KALASAPURA_66	11:12	16:13	5:01	LINE CLEAR AVAILED
226	23-Jun-21	HASSAN	66	HV1	SIGEBAGE_66	15:05	15:56	0:51	LINE CLEAR AVAILED
227	23-Jun-21	HASSAN	66	HV2	BAGUR_66	15:56	16:14	0:18	TRANSFORMER FAULT
228	23-Jun-21	HASSAN	66	HV2	BASAVAGHATTA	13:23	13:26	0:03	TRANSFORMER FAULT
229	23-Jun-21	HASSAN	66	LV1	MRSMSG_220	9:09	15:02	5:53	LINE CLEAR AVAILED
230	23-Jun-21	HASSAN	66	LV2	MRSMSG_220	9:11	14:52	5:41	LINE CLEAR AVAILED
231	23-Jun-21	HASSAN	66	LV3	MRSMSG_220	9:11	14:52	5:41	LINE CLEAR AVAILED
232	23-Jun-21	HASSAN	66	LV4	MRSMSG_220	9:12	14:52	5:40	LINE CLEAR AVAILED
233	23-Jun-21	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	9:09	9:16	0:07	HAND TRIPPED
234	23-Jun-21	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	14:52	15:03	0:11	HAND TRIPPED
235	23-Jun-21	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	9:09	9:15	0:06	HAND TRIPPED
236	23-Jun-21	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	14:52	15:03	0:11	HAND TRIPPED
237	23-Jun-21	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	9:09	9:15	0:06	HAND TRIPPED
238	23-Jun-21	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	14:52	15:03	0:11	HAND TRIPPED
239	23-Jun-21	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	9:09	9:14	0:05	HAND TRIPPED
240	23-Jun-21	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	14:52	15:02	0:10	HAND TRIPPED
241	23-Jun-21	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	9:24	9:32	0:08	HAND TRIPPED
242	23-Jun-21	HASSAN	110	HV1	SHIKARIPURA_110	15:20 (22.06.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
243	23-Jun-21	HASSAN	110	HV1	KONAJE_110	9:35	9:38	0:03	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
244	23-Jun-21	HASSAN	110	HV2	KADUR_220	12:42	13:07	0:25	TRANSFORMER FAULT
245	23-Jun-21	HASSAN	110	HV2	KONAJE_110	9:35	9:39	0:04	HAND TRIPPED
246	23-Jun-21	HASSAN	110	HV2	VITLA_110	10:41	12:05	1:24	LINE CLEAR AVAILED
247	23-Jun-21	HASSAN	110	HV3	HIRIYADKA_110	17:09	17:19	0:10	TRANSFORMER FAULT
248	23-Jun-21	HASSAN	110	HV3	KONAJE_110	9:35	9:38	0:03	HAND TRIPPED
249	23-Jun-21	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN:LINE CLEAR AVAILED
250	23-Jun-21	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN:LINE CLEAR AVAILED
251	23-Jun-21	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	11:12	12:49	1:37	NFBC ISSUED
252	23-Jun-21	HASSAN	110	LV1	KADUR_220	10:35	12:45	2:10	LINE CLEAR AVAILED
253	23-Jun-21	HASSAN	110	LV2	PUTTUR_220	9:26	13:08	3:42	LINE CLEAR AVAILED
254	23-Jun-21	HASSAN	110	LV3	MRSMSG_220	9:09	14:57	5:48	LINE CLEAR AVAILED
255	23-Jun-21	HASSAN	110	LV3	MRSMSG_220	14:59	15:02	0:03	HAND TRIPPED
256	23-Jun-21	HASSAN	220	HV1	KADUR_220	10:35	12:39	2:04	LINE CLEAR AVAILED
257	23-Jun-21	HASSAN	220	HV2	PUTTUR_220	9:26	13:08	3:42	LINE CLEAR AVAILED
258	23-Jun-21	HASSAN	220	HV3	KAVOOR_220	9:47	13:50	4:03	LINE CLEAR AVAILED
259	23-Jun-21	HASSAN	220	HV3	MRSMSG_220	9:10	14:47	5:37	LINE CLEAR AVAILED
260	23-Jun-21	HASSAN	220	KEMAR-Varahi2	KEMAR_220	10:40	13:40	3:00	LINE CLEAR AVAILED
261	23-Jun-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	10:42	13:36	2:54	LINE CLEAR AVAILED
262	23-Jun-21	HASSAN	220	VARAHI-KEMAR3	varahi_gen	10:20	10:26	0:06	HAND TRIPPED
263	23-Jun-21	MYSURU	66	DEVNUR(N'GUD)-BAS1	NO STATIONS EFFECTED	9:20	15:09	5:49	LINE CLEAR AVAILED
264	23-Jun-21	MYSURU	66	DEVNUR(N'GUD)-BAS2	NO STATIONS EFFECTED	9:20	15:10	5:50	LINE CLEAR AVAILED
265	23-Jun-21	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
266	23-Jun-21	MYSURU	66	KABHALLY-GUNDLUPETE	NO STATIONS EFFECTED	18:58	19:10	0:11	LINE FAULT
267	23-Jun-21	MYSURU	66	KUSHALNAGARA-RAMANATHAPURA 1	ALUR SIDDAPURA_66 KANAGAL_66	18:44	18:57	0:12	LINE FAULT
268	23-Jun-21	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
269	23-Jun-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 VADERALLI_66	9:02	10:17	1:15	LINE CLEAR AVAILED
270	23-Jun-21	MYSURU	66	TUBINKERE-NAGAMANGALA 2	SHIVALLY_66	11:22	11:27	0:04	LINE FAULT
271	23-Jun-21	MYSURU	66	TUBINKERE-NAGAMANGALA 2	SHIVALLY_66	9:02	10:15	1:12	LINE CLEAR AVAILED
272	23-Jun-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	19:00	19:25	0:24	LINE FAULT
273	23-Jun-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	19:00	19:10	0:09	LINE FAULT
274	23-Jun-21	TUMKUR	66	PAVAGADA_220-PAVGD1	PAVAGADA_220	10:58	11:04	0:06	LINE FAULT
275	23-Jun-21	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	8:07	8:15	0:07	HAND TRIPPED
276	23-Jun-21	TUMKUR	66	TR-1	BADAVANAHALLI_66	11:04	11:52	0:47	LINE CLEAR AVAILED
277	23-Jun-21	TUMKUR	66	TR-1	CHANNAGIRI_66	0:25	0:52	0:27	TRANSFORMER FAULT
278	23-Jun-21	TUMKUR	66	TR-1	DYAVARANAHALLI_66	14:44	15:28	0:44	LINE CLEAR AVAILED
279	23-Jun-21	TUMKUR	66	TR-1	GOWRASAMUDRA_66	8:36	9:02	0:26	LINE CLEAR AVAILED
280	23-Jun-21	TUMKUR	66	TR-1	HARIYABBE_66	10:47	10:50	0:03	TRANSFORMER FAULT
281	23-Jun-21	TUMKUR	66	TR-1	PAVAGADA_220	7:14	7:44	0:29	TRANSFORMER FAULT
282	23-Jun-21	TUMKUR	66	TR-1	PAVAGADA_220	7:52	7:56	0:04	TRANSFORMER FAULT
283	23-Jun-21	TUMKUR	66	TR-1	RAMPURA_66	10:20	10:26	0:05	TRANSFORMER FAULT
284	23-Jun-21	TUMKUR	66	TR-2	KADAJJI_66	12:20	12:26	0:06	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
285	23-Jun-21	TUMKUR	66	TR-2(LV SIDE)	KDB VASANTANARASAPURA_220	11:14	12:33	1:19	LINE CLEAR AVAILED
286	23-Jun-21	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	11:30	19:12	7:42	LINE CLEAR AVAILED
287	23-Jun-21	TUMKUR	220	GUTTUR 400KV- HAVERI 2	HAVERI_220	11:30	19:12	7:42	LINE CLEAR AVAILED
288	23-Jun-21	TUMKUR	220	TR-2	KDB VASANTANARASAPURA_220	11:15	12:32	1:17	LINE CLEAR AVAILED
289	24-Jun-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
290	24-Jun-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
291	24-Jun-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
292	24-Jun-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
293	24-Jun-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
294	24-Jun-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
295	24-Jun-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
296	24-Jun-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
297	24-Jun-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	21:02 (10.06.2021)			LINE OPEN:LINE CLEAR AVAILED
298	24-Jun-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
299	24-Jun-21	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON_110	17:30 (18.06.2021)			LINE OPEN:LINE CLEAR AVAILED
300	24-Jun-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	13:15 (20.06.2021)			LINE OPEN:LINE CLEAR AVAILED
301	24-Jun-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
302	24-Jun-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
303	24-Jun-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	13:36 (23.06.2021)			LINE OPEN:LINE CLEAR AVAILED
304	24-Jun-21	BAGALKOT	220	BELAGAUM-KANABARGI2	STATION NOT AFFECTED BELGAUM_220	11:35	12:52	1:17	LINE CLEAR AVAILED
305	24-Jun-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KANABARGI_110	12:46	14:11	1:25	LINE CLEAR AVAILED
306	24-Jun-21	BAGALKOT	110	BELLATTI-ENERCON2	ENERCON IPP_110 STATION NOT AFFECTED BELLATTI_110	8:17	8:48	0:31	LINE CLEAR AVAILED
307	24-Jun-21	BAGALKOT	110	BAGEWADI220-MAMDAPUR	MAMDAPUR_110	5:49	11:13	5:24	LINE CLEAR AVAILED
308	24-Jun-21	BAGALKOT	110	BIDNAL220-NAVALGUND	STATION NOT AFFECTED BIDNAL_220	19:06 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
309	24-Jun-21	BAGALKOT	110	NAVALGUND-BIDNAL220	STATION NOT AFFECTED NAVALGUND_110	23:00 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
310	24-Jun-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
311	24-Jun-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED JAMAKHANDI_110	11:48	12:26	0:38	LINE CLEAR AVAILED
312	24-Jun-21	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED JAMAKHANDI_110	11:48	12:26	0:38	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
313	24-Jun-21	BAGALKOT	110	110/33KV, HV2 (HV1)	ONTIGODI_33, YADWAD_33, STATION NOT AFFECTED UTTUR 110	17:03	17:22	0:19	TRANSFORMER FAULT
314	24-Jun-21	BAGALKOT	220	SRSHUBLI-NAGZARI1	STATION NOT AFFECTED HUBLI 220	11:16	16:38	5:22	LINE CLEAR AVAILED
315	24-Jun-21	BAGALKOT	220	SRSHUBLI-NAGZARI2	STATION NOT AFFECTED HUBLI 220	11:16	16:38	5:22	LINE CLEAR AVAILED
316	24-Jun-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MALLIGERE 110	15:28	17:25	1:57	LINE CLEAR AVAILED
317	24-Jun-21	BAGALKOT	110	110/33KV ,HV3	MMCL_33, SPINNING MILL_33 STATION NOT AFFECTED LAXMESHWAR 110	17:21	17:24	0:03	LINE CLEAR AVAILED
318	24-Jun-21	BAGALKOT	220	220/110,HV1(HV2)	STATION NOT AFFECTED NARENDRA 220	10:29	13:28	2:59	LINE CLEAR AVAILED
319	24-Jun-21	BAGALKOT	220	HAVERI220-GUTTUR 2	STATION NOT AFFECTED HAVERI 220	15:54	18:46	2:52	LINE CLEAR AVAILED
320	24-Jun-21	BAGALKOT	110	110/11KV, HV2 & LV2	STATION NOT AFFECTED KUD DHARWAD 110	15:34	15:43	0:09	TRANSFORMER FAULT
321	24-Jun-21	BAGALKOT	110	110/11KV, HV2 & LV2	STATION NOT AFFECTED KUD DHARWAD 110	16:03	16:12	0:09	TRANSFORMER FAULT
322	25-Jun-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
323	25-Jun-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
324	25-Jun-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
325	25-Jun-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
326	25-Jun-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
327	25-Jun-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
328	25-Jun-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI 110	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
329	25-Jun-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI 110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
330	25-Jun-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI 220	21:02 (10.06.2021)			LINE OPEN:LINE CLEAR AVAILED
331	25-Jun-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B) 110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
332	25-Jun-21	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON 110	17:30 (18.06.2021)			LINE OPEN:LINE CLEAR AVAILED
333	25-Jun-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI 220	13:15 (20.06.2021)			LINE OPEN:LINE CLEAR AVAILED
334	25-Jun-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI 220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
335	25-Jun-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI 220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
336	25-Jun-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	13:36 (23.06.2021)			LINE OPEN:LINE CLEAR AVAILED
337	25-Jun-21	BAGALKOT	110	BIDNAL220-NAVALGUND	STATION NOT AFFECTED BIDNAL 220	19:06 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
338	25-Jun-21	BAGALKOT	110	NAVALGUND-BIDNAL220	STATION NOT AFFECTED NAVALGUND 110	23:00 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
339	25-Jun-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA 110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
340	25-Jun-21	BAGALKOT	110	110/11KV,HV4	BELGAUM_110	14:08	16:45	2:37	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
341	25-Jun-21	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	4:05	4:08	0:03	TRANSFORMER FAULT
342	25-Jun-21	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	19:28 (25.06.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
343	25-Jun-21	BAGALKOT	110	110/11KVHV1 &2	GOPANAKOPPA_110	12:47	15:29	2:42	LINE CLEAR AVAILED
344	25-Jun-21	BAGALKOT	110	HALIYAL-ALNAVAR(GMR)	ALNAVAR_110	5:38	12:47	7:09	LINE FAULT
345	25-Jun-21	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	9:13	9:15	0:02	TRANSFORMER FAULT
346	25-Jun-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DHULKED_33, ALSANGI_33	6:33	6:41	0:08	TRANSFORMER FAULT
347	25-Jun-21	BAGALKOT	110	VAJRAMATTI220- BILAGI	BILAGI_110, SHIRGUPPI_110, TOLAMATTI_110, BISNAL_110, GIRISAGAR_110	2:54	3:02	0:08	LINE FAULT
348	25-Jun-21	BAGALKOT	110	110/11KV, HV3	SOUDATTI_110	23:19	23:31	0:12	LINE CLEAR AVAILED
349	25-Jun-21	BAGALKOT	110	110/11KV, HV3	SOUDATTI_110	23:39	23:59	0:20	LINE CLEAR AVAILED
350	25-Jun-21	BAGALKOT	110	MUNDARGI- VIJAYNAGAR SUGARS	MUNDARGI_110	12:47	16:03	3:16	LINE CLEAR AVAILED
351	25-Jun-21	BAGALKOT	110	MRUTHYUNJAY NAGAR- NARENDRA1	MRUTHYUNJAY NAGAR_110	3:57	12:16	8:19	LINE CLEAR AVAILED
352	25-Jun-21	BAGALKOT	110	MRUTHYUNJAY NAGAR- NARENDRA2	MRUTHYUNJAY NAGAR_110	3:31	12:24	8:53	LINE CLEAR AVAILED
353	26-Jun-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
354	26-Jun-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
355	26-Jun-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
356	26-Jun-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
357	26-Jun-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
358	26-Jun-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
359	26-Jun-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
360	26-Jun-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
361	26-Jun-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	21:02 (10.06.2021)			LINE OPEN:LINE CLEAR AVAILED
362	26-Jun-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
363	26-Jun-21	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON_110	17:30 (18.06.2021)	19:58 (26.06.2021)	0:51 hrs	LINE CHARGED
364	26-Jun-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	13:15 (20.06.2021)			LINE OPEN:LINE CLEAR AVAILED
365	26-Jun-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
366	26-Jun-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
367	26-Jun-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	13:36 (23.06.2021)			LINE OPEN:LINE CLEAR AVAILED
368	26-Jun-21	BAGALKOT	110	BIDNAL220-NAVALGUND	STATION NOT AFFECTED BIDNAL_220	19:06 (24.06.2021)	20:47 (26.06.2021)	1:41 hrs	LINE CHARGED
369	26-Jun-21	BAGALKOT	110	NAVALGUND-BIDNAL220	STATION NOT AFFECTED NAVALGUND_110	23:00 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
370	26-Jun-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
371	26-Jun-21	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	19:28 (25.06.2021)	20:22 (26.06.2021)	23:44 hrs	TRANSFORMER CHARGED
372	26-Jun-21	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	22:17 (26.06.2021)			LINE OPEN:LINE FAULT
373	26-Jun-21	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	12:23	12:56	0:33	LINE CLEAR AVAILED
374	26-Jun-21	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	22:54	23:01	0:07	LINE FAULT
375	26-Jun-21	BAGALKOT	110	SOUDATTI220-MMCL	SOUDATTI_220	13:14	13:30	0:16	LINE FAULT
376	26-Jun-21	BAGALKOT	110	SOUDATTI220-MMCL	SOUDATTI_220	13:53	15:13	1:20	LINE FAULT
377	26-Jun-21	BAGALKOT	110	110/11KV, HV1	TUMMINKATTI_110	14:14	14:48	0:34	LINE CLEAR AVAILED
378	27-Jun-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
379	27-Jun-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
380	27-Jun-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
381	27-Jun-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
382	27-Jun-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
383	27-Jun-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
384	27-Jun-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
385	27-Jun-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
386	27-Jun-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	21:02 (10.06.2021)	18:21 (27.06.2021)	21:19 hrs	LINE CHARGED
387	27-Jun-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
388	27-Jun-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	13:15 (20.06.2021)	18:21 (27.06.2021)	5:06 hrs	LINE CHARGED
389	27-Jun-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
390	27-Jun-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
391	27-Jun-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	13:36 (23.06.2021)			LINE OPEN:LINE CLEAR AVAILED
392	27-Jun-21	BAGALKOT	110	NAVALGUND-BIDNAL220	STATION NOT AFFECTED NAVALGUND_110	23:00 (24.06.2021)	15:06 (27.06.2021)	16:06 hrs	LINE CHARGED
393	27-Jun-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
394	27-Jun-21	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	22:17 (26.06.2021)	12:14 (27.06.2021)	13:57 hrs	LINE CHARGED
395	27-Jun-21	BAGALKOT	220	ALMATTI 2- BAGALKOT	BAGALKOT_220	6:39	7:27	0:48	LINE FAULT
396	27-Jun-21	BAGALKOT	110	BAGALKOT-NEERBUDIHAL(KATARAKI)	NEERBUDIHAL_110	2:55	3:16	0:21	LINE FAULT
397	27-Jun-21	BAGALKOT	110	BIJAPUR220-ENERCON(BAGEWADI)	BIJAPUR_220	7:27	7:35	0:08	LINE FAULT
398	27-Jun-21	BAGALKOT	110	KANABARGI LAYOUT-NEHRU NAGAR	KANABARGI LAYOUT_110	14:29	14:32	0:03	LOAD CHANGEOVER
399	27-Jun-21	BAGALKOT	110	KANABARGI LAYOUT-NEHRU NAGAR	KANABARGI LAYOUT_110	16:18	16:21	0:03	LOAD CHANGEOVER
400	27-Jun-21	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	10:57	11:45	0:48	LINE CLEAR AVAILED
401	27-Jun-21	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	15:58 (27.06.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
402	27-Jun-21	BAGALKOT	110	VAJRAMATTI220- BILAGI	BILAGI_110, SHIRGUPPI_110, TOLAMATTI_110, BISNAL_110, GIRISAGAR_110	2:51	2:58	0:07	LINE FAULT
403	27-Jun-21	BAGALKOT	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	KD JAMBAGI_110, MUDHOL_110	2:39	3:53	1:14	LINE FAULT
404	27-Jun-21	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	7:09	7:13	0:04	TRANSFORMER FAULT
405	27-Jun-21	BAGALKOT	110	UMMACHAGI- SIRSI	UMMACHAGI_110	11:33	12:34	1:01	LOAD CHANGEOVER
406	27-Jun-21	BAGALKOT	110	HUBLI- SIRSI (KALGHATAGI)	KALAGHATAGI_110	11:40	12:20	0:40	LINE FAULT
407	27-Jun-21	BAGALKOT	110	110/11KV, HV1	SHIRGOAN_110	11:12	13:38	2:26	LINE CLEAR AVAILED
408	27-Jun-21	BAGALKOT	110	RANNABELAGALI- UTTUR	UTTUR_110	2:40	3:50	1:10	LINE FAULT
409	27-Jun-21	BAGALKOT	110	BAGEWADI(NIDAGUNDI)- MUKARTIHAL	MUKARTIHAL_110	10:08	12:40	2:32	LINE CLEAR AVAILED
410	27-Jun-21	BAGALKOT	110	MUDEDEBIHAL- KNM SOLAR	MUDEDEBIHAL_110	12:21	12:34	0:13	HAND TRIPPED
411	27-Jun-21	BAGALKOT	110	MANALI SUGARS- MALGHAN (S)	MALGHAN(S)_110	4:54	5:03	0:09	LINE FAULT
412	27-Jun-21	BAGALKOT	110	KULGERI CROSS- KERUR	KULIGERI CROSS_110	14:30	14:40	0:10	LINE CLEAR AVAILED
413	24-Jun-21	BENGALURU	220	ITI 220 - HOODY 220	ITI 220	11:32	12:29	0:57	LINE FAULT
414	24-Jun-21	BENGALURU	220	ITI 220 - MANYATHA TECH PARK 220	NO STATION AFFECTED	11:32	12:29	0:57	LINE FAULT
415	24-Jun-21	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	11:32	11:43	0:11	LINE CLEAR AVAILED
416	24-Jun-21	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	11:32	12:29	0:57	LINE CLEAR AVAILED
417	24-Jun-21	BENGALURU	66	ITI 220 - ITI 66	ITI 66	11:32	12:29	0:57	LINE CLEAR AVAILED
418	24-Jun-21	BENGALURU	66	ITI 220 - NGEF	NGEF, NGEF(EHT)	11:32	12:29	0:57	LINE CLEAR AVAILED
419	24-Jun-21	BENGALURU	66	HV2	BANASAWADI	11:32	11:41	0:09	MAIN SUPPLY FAILURE
420	24-Jun-21	BENGALURU	66	HV2	BANASAWADI	12:37	12:42	0:05	LOAD CHANGEOVER
421	24-Jun-21	BENGALURU	220	HOODY 220 - ITI 220	NO STATION AFFECTED	11:32	12:29	0:57	LINE FAULT
422	24-Jun-21	BENGALURU	66	JAYADEVA - ADUGODI 1	NO STATION AFFECTED	1:27	9:02	7:35	LINE FAULT
423	24-Jun-21	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	6:49	7:06	0:17	LINE FAULT
424	24-Jun-21	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	14:30	14:35	0:05	LOAD CHANGEOVER
425	24-Jun-21	BENGALURU	66	HV1	SIDDALAGATTA	0:45	1:10	0:24	TRANSFORMER FAULT
426	24-Jun-21	BENGALURU	66	HV1	MULBAGLU	11:41	11:45	0:03	LINE CLEAR AVAILED
427	24-Jun-21	BENGALURU	66	HV1	MAASTHI	14:55	17:35	2:40	LINE CLEAR AVAILED
428	24-Jun-21	BENGALURU	66	HV2	MAASTHI	14:55	16:20	1:25	LINE CLEAR AVAILED
429	24-Jun-21	BENGALURU	66	HV2	MAASTHI	17:15	17:41	0:26	LINE CLEAR AVAILED
430	24-Jun-21	BENGALURU	66	HV1	HUKUNDA	12:24	14:05	1:40	LINE CLEAR AVAILED
431	24-Jun-21	BENGALURU	66	HV2	HUKUNDA	12:24	14:10	1:45	LINE CLEAR AVAILED
432	24-Jun-21	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	16:12	16:26	0:14	LINE FAULT
433	24-Jun-21	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	10:00	10:06	0:05	LINE FAULT
434	24-Jun-21	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	18:43	18:50	0:07	LOAD CHANGEOVER
435	24-Jun-21	BENGALURU	66	HV1	MATHIKERE 66	5:20	6:19	0:59	TRANSFORMER FAULT
436	24-Jun-21	BENGALURU	66	HV1	MATHIKERE 66	14:15	14:20	0:05	TRANSFORMER FAULT
437	24-Jun-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
438	24-Jun-21	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	14:30:32(18-6-2021)			LINE OPEN:LINE FAULT
439	24-Jun-21	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
440	25-Jun-21	BENGALURU	66	B G ROAD - SOMANAHALLI 220	B G ROAD	10:33	10:37	0:04	LOAD CHANGEOVER
441	25-Jun-21	BENGALURU	66	B G ROAD - JIGANI LINK ROAD	B G ROAD	15:13	15:18	0:05	LOAD CHANGEOVER
442	25-Jun-21	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	12:48	12:53	0:05	LOAD CHANGEOVER
443	25-Jun-21	BENGALURU	66	GOLF LINK - HAL 220	GOLF LINK	11:25	11:36	0:11	LOAD CHANGEOVER
444	25-Jun-21	BENGALURU	66	HV2	AMAR JYOTHI	11:25	11:40	0:15	LOAD CHANGEOVER
445	25-Jun-21	BENGALURU	66	HV2	AMAR JYOTHI	13:30	13:35	0:05	LOAD CHANGEOVER
446	25-Jun-21	BENGALURU	66	IISC - HEBBAL 220	IISC	10:08	10:12	0:04	LOAD CHANGEOVER
447	25-Jun-21	BENGALURU	66	HV2	ISKON	11:18	11:20	0:02	LINE CLEAR AVAILED
448	25-Jun-21	BENGALURU	66	KADUGODI - EPIP 220	KADUGODI	12:42	13:45	1:03	LINE CLEAR AVAILED
449	25-Jun-21	BENGALURU	66	HV1	NGEF	11:46	11:50	0:04	LINE CLEAR AVAILED
450	25-Jun-21	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	4:23	4:32	0:09	TRANSFORMER FAULT
451	25-Jun-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	10:19	10:25	0:06	LINE FAULT
452	25-Jun-21	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	15:31	15:51	0:20	LINE FAULT
453	25-Jun-21	BENGALURU	220	HV2	VRISHABHAVATHI	16:30	21:30	5:00	TRANSFORMER FAULT
454	25-Jun-21	BENGALURU	66	HV1	YARANDANAHALLI 220	16:29	16:50	0:21	TRANSFORMER FAULT
455	25-Jun-21	BENGALURU	66	KONDASPURA - HOSKOTE 220	KONDASPURA	13:51	13:56	0:05	LOAD CHANGEOVER
456	25-Jun-21	BENGALURU	66	HV1	SIDDLAGHATTA	19:59	20:31	0:32	TRANSFORMER FAULT
457	25-Jun-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	10:07	10:11	0:03	LINE FAULT
458	25-Jun-21	BENGALURU	66	HV1	MATHIKERE	15:06	16:20	1:13	LINE CLEAR AVAILED
459	25-Jun-21	BENGALURU	66	HV2	KODIHALLI HAROBELE	11:26	11:46	0:20	LINE CLEAR AVAILED
460	25-Jun-21	BENGALURU	66	HV2	MAASTI	17:23	17:34	0:11	LINE CLEAR AVAILED
461	25-Jun-21	BENGALURU	66	JIGANI LINK ROAD - SOMANAHALLI 220	JIGANI LINK ROAD	10:30	10:37	0:07	LOAD CHANGEOVER
462	25-Jun-21	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	10:05	10:10	0:05	LOAD CHANGEOVER
463	25-Jun-21	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	11:20	11:25	0:05	LOAD CHANGEOVER
464	25-Jun-21	BENGALURU	66	ARMY WELFARE ORGANISATION - KONDASPURA	KONDASPURA	9:52	10:05	0:13	LINE CLEAR AVAILED
465	25-Jun-21	BENGALURU	66	ARMY WELFARE ORGANISATION - KADUGODI	ARMY WELFARE ORGANISATION	12:42	13:52	1:10	LINE CLEAR AVAILED
466	25-Jun-21	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	9:57	10:05	0:08	LOAD CHANGEOVER
467	25-Jun-21	BENGALURU	66	HBR LAYOUT - HEBBAL 220	HBR LAYOUT	14:03	14:08	0:05	LOAD CHANGEOVER
468	25-Jun-21	BENGALURU	66	HV1	CHAKAVELU	13:08	13:14	0:06	LINE CLEAR AVAILED
469	25-Jun-21	BENGALURU	66	HV1	CB PURA URBAN	10:25	10:30	0:04	LINE CLEAR AVAILED
470	25-Jun-21	BENGALURU	66	HV1	CB PURA URBAN	13:40	13:45	0:05	LINE CLEAR AVAILED
471	25-Jun-21	BENGALURU	66	CHELUR - ESUN SOLAR	ESUN SOLAR	10:07	10:42	0:34	MAIN SUPPLY FAILURE
472	25-Jun-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
473	25-Jun-21	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	14:30:32(18-6-2021)			LINE OPEN:LINE FAULT
474	25-Jun-21	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
475	26-Jun-21	BENGALURU	66	HAMUMANTHNAGAR - SOMANAHALLI 220	HANUMANTHNAGAR, YEDUMADU	9:40	9:45	0:05	LOAD CHANGEOVER
476	26-Jun-21	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	15:56	16:15	0:19	MAIN SUPPLY FAILURE
477	26-Jun-21	BENGALURU	66	IISC - NRS 220	IISC	16:53	16:57	0:04	LOAD CHANGEOVER
478	26-Jun-21	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	11:03	11:13	0:10	LINE FAULT
479	26-Jun-21	BENGALURU	66	HV1	VICTORIA	11:56	11:57	0:01	LINE CLEAR AVAILED
480	26-Jun-21	BENGALURU	66	HV2	VICTORIA	10:55	10:57	0:02	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
481	26-Jun-21	BENGALURU	66	VRISHABHAVATHI 220 - SIR M V LAYOUT	SIR M V LAYOUT, KENGERI SATELLITE TOWN	12:01	12:45	0:44	LINE FAULT
482	26-Jun-21	BENGALURU	66	SADLI - MITTEMARI 220	SADLI, DIBURALLI	5:49	5:59	0:10	LINE FAULT
483	26-Jun-21	BENGALURU	66	HV1	SARJAPURA 220	9:10	9:17	0:06	LINE CLEAR AVAILED
484	26-Jun-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	9:10	9:18	0:07	LINE CLEAR AVAILED
485	26-Jun-21	BENGALURU	220	HV2	SARJAPURA 220	9:10	9:17	0:06	LINE CLEAR AVAILED
486	26-Jun-21	BENGALURU	66	YEDUMADU - KANAKPURA 220	YEDUMADU	15:01	15:04	0:03	LOAD CHANGE OVER
487	26-Jun-21	BENGALURU	66	KONDASPURA - HOSKOTE 220	KONDASPURA	16:17	16:22	0:05	LOAD CHANGE OVER
488	26-Jun-21	BENGALURU	66	VIDYANAGAR - SAHAKARNAGAR	HENNUR CROSS	15:56	16:53	0:56	LINE FAULT
489	26-Jun-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTURU	9:18	9:23	0:05	LINE FAULT
490	26-Jun-21	BENGALURU	66	HV1	GOWRIBIDANUR 220	20:50	20:55	0:05	TRANSFORMER FAULT
491	26-Jun-21	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	14:00	14:10	0:10	LOAD CHANGE OVER
492	26-Jun-21	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	16:30	16:35	0:05	LOAD CHANGE OVER
493	26-Jun-21	BENGALURU	66	ARMY WELFARE ORGANISATION - KONDASPURA	KONDASPURA	12:17	12:32	0:15	LINE CLEAR AVAILED
494	26-Jun-21	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	12:26	12:29	0:03	LOAD CHANGE OVER
495	26-Jun-21	BENGALURU	66	HBR LAYOUT - HEBBAL 220	HBR LAYOUT	16:22	16:25	0:03	LOAD CHANGE OVER
496	26-Jun-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
497	26-Jun-21	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	14:30:32(18-6-2021)			LINE OPEN:LINE FAULT
498	26-Jun-21	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
499	26-Jun-21	BENGALURU	66	HV2	MAASTI	10:15:06(26-6-2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
500	26-Jun-21	BENGALURU	66	HV2	JIGANI LINK ROAD	22:15(26-6-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
501	27-Jun-21	BENGALURU	66	ELECTRONIC CITY P2 S1 - NAGNATHPURA 220	ELECTRONIC CITY P2 S1	12:02	12:32	0:30	MAIN SUPPLY FAILURE
502	27-Jun-21	BENGALURU	66	ELECTRONIC CITY P2 S1 - ELECTRONIC CITY	ELECTRONIC CITY P2 S1	14:53	15:03	0:10	LOAD CHANGE OVER
503	27-Jun-21	BENGALURU	66	HEBBALA 220 - L R BANDE	L R BANDE	21:33	22:18	0:45	LINE CLEAR AVAILED
504	27-Jun-21	BENGALURU	66	HV1	BANASAWADI	21:33	22:15	0:42	MAIN SUPPLY FAILURE
505	27-Jun-21	BENGALURU	66	HV3	BANASAWADI	21:33	22:15	0:42	MAIN SUPPLY FAILURE
506	27-Jun-21	BENGALURU	220	HSR LAYOUT 220 - NAGANATHPURA 220	NAGANATHPURA 220	12:02	12:36	0:34	LINE FAULT
507	27-Jun-21	BENGALURU	66	HV2	KADUGODI	21:41	21:47	0:06	TRANSFORMER FAULT
508	27-Jun-21	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA	12:02	12:41	0:39	MAIN SUPPLY FAILURE
509	27-Jun-21	BENGALURU	66	HV1	NAGANATHPURA 220	12:02	12:41	0:39	MAIN SUPPLY FAILURE
510	27-Jun-21	BENGALURU	66	HV2	NAGANATHPURA 220	12:02	12:41	0:39	MAIN SUPPLY FAILURE
511	27-Jun-21	BENGALURU	66	HV3	NAGANATHPURA 220	12:02	12:41	0:39	MAIN SUPPLY FAILURE
512	27-Jun-21	BENGALURU	66	HV1	SRIGANDA KAVALU	11:10	11:15	0:05	LINE CLEAR AVAILED
513	27-Jun-21	BENGALURU	66	HV2	SRIGANDA KAVALU	11:10	11:15	0:05	LINE CLEAR AVAILED
514	27-Jun-21	BENGALURU	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	15:30	16:46	1:16	LINE FAULT
515	27-Jun-21	BENGALURU	66	SIR M V LAYOUT - KUMBALAGODU	SIR M V LAYOUT, KENGERI SATELLITE TOWN	18:20	18:25	0:05	LOAD CHANGE OVER
516	27-Jun-21	BENGALURU	66	HULLENAHALLI - KUDUR	KUDUR	9:22	9:40	0:17	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
517	27-Jun-21	BENGALURU	66	HV1	MULBAGLU	10:34	10:37	0:02	LINE CLEAR AVAILED
518	27-Jun-21	BENGALURU	66	HV1	WELCAST STEEL	11:45	11:50	0:05	LINE CLEAR AVAILED
519	27-Jun-21	BENGALURU	66	HV2	WELCAST STEEL	10:25	11:25	1:00	LINE CLEAR AVAILED
520	27-Jun-21	BENGALURU	66	HV1	RANGANDODDI	14:02	14:40	0:38	LINE CLEAR AVAILED
521	27-Jun-21	BENGALURU	66	HV2	RANGANDODDI	14:17	14:40	0:23	LINE CLEAR AVAILED
522	27-Jun-21	BENGALURU	66	CHINTAMANI 220 - TALAGWARA	TALAGWARA, Y HUNISENAHALLI, CHEEMANGALA	12:25	12:33	0:07	LINE FAULT
523	27-Jun-21	BENGALURU	66	HV1	GOWRIBIDANUR 220	13:05	13:15	0:10	TRANSFORMER FAULT
524	27-Jun-21	BENGALURU	66	JIGANI LINK ROAD - JIGANI 220	JIGANI LINK ROAD, BG ROAD	11:04	11:07	0:03	LOAD CHANGE OVER
525	27-Jun-21	BENGALURU	66	HV1	JIGANI LINK ROAD	17:00	17:40	0:40	LINE CLEAR AVAILED
526	27-Jun-21	BENGALURU	66	JIGANI LINK ROAD - SOMANAHALLI 220	JIGANI LINK ROAD	16:50	17:00	0:10	LINE CLEAR AVAILED
527	27-Jun-21	BENGALURU	66	HV2	DODDABELAVANGALA	19:34	19:45	0:11	TRANSFORMER FAULT
528	27-Jun-21	BENGALURU	66	HV2	DODDABELAVANGALA	20:05	20:33	0:27	TRANSFORMER FAULT
529	27-Jun-21	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	16:56	17:04	0:07	LINE FAULT
530	27-Jun-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
531	27-Jun-21	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	14:30:32(18-6-2021)			LINE OPEN:LINE FAULT
532	27-Jun-21	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
533	27-Jun-21	BENGALURU	66	HV2	JIGANI LINK ROAD	22:15(26-6-2021)	1:37(27-6-2021)	3:21 hrs	TRANSFORMER CHARGED
534	27-Jun-21	BENGALURU	66	HV2	MAASTI	10:15:06(26-6-2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
535	25-Jun-21	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANA HALLI_220	16:01	16:20	0:12	LINE CLEAR AVAILED
536	25-Jun-21	TUMKUR	220	TR-3(HV SIDE)	CHITRADURGA_220	11:23	13:08	0:12	LINE CLEAR AVAILED
537	25-Jun-21	TUMKUR	110	HONNAVALI 110- KADUR110	HONNAVALI_110	6:35	6:48	0:12	LINE FAULT
538	25-Jun-21	TUMKUR	110	HONNAVALI 110-ADAN SOLAR_66	ADAN SOLAR_IPP_66	19:22	20:09	0:12	LINE CLEAR AVAILED
539	25-Jun-21	TUMKUR	110	TR-1	KBCROSS_220	15:17	16:42	0:12	LINE CLEAR AVAILED
540	25-Jun-21	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	ANCHEPALYA_220	11:47	19:17	0:12	LINE CLEAR AVAILED
541	25-Jun-21	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANA HALLI_220	16:01	16:20	0:12	LINE CLEAR AVAILED
542	25-Jun-21	TUMKUR	66	BALENAHALLI66-CHALLAKERE	CHALLAKERE_66,SANIKERE-66	11:14	13:58	0:12	MAIN SUPPLY FAILURE
543	25-Jun-21	TUMKUR	66	BALENAHALLI66-CHITRADURGA220	BALENAHALLI_66	11:14	13:48	0:12	MAIN SUPPLY FAILURE
544	25-Jun-21	TUMKUR	66	BEVINAHALLI _AFTL SOLAR_IPP_66	AFTL SOLAR_IPP_66	20:48	21:00	0:12	LINE FAULT
545	25-Jun-21	TUMKUR	66	CHITRADURGA 220kV-CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	11:13	13:37	0:12	LINE CLEAR AVAILED
546	25-Jun-21	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	11:23	13:12	0:12	LINE CLEAR AVAILED
547	25-Jun-21	TUMKUR	66	CHITRADURGA 220kV- SUZLON 1	SUZLON1_IPP_66	11:51	12:26	0:12	LINE CLEAR AVAILED
548	25-Jun-21	TUMKUR	66	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	11:16	13:36	0:12	LINE CLEAR AVAILED
549	25-Jun-21	TUMKUR	66	TR-1	CHIKKATOTTLUKERE_66	16:39	17:08	0:12	LINE CLEAR AVAILED
550	25-Jun-21	TUMKUR	66	TR-1	HANGAL_66	13:15	13:24	0:12	LINE CLEAR AVAILED
551	25-Jun-21	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	17:50	18:41	0:12	LINE CLEAR AVAILED
552	26-Jun-21	TUMKUR	110	TR-1	TURUVEKERE_66	11:26	11:49	0:12	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
553	26-Jun-21	TUMKUR	66	ANCHEPALYA 220KV- VIJAYA STEEL	ANCHEPALYA_220	11:18	16:25	0:12	LINE CLEAR AVAILED
554	26-Jun-21	TUMKUR	66	BEVINAHALLI _AFTL SOLAR_IPP_66	AFTL SOLAR_IPP_66	6:03	6:13	0:12	LINE FAULT
555	26-Jun-21	TUMKUR	66	BUKKAPATNA66-GOLDEN SOLAR-IPP_66	GOLDEN SOLAR-IPP_66	12:15	15:50	0:12	MAIN SUPPLY FAILURE
556	26-Jun-21	TUMKUR	66	TR-1	CHIKKABANAGERE_66	17:51	18:05	0:12	LINE CLEAR AVAILED
557	27-Jun-21	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	9:23	9:32	0:12	LINE CLEAR AVAILED
558	27-Jun-21	TUMKUR	66	ANCHEPALYA 220- VIJAYASTEEL	VIJAYASTEEL	9:37	9:43	0:12	LINE CLEAR AVAILED
559	27-Jun-21	TUMKUR	66	I D HALLI-CLEAN MAX SOLARSOLAR_IPP_66 CLEAN MAX SOLARSOLAR IPP 6		20:44	21:09	0:12	LINE FAULT
560	27-Jun-21	TUMKUR	66	MADHUGIRI 220kv-PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	20:01	20:21	0:12	LINE FAULT
561	27-Jun-21	TUMKUR	66	TR-2	MADDHUGIRI_66	13:40	13:58	0:12	TRANSFORMER FAULT
562	27-Jun-21	TUMKUR	66	TR-2	MADDHUGIRI_66	14:10	14:35	0:12	TRANSFORMER FAULT
563	24-Jun-21	MYSURU	66	HOOTAGALLI-HAMPAPURA(DODDAKADANUR)	DODDAKADNUR(HAMPAPURA)_66	5:57	6:02	0:05	LINE FAULT
564	24-Jun-21	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
565	24-Jun-21	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
566	25-Jun-21	MYSURU	66	HV1	KIADBMANDYA_66	10:16	10:27	0:10	HAND TRIPPED
567	25-Jun-21	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	14:31	14:39	0:07	LINE FAULT
568	25-Jun-21	MYSURU	66	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	10:10	14:30	4:20	LINE CLEAR AVAILED
569	25-Jun-21	MYSURU	66	HV2	NAGAMANGALA_66	15:05	16:01	0:56	LINE CLEAR AVAILED
570	25-Jun-21	MYSURU	66	HV1	NANJANGUDU_66	14:07	14:52	0:45	LINE CLEAR AVAILED
571	25-Jun-21	MYSURU	66	HV1	SANTHESARAGUR_66	10:50	16:00	5:10	LINE CLEAR AVAILED
572	25-Jun-21	MYSURU	66	HV2	SANTHESARAGUR_66	11:00	16:00	5:00	LINE CLEAR AVAILED
573	25-Jun-21	MYSURU	66	HV1	SRIRANGAPATNA_66	12:06	13:28	1:21	LINE CLEAR AVAILED
574	25-Jun-21	MYSURU	66	HV2	SRIRANGAPATNA_66	13:28	15:06	1:38	LINE CLEAR AVAILED
575	25-Jun-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 TARIPURA_66 GAMANAHALLY_66	5:35	5:40	0:05	LINE FAULT
576	25-Jun-21	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
577	25-Jun-21	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
578	26-Jun-21	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	8:47	8:54	0:07	LINE FAULT
579	26-Jun-21	MYSURU	66	KADAKOLA-MANTAKALLI	MANDAKALLI_66	13:16	13:25	0:08	LINE FAULT
580	26-Jun-21	MYSURU	66	HV1	MANDGERE_66	15:36	15:45	0:08	TRANSFORMER FAULT
581	26-Jun-21	MYSURU	66	HV3	SRIMANGALA_33	14:12	14:32	0:20	TRANSFORMER FAULT
582	26-Jun-21	MYSURU	66	HV3	SRIMANGALA_33	14:35	14:42	0:07	TRANSFORMER FAULT
583	26-Jun-21	MYSURU	66	HV3	SRIMANGALA_33	21:16	21:24	0:08	TRANSFORMER FAULT
584	26-Jun-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	9:29	10:26	0:56	LINE CLEAR AVAILED
585	26-Jun-21	MYSURU	66	TUBINKERE-NAGAMANGALA 2	SHIVALLY_66	9:29	10:26	0:56	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
586	26-Jun-21	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
587	26-Jun-21	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
588	27-Jun-21	MYSURU	66	HV1	PONNAMPETE_33	11:36	12:01	0:24	TRANSFORMER FAULT
589	27-Jun-21	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
590	27-Jun-21	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
591	24-Jun-21	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN:LINE CLEAR AVAILED
592	24-Jun-21	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN:LINE CLEAR AVAILED
593	24-Jun-21	HASSAN	110	HV1	SHIKARIPURA_110	15:20 (22.06.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
594	24-Jun-21	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	11:06	15:28	4:22	LINE CLEAR AVAILED
595	24-Jun-21	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	15:30	17:16	1:46	LINE CLEAR AVAILED
596	24-Jun-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	12:36	13:24	0:48	LINE CLEAR AVAILED
597	24-Jun-21	HASSAN	220	HV2	PUTTUR_220	9:13	15:24	6:11	LINE CLEAR AVAILED
598	24-Jun-21	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	15:30	17:14	1:44	NFBC ISSUED
599	24-Jun-21	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	12:36	13:24	0:48	LINE CLEAR AVAILED
600	24-Jun-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:00	13:22	3:22	LINE CLEAR AVAILED
601	24-Jun-21	HASSAN	110	HV2	HALADY_110	11:50	16:10	4:20	LINE CLEAR AVAILED
602	24-Jun-21	HASSAN	110	HV1	ANANDPURA_110	10:23	20:00	9:37	LINE CLEAR AVAILED
603	24-Jun-21	HASSAN	110	HV2	ANANDPURA_110	9:35	18:11	8:36	LINE CLEAR AVAILED
604	24-Jun-21	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	17:40	17:45	0:05	HAND TRIPPED
605	24-Jun-21	HASSAN	110	HV2	KADUR_220	13:51	15:04	1:13	TRANSFORMER FAULT
606	24-Jun-21	HASSAN	110	KEMAR-Manipal2	KEMAR_220	11:25	13:10	1:45	LINE CLEAR AVAILED
607	24-Jun-21	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	16:11	16:20	0:09	LINE CLEAR AVAILED
608	24-Jun-21	HASSAN	110	LV2	PUTTUR_220	9:13	15:24	6:11	LINE CLEAR AVAILED
609	24-Jun-21	HASSAN	110	HV3	SAGARA_110	14:45	16:41	1:56	TRANSFORMER FAULT
610	24-Jun-21	HASSAN	110	HV1	SHIRALKOPPA_220	14:44	15:11	0:27	LINE CLEAR AVAILED
611	24-Jun-21	HASSAN	66	HV1	GANGUR_66	12:42	13:02	0:20	LINE CLEAR AVAILED
612	24-Jun-21	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	5:42	5:51	0:09	LINE FAULT
613	24-Jun-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATANAHALLI_66	10:51	10:58	0:07	LINE FAULT
614	25-Jun-21	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN:LINE CLEAR AVAILED
615	25-Jun-21	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN:LINE CLEAR AVAILED
616	25-Jun-21	HASSAN	110	HV1	SHIKARIPURA_110	15:20 (22.06.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
617	25-Jun-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:09(25.06.2021)			LINE OPEN:LINE CLEAR AVAILED
618	25-Jun-21	HASSAN	110	DMKURK-HONNAVALLI	DMKURKE_110	6:25	6:35	0:10	MAIN SUPPLY FAILURE
619	25-Jun-21	HASSAN	110	HV1	ESSUR_110	10:32	18:30	7:58	LINE CLEAR AVAILED
620	25-Jun-21	HASSAN	110	HV2	ESSUR_110	10:32	18:30	7:58	LINE CLEAR AVAILED
621	25-Jun-21	HASSAN	110	HV1	GURUPURA_110	10:32	16:09	5:37	LINE CLEAR AVAILED
622	25-Jun-21	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	12:58	16:18	3:20	LINE CLEAR AVAILED
623	25-Jun-21	HASSAN	110	HOSUR-BALIGAVI	HOSUR_110	10:50	14:14	3:24	NFBC ISSUED
624	25-Jun-21	HASSAN	110	KEMAR-Manipal1	KEMAR_220	11:02	13:21	2:19	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
625	25-Jun-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	11:02	13:21	2:19	NFBC ISSUED
626	25-Jun-21	HASSAN	110	HV5	MRSMSG_220	9:09	14:57	5:48	LINE CLEAR AVAILED
627	25-Jun-21	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	10:36	16:50	6:14	LINE CLEAR AVAILED
628	25-Jun-21	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:13	17:30	7:17	LINE CLEAR AVAILED
629	25-Jun-21	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:11	17:25	7:14	LINE CLEAR AVAILED
630	25-Jun-21	HASSAN	66	HV1	ALDUR_66	10:22	17:15	6:53	LINE CLEAR AVAILED
631	25-Jun-21	HASSAN	66	HV1	BYACHANAHALLI_66	3:15	4:05	0:50	TRANSFORMER FAULT
632	26-Jun-21	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN:LINE CLEAR AVAILED
633	26-Jun-21	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN:LINE CLEAR AVAILED
634	26-Jun-21	HASSAN	110	HV1	SHIKARIPURA_110	15:20 (22.06.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
635	26-Jun-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:09(25.06.2021)			LINE OPEN:LINE CLEAR AVAILED
636	26-Jun-21	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	12:32	13:44	1:12	LINE CLEAR AVAILED
637	26-Jun-21	HASSAN	110	HV1	SAGARA_110	17:45	18:54	1:09	LINE CLEAR AVAILED
638	26-Jun-21	HASSAN	110	HV2	SAGARA_110	16:50	18:55	2:05	LINE CLEAR AVAILED
639	26-Jun-21	HASSAN	110	HV3	SAGARA_110	10:08	18:54	8:46	LINE CLEAR AVAILED
640	26-Jun-21	HASSAN	110	HV1	SHIRALKOPPA_110	10:45	18:26	7:41	LINE CLEAR AVAILED
641	26-Jun-21	HASSAN	110	HV2	SHIRALKOPPA_110	10:45	18:26	7:41	LINE CLEAR AVAILED
642	26-Jun-21	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_110	10:39	18:31	7:52	LINE CLEAR AVAILED
643	26-Jun-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	10:02	10:55	0:53	HAND TRIPPED
644	26-Jun-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	10:58	18:22	7:24	LINE CLEAR AVAILED
645	26-Jun-21	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	14:20	14:30	0:10	LINE FAULT
646	26-Jun-21	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	11:43	13:52	2:09	NFBC ISSUED
647	26-Jun-21	HASSAN	66	HV1	MAGGE_66	11:43	13:52	2:09	MAIN SUPPLY FAILURE
648	26-Jun-21	HASSAN	66	HV2	MAGGE_66	11:43	13:52	2:09	MAIN SUPPLY FAILURE
649	26-Jun-21	HASSAN	66	SAKALE-HASSAN	SAKLESH PURA_66	11:43	13:55	2:12	LINE CLEAR AVAILED
650	26-Jun-21	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	10:24	10:30	0:06	LINE FAULT
651	27-Jun-21	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN:LINE CLEAR AVAILED
652	27-Jun-21	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN:LINE CLEAR AVAILED
653	27-Jun-21	HASSAN	110	HV1	SHIKARIPURA_110	15:20 (22.06.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
654	27-Jun-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:09(25.06.2021)			LINE OPEN:LINE CLEAR AVAILED
655	27-Jun-21	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	22:51(27.06.2021)			LINE OPEN:LINE CLEAR AVAILED
656	27-Jun-21	HASSAN	110	HV1	ARASIKERE_110	12:45	13:30	0:45	TRANSFORMER FAULT
657	27-Jun-21	HASSAN	110	HV2	KADUR_220	12:47	13:26	0:39	TRANSFORMER FAULT
658	27-Jun-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	17:24	19:00	1:36	LINE CLEAR AVAILED
659	27-Jun-21	HASSAN	66	HV1	HALLIMYSORE_66	9:32	9:41	0:09	TRANSFORMER FAULT
660	24-Jun-21	GULBARGA	400	RTPS-MUNIRABAD(GD HALLI)	RTPS_400	00:53(19.06.2021)			LINE OPEN:LINE FAULT
661	24-Jun-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	4:40	5:20	0:40	LINE FAULT
662	24-Jun-21	GULBARGA	110	MALLAT-BYAGWATH1	BYAGWATH1_110	0:45	1:06	0:21	LINE FAULT
663	24-Jun-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	5:55	6:00	0:05	LINE FAULT
664	24-Jun-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	21:22	21:33	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
665	24-Jun-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	0:20	0:30	0:10	LINE FAULT
666	24-Jun-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	5:50	6:05	0:15	LINE FAULT
667	24-Jun-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	9:17	9:21	0:04	LINE FAULT
668	24-Jun-21	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	10:36	10:42	0:06	LINE CLEAR AVAILED
669	24-Jun-21	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	14:37	14:49	0:12	LINE CLEAR AVAILED
670	24-Jun-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:42	20:48	0:06	LINE FAULT
671	24-Jun-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	23:08	23:16	0:08	LINE FAULT
672	24-Jun-21	GULBARGA	110	HV2	GINIGERA_110	6:30	7:20	0:10	TRANSFORMER FAULT
673	24-Jun-21	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	21:01	21:16	0:15	LINE FAULT
674	24-Jun-21	GULBARGA	66	HV2	TAMBRAHALI_66	5:46	6:02	0:16	TRANSFORMER FAULT
675	24-Jun-21	GULBARGA	66	HV2	TAMBRAHALI_66	7:59	8:02	0:03	TRANSFORMER FAULT
676	24-Jun-21	GULBARGA	66	HV2	TAMBRAHALI_66	15:05	15:10	0:05	TRANSFORMER FAULT
677	25-Jun-21	GULBARGA	400	RTPS-MUNIRABAD(GD HALLI)	RTPS_400	00:53(19.06.2021)			LINE OPEN:LINE FAULT
678	25-Jun-21	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSL SUGARS IPP,CHOWDAPUR_110	5:44	5:50	0:06	LINE FAULT
679	25-Jun-21	GULBARGA	66	HV2	TAMBRAHALI_66	6:24	6:29	0:05	TRANSFORMER FAULT
680	25-Jun-21	GULBARGA	66	HV2	TAMBRAHALI_66	7:53	8:01	0:08	TRANSFORMER FAULT
681	26-Jun-21	GULBARGA	400	RTPS-MUNIRABAD(GD HALLI)	RTPS_400	00:53(19.06.2021)	11:18(26.06.2021)	178:25 hrs	LINE CHARGED
682	26-Jun-21	GULBARGA	220	RAICHUR-JURALA1&2(IDLE LINE)	RAICHUR_220	11:50	18:29	6:39	LINE CLEAR AVAILED
683	26-Jun-21	GULBARGA	220	HV1	RAICHUR_220	22:39	23:56	1:17	TRANSFORMER FAULT
684	26-Jun-21	GULBARGA	220	HV1	KUDLIGI_220	17:45	18:00	0:15	TRANSFORMER FAULT
685	26-Jun-21	GULBARGA	220	HV1	KUSHTAGI_220	19:44	20:06	0:22	TRANSFORMER FAULT
686	26-Jun-21	GULBARGA	110	HV1	GURUMITAKAL_110	11:15	15:10	3:55	LINE CLEAR AVAILED
687	26-Jun-21	GULBARGA	110	HV2	GURUMITAKAL_110	11:15	16:50	5:35	LINE CLEAR AVAILED
688	26-Jun-21	GULBARGA	110	MASKI-HATTI	HATTI_110	4:34	4:43	0:09	LINE FAULT
689	26-Jun-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	19:03	19:18	0:15	LINE FAULT
690	26-Jun-21	GULBARGA	110	MASKI-RENEW SLR	MASKI_110	19:03	20:02	0:59	LINE FAULT
691	26-Jun-21	GULBARGA	110	MUNIRABAD-TBDAM	MUNIRABAD_220	8:54	13:15	4:21	NFBC ISSUED
692	26-Jun-21	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110, DEVANGAON_110,RENUKA_IPP,A FZALPUR_110,KARAJAGI_110	20:03	21:13	1:10	LINE FAULT
693	26-Jun-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YEDRAMI_110,MORATAGI_110	23:30	23:35	0:05	LINE FAULT
694	26-Jun-21	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110	18:03	18:08	0:05	LINE CLEAR AVAILED
695	26-Jun-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	22:49	22:57	0:08	LINE FAULT
696	26-Jun-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	22:39	22:58	0:19	LINE FAULT
697	26-Jun-21	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI_110	22:39	22:53	0:14	LINE FAULT
698	26-Jun-21	GULBARGA	110	HV2	HATTI_110	14:20	14:26	0:06	TRANSFORMER FAULT
699	26-Jun-21	GULBARGA	110	YELBURGA-PRPJSLR	YELBURGA_110	19:44	20:35	0:51	LINE CLEAR AVAILED
700	26-Jun-21	GULBARGA	110	HUMNABAD-MANNAEKHELI	MANNAEKHELI_110	22:16	22:37	0:21	LINE FAULT
701	26-Jun-21	GULBARGA	66	KUDLIGI-KUDLIGI	KUDLIGI_66	10:32	17:02	6:30	LINE CLEAR AVAILED
702	27-Jun-21	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	15:31(27.06.2021)			LINE OPEN:LINE CLEAR AVAILED
703	27-Jun-21	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	22:37(27.06.2021)			LINE OPEN:LINE CLEAR AVAILED
704	27-Jun-21	GULBARGA	220	HV1	RAICHUR_220	10:15	10:46	0:31	TRANSFORMER FAULT
705	27-Jun-21	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	1:10	8:37	7:27	LINE CLEAR AVAILED
706	27-Jun-21	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	1:15	8:27	7:12	LINE CLEAR AVAILED
707	27-Jun-21	GULBARGA	220	HV2	KUDLIGI_220	11:25	11:55	0:30	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
708	27-Jun-21	GULBARGA	220	ITTAGI-NEELGUNDA	ITTAGI_220	0:00	15:10	15:10	LINE FAULT
709	27-Jun-21	GULBARGA	110	HV1	SANKLAPUR_110	3:12	3:16	0:04	TRANSFORMER FAULT
710	27-Jun-21	GULBARGA	110	GURUMITAKAL-KONKAL	KONKAL_110	6:10	6:19	0:09	LINE FAULT
711	27-Jun-21	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	5:55	6:05	0:10	LINE FAULT
712	27-Jun-21	GULBARGA	110	HV2	SRERAMANAGAR_110	11:34	12:57	1:23	LINE CLEAR AVAILED
713	27-Jun-21	GULBARGA	110	SRERAMANAGAR-SINDHANOOR	SRERAMANAGAR_110	11:25	11:30	0:05	LINE CLEAR AVAILED
714	27-Jun-21	GULBARGA	110	KOLHAR-NSSK	JANAWADA_110,NSSK SUGAR FACTORY IPP	5:39	5:45	0:06	LINE FAULT
715	27-Jun-21	GULBARGA	110	HV1	KUDITINI_110	13:54	14:03	0:09	TRANSFORMER FAULT
716	27-Jun-21	GULBARGA	110	MARAGUTTI-CLN SLR	MARAGUTTI_110	19:37	19:51	0:14	LINE FAULT
717	27-Jun-21	GULBARGA	110	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110	1:33	1:36	0:03	MAIN SUPPLY FAILURE
718	27-Jun-21	GULBARGA	110	TEKKALKOTE-ABHIMN_SLR	TEKKALKOTE_110	17:54	17:59	0:05	LINE FAULT
719	27-Jun-21	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110,SASTHAPUR_110	15:20	15:30	0:10	LINE FAULT
720	27-Jun-21	GULBARGA	110	RAJESHWAR-WARDHA_SLR	RAJESHWAR_110	17:18	23:50	6:32	LINE CLEAR AVAILED
721	27-Jun-21	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	23:05(27.06.2021)			LINE OPEN:LINE CLEAR AVAILED
722	27-Jun-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	5:53	6:05	0:12	MAIN SUPPLY FAILURE
723	27-Jun-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	NANDUR_110,GULBARGA UNIVERSITY_110	4:23	4:32	0:09	LINE FAULT
724	27-Jun-21	GULBARGA	110	SINDHANOOR-SIRGUPPA	DHADESUGUR_110,SIRAGUPPA_110,TEKKALKOTE_110	1:36	1:46	0:10	LINE FAULT
725	27-Jun-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	3:36	3:56	0:20	LINE FAULT
726	27-Jun-21	GULBARGA	110	SINDHANOOR-SIRGUPPA	DHADESUGUR_110,SIRAGUPPA_110,TEKKALKOTE_110	3:47	3:57	0:10	LINE FAULT
727	27-Jun-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	4:14	4:34	0:20	LINE FAULT
728	27-Jun-21	GULBARGA	110	SINDHANOOR-SIRGUPPA	DHADESUGUR_110,SIRAGUPPA_110,TEKKALKOTE_110	5:50	6:00	0:10	LINE FAULT
729	27-Jun-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	16:20	16:30	0:10	LINE FAULT
730	27-Jun-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	21:05	21:15	0:10	LINE FAULT
731	27-Jun-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	0:05	0:25	0:20	LINE FAULT
732	27-Jun-21	GULBARGA	110	MALLAT-BYAGWATH1	BYAGWATH1_110,VALKAMDINNI_110	2:03	2:18	0:15	LINE FAULT
733	27-Jun-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	19:13	19:23	0:10	LINE FAULT
734	27-Jun-21	GULBARGA	110	MALLAT-BYAGWATH1	BYAGWATH1_110,VALKAMDINNI_110	19:47	19:57	0:10	LINE FAULT
735	27-Jun-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	19:51	20:02	0:11	LINE FAULT
736	27-Jun-21	GULBARGA	110	MALLAT-BYAGWATH1	BYAGWATH1_110,VALKAMDINNI_110	19:58	20:10	0:12	LINE FAULT
737	27-Jun-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	22:06	22:16	0:10	LINE FAULT
738	27-Jun-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	22:22	22:32	0:10	LINE FAULT
739	27-Jun-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SIRWAR_110,ALKOD_110,BYAGWATH_110,VALKAMDINNI_110(IDLE)	1:00	1:09	0:09	LINE FAULT
740	27-Jun-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SIRWAR_110,ALKOD_110,BYAGWATH_110,VALKAMDINNI_110(IDLE)	8:50	15:10	6:20	LINE CLEAR AVAILED
741	27-Jun-21	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	8:50	9:12	0:22	LINE FAULT
742	27-Jun-21	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	13:21	13:58	0:37	LINE CLEAR AVAILED
743	27-Jun-21	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	14:35	16:10	1:35	LINE CLEAR AVAILED
744	27-Jun-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	21:53	21:59	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
745	27-Jun-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SIRWAR_110,ALKOD_110,BYAGA WATH_110,VALKAMDINNI_110(IDLE)	23:32	23:37	0:05	LINE FAULT
746	27-Jun-21	GULBARGA	110	HATTI-GMSH	HATTI_110	5:58	6:08	0:10	LINE FAULT
747	27-Jun-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	20:04	20:10	0:06	LINE FAULT
748	27-Jun-21	GULBARGA	110	SEDAM-ULTRATECHCEMENTS_IPP	SEDAM_220	5:45	5:50	0:05	LINE FAULT
749	27-Jun-21	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITAKAL_110	6:03	6:10	0:07	LINE FAULT
750	27-Jun-21	GULBARGA	110	SEDAM-ULTRATECHCEMENTS_IPP	SEDAM_220	6:30	8:38	2:08	LINE FAULT
751	27-Jun-21	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110, KURUGOD_110,SHATVAHANA_IPP ,AGARWAL_IPP,SUZLON_IPP,KAM ALAPUR_110,RBNS FACTORY,MATRI_110	3:37	3:45	0:08	LINE FAULT
752	27-Jun-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	6:16	6:21	0:05	LINE FAULT
753	27-Jun-21	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110,GULBARGA SOUTH_110	5:30	5:45	0:15	LINE FAULT
754	27-Jun-21	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,MGSSK_IPP,BHALKI SUGAR_IPP	23:15	23:20	0:05	LINE FAULT
755	27-Jun-21	GULBARGA	110	HUMNABAD-MANNAEKHELI	MANNAEKHELI_110	10:02	14:48	4:46	LINE CLEAR AVAILED
756	27-Jun-21	GULBARGA	110	HUMNABAD-MANNAEKHELI	MANNAEKHELI_110	19:53	20:11	0:18	LINE FAULT
757	27-Jun-21	GULBARGA	110	YELBURGA-PRPJSLR	YELBURGA_110	4:45	4:59	0:14	LINE CLEAR AVAILED
758	27-Jun-21	GULBARGA	110	YELBURGA-PRPJSLR	YELBURGA_110	11:50	12:21	0:31	LINE CLEAR AVAILED
759	27-Jun-21	GULBARGA	110	YELBURGA-PRPJSLR	YELBURGA_110	12:31	12:47	0:16	LINE CLEAR AVAILED
760	27-Jun-21	GULBARGA	66	ITTAGI-SUZLON2_IPP	ITTAGI_220	13:25	15:12	1:47	LINE FAULT
761	27-Jun-21	GULBARGA	66	ITTAGI-SUZLON1_IPP	ITTAGI_220	14:30	15:12	0:42	LINE FAULT
762	28-Jun-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
763	28-Jun-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
764	28-Jun-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
765	28-Jun-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
766	28-Jun-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
767	28-Jun-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
768	28-Jun-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
769	28-Jun-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
770	28-Jun-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
771	28-Jun-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
772	28-Jun-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
773	28-Jun-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	13:36 (23.06.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
774	28-Jun-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVALIED
775	28-Jun-21	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	15:58 (27.06.2021)	7:30 (28.06.2021)	15:32HRS	TRANSFORMER CHARGED
776	28-Jun-21	BAGALKOT	220	220/110KV,HV2,LV2	BIJAPUR_220	14:45	15:33	0:48	LINE CLEAR AVALIED
777	28-Jun-21	BAGALKOT	110	BIJAPUR220- ENERCON(BAGEWADI)	BIJAPUR_220	14:21	14:36	0:15	LINE FAULT
778	28-Jun-21	BAGALKOT	110	110/11KV,HV3(HV2)	SOUDATTI_110	18:52	19:31	0:39	LINE CLEAR AVALIED
779	28-Jun-21	BAGALKOT	110	(KIRVATTI) AMBEWADI- UMMACHAGI	STATION NOT AFFECTED UMMACHAGI_110	8:49 (28.6.2021)			LINE OPEN:LINE CLEAR AVALIED
780	28-Jun-21	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED AMBEWADI_220	17:28	17:31	0:03	TRANSFORMER FAULT
781	28-Jun-21	BAGALKOT	110	110/11KV,HV2	LAKAMANAHALLI_110	20:16	20:25	0:09	TRANSFORMER FAULT
782	28-Jun-21	BAGALKOT	110	110/11KV,HV1	HUDLI_110	11:28	13:05	1:37	LINE CLEAR AVALIED
783	28-Jun-21	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED MUDDEBIHAL_110	5:52	12:05	6:13	LINE CLEAR AVALIED
784	28-Jun-21	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED MUDDEBIHAL_110	5:52	12:05	6:13	LINE CLEAR AVALIED
785	28-Jun-21	BAGALKOT	110	KN SOLAR-MUDDEBIHAL	STATION NOT AFFECTED MUDDEBIHAL_110	12:05	13:37	1:32	LINE CLEAR AVALIED
786	28-Jun-21	BAGALKOT	110	BALAJI SUGARS-MUDDEBIHAL	STATION NOT AFFECTED MUDDEBIHAL_110	5:55	13:40	7:45	LINE CLEAR AVALIED
787	28-Jun-21	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	15:48	16:32	0:44	TRANSFORMER FAULT
788	28-Jun-21	BAGALKOT	110	110/33KV, HV3	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	7:56	8:04	0:08	TRANSFORMER FAULT
789	28-Jun-21	BAGALKOT	110	110/33KV, HV3	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	14:37	18:54	4:17	LINE CLEAR AVALIED
790	28-Jun-21	BAGALKOT	110	VADAGOAN- BELGAUM	VADAGOAN_110	3:53	4:10	0:17	HAND TRIPPED
791	28-Jun-21	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	13:45	14:31	0:46	LINE FAULT
792	28-Jun-21	BAGALKOT	220	HUBLI- NAGJHARI1	HUBLI_220	10:42	16:04	5:22	LINE CLEAR AVALIED
793	28-Jun-21	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	13:47	14:30	0:43	LINE FAULT
794	28-Jun-21	BAGALKOT	110	110/33KV, HV3	SINDAGI_110, KALKERI_33	12:21	14:59	2:38	LINE CLEAR AVALIED
795	28-Jun-21	BENGALURU	66	HV3	EAST DIVISION COMPOUND	13:01	13:04	0:03	LINE CLEAR AVALIED
796	28-Jun-21	BENGALURU	66	GOLF LINK ROAD - HAL 220	GOLF LINK ROAD	12:10	12:15	0:05	LOAD CHANGEOVER
797	28-Jun-21	BENGALURU	66	HV2	AMAR JYOTHI	11:05	11:15	0:10	LOAD CHANGEOVER
798	28-Jun-21	BENGALURU	66	HV1	AMAR JYOTHI	11:12	11:20	0:08	LOAD CHANGEOVER
799	28-Jun-21	BENGALURU	66	HV1	LEELA VENTURE	4:15	4:35	0:20	TRANSFORMER FAULT
800	28-Jun-21	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	15:13	15:36	0:23	LOAD CHANGEOVER
801	28-Jun-21	BENGALURU	66	HV1	NIMHANS 220	12:24	12:25	0:01	LINE CLEAR AVALIED
802	28-Jun-21	BENGALURU	66	TADIGOL - CHINTAMANI 220	TAGIGOL , LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI	20:50	21:00	0:10	LINE FAULT
803	28-Jun-21	BENGALURU	66	HV2	TADIGOL	12:10	13:30	1:20	LINE CLEAR AVALIED
804	28-Jun-21	BENGALURU	66	JIGANI LINK ROAD - SOMANHALLI 220	JIGANI LINK ROAD	21:10	21:20	0:10	LOAD CHANGEOVER
805	28-Jun-21	BENGALURU	66	HV1	KYALANUR	11:59	12:05	0:05	LINE CLEAR AVALIED
806	28-Jun-21	BENGALURU	66	HV1	KANAKAPURA 66	12:04	12:10	0:05	LINE CLEAR AVALIED
807	28-Jun-21	BENGALURU	66	HV2	JANGAMKOTE	18:23	18:41	0:17	LINE CLEAR AVALIED
808	28-Jun-21	BENGALURU	66	HV2	DODDABELAVANGALA	10:50	12:05	1:14	LINE CLEAR AVALIED
809	28-Jun-21	BENGALURU	66	HV1	BANGARPET	16:29	16:43	0:14	TRANSFORMER FAULT
810	28-Jun-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:27	11:30	0:02	LINE CLEAR AVALIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
811	28-Jun-21	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	12:03	12:13	0:09	LINE FAULT
812	28-Jun-21	BENGALURU	66	HV1	PATH PALYA	14:37	15:23	0:45	LINE CLEAR AVAILED
813	28-Jun-21	BENGALURU	66	GOWRIBIDANUR 220 - MANCHENAHALLI	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	21:10	21:19	0:08	LINE CLEAR AVAILED
814	28-Jun-21	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	14:30:32(18-6-2021)	13:32(28-6-2021)	239:01HRS	LINE CHARGED
815	28-Jun-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
816	28-Jun-21	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
817	28-Jun-21	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	18:36:16(28-6-2021)			LINE OPEN:LINE FAULT
818	28-Jun-21	BENGALURU	66	HV2	MAASTI	10:15:06(26-6-2021)	17:33:36(28-6-2021)	31:17HRS	TRANSFORMER CHARGED
819	28-Jun-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	23:43(28.06.2021			LINE OPEN:LINE CLEAR AVAILED
820	28-Jun-21	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	15:31(27.06.2021)	6:40(28.06.2021)	15:09HRS	LINE CHARGED
821	28-Jun-21	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	22:37(27.06.2021)	6:45(28.06.2021)	8:08HRS	LINE CHARGED
822	28-Jun-21	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	13:30(27.06.2021)	6:44(28.06.2021)	17:14HRS	LINE CHARGED
823	28-Jun-21	GULBARGA	220	LINGASUGUR-RTPS1	BAGEWADI_220	3:42	4:17	0:35	MAIN SUPPLY FAILURE
824	28-Jun-21	GULBARGA	220	LINGASUGUR-RTPS2	BAGEWADI_220	5:22	5:44	0:22	MAIN SUPPLY FAILURE
825	28-Jun-21	GULBARGA	110	KOLHAR-NSSK	JANAWADA_110,NSSK SUGAR FACTORY_ IPP	5:27	5:30	0:03	LINE FAULT
826	28-Jun-21	GULBARGA	110	HV1	KUDITINI_110	3:45	3:54	0:09	TRANSFORMER FAULT
827	28-Jun-21	GULBARGA	110	HV1	KUDITINI_110	6:00	7:03	1:03	LINE CLEAR AVAILED
828	28-Jun-21	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	4:00	4:25	0:25	MAIN SUPPLY FAILURE
829	28-Jun-21	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	5:20	5:30	0:10	MAIN SUPPLY FAILURE
830	28-Jun-21	GULBARGA	110	SINDHANOOR110-MUDDAPURA	MUDDAPURA_110	3:15	3:20	0:05	LINE FAULT
831	28-Jun-21	GULBARGA	110	HV2	SINDHANOOR_110	6:55	7:05	0:10	TRANSFORMER FAULT
832	28-Jun-21	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	23:05(27.06.2021)	00:05(28.06.2021)	1:00HRS	LINE CHARGED
833	28-Jun-21	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110,SASTHAPUR_110	5:25	5:30	0:05	LINE FAULT
834	28-Jun-21	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	6:53	7:00	0:07	MAIN SUPPLY FAILURE
835	28-Jun-21	GULBARGA	110	SEDAM-VCATSAGAR_ IPP	SEDAM_220	5:12	5:34	0:22	LINE FAULT
836	28-Jun-21	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	6:03	6:20	0:17	LINE FAULT
837	28-Jun-21	GULBARGA	110	BENUR-YERADONA	BENUR_110	10:00	17:45	7:45	LINE CLEAR AVAILED
838	28-Jun-21	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	0:20	3:20	3:00	LINE FAULT
839	28-Jun-21	GULBARGA	110	HV3	HATTI_110	0:20	0:47	0:27	TRANSFORMER FAULT
840	28-Jun-21	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	21:52	22:55	1:03	LINE CLEAR AVAILED
841	28-Jun-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	0:01	0:11	0:10	LINE FAULT
842	28-Jun-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SIRWAR_110,ALKOD_110,BYAGA WATH_110,VALKAMDINNI_110(IDLE)	12:17	12:25	0:08	MAIN SUPPLY FAILURE
843	28-Jun-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	4:53	5:01	0:08	MAIN SUPPLY FAILURE
844	28-Jun-21	GULBARGA	110	RAICHUR- JURALA2(IDLE LINE)	KURDICROSS_110,MADLAPUR_110,MANVI_110	10:30	21:00	10:30	NFBC ISSUED
845	28-Jun-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	19:03	19:11	0:08	MAIN SUPPLY FAILURE
846	28-Jun-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:33	21:10	0:37	MAIN SUPPLY FAILURE
847	28-Jun-21	GULBARGA	110	RAICHUR -MALIYABAD	KURDICROSS_110,MADLAPUR_110,MANVI_110	20:46	21:05	0:19	MAIN SUPPLY FAILURE
848	28-Jun-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	21:35	21:53	0:18	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
849	28-Jun-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SIRWAR_110,ALKOD_110,BYAGA WATH_110,VALKAMDINNI_110(IDLE)	22:05	22:10	0:05	MAIN SUPPLY FAILURE
850	28-Jun-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	23:06	23:16	0:10	MAIN SUPPLY FAILURE
851	28-Jun-21	GULBARGA	110	HV1	JANAWADA_110	13:00	13:25	0:25	LINE CLEAR AVAILED
852	28-Jun-21	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANAGAVATHI_110,SRNAGAR,KARTAGI_110	13:20	14:32	1:12	LINE CLEAR AVAILED
853	28-Jun-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	17:45	17:55	0:10	MAIN SUPPLY FAILURE
854	28-Jun-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	23:25	23:45	0:20	MAIN SUPPLY FAILURE
855	28-Jun-21	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP	5:21	5:30	0:09	MAIN SUPPLY FAILURE
856	28-Jun-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	6:11	6:22	0:11	MAIN SUPPLY FAILURE
857	28-Jun-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	18:55	19:03	0:08	MAIN SUPPLY FAILURE
858	28-Jun-21	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	4:02	4:08	0:06	MAIN SUPPLY FAILURE
859	28-Jun-21	GULBARGA	110	HUMNABAD-SASTHAPUR	RAJESHWAR_110,MANTHAL_110,SASTHAPUR_110	23:59(27.06.2021)	00:05(28.06.2021)	0:06HRS	LINE CHARGED
860	28-Jun-21	GULBARGA	110	CHINCHOLI-SEDAM,MANEKHALLI	CHINCHOLI_110	10:38	14:55	4:17	LINE CLEAR AVAILED
861	28-Jun-21	GULBARGA	110	HV1 & HV2	CHINCHOLI_110	10:38	14:55	4:17	LINE CLEAR AVAILED
862	28-Jun-21	GULBARGA	66	KOTTUR-UJJANI	UJJANI_66	12:55	15:05	2:10	LINE CLEAR AVAILED
863	28-Jun-21	GULBARGA	66	BANVEKAL-SLRSYS	BANAVEKAL_66	13:15	13:40	0:25	LINE FAULT
864	28-Jun-21	GULBARGA	66	HV2	KOGALI_66	9:25	9:30	0:05	TRANSFORMER FAULT
865	28-Jun-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:09(25.06.2021)	11:46 (28.06.2021)	67:36 hrs	LINE CHARGED
866	28-Jun-21	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	22:51(27.06.2021)	10:47(28.06.2021)	11:54 hrs	LINE CHARGED
867	28-Jun-21	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN:LINE CLEAR AVAILED
868	28-Jun-21	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN:LINE CLEAR AVAILED
869	28-Jun-21	HASSAN	110	HV1	SHIKARIPURA_110	15:20 (22.06.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
870	28-Jun-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	13:35	14:11	0:36	LINE FAULT
871	28-Jun-21	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	13:34	14:11	0:37	LINE FAULT
872	28-Jun-21	HASSAN	220	HV1	SHIRALKOPPA_220	15:57	18:09	2:12	LINE CLEAR AVAILED
873	28-Jun-21	HASSAN	110	HV2	BHADRAVATHI_110	19:47	20:33	0:46	LINE CLEAR AVAILED
874	28-Jun-21	HASSAN	110	HV2	BHADRAVATHI_110	20:47	21:09	0:22	LINE CLEAR AVAILED
875	28-Jun-21	HASSAN	110	BRAHMAVA-MANIPAL	BRAHMAVA	15:45	16:01	0:16	MAIN SUPPLY FAILURE
876	28-Jun-21	HASSAN	110	KEMAR-Manipal2	KEMAR_220	13:50	14:08	0:18	LINE FAULT
877	28-Jun-21	HASSAN	110	KEMAR-Manipal2	KEMAR_220	16:32	19:14	2:42	LINE CLEAR AVAILED
878	28-Jun-21	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	15:45	16:01	0:16	MAIN SUPPLY FAILURE
879	28-Jun-21	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	15:45	16:01	0:16	MAIN SUPPLY FAILURE
880	28-Jun-21	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	15:45	16:01	0:16	MAIN SUPPLY FAILURE
881	28-Jun-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	13:48	14:00	0:12	HAND TRIPPED
882	28-Jun-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	15:30	16:02	0:32	LINE FAULT
883	28-Jun-21	HASSAN	110	MANIPAL-KEMAR2	MANIPAL_110	15:45	19:10	3:25	LINE FAULT
884	28-Jun-21	HASSAN	110	HV2	NITTUR_110	15:44	17:46	2:02	LINE CLEAR AVAILED
885	28-Jun-21	HASSAN	110	NITUR110-MANIPAL	NITUR110	15:44	16:07	0:23	MAIN SUPPLY FAILURE
886	28-Jun-21	HASSAN	110	NITUR110-MANIPAL	NITTUR_110	13:52	14:00	0:08	MAIN SUPPLY FAILURE
887	28-Jun-21	HASSAN	110	NITUR110-MANIPAL	NITTUR_110	15:33	15:43	0:10	MAIN SUPPLY FAILURE
888	28-Jun-21	HASSAN	110	LV1	SHIRALKOPPA_220	15:55	18:09	2:14	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
889	28-Jun-21	HASSAN	66	CHANNARA-CRPATNA2	CHANNARAYAPATNA_66	15:29	17:33	2:04	LINE CLEAR AVAILED
890	28-Jun-21	HASSAN	66	CHANNARA-MALLALI	CHANNARAYAPATNA_66	17:35	17:40	0:05	HAND TRIPPED
891	28-Jun-21	HASSAN	66	HV1	GANGUR_66	12:25	12:40	0:15	LINE CLEAR AVAILED
892	28-Jun-21	HASSAN	66	ANAVATI-BARNGI	ANAVATTI_110	12:35	13:45	1:10	LINE CLEAR AVAILED
893	28-Jun-21	MYSURU	66	HV1	BANNUR_66	13:00	13:21	0:21	LINE CLEAR AVAILED
894	28-Jun-21	MYSURU	66	HV2	BANNUR_66	18:58	19:40	0:42	TRANSFORMER FAULT
895	28-Jun-21	MYSURU	66	HV2	DUNDANAHALLI_66	22:18	23:00	0:41	HAND TRIPPED
896	28-Jun-21	MYSURU	66	ELWALA-HUNSUR	GAVADAGERE_66	17:28	17:43	0:15	LINE FAULT
897	28-Jun-21	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
898	28-Jun-21	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
899	28-Jun-21	TUMKUR	66	ANCHEPALYA 220kv- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	11:53	12:13	0:19	HAND TRIPPED
900	28-Jun-21	TUMKUR	66	ANCHEPALYA 220kv- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66	16:40	17:04	0:24	LINE FAULT
901	28-Jun-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:05	6:17	0:12	LINE FAULT
902	28-Jun-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	8:55	9:06	0:11	LINE FAULT
903	28-Jun-21	TUMKUR	66	TR-1	HIRIYUR_66	8:54	9:03	0:09	TRANSFORMER FAULT
904	28-Jun-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	13:11	14:28	1:17	LINE FAULT
905	28-Jun-21	TUMKUR	66	TR-1	HOLALKERE_66	15:15	18:25	3:09	LINE CLEAR AVAILED
906	28-Jun-21	TUMKUR	66	TR-2	HOLALKERE_66	15:15	17:45	2:29	LINE CLEAR AVAILED
907	28-Jun-21	TUMKUR	66	TR-3	HOLALKERE_66	10:47	11:30	0:42	LINE CLEAR AVAILED
908	28-Jun-21	TUMKUR	66	HULIYURDURGA- ANCHEPALYA220	HULIYURDURGA_66	22:20	22:45	0:25	LINE FAULT
909	28-Jun-21	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	NIDSALE_66,DUNDANAHALLI_66	22:20	22:48	0:28	LINE FAULT
910	28-Jun-21	TUMKUR	66	LOKEKERE-TYAVANAGI	LOKEKERE_66	6:05	6:19	0:14	LINE FAULT
911	28-Jun-21	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	17:35	21:04	3:29	LINE CLEAR AVAILED
912	28-Jun-21	TUMKUR	66	NIDASALE-DUNDANAHALLI	NIDASALE_66	22:20	22:57	0:37	LINE FAULT
913	28-Jun-21	TUMKUR	66	PULAMGHATTA-MADHUGIRI	PULAMGHATTA_66	17:38	21:20	3:42	MAIN SUPPLY FAILURE
914	28-Jun-21	TUMKUR	66	TR-1	PAVAGADA_220	19:11	19:19	0:07	TRANSFORMER FAULT
915	28-Jun-21	TUMKUR	66	THOVINAKERE-KORA	THOVINAKERE_66	5:05	5:29	0:24	LINE FAULT
916	28-Jun-21	TUMKUR	66	THOVINAKERE-KORA	THOVINAKERE_66	18:06	18:37	0:31	LINE FAULT
917	28-Jun-21	TUMKUR	66	TR-2	URDIGERE_66	11:33	11:47	0:13	LINE CLEAR AVAILED
918	28-Jun-21	TUMKUR	66	TR1	YEDIYUR_66	16:35	17:19	0:43	LINE CLEAR AVAILED
919	28-Jun-21	TUMKUR	66	TR-2	YEDIYUR_66	16:50	17:31	0:41	LINE CLEAR AVAILED