

400/220/110/66 kV TRANSMISSION OUTAGES FROM 17.05.2022 TO 23.05.2022

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|-----------------------------------|---|-----------------------|-----------------------|------------|-------------------------------------|
| 1 | 17-May-2022 | BAGALKOT | 220 | GADAG-HARTHI2 | STATION NOT AFFECTED GADAG_220 | 13:13 (03.03.2022) | 14:32 (17.05.2022) | 1801:19HRS | LINE CHARGED |
| 2 | 17-May-2022 | BAGALKOT | 110 | PG HUNSHYAL-MUDALAGI (NAGANUR) | STATION NOT AFFECTED PG HUNSHYAL_110 | 16:13 (04.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 3 | 17-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED LAXMESHVAR_110 | 17:55 (28.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 4 | 17-May-2022 | BAGALKOT | 110 | AMBEWADI- NK1 (KAVALWADA) | STATION NOT AFFECTED AMBEWADI_220 | 9:30 (09.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 5 | 17-May-2022 | BAGALKOT | 110 | AMBEWADI- NK2 (HALIYAL) | STATION NOT AFFECTED AMBEWADI_220 | 9:33 (09.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 6 | 17-May-2022 | BAGALKOT | 110 | BASAVANAKATTI-GUTTAL | STATION NOT AFFECTED BASAVANAKATTI_110 | 16:57 (16.05.2022) | 9:10 (17.05.2022) | 16:13hrs | LINE CHARGED |
| 7 | 17-May-2022 | BAGALKOT | 110 | SIRSI1-KUMTA | STATION NOT AFFECTED KUMTA_110 | 22:08 (16.05.2022) | 6:03 (17.05.2022) | 7:57hrs | LINE CHARGED |
| 8 | 17-May-2022 | BAGALKOT | 110 | SIRSI2-KUMTA | STATION NOT AFFECTED KUMTA_110 | 21:18 (16.05.2022) | 6:03 (17.05.2022) | 8:45hrs | LINE CHARGED |
| 9 | 17-May-2022 | BAGALKOT | 110 | SIRSI-KUMTA2 | STATION NOT AFFECTED SIRSI_110 | 21:19 (16.05.2022) | 1:20 (17.05.2022) | 4:01hrs | LINE CHARGED |
| 10 | 17-May-2022 | BAGALKOT | 220 | BELGAUM- AEQUS1 | STATION NOT AFFECTED BELGAUM_220 | 10:39 (16.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 11 | 17-May-2022 | BAGALKOT | 220 | HAVERI- GUTTUR2 | STATION NOT AFFECTED HAVERI_220 | 17:56 (16.05.2022) | | | LINE OPEN,LINE FAULT |
| 12 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | AIGALI_110 | 5:16 | 5:29 | 0:13 | TRANSFORMER FAULT |
| 13 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | ALMEL_110 | 15:18 | 19:47 | 4:29 | LINE CLEAR AVAILED |
| 14 | 17-May-2022 | BAGALKOT | 110 | ALMEL- KPR SUGARS | ALMEL_110 | 18:31 | 18:36 | 0:05 | LINE FAULT |
| 15 | 17-May-2022 | BAGALKOT | 110 | ALMEL- JAMKHANDI SUGARS | ALMEL_110 | 18:31 | 18:36 | 0:05 | LINE FAULT |
| 16 | 17-May-2022 | BAGALKOT | 110 | BAGEWADI (HIREMASALI)- ATHARGA | STATION NOT AFFECTED ATHARGA_110 | 20:04 (17.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 17 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | BABLESHWAR_110 | 14:37 | 17:00 | 2:23 | LINE CLEAR AVAILED |
| 18 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV4 | BAILHONGAL_110 | 18:40 | 19:00 | 0:20 | TRANSFORMER FAULT |
| 19 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | BEDI_110 | 11:40 | 12:48 | 1:08 | LINE CLEAR AVAILED |
| 20 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | THORVI_110 | 12:43 | 12:45 | 0:02 | TRANSFORMER FAULT |
| 21 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | CHIKKODI_110 | 18:56 | 19:09 | 0:13 | TRANSFORMER FAULT |
| 22 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | DEVARGENNUR_110 | 19:09 | 20:11 | 1:02 | TRANSFORMER FAULT |
| 23 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | GARAG_110 | 15:00 | 15:12 | 0:12 | HAND TRIPPED |
| 24 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | GARAG_110 | 15:00 | 15:11 | 0:11 | HAND TRIPPED |
| 25 | 17-May-2022 | BAGALKOT | 110 | 110/33KV, HV3 | HIDIKAL_110, KOLIGUDDA_33, MYTRA SOLAR_33 | 20:56 | 21:03 | 0:07 | TRANSFORMER FAULT |
| 26 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | HALKI_110 | 18:15 | 18:19 | 0:04 | TRANSFORMER FAULT |
| 27 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | HALKI_110 | 22:12 | 22:16 | 0:04 | TRANSFORMER FAULT |
| 28 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | HALKI_110 | 22:18 | 22:21 | 0:03 | TRANSFORMER FAULT |
| 29 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | HIREMASALI_110 | 17:04 | 17:15 | 0:11 | TRANSFORMER FAULT |
| 30 | 17-May-2022 | BAGALKOT | 110 | HIREMASALI- F2(ATHARGA) | STATION NOT AFFECTED HIREMASALI_110 | 20:54 (17.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 31 | 17-May-2022 | BAGALKOT | 110 | ITANAL- BPCL | STATION NOT AFFECTED ITANAL_110 | 21:56 | 22:11 | 0:15 | LINE FAULT |
| 32 | 17-May-2022 | BAGALKOT | 110 | KAGAWADA- SHIRAGUPPI SUGARS | KAGAWAD_110 | 13:20 | 13:54 | 0:34 | HAND TRIPPED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|---------------------------------|---|-----------------------|-----------------------|-----------|-------------------------------------|
| 33 | 17-May-2022 | BAGALKOT | 110 | KADANKOPPA- KAVALWADA | STATION NOT AFFECTED KADANKOPPA_110 | 9:48 | 10:55 | 1:07 | LINE FAULT |
| 34 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV4 | KERUR_110 | 19:03 | 19:14 | 0:11 | TRANSFORMER FAULT |
| 35 | 17-May-2022 | BAGALKOT | 110 | KULIGERI CROSS- MRN SUGARS | KULIGERI CROSS_110 | 18:36 | 18:39 | 0:03 | LINE FAULT |
| 36 | 17-May-2022 | BAGALKOT | 110 | KULIGOD- GAMESHA | KULIGOD_110 | 21:29 | 21:42 | 0:13 | LINE FAULT |
| 37 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | MALGHAN(B)_110 | 16:59 | 19:00 | 2:01 | LINE CLEAR AVAILED |
| 38 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | MK HUBLI_110, GANDIVAD_33, ACHME SOLAR_33 | 15:40 | 16:18 | 0:38 | TRANSFORMER FAULT |
| 39 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | MUNDAGOD_110 | 12:11 | 13:50 | 1:39 | LINE CLEAR AVAILED |
| 40 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | NAVANAGAR(B)_110 | 15:53 | 16:01 | 0:08 | HAND TRIPPED |
| 41 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV3 | RATTIHALI_110 | 19:03 | 19:07 | 0:04 | TRANSFORMER FAULT |
| 42 | 17-May-2022 | BAGALKOT | 110 | RON- GAJENDRAGAD1 | STATION NOT AFFECTED RON_110 | 23:21 (17.05.2022) | | | LINE OPEN,LINE FAULT |
| 43 | 17-May-2022 | BAGALKOT | 110 | RON- GAJENDRAGAD2 | STATION NOT AFFECTED RON_110 | 23:21 (17.05.2022) | | | LINE OPEN,LINE FAULT |
| 44 | 17-May-2022 | BAGALKOT | 110 | SALAHALLI- GAMESHA | SALAHALLI_110 | 13:49 | 15:02 | 1:13 | LINE CLEAR AVAILED |
| 45 | 17-May-2022 | BAGALKOT | 110 | SAMBAPUR ROAD- RVNL(RAILWAY) | SAMBAPUR ROAD_110 | 20:34 | 20:38 | 0:04 | LINE FAULT |
| 46 | 17-May-2022 | BAGALKOT | 110 | 110/33KV, HV3 | SHIGGOAN_110, AMBUJA_33, SHIGGOAN_33 | 20:07 | 20:25 | 0:18 | TRANSFORMER FAULT |
| 47 | 17-May-2022 | BAGALKOT | 110 | TAKKALAKI- WARADA SOLAR | TAKKALAKI_110 | 19:55 (17.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 48 | 17-May-2022 | BAGALKOT | 110 | YLWD-F2 Cbreaker(SAVALAGI) | YELAMANAWADI_110 | 9:05 | 18:48 | 9:43 | LINE CLEAR AVAILED |
| 49 | 17-May-2022 | BAGALKOT | 110 | 110/33KV, HV3 | ONTIGODI_33, YADWAD_33,YADWAD_110 | 16:50 | 17:08 | 0:18 | TRANSFORMER FAULT |
| 50 | 17-May-2022 | BAGALKOT | 110 | UKLI-F2 Cbreaker(BB 220) | UKKALI_110 | 19:34 (17.05.2022) | | | LINE OPEN,LINE FAULT |
| 51 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV1&HV2 | STATION NOT AFFECTED TODALBAGI_110 | 15:03 | 15:35 | 0:32 | LINE CLEAR AVAILED |
| 52 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | TERDAL_110 | 21:55 (4.05.2022) | 16:39 (17.05.2022) | 306:44hrs | TRANSFORMER CHARGED |
| 53 | 17-May-2022 | BAGALKOT | 220 | BELGAUM-CHIKKODI2 | BELGAUM_220 | 9:37 | 16:05 | 6:28 | HAND TRIPPED |
| 54 | 17-May-2022 | BAGALKOT | 220 | GHATAPRABHA-NARENDRA2 | STATION NOT AFFECTED GHATAPRABHA_220 | 20:13 (17.05.2022) | | | LINE OPEN,LINE FAULT |
| 55 | 17-May-2022 | BAGALKOT | 220 | 220/110KV,HV1,LV1 | STATION NOT AFFECTED GHATAPRABHA_220 | 20:13 (17.05.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 56 | 17-May-2022 | BAGALKOT | 220 | GHATAPRABHA- MUGALKHOD1 | STATION NOT AFFECTED GHATAPRABHA_220 | 21:03 | 23:06 | 2:03 | LINE FAULT |
| 57 | 17-May-2022 | BAGALKOT | 220 | GHATAPRABHA- MUGALKHOD2 | STATION NOT AFFECTED GHATAPRABHA_220 | 21:03 (17.05.2022) | | | LINE OPEN,LINE FAULT |
| 58 | 17-May-2022 | BAGALKOT | 110 | GHATAPRABHA-GOKAK | STATION NOT AFFECTED GHATAPRABHA_220 | 21:35 | 22:18 | 0:43 | LINE FAULT |
| 59 | 17-May-2022 | BAGALKOT | 220 | HUBLI-SIRSI1 | STATION NOT AFFECTED HUBLI_220 | 11:52 | 14:14 | 2:22 | LINE CLEAR AVAILED |
| 60 | 17-May-2022 | BAGALKOT | 220 | HUBLI-SIRSI2 | STATION NOT AFFECTED HUBLI_220 | 11:50 | 14:10 | 2:20 | LINE CLEAR AVAILED |
| 61 | 17-May-2022 | BAGALKOT | 220 | KADRA-KARWAR1 | STATION NOT AFFECTED KARWAR_220 | 13:05 | 19:35 | 6:30 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|----------------------------|---|-----------------------|-----------|----------|-------------------------------------|
| 62 | 17-May-2022 | BAGALKOT | 110 | 220/110KV,LV2,LV1 | STATION NOT AFFECTED KARWAR_220 | 12:53 | 19:42 | 6:49 | LINE CLEAR AVAILED |
| 63 | 17-May-2022 | BAGALKOT | 110 | KARWAR-ARGA(KUMTA) | STATION NOT AFFECTED KARWAR_220 | 1:12 | 1:14 | 0:02 | HAND TRIPPED |
| 64 | 17-May-2022 | BAGALKOT | 110 | KARWAR-BINAGA | STATION NOT AFFECTED KARWAR_220 | 12:53 | 12:59 | 0:06 | HAND TRIPPED |
| 65 | 17-May-2022 | BAGALKOT | 110 | KARWAR-BINAGA | STATION NOT AFFECTED KARWAR_220 | 14:46 | 15:10 | 0:24 | LINE CLEAR AVAILED |
| 66 | 17-May-2022 | BAGALKOT | 220 | BAGALKOT - GADAG1 | STATION NOT AFFECTED BAGAKOT_220 | 19:07 | 19:47 | 0:40 | LINE FAULT |
| 67 | 17-May-2022 | BAGALKOT | 110 | 110/33KV,HV2 | KATAGERI_33,GADDANAKER I_33 BAGAKOT_220 | 18:12 | 18:30 | 0:18 | TRANSFORMER FAULT |
| 68 | 17-May-2022 | BAGALKOT | 220 | MUGALKHOD- GHATAPRABHA2 | STATION NOT AFFECTED MUGALKHOD_220 | 21:03(17.5.22) | | | LINE OPEN,LINE FAULT |
| 69 | 17-May-2022 | BAGALKOT | 220 | MUGALKHOD-RAIBAG1 | MUGALKHOD_220 | 21:03 | 21:34 | 0:31 | LINE FAULT |
| 70 | 17-May-2022 | BAGALKOT | 220 | MUGALKHOD-RAIBAG2 | MUGALKHOD_220 | 21:03 | 21:35 | 0:32 | LINE FAULT |
| 71 | 17-May-2022 | BAGALKOT | 110 | RANEBENNUR-HIREKERUR | HIREKERUR_110 | 5:35 | 5:45 | 0:10 | LINE FAULT |
| 72 | 17-May-2022 | BAGALKOT | 220 | CHIKKODI-MUGALKHOD1 | CHIKKODI_220 | 21:05 | 21:25 | 0:20 | LINE FAULT |
| 73 | 17-May-2022 | BAGALKOT | 220 | CHIKKODI-MUGALKHOD2 | CHIKKODI_220 | 21:05 | 21:25 | 0:20 | LINE FAULT |
| 74 | 17-May-2022 | BAGALKOT | 220 | AEQUS-CHIKKODI1 | AEQUS_220 | 9:24 | 10:36 | 1:12 | HAND TRIPPED |
| 75 | 17-May-2022 | BAGALKOT | 220 | BAGEWADI-RBRK | BAGEWADI_220 | 18:24 | 18:53 | 0:29 | LINE FAULT |
| 76 | 17-May-2022 | BAGALKOT | 220 | BIDNAL-HARTHI1 | BIDNAL_220 | 11:20 | 16:09 | 4:49 | LINE CLEAR AVAILED |
| 77 | 17-May-2022 | BAGALKOT | 220 | BIDNAL-HARTHI2 | BIDNAL_220 | 11:20 | 16:10 | 4:50 | LINE CLEAR AVAILED |
| 78 | 17-May-2022 | BAGALKOT | 220 | BIDNAL-TADASA1 | BIDNAL_220 | 17:53 | 18:08 | 0:15 | HAND TRIPPED |
| 79 | 17-May-2022 | BAGALKOT | 220 | BIDNAL-TADASA2 | BIDNAL_220 | 17:52 (17.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 80 | 17-May-2022 | BAGALKOT | 110 | HAVERI-SAVANUR | HAVERI_220 | 23:31 (17.05.2022) | | | LINE OPEN,LINE FAULT |
| 81 | 17-May-2022 | BAGALKOT | 220 | GADAG-BAGALKOT1 | GADAG_220 | 19:08 | 19:45 | 0:37 | LINE FAULT |
| 82 | 17-May-2022 | BAGALKOT | 110 | SHIRAHATTI-BPCL2 | STATION NOT AFFECTED SHIRAHATTI_110 | 16:40 (27.04.2022) | | | LINE OPEN,LINE FAULT |
| 83 | 17-May-2022 | BAGALKOT | 220 | SIRSI- HUBLI1 | STATION NOT AFFECTED SIRSI_220 | 15:26 (13.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 84 | 17-May-2022 | BAGALKOT | 220 | SIRSI- HUBLI2 | STATION NOT AFFECTED SIRSI_220 | 15:26 (13.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 85 | 17-May-2022 | BAGALKOT | 220 | NARENDRA- BELGAUM1 | STATION NOT AFFECTED NARENDRA_220 | 9:01 (14.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 86 | 17-May-2022 | BAGALKOT | 220 | BELGAUM- NARENDRA1 | STATION NOT AFFECTED BELGAUM_220 | 9:01 (14.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 87 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | UKKALI_110 | 19:34 (17.05.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 88 | 17-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | TERDAL_110 | 10:20 | 10:50 | 0:30 | LINE CLEAR AVAILED |
| 89 | 17-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | MAREGUDDI_110 | 9:50 | 13:55 | 4:05 | LINE CLEAR AVAILED |
| 90 | 17-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | MAREGUDDI_110 | 14:05 | 14:30 | 0:25 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--------------------------------------|---|---------|-----------|----------|--------------------|
| 91 | 17-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | MAREGUDDI_110 | 10:40 | 10:50 | 0:10 | LINE CLEAR AVAILED |
| 92 | 17-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | MAREGUDDI_110 | 12:45 | 12:50 | 0:05 | LINE CLEAR AVAILED |
| 93 | 17-May-2022 | BAGALKOT | 110 | INDI-DEVAR HIPPARAGI | INDI_220 | 17:50 | 17:56 | 0:06 | LINE FAULT |
| 94 | 17-May-2022 | BAGALKOT | 110 | INDI-DEVAR HIPPARAGI | INDI_220 | 18:16 | 18:21 | 0:05 | LINE FAULT |
| 95 | 17-May-2022 | BENGALURU | 66 | HV2 | APPAREL PARK | 22:01 | 23:10 | 1:09 | TRANSFORMER FAULT |
| 96 | 17-May-2022 | BENGALURU | 66 | HV3 | BIDADI 220 | 19:22 | 19:55 | 0:33 | TRANSFORMER FAULT |
| 97 | 17-May-2022 | BENGALURU | 220 | HV2 | HAL 220 | 22:10 | 23:15 | 1:05 | TRANSFORMER FAULT |
| 98 | 17-May-2022 | BENGALURU | 66 | KENGERI SATELLITE TOWN - KUMBALAGODU | CHANDRAPPA CIRCLE | 20:20 | 21:20 | 1:00 | LINE FAULT |
| 99 | 17-May-2022 | BENGALURU | 66 | KORAMANGALA 220 - ADUGODI 1 | NO STATION AFFECTED | 22:16 | 23:38 | 1:22 | LINE FAULT |
| 100 | 17-May-2022 | BENGALURU | 66 | HV1 | MATHIKERE | 20:44 | 20:54 | 0:10 | TRANSFORMER FAULT |
| 101 | 17-May-2022 | BENGALURU | 66 | REMC0 - NRS | VIJAYANAGARA | 8:17 | 8:27 | 0:10 | LINE FAULT |
| 102 | 17-May-2022 | BENGALURU | 66 | NRS 220 - MYSORE ROAD 1 | VIJAYANAGARA | 11:06 | 11:08 | 0:02 | LINE CLEAR AVAILED |
| 103 | 17-May-2022 | BENGALURU | 66 | SOMANAHALLI 220 - JIGANI 2 | BG ROAD, JIGANI LINK ROAD, KIRLOSKAR(EHT) | 19:58 | 20:24 | 0:26 | LINE FAULT |
| 104 | 17-May-2022 | BENGALURU | 66 | HV1 | SOUTH CITY | 15:20 | 15:21 | 0:01 | LINE CLEAR AVAILED |
| 105 | 17-May-2022 | BENGALURU | 66 | SUBRAMANYAPURA 220 - BMRCL | NO STATION AFFECTED | 21:15 | 22:58 | 1:43 | LINE FAULT |
| 106 | 17-May-2022 | BENGALURU | 66 | T GOLLAHALLI 220 - AVANI | AVANI, MULBAGAL | 23:56 | 23:59 | 0:03 | LINE FAULT |
| 107 | 17-May-2022 | BENGALURU | 66 | HV1 | TK HALLI 220 | 11:41 | 12:25 | 0:44 | LINE CLEAR AVAILED |
| 108 | 17-May-2022 | BENGALURU | 66 | TK HALLI 220 - AKKURMOLE | AKKURMOLE | 19:12 | 19:52 | 0:40 | LINE FAULT |
| 109 | 17-May-2022 | BENGALURU | 66 | TK HALLI 220 - SHIMSHA | NO STATION AFFECTED | 2:52 | 3:10 | 0:18 | LINE FAULT |
| 110 | 17-May-2022 | BENGALURU | 66 | TK HALLI 220 - SHIMSHA | NO STATION AFFECTED | 18:36 | 19:52 | 1:16 | LINE FAULT |
| 111 | 17-May-2022 | BENGALURU | 66 | HV1 | GANJIGUNTE | 6:05 | 6:15 | 0:10 | TRANSFORMER FAULT |
| 112 | 17-May-2022 | BENGALURU | 66 | LAKKUR - MALUR 220 | LAKKUR, DEVANGONDI | 12:10 | 12:20 | 0:10 | LINE CLEAR AVAILED |
| 113 | 17-May-2022 | BENGALURU | 66 | LAKKUR - MALUR 220 | LAKKUR, DEVANGONDI | 15:25 | 15:30 | 0:05 | LINE CLEAR AVAILED |
| 114 | 17-May-2022 | BENGALURU | 66 | HV2 | LAKKUR | 12:10 | 12:20 | 0:10 | LINE CLEAR AVAILED |
| 115 | 17-May-2022 | BENGALURU | 66 | MAGADI 220 - MAGADI 66 | MAGADI 66, GUEDEMARANAHALLI, HOSPALYA CIRCLE | 6:59 | 7:40 | 0:41 | LINE FAULT |
| 116 | 17-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - BAGEPALLI 2 | VIDHURASHWATHA, GUNDLU KOTTUR | 6:30 | 6:36 | 0:06 | LINE FAULT |
| 117 | 17-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - DB PURA 1 | MANCHENAHALLI, GUNDAMGERE | 22:31 | 22:36 | 0:05 | LINE FAULT |
| 118 | 17-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - ACC (EHT) | ACC (EHT) | 23:00 | 23:18 | 0:18 | LINE FAULT |
| 119 | 17-May-2022 | BENGALURU | 66 | KOLAR 220 - THAYLUR | TAMAKA | 8:23 | 9:01 | 0:38 | LINE FAULT |
| 120 | 17-May-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 2 | NARASAPURA, HONDA (EHT), KC VALLEY (EHT) | 18:58 | 21:36 | 2:38 | LINE FAULT |
| 121 | 17-May-2022 | BENGALURU | 66 | KOLAR 220 - VOKKALERI | VOKKALERI | 20:27 | 21:36 | 1:09 | LINE CLEAR AVAILED |
| 122 | 17-May-2022 | BENGALURU | 66 | KOLAR 220 - VOKKALERI | VOKKALERI | 21:37 | 21:40 | 0:03 | LINE CLEAR AVAILED |
| 123 | 17-May-2022 | BENGALURU | 66 | YELAHANKA 220 - LINE8 | RAJANKUNTE | 21:45 | 22:16 | 0:30 | LINE FAULT |
| 124 | 17-May-2022 | BENGALURU | 66 | TADIGOLU CROSS - CHINTAMANI 220 | TADIGOLU CROSS, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU | 12:45 | 13:34 | 0:49 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|------------------------------|--|--------------------|--------------------|-----------|-------------------------------------|
| 125 | 17-May-2022 | BENGALURU | 66 | MITTEMARI 220 - BAGEPALLI 1 | VATADOSANAHALLI | 12:17 | 12:44 | 0:27 | LINE CLEAR AVAIED |
| 126 | 17-May-2022 | BENGALURU | 66 | MITTEMARI 220 - SOMANATHPURA | SOMANATHPURA, CHAKAVELU, CHELUR | 16:22 | 17:23 | 1:00 | LINE CLEAR AVAIED |
| 127 | 17-May-2022 | BENGALURU | 66 | MITTEMARI 220 - JULLUPALYA | JULLUPALYA | 23:49 | 23:56 | 0:07 | LINE FAULT |
| 128 | 17-May-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 1 | NARASAPURA, HONDA (EHT), KC VALLEY (EHT) | 18:32 | 18:54 | 0:22 | LINE FAULT |
| 129 | 17-May-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 1 | NARASAPURA, HONDA (EHT), KC VALLEY (EHT) | 18:58 | 19:13 | 0:14 | LINE CLEAR AVAIED |
| 130 | 17-May-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 1 | NARASAPURA, HONDA (EHT), KC VALLEY (EHT) | 20:02 | 21:36 | 1:33 | LINE CLEAR AVAIED |
| 131 | 17-May-2022 | BENGALURU | 66 | DB PURA 220 - DG 2 | DODDABELAVANGALA | 22:22 | 22:36 | 0:14 | LINE FAULT |
| 132 | 17-May-2022 | BENGALURU | 66 | DB PURA 220 - DG 2 | DODDABELAVANGALA | 22:41 | 22:46 | 0:05 | LINE FAULT |
| 133 | 17-May-2022 | BENGALURU | 66 | ALUR - SRS PEENYA 220 | ALUR, NELAMANGALA 66 | 21:45 | 22:23 | 0:37 | LINE FAULT |
| 134 | 17-May-2022 | BENGALURU | 66 | HV3 | NELAMANGALA 66 | 7:06 | 7:18 | 0:12 | TRANSFORMER FAULT |
| 135 | 17-May-2022 | BENGALURU | 66 | HV2 | MANCHENAHALLI | 9:53 | 9:59 | 0:05 | TRANSFORMER FAULT |
| 136 | 17-May-2022 | BENGALURU | 66 | HV2 | KEMBODI | 10:30 | 10:35 | 0:05 | LINE CLEAR AVAIED |
| 137 | 17-May-2022 | BENGALURU | 66 | HV2 | KIADB DB PURA 220 | 21:59 | 22:09 | 0:10 | TRANSFORMER FAULT |
| 138 | 17-May-2022 | BENGALURU | 66 | HBR LAYOUT 66 - KONDASPURA | KONDASPURA | 22:22 | 22:55 | 0:33 | LINE FAULT |
| 139 | 17-May-2022 | BENGALURU | 66 | HV1 | JIGANI 66 | 16:00 | 16:30 | 0:30 | LINE CLEAR AVAIED |
| 140 | 17-May-2022 | BENGALURU | 66 | HV1 | DALASNUR | 11:20 | 13:33 | 2:13 | LINE CLEAR AVAIED |
| 141 | 17-May-2022 | BENGALURU | 66 | TUBUGERE - AFTL SOLAR IPP | AFTL SOLAR IPP | 22:11(17-5-2022) | | | LINE OPEN,LINE FAULT |
| 142 | 17-May-2022 | BENGALURU | 66 | T GOLLAHALLI 220 - AVANI | AVANI, MULBAGAL | 23:56(17/05/2022) | | | LINE OPEN,LINE FAULT |
| 143 | 17-May-2022 | GULBARGA | 400 | BTPSG-HIRIYUR2 | HIRIYUR_400 | 16:12(08.05.2022) | | | LINE OPEN,LINE FAULT |
| 144 | 17-May-2022 | GULBARGA | 220 | LINGAPUR-BTPS | LINGAPUR_220 | 01:55(17.05.2022) | | | LINE OPEN,LINE CLEAR AVAIED |
| 145 | 17-May-2022 | GULBARGA | 220 | KUDLIGI-HIREMALLANAHALLI 1&2 | KUDLIGI_220 | 17:25(08.05.2022) | | | LINE OPEN,LINE FAULT |
| 146 | 17-May-2022 | GULBARGA | 220 | HV2 | KUDLIGI_220 | 16:18(12.08.2021) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 147 | 17-May-2022 | GULBARGA | 220 | ALIPUR-RAGALPADU | RAGALPADU_220 | 2:35(17.05.2022) | | | LINE OPEN,LINE CLEAR AVAIED |
| 148 | 17-May-2022 | GULBARGA | 220 | HV2,LV2 | MUNIRABAD_220 | 18:20 | 19:12 | 0:52 | TRANSFORMER FAULT |
| 149 | 17-May-2022 | GULBARGA | 220 | HV1,LV1 | MUNIRABAD_220 | 18:20 | 20:43 | 2:23 | TRANSFORMER FAULT |
| 150 | 17-May-2022 | GULBARGA | 220 | HV2,LV2 | MUNIRABAD_220 | 20:19 | 21:00 | 0:41 | TRANSFORMER FAULT |
| 151 | 17-May-2022 | GULBARGA | 220 | HV2 & LV2 | HUMNABAD_220 | 15:35 | 17:18 | 1:43 | TRANSFORMER FAULT |
| 152 | 17-May-2022 | GULBARGA | 220 | HV1 | KUSTAGI_220 | 15:00 | 20:00 | 5:00 | LINE CLEAR AVAIED |
| 153 | 17-May-2022 | GULBARGA | 220 | HV1 | RAICHUR_220 | 18:52 | 19:05 | 0:13 | TRANSFORMER FAULT |
| 154 | 17-May-2022 | GULBARGA | 220 | MALLAT-RTPS | MALLAT_220 | 19:23 | 19:39 | 0:16 | LINE FAULT |
| 155 | 17-May-2022 | GULBARGA | 220 | KUSTAGI-SULEKAL | KUSTAGI_220 | 12:38 | 12:45 | 0:07 | LINE FAULT |
| 156 | 17-May-2022 | GULBARGA | 220 | RTPS-MALLAT | RTPS_220 | 19:22 | 19:39 | 0:17 | LINE FAULT |
| 157 | 17-May-2022 | GULBARGA | 220 | ITTAGI-BMM ISPAT_IPP | BMM ISPAT_IPP | 18:50 (16.05.2022) | 14:15 (17.05.2022) | 19:25 HRS | LINE CHARGED |
| 158 | 17-May-2022 | GULBARGA | 220 | RAICHUR-JURALA_1_IPP | RAICHUR_220 | 11:39 | 17:07 | 5:28 | LINE CLEAR AVAIED |
| 159 | 17-May-2022 | GULBARGA | 110 | HV1 | SIRWAR_110 | 23:15(17.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAIED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--------------------------------|---|--------------------|--------------------|-----------|------------------------------|
| 160 | 17-May-2022 | GULBARGA | 110 | SHAHAPUR-KHANAPUR | KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP | 10:55 (11.04.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 161 | 17-May-2022 | GULBARGA | 110 | HUMNABAD-SASTHAPUR | RAJESHWAR_110,SASTHAPUR_110,MANTHAL_110 | 15:22(17/5/2022) | | | LINE OPEN,LINE FAULT |
| 162 | 17-May-2022 | GULBARGA | 110 | HV2 | SHORAPUR_110 | 22:30 | 22:38 | 0:08 | TRANSFORMER FAULT |
| 163 | 17-May-2022 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 19:58 | 20:24 | 0:26 | TRANSFORMER FAULT |
| 164 | 17-May-2022 | GULBARGA | 110 | HV3 | YELBURGA_110 | 17:12 | 18:07 | 0:55 | LINE CLEAR AVAILED |
| 165 | 17-May-2022 | GULBARGA | 110 | HV2 | ALIPUR_220 | 22:47 | 23:35 | 0:48 | TRANSFORMER FAULT |
| 166 | 17-May-2022 | GULBARGA | 110 | HV2 | KUSTAGI_220 | 16:14 | 16:26 | 0:12 | TRANSFORMER FAULT |
| 167 | 17-May-2022 | GULBARGA | 110 | HV1 | KUSTAGI_220 | 16:28 | 17:40 | 1:12 | TRANSFORMER FAULT |
| 168 | 17-May-2022 | GULBARGA | 110 | HV2 | KUSTAGI_220 | 17:53 | 18:30 | 0:37 | TRANSFORMER FAULT |
| 169 | 17-May-2022 | GULBARGA | 110 | HV1 | SHAHAPUR_220 | 21:53 | 22:15 | 0:22 | TRANSFORMER FAULT |
| 170 | 17-May-2022 | GULBARGA | 110 | KAPNOOR-MAHAGAON | MAHAGAON_110,MARAGUTTI_110 | 16:18 | 16:52 | 0:34 | LINE FAULT |
| 171 | 17-May-2022 | GULBARGA | 110 | STAR METALLIC-MUNIRABAD | MUNIRABAD_220 | 18:23 | 19:20 | 0:57 | LINE FAULT |
| 172 | 17-May-2022 | GULBARGA | 110 | GOOGLE-RAICHUR | GOOGLE_110 | 20:00 | 20:10 | 0:10 | MAIN SUPPLY FAILURE |
| 173 | 17-May-2022 | GULBARGA | 110 | GOOGLE-RAICHUR | GOOGLE_110 | 20:50 | 21:05 | 0:15 | MAIN SUPPLY FAILURE |
| 174 | 17-May-2022 | GULBARGA | 110 | MASKI-SINDHANOOR | MASKI_110 | 5:26 | 5:39 | 0:13 | MAIN SUPPLY FAILURE |
| 175 | 17-May-2022 | GULBARGA | 110 | SIRWAR-MALLAT | SIRWAR_110 | 14:20 | 14:45 | 0:25 | LINE FAULT |
| 176 | 17-May-2022 | GULBARGA | 110 | SIRWAR-RAICHUR | SIRWAR_110 | 18:30 | 18:40 | 0:10 | LINE CLEAR AVAILED |
| 177 | 17-May-2022 | GULBARGA | 110 | ALIPUR-MUNIRABAD | TORANGALLU_110,KUDITINI_110,KURUGOD_110,SHATVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAMLAPUR_110,METRI_110,RBNS FACTORY | 16:40 | 17:41 | 1:01 | LINE CLEAR AVAILED |
| 178 | 17-May-2022 | GULBARGA | 110 | HALBARGA-HALLIKHED | HALLIKHED_110 | 18:52 | 19:04 | 0:12 | LINE FAULT |
| 179 | 17-May-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 19:40 | 19:50 | 0:10 | LINE FAULT |
| 180 | 17-May-2022 | GULBARGA | 110 | MALLAT-SIRWAR | SIRWAR_110 | 20:43 | 20:49 | 0:06 | LINE FAULT |
| 181 | 17-May-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 22:05 | 22:35 | 0:30 | LINE FAULT |
| 182 | 17-May-2022 | GULBARGA | 110 | RAICHUR-SHAHAPUR1 | GABBUR_110 | 18:16 (16.05.2022) | 15:41 (17.05.2022) | 21:25 HRS | LINE CHARGED |
| 183 | 17-May-2022 | GULBARGA | 110 | KUSTAGI-HANUMASAGAR | HANUMASAGAR_110,HIREGONNAGAR_110,HANUMANAL_110 | 15:05 | 20:07 | 5:02 | LINE CLEAR AVAILED |
| 184 | 17-May-2022 | GULBARGA | 110 | RAICHUR-APMC_1 | APMC_110,CHIKSUGUR_110,SHAKTINAGAR_110 | 18:48 | 19:20 | 0:32 | LINE FAULT |
| 185 | 17-May-2022 | GULBARGA | 110 | RAICHUR-APMC_2 | APMC_110,CHIKSUGUR_110,SHAKTINAGAR_110 | 18:47 | 19:20 | 0:33 | LINE FAULT |
| 186 | 17-May-2022 | GULBARGA | 110 | RAICHUR-SHAHPUR2 | GOOGLE_110 | 19:55 | 21:02 | 1:07 | LINE FAULT |
| 187 | 17-May-2022 | GULBARGA | 110 | SHAHAPUR-RAICHUR_1 | DEODURGA_110 | 11:30 | 11:43 | 0:13 | LINE CLEAR AVAILED |
| 188 | 17-May-2022 | GULBARGA | 110 | SHAHAPUR-RAICHUR_2 | DEODURGA_110 | 11:30 | 11:43 | 0:13 | LINE CLEAR AVAILED |
| 189 | 17-May-2022 | GULBARGA | 110 | SHAHAPUR-KBJNL | KBJNL_110 | 16:16 | 16:41 | 0:25 | LINE FAULT |
| 190 | 17-May-2022 | GULBARGA | 110 | SEDAM-MALKHED RAILWAY TRACTION | MALKHED RAILWAY TRACTION_110 | 17:32 | 19:25 | 1:53 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|------------------------|--|--------------------|-----------------------|-----------|-------------------------------------|
| 191 | 17-May-2022 | GULBARGA | 66 | HV3 | HALVAGALU_66 | 7:25 | 8:15 | 0:50 | LINE CLEAR AVAILED |
| 192 | 17-May-2022 | GULBARGA | 66 | HV2 | TAMBRAHALLI_66 | 12:00 | 12:05 | 0:05 | TRANSFORMER FAULT |
| 193 | 17-May-2022 | GULBARGA | 66 | HV2 | PUNABGHATA_66 | 12:05 | 12:30 | 0:25 | TRANSFORMER FAULT |
| 194 | 17-May-2022 | GULBARGA | 66 | HV1 | BADELADUKU_220 | 9:00 | 9:15 | 0:15 | TRANSFORMER FAULT |
| 195 | 17-May-2022 | GULBARGA | 66 | ITTAGI-KUDLIGI_2 | KUDLIGI_66,CHORNOOR_66, BANVIKAL_66,BADELADUKU_220 | 17:10 (16.05.2022) | 7:40 (17.05.2022) | 14:30 HRS | LINE CHARGED |
| 196 | 17-May-2022 | GULBARGA | 66 | KUDLIGI-BADELADUKU | BADELADUKU_220,BANVIKAL_66,CHORNOOR_66,ACME SOLAR IPP | 8:35 | 8:50 | 0:15 | LINE FAULT |
| 197 | 17-May-2022 | GULBARGA | 66 | ITTAGI-HUVINAHADAGALI | HUVINAHADGALI_66,HOLAG UNDI_66 | 15:09 | 16:32 | 1:23 | LINE CLEAR AVAILED |
| 198 | 17-May-2022 | HASSAN | 66 | RAMNAT-KATTEPURA_MINIH | RAMNATHPURA_66 | 12:41(11.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 199 | 17-May-2022 | HASSAN | 110 | JOG-NK2 | mghejog_gen | 17:05(28.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 200 | 17-May-2022 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 12:15 (29.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 201 | 17-May-2022 | HASSAN | 110 | HV3 | JOG_110 | 10:55(05.04.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 202 | 17-May-2022 | HASSAN | 220 | HV3 | KAVOOR_220 | 19:55(30.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 203 | 17-May-2022 | HASSAN | 220 | GERSOPA-TALGUPA1 | gerusoppa_gen | 19:49(16.05.2022) | | | LINE OPEN,LINE FAULT |
| 204 | 17-May-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY1 | MRSMSG_220 | 19:50(16.05.2022) | | | LINE OPEN,LINE FAULT |
| 205 | 17-May-2022 | HASSAN | 220 | SHRAVTY-TALAGUPPA1 | sharavathy_gen | 20:17 (16.05.2022) | 18:34(17.05.2022) | 22:17HRS | LINE CHARGED |
| 206 | 17-May-2022 | HASSAN | 220 | TALAGU-SGS1 | TALAGUPPA_400 | 20:14(16.05.2022) | 18:34(17.05.2022) | 22:20HRS | LINE CHARGED |
| 207 | 17-May-2022 | HASSAN | 110 | MOODAB-SOHAM1 | MOODABIDRE_110 | 17:02(16.05.2022) | 19:09 (17.05.2022) | 26:07HRS | LINE CHARGED |
| 208 | 17-May-2022 | HASSAN | 110 | MOODAB-SOHAM2 | MOODABIDRE_110 | 17:05(16.05.2022) | 19:09 (17.05.2022) | 26:04HRS | LINE CHARGED |
| 209 | 17-May-2022 | HASSAN | 110 | SHIRAL-SHKARPURA | SHIRALKOPPA_110 | 22:50(16.05.2022) | 10:40(17.05.2022) | 11:50HRS | LINE CHARGED |
| 210 | 17-May-2022 | HASSAN | 66 | HV1 | HOLEHONNUR_66 | 21:15 (16.05.2022) | 11:00(17.05.2022) | 13:45HRS | TRANSFORMER CHARGED |
| 211 | 17-May-2022 | HASSAN | 110 | HV2 | BARANGI_110 | 10:22(17.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 212 | 17-May-2022 | HASSAN | 66 | HV1 | RAMPURA_66 | 21:24(17.05.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 213 | 17-May-2022 | HASSAN | 220 | KEMAR-Varahi1 | KEMAR_220 | 14:07 | 15:14 | 1:07 | NFBC ISSUED |
| 214 | 17-May-2022 | HASSAN | 220 | KEMAR-Varahi2 | KEMAR_220 | 13:04 | 13:33 | 0:29 | LINE CLEAR AVAILED |
| 215 | 17-May-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY1 | MRSMSG_220 | 13:13 | 17:05 | 3:52 | HAND TRIPPED |
| 216 | 17-May-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY3 | MRSMSG_220 | 5:34 | 12:47 | 7:13 | LINE FAULT |
| 217 | 17-May-2022 | HASSAN | 110 | HV1 | HEGGUNJE_220 | 14:44 | 15:47 | 1:03 | LINE CLEAR AVAILED |
| 218 | 17-May-2022 | HASSAN | 220 | SHRAVTY-SHIMOGA1 | sharavathy_gen | 13:13 | 17:05 | 3:52 | LINE CLEAR AVAILED |
| 219 | 17-May-2022 | HASSAN | 220 | SHRAVTY-SHIMOGA3 | sharavathy_gen | 5:36 | 12:47 | 7:11 | LINE FAULT |
| 220 | 17-May-2022 | HASSAN | 220 | VARAHI-KEMAR1 | varahi_gen | 14:07 | 15:15 | 1:08 | LINE CLEAR AVAILED |
| 221 | 17-May-2022 | HASSAN | 220 | VARAHI-KEMAR2 | varahi_gen | 13:04 | 13:38 | 0:34 | NFBC ISSUED |
| 222 | 17-May-2022 | HASSAN | 110 | HV1 | BARANGI_110 | 15:06 | 17:42 | 2:36 | LINE CLEAR AVAILED |
| 223 | 17-May-2022 | HASSAN | 110 | HV1 | BIRUR_110 | 15:35 | 16:18 | 0:43 | TRANSFORMER FAULT |
| 224 | 17-May-2022 | HASSAN | 110 | HV2 | ESSUR_110 | 8:29 | 12:37 | 4:08 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|----------------------------|---------------------------------------|---------|-----------|----------|---------------------|
| 225 | 17-May-2022 | HASSAN | 110 | HIRIYA-MANIPAL | HIRIYADKA_110 | 10:13 | 12:00 | 1:47 | NFBC ISSUED |
| 226 | 17-May-2022 | HASSAN | 110 | HV3 | PUTTUR_110 | 9:34 | 9:43 | 0:09 | TRANSFORMER FAULT |
| 227 | 17-May-2022 | HASSAN | 110 | HV1 | SHIVAPURA_110 | 17:47 | 18:50 | 1:03 | LINE CLEAR AVAILED |
| 228 | 17-May-2022 | HASSAN | 66 | HV1 | BELUR_66 | 6:55 | 7:45 | 0:50 | TRANSFORMER FAULT |
| 229 | 17-May-2022 | HASSAN | 66 | CHANNAR-UDAYAPURA | CHANNARAYAPATNA_66 | 12:49 | 12:58 | 0:09 | LINE FAULT |
| 230 | 17-May-2022 | HASSAN | 66 | KANDLI-SAKLESHPUR | KANDLI_66 | 12:41 | 14:02 | 1:21 | LINE CLEAR AVAILED |
| 231 | 17-May-2022 | HASSAN | 66 | HV2 | RAMPURA_66 | 23:10 | 23:20 | 0:10 | TRANSFORMER FAULT |
| 232 | 17-May-2022 | HASSAN | 66 | SAKALE-HASSAN | SAKLESH PURA_66 | 12:47 | 14:02 | 1:15 | LINE CLEAR AVAILED |
| 233 | 17-May-2022 | HASSAN | 66 | TAVAREC-HONNALLI | TAVARECHATNAHALLY_66 | 7:30 | 7:55 | 0:25 | LINE FAULT |
| 234 | 17-May-2022 | HASSAN | 66 | UDAYAP-BAGUR | UDAYAPURA_66 | 13:01 | 13:06 | 0:05 | MAIN SUPPLY FAILURE |
| 235 | 17-May-2022 | HASSAN | 66 | UDAYAP-SATHENAHALLI | UDAYAPURA_66 | 13:01 | 13:08 | 0:07 | MAIN SUPPLY FAILURE |
| 236 | 17-May-2022 | MYSURU | 66 | HV2 | DEVANOORNGUDU_66 | 12:06 | 12:23 | 0:17 | LINE CLEAR AVAILED |
| 237 | 17-May-2022 | MYSURU | 66 | HV2 | DEVANOORNGUDU_66 | 15:15 | 15:23 | 0:08 | LINE CLEAR AVAILED |
| 238 | 17-May-2022 | MYSURU | 66 | DEVANURU NANJANGUDU-SUTTUR | SUTTUR_66 | 18:55 | 19:05 | 0:10 | LINE FAULT |
| 239 | 17-May-2022 | MYSURU | 66 | DEVANURU NANJANGUDU-SUTTUR | SUTTUR_66 | 20:28 | 20:36 | 0:08 | LINE FAULT |
| 240 | 17-May-2022 | MYSURU | 66 | HANNUR-AMP SOLAR | NO STATIONS EFFECTED | 17:22 | 17:35 | 0:12 | LINE FAULT |
| 241 | 17-May-2022 | MYSURU | 66 | HANNUR-MADHUVANAHALLI 1 | NO STATIONS EFFECTED | 17:22 | 17:31 | 0:09 | LINE FAULT |
| 242 | 17-May-2022 | MYSURU | 66 | HDKOTE-TARAKA | ANTHARSANTHE_66 | 9:24 | 9:30 | 0:06 | LINE FAULT |
| 243 | 17-May-2022 | MYSURU | 66 | KRNAGARA-BILIKERE | BILIKERE_66 DMG_HALLI_66 GVGUDI_66 | 7:25 | 7:35 | 0:10 | LINE FAULT |
| 244 | 17-May-2022 | MYSURU | 66 | HV1 | MADDUR_66 | 9:40 | 11:20 | 1:40 | LINE CLEAR AVAILED |
| 245 | 17-May-2022 | MYSURU | 66 | HV2 | MADDUR_66 | 11:20 | 12:50 | 1:30 | LINE CLEAR AVAILED |
| 246 | 17-May-2022 | MYSURU | 66 | HV2 | MADIKERI_66 | 11:46 | 16:16 | 4:30 | LINE CLEAR AVAILED |
| 247 | 17-May-2022 | MYSURU | 66 | MALAVALLI-SHIMSHA | MALAVALLI_66 | 2:26 | 2:49 | 0:23 | MAIN SUPPLY FAILURE |
| 248 | 17-May-2022 | MYSURU | 66 | MALAVALLI-SHIMSHA | MALAVALLI_66 | 2:53 | 4:34 | 1:41 | MAIN SUPPLY FAILURE |
| 249 | 17-May-2022 | MYSURU | 66 | MALAVALLI-SHIMSHA | MALAVALLI_66 | 5:10 | 5:16 | 0:06 | MAIN SUPPLY FAILURE |
| 250 | 17-May-2022 | MYSURU | 66 | HV1 | MALAVALLI_66 | 5:10 | 8:52 | 3:42 | LINE CLEAR AVAILED |
| 251 | 17-May-2022 | MYSURU | 66 | HV2 | MALAVALLI_66 | 5:10 | 8:52 | 3:42 | LINE CLEAR AVAILED |
| 252 | 17-May-2022 | MYSURU | 66 | MALAVALLI-SHIMSHA | MALAVALLI_66 | 13:35 | 15:58 | 2:23 | LINE CLEAR AVAILED |
| 253 | 17-May-2022 | MYSURU | 66 | MALAVALLI-SHIMSHA | MALAVALLI_66 | 18:35 | 18:55 | 0:20 | MAIN SUPPLY FAILURE |
| 254 | 17-May-2022 | MYSURU | 66 | HV1 | MALAVALLI_66 | 18:55 | 21:13 | 2:18 | LINE CLEAR AVAILED |
| 255 | 17-May-2022 | MYSURU | 66 | HV2 | MALAVALLI_66 | 18:55 | 21:13 | 2:18 | LINE CLEAR AVAILED |
| 256 | 17-May-2022 | MYSURU | 66 | HV2 | NAGAMANGALA_66 | 21:11 | 22:10 | 0:58 | HAND TRIPPED |
| 257 | 17-May-2022 | MYSURU | 66 | HV1 | BILIKERE_66 | 21:37 | 21:51 | 0:14 | TRANSFORMER FAULT |
| 258 | 17-May-2022 | MYSURU | 66 | BILIKERE-D M G HALLI | DMG_HALLI_66 | 0:00 | 0:05 | 0:05 | LINE FAULT |
| 259 | 17-May-2022 | MYSURU | 66 | BILIKERE-D M G HALLI | DMG_HALLI_66 | 3:32 | 3:40 | 0:08 | LINE FAULT |
| 260 | 17-May-2022 | MYSURU | 66 | HV1 | HOSURGATE_66 | 13:10 | 15:30 | 2:20 | LINE CLEAR AVAILED |
| 261 | 17-May-2022 | MYSURU | 66 | HV1 | KUNTHUR_66 | 12:10 | 12:30 | 0:20 | LINE CLEAR AVAILED |
| 262 | 17-May-2022 | MYSURU | 66 | HV2 | BANANGADI_66 | 7:10 | 9:10 | 2:00 | LINE CLEAR AVAILED |
| 263 | 17-May-2022 | MYSURU | 66 | HOOTGALLY-KAGGEREHAMPAPURA | KAGGEREHAMPAPURA_66 | 12:03 | 12:20 | 0:17 | LINE FAULT |
| 264 | 17-May-2022 | MYSURU | 66 | KADAKOLA-SARGUR1 | HAMPAPURA(K)_66 JAIPUR_66 | 17:24 | 17:25 | 0:01 | HAND TRIPPED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|-----------------------------------|--|-----------------------------|-----------------------------|----------|------------------------------|
| 265 | 17-May-2022 | MYSURU | 66 | VAJMANGALA-KADAKOLA1 | AYRALLI_66 MARADIHUNDI_66 | 7:53 | 8:11 | 0:18 | LINE FAULT |
| 266 | 17-May-2022 | MYSURU | 66 | VAJMANGALA-JYOTHINAGARA | DKMAIDANA_66 FTS_66 JYOTHINAGARA_66 | 10:44 | 10:58 | 0:14 | LINE FAULT |
| 267 | 17-May-2022 | MYSURU | 220 | HV2 | VAJAMANGALA_220 | 12:44 | 16:53 | 4:09 | LINE CLEAR AVAILED |
| 268 | 17-May-2022 | MYSURU | 66 | VAJMANGALA-DEVNUR(MYS) | DEVANOORMYS_66 RAJEEVNAGARA_66 | 10:10 | 11:24 | 1:14 | LINE FAULT |
| 269 | 17-May-2022 | MYSURU | 66 | KUSHALNAGARA-RAMANATHAPURA1 | ALUR SIDDAPUR_66 KANAGAL_66 RAMANATHAPURA_66 RUDRAPATNA_66 CB HALLI_66 | 18:54 | 19:01 | 0:07 | LINE FAULT |
| 270 | 17-May-2022 | MYSURU | 220 | TUBINKERE-BASTHIPURA | NO STATIONS EFFECTED | 12:40 | 14:13 | 1:33 | LINE CLEAR AVAILED |
| 271 | 17-May-2022 | MYSURU | 220 | TUBINKERE-KOTHIPURA1 | NO STATIONS EFFECTED | 15:12 | 16:52 | 1:40 | LINE CLEAR AVAILED |
| 272 | 17-May-2022 | MYSURU | 66 | MADHUVANAHALLI-KUNTHUR | NO STATIONS EFFECTED | 17:03 | 17:27 | 0:24 | LINE FAULT |
| 273 | 17-May-2022 | MYSURU | 66 | NAGAMANGALA220-KOPPA | BASARALU_66 BESAGARAHALLI_66 DUNDANAHALLI_66 KOPPA_66 | 8:50 | 9:12 | 0:22 | LINE FAULT |
| 274 | 17-May-2022 | MYSURU | 66 | NAGAMANGALA220-GUDDENAHALLI | BOGADHI MANDYA_66 GUDDENAHALLI_66 | 9:09 | 9:19 | 0:10 | LINE FAULT |
| 275 | 17-May-2022 | MYSURU | 66 | HV2 | SANTHEBACHALLI_66 | 12:20 | 12:55 | 0:35 | LINE CLEAR AVAILED |
| 276 | 17-May-2022 | MYSURU | 66 | HV2 | BGNAGARA_66 | 10:40:00 PM (16/05/2022) | 11:30:00 AM (17/05/2022) | 12:50hrs | TRANSFORMER CHARGED |
| 277 | 17-May-2022 | MYSURU | 66 | MALAVALLI-K K HALLI | NO STATIONS EFFECTED | 12:18:00 PM (16/05/2022) | 3:18:00 PM (17/05/2022) | 3:00hrs | LINE CHARGED |
| 278 | 17-May-2022 | MYSURU | 66 | TUBINAKERE-NAGAMANGALA 1 | NO STATIONS EFFECTED | 6:10:00 AM (15/05/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 279 | 17-May-2022 | MYSURU | 66 | HEBBANI-TK HALLI | NO STATIONS EFFECTED | 12:03:00 (14.5.2022) | | | LINE OPEN,LINE FAULT |
| 280 | 17-May-2022 | MYSURU | 66 | KHB STATION-BILIKERE | NO STATIONS EFFECTED | 10:57:05 (4/5/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 281 | 17-May-2022 | MYSURU | 66 | DUNDANAHALLY-HULIYURDURGA | NO STATIONS EFFECTED | 8:36:34 (30/04/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 282 | 17-May-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 6:26:00 PM (22/04/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 283 | 17-May-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16:00 (08/12/2021) | | | LINE OPEN,LINE CLEAR AVAILED |
| 284 | 17-May-2022 | TUMKUR | 66 | DAVANGERE SRS-HARIHARA(YARAGUNTA) | HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66 | 17:35(16.5.22) | 11:39(17.5.22) | 18:04hrs | LINE CHARGED |
| 285 | 17-May-2022 | TUMKUR | 220 | TR-1 | KIADB V N PURA_220 | 13:37 | 13:50 | 0:13 | LINE CLEAR AVAILED |
| 286 | 17-May-2022 | TUMKUR | 220 | TR-1(HV & LV SIDE) | PAVAGADA_220 | 0:10 | 5:55 | 5:45 | TRANSFORMER FAULT |
| 287 | 17-May-2022 | TUMKUR | 220 | PAVAGADA 220kV-MADHUGIRI 1 | PAVAGADA_220 | 0:35 | 5:55 | 5:20 | LINE FAULT |
| 288 | 17-May-2022 | TUMKUR | 220 | PAVAGADA 220kV- GREEN KO | HEBBUR_66, BHAKTARAHALLI_66 | 0:35 | 6:30 | 5:55 | LINE FAULT |
| 289 | 17-May-2022 | TUMKUR | 110 | TR-2 | KBCROSS_220 | 10:50 | 11:51 | 1:01 | LINE CLEAR AVAILED |
| 290 | 17-May-2022 | TUMKUR | 110 | TR-1 | KBCROSS_220 | 14:35 | 14:50 | 0:15 | LINE CLEAR AVAILED |
| 291 | 17-May-2022 | TUMKUR | 110 | TR-2 | KBCROSS_220 | 18:24 | 20:28 | 2:04 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|---|--|-----------------------|-----------------------|----------|-------------------------------------|
| 292 | 17-May-2022 | TUMKUR | 66 | ANTHRASANAHALI 220KV- CHELUR | CHELURU_66, HOSAKERE_66, HAGAL WADI_66 | 1:31 | 2:00 | 0:29 | LINE FAULT |
| 293 | 17-May-2022 | TUMKUR | 66 | ANTHRASANAHALI 220KV- MELEKOTE | MELKOTE_66, BADDIHALLI_66,HONNUDIKE _66 | 6:27 | 6:38 | 0:11 | LINE FAULT |
| 294 | 17-May-2022 | TUMKUR | 66 | HONNALLI 220kv- BANUVALLI | BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66 | 7:44 | 8:47 | 1:03 | LINE CLEAR AVAILED |
| 295 | 17-May-2022 | TUMKUR | 66 | HONNALLI 220kv- BANUVALLI | BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66 | 1:39 | 2:28 | 0:49 | LINE CLEAR AVAILED |
| 296 | 17-May-2022 | TUMKUR | 66 | HONNALLI 220kv- KUNDUR66 | KUNDUR,_66,MALEBENNUR _66,DEVARABELKERE_66 | 1:39 | 2:28 | 0:49 | LINE CLEAR AVAILED |
| 297 | 17-May-2022 | TUMKUR | 66 | HONNALLI 220KV- NYAMATHI | CHILLUR_66, NYAMATHI_66, SAVALANGA_66 | 5:38 | 5:49 | 0:11 | LINE FAULT |
| 298 | 17-May-2022 | TUMKUR | 66 | HONNALLI 220KV- NYAMATHI | CHILLUR_66, NYAMATHI_66, SAVALANGA_66 | 13:39 | 13:50 | 0:11 | LINE FAULT |
| 299 | 17-May-2022 | TUMKUR | 66 | HONNALLI 220kv- LINGADAHALLI- CHANNAGIRI(NALLUR) | DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66 | 21:00 | 21:10 | 0:10 | LINE FAULT |
| 300 | 17-May-2022 | TUMKUR | 66 | CHITRADURGA 220kv- PANDARAHALLI 2 | PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_6 6 | 12:18 | 12:49 | 0:31 | LINE CLEAR AVAILED |
| 301 | 17-May-2022 | TUMKUR | 66 | CHITRADURGA 220kv- CHITRADURGA 4 | CHITRADURGA_220 | 11:36 | 18:36 | 7:00 | LINE CLEAR AVAILED |
| 302 | 17-May-2022 | TUMKUR | 66 | KDBVNP- TMTP | TMTP_66 | 13:19 | 15:38 | 2:19 | LINE CLEAR AVAILED |
| 303 | 17-May-2022 | TUMKUR | 66 | PAVAGADA 220kv- YN HOSAKETE | PAVAGADA_220 | 0:35 | 10:22 | 9:47 | LINE FAULT |
| 304 | 17-May-2022 | TUMKUR | 66 | PAVAGADA220-PAVAGADA2 | PAVAGADA_220 | 0:35 | 10:22 | 9:47 | LINE FAULT |
| 305 | 17-May-2022 | TUMKUR | 66 | HANDANKERE-K B CROSS | C N HALLI_66, HANDANKERE_66 | 17:00 | 17:15 | 0:15 | MAIN SUPPLY FAILURE |
| 306 | 17-May-2022 | TUMKUR | 66 | TR1 & 2 | HANDANKERE_66 | 17:00 | 17:15 | 0:15 | MAIN SUPPLY FAILURE |
| 307 | 17-May-2022 | TUMKUR | 66 | HULIYAR- K B CROSS | HULIYAR_110, C N HALLI_110 | 17:00 | 17:15 | 0:15 | MAIN SUPPLY FAILURE |
| 308 | 17-May-2022 | TUMKUR | 66 | TR-1, TR-2 & TR-3 | HULIYAR_110 | 17:00 | 17:15 | 0:15 | MAIN SUPPLY FAILURE |
| 309 | 18-May-2022 | BAGALKOT | 110 | PG HUNSHYAL-MUDALAGI (NAGANUR) | STATION NOT AFFECTED PG HUNSHYAL_110 | 16:13 (04.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 310 | 18-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED LAXMESHVAR_110 | 17:55 (28.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 311 | 18-May-2022 | BAGALKOT | 110 | AMBEWADI- NK1 (KAVALWADA) | STATION NOT AFFECTED AMBEWADI_220 | 9:30 (09.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 312 | 18-May-2022 | BAGALKOT | 110 | AMBEWADI- NK2 (HALIYAL) | STATION NOT AFFECTED AMBEWADI_220 | 9:33 (09.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 313 | 18-May-2022 | BAGALKOT | 220 | BELGAUM- AEQUS1 | STATION NOT AFFECTED BELGAUM_220 | 10:39 (16.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 314 | 18-May-2022 | BAGALKOT | 220 | HAVERI- GUTTUR2 | STATION NOT AFFECTED HAVERI_220 | 17:56 (16.05.2022) | 13:51 (18.05.2022) | 43:55hrs | LINE CHARGED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|-------------------------------|---|-----------------------|-----------------------|----------|------------------------------|
| 315 | 18-May-2022 | BAGALKOT | 110 | BAGEWADI (HIREMASALI)-ATHARGA | STATION NOT AFFECTED ATHARGA_110 | 20:04 (17.05.2022) | 19:27 (18.05.2022) | 23:23hrs | LINE CHARGED |
| 316 | 18-May-2022 | BAGALKOT | 110 | HIREMASALI- F2(ATHARGA) | STATION NOT AFFECTED HIREMASALI_110 | 20:54 (17.05.2022) | 19:23 (18.05.2022) | 22:29hrs | LINE CHARGED |
| 317 | 18-May-2022 | BAGALKOT | 110 | RON- GAJENDRAGAD1 | STATION NOT AFFECTED RON_110 | 23:21 (17.05.2022) | 12:40 (18.05.2022) | 13:19hrs | LINE CHARGED |
| 318 | 18-May-2022 | BAGALKOT | 110 | RON- GAJENDRAGAD2 | STATION NOT AFFECTED RON_110 | 23:21 (17.05.2022) | 12:40 (18.05.2022) | 13:19hrs | LINE CHARGED |
| 319 | 18-May-2022 | BAGALKOT | 110 | TAKKALAKI- WARADA SOLAR | TAKKALAKI_110 | 19:55 (17.05.2022) | 1:20 (18.05.2022) | 5:25hrs | LINE CHARGED |
| 320 | 18-May-2022 | BAGALKOT | 110 | UKLI-F2 Cbreaker(BB 220) | UKKALI_110 | 19:34 (17.05.2022) | 22:40 (18.05.2022) | 27:06hrs | LINE CHARGED |
| 321 | 18-May-2022 | BAGALKOT | 220 | GHATAPRABHA-NARENDRA2 | STATION NOT AFFECTED GHATAPRABHA_220 | 20:13 (17.05.2022) | 00:00 (18.05.2022) | 3:47hrs | LINE CHARGED |
| 322 | 18-May-2022 | BAGALKOT | 220 | 220/110KV,HV1,LV1 | STATION NOT AFFECTED GHATAPRABHA_220 | 20:13 (17.05.2022) | 0:39 (18.05.2022) | 4:26hrs | TRANSFORMER CHARGED |
| 323 | 18-May-2022 | BAGALKOT | 220 | GHATAPRABHA-MUGALKHOD 2 | STATION NOT AFFECTED GHATAPRABHA_220 | 21:03 (17.05.2022) | 0:20 (18.05.2022) | 3:17hrs | LINE CHARGED |
| 324 | 18-May-2022 | BAGALKOT | 220 | MUGALKHOD- GHATAPRABHA2 | STATION NOT AFFECTED MUGALKHOD_220 | 21:03 (17.05.2022) | 0:25 (18.05.2022) | 3:23hrs | LINE CHARGED |
| 325 | 18-May-2022 | BAGALKOT | 220 | BIDNAL-TADASA2 | BIDNAL_220 | 17:52 (17.05.2022) | 13:59 (18.05.2022) | 20:07hrs | LINE CHARGED |
| 326 | 18-May-2022 | BAGALKOT | 110 | HAVERI-SAVANUR | HAVERI_220 | 23:31 (17.05.2022) | 9:10 (18.05.2022) | 9:39hrs | LINE CHARGED |
| 327 | 18-May-2022 | BAGALKOT | 110 | THORVI- BHUTNAL_110 | STATION NOT AFFECTED THORVI_110 | 5:45 | 8:55 | 3:10 | LINE CLEAR AVAILED |
| 328 | 18-May-2022 | BAGALKOT | 110 | AEQUS220- DADDI | DADDI_110 | 6:15 | 8:25 | 2:10 | LINE CLEAR AVAILED |
| 329 | 18-May-2022 | BAGALKOT | 110 | DAMBAL- GADAG | STATION NOT AFFECTED DAMBAL_110 | 23:53 | 23:57 | 0:04 | LINE FAULT |
| 330 | 18-May-2022 | BAGALKOT | 110 | DAMBAL- SAMBAPUR ROAD | STATION NOT AFFECTED DAMBAL_110 | 23:53 | 23:57 | 0:04 | LINE FAULT |
| 331 | 18-May-2022 | BAGALKOT | 110 | GAJENDRAGAD- RON1&2 | STATION NOT AFFECTED GAJENDRAGAD_110 | 0:09 | 14:36 | 14:27 | HAND TRIPPED |
| 332 | 18-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | HIREMASALI_110 | 15:00 | 15:10 | 0:10 | TRANSFORMER FAULT |
| 333 | 18-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | HIREMASALI_110 | 17:25 | 17:30 | 0:05 | TRANSFORMER FAULT |
| 334 | 18-May-2022 | BAGALKOT | 110 | KUMATA- KRCL(RAILWAY LINE) | KUMATA_110 | 13:57 | 14:01 | 0:04 | LINE FAULT |
| 335 | 18-May-2022 | BAGALKOT | 110 | LAXMESHWAR- SHIRAHATTI | STATION NOT AFFECTED LAXMESHWAR_110 | 2:58 | 4:50 | 1:52 | LINE FAULT |
| 336 | 18-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | LOKAPUR_110 | 11:40 | 17:07 | 5:27 | LINE CLEAR AVAILED |
| 337 | 18-May-2022 | BAGALKOT | 110 | 110/33KV, HV4 | MACHE_110 | 11:15 | 12:17 | 1:02 | LINE CLEAR AVAILED |
| 338 | 18-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | MAMADAPUR(S)_110 | 14:04 | 14:35 | 0:31 | LINE CLEAR AVAILED |
| 339 | 18-May-2022 | BAGALKOT | 110 | GADAG220- SAMBAPUR ROAD | STATION NOT AFFECTED SAMBAPUR ROAD_110 | 23:57 (18.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 340 | 18-May-2022 | BAGALKOT | 110 | SAVANUR- ASF SOLAR | SAVANUR_110 | 0:19 | 0:38 | 0:19 | HAND TRIPPED |
| 341 | 18-May-2022 | BAGALKOT | 110 | TAKKALAKI- TIKOTA | TAKKALAKI_110 | 8:55 | 9:00 | 0:05 | HAND TRIPPED |
| 342 | 18-May-2022 | BAGALKOT | 220 | BELGAUM-CHIKKODI2 | STATION NOT AFFECTED BELGAUM_220 | 16:02 | 21:12 | 5:10 | LINE CLEAR AVAILED |
| 343 | 18-May-2022 | BAGALKOT | 110 | GHATAPRABHA-SHIRGOAN | STATION NOT AFFECTED GHATAPRABHA_220 | 9:05 | 15:16 | 6:11 | LINE CLEAR AVAILED |
| 344 | 18-May-2022 | BAGALKOT | 110 | RANEENNUR-HIREKERUR | HIREKERUR_110 | 2:30 | 2:37 | 0:07 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--------------------------------------|--|-----------------------|-----------------------|----------|-------------------------------------|
| 345 | 18-May-2022 | BAGALKOT | 220 | KADRA-KARWAR LINE-1 | STATION NOT AFFECTED KARWAR_220 | 13:20 | 20:00 | 6:40 | LINE CLEAR AVAILED |
| 346 | 18-May-2022 | BAGALKOT | 110 | KARWAR- BINAGA | STATION NOT AFFECTED KARWAR_220 | 13:15 | 13:35 | 0:20 | HAND TRIPPED |
| 347 | 18-May-2022 | BAGALKOT | 110 | KARWAR- BINAGA | STATION NOT AFFECTED KARWAR_220 | 20:00 | 20:10 | 0:10 | HAND TRIPPED |
| 348 | 18-May-2022 | BAGALKOT | 110 | KARWAR-KUMTA | STATION NOT AFFECTED KARWAR_220 | 20:10 | 20:15 | 0:05 | HAND TRIPPED |
| 349 | 18-May-2022 | BAGALKOT | 220 | SOUDATTI-MAHALINGAPUR | STATION NOT AFFECTED SOUDATTI_220 | 9:21 | 17:14 | 7:53 | LINE CLEAR AVAILED |
| 350 | 18-May-2022 | BAGALKOT | 110 | SOUDATTI-MMCL | STATION NOT AFFECTED SOUDATTI_220 | 21:45 | 22:13 | 0:28 | LINE FAULT |
| 351 | 18-May-2022 | BAGALKOT | 110 | AMBEWADI-SUPA1 | STATION NOT AFFECTED AMBEWADI_220 | 12:02 | 15:20 | 3:18 | LINE CLEAR AVAILED |
| 352 | 18-May-2022 | BAGALKOT | 220 | DHONI-GADAG2 | STATION NOT AFFECTED DHONI_400 | 23:03 (18.05.2022) | | | LINE OPEN,LINE FAULT |
| 353 | 18-May-2022 | BAGALKOT | 220 | GADAG-DHONI2 | STATION NOT AFFECTED GADAG_220 | 23:03 (18.05.2022) | | | LINE OPEN,LINE FAULT |
| 354 | 18-May-2022 | BAGALKOT | 110 | GADAG-SAMBAPUR ROAD | STATION NOT AFFECTED GADAG_220 | 22:56 (18.05.2022) | | | LINE OPEN,LINE FAULT |
| 355 | 18-May-2022 | BAGALKOT | 220 | 220/110KV,HV1,LV1 | STATION NOT AFFECTED GADAG_220 | 22:56 (18.05.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 356 | 18-May-2022 | BAGALKOT | 220 | 220/110KV,HV3,LV3 | STATION NOT AFFECTED GADAG_220 | 22:56 (18.05.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 357 | 18-May-2022 | BAGALKOT | 220 | MAHALINGAPUR-SOUDATTI | STATION NOT AFFECTED MAHALINGAPUR_220 | 9:22 | 17:14 | 7:52 | NFBC ISSUED |
| 358 | 18-May-2022 | BAGALKOT | 110 | SHIRAHATTI-BPCL2 | STATION NOT AFFECTED SHIRAHATTI_110 | 16:40 (27.04.2022) | | | LINE OPEN,LINE FAULT |
| 359 | 18-May-2022 | BAGALKOT | 220 | SIRSI- HUBLI1 | STATION NOT AFFECTED SIRSI_220 | 15:26 (13.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 360 | 18-May-2022 | BAGALKOT | 220 | SIRSI- HUBLI2 | STATION NOT AFFECTED SIRSI_220 | 15:26 (13.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 361 | 18-May-2022 | BAGALKOT | 220 | NARENDRA- BELGAUM1 | STATION NOT AFFECTED NARENDRA_220 | 9:01 (14.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 362 | 18-May-2022 | BAGALKOT | 220 | BELGAUM- NARENDRA1 | STATION NOT AFFECTED BELGAUM_220 | 9:01 (14.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 363 | 18-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | UKKALI_110 | 19:34 (17.05.2022) | 22:40 (18.05.2022) | 27:06hrs | TRANSFORMER CHARGED |
| 364 | 18-May-2022 | BAGALKOT | 220 | KARWAR- KADRA2 | STATION NOT AFFECTED KARWAR_220 | 21:12 (16.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 365 | 18-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | GANESHGUDI_110 | 12:05 | 13:02 | 0:57 | LINE CLEAR AVAILED |
| 366 | 18-May-2022 | BAGALKOT | 110 | 110/33KV, HV3 | YELPARAHATTI_110 | 18:20 (24.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 367 | 18-May-2022 | BENGALURU | 66 | HV2 | APPAREL PARK | 12:50 | 12:55 | 0:05 | LOAD CHANGE OVER |
| 368 | 18-May-2022 | BENGALURU | 66 | BG ROAD - JIGANI LINK ROAD | BG ROAD | 9:47 | 9:52 | 0:05 | LOAD CHANGE OVER |
| 369 | 18-May-2022 | BENGALURU | 66 | BG ROAD - SOMANAHALLI 220 | BG ROAD | 11:05 | 11:41 | 0:36 | MAIN SUPPLY FAILURE |
| 370 | 18-May-2022 | BENGALURU | 66 | BG ROAD - JIGANI LINK ROAD | BG ROAD | 15:21 | 15:26 | 0:05 | LOAD CHANGE OVER |
| 371 | 18-May-2022 | BENGALURU | 66 | JAKKASANDRA - ADUGODI | JAKKASANDRA | 1:39 | 4:39 | 3:00 | LINE CLEAR AVAILED |
| 372 | 18-May-2022 | BENGALURU | 66 | HV1 | JAKKASANDRA | 1:14 | 4:40 | 3:26 | TRANSFORMER FAULT |
| 373 | 18-May-2022 | BENGALURU | 66 | KENGERI SATELLITE TOWN - KUMBALAGODU | CHANDRAPPA CIRCLE | 13:40 | 14:12 | 0:32 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--------------------------------|---|---------|-----------|----------|---------------------|
| 374 | 18-May-2022 | BENGALURU | 66 | HV1 | KUMBALAGODU | 0:33 | 0:50 | 0:17 | TRANSFORMER FAULT |
| 375 | 18-May-2022 | BENGALURU | 66 | RAJANUKUNTE - YELAHANKA 220 | RAJANUKUNTE | 18:34 | 19:10 | 0:36 | MAIN SUPPLY FAILURE |
| 376 | 18-May-2022 | BENGALURU | 66 | SOMANAHALLI 220 - JIGANI 2 | BG ROAD, JIGANI LINK ROAD, KIRLOSKAR(EHT) | 11:05 | 11:41 | 0:36 | LINE FAULT |
| 377 | 18-May-2022 | BENGALURU | 66 | KANASAWADI - YELAHANKA 220 | KANASAWADI | 21:40 | 22:10 | 0:30 | LOAD CHANGE OVER |
| 378 | 18-May-2022 | BENGALURU | 66 | T GOLLAHALLI 220 - AVANI | AVANI, MULBAGAL | 0:00 | 1:13 | 1:13 | LINE FAULT |
| 379 | 18-May-2022 | BENGALURU | 66 | HV1 | SAMANDURU | 9:55 | 15:20 | 5:25 | LINE CLEAR AVAIED |
| 380 | 18-May-2022 | BENGALURU | 66 | HV2 | SAMANDURU | 9:55 | 15:28 | 5:33 | LINE CLEAR AVAIED |
| 381 | 18-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - DB PURA 1 | MANCHENAHALLI, GUNDAMGERE | 18:25 | 18:33 | 0:08 | LINE CLEAR AVAIED |
| 382 | 18-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - DB PURA 1 | MANCHENAHALLI, GUNDAMGERE | 13:10 | 13:58 | 0:48 | LINE CLEAR AVAIED |
| 383 | 18-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - DB PURA 1 | MANCHENAHALLI, GUNDAMGERE | 10:35 | 10:38 | 0:03 | LINE CLEAR AVAIED |
| 384 | 18-May-2022 | BENGALURU | 220 | HV2 | GOWRIBIDANUR 220 | 18:25 | 18:32 | 0:07 | LINE CLEAR AVAIED |
| 385 | 18-May-2022 | BENGALURU | 220 | HV2 | GOWRIBIDANUR 220 | 10:46 | 11:22 | 0:36 | TRANSFORMER FAULT |
| 386 | 18-May-2022 | BENGALURU | 220 | HV2 | GOWRIBIDANUR 220 | 13:22 | 14:13 | 0:51 | LINE CLEAR AVAIED |
| 387 | 18-May-2022 | BENGALURU | 66 | HV1 | THONDEBHAVI | 15:00 | 15:10 | 0:10 | LINE CLEAR AVAIED |
| 388 | 18-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - DB PURA 2 | THONDEBHAVI | 10:35 | 10:38 | 0:03 | LINE CLEAR AVAIED |
| 389 | 18-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - DB PURA 2 | THONDEBHAVI | 19:08 | 19:29 | 0:21 | LINE FAULT |
| 390 | 18-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - ACC (EHT) | ACC (EHT) | 19:08 | 19:29 | 0:21 | LINE FAULT |
| 391 | 18-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - DB PURA 2 | THONDEBHAVI | 13:10 | 13:53 | 0:43 | LINE CLEAR AVAIED |
| 392 | 18-May-2022 | BENGALURU | 66 | HV1 | GOWRIBIDANUR 220 | 0:32 | 0:38 | 0:06 | TRANSFORMER FAULT |
| 393 | 18-May-2022 | BENGALURU | 66 | MALUR 220 - LAKKUR | LAKKUR, DEVANGONDI | 6:06 | 6:31 | 0:25 | LINE FAULT |
| 394 | 18-May-2022 | BENGALURU | 66 | YELAHANKA 220 - LINE7 | KANASWADI | 16:01 | 16:14 | 0:13 | LINE FAULT |
| 395 | 18-May-2022 | BENGALURU | 66 | YELAHANKA 220 - LINE8 | RAJANKUNTE | 18:34 | 18:50 | 0:16 | LINE FAULT |
| 396 | 18-May-2022 | BENGALURU | 66 | YELAHANKA 220 - LINE8 | RAJANKUNTE | 18:50 | 19:10 | 0:20 | LINE FAULT |
| 397 | 18-May-2022 | BENGALURU | 66 | HV2 | SM MANGALA | 10:42 | 10:55 | 0:12 | TRANSFORMER FAULT |
| 398 | 18-May-2022 | BENGALURU | 220 | MITTEMARI 220 - GOWRIBIDANUR 2 | MITTEMARI 220 | 1:33 | 1:39 | 0:05 | LINE FAULT |
| 399 | 18-May-2022 | BENGALURU | 220 | HV2 | MITTEMARI 220 | 1:33 | 1:39 | 0:05 | MAIN SUPPLY FAILURE |
| 400 | 18-May-2022 | BENGALURU | 220 | LV2 | MITTEMARI 220 | 1:33 | 8:01 | 6:27 | MAIN SUPPLY FAILURE |
| 401 | 18-May-2022 | BENGALURU | 66 | MITTEMARI 220 - SOMENAHALLI | SOMENAHALLI, PERESANDRA | 1:33 | 1:55 | 0:21 | MAIN SUPPLY FAILURE |
| 402 | 18-May-2022 | BENGALURU | 66 | MITTEMARI 220 - JULLUPALYA | JULLUPALYA | 1:33 | 1:55 | 0:21 | MAIN SUPPLY FAILURE |
| 403 | 18-May-2022 | BENGALURU | 66 | MITTEMARI 220 - SADLI | SADLI | 1:33 | 1:55 | 0:21 | MAIN SUPPLY FAILURE |
| 404 | 18-May-2022 | BENGALURU | 66 | MITTEMARI 220 - SOMENAHALLI | SOMENAHALLI, PERESANDRA | 7:47 | 8:02 | 0:15 | LINE CLEAR AVAIED |
| 405 | 18-May-2022 | BENGALURU | 66 | MITTEMARI 220 - JULLUPALYA | JULLUPALYA | 7:47 | 8:02 | 0:15 | LINE CLEAR AVAIED |
| 406 | 18-May-2022 | BENGALURU | 66 | MITTEMARI 220 - SADLI | SADLI | 7:47 | 8:02 | 0:15 | LINE CLEAR AVAIED |
| 407 | 18-May-2022 | BENGALURU | 66 | HV1 | MANCHENAHALLI | 17:00 | 17:20 | 0:20 | LINE CLEAR AVAIED |
| 408 | 18-May-2022 | BENGALURU | 66 | HV2 | MANCHENAHALLI | 17:00 | 17:50 | 0:50 | LINE CLEAR AVAIED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--|---|--------------------|------------------|----------|-------------------------------------|
| 409 | 18-May-2022 | BENGALURU | 66 | HV2 | MALLASANDRA | 2:04 | 2:25 | 0:20 | TRANSFORMER FAULT |
| 410 | 18-May-2022 | BENGALURU | 66 | KONDASPURA - EPIP 220 | KONDASPURA | 12:43 | 12:46 | 0:02 | LOAD CHANGE OVER |
| 411 | 18-May-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 1 | NARASAPURA, HONDA (EHT), KC VALLEY (EHT) | 18:11 | 18:21 | 0:10 | LINE FAULT |
| 412 | 18-May-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 1 | NARASAPURA, HONDA (EHT), KC VALLEY (EHT) | 21:27 | 22:16 | 0:49 | LINE FAULT |
| 413 | 18-May-2022 | BENGALURU | 220 | LV2 | KOLAR 220 | 21:27 | 21:51 | 0:24 | LINE CLEAR AVAILED |
| 414 | 18-May-2022 | BENGALURU | 66 | KOLAR 220 - VOKKALERI | VOKKALERI | 21:27 | 21:56 | 0:29 | MAIN SUPPLY FAILURE |
| 415 | 18-May-2022 | BENGALURU | 66 | HV1 | KOLAR 220 | 21:27 | 21:54 | 0:27 | MAIN SUPPLY FAILURE |
| 416 | 18-May-2022 | BENGALURU | 66 | HV2 | KOLAR 220 | 21:27 | 21:53 | 0:26 | MAIN SUPPLY FAILURE |
| 417 | 18-May-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 2 | NARASAPURA, HONDA (EHT), KC VALLEY (EHT) | 21:27 | 22:16 | 0:49 | MAIN SUPPLY FAILURE |
| 418 | 18-May-2022 | BENGALURU | 66 | KOLAR 220 - VEMGAL | TALAGUNDA, VEMGAL, KYALNUR | 22:28 | 22:32 | 0:04 | LINE CLEAR AVAILED |
| 419 | 18-May-2022 | BENGALURU | 66 | KOLAR 220 - PGCIL AUX | PGCIL AUX, SUGUTUR | 22:59 | 23:01 | 0:02 | LINE CLEAR AVAILED |
| 420 | 18-May-2022 | BENGALURU | 66 | KOLAR 220 - THAYLUR | TAMAKA | 22:56 | 22:58 | 0:02 | LINE CLEAR AVAILED |
| 421 | 18-May-2022 | BENGALURU | 66 | BAIRAKUR - T GOLAHALLI 220 | BAIRAKUR | 0:15 | 0:49 | 0:33 | LINE FAULT |
| 422 | 18-May-2022 | BENGALURU | 66 | CHIKKABALLAPURA I/A - NALLIMARDANAHLLI | NALLIMARDANAHLLI | 17:25 | 17:35 | 0:09 | LINE FAULT |
| 423 | 18-May-2022 | BENGALURU | 66 | DB PURA 220 - DG 2 | DODDABELAVANGALA | 22:10 | 22:12 | 0:02 | LINE CLEAR AVAILED |
| 424 | 18-May-2022 | BENGALURU | 66 | HV1 | BAIRAKURU | 10:25 | 13:35 | 3:10 | LINE CLEAR AVAILED |
| 425 | 18-May-2022 | BENGALURU | 66 | HV1 | BAIRAKURU | 22:03 | 22:43 | 0:40 | LINE CLEAR AVAILED |
| 426 | 18-May-2022 | BENGALURU | 66 | HV1 | ATTIBELE | 13:00 | 13:18 | 0:18 | LINE CLEAR AVAILED |
| 427 | 18-May-2022 | BENGALURU | 66 | HV1 | CHINTAMANI 66 | 12:17 | 12:20 | 0:03 | LINE CLEAR AVAILED |
| 428 | 18-May-2022 | BENGALURU | 66 | HV1 | DALASNUR | 7:00 | 7:08 | 0:08 | TRANSFORMER FAULT |
| 429 | 18-May-2022 | BENGALURU | 220 | HV2 | KIADB DB PURA 220 | 4:15 | 6:19 | 2:04 | TRANSFORMER FAULT |
| 430 | 18-May-2022 | BENGALURU | 66 | TUBUGERE - AFTL SOLAR (IPP) | AFTL SOLAR (IPP) | 22:11(17-5-2022) | 6:35(18-5-2022) | 8:23hrs | LINE CHARGED |
| 431 | 18-May-2022 | BENGALURU | 66 | T GOLLAHALLI 220 - AVANI | AVANI, MULBAGAL | 23:56(17/05/2022) | 1:13(18/05/2022) | 1:17HRS | LINE CHARGED |
| 432 | 18-May-2022 | GULBARGA | 400 | BTPSG-HIRIYUR2 | HIRIYUR_400 | 16:12(08.05.2022) | | | LINE OPEN,LINE FAULT |
| 433 | 18-May-2022 | GULBARGA | 400 | BTPSG-GUTTUR | GUTTUR_400 | 22:36 | 23:07 | 0:31 | LINE FAULT |
| 434 | 18-May-2022 | GULBARGA | 400 | BTPSG-HIRIYUR1 | HIRIYUR_400 | 22:40 | 22:58 | 0:18 | LINE FAULT |
| 435 | 18-May-2022 | GULBARGA | 220 | LINGAPUR-BTPS | LINGAPUR_220 | 01:55(17.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 436 | 18-May-2022 | GULBARGA | 220 | ALIPUR-RAGALPADU | RAGALPADU_220 | 2:35(17.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 437 | 18-May-2022 | GULBARGA | 220 | KUDLIGI-HIREMALLANAHALLI 1&2 | KUDLIGI_220 | 17:25(08.05.2022) | | | LINE OPEN,LINE FAULT |
| 438 | 18-May-2022 | GULBARGA | 220 | HV2 | KUDLIGI_220 | 16:18(12.08.2021) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 439 | 18-May-2022 | GULBARGA | 220 | LV1 & LV2 | RAICHUR_220 | 18:17 | 18:40 | 0:23 | TRANSFORMER FAULT |
| 440 | 18-May-2022 | GULBARGA | 220 | RAICHUR-JURALA_2_IPP | RAICHUR_220 | 11:12 | 15:12 | 4:00 | LINE CLEAR AVAILED |
| 441 | 18-May-2022 | GULBARGA | 110 | SHAHAPUR-KHANAPUR | KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP | 10:55 (11.04.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 442 | 18-May-2022 | GULBARGA | 110 | HUMNABAD-SASTHAPUR | RAJESHWAR_110,SASTHAPUR_110,MANTHAL_110 | 15:22(17/5/2022) | | | LINE OPEN,LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|-------------------------|---|-------------------|-------------------|----------|----------------------|
| 443 | 18-May-2022 | GULBARGA | 110 | STAR METALLIC-MUNIRABAD | MUNIRABAD_220 | 22:35(18.05.2022) | | | LINE OPEN,LINE FAULT |
| 444 | 18-May-2022 | GULBARGA | 110 | HV3 | CHICKSUGUR_110 | 6:35 | 6:50 | 0:15 | TRANSFORMER FAULT |
| 445 | 18-May-2022 | GULBARGA | 110 | HV3 | CHICKSUGUR_110 | 1:05 | 1:20 | 0:15 | TRANSFORMER FAULT |
| 446 | 18-May-2022 | GULBARGA | 110 | HV3 | CHICKSUGUR_110 | 11:20 | 16:15 | 4:55 | LINE CLEAR AVAILED |
| 447 | 18-May-2022 | GULBARGA | 110 | HV2 | CHICKSUGUR_110 | 11:15 | 12:58 | 1:43 | LINE CLEAR AVAILED |
| 448 | 18-May-2022 | GULBARGA | 110 | HV1 | CHICKSUGUR_110 | 7:38 | 12:35 | 4:57 | LINE CLEAR AVAILED |
| 449 | 18-May-2022 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 18:50 | 18:57 | 0:07 | TRANSFORMER FAULT |
| 450 | 18-May-2022 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 21:55 | 22:00 | 0:05 | TRANSFORMER FAULT |
| 451 | 18-May-2022 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 22:13 | 22:15 | 0:02 | TRANSFORMER FAULT |
| 452 | 18-May-2022 | GULBARGA | 110 | HV1 | BENNUR_110 | 10:00 | 10:50 | 0:50 | TRANSFORMER FAULT |
| 453 | 18-May-2022 | GULBARGA | 110 | HV1 | BENNUR_110 | 15:50 | 16:00 | 0:10 | TRANSFORMER FAULT |
| 454 | 18-May-2022 | GULBARGA | 110 | HV1 | SIRWAR_110 | 23:15(17.05.2022) | 00:15(18.05.2022) | 1:00HRS | TRANSFORMER CHARGED |
| 455 | 18-May-2022 | GULBARGA | 110 | HV1 | HALAKUNDI_110 | 7:20 | 8:50 | 1:30 | TRANSFORMER FAULT |
| 456 | 18-May-2022 | GULBARGA | 110 | HV2 | SHAHAPUR_220 | 15:40 | 15:50 | 0:10 | TRANSFORMER FAULT |
| 457 | 18-May-2022 | GULBARGA | 110 | HV2 | HATTI_110 | 18:23 | 18:25 | 0:02 | TRANSFORMER FAULT |
| 458 | 18-May-2022 | GULBARGA | 110 | HV2 | HATTI_110 | 18:27 | 19:09 | 0:42 | TRANSFORMER FAULT |
| 459 | 18-May-2022 | GULBARGA | 110 | HV2 | HATTI_110 | 19:22 | 19:30 | 0:08 | TRANSFORMER FAULT |
| 460 | 18-May-2022 | GULBARGA | 110 | HV2 | HATTI_110 | 21:17 | 21:18 | 0:01 | TRANSFORMER FAULT |
| 461 | 18-May-2022 | GULBARGA | 110 | HV2 | ALIPUR_220 | 4:40 | 5:20 | 0:40 | TRANSFORMER FAULT |
| 462 | 18-May-2022 | GULBARGA | 110 | HV3 | MUNIRABAD_220 | 3:15 | 4:18 | 1:03 | TRANSFORMER FAULT |
| 463 | 18-May-2022 | GULBARGA | 110 | HV1 | SINDHANOOR_220 | 20:05 | 23:35 | 3:30 | TRANSFORMER FAULT |
| 464 | 18-May-2022 | GULBARGA | 110 | KAPNOOR-MADIYAL | MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY | 1:45 | 2:08 | 0:23 | LINE FAULT |
| 465 | 18-May-2022 | GULBARGA | 110 | MATAMARI-RAICHUR | MATAMARI_110 | 18:15 | 18:40 | 0:25 | MAIN SUPPLY FAILURE |
| 466 | 18-May-2022 | GULBARGA | 110 | YAPALDINI-VADAVATTI | YAPALDINI_110 | 18:15 | 18:40 | 0:25 | MAIN SUPPLY FAILURE |
| 467 | 18-May-2022 | GULBARGA | 110 | YEREGERA-RAICHUR | YEREGERA_110 | 18:15 | 18:38 | 0:23 | MAIN SUPPLY FAILURE |
| 468 | 18-May-2022 | GULBARGA | 110 | MASKI-SINDHNOOR | MASKI_110 | 2:46 | 2:56 | 0:10 | LINE FAULT |
| 469 | 18-May-2022 | GULBARGA | 110 | MASKI-SINDHNOOR | MASKI_110 | 3:44 | 4:00 | 0:16 | LINE FAULT |
| 470 | 18-May-2022 | GULBARGA | 110 | RAICHUR-APMC_1 | APMC_110,CHIKSUGUR_110 ,SHAKTINAGAR_110 | 18:17 | 18:45 | 0:28 | LINE FAULT |
| 471 | 18-May-2022 | GULBARGA | 110 | RAICHUR-APMC_2 | APMC_110,CHIKSUGUR_110 ,SHAKTINAGAR_110 | 18:17 | 18:45 | 0:28 | LINE FAULT |
| 472 | 18-May-2022 | GULBARGA | 110 | RAICHUR-SHAHAPUR1 | GABBUR_110 | 17:54 | 18:40 | 0:46 | LINE FAULT |
| 473 | 18-May-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | YADGIR_110,SAIDAPUR_110 ,KHANAPUR_110,WADGERA_110 | 16:48 | 16:52 | 0:04 | LINE CLEAR AVAILED |
| 474 | 18-May-2022 | GULBARGA | 110 | SEDAM-CHINCHOLI | CHINCHOLI_110 | 13:35 | 15:30 | 1:55 | LINE CLEAR AVAILED |
| 475 | 18-May-2022 | GULBARGA | 110 | KUSTAGI-TAWERGERE | TAWERGERE_110 | 21:14 | 0:00 | 2:46 | LINE FAULT |
| 476 | 18-May-2022 | GULBARGA | 110 | KUSTAGI-KANAKGIRI | GANADAL_110 | 21:18 | 23:30 | 2:12 | LINE FAULT |
| 477 | 18-May-2022 | GULBARGA | 110 | MASKI-SINDHNOOR | MASKI_110 | 2:46 | 2:56 | 0:10 | LINE FAULT |
| 478 | 18-May-2022 | GULBARGA | 110 | MASKI-SINDHNOOR | MASKI_110 | 3:55 | 4:02 | 0:07 | LINE FAULT |
| 479 | 18-May-2022 | GULBARGA | 110 | MUDDAPUR-SINDHNOOR | MUDDAPUR_110 | 8:37 | 13:03 | 4:26 | LINE CLEAR AVAILED |
| 480 | 18-May-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 3:23 | 3:33 | 0:10 | LINE FAULT |
| 481 | 18-May-2022 | GULBARGA | 110 | MALLAT-SIRWAR | SIRWAR_110 | 18:47 | 18:51 | 0:04 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--------------------------------|--|--------------------|-----------|----------|------------------------------|
| 482 | 18-May-2022 | GULBARGA | 110 | MALLAT-BYAGAWATH1 | BYAGAWATH_110,VALKAMD INNI_110 | 19:42 | 20:00 | 0:18 | LINE FAULT |
| 483 | 18-May-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 21:38 | 21:48 | 0:10 | LINE FAULT |
| 484 | 18-May-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 22:34 | 22:47 | 0:13 | LINE FAULT |
| 485 | 18-May-2022 | GULBARGA | 110 | HUMNABAD-MANEIKHELLI | MANAIKHELLI_110 | 1:09 | 1:27 | 0:18 | LINE FAULT |
| 486 | 18-May-2022 | GULBARGA | 110 | ALIPUR-MUNIRABAD | TORANGALLU_110,KUDITINI_110,KURUGOD_110,SHATV AHANA_IPP,AGARWAL_IPP,S UZLON_IPP,KAMLAPUR_110, METRI_110,RBNS FACTORY | 4:40 | 5:20 | 0:40 | LINE FAULT |
| 487 | 18-May-2022 | GULBARGA | 110 | MUNIRABAD-DONIMALAI2 | STAR METALLIC_IPP,JINDAL PUMP HOUSE | 22:38 | 23:57 | 1:19 | LINE FAULT |
| 488 | 18-May-2022 | GULBARGA | 110 | MUNIRABAD-DONIMALAI2 | STAR METALLIC_IPP,JINDAL PUMP HOUSE | 23:06 | 23:57 | 0:51 | LINE FAULT |
| 489 | 18-May-2022 | GULBARGA | 110 | SINDHANOOR220-SINDHANOOR1,2 | SINDHANOOR_110,MUDDAP UR_110,MASKI_110,HATTI_1 10,VALKAMDINNI_110,BYAG WAT_110 | 7:55 | 12:45 | 4:50 | NFBC ISSUED |
| 490 | 18-May-2022 | GULBARGA | 110 | SINDHANOOR220-SIRUGUPPA | DHADESUGUR_110,SIRUGUP PA_110,TEKKALKOTE_110,N SL SUGARS_IPP,SIRIGERE CROSS_110,VOORA_IPP | 8:03 | 12:40 | 4:37 | NFBC ISSUED |
| 491 | 18-May-2022 | GULBARGA | 110 | SINDHANOOR220-ADAVI AMARESHWAR | MANVI_110,MADLAPUR_11 0,KURDICROSS_110,ADAVI AMARESHWAR_110 | 8:03 | 12:45 | 4:42 | NFBC ISSUED |
| 492 | 18-May-2022 | GULBARGA | 110 | SINDHANOOR220-SINDHANOOR2 | SINDHANOOR_110,VALKAM DINNI_110,BYAGWAT_110 | 20:45 | 20:55 | 0:10 | LINE FAULT |
| 493 | 18-May-2022 | GULBARGA | 110 | SINDHANOOR220-ADAVI AMARESHWAR | MANVI_110,MADLAPUR_11 0,KURDICROSS_110,ADAVI AMARESHWAR_110 | 20:45 | 20:55 | 0:10 | LINE FAULT |
| 494 | 18-May-2022 | GULBARGA | 66 | ITTAGI-KUDLIGI_2 | KUDLIGI_66,CHORNOOR_66, BANVIKAL_66,BADELADUKU _220,ACME SOLAR_IPP | 13:03 (18.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 495 | 18-May-2022 | GULBARGA | 66 | HV2 | TAMBRAHALLI_66 | 20:50 | 20:55 | 0:05 | TRANSFORMER FAULT |
| 496 | 18-May-2022 | GULBARGA | 66 | HV1 | PUNABGHATA_66 | 15:20 | 15:30 | 0:10 | LINE CLEAR AVAILED |
| 497 | 18-May-2022 | GULBARGA | 66 | BADELADUKU-KUDLIGI | BADELADUKU_220,BANVIKA L_66,CHORNOOR_66,ACME SOLAR_IPP | 13:40 | 17:25 | 3:45 | NFBC ISSUED |
| 498 | 18-May-2022 | GULBARGA | 66 | NEELGUNDA-PUNABGATTA | PUNABGATTA_66, UCHCHANGIDURGA_66 | 1:47 | 2:01 | 0:14 | LINE FAULT |
| 499 | 18-May-2022 | HASSAN | 66 | RAMNAT-KATTEPURA_MINIH | RAMNATHPURA_66 | 12:41(11.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 500 | 18-May-2022 | HASSAN | 110 | JOG-NK2 | mghejog_gen | 17:05(28.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|----------------------|---------------------|--------------------|--------------------|----------|-------------------------------------|
| 501 | 18-May-2022 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 12:15 (29.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 502 | 18-May-2022 | HASSAN | 110 | HV3 | JOG_110 | 10:55(05.04.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 503 | 18-May-2022 | HASSAN | 220 | HV3 | KAVOOR_220 | 19:55(30.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 504 | 18-May-2022 | HASSAN | 110 | HV2 | BARANGI_110 | 10:22(17.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 505 | 18-May-2022 | HASSAN | 66 | HV1 | RAMPURA_66 | 21:24(17.05.2022) | 12:48(18.05.2022) | 15:24HRS | TRANSFORMER CHARGED |
| 506 | 18-May-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY1 | MRSMSG_220 | 19:50(16.05.2022) | 17:33(18.05.2022) | 45:43HRS | LINE CHARGED |
| 507 | 18-May-2022 | HASSAN | 220 | GERSOPA-TALGUPA1 | gerusoppa_gen | 19:49(16.05.2022) | 17:40(18.05.2022) | 45:51HRS | LINE CHARGED |
| 508 | 18-May-2022 | HASSAN | 110 | PUTTUR-PUTUR 2 | PUTTUR_220 | 22:06(18.05.2022) | | | LINE OPEN,LINE FAULT |
| 509 | 18-May-2022 | HASSAN | 66 | CHANNAR-UDAYAPURA | CHANNARAYAPATNA_66 | 23:21(18.05.2022) | | | LINE OPEN,LINE FAULT |
| 510 | 18-May-2022 | HASSAN | 220 | KAVOOR-KEMR2 | KAVOOR_220 | 10:15 | 16:03 | 5:48 | LINE CLEAR AVAILED |
| 511 | 18-May-2022 | HASSAN | 220 | MRSSHM-VARAH12 | MRSMSG_220 | 11:27 | 14:52 | 3:25 | NFBC ISSUED |
| 512 | 18-May-2022 | HASSAN | 220 | MRSSHM-VARAH12 | MRSMSG_220 | 15:01 | 16:08 | 1:07 | NFBC ISSUED |
| 513 | 18-May-2022 | HASSAN | 220 | MRSSHM-VARAH13 | MRSMSG_220 | 17:18 | 18:39 | 1:21 | NFBC ISSUED |
| 514 | 18-May-2022 | HASSAN | 220 | MRSSHM-VARAH13 | MRSMSG_220 | 18:41 | 18:55 | 0:14 | NFBC ISSUED |
| 515 | 18-May-2022 | HASSAN | 66 | MRSSHM-DVG2 | MRSMSG_220 | 14:13 | 14:56 | 0:43 | LINE FAULT |
| 516 | 18-May-2022 | HASSAN | 220 | MSEZ-KAVOOR2 | MSEZ_220 | 10:18 | 16:02 | 5:44 | NFBC ISSUED |
| 517 | 18-May-2022 | HASSAN | 220 | VARAH1-SHIMOGA2 | varahi_gen | 11:00 | 14:52 | 3:52 | LINE CLEAR AVAILED |
| 518 | 18-May-2022 | HASSAN | 220 | VARAH1-SHIMOGA2 | varahi_gen | 15:01 | 16:08 | 1:07 | LINE CLEAR AVAILED |
| 519 | 18-May-2022 | HASSAN | 220 | VARAH1-SHMG3 | varahi_gen | 17:18 | 18:38 | 1:20 | LINE CLEAR AVAILED |
| 520 | 18-May-2022 | HASSAN | 220 | VARAH1-SHMG3 | varahi_gen | 18:41 | 18:55 | 0:14 | LINE CLEAR AVAILED |
| 521 | 18-May-2022 | HASSAN | 110 | HV1 | BARANGI_110 | 23:20 | 23:58 | 0:38 | LINE CLEAR AVAILED |
| 522 | 18-May-2022 | HASSAN | 110 | GURUVA-SLVPWR | GURUVAYANAKERE_110 | 8:41 | 15:07 | 6:26 | LINE CLEAR AVAILED |
| 523 | 18-May-2022 | HASSAN | 110 | KADUR-AJAMPURA | KADUR_220 | 6:36 | 7:18 | 0:42 | LINE FAULT |
| 524 | 18-May-2022 | HASSAN | 110 | KITTADA-BLGAVE | KITTADAHALLY_110 | 10:00 | 17:30 | 7:30 | LINE CLEAR AVAILED |
| 525 | 18-May-2022 | HASSAN | 110 | HV1 | KITTADAHALLY_110 | 10:00 | 17:30 | 7:30 | LINE CLEAR AVAILED |
| 526 | 18-May-2022 | HASSAN | 110 | HV2 | KITTADAHALLY_110 | 10:00 | 17:30 | 7:30 | LINE CLEAR AVAILED |
| 527 | 18-May-2022 | HASSAN | 110 | PUTTUR-SLTR | PUTTUR_220 | 13:05 | 14:28 | 1:23 | LINE CLEAR AVAILED |
| 528 | 18-May-2022 | HASSAN | 66 | HV2 | ARAKALGUD_66 | 13:00 | 13:05 | 0:05 | TRANSFORMER FAULT |
| 529 | 18-May-2022 | HASSAN | 66 | HV4 | BALEHONNUR_66 | 0:58 | 1:09 | 0:11 | TRANSFORMER FAULT |
| 530 | 18-May-2022 | HASSAN | 66 | HV4 | BALEHONNUR_66 | 7:04 | 7:18 | 0:14 | TRANSFORMER FAULT |
| 531 | 18-May-2022 | HASSAN | 66 | HV4 | BALEHONNUR_66 | 13:53 | 14:01 | 0:08 | TRANSFORMER FAULT |
| 532 | 18-May-2022 | HASSAN | 66 | BANDISH-RAMNATHPURA | BANDISHETTIHALLY_66 | 12:32 | 12:49 | 0:17 | LINE FAULT |
| 533 | 18-May-2022 | HASSAN | 66 | CHANNAR-UDAYAPURA | CHANNARAYAPATNA_66 | 22:35 | 23:20 | 0:45 | LINE FAULT |
| 534 | 18-May-2022 | HASSAN | 66 | HV1 | HNPURA_66 | 4:30 | 4:40 | 0:10 | MAIN SUPPLY FAILURE |
| 535 | 18-May-2022 | HASSAN | 66 | HV2 | HNPURA_66 | 4:30 | 4:40 | 0:10 | MAIN SUPPLY FAILURE |
| 536 | 18-May-2022 | HASSAN | 66 | HNPURA-RAMNATHPURA | HNPURA_66 | 4:30 | 4:40 | 0:10 | MAIN SUPPLY FAILURE |
| 537 | 18-May-2022 | HASSAN | 66 | HNPURA-RAMNATHPURA | HNPURA_66 | 4:55 | 5:00 | 0:05 | MAIN SUPPLY FAILURE |
| 538 | 18-May-2022 | HASSAN | 66 | HNPURA-SOMANAHALLI | HNPURA_66 | 4:55 | 5:00 | 0:05 | MAIN SUPPLY FAILURE |
| 539 | 18-May-2022 | HASSAN | 66 | HV1 | HOLALUR_66 | 7:40 | 8:28 | 0:48 | TRANSFORMER FAULT |
| 540 | 18-May-2022 | HASSAN | 66 | HV2 | RAMPURA_66 | 0:01 | 0:15 | 0:14 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|---------------------------|---|----------------------------|-----------|----------|------------------------------|
| 541 | 18-May-2022 | HASSAN | 66 | HV2 | RAMPURA_66 | 0:25 | 0:30 | 0:05 | TRANSFORMER FAULT |
| 542 | 18-May-2022 | HASSAN | 66 | HV2 | RAMPURA_66 | 0:35 | 9:45 | 9:10 | TRANSFORMER FAULT |
| 543 | 18-May-2022 | HASSAN | 66 | HV1 | SIGEBAGE_66 | 17:20 | 17:50 | 0:30 | LINE CLEAR AVAILED |
| 544 | 18-May-2022 | HASSAN | 66 | UDAYAP-BAGUR | UDAYAPURA_66 | 23:27 | 23:29 | 0:02 | MAIN SUPPLY FAILURE |
| 545 | 18-May-2022 | HASSAN | 66 | UDAYAP-SATHENAHALLI | UDAYAPURA_66 | 23:27 | 23:29 | 0:02 | MAIN SUPPLY FAILURE |
| 546 | 18-May-2022 | HASSAN | 66 | UDAYAP-CRP 1 | UDAYAPURA_66 | 10:30 | 11:30 | 1:00 | LINE FAULT |
| 547 | 18-May-2022 | HASSAN | 66 | CHANNAR-UDAYAPURA | CHANNARAYAPATNA_66 | 23:21(18.05.2022) | | | LINE OPEN,LINE FAULT |
| 548 | 18-May-2022 | MYSURU | 66 | VAJMANGALA-HEBBANI | NO STATIONS EFFECTED | 15:07 | 15:10 | 0:03 | LINE FAULT |
| 549 | 18-May-2022 | MYSURU | 66 | HV1 | MADHUVANAHALLI_220 | 14:48 | 15:42 | 0:54 | LINE CLEAR AVAILED |
| 550 | 18-May-2022 | MYSURU | 66 | HV2 | MADHUVANAHALLI_220 | 14:48 | 15:42 | 0:54 | LINE CLEAR AVAILED |
| 551 | 18-May-2022 | MYSURU | 66 | BILIKERE-KHB | DMG_HALLI_66 | 15:41 | 15:52 | 0:11 | LINE FAULT |
| 552 | 18-May-2022 | MYSURU | 66 | CR NAGARA-CHANDAKAWADI | CHANDAKAVADI_66 | 10:14 | 10:31 | 0:17 | LINE FAULT |
| 553 | 18-May-2022 | MYSURU | 220 | KUSHALNAGARA-BASTIPURA 2 | NO STATIONS EFFECTED | 1:06 | 7:10 | 6:04 | LINE FAULT |
| 554 | 18-May-2022 | MYSURU | 66 | KR PETE 220-KR PETE 1 | AKKIHEBBAL_66 KIKKERI_66 KRPET_66 | 22:13 | 22:18 | 0:05 | LINE FAULT |
| 555 | 18-May-2022 | MYSURU | 66 | KR PETE 220-KR PETE 2 | NO STATIONS EFFECTED | 22:13 | 22:18 | 0:05 | LINE FAULT |
| 556 | 18-May-2022 | MYSURU | 66 | KR PETE 220-BOOKANAKERE | BOOKANAKERE_66 CHINAKURALI_66 GANJIGERE_66 SHEELUNERE_66 | 23:21 | 23:27 | 0:06 | LINE FAULT |
| 557 | 18-May-2022 | MYSURU | 66 | KUNTHUR-DR PETE | JANNUR_66 MUGUR_66 SANTHEMARAHALLI_66 TNARASIPURA_66 THAYUR_66 | 10:50 | 10:55 | 0:05 | LINE FAULT |
| 558 | 18-May-2022 | MYSURU | 66 | HV2 | MANDYA_66 | 9:03 | 9:09 | 0:06 | TRANSFORMER FAULT |
| 559 | 18-May-2022 | MYSURU | 66 | KOPPA -NSL | NO STATIONS EFFECTED | 12:26 | 12:51 | 0:25 | HAND TRIPPED |
| 560 | 18-May-2022 | MYSURU | 66 | BANIMANTAPA-VIJAYANAGAR | BANNIMANTAP_66 | 11:10 | 12:03 | 0:53 | LINE CLEAR AVAILED |
| 561 | 18-May-2022 | MYSURU | 66 | HV1 | DEVANOORNGUDU_66 | 12:46 | 16:36 | 3:49 | LINE CLEAR AVAILED |
| 562 | 18-May-2022 | MYSURU | 66 | D R PETE-KUNTHUR | JANNUR_66 MUGUR_66 SANTHEMARAHALLI_66 TNARASIPURA_66 THAYUR_66 | 16:00 | 16:05 | 0:05 | LINE FAULT |
| 563 | 18-May-2022 | MYSURU | 66 | KOLLEGALA-MADHUVANAHALLI | NO STATIONS EFFECTED | 11:33 | 13:34 | 2:01 | HAND TRIPPED |
| 564 | 18-May-2022 | MYSURU | 66 | HV2 | NAGAMANGALA_66 | 11:45 | 12:20 | 0:35 | HAND TRIPPED |
| 565 | 18-May-2022 | MYSURU | 66 | HV1 | SINDHUVALI_66 | 18:00 | 19:10 | 1:10 | HAND TRIPPED |
| 566 | 18-May-2022 | MYSURU | 66 | HV2 | SINDHUVALI_66 | 19:06 | 19:10 | 0:04 | HAND TRIPPED |
| 567 | 18-May-2022 | MYSURU | 66 | TUBINAKERE-NAGAMANGALA 1 | NO STATIONS EFFECTED | 6:10:00 AM (15/05/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 568 | 18-May-2022 | MYSURU | 66 | HEBBANI-TK HALLI | NO STATIONS EFFECTED | 12:03:00 (14.5.2022) | | | LINE OPEN,LINE FAULT |
| 569 | 18-May-2022 | MYSURU | 66 | KHB STATION-BILIKERE | NO STATIONS EFFECTED | 10:57:05 (4/5/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 570 | 18-May-2022 | MYSURU | 66 | DUNDANAHALLY-HULIYURDURGA | NO STATIONS EFFECTED | 8:36:34 (30/04/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 571 | 18-May-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 6:26:00 PM (22/04/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 572 | 18-May-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16:00 (08/12/2021) | | | LINE OPEN,LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|---|--|-----------------------|-----------------------|-----------|-------------------------------------|
| 573 | 18-May-2022 | TUMKUR | 220 | CHITRADURGA 220kV-THALLAK | CHITRADURGA_220 | 10:11(18.5.22) | 0:31(19.5.22) | 14:30hrs | LINE CHARGED |
| 574 | 18-May-2022 | TUMKUR | 220 | TR-3 | CHITRADURGA_220 | 10:42 | 18:46 | 8:03 | LINE CLEAR AVAILED |
| 575 | 18-May-2022 | TUMKUR | 220 | GUTTUR 400KV- HAVERI 1 | HAVERI_220 | 10:26 | 13:51 | 3:25 | NFBC ISSUED |
| 576 | 18-May-2022 | TUMKUR | 220 | HIRIYUR 220KV- THALLAK | THALLAK_66 | 22:14(18.5.22) | 0.08(19.5.22) | 0:53hrs | LINE CHARGED |
| 577 | 18-May-2022 | TUMKUR | 220 | THALLAK 220kV -HIRIYUR | SANEKERE_66, THALLAKK_220 | 22:11 | 23:02 | 0:51 | LINE FAULT |
| 578 | 18-May-2022 | TUMKUR | 220 | THALLAK 220kV-CHITRADURGA | CHITRADURGA_220 | 22:11 | 23:02 | 0:51 | LINE FAULT |
| 579 | 18-May-2022 | TUMKUR | 220 | PAVAGADA 220kV-MADHUGIRI 1 | PAVAGADA_220 | 19:20 | 22:50 | 3:30 | LINE FAULT |
| 580 | 18-May-2022 | TUMKUR | 220 | PAVAGADA 220kV-MADHUGIRI 2 | PAVAGADA_220 | 19:20 | 22:50 | 3:30 | LINE FAULT |
| 581 | 18-May-2022 | TUMKUR | 220 | HV1(HV & LV) | PAVAGADA_220 | 19:20 | 20:30 | 1:10 | TRANSFORMER FAULT |
| 582 | 18-May-2022 | TUMKUR | 220 | HV2(HV & LV) | PAVAGADA_220 | 19:20 | 20:30 | 1:10 | TRANSFORMER FAULT |
| 583 | 18-May-2022 | TUMKUR | 220 | PAVAGADA 220kV- GREEN KO | HEBBUR_66, BHAKTARAHALLI_66 | 19:20 | 20:30 | 1:10 | LINE FAULT |
| 584 | 18-May-2022 | TUMKUR | 66 | BALENAHALLI-CHALKERE | CHALKERE_66 | 22:10 | 23:15 | 1:04 | LINE FAULT |
| 585 | 18-May-2022 | TUMKUR | 66 | CHITRADURGA 220kV-HIRIYUR | SANEKERE_66, CHALKERE_66, IMANGALA_66 | 22:37 | 23:38 | 1:01 | LINE FAULT |
| 586 | 18-May-2022 | TUMKUR | 66 | CHITRADURGA 220kV-SUZLON 2 | SUZLON2_IPP_66 | 18:28 | 18:51 | 0:23 | HAND TRIPPED |
| 587 | 18-May-2022 | TUMKUR | 66 | CHITRADURGA 220kV-CHALLAKERE(BALENAHALLI) | BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66 | 18:28 | 18:50 | 0:22 | HAND TRIPPED |
| 588 | 18-May-2022 | TUMKUR | 66 | HIRIYUR 220KV-CHALLAKERE | CHALLAKERE_66, SANIKERE_66 | 22:07 | 22:35 | 0:28 | LINE FAULT |
| 589 | 18-May-2022 | TUMKUR | 66 | NAYAKANAHATTI66-HIREMALLANHOLE | NAYAKANAHATTI_66 | 7:38 | 7:48 | 0:09 | LINE FAULT |
| 590 | 18-May-2022 | TUMKUR | 66 | SASALUHALLA-MAYAKONDA | SAVALANGA_66 | 3:10 | 4:20 | 1:10 | MAIN SUPPLY FAILURE |
| 591 | 18-May-2022 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR2 | WELSPUN SOLAR2 | 21:47 | 22:41 | 0:54 | LINE FAULT |
| 592 | 18-May-2022 | TUMKUR | 66 | THALLAK 220kV- CHALLAKERE-2 | CHALLAKERE_66 | 22:08 | 22:38 | 0:30 | LINE FAULT |
| 593 | 18-May-2022 | TUMKUR | 66 | THALLAK 220kV-CHALLAKERE1 | CHALLAKERE_66, SANIKERE_66 | 22:10(18.5.22) | 8:32(19.5.22) | 10:22hrs | LINE CHARGED |
| 594 | 18-May-2022 | TUMKUR | 66 | URDIGERE-KOLALA | KOLALA_66 | 16:35 | 17:10 | 0:35 | LINE FAULT |
| 595 | 18-May-2022 | TUMKUR | 66 | PAVAGADA 220kV-SHYLAPURA | SHYLAPURA_66 | 19:20 | 21:00 | 1:40 | LINE FAULT |
| 596 | 18-May-2022 | TUMKUR | 66 | PAVAGADA 220kV- YN HOSAKETE | PAVAGADA_220 | 19:20 | 21:01 | 1:41 | LINE FAULT |
| 597 | 18-May-2022 | TUMKUR | 66 | PAVAGADA220-PAVAGADA2 | PAVAGADA_220 | 19:20 | 21:01 | 1:41 | LINE FAULT |
| 598 | 18-May-2022 | TUMKUR | 66 | PAVAGADA220-NAGALMADIKE | NAGALMADIKE_66 | 21:05 | 21:40 | 0:35 | LINE FAULT |
| 599 | 19-May-2022 | BAGALKOT | 110 | PG HUNSHYAL-MUDALAGI (NAGANUR) | STATION NOT AFFECTED PG HUNSHYAL_110 | 16:13 (04.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 600 | 19-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED LAXMESHWAR_110 | 17:55 (28.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 601 | 19-May-2022 | BAGALKOT | 110 | AMBEWADI- NK1 (KAVALWADA) | STATION NOT AFFECTED AMBEWADI_220 | 9:30 (09.05.2022) | 15:37 (19.05.2022) | 246:07hrs | LINE CHARGED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|---------------------------------|---|-----------------------|-----------------------|-----------|------------------------------|
| 602 | 19-May-2022 | BAGALKOT | 110 | AMBEWADI- NK2 (HALIYAL) | STATION NOT AFFECTED AMBEWADI_220 | 9:33 (09.05.2022) | 15:35 (19.05.2022) | 246:02hrs | LINE CHARGED |
| 603 | 19-May-2022 | BAGALKOT | 220 | BELGAUM- AEQUS1 | STATION NOT AFFECTED BELGAUM_220 | 10:39 (16.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 604 | 19-May-2022 | BAGALKOT | 110 | GADAG220- SAMBAPUR ROAD | STATION NOT AFFECTED SAMBAPUR ROAD_110 | 23:57 (18.05.2022) | 12:38 (19.05.2022) | 12:41hrs | LINE CHARGED |
| 605 | 19-May-2022 | BAGALKOT | 220 | DHONI-GADAG2 | STATION NOT AFFECTED DHONI_400 | 23:03 (18.05.2022) | | | LINE OPEN,LINE FAULT |
| 606 | 19-May-2022 | BAGALKOT | 220 | GADAG-DHONI2 | STATION NOT AFFECTED GADAG_220 | 23:03 (18.05.2022) | | | LINE OPEN,LINE FAULT |
| 607 | 19-May-2022 | BAGALKOT | 110 | GADAG-SAMBAPUR ROAD | STATION NOT AFFECTED GADAG_220 | 22:56 (18.05.2022) | 12:34 (19.05.2022) | 13:38hrs | LINE CHARGED |
| 608 | 19-May-2022 | BAGALKOT | 220 | 220/110KV,HV1,LV1 | STATION NOT AFFECTED GADAG_220 | 22:56 (18.05.2022) | 13:18 (19.05.2022) | 14:22hrs | TRANSFORMER CHARGED |
| 609 | 19-May-2022 | BAGALKOT | 220 | 220/110KV,HV3,LV3 | STATION NOT AFFECTED GADAG_220 | 22:56 (18.05.2022) | 12:38 (19.05.2022) | 13:42hrs | TRANSFORMER CHARGED |
| 610 | 19-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | ALAMEL_110 | 13:45 | 14:05 | 0:20 | HAND TRIPPED |
| 611 | 19-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | BANAHATTI_110 | 13:54 | 17:47 | 3:53 | LINE CLEAR AVAILED |
| 612 | 19-May-2022 | BAGALKOT | 110 | 110/11KV, HV3 | BIJAPUR CITY_110 | 21:03 | 21:08 | 0:05 | TRANSFORMER FAULT |
| 613 | 19-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | THORVI_110 | 14:54 | 15:00 | 0:06 | TRANSFORMER FAULT |
| 614 | 19-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | BYADAGI_110 | 3:26 | 4:12 | 0:46 | TRANSFORMER FAULT |
| 615 | 19-May-2022 | BAGALKOT | 110 | GADAG220- DAMBAL | DAMBAL_110 | 10:54 | 12:39 | 1:45 | LINE CLEAR AVAILED |
| 616 | 19-May-2022 | BAGALKOT | 110 | DAMBAL- MUNDARGI | DAMBAL_110 | 10:54 | 12:39 | 1:45 | HAND TRIPPED |
| 617 | 19-May-2022 | BAGALKOT | 110 | DAMBAL- SUZLON1&2 | DAMBAL_110 | 10:52 | 12:43 | 1:51 | HAND TRIPPED |
| 618 | 19-May-2022 | BAGALKOT | 110 | DAMBAL- EILS | DAMBAL_110 | 10:52 | 12:53 | 2:01 | HAND TRIPPED |
| 619 | 19-May-2022 | BAGALKOT | 110 | DAMBAL- ASE SOLAR | DAMBAL_110 | 10:53 | 12:50 | 1:57 | HAND TRIPPED |
| 620 | 19-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | DEVARGENNUR_110 | 12:10 | 12:25 | 0:15 | TRANSFORMER FAULT |
| 621 | 19-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | HALKI_110 | 11:27 | 11:34 | 0:07 | TRANSFORMER FAULT |
| 622 | 19-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | HALKI_110 | 18:02 | 18:13 | 0:11 | TRANSFORMER FAULT |
| 623 | 19-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | HIREMASALI_110 | 15:34 | 15:38 | 0:04 | TRANSFORMER FAULT |
| 624 | 19-May-2022 | BAGALKOT | 110 | 110/11KV, HV4 | HUKKERI_110 | 15:00 | 15:10 | 0:10 | TRANSFORMER FAULT |
| 625 | 19-May-2022 | BAGALKOT | 110 | HUNGUND- JINDAL (EHT) | HUNGUND_110 | 22:17 | 22:25 | 0:08 | LINE FAULT |
| 626 | 19-May-2022 | BAGALKOT | 110 | ILKAL- KUSHTAGI2 | ILKAL_110 | 6:01 | 15:18 | 9:17 | HAND TRIPPED |
| 627 | 19-May-2022 | BAGALKOT | 110 | ILKAL- AVAADA SOLAR | ILKAL_110 | 15:14 | 15:23 | 0:09 | HAND TRIPPED |
| 628 | 19-May-2022 | BAGALKOT | 110 | 110/11KV, HV4 | KERUR_110 | 12:09 | 13:25 | 1:16 | LINE CLEAR AVAILED |
| 629 | 19-May-2022 | BAGALKOT | 110 | 110/11KV, HV4 | KERUR_110 | 13:35 | 13:49 | 0:14 | LINE CLEAR AVAILED |
| 630 | 19-May-2022 | BAGALKOT | 110 | KULIGOD- GAMESHA | KULIGOD_110 | 22:10 | 22:14 | 0:04 | HAND TRIPPED |
| 631 | 19-May-2022 | BAGALKOT | 110 | LOKAPUR- DALMIYA CEMENTS | LOKAPUR_110 | 19:08 | 19:28 | 0:20 | LINE FAULT |
| 632 | 19-May-2022 | BAGALKOT | 110 | LOKAPUR- DALMIYA CEMENTS | LOKAPUR_110 | 19:34 | 20:18 | 0:44 | HAND TRIPPED |
| 633 | 19-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | MALGHAN(B)_110 | 18:25 | 19:12 | 0:47 | LINE CLEAR AVAILED |
| 634 | 19-May-2022 | BAGALKOT | 110 | MAMADAPUR(B)- BABLESHWAR | MAMADAPUR(B)_110 | 19:47 | 19:55 | 0:08 | LINE FAULT |
| 635 | 19-May-2022 | BAGALKOT | 110 | MALGHAN(S)- MANALI SUGARS | MALGHAN(S)_110 | 13:47 | 13:49 | 0:02 | HAND TRIPPED |
| 636 | 19-May-2022 | BAGALKOT | 110 | MUNDARGI- VIJAY NAGAR SUGARS | MUNDARGI_110 | 0:00 | 0:04 | 0:04 | HAND TRIPPED |
| 637 | 19-May-2022 | BAGALKOT | 110 | MUNDARGI- VIJAY NAGAR SUGARS | MUNDARGI_110 | 12:41 | 12:43 | 0:02 | HAND TRIPPED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|------------------------------------|---|-----------------------|-----------|----------|-------------------------------------|
| 638 | 19-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | NEERABUDIHAL_110 | 12:37 | 16:28 | 3:51 | LINE CLEAR AVAILED |
| 639 | 19-May-2022 | BAGALKOT | 110 | NEERABUDIHAL- KATARAKI | NEERABUDIHAL_110 | 12:03 | 19:20 | 7:17 | HAND TRIPPED |
| 640 | 19-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | GAJENDRAGAD_110 | 11:28 | 17:27 | 5:59 | LINE CLEAR AVAILED |
| 641 | 19-May-2022 | BAGALKOT | 110 | 110/33KV, HV3&HV4 | GAJENDRAGAD_110 | 11:30 | 17:27 | 5:57 | LINE CLEAR AVAILED |
| 642 | 19-May-2022 | BAGALKOT | 110 | GAJENDRAGAD- RON1&2 | GAJENDRAGAD_110 | 11:30 | 17:26 | 5:56 | LINE CLEAR AVAILED |
| 643 | 19-May-2022 | BAGALKOT | 110 | GAJENDRAGAD-KUSHTAGI | GAJENDRAGAD_110 | 11:30 | 18:43 | 7:13 | LINE CLEAR AVAILED |
| 644 | 19-May-2022 | BAGALKOT | 110 | MAHALINGAPUR- RANNABELAGALI | STATION NOT AFFECTED RANNABELAGALI_110 | 15:21 | 18:07 | 2:46 | HAND TRIPPED |
| 645 | 19-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | RANNABELAGALI_110 | 16:36 | 18:07 | 1:31 | LINE CLEAR AVAILED |
| 646 | 19-May-2022 | BAGALKOT | 110 | RON- GAJENDRAGAD1&2 | STATION NOT AFFECTED RON_110 | 11:36 | 17:11 | 5:35 | LINE CLEAR AVAILED |
| 647 | 19-May-2022 | BAGALKOT | 110 | SAMBAPUR ROAD- DAMBAL | SAMBAPUR ROAD_110 | 12:38 | 12:57 | 0:19 | HAND TRIPPED |
| 648 | 19-May-2022 | BAGALKOT | 110 | SAMBAPUR ROAD- RAILWAY LINE | SAMBAPUR ROAD_110 | 12:38 | 12:46 | 0:08 | HAND TRIPPED |
| 649 | 19-May-2022 | BAGALKOT | 110 | BABALESHWAR- MAMADAPUR(TIKOTA) | BABLESHWAR_110 | 19:48 | 20:31 | 0:43 | LINE FAULT |
| 650 | 19-May-2022 | BAGALKOT | 110 | M L PURA(RANNA BELAGALI)- UTTUR | UTTUR_110 | 15:14 | 18:07 | 2:53 | MAIN SUPPLY FAILURE |
| 651 | 19-May-2022 | BAGALKOT | 110 | TODALBAGI -JAMAKHANDI SUGARS | TODALBAGI_110 | 19:47 | 19:53 | 0:06 | LINE FAULT |
| 652 | 19-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | TODALBAGI_110 | 13:52 | 14:00 | 0:08 | TRANSFORMER FAULT |
| 653 | 19-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | TILUVALI_110 | 5:46 | 15:28 | 9:42 | TRANSFORMER FAULT |
| 654 | 19-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | TILUVALI_110 | 16:31 | 16:50 | 0:19 | LINE CLEAR AVAILED |
| 655 | 19-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | TILUVALI_110 | 17:30 (19.05.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 656 | 19-May-2022 | BAGALKOT | 110 | TIKOT-BHUTNAL(TAKKALAKI) | TIKOT_110 | 5:50 | 14:25 | 8:35 | NFBC ISSUED |
| 657 | 19-May-2022 | BAGALKOT | 110 | TARIHAL-IDLE (GAMANGHATTI) | TARIHAL_110 | 14:43 | 15:28 | 0:45 | LINE CLEAR AVAILED |
| 658 | 19-May-2022 | BAGALKOT | 110 | TAKKALKI-TIKOTA | STATON NOT AFFECTED TAKKALKI_110 | 5:50 | 14:17 | 8:27 | LINE CLEAR AVAILED |
| 659 | 19-May-2022 | BAGALKOT | 220 | KADRA-KARWAR1 | STATION NOT AFFECTED KARWAR_220 | 9:58 | 14:48 | 4:50 | LINE CLEAR AVAILED |
| 660 | 19-May-2022 | BAGALKOT | 220 | KADRA-KARWAR1 | STATION NOT AFFECTED KARWAR_220 | 15:44 | 18:17 | 2:33 | LINE CLEAR AVAILED |
| 661 | 19-May-2022 | BAGALKOT | 110 | KARWAR-BINAGA | STATION NOT AFFECTED KARWAR_220 | 9:56 | 10:04 | 0:08 | HAND TRIPPED |
| 662 | 19-May-2022 | BAGALKOT | 110 | KARWAR-BINAGA | STATION NOT AFFECTED KARWAR_220 | 18:20 | 18:25 | 0:05 | HAND TRIPPED |
| 663 | 19-May-2022 | BAGALKOT | 110 | KARWAR-KUMTA | STATION NOT AFFECTED KARWAR_220 | 18:37 | 18:38 | 0:01 | HAND TRIPPED |
| 664 | 19-May-2022 | BAGALKOT | 220 | BAGALKOT - ALAMATTI1 | STATION NOT AFFECTED BAGALKOT_220 | 6:29 | 16:30 | 10:01 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--|--|-----------------------|-----------|----------|------------------------------|
| 665 | 19-May-2022 | BAGALKOT | 220 | BAGALKOT - ALAMATTI2 | STATION NOT AFFECTED BAGALKOT_220 | 13:47 | 16:30 | 2:43 | LINE CLEAR AVAILED |
| 666 | 19-May-2022 | BAGALKOT | 220 | HUBLI-BIDNAL2 | STATION NOT AFFECTED HUBLI_220 | 8:01 | 12:42 | 4:41 | LINE FAULT |
| 667 | 19-May-2022 | BAGALKOT | 220 | AMBEWADI-PONDA2 | STATION NOT AFFECTED AMBEWADI_220 | 14:10 (19.05.2022) | | | LINE OPEN,LINE FAULT |
| 668 | 19-May-2022 | BAGALKOT | 220 | SOUDATTI-MAHALINGAPUR | STATION NOT AFFECTED SOUNDATTI_220 | 11:32 | 19:15 | 7:43 | LINE CLEAR AVAILED |
| 669 | 19-May-2022 | BAGALKOT | 110 | CHIKKODI-SADALAGA | SADALAGA_110 | 17:45 | 18:40 | 0:55 | LINE FAULT |
| 670 | 19-May-2022 | BAGALKOT | 110 | CHIKKODI-SADALAGA | SADALAGA_110 | 18:40 | 20:20 | 1:40 | LINE FAULT |
| 671 | 19-May-2022 | BAGALKOT | 110 | CHIKKODI-SADALAGA | SADALAGA_110 | 20:19 (19.05.2022) | | | LINE OPEN,LINE FAULT |
| 672 | 19-May-2022 | BAGALKOT | 220 | RANEENNUR-RATTIHALLI (TUMMINAKATTI) | STATION NOT AFFECTED RANEENNUR_220 | 3:26 | 3:40 | 0:14 | HAND TRIPPED |
| 673 | 19-May-2022 | BAGALKOT | 110 | BIJAPUR-KIADB1 | STATION NOT AFFECTED BIJAPUR_220 | 16:20 | 17:09 | 0:49 | LINE FAULT |
| 674 | 19-May-2022 | BAGALKOT | 220 | BAGEWADI-RBRK | STATION NOT AFFECTED BAGEWADI_220 | 15:37 | 16:04 | 0:27 | LINE FAULT |
| 675 | 19-May-2022 | BAGALKOT | 220 | BAGEWADI-BIJAPUR1 | STATION NOT AFFECTED BAGEWADI_220 | 17:54 (19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 676 | 19-May-2022 | BAGALKOT | 220 | BAGEWADI-BIJAPUR2 | STATION NOT AFFECTED BAGEWADI_220 | 17:54 (19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 677 | 19-May-2022 | BAGALKOT | 220 | 220/110KV,HV2,LV2 | STATION NOT AFFECTED GHATAPRABHA_220 | 19:49 | 20:27 | 0:38 | TRANSFORMER FAULT |
| 678 | 19-May-2022 | BAGALKOT | 110 | GHATAPRABHA-GOKAK | GOKAKA_110 | 19:49 | 20:31 | 0:42 | LINE FAULT |
| 679 | 19-May-2022 | BAGALKOT | 220 | MAHALINGAPUR-SOUDATTI | STATION NOT AFFECTED MAHALINGAPUR_220 | 11:33 | 19:16 | 7:43 | NFBC ISSUED |
| 680 | 19-May-2022 | BAGALKOT | 110 | HAVERI-SAVANUR | HAVERI_220 | 3:12 | 11:17 | 8:05 | LINE FAULT |
| 681 | 19-May-2022 | BAGALKOT | 110 | VAJRAMATTI-MANTUR1 | MANTUR_110 | 14:30 | 14:46 | 0:16 | LINE FAULT |
| 682 | 19-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | YELLAMANWADI_110 | 12:15 | 15:21 | 3:06 | LINE CLEAR AVAILED |
| 683 | 19-May-2022 | BAGALKOT | 110 | SHIRAHATTI-BPCL2 | STATION NOT AFFECTED SHIRAHATTI_110 | 16:40 (27.04.2022) | | | LINE OPEN,LINE FAULT |
| 684 | 19-May-2022 | BAGALKOT | 220 | SIRSI- HUBLI1 | STATION NOT AFFECTED SIRSI_220 | 15:26 (13.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 685 | 19-May-2022 | BAGALKOT | 220 | SIRSI- HUBLI2 | STATION NOT AFFECTED SIRSI_220 | 15:26 (13.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 686 | 19-May-2022 | BAGALKOT | 220 | NARENDRA- BELGAUM1 | STATION NOT AFFECTED NARENDRA_220 | 9:01 (14.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 687 | 19-May-2022 | BAGALKOT | 220 | BELGAUM- NARENDRA1 | STATION NOT AFFECTED BELGAUM_220 | 9:01 (14.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 688 | 19-May-2022 | BAGALKOT | 220 | KARWAR- KADRA2 | STATION NOT AFFECTED KARWAR_220 | 21:12 (16.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|---|---|-----------------------|-----------|----------|-------------------------------------|
| 689 | 19-May-2022 | BAGALKOT | 110 | 110/33KV, HV3 | YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 690 | 19-May-2022 | BAGALKOT | 110 | TARIHAL NAVANAGAR (H) | TARIHAL_110 | 13:10 | 15:34 | 2:24 | LINE CLEAR AVAILED |
| 691 | 19-May-2022 | BAGALKOT | 110 | YLWD-SAVALAGI | STATION NOT AFFECTED YELLAMANAWADI_110 | 24:00 (18.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 692 | 19-May-2022 | BAGALKOT | 110 | BAGALKOT-NEERABUDIHAL | STATION NOT AFFECTED BAGALKOT_220 | 5:58 | 6:15 | 0:17 | LINE FAULT |
| 693 | 19-May-2022 | BAGALKOT | 110 | BAGALKOT-NEERABUDIHAL | STATION NOT AFFECTED BAGALKOT_220 | 10:06 | 11:38 | 1:32 | LINE CLEAR AVAILED |
| 694 | 19-May-2022 | BAGALKOT | 220 | MUGALKHOD-KULIGOD | STATION NOT AFFECTED MUGALKHOD_220 | 21:09 | 22:07 | 0:58 | LINE FAULT |
| 695 | 19-May-2022 | BAGALKOT | 110 | KAWALWADA-HALIYAL | HALIYAL_110 | 12:59 | 13:10 | | HAND TRIPPED |
| 696 | 19-May-2022 | BAGALKOT | 110 | 110/33KV,HV3 | HALIYAL_110 | 13:59 (19.05.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 697 | 19-May-2022 | BAGALKOT | 220 | ATHANI-KAKMARI1 | STATION NOT AFFECTED STATION NOT AFFECTED ATHANI_220 | 3:12 | 14:48 | 11:36 | LINE FAULT |
| 698 | 19-May-2022 | BAGALKOT | 110 | GHATAPRABHA-KABBUR | KABBUR_110 | 10:41 | 16:44 | 6:03 | LINE CLEAR AVAILED |
| 699 | 19-May-2022 | BAGALKOT | 110 | MAHALINGAPUR- RANNABELAGALI | STATION NOT AFFECTED MAHALINGAPUR_220 | 17:44 | 22:30 | 4:46 | LINE CLEAR AVAILED |
| 700 | 19-May-2022 | BENGALURU | 66 | ABBIGERE - YELAHANKA 220 | ABBIGERE | 9:40 | 10:04 | 0:24 | LINE FAULT |
| 701 | 19-May-2022 | BENGALURU | 66 | ABBIGERE - WELCAST | WELCAST | 9:40 | 9:46 | 0:06 | MAIN SUPPLY FAILURE |
| 702 | 19-May-2022 | BENGALURU | 66 | GOKULA - RMV | RMV, TATA INSTITUTE (EHT) | 15:07 | 15:22 | 0:15 | LINE FAULT |
| 703 | 19-May-2022 | BENGALURU | 66 | GOKULA - HMT (EH) | HMT (EHT) | 15:07 | 15:46 | 0:39 | LINE FAULT |
| 704 | 19-May-2022 | BENGALURU | 66 | HV2 | BIEC | 6:04 | 6:26 | 0:22 | LINE CLEAR AVAILED |
| 705 | 19-May-2022 | BENGALURU | 66 | HOODY 220 - HP (EHT) | HP (EHT) | 15:52 | 16:56 | 1:04 | LINE CLEAR AVAILED |
| 706 | 19-May-2022 | BENGALURU | 66 | KENGERI SATELLITE TOWN - KUMBALAGODU | CHANDRAPPA CIRCLE | 13:00 | 14:40 | 1:40 | LINE CLEAR AVAILED |
| 707 | 19-May-2022 | BENGALURU | 66 | RMV - HEBBALA 220 | RMV, TATA INSTITUTE (EHT) | 17:25 | 17:30 | 0:05 | LOAD CHANGE OVER |
| 708 | 19-May-2022 | BENGALURU | 66 | SOMANAHALLI 220 - HAROHALLI 2 | INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT), VR DODDI, GURUVINAPURA | 13:01 | 14:49 | 1:48 | LINE CLEAR AVAILED |
| 709 | 19-May-2022 | BENGALURU | 66 | RAJANUKUNTE - DB PURA 220 | RAJANUKUNTE | 7:05 | 7:10 | 0:05 | LOAD CHANGE OVER |
| 710 | 19-May-2022 | BENGALURU | 66 | SAUDELLA - ANNABELE(DLF) | ANNABELE(DLF) | 12:17 | 14:36 | 2:19 | LINE FAULT |
| 711 | 19-May-2022 | BENGALURU | 66 | HV2 | PILLAGUMPA | 12:53 | 13:06 | 0:13 | TRANSFORMER FAULT |
| 712 | 19-May-2022 | BENGALURU | 66 | HV2 | SARIAPURA 220 | 12:59 | 13:05 | 0:06 | TRANSFORMER FAULT |
| 713 | 19-May-2022 | BENGALURU | 66 | HV1 CB | N G HULKUR | 14:40 | 14:45 | 0:04 | LINE CLEAR AVAILED |
| 714 | 19-May-2022 | BENGALURU | 66 | HV2 CB | N G HULKUR | 13:54 | 14:00 | 0:05 | LINE CLEAR AVAILED |
| 715 | 19-May-2022 | BENGALURU | 66 | HV2 CB | N G HULKUR | 15:34 | 15:40 | 0:05 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|------------------------------------|--|---------|-----------|----------|---------------------|
| 716 | 19-May-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 1 | NO STATION AFFECTED | 14:11 | 15:43 | 1:32 | LINE CLEAR AVAILED |
| 717 | 19-May-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 2 | NO STATION AFFECTED | 12:10 | 14:07 | 1:57 | LINE CLEAR AVAILED |
| 718 | 19-May-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 2 | NO STATION AFFECTED | 15:13 | 15:15 | 0:02 | LINE CLEAR AVAILED |
| 719 | 19-May-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 2 | NO STATION AFFECTED | 15:50 | 18:09 | 2:19 | LINE CLEAR AVAILED |
| 720 | 19-May-2022 | BENGALURU | 220 | HV2 | MITTEMARI 220 | 2:59 | 3:11 | 0:11 | MAIN SUPPLY FAILURE |
| 721 | 19-May-2022 | BENGALURU | 66 | MITTEMARI 220 - SADLI | SADLI | 2:59 | 3:08 | 0:08 | MAIN SUPPLY FAILURE |
| 722 | 19-May-2022 | BENGALURU | 66 | MITTEMARI 220 - JULLUPALYA | JULLUPALYA | 2:59 | 3:08 | 0:08 | MAIN SUPPLY FAILURE |
| 723 | 19-May-2022 | BENGALURU | 66 | MITTEMARI 220 - SOMENAHALLI | SOMENAHALLI, PERESANDRA | 2:59 | 3:08 | 0:08 | MAIN SUPPLY FAILURE |
| 724 | 19-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - BAGEPALLI 1 | NO STATION AFFECTED | 12:02 | 13:22 | 1:20 | HAND TRIPPED |
| 725 | 19-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - BAGEPALLI 2 | VIDHURASHWATHA, GUNDLU KOTTUR | 12:02 | 13:22 | 1:20 | HAND TRIPPED |
| 726 | 19-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - DB PURA 1 | MANCHENAHALLI, GUNDAMGERE | 12:02 | 13:22 | 1:20 | HAND TRIPPED |
| 727 | 19-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - DB PURA 2 | THONDEBHAVI | 12:02 | 13:22 | 1:20 | HAND TRIPPED |
| 728 | 19-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - PERESANDRA | D PALYA, GUDIBANDE, MANDIKAL, PERESANDRA | 12:02 | 13:22 | 1:20 | HAND TRIPPED |
| 729 | 19-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - KODIGENAHALLI | ID HALLI, KODIGENAHALLI | 12:02 | 13:22 | 1:20 | HAND TRIPPED |
| 730 | 19-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - HOSUR RAMAPURA | HOSUR RAMAPURA, NITRALLI | 12:02 | 13:22 | 1:20 | HAND TRIPPED |
| 731 | 19-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - AFTL SOLAR(EHT) | AFTL SOLAR(EHT) | 12:02 | 13:22 | 1:20 | HAND TRIPPED |
| 732 | 19-May-2022 | BENGALURU | 220 | GOWRIBIDANUR 220 - RVNL 1 | RAILWAYS | 3:01 | 3:10 | 0:09 | LINE FAULT |
| 733 | 19-May-2022 | BENGALURU | 220 | GOWRIBIDANUR 220 - RVNL 2 | NO STATION AFFECTED | 3:01 | 3:10 | 0:09 | LINE FAULT |
| 734 | 19-May-2022 | BENGALURU | 220 | GOWRIBIDANUR 220 - PGCIL 1 | NO STATION AFFECTED | 3:06 | 11:00 | 7:54 | MAIN SUPPLY FAILURE |
| 735 | 19-May-2022 | BENGALURU | 220 | HV1 | GOWRIBIDANUR 220 | 12:02 | 13:19 | 1:17 | LINE CLEAR AVAILED |
| 736 | 19-May-2022 | BENGALURU | 220 | HV2 | GOWRIBIDANUR 220 | 12:02 | 13:19 | 1:17 | LINE CLEAR AVAILED |
| 737 | 19-May-2022 | BENGALURU | 66 | HV1 | BAIRAKURU | 11:15 | 12:55 | 1:40 | LINE CLEAR AVAILED |
| 738 | 19-May-2022 | BENGALURU | 66 | HV1 | BAIRAKURU | 13:53 | 14:00 | 0:07 | LINE CLEAR AVAILED |
| 739 | 19-May-2022 | BENGALURU | 66 | HV2 | GUDEMARANAHALLI | 12:30 | 12:40 | 0:10 | LINE CLEAR AVAILED |
| 740 | 19-May-2022 | BENGALURU | 66 | HV1 | IRGAMPALLI | 22:15 | 22:30 | 0:15 | TRANSFORMER FAULT |
| 741 | 19-May-2022 | BENGALURU | 66 | HV2 | KEMBODI | 15:46 | 17:12 | 1:25 | LINE CLEAR AVAILED |
| 742 | 19-May-2022 | BENGALURU | 66 | HV2 | MALLASANDRA | 14:00 | 14:30 | 0:29 | LINE CLEAR AVAILED |
| 743 | 19-May-2022 | BENGALURU | 66 | HV1 | VIDHURASHWATHA | 15:48 | 16:05 | 0:16 | TRANSFORMER FAULT |
| 744 | 19-May-2022 | BENGALURU | 66 | CHINTAMANI 220 - SIDLAGHATTA | SIDLAGHATTA, MELUR | 5:40 | 5:46 | 0:05 | LINE FAULT |
| 745 | 19-May-2022 | BENGALURU | 66 | KUNDANA - DB PURA 220 | KUNDANA | 14:56 | 15:15 | 0:18 | LINE FAULT |
| 746 | 19-May-2022 | BENGALURU | 66 | MAASTHI - ADANI SOLAR (IPP) | NO STATION AFFECTED | 17:08 | 17:51 | 0:43 | LINE FAULT |
| 747 | 19-May-2022 | BENGALURU | 220 | MITTEMARI 220 - GOWRIBIDANUR 2 | NO STATION AFFECTED | 2:59 | 3:10 | 0:10 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|------------------------------|---|--------------------|------------------|----------|-------------------------------------|
| 748 | 19-May-2022 | BENGALURU | 66 | MITTEMARI 220 - SOMANATHPURA | SOMANATHPURA, CHAKAVELU, CHELUR | 8:14 | 9:00 | 0:45 | LINE CLEAR AVAILED |
| 749 | 19-May-2022 | GULBARGA | 400 | BTPSG-GUTTUR | GUTTUR_400 | 11:38(19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 750 | 19-May-2022 | GULBARGA | 400 | BTPSG-HIRIYUR2 | HIRIYUR_400 | 16:12(08.05.2022) | | | LINE OPEN,LINE FAULT |
| 751 | 19-May-2022 | GULBARGA | 220 | ALIPUR-RAGALPADU | RAGALPADU_220 | 2:35(17.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 752 | 19-May-2022 | GULBARGA | 220 | LINGAPUR-BTPS | LINGAPUR_220 | 01:55(17.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 753 | 19-May-2022 | GULBARGA | 220 | KUDLIGI-HIREMALLANAHALLI 1&2 | KUDLIGI_220 | 17:25(08.05.2022) | | | LINE OPEN,LINE FAULT |
| 754 | 19-May-2022 | GULBARGA | 220 | HV2 | KUDLIGI_220 | 16:18(12.08.2021) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 755 | 19-May-2022 | GULBARGA | 220 | HV1 | KUSATGI_220 | 6:00 | 6:23 | 0:23 | TRANSFORMER FAULT |
| 756 | 19-May-2022 | GULBARGA | 220 | MALLAT-RTPS | MALLAT_220 | 22:22 | 23:02 | 0:40 | LINE FAULT |
| 757 | 19-May-2022 | GULBARGA | 220 | KAPANOOR-SHAHAPUR | KAPNOOR_220 | 11:36 | 16:40 | 5:04 | LINE CLEAR AVAILED |
| 758 | 19-May-2022 | GULBARGA | 220 | SHAHAPUR-LINGASUGUR | SHAHAPUR_220 | 23:10 | 23:46 | 0:36 | LINE FAULT |
| 759 | 19-May-2022 | GULBARGA | 220 | RAICHUR-JURALA_1_IPP | RAICHUR_220 | 11:57 | 17:10 | 5:13 | NFBC ISSUED |
| 760 | 19-May-2022 | GULBARGA | 220 | RAICHUR-JURALA_2_IPP | RAICHUR_220 | 11:57 | 17:10 | 5:13 | NFBC ISSUED |
| 761 | 19-May-2022 | GULBARGA | 110 | HUMNABAD-SASTHAPUR | RAJESHWAR_110,SASTHAPUR_110,MANTHAL_110 | 15:22(17/5/2022) | | | LINE OPEN,LINE FAULT |
| 762 | 19-May-2022 | GULBARGA | 110 | SHAHAPUR-KHANAPUR | KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP | 10:55 (11.04.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 763 | 19-May-2022 | GULBARGA | 110 | HV1 | SHAKTINAGAR_110 | 9:30 | 13:40 | 4:10 | LINE CLEAR AVAILED |
| 764 | 19-May-2022 | GULBARGA | 110 | HV2 | SHAKTINAGAR_110 | 13:52 | 14:58 | 1:06 | LINE CLEAR AVAILED |
| 765 | 19-May-2022 | GULBARGA | 110 | HV4 | YELBURGA_110 | 15:54 | 16:20 | 0:26 | TRANSFORMER FAULT |
| 766 | 19-May-2022 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 18:19 | 18:27 | 0:08 | TRANSFORMER FAULT |
| 767 | 19-May-2022 | GULBARGA | 110 | HV1 | YAKATPUR_110 | 11:50 | 12:55 | 1:05 | LINE CLEAR AVAILED |
| 768 | 19-May-2022 | GULBARGA | 110 | HV1 | TEKKALKOTE_110 | 8:50 | 13:25 | 4:35 | TRANSFORMER FAULT |
| 769 | 19-May-2022 | GULBARGA | 110 | HV2 | TEKKALKOTE_110 | 13:15 | 13:25 | 0:10 | LINE CLEAR AVAILED |
| 770 | 19-May-2022 | GULBARGA | 110 | HV1 | HALAKUNDI_110 | 7:05 | 9:05 | 2:00 | LINE CLEAR AVAILED |
| 771 | 19-May-2022 | GULBARGA | 110 | HV1 | HALAKUNDI_110 | 13:55 | 14:10 | 0:15 | TRANSFORMER FAULT |
| 772 | 19-May-2022 | GULBARGA | 110 | HV1 | HALAKUNDI_110 | 14:20 | 18:05 | 3:45 | LINE CLEAR AVAILED |
| 773 | 19-May-2022 | GULBARGA | 110 | HV1 | MATAMARI_110 | 8:50 | 8:55 | 0:05 | TRANSFORMER FAULT |
| 774 | 19-May-2022 | GULBARGA | 110 | HV3 | MUNIRABAD_220 | 3:15 | 4:18 | 1:03 | TRANSFORMER FAULT |
| 775 | 19-May-2022 | GULBARGA | 110 | HV2 | KUSTAGI_220 | 0:04 | 0:07 | 0:03 | TRANSFORMER FAULT |
| 776 | 19-May-2022 | GULBARGA | 110 | HV1 | KUSTAGI_220 | 1:26 | 14:06 | 12:40 | TRANSFORMER FAULT |
| 777 | 19-May-2022 | GULBARGA | 110 | HV2 | KUSTAGI_220 | 19:57 | 21:33 | 1:36 | TRANSFORMER FAULT |
| 778 | 19-May-2022 | GULBARGA | 110 | GANDHINAGAR-TURVIHAL | TURVIHAL_110 | 0:05 | 0:10 | 0:05 | LINE FAULT |
| 779 | 19-May-2022 | GULBARGA | 110 | GANDHINAGAR-TURVIHAL | TURVIHAL_110 | 1:20 | 1:25 | 0:05 | LINE FAULT |
| 780 | 19-May-2022 | GULBARGA | 110 | GANDHINAGAR-TURVIHAL | TURVIHAL_110 | 2:05 | 2:10 | 0:05 | LINE FAULT |
| 781 | 19-May-2022 | GULBARGA | 110 | STAR METALLIC-MUNIRABAD | MUNIRABAD_220 | 22:35(18.05.2022) | 1:01(19.05.2022) | 2:26hrs | LINE CHARGED |
| 782 | 19-May-2022 | GULBARGA | 110 | SHAHAPUR-KBJNL | KBJNL_110 | 2:55 | 3:02 | 0:07 | LINE FAULT |
| 783 | 19-May-2022 | GULBARGA | 110 | SHAHAPUR-KBJNL | KBJNL_110 | 3:57 | 4:10 | 0:13 | LINE FAULT |
| 784 | 19-May-2022 | GULBARGA | 110 | SHAHAPUR-SHORAPUR | SHORAPUR_110 | 4:41 | 4:50 | 0:09 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|-------------------------------|--|--------------------|-----------|----------|------------------------------|
| 785 | 19-May-2022 | GULBARGA | 110 | SHAHAPUR-KEMBHAVI | KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUN ASAGI_110 | 5:10 | 5:18 | 0:08 | LINE FAULT |
| 786 | 19-May-2022 | GULBARGA | 110 | YELBURGA- PARAMPOOJYA_IPP | YELBURGA_110 | 10:10 | 10:36 | 0:26 | LINE FAULT |
| 787 | 19-May-2022 | GULBARGA | 110 | YELBURGA- PARAMPOOJYA_IPP | YELBURGA_110 | 16:27 | 23:43 | 7:16 | LINE FAULT |
| 788 | 19-May-2022 | GULBARGA | 110 | HUNSIGI-KEMBHAVI | HUNSIGI_110 | 5:15 | 5:20 | 0:05 | MAIN SUPPLY FAILURE |
| 789 | 19-May-2022 | GULBARGA | 110 | AURAD-DONGARGAON | DONGARGAON_110 | 6:05 | 6:10 | 0:05 | LINE FAULT |
| 790 | 19-May-2022 | GULBARGA | 110 | TEKKALKOTE- SHAHISOLAR_IPP | TEKKALKOTE_110 | 13:15 | 13:30 | 0:15 | LINE CLEAR AVAILED |
| 791 | 19-May-2022 | GULBARGA | 110 | TEKKALKOTE-AGNISOLAR_IPP | TEKKALKOTE_110 | 13:15 | 14:55 | 1:40 | LINE CLEAR AVAILED |
| 792 | 19-May-2022 | GULBARGA | 110 | TEKKALKOTE-SIRIGUPPA | TEKKALKOTE_110 | 20:10 | 20:35 | 0:25 | MAIN SUPPLY FAILURE |
| 793 | 19-May-2022 | GULBARGA | 110 | MUDDAPUR-SINDHANOOR | MUDDAPUR_110 | 2:40 | 2:52 | 0:12 | MAIN SUPPLY FAILURE |
| 794 | 19-May-2022 | GULBARGA | 110 | MUDDAPUR-MASKI | MUDDAPUR_110 | 20:01 | 20:08 | 0:07 | LINE FAULT |
| 795 | 19-May-2022 | GULBARGA | 110 | MUDDAPUR-MASKI | MUDDAPUR_110 | 21:05 | 21:10 | 0:05 | LINE FAULT |
| 796 | 19-May-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 1:07 | 1:23 | 0:16 | LINE FAULT |
| 797 | 19-May-2022 | GULBARGA | 110 | MALLAT-SIRWAR | SIRWAR_110 | 2:17 | 2:26 | 0:09 | LINE FAULT |
| 798 | 19-May-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 3:40 | 7:37 | 3:57 | LINE FAULT |
| 799 | 19-May-2022 | GULBARGA | 110 | MALLAT-ALKOD | ALKOD_110,GALAG_110 | 3:57 | 4:05 | 0:08 | LINE FAULT |
| 800 | 19-May-2022 | GULBARGA | 110 | MALLAT-ALKOD | ALKOD_110,GALAG_110 | 4:38 | 4:46 | 0:08 | LINE FAULT |
| 801 | 19-May-2022 | GULBARGA | 110 | MALLAT-BYAGAWATH1 | BYAGAWATH_110,VALKAMD INNI_110 | 5:23 | 5:30 | 0:07 | LINE FAULT |
| 802 | 19-May-2022 | GULBARGA | 110 | MALLAT-SIRWAR | SIRWAR_110 | 5:37 | 5:47 | 0:10 | LINE FAULT |
| 803 | 19-May-2022 | GULBARGA | 110 | MALLAT-SIRWAR | SIRWAR_110 | 21:56 | 22:05 | 0:09 | LINE FAULT |
| 804 | 19-May-2022 | GULBARGA | 110 | MALLAT-ALKOD | ALKOD_110,GALAG_110 | 22:25 | 22:44 | 0:19 | LINE FAULT |
| 805 | 19-May-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 23:05 | 23:13 | 0:08 | LINE FAULT |
| 806 | 19-May-2022 | GULBARGA | 110 | SINDHANOOR-MUNIRABAD2 | MUKUNDA_110,YARADONA _110,BENNUR_110,BTPS WORKS,KAMPLI_110 | 1:20 | 2:05 | 0:45 | LINE FAULT |
| 807 | 19-May-2022 | GULBARGA | 110 | SINDHANOOR-NIRLOOTI | NIRLOOTI_IPP | 14:18 | 14:28 | 0:10 | LINE FAULT |
| 808 | 19-May-2022 | GULBARGA | 110 | KUSTAGI-ILKAL_1 | ILKAL_110 | 6:00 | 15:18 | 9:18 | LINE FAULT |
| 809 | 19-May-2022 | GULBARGA | 110 | KUSTAGI-ILKAL_2 | ILKAL_110 | 8:17 | 15:18 | 7:01 | LINE FAULT |
| 810 | 19-May-2022 | GULBARGA | 110 | RAICHUR-SHAHPUR2 | GOOGLE_110 | 22:30 | 23:25 | 0:55 | LINE FAULT |
| 811 | 19-May-2022 | GULBARGA | 66 | ITTAGI-KUDLIGI_2 | KUDLIGI_66,CHORNOOR_66, BANVIKAL_66,BADELADUKU _220,ACME SOLAR_IPP | 13:03 (18.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 812 | 19-May-2022 | GULBARGA | 66 | HV1 | UCHCHANGIDURGA_66 | 11:40 | 11:50 | 0:10 | LINE CLEAR AVAILED |
| 813 | 19-May-2022 | GULBARGA | 66 | HV2 | TAMBRAHALLI_66 | 10:15 | 10:20 | 0:05 | TRANSFORMER FAULT |
| 814 | 19-May-2022 | GULBARGA | 66 | HV1 | HARAPANAHALLI_66 | 15:00 | 15:05 | 0:05 | TRANSFORMER FAULT |
| 815 | 19-May-2022 | GULBARGA | 66 | HV1 | HALAVAGALU_66 | 15:10 | 16:40 | 1:30 | LINE CLEAR AVAILED |
| 816 | 19-May-2022 | GULBARGA | 66 | HV2 | HALAVAGALU_66 | 16:10 | 16:30 | 0:20 | LINE CLEAR AVAILED |
| 817 | 19-May-2022 | GULBARGA | 66 | HV1 | UJJAINI_66 | 12:55 | 13:00 | 0:05 | TRANSFORMER FAULT |
| 818 | 19-May-2022 | GULBARGA | 66 | HV1 | BADELADUKU_220 | 12:15 | 12:30 | 0:15 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|-------------------------|-------------------------|--------------------|------------------|----------|-------------------------------------|
| 819 | 19-May-2022 | GULBARGA | 66 | ITTAGI-HAGRIBOMMANHALLI | UP HALLI_66,HB HALLI_66 | 17:20 | 17:25 | 0:05 | LINE CLEAR AVAILED |
| 820 | 19-May-2022 | GULBARGA | 66 | UJJAINI-KOTTUR | UJJAINI_66 | 7:00 | 7:10 | 0:10 | MAIN SUPPLY FAILURE |
| 821 | 19-May-2022 | GULBARGA | 66 | UJJAINI-KOTTUR | UJJAINI_66 | 11:00 | 12:25 | 1:25 | MAIN SUPPLY FAILURE |
| 822 | 19-May-2022 | GULBARGA | 66 | UJJAINI-KOTTUR | UJJAINI_66 | 13:10 | 13:20 | 0:10 | MAIN SUPPLY FAILURE |
| 823 | 19-May-2022 | GULBARGA | 66 | UJJAINI-KOTTUR | UJJAINI_66 | 13:30 | 13:55 | 0:25 | MAIN SUPPLY FAILURE |
| 824 | 19-May-2022 | GULBARGA | 66 | UJJAINI-SOKKE | UJJAINI_66 | 17:15 | 17:30 | 0:15 | MAIN SUPPLY FAILURE |
| 825 | 19-May-2022 | GULBARGA | 66 | UJJAINI-BREIPL_IPP | UJJAINI_66 | 19:25 | 19:35 | 0:10 | LINE FAULT |
| 826 | 19-May-2022 | GULBARGA | 66 | UJJAINI-BREIPL_IPP | UJJAINI_66 | 19:40 | 20:55 | 1:15 | LINE FAULT |
| 827 | 19-May-2022 | GULBARGA | 66 | MAGALA-HIREHADAGALI | MAGALA_110 | 15:40 | 17:40 | 2:00 | MAIN SUPPLY FAILURE |
| 828 | 19-May-2022 | HASSAN | 66 | RAMNAT-KATTEPURA_MINIH | RAMNATHPURA_66 | 12:41(11.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 829 | 19-May-2022 | HASSAN | 110 | JOG-NK2 | mghejog_gen | 17:05(28.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 830 | 19-May-2022 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 12:15 (29.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 831 | 19-May-2022 | HASSAN | 110 | HV3 | JOG_110 | 10:55(05.04.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 832 | 19-May-2022 | HASSAN | 220 | HV3 | KAVOOR_220 | 19:55(30.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 833 | 19-May-2022 | HASSAN | 110 | HV2 | BARANGI_110 | 10:22(17.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 834 | 19-May-2022 | HASSAN | 110 | HV2 | ARASIKERE_110 | 19:20(19.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 835 | 19-May-2022 | HASSAN | 110 | LPH-MGHE 2 | gen_lph | 14:20(19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 836 | 19-May-2022 | HASSAN | 110 | HV2 | SORABA_110 | 15:20(19.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 837 | 19-May-2022 | HASSAN | 66 | ALDUR-BALEHONNUR | ALDUR_66 | 5:30(19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 838 | 19-May-2022 | HASSAN | 110 | PUTUR-PUTTUR2 | PUTTUR_110 | 22:06(18.05.2022) | 2:14(19.05.2022) | 4:08HRS | LINE CHARGED |
| 839 | 19-May-2022 | HASSAN | 220 | SHRAVTY-SHIRALKOPPA | sharavathy_gen | 3:26 | 21:36 | 18:10 | LINE FAULT |
| 840 | 19-May-2022 | HASSAN | 220 | SHRLKP-SGS | SHIRALKOPPA_220 | 3:26 | 21:36 | 18:10 | LINE FAULT |
| 841 | 19-May-2022 | HASSAN | 110 | SHRLKP-BARANG | SHIRALKOPPA_220 | 3:26 | 3:40 | 0:14 | MAIN SUPPLY FAILURE |
| 842 | 19-May-2022 | HASSAN | 110 | SHRLKP-KITTADAHALLI | SHIRALKOPPA_220 | 3:26 | 3:40 | 0:14 | MAIN SUPPLY FAILURE |
| 843 | 19-May-2022 | HASSAN | 110 | SHRLKP-SHIRALKOPPA | SHIRALKOPPA_220 | 3:26 | 3:40 | 0:14 | MAIN SUPPLY FAILURE |
| 844 | 19-May-2022 | HASSAN | 110 | SHRLKP-SORAB | SHIRALKOPPA_220 | 3:26 | 3:41 | 0:15 | MAIN SUPPLY FAILURE |
| 845 | 19-May-2022 | HASSAN | 110 | ALKOLA-MRS | ALKOLA_110 | 4:35 | 5:25 | 0:50 | LINE FAULT |
| 846 | 19-May-2022 | HASSAN | 110 | HV1 | BARANGI_110 | 10:00 | 11:00 | 1:00 | LINE CLEAR AVAILED |
| 847 | 19-May-2022 | HASSAN | 110 | HV1 | BIRUR_110 | 7:50 | 8:15 | 0:25 | TRANSFORMER FAULT |
| 848 | 19-May-2022 | HASSAN | 110 | HV2 | BELGUMBA | 2:55 | 3:00 | 0:05 | TRANSFORMER FAULT |
| 849 | 19-May-2022 | HASSAN | 110 | HV2 | BELGUMBA | 3:35 | 3:40 | 0:05 | TRANSFORMER FAULT |
| 850 | 19-May-2022 | HASSAN | 110 | HV2 | BELGUMBA | 3:40 | 7:45 | 4:05 | LINE CLEAR AVAILED |
| 851 | 19-May-2022 | HASSAN | 110 | HV1 | KADUR_220 | 8:04 | 10:30 | 2:26 | TRANSFORMER FAULT |
| 852 | 19-May-2022 | HASSAN | 110 | MRSSHM-GAJNUR | MRSMSG_220 | 15:15 | 15:21 | 0:06 | HAND TRIPPED |
| 853 | 19-May-2022 | HASSAN | 110 | SAGARA-SORABA | SAGARA_110 | 4:40 | 5:25 | 0:45 | MAIN SUPPLY FAILURE |
| 854 | 19-May-2022 | HASSAN | 66 | HV1 | BALEHONNUR_66 | 5:30 | 10:00 | 4:30 | TRANSFORMER FAULT |
| 855 | 19-May-2022 | HASSAN | 66 | HV1 | BALEHONNUR_66 | 1:06 | 2:42 | 1:36 | TRANSFORMER FAULT |
| 856 | 19-May-2022 | HASSAN | 66 | HV1 | BELUR_66 | 3:15 | 7:30 | 4:15 | TRANSFORMER FAULT |
| 857 | 19-May-2022 | HASSAN | 66 | HV1 | BELUR_66 | 7:40 | 8:00 | 0:20 | HAND TRIPPED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|----------------------------|---|-------------------|-----------------------|-----------|---------------------|
| 858 | 19-May-2022 | HASSAN | 66 | HV1 | BELUR_66 | 11:10 | 12:30 | 1:20 | HAND TRIPPED |
| 859 | 19-May-2022 | HASSAN | 66 | HV1 | HNPURA_66 | 18:05 | 18:17 | 0:12 | HAND TRIPPED |
| 860 | 19-May-2022 | HASSAN | 66 | HV2 | HNPURA_66 | 18:05 | 18:17 | 0:12 | HAND TRIPPED |
| 861 | 19-May-2022 | HASSAN | 66 | HNPURA-SOMANAHALLI | HNPURA_66 | 18:05 | 18:17 | 0:12 | HAND TRIPPED |
| 862 | 19-May-2022 | HASSAN | 66 | UDAYAP-SHANTIGRAMA | UDAYAPURA_66 | 11:30 | 18:15 | 6:45 | LINE CLEAR AVAILED |
| 863 | 19-May-2022 | HASSAN | 66 | UDDURKO-SUZLON1 | UDDURKOPPALU_66 | 8:45 | 12:15 | 3:30 | LINE FAULT |
| 864 | 19-May-2022 | HASSAN | 66 | CHANNAR-MALLALI | CHANNARAYAPATNA_66 | 10:05 | 11:35 | 1:30 | LINE CLEAR AVAILED |
| 865 | 19-May-2022 | HASSAN | 66 | CHANNAR-MALLALI | CHANNARAYAPATNA_66 | 13:58 | 14:20 | 0:22 | LINE FAULT |
| 866 | 19-May-2022 | HASSAN | 66 | CHANNAR-MALLALI | CHANNARAYAPATNA_66 | 17:25 | 18:25 | 1:00 | LINE CLEAR AVAILED |
| 867 | 19-May-2022 | HASSAN | 66 | CHANNAR-UDAYAPURA | CHANNARAYAPATNA_66 | 10:05 | 11:30 | 1:25 | LINE CLEAR AVAILED |
| 868 | 19-May-2022 | HASSAN | 66 | CHANNAR-UDAYAPURA | CHANNARAYAPATNA_66 | 23:21(18.05.2022) | 11:30 (19.05.2022) | 12:08 hrs | LINE CHARGED |
| 869 | 19-May-2022 | HASSAN | 110 | PUTUR-PUTTUR2 | PUTTUR_110 | 22:06(18.05.2022) | 2:14(19.05.2022) | 4:08HRS | LINE CHARGED |
| 870 | 19-May-2022 | HASSAN | 110 | SHRLKP-BARANG | SHIRALKOPPA_220 | 3:26 | 3:40 | 0:14 | MAIN SUPPLY FAILURE |
| 871 | 19-May-2022 | HASSAN | 110 | SHRLKP-KITTADAHALLI | SHIRALKOPPA_220 | 3:26 | 3:40 | 0:14 | MAIN SUPPLY FAILURE |
| 872 | 19-May-2022 | HASSAN | 110 | SHRLKP-SHIRALKOPPA | SHIRALKOPPA_220 | 3:26 | 3:40 | 0:14 | MAIN SUPPLY FAILURE |
| 873 | 19-May-2022 | HASSAN | 110 | SHRLKP-SORAB | SHIRALKOPPA_220 | 3:26 | 3:41 | 0:15 | MAIN SUPPLY FAILURE |
| 874 | 19-May-2022 | HASSAN | 110 | HV1 | BARANGI_110 | 10:00 | 11:00 | 1:00 | LINE CLEAR AVAILED |
| 875 | 19-May-2022 | HASSAN | 110 | HV2 | BELGUMBA | 3:40 | 7:45 | 4:05 | LINE CLEAR AVAILED |
| 876 | 19-May-2022 | HASSAN | 110 | MRSSHM-GAJNUR | MRSMSG_220 | 15:15 | 15:21 | 0:06 | HAND TRIPPED |
| 877 | 19-May-2022 | HASSAN | 110 | SAGARA-SORABA | SAGARA_110 | 4:40 | 5:25 | 0:45 | MAIN SUPPLY FAILURE |
| 878 | 19-May-2022 | HASSAN | 66 | HV1 | BELUR_66 | 7:40 | 8:00 | 0:20 | HAND TRIPPED |
| 879 | 19-May-2022 | HASSAN | 66 | HV1 | BELUR_66 | 11:10 | 12:30 | 1:20 | HAND TRIPPED |
| 880 | 19-May-2022 | HASSAN | 66 | HV1 | HNPURA_66 | 18:05 | 18:17 | 0:12 | HAND TRIPPED |
| 881 | 19-May-2022 | HASSAN | 66 | HV2 | HNPURA_66 | 18:05 | 18:17 | 0:12 | HAND TRIPPED |
| 882 | 19-May-2022 | HASSAN | 66 | HNPURA-SOMANAHALLI | HNPURA_66 | 18:05 | 18:17 | 0:12 | HAND TRIPPED |
| 883 | 19-May-2022 | HASSAN | 66 | UDAYAP-SHANTIGRAMA | UDAYAPURA_66 | 11:30 | 18:15 | 6:45 | LINE CLEAR AVAILED |
| 884 | 19-May-2022 | HASSAN | 66 | CHANNAR-MALLALI | CHANNARAYAPATNA_66 | 10:05 | 11:35 | 1:30 | LINE CLEAR AVAILED |
| 885 | 19-May-2022 | HASSAN | 66 | CHANNAR-MALLALI | CHANNARAYAPATNA_66 | 17:25 | 18:25 | 1:00 | LINE CLEAR AVAILED |
| 886 | 19-May-2022 | MYSURU | 66 | KUSHALNAGARA-PERİYAPATNA 1 | PERİYAPATNA_66 PONNAMPET_66 VIRAJPET_66 HANAGODU_66 KAMPLAPURA_66 | 8:27 | 8:45 | 0:18 | LINE FAULT |
| 887 | 19-May-2022 | MYSURU | 66 | KUSHALNAGARA-PERİYAPATNA 2 | BYLUKUPPE_66 | 8:27 | 8:49 | 0:22 | LINE FAULT |
| 888 | 19-May-2022 | MYSURU | 66 | KR PETE 220-KR PETE 1 | AKKIHEBBAL_66 KIKKERI_66 KRPET_66 | 3:44 | 3:54 | 0:10 | LINE FAULT |
| 889 | 19-May-2022 | MYSURU | 66 | KR PETE 220-KR PETE 2 | NO STATIONS EFFECTED | 3:44 | 3:54 | 0:10 | LINE FAULT |
| 890 | 19-May-2022 | MYSURU | 66 | KR PETE 220-BOOKANAKERE | BOOKANAKERE_66 CHINAKURALI_66 GANJIGERE_66 SHEELUNERE_66 | 3:47 | 3:54 | 0:07 | LINE FAULT |
| 891 | 19-May-2022 | MYSURU | 66 | KR PETE 220-BOOKANAKERE | BOOKANAKERE_66 CHINAKURALI_66 GANJIGERE_66 SHEELUNERE_66 | 4:12 | 4:17 | 0:05 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|---|-------------------------------|----------------------------|-----------|----------|-------------------------------------|
| 892 | 19-May-2022 | MYSURU | 66 | KR PETE 220- MAHADESHWARAPURA | MADESWARAPURA_66 | 12:42 | 18:34 | 5:52 | NFBC ISSUED |
| 893 | 19-May-2022 | MYSURU | 66 | MADHUVANAHALLI- KOLLEGALA | NO STATIONS EFFECTED | 9:26 | 9:32 | 0:06 | LINE FAULT |
| 894 | 19-May-2022 | MYSURU | 66 | MADHUVANAHALLI- LOKKANAHALLI | LOKKANAHALLI_66 PGPALYA_66 | 13:33 | 13:38 | 0:05 | LINE FAULT |
| 895 | 19-May-2022 | MYSURU | 66 | CHUNCHANAKATTE-KR NAGARA | NO STATIONS EFFECTED | 15:00 | 16:40 | 1:40 | LINE CLEAR AVAILED |
| 896 | 19-May-2022 | MYSURU | 66 | MALAVALLI-KK HALLI | NO STATIONS EFFECTED | 10:49 | 12:31 | 1:42 | LINE FAULT |
| 897 | 19-May-2022 | MYSURU | 66 | HV1 | MALAVALLI_66 | 10:49 | 11:05 | 0:16 | MAIN SUPPLY FAILURE |
| 898 | 19-May-2022 | MYSURU | 66 | MALAVALLI-SHIMSHA | HADLI_66 MALAVALLI_66 | 11:05 | 12:27 | 1:22 | LINE CLEAR AVAILED |
| 899 | 19-May-2022 | MYSURU | 66 | BANNIMANTAPA- VIJAYANAGARA | BANNIMANTAP_66 | 17:59 | 18:35 | 0:35 | LINE CLEAR AVAILED |
| 900 | 19-May-2022 | MYSURU | 66 | HV2 | JAIPUR_66 | 12:51 | 14:10 | 1:19 | LINE CLEAR AVAILED |
| 901 | 19-May-2022 | MYSURU | 66 | JAKKANAHALLY- MADESHWARAPURA | G MALLIGERE_66 | 12:22 | 18:15 | 5:53 | LINE CLEAR AVAILED |
| 902 | 19-May-2022 | MYSURU | 66 | JAKKANAHALLY-TUBINKRE | JAKKANAHALLY_66 | 10:17 | 17:48 | 7:30 | LINE CLEAR AVAILED |
| 903 | 19-May-2022 | MYSURU | 66 | KIADBMANDYA-TUMBEKERE | TUMBEKERE_66 | 17:17 | 17:22 | 0:04 | LINE FAULT |
| 904 | 19-May-2022 | MYSURU | 66 | KIRUGAVALUMALIYURU | MALIYURU_66 | 9:29 | 9:36 | 0:06 | LINE FAULT |
| 905 | 19-May-2022 | MYSURU | 66 | HV2 | KOLLEGALA_66 | 10:30 | 10:35 | 0:05 | TRANSFORMER FAULT |
| 906 | 19-May-2022 | MYSURU | 66 | TUBINAKERE-NAGAMANGALA 1 | NO STATIONS EFFECTED | 6:10:00 AM (15/05/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 907 | 19-May-2022 | MYSURU | 66 | HEBBANI-TK HALLI | NO STATIONS EFFECTED | 12:03:00(14.5.2022) | | | LINE OPEN,LINE FAULT |
| 908 | 19-May-2022 | MYSURU | 66 | KHB STATION-BILIKERE | NO STATIONS EFFECTED | 10:57:05 (4/5/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 909 | 19-May-2022 | MYSURU | 66 | DUNDANAHALLY- HULIYURDURGA | NO STATIONS EFFECTED | 8:36:34 (30/04/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 910 | 19-May-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 6:26:00 PM (22/04/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 911 | 19-May-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16:00 (08/12/2021) | | | LINE OPEN,LINE CLEAR AVAILED |
| 912 | 19-May-2022 | TUMKUR | 220 | CHITRADURGA 220- GUTTUR 220 | GUTTUR 220 | 14:05 | 15:43 | 1:38 | LINE FAULT |
| 913 | 19-May-2022 | TUMKUR | 220 | MADHUGIRI 220kV- VASANTANARASAPURA 1 | VASANTANARASAPURA LINE 1 | 2:59 | 9:51 | 6:52 | LINE FAULT |
| 914 | 19-May-2022 | TUMKUR | 220 | MADHUGIRI 220kV- PAVAGADA 220 1 | MADHUGIRI_220 | 15:28 | 16:10 | 0:42 | LINE CLEAR AVAILED |
| 915 | 19-May-2022 | TUMKUR | 220 | THALLAK 220kV- SVIP_IPP | SVIP_IPP | 5:00 | 5:15 | 0:15 | LINE FAULT |
| 916 | 19-May-2022 | TUMKUR | 220 | TR-3(HV & LV) | THALLAK_220 | 5:47 | 6:04 | 0:17 | TRANSFORMER FAULT |
| 917 | 19-May-2022 | TUMKUR | 220 | CHITRADURGA 220- GUTTUR 220 | GUTTUR 220 | 15:44(19.5.22) | | | LINE OPEN,LINE FAULT |
| 918 | 19-May-2022 | TUMKUR | 220 | DAVANGERE SRS- GUTTUR-1 | DAVANGERE_SRS_220 | 12:59(19.5.22) | | | LINE OPEN,LINE CLEAR AVAILED |
| 919 | 19-May-2022 | TUMKUR | 66 | TR1 & 2 | KADAJJI_66 | 17:43(19.5.22) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 920 | 19-May-2022 | TUMKUR | 66 | TR-1 | CHALLAKERE | 9:57 | 10:05 | 0:08 | TRANSFORMER FAULT |
| 921 | 19-May-2022 | TUMKUR | 66 | CHIKKABANAGERE- HARIYABBE | CHIKKABANAGERE_66 | 18:40 | 19:40 | 1:00 | LINE FAULT |
| 922 | 19-May-2022 | TUMKUR | 66 | CHIKKABANAGERE- HARIYABBE | CHIKKABANAGERE_66 | 21:25 | 21:42 | 0:17 | LINE CLEAR AVAILED |
| 923 | 19-May-2022 | TUMKUR | 66 | CHITRADURGA 220kV- CHITRADURGA 4 | CHITRADURGA_220 | 11:46 | 11:56 | 0:10 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--------------------------------------|--|-----------------------|-----------------------|----------|-------------------------------------|
| 924 | 19-May-2022 | TUMKUR | 66 | CHITRADURGA 220kV- PANDARAHALLI 2 | PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_6 6 | 22:21 | 22:42 | 0:21 | LINE FAULT |
| 925 | 19-May-2022 | TUMKUR | 66 | TR-1 | HANAGAL_66 | 8:30 | 8:55 | 0:25 | HAND TRIPPED |
| 926 | 19-May-2022 | TUMKUR | 66 | KALAMARANAHALLI- BPCLSOLAR IPP_66 | BPCLSOLAR_IPP_66 | 6:09 | 6:54 | 0:45 | LINE FAULT |
| 927 | 19-May-2022 | TUMKUR | 66 | MADHUGIRI 220kV- PULLAMAGATTA | PULLAMGATTA_66 | 5:49 | 6:35 | 0:46 | LINE FAULT |
| 928 | 19-May-2022 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR1 | WELSPUNSOLAR1_IPP_66 | 5:47 | 6:08 | 0:21 | LINE FAULT |
| 929 | 19-May-2022 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR2 | WELSPUN SOLAR2 | 5:47 | 6:10 | 0:23 | HAND TRIPPED |
| 930 | 20-May-2022 | BAGALKOT | 110 | PG HUNSHYAL-MUDALAGI (NAGANUR) | STATION NOT AFFECTED PG HUNSHYAL_110 | 16:13 (04.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 931 | 20-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED LAXMESHWAR_110 | 17:55 (28.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 932 | 20-May-2022 | BAGALKOT | 220 | BELGAUM- AEQUS1 | STATION NOT AFFECTED BELGAUM_220 | 10:39 (16.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 933 | 20-May-2022 | BAGALKOT | 220 | DHONI-GADAG2 | STATION NOT AFFECTED DHONI_400 | 23:03 (18.05.2022) | 14:30 (20.05.2022) | 39:27:00 | LINE FAULT |
| 934 | 20-May-2022 | BAGALKOT | 220 | GADAG-DHONI2 | STATION NOT AFFECTED GADAG_220 | 23:03 (18.05.2022) | 14:30 (20.05.2022) | 39:27:00 | LINE FAULT |
| 935 | 20-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | TILUVALI_110 | 17:30 (19.05.2022) | 11:25 (20.05.2022) | 17:55:00 | TRANSFORMER FAULT |
| 936 | 20-May-2022 | BAGALKOT | 220 | AMBEWADI-PONDA2 | STATION NOT AFFECTED AMBEWADI_220 | 14:10 (19.05.2022) | | | LINE OPEN,LINE FAULT |
| 937 | 20-May-2022 | BAGALKOT | 110 | CHIKKODI-SADALAGA | SADALAGA_110 | 20:19 (19.05.2022) | 21:10 (20.05.2022) | 24:51:00 | LINE FAULT |
| 938 | 20-May-2022 | BAGALKOT | 220 | BAGEWADI-BIJAPUR1 | STATION NOT AFFECTED BAGEWADI_220 | 17:54 (19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 939 | 20-May-2022 | BAGALKOT | 220 | BAGEWADI-BIJAPUR2 | STATION NOT AFFECTED BAGEWADI_220 | 17:54 (19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 940 | 20-May-2022 | BAGALKOT | 110 | AINAPUR-ATHANI SUGARS | AINAPUR_110 | 21:04 | 21:09 | 0:05 | LINE FAULT |
| 941 | 20-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | AINAPUR_110 | 17:10 | 17:22 | 0:12 | TRANSFORMER FAULT |
| 942 | 20-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | AIGALI_110 | 16:04 | 17:24 | 1:20 | LINE CLEAR AVAILED |
| 943 | 20-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | AREMALLAPUR_110 | 12:43 | 13:50 | 1:07 | LINE CLEAR AVAILED |
| 944 | 20-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | AREMALLAPUR_110 | 16:33 | 17:05 | 0:32 | LINE CLEAR AVAILED |
| 945 | 20-May-2022 | BAGALKOT | 110 | BABLESHWAR-MAMADAPUR (TIKOTA) | TIKOTA_110 | 21:56 | 22:26 | 0:30 | LINE FAULT |
| 946 | 20-May-2022 | BAGALKOT | 110 | 110/11KV,HV3 | BIJAPUR CITY_110 | 0:00 | 0:03 | 0:03 | TRANSFORMER FAULT |
| 947 | 20-May-2022 | BAGALKOT | 110 | DAMBAL-SUZLON1 | DAMBAL_110 | 3:25 | 12:54 | 9:29 | LINE FAULT |
| 948 | 20-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | GARAG_110 | 12:25 | 13:31 | 1:06 | LINE CLEAR AVAILED |
| 949 | 20-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | HATTARAGI_110 | 4:24 | 10:50 | 6:26 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|----------------------------------|--|--------------------|-----------|----------|------------------------------|
| 950 | 20-May-2022 | BAGALKOT | 110 | 110/33KV,HV3(HV1) | RUSTUMPUR LIS_33,BELGAUM W/S1,BELGAUM W/S2& ,KDACHINA MALKI LIS_33 HIDIKAL DAM_110 | 1:43 | 1:58 | 0:15 | TRANSFORMER FAULT |
| 951 | 20-May-2022 | BAGALKOT | 110 | 110/33KV,HV2 | KODA_33,CHIKKERUR_33 HIREKERUR_110 | 17:02 | 17:14 | 0:12 | TRANSFORMER FAULT |
| 952 | 20-May-2022 | BAGALKOT | 110 | HAVERI-TILUVALI | HAVERI_220 | 6:25 | 10:25 | 4:00 | LINE FAULT |
| 953 | 20-May-2022 | BAGALKOT | 110 | HAVERI-TILUVALI | HAVERI_220 | 12:06 | 12:08 | 0:02 | HAND TRIPPED |
| 954 | 20-May-2022 | BAGALKOT | 110 | MUDEDEBIHAL-HIREMURNAL | HIREMURNAL_110 | 10:45 | 11:21 | 0:36 | LINE FAULT |
| 955 | 20-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | HALKI_110 | 9:52 | 10:03 | 0:11 | TRANSFORMER FAULT |
| 956 | 20-May-2022 | BAGALKOT | 110 | UTTUR- F2(YADAWAD) | UTTUR_110 | 12:52 | 16:45 | 3:53 | NFBC ISSUED |
| 957 | 20-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | YADAWAD_110 | 12:55 | 16:45 | 3:50 | HAND TRIPPED |
| 958 | 20-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | YADAWAD_110 | 12:55 | 16:45 | 3:50 | HAND TRIPPED |
| 959 | 20-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | TODALBAGI_110 | 13:30 | 13:35 | 0:05 | HAND TRIPPED |
| 960 | 20-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | TUMMINKATTI_110 | 15:35 | 17:03 | 1:28 | LINE CLEAR AVAILED |
| 961 | 20-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | MUNDAGOD_110 | 12:45 | 14:45 | 2:00 | LINE CLEAR AVAILED |
| 962 | 20-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | MUNDAGOD_110 | 17:35 | 18:46 | 1:11 | LINE CLEAR AVAILED |
| 963 | 20-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | LOKAPUR_110 | 13:38 | 13:40 | 0:02 | HAND TRIPPED |
| 964 | 20-May-2022 | BAGALKOT | 110 | 110/11KV, HV4 | KULIGOD_110 | 17:37 | 19:33 | 1:56 | LINE CLEAR AVAILED |
| 965 | 20-May-2022 | BAGALKOT | 110 | KUDAL SANGAM- HUNGUND | STATION NOT AFFECTED KUDAL SANGAM_110 | 1:29 | 17:30 | 16:01 | HAND TRIPPED |
| 966 | 20-May-2022 | BAGALKOT | 110 | 110/11KV, HV4 | KERUR_110 | 11:15 | 11:52 | 0:37 | LINE CLEAR AVAILED |
| 967 | 20-May-2022 | BAGALKOT | 110 | 110/11KV, HV4 | KERUR_110 | 12:09 | 12:30 | 0:21 | LINE CLEAR AVAILED |
| 968 | 20-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | KALADAGI_110 | 11:44 | 14:10 | 2:26 | LINE CLEAR AVAILED |
| 969 | 20-May-2022 | BAGALKOT | 110 | HUNGUND- BAGEWADI (KUDAL SANGAM) | STATION NOT AFFECTED HUNAGUND_110 | 0:25 | 17:20 | 16:55 | LINE FAULT |
| 970 | 20-May-2022 | BAGALKOT | 220 | GADAG-DHONI1 | GADAG_220 | 11:22 | 14:30 | 3:06 | LINE CLEAR AVAILED |
| 971 | 20-May-2022 | BAGALKOT | 110 | BAGALKOT220-BAGALKOT2 | BAGAKOT_220 | 22:11 | 22:21 | 0:10 | LINE FAULT |
| 972 | 20-May-2022 | BAGALKOT | 220 | MK HUBLI-NARENDRA LINE2 | MK HUBLI_220 | 21:34 | 22:48 | 1:14 | LINE FAULT |
| 973 | 20-May-2022 | BAGALKOT | 110 | MK HUBLI220-MK HUBLI2 | MK HUBLI_220 | 7:40 | 8:00 | 0:20 | LINE FAULT |
| 974 | 20-May-2022 | BAGALKOT | 220 | KARWAR-KADRA1 | KARWAR_220 | 16:08 | 19:06 | 2:58 | LINE CLEAR AVAILED |
| 975 | 20-May-2022 | BAGALKOT | 220 | 220/110KV,HV2,LV2 | KARWAR_220 | 9:18 | 19:49 | 10:31 | LINE CLEAR AVAILED |
| 976 | 20-May-2022 | BAGALKOT | 110 | KARWAR-BINAGA | KARWAR_220 | 16:04 | 16:10 | 0:06 | HAND TRIPPED |
| 977 | 20-May-2022 | BAGALKOT | 110 | KARWAR-BINAGA | KARWAR_220 | 18:20 | 19:28 | 19:32 | HAND TRIPPED |
| 978 | 20-May-2022 | BAGALKOT | 220 | DHONI- GADAG1 | DHONI_400 | 11:22 | 14:30 | 1:40 | LINE FAULT |
| 979 | 20-May-2022 | BAGALKOT | 110 | SHIRAHATTI-BPCL2 | STATION NOT AFFECTED SHIRAHATTI_110 | 16:40 (27.04.2022) | | | LINE OPEN,LINE FAULT |
| 980 | 20-May-2022 | BAGALKOT | 220 | SIRSI- HUBLI1 | STATION NOT AFFECTED SIRSI_220 | 15:26 (13.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 981 | 20-May-2022 | BAGALKOT | 220 | SIRSI- HUBLI2 | STATION NOT AFFECTED SIRSI_220 | 15:26 (13.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 982 | 20-May-2022 | BAGALKOT | 220 | NARENDRA- BELGAUM1 | STATION NOT AFFECTED NARENDRA_220 | 9:01 (14.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|---------------------------------------|---|-----------------------|-----------|----------|-------------------------------------|
| 983 | 20-May-2022 | BAGALKOT | 220 | BELGAUM- NARENDRA1 | STATION NOT AFFECTED BELGAUM_220 | 9:01 (14.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 984 | 20-May-2022 | BAGALKOT | 220 | KARWAR- KADRA2 | STATION NOT AFFECTED KARWAR_220 | 21:12 (16.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 985 | 20-May-2022 | BAGALKOT | 110 | 110/33KV, HV3 | YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 986 | 20-May-2022 | BAGALKOT | 110 | YLWD-SAVALAGI | STATION NOT AFFECTED YELLAMANAWADI_110 | 24:00 (18.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 987 | 20-May-2022 | BAGALKOT | 110 | 110/33KV,HV3 | HALIYAL_110 | 13:59 (19.05.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 988 | 20-May-2022 | BAGALKOT | 110 | BELGAUM220- NEHRU NAGAR | NEHARU NAGAR_110 | 8:20 | 10:20 | 2:00 | HAND TRIPPED |
| 989 | 20-May-2022 | BAGALKOT | 110 | CHIKKODI-SADALAGA | CHIKKODI_220 | 12:00 | 7:20 | 7:20 | LINE FAULT |
| 990 | 20-May-2022 | BAGALKOT | 110 | 110/33KV,HV1 | HUKKERI_110 | 4:30 | 14:10 | 9:40 | LINE CLEAR AVAILED |
| 991 | 20-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | BHOJ_110 | 12:45 | 12:55 | 0:10 | TRANSFORMER FAULT |
| 992 | 20-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | VAJRARMATTI_110 | 11:20 | 11:30 | 0:10 | TRANSFORMER FAULT |
| 993 | 20-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | HALAKI_110 | 9:52 | 10:02 | 0:10 | TRANSFORMER FAULT |
| 994 | 20-May-2022 | BAGALKOT | 220 | 110/11KV,HV1 | RANEBENNUR_220 | 12:37 | 17:25 | 4:48 | LINE CLEAR AVAILED |
| 995 | 20-May-2022 | BAGALKOT | 110 | ATHANI220-ATHANI | ATHANI_220 | 9:15 | 9:56 | 0:41 | LINE FAULT |
| 996 | 20-May-2022 | BAGALKOT | 110 | ATHANI220-AIGALI | ATHANI_220 | 9:15 | 9:59 | 0:44 | LINE FAULT |
| 997 | 20-May-2022 | BAGALKOT | 110 | ATHANI220-BALIGERI | ATHANI_220 | 9:15 | 9:57 | 0:42 | LINE FAULT |
| 998 | 20-May-2022 | BAGALKOT | 110 | ATHANI220-SATTI | ATHANI_220 | 9:15 | 9:58 | 0:43 | LINE FAULT |
| 999 | 20-May-2022 | BAGALKOT | 110 | ATHANI220-KARI MASUTI | ATHANI_220 | 9:15 | 9:55 | 0:40 | LINE FAULT |
| 1000 | 20-May-2022 | BAGALKOT | 110 | KUDACHI220-AINAPUR | AINAPUR_110 | 20:50 | 21:00 | 0:10 | LINE FAULT |
| 1001 | 20-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | AREMALLAPUR_110 | 11:50 | 12:30 | 0:40 | LINE CLEAR AVAILED |
| 1002 | 20-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | AREMALLAPUR_110 | 15:50 | 16:20 | 0:30 | LINE CLEAR AVAILED |
| 1003 | 20-May-2022 | BENGALURU | 66 | ABBIGERE - WELCAST | ABBIGERE | 8:59 | 9:05 | 0:06 | LINE FAULT |
| 1004 | 20-May-2022 | BENGALURU | 66 | BRIGADE MEADOWS - SOMANAHALLI 220 | BRIGADE MEADOWS | 18:37 | 19:01 | 0:24 | MAIN SUPPLY FAILURE |
| 1005 | 20-May-2022 | BENGALURU | 66 | HV1 | KUMBALAGODU | 7:00 | 7:10 | 0:10 | TRANSFORMER FAULT |
| 1006 | 20-May-2022 | BENGALURU | 66 | HV1 | KUMBALAGODU | 9:57 | 9:59 | 0:02 | LOAD CHANGE OVER |
| 1007 | 20-May-2022 | BENGALURU | 66 | SOMANAHALLI 220 - SUBRAMANYAPURA 2 | BRIGADE MEADOWS, SHOBHA FOREST | 18:37 | 19:01 | 0:24 | LINE FAULT |
| 1008 | 20-May-2022 | BENGALURU | 66 | HV2 | BANASAWADI | 9:17 | 9:33 | 0:16 | LINE CLEAR AVAILED |
| 1009 | 20-May-2022 | BENGALURU | 66 | WELCAST STEEL - SRS PEENYA 220 | WELCAST STEEL | 15:05 | 15:08 | 0:03 | LOAD CHANGE OVER |
| 1010 | 20-May-2022 | BENGALURU | 66 | WELCAST STEEL - SRS PEENYA 220 | WELCAST STEEL | 1:21 | 1:24 | 0:03 | LOAD CHANGE OVER |
| 1011 | 20-May-2022 | BENGALURU | 66 | HV2 | JIGANI 220 | 13:53 | 14:22 | 0:29 | TRANSFORMER FAULT |
| 1012 | 20-May-2022 | BENGALURU | 66 | HV1 | GUNDAMGERE | 4:05 | 4:10 | 0:05 | TRANSFORMER FAULT |
| 1013 | 20-May-2022 | BENGALURU | 66 | HV1 | GUNDAMGERE | 9:00 | 9:05 | 0:05 | TRANSFORMER FAULT |
| 1014 | 20-May-2022 | BENGALURU | 66 | HV1 | GOWRIBIDANUR 220 | 15:45 | 16:05 | 0:20 | TRANSFORMER FAULT |
| 1015 | 20-May-2022 | BENGALURU | 66 | HV2 | VIDHURASHWATHA | 13:00 | 14:07 | 1:07 | LINE CLEAR AVAILED |
| 1016 | 20-May-2022 | BENGALURU | 66 | HV2 | SARJAPURA 220 | 12:59 | 13:05 | 0:05 | TRANSFORMER FAULT |
| 1017 | 20-May-2022 | BENGALURU | 66 | HV1 | N G HULKUR | 13:10 | 13:15 | 0:05 | LINE CLEAR AVAILED |
| 1018 | 20-May-2022 | BENGALURU | 66 | HV2 | N G HULKUR | 12:05 | 12:10 | 0:04 | LINE CLEAR AVAILED |
| 1019 | 20-May-2022 | BENGALURU | 66 | HV2 | M GOLLAHALLI | 9:51 | 11:14 | 1:23 | LINE CLEAR AVAILED |
| 1020 | 20-May-2022 | BENGALURU | 66 | HV1 | KYALANUR | 9:48 | 9:57 | 0:08 | TRANSFORMER FAULT |
| 1021 | 20-May-2022 | BENGALURU | 66 | HV1 | KYALANUR | 10:49 | 10:57 | 0:07 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|---------------------------------|---|--------------------|--------------------|----------|-------------------------------------|
| 1022 | 20-May-2022 | BENGALURU | 66 | HV2 | KODIHALLI CHINTAMANI | 16:37 | 16:45 | 0:07 | TRANSFORMER FAULT |
| 1023 | 20-May-2022 | BENGALURU | 66 | HV1 | IRGAMPALLI | 10:44 | 10:51 | 0:06 | LINE CLEAR AVAILED |
| 1024 | 20-May-2022 | BENGALURU | 66 | HV2 | DODDABELAVANGALA | 11:01 | 12:15 | 1:13 | LINE CLEAR AVAILED |
| 1025 | 20-May-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 1 | NO STATION AFFECTED | 15:50 | 17:15 | 1:25 | LINE CLEAR AVAILED |
| 1026 | 20-May-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 2 | NO STATION AFFECTED | 11:22 | 15:47 | 4:25 | LINE CLEAR AVAILED |
| 1027 | 20-May-2022 | BENGALURU | 66 | DABUSPET 220 - JINDAL (EHT) | JINDAL (EHT) | 3:25 | 3:45 | 0:20 | LINE FAULT |
| 1028 | 20-May-2022 | GULBARGA | 400 | BTPSG-HIRIYUR2 | HIRIYUR_400 | 16:12(08.05.2022) | | | LINE OPEN,LINE FAULT |
| 1029 | 20-May-2022 | GULBARGA | 400 | BTPSG-GUTTUR | GUTTUR_400 | 11:38(19.05.2022) | 13:30(20.05.2022) | 25:52HRS | LINE CHARGED |
| 1030 | 20-May-2022 | GULBARGA | 220 | BADELADUKU-HIREMALLANAHALLI 1&2 | BADELADUKU_220 | 17:25(08.05.2022) | | | LINE OPEN,LINE FAULT |
| 1031 | 20-May-2022 | GULBARGA | 220 | HV2 | BADELADUKU_220 | 16:18(12.08.2021) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1032 | 20-May-2022 | GULBARGA | 220 | ALIPUR-RAGALPADU | RAGALPADU_220 | 2:35(17.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1033 | 20-May-2022 | GULBARGA | 220 | LINGAPUR-BTPS | LINGAPUR_220 | 01:55(17.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1034 | 20-May-2022 | GULBARGA | 220 | MALLAT-LINGASUGUR | MALLAT_220 | 0:32 | 0:51 | 0:19 | LINE FAULT |
| 1035 | 20-May-2022 | GULBARGA | 110 | SHAHAPUR-KHANAPUR | KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP | 10:55 (11.04.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1036 | 20-May-2022 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 17:40 | 17:45 | 0:05 | TRANSFORMER FAULT |
| 1037 | 20-May-2022 | GULBARGA | 110 | HV1 | ADAVI AMARESHWAR_110 | 5:36 | 13:37 | 8:01 | TRANSFORMER FAULT |
| 1038 | 20-May-2022 | GULBARGA | 110 | HV1 | NIRNA_110 | 21:25 | 21:30 | 0:05 | TRANSFORMER FAULT |
| 1039 | 20-May-2022 | GULBARGA | 110 | HV1 | NIRNA_110 | 21:40 | 21:45 | 0:05 | TRANSFORMER FAULT |
| 1040 | 20-May-2022 | GULBARGA | 110 | HV2 | MATAMARI_110 | 8:25 | 8:30 | 0:05 | TRANSFORMER FAULT |
| 1041 | 20-May-2022 | GULBARGA | 110 | HV2 | NALWAR_110 | 16:30 | 16:40 | 0:10 | TRANSFORMER FAULT |
| 1042 | 20-May-2022 | GULBARGA | 110 | HV1 (10-MVA) | KUSTAGI_220 | 9:16 | 9:26 | 0:10 | TRANSFORMER FAULT |
| 1043 | 20-May-2022 | GULBARGA | 110 | HV1 (10-MVA) | KUSTAGI_220 | 9:41 | 9:46 | 0:05 | TRANSFORMER FAULT |
| 1044 | 20-May-2022 | GULBARGA | 110 | HV2 | KUSTAGI_220 | 10:03 | 10:27 | 0:24 | TRANSFORMER FAULT |
| 1045 | 20-May-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | YADGIR_110,SAIDAPUR_110 ,KHANAPUR_110,WADGERA_110 | 2:38 | 2:43 | 0:05 | LINE FAULT |
| 1046 | 20-May-2022 | GULBARGA | 110 | SHAHAPUR-KEMBHAVI | KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNASAGI_110 | 4:50 | 4:56 | 0:06 | LINE FAULT |
| 1047 | 20-May-2022 | GULBARGA | 110 | RAICHUR-SHAHPUR2 | GOOGLE_110 | 0:12 | 0:18 | 0:06 | LINE FAULT |
| 1048 | 20-May-2022 | GULBARGA | 110 | RAICHUR-SHAHPUR2 | GOOGLE_110 | 2:48 | 2:54 | 0:06 | LINE FAULT |
| 1049 | 20-May-2022 | GULBARGA | 110 | YELBURGA-PARAMPOOJYA_IPP | YELBURGA_110 | 0:37 | 9:35 | 8:58 | LINE FAULT |
| 1050 | 20-May-2022 | GULBARGA | 110 | YELBURGA-PARAMPOOJYA_IPP | YELBURGA_110 | 10:45 | 11:10 | 0:25 | LINE FAULT |
| 1051 | 20-May-2022 | GULBARGA | 110 | NIRNA-CHITGUPPA | NIRNA_110 | 20:30 | 20:40 | 0:10 | MAIN SUPPLY FAILURE |
| 1052 | 20-May-2022 | GULBARGA | 110 | NANDUR-GULBARGAUNIVERSITY | NANDUR_110 | 10:14 | 13:45 | 3:31 | LINE CLEAR AVAILED |
| 1053 | 20-May-2022 | GULBARGA | 110 | HUNSIGI-KEMBHAVI | HUNSIGI_110 | 4:50 | 5:00 | 0:10 | MAIN SUPPLY FAILURE |
| 1054 | 20-May-2022 | GULBARGA | 110 | HUNSIGI-KEMBHAVI | HUNSIGI_110 | 21:35 | 21:40 | 0:05 | MAIN SUPPLY FAILURE |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|-------------------------|--|--------------------|--------------------|-----------|-------------------------------------|
| 1055 | 20-May-2022 | GULBARGA | 110 | NALWAR-CLNSLR | NALWAR_110 | 16:30 | 16:35 | 0:05 | LINE CLEAR AVAILED |
| 1056 | 20-May-2022 | GULBARGA | 110 | GALAG-ALKOD | GALAG_110 | 20:30 | 20:40 | 0:10 | MAIN SUPPLY FAILURE |
| 1057 | 20-May-2022 | GULBARGA | 110 | HALBARGA-SANTAPUR | SANTAPUR_110,DONGARGO AN_110,DIGGI_110 | 4:17 | 4:23 | 0:06 | LINE FAULT |
| 1058 | 20-May-2022 | GULBARGA | 110 | HUMNABAD-ALAND | ALAND_110,KADAGANCHI_110 | 9:46 | 10:43 | 0:57 | LINE FAULT |
| 1059 | 20-May-2022 | GULBARGA | 110 | HUMNABAD-ALAND | ALAND_110,KADAGANCHI_110 | 9:46 | 10:43 | 0:57 | LINE FAULT |
| 1060 | 20-May-2022 | GULBARGA | 110 | SINDHANOOR-MUNIRABAD2 | MUKUNDA_110,YARADONA_110,BENNUR_110,BTPAS WATER WORKS,KAMPLI_110 | 0:18 | 0:28 | 0:10 | LINE FAULT |
| 1061 | 20-May-2022 | GULBARGA | 110 | SINDHANOOR-NIRLOOTI_IPP | NIRLOOTI_IPP | 0:40 | 0:50 | 0:10 | LINE FAULT |
| 1062 | 20-May-2022 | GULBARGA | 110 | KAPANOOR-MADIYAL | MADIYAL_110,NSL SUGARS,CHOWDAPUR_110 | 14:23 | 14:35 | 0:12 | LINE FAULT |
| 1063 | 20-May-2022 | GULBARGA | 110 | KAPANOOR-ALAND | ALAND_110,KADAGANCHI_110 | 14:45 | 14:49 | 0:04 | LINE FAULT |
| 1064 | 20-May-2022 | GULBARGA | 110 | SHAHAPUR-KEMBHAVI | KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUN ASAGI_110 | 21:34 | 21:37 | 0:03 | LINE FAULT |
| 1065 | 20-May-2022 | GULBARGA | 110 | RAICHUR-SINDHNOOR2 | KURDICROSS_110,MADLAPUR_110,MANVI_110 | 22:33 | 22:45 | 0:12 | LINE FAULT |
| 1066 | 20-May-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 0:41 | 0:47 | 0:06 | LINE FAULT |
| 1067 | 20-May-2022 | GULBARGA | 110 | MALLAT-SIRWAR | SIRWAR_110 | 2:21 | 2:29 | 0:08 | LINE FAULT |
| 1068 | 20-May-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 3:55 | 4:00 | 0:05 | LINE FAULT |
| 1069 | 20-May-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 4:43 | 4:48 | 0:05 | LINE FAULT |
| 1070 | 20-May-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 4:58 | 5:03 | 0:05 | LINE FAULT |
| 1071 | 20-May-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 17:50 | 18:03 | 0:13 | LINE FAULT |
| 1072 | 20-May-2022 | GULBARGA | 110 | HUMNABAD-SASTHAPUR | RAJESHWAR_110,SASTHAPUR_110,MANTHAL_110 | 15:22(17/5/2022) | 17:07(20/05/2022) | 73:45 HRS | LINE CHARGED |
| 1073 | 20-May-2022 | GULBARGA | 66 | ITTAGI-KUDLIGI_2 | KUDLIGI_66,CHORNOOR_66,BANVIKAL_66,BADELADUKU_220,ACME SOLAR_IPP | 13:03 (18.05.2022) | 18:25 (20.05.2022) | 53:22 HRS | LINE CHARGED |
| 1074 | 20-May-2022 | HASSAN | 110 | HV2 | SORABA_110 | 15:20(19.05.2022) | 13:35 (20.05.2022) | 21:55 hrs | TRANSFORMER CHARGED |
| 1075 | 20-May-2022 | HASSAN | 110 | LPH-MGHE 2 | LPH | 14:20(19.05.2022) | 13:34 (20.05.2022) | 23:13 hrs | LINE CHARGED |
| 1076 | 20-May-2022 | HASSAN | 66 | RAMNAT-KATTEPURA_MINIH | RAMNATHPURA_66 | 12:41(11.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1077 | 20-May-2022 | HASSAN | 110 | JOG-NK2 | mghejog_gen | 17:05(28.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1078 | 20-May-2022 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 12:15 (29.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1079 | 20-May-2022 | HASSAN | 110 | HV3 | JOG_110 | 10:55(05.04.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1080 | 20-May-2022 | HASSAN | 220 | HV3 | KAVOOR_220 | 19:55(30.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|-------------------------|---|-------------------|-----------|----------|-------------------------------------|
| 1081 | 20-May-2022 | HASSAN | 110 | HV2 | BARANGI_110 | 10:22(17.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1082 | 20-May-2022 | HASSAN | 66 | CHANNAR-UDAYAPURA | CHANNARAYAPATNA_66 | 23:21(18.05.2022) | | | LINE OPEN,LINE FAULT |
| 1083 | 20-May-2022 | HASSAN | 110 | HV2 | ARASIKERE_110 | 19:20(19.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1084 | 20-May-2022 | HASSAN | 66 | ALDUR-BALEHONNUR | ALDUR_66 | 5:30(19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1085 | 20-May-2022 | HASSAN | 110 | HV2 | ARASIKERE_110 | 23:35(20.05.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1086 | 20-May-2022 | HASSAN | 220 | MRSSHM-HONNALLI | MRSMG_220 | 5:55 | 12:21 | 6:26 | LINE FAULT |
| 1087 | 20-May-2022 | HASSAN | 220 | HV1 | MSEZ_220 | 11:33 | 12:13 | 0:40 | LINE CLEAR AVAILED |
| 1088 | 20-May-2022 | HASSAN | 110 | LV1 | MSEZ_220 | 11:33 | 12:13 | 0:40 | LINE CLEAR AVAILED |
| 1089 | 20-May-2022 | HASSAN | 110 | HV1 | BRAHMAVARA_110 | 10:37 | 10:45 | 0:08 | TRANSFORMER FAULT |
| 1090 | 20-May-2022 | HASSAN | 110 | HV1 | BRAHMAVARA_110 | 10:53 | 11:00 | 0:07 | TRANSFORMER FAULT |
| 1091 | 20-May-2022 | HASSAN | 110 | HV1 | KADUR_220 | 9:17 | 11:30 | 2:13 | TRANSFORMER FAULT |
| 1092 | 20-May-2022 | HASSAN | 110 | HV1 | SORABA_110 | 16:00 | 17:00 | 1:00 | LINE CLEAR AVAILED |
| 1093 | 20-May-2022 | HASSAN | 66 | HNPR2-HASS2 | HOLENARASIPURA_220 | 6:40 | 6:55 | 0:15 | LINE FAULT |
| 1094 | 20-May-2022 | HASSAN | 66 | HNPR2-HASS2 | HOLENARASIPURA_220 | 14:00 | 14:15 | 0:15 | HAND TRIPPED |
| 1095 | 20-May-2022 | HASSAN | 66 | MALALI-CRPATNA | MALALI_66 | 6:35 | 6:55 | 0:20 | MAIN SUPPLY FAILURE |
| 1096 | 20-May-2022 | HASSAN | 66 | MALALI-CRPATNA | MALALI_66 | 14:00 | 14:20 | 0:20 | LINE CLEAR AVAILED |
| 1097 | 20-May-2022 | HASSAN | 66 | RMWNGR-HASSAN | RAMESHWARNAGAR_66 | 9:45 | 9:50 | 0:05 | HAND TRIPPED |
| 1098 | 20-May-2022 | HASSAN | 66 | RMWNGR-SHANTI | RAMESHWARNAGAR_66 | 6:35 | 7:00 | 0:25 | MAIN SUPPLY FAILURE |
| 1099 | 20-May-2022 | HASSAN | 66 | SIGEBAG-KDLGRE | SIGEBAGE_66 | 21:20 | 21:35 | 0:15 | HAND TRIPPED |
| 1100 | 20-May-2022 | HASSAN | 66 | TAVAREC-HONNAVALI | TAVARECHATNAHALI_66 | 12:10 | 12:30 | 0:20 | LINE FAULT |
| 1101 | 20-May-2022 | MYSURU | 66 | KR PETE 220-KR PETE 2 | NO STATIONS EFFECTED | 11:36 | 13:25 | 1:49 | LINE CLEAR AVAILED |
| 1102 | 20-May-2022 | MYSURU | 66 | CR NAGARA-HONGANUR | HONGANUR_66 YELANDUR_66 | 17:42 | 17:48 | 0:06 | LINE FAULT |
| 1103 | 20-May-2022 | MYSURU | 66 | HV1 | YEREHALI_66 | 18:25 | 18:35 | 0:10 | TRANSFORMER FAULT |
| 1104 | 20-May-2022 | MYSURU | 66 | TUBINKERE-PANDAVAPURA | BELAGOLA_66 BANANGADI_66 DODDABYADARAHALLI_66 PANDAVAPURA_66 | 1:45 | 1:55 | 0:10 | LINE FAULT |
| 1105 | 20-May-2022 | MYSURU | 66 | TUBINKERE-NAGAMANGALA 2 | BASARALU_66 HARADANAHALLI_66 KESLAGERE_66 SHIVALLY_66 | 11:18 | 11:27 | 0:09 | HAND TRIPPED |
| 1106 | 20-May-2022 | MYSURU | 66 | TUBINKERE-NAGAMANGALA 2 | BASARALU_66 HARADANAHALLI_66 KESLAGERE_66 SHIVALLY_66 | 22:45 | 22:50 | 0:05 | LINE FAULT |
| 1107 | 20-May-2022 | MYSURU | 66 | MADHUVANAHALLI-MAMBALLI | NO STATIONS EFFECTED | 9:43 | 9:48 | 0:05 | LINE FAULT |
| 1108 | 20-May-2022 | MYSURU | 220 | HV1 | NAGAMANGALA_220 | 14:55 | 15:50 | 0:55 | LINE CLEAR AVAILED |
| 1109 | 20-May-2022 | MYSURU | 220 | HV2 | NAGAMANGALA_220 | 15:55 | 16:45 | 0:50 | LINE CLEAR AVAILED |
| 1110 | 20-May-2022 | MYSURU | 66 | BANNIMANTAPA-VIJAYNAGAR | BANNIMANTAP_66 | 10:00 | 10:48 | 0:48 | HAND TRIPPED |
| 1111 | 20-May-2022 | MYSURU | 66 | HV1 | DODDABYADARAHALLI_66 | 11:21 | 12:10 | 0:48 | LINE CLEAR AVAILED |
| 1112 | 20-May-2022 | MYSURU | 66 | KUNTHUR-BANNARI IPP | NO STATIONS EFFECTED | 9:19 | 13:15 | 3:55 | LINE CLEAR AVAILED |
| 1113 | 20-May-2022 | MYSURU | 66 | MUGUR-CLEAN SOLAR | NO STATIONS EFFECTED | 8:38 | 8:42 | 0:03 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--------------------------------------|--|----------------------------|----------------------------|----------|-------------------------------------|
| 1114 | 20-May-2022 | MYSURU | 66 | TUBINAKERE-NAGAMANGALA 1 | NO STATIONS EFFECTED | 6:10:00 AM (15/05/2022) | 2:02:00 PM (20/05/2022) | 7:52HRS | LINE CHARGED |
| 1115 | 20-May-2022 | MYSURU | 66 | HEBBANI-TK HALLI | NO STATIONS EFFECTED | 12:03:00 (14.5.2022) | | | LINE OPEN,LINE FAULT |
| 1116 | 20-May-2022 | MYSURU | 66 | KHB STATION-BILIKERE | NO STATIONS EFFECTED | 10:57:05 (4/5/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1117 | 20-May-2022 | MYSURU | 66 | DUNDANAHALLY- HULIYURDURGA | NO STATIONS EFFECTED | 8:36:34 (30/04/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1118 | 20-May-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 6:26:00 PM (22/04/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1119 | 20-May-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16:00 (08/12/2021) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1120 | 20-May-2022 | TUMKUR | 220 | CHITRADURGA 220- GUTTUR 220 | GUTTUR 220 | 17:05(19.5.22) | 15:44(20.5.22) | 22:39 | LINE FAULT |
| 1121 | 20-May-2022 | TUMKUR | 220 | DAVANGERE SRS- GUTTUR-1 | DAVANGERE_SRS_220 | 23:47(19.5.22) | 12:59(20.5.22) | 13:02 | HAND TRIPPED |
| 1122 | 20-May-2022 | TUMKUR | 66 | TR1 & 2 | KADAJJI_66 | 17:43 | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1123 | 20-May-2022 | TUMKUR | 220 | DAVANGERE SRS- GUTTUR-2 | DAVANGERE_SRS_220 | 13:00 | 15:01 | 2:01 | HAND TRIPPED |
| 1124 | 20-May-2022 | TUMKUR | 220 | CHITRADURGA 220- GUTTUR 220 | GUTTUR 220 | 16:42 | 16:47 | 0:05 | LINE FAULT |
| 1125 | 20-May-2022 | TUMKUR | 110 | TR-1 | NONAVINAKERE_110 | 12:50 | 13:45 | 0:55 | LINE CLEAR AVAILED |
| 1126 | 20-May-2022 | TUMKUR | 66 | CHITRADURGA 220kv- PANDARAHALLI 2 | PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66 | 6:24 | 6:41 | 0:17 | LINE FAULT |
| 1127 | 20-May-2022 | TUMKUR | 66 | CHITRADURGA 220kv- CHITRADURGA 4 | CHITRADURGA_220 | 6:24 | 6:44 | 0:20 | LINE FAULT |
| 1128 | 20-May-2022 | TUMKUR | 66 | HIRIYUR220kv-BEVINAHALLI | JAVAGONDANAHALLI_66, BEVINAHALLI_66 | 18:48 | 19:03 | 0:15 | LINE FAULT |
| 1129 | 20-May-2022 | TUMKUR | 66 | HIRIYUR 220kv- SUZLON 2 | SUZLON1_IPP_66 | 18:46 | 19:48 | 1:02 | LINE FAULT |
| 1130 | 20-May-2022 | TUMKUR | 66 | HIRIYUR 220kv- SUZLON 2 | SUZLON1_IPP_66 | 19:54 | 20:10 | 0:16 | LINE FAULT |
| 1131 | 20-May-2022 | TUMKUR | 66 | KDBVNP- TMTP | TMTP_66 | 12:42 | 15:15 | 2:33 | LINE CLEAR AVAILED |
| 1132 | 20-May-2022 | TUMKUR | 66 | MADHUGIRI 220kv- PAVAGADA_220 1 | PAVAGADA_220 | 7:35 | 10:22 | 2:47 | LINE CLEAR AVAILED |
| 1133 | 20-May-2022 | TUMKUR | 66 | MADHUGIRI 220kv- PAVAGADA 2 | PAVAGADA_220 | 7:35 | 10:22 | 2:47 | LINE CLEAR AVAILED |
| 1134 | 20-May-2022 | TUMKUR | 66 | PAVAGADA 220kv- MADHUGIRI 1 | PAVAGADA_220 | 7:10 | 10:25 | 3:15 | LINE CLEAR AVAILED |
| 1135 | 20-May-2022 | TUMKUR | 66 | PAVAGADA 220kv- MADHUGIRI 2 | PAVAGADA_220 | 7:10 | 10:25 | 3:15 | LINE CLEAR AVAILED |
| 1136 | 20-May-2022 | TUMKUR | 66 | SIRA- MADHUGIRI 2 | BUKKAPATNA_66, KALLAMBELLA_66 | 11:57 | 12:10 | 0:13 | LINE FAULT |
| 1137 | 20-May-2022 | TUMKUR | 66 | HOSAKERE- MADHUGIRI 1 | ID HALLI_66,HOSKERE_66, MIDIGESHI_66 | 6:45 | 10:10 | 3:25 | MAIN SUPPLY FAILURE |
| 1138 | 21-May-2022 | BAGALKOT | 110 | PG HUNSHYAL-MUDALAGI (NAGANUR) | STATION NOT AFFECTED PG HUNSHYAL_110 | 16:13 (04.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1139 | 21-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED LAXMESHVAR_110 | 17:55 (28.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|------------------------------|---------------------------------------|-----------------------|-----------|----------|------------------------------|
| 1140 | 21-May-2022 | BAGALKOT | 220 | BELGAUM- AEQU51 | STATION NOT AFFECTED BELGAUM_220 | 10:39 (16.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1141 | 21-May-2022 | BAGALKOT | 220 | AMBEWADI-PONDA2 | STATION NOT AFFECTED AMBEWADI_220 | 14:10 (19.05.2022) | | | LINE OPEN,LINE FAULT |
| 1142 | 21-May-2022 | BAGALKOT | 220 | BAGEWADI-BIJAPUR1 | STATION NOT AFFECTED BAGEWADI_220 | 17:54 (19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1143 | 21-May-2022 | BAGALKOT | 220 | BAGEWADI-BIJAPUR2 | STATION NOT AFFECTED BAGEWADI_220 | 17:54 (19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1144 | 21-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | AINAPUR_110 | 10:48 | 11:05 | 0:17 | TRANSFORMER FAULT |
| 1145 | 21-May-2022 | BAGALKOT | 110 | ALMEL-KPR SUGARS | STATION NOT AFFECTED ALMEL_110 | 12:13 | 12:27 | 0:14 | LINE CLEAR AVAILED |
| 1146 | 21-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | ANAND NAGAR_110 | 12:11 | 12:48 | 0:37 | LINE CLEAR AVAILED |
| 1147 | 21-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | AEQUS_220 | 12:07 | 13:00 | 0:53 | LINE CLEAR AVAILED |
| 1148 | 21-May-2022 | BAGALKOT | 110 | HUNGUND-KBJNL | STATION NOT AFFECTED HUNGUND_110 | 12:05 | 15:18 | 3:13 | LINE CLEAR AVAILED |
| 1149 | 21-May-2022 | BAGALKOT | 110 | 110/11KV,HV3 | JAMAKHANDI_110 | 15:25 | 15:43 | 0:18 | TRANSFORMER FAULT |
| 1150 | 21-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | KALADAGI_110 | 13:45 | 13:55 | 0:10 | LINE CLEAR AVAILED |
| 1151 | 21-May-2022 | BAGALKOT | 110 | LOKAPUR-DALMIYA CEMENT | STATION NOT AFFECTED LOKAPUR_110 | 5:38 | 6:00 | 0:22 | LINE FAULT |
| 1152 | 21-May-2022 | BAGALKOT | 110 | LOKAPUR-SALAHALLI | SALAHALLI_110 | 12:24 | 14:44 | 2:20 | LINE FAULT |
| 1153 | 21-May-2022 | BAGALKOT | 110 | MURDESHWAR- RAILWAY(KRCL) | MURDESHWAR_110 | 13:35 | 13:46 | 0:11 | LINE FAULT |
| 1154 | 21-May-2022 | BAGALKOT | 110 | BAGEWADI220-UKKALI | UKKALI_110 | 10:21 | 12:30 | 2:09 | LINE FAULT |
| 1155 | 21-May-2022 | BAGALKOT | 110 | 110/11KV HV3 | STATION NOT AFFECTED TILUVALLI_110 | 15:35 | 16:05 | 0:30 | TRANSFORMER FAULT |
| 1156 | 21-May-2022 | BAGALKOT | 110 | TAKKALAKI-TIKOTA | STATION NOT AFFECTED TAKKALAKI_110 | 7:51 | 12:03 | 4:12 | NFBC ISSUED |
| 1157 | 21-May-2022 | BAGALKOT | 110 | SIRSI- KAVALWADA(ESALE2) | STATION NOT AFFECTED SIRSI_110 | 11:19 | 14:36 | 3:17 | NFBC ISSUED |
| 1158 | 21-May-2022 | BAGALKOT | 220 | AMBEWADI- PONDA1 | STATION NOT AFFECTED AMBEWADI_220 | 10:23 | 17:03 | 6:40 | LINE CLEAR AVAILED |
| 1159 | 21-May-2022 | BAGALKOT | 220 | AMBEWADI- PONDA2 | STATION NOT AFFECTED AMBEWADI_220 | 14:10 | 17:04 | 2:54 | LINE FAULT |
| 1160 | 21-May-2022 | BAGALKOT | 220 | BAGALKOT- ALAMATTI1 | BAGALKOT_220 | 11:21 | 11:37 | 0:16 | LINE FAULT |
| 1161 | 21-May-2022 | BAGALKOT | 220 | BAGALKOT - ALAMATTI2 | BAGALKOT_220 | 11:21 | 11:37 | 0:16 | LINE FAULT |
| 1162 | 21-May-2022 | BAGALKOT | 220 | BAGEWADI- ADPH1 | BAGEWADI_220 | 11:20 | 11:45 | 0:25 | LINE FAULT |
| 1163 | 21-May-2022 | BAGALKOT | 220 | BAGEWADI- ADPH2 | BAGEWADI_220 | 11:20 | 11:45 | 0:25 | LINE FAULT |
| 1164 | 21-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | AEQUS_110 | 12:07 | 13:05 | 0:58 | LINE CLEAR AVAILED |
| 1165 | 21-May-2022 | BAGALKOT | 220 | DHONI- GADAG1 | DHONI_400 | 11:21 | 11:28 | 0:07 | LINE FAULT |
| 1166 | 21-May-2022 | BAGALKOT | 220 | BIDNAL- SOUDATTI | BIDNAL_220 | 15:47 | 20:13 | 4:26 | NFBC ISSUED |
| 1167 | 21-May-2022 | BAGALKOT | 110 | GHATAPRABHA220- GOKAK | GHATAPRABHA_220 | 14:00 | 15:15 | 1:15 | LINE CLEAR AVAILED |
| 1168 | 21-May-2022 | BAGALKOT | 110 | MAHALINGAPUR- RABAKAVI | RABAKAVI_110 | 4:44 | 4:53 | 0:09 | LINE FAULT |
| 1169 | 21-May-2022 | BAGALKOT | 110 | MAHALINGAPUR- DAVALESHWAR | DAVALESHWAR_110 | 12:48 | 12:52 | 0:04 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|------------------------|---|-----------------------|-----------------------|-----------|-------------------------------------|
| 1170 | 21-May-2022 | BAGALKOT | 220 | MAHALINGAPUR- SOUDATTI | MAHALINGAPUR_220 | 9:28 | 15:44 | 6:16 | LINE CLEAR AVAILED |
| 1171 | 21-May-2022 | BAGALKOT | 220 | RANEBENNUR- GUTTUR | RANEBENNUR_220 | 10:20 | 10:26 | 0:06 | LINE FAULT |
| 1172 | 21-May-2022 | BAGALKOT | 220 | SOUDATTI- MAHALINGAPUR | STATION NOT AFFECTED SOUDATTI_220 | 9:28 | 15:43 | 6:15 | LINE CLEAR AVAILED |
| 1173 | 21-May-2022 | BAGALKOT | 220 | SOUDATTI- BIDNAL | STATION NOT AFFECTED SOUDATTI_220 | 15:47 | 20:12 | 4:25 | LINE CLEAR AVAILED |
| 1174 | 21-May-2022 | BAGALKOT | 220 | VAJRAMATTI-BAGALKOT1 | STATION NOT AFFECTED VAJRAMATTI_220 | 11:30 | 11:59 | 0:29 | LINE FAULT |
| 1175 | 21-May-2022 | BAGALKOT | 220 | VAJRAMATTI-BAGALKOT1 | STATION NOT AFFECTED VAJRAMATTI_220 | 11:30 | 18:00 | 6:30 | LINE FAULT |
| 1176 | 21-May-2022 | BAGALKOT | 110 | 220/110KV, HV1&LV1 | STATION NOT AFFECTED VAJRAMATTI_220 | 11:23 | 16:18 | 4:55 | TRANSFORMER FAULT |
| 1177 | 21-May-2022 | BAGALKOT | 110 | 110/11KV, HV3 (HV2) | RATTIHALLI_110 | 12:08 | 12:35 | 0:27 | LINE CLEAR AVAILED |
| 1178 | 21-May-2022 | BAGALKOT | 220 | HUBLI- SIRSI1 | STATION NOT AFFECTED HUBLI_220 | 10:24 | 15:11 | 4:47 | LINE CLEAR AVAILED |
| 1179 | 21-May-2022 | BAGALKOT | 110 | RANEBENNUR- RATTIHALLI | RATTIHALLI_110 | 12:40 | 13:04 | 0:24 | LINE CLEAR AVAILED |
| 1180 | 21-May-2022 | BAGALKOT | 110 | SHIRAHATTI-BPCL2 | STATION NOT AFFECTED SHIRAHATTI_110 | 16:40 (27.04.2022) | | | LINE OPEN,LINE FAULT |
| 1181 | 21-May-2022 | BAGALKOT | 220 | SIRSI- HUBLI1 | STATION NOT AFFECTED SIRSI_220 | 15:26 (13.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1182 | 21-May-2022 | BAGALKOT | 220 | SIRSI- HUBLI2 | STATION NOT AFFECTED SIRSI_220 | 15:26 (13.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1183 | 21-May-2022 | BAGALKOT | 220 | NARENDRA- BELGAUM1 | STATION NOT AFFECTED NARENDRA_220 | 9:01 (14.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1184 | 21-May-2022 | BAGALKOT | 220 | BELGAUM- NARENDRA1 | STATION NOT AFFECTED BELGAUM_220 | 9:01 (14.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1185 | 21-May-2022 | BAGALKOT | 220 | KARWAR- KADRA2 | STATION NOT AFFECTED KARWAR_220 | 21:12 (16.05.2022) | 10:27 (21.05.2022) | 109:15HRS | LINE CHARGED |
| 1186 | 21-May-2022 | BAGALKOT | 110 | 110/33KV, HV3 | YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1187 | 21-May-2022 | BAGALKOT | 110 | YLWD-SAVALAGI | STATION NOT AFFECTED YELLAMANAWADI_110 | 24:00 (18.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1188 | 21-May-2022 | BAGALKOT | 110 | 110/33KV,HV3 | HALIYAL_110 | 13:59 (19.05.2022) | 12:49 (21.05.2022) | 46:50:00 | TRANSFORMER FAULT |
| 1189 | 21-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | CHADCHAN_110 | 7:20 (19.05.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1190 | 21-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | MANTUR(B)_110 | 11:40 | 14:45 | 3:05 | LINE CLEAR AVAILED |
| 1191 | 21-May-2022 | BAGALKOT | 110 | 110/11KV, HV3 | MANTUR(B)_110 | 9:52 | 10:02 | 0:10 | LINE CLEAR AVAILED |
| 1192 | 21-May-2022 | BAGALKOT | 110 | HATTARGI- HUKKERI | HATTARGI_110 | 9:20 | 15:10 | 5:50 | LINE CLEAR AVAILED |
| 1193 | 21-May-2022 | BAGALKOT | 220 | BAGEWADI- LINGASUR1 | BAGEWADI_220 | 11:10 | 11:11 | 0:01 | HAND TRIPPED |
| 1194 | 21-May-2022 | BAGALKOT | 220 | BAGEWADI- LINGASUR1 | BAGEWADI_220 | 11:45 | 11:48 | 0:03 | HAND TRIPPED |
| 1195 | 21-May-2022 | BAGALKOT | 220 | BAGEWADI- LINGASUR2 | BAGEWADI_220 | 11:45 | 11:57 | 0:12 | HAND TRIPPED |
| 1196 | 21-May-2022 | BAGALKOT | 110 | 110/11KV, HV3(HV2) | RATTIHALLI_110 | 14:00 | 14:05 | 0:05 | TRANSFORMER FAULT |
| 1197 | 21-May-2022 | BAGALKOT | 110 | RANEBENNUR- RATTIHALLI | RATTIHALLI_110 | 10:20 | 10:30 | 0:10 | MAIN SUPPLY FAILURE |
| 1198 | 21-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | CHADCHAN_110 | 7:20 (19.05.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1199 | 21-May-2022 | BENGALURU | 66 | HV1 | AMAR JYOTHI | 14:00 | 14:31 | 0:31 | LINE CLEAR AVAILED |
| 1200 | 21-May-2022 | BENGALURU | 66 | HV3 | BIDADI 220 | 20:32 | 20:53 | 0:21 | TRANSFORMER FAULT |
| 1201 | 21-May-2022 | BENGALURU | 66 | HV2 | BIDADI 220 | 12:12 | 12:44 | 0:32 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--|--|-------------------|-----------|----------|-------------------------------------|
| 1202 | 21-May-2022 | BENGALURU | 66 | BRIGADE MEADOWS - SUBRAMANYAPURA 220 | BRIGADE MEADOWS | 6:25 | 6:35 | 0:10 | LOAD CHANGE OVER |
| 1203 | 21-May-2022 | BENGALURU | 66 | HV1 | NAGANATHPURA 220 | 11:18 | 11:19 | 0:01 | LINE CLEAR AVAILED |
| 1204 | 21-May-2022 | BENGALURU | 66 | RAJANKUNTE - YELAHANKA 220 | RAJANKUNTE | 5:55 | 6:15 | 0:20 | MAIN SUPPLY FAILURE |
| 1205 | 21-May-2022 | BENGALURU | 66 | RAJANKUNTE - DB PURA 220 | RAJANKUNTE | 9:20 | 9:25 | 0:05 | LOAD CHANGE OVER |
| 1206 | 21-May-2022 | BENGALURU | 66 | HV1 | TK HALLI 220 | 10:40 | 10:42 | 0:02 | LINE CLEAR AVAILED |
| 1207 | 21-May-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ANEKAL 1 | SURYANAGAR | 11:03 | 11:28 | 0:25 | LINE FAULT |
| 1208 | 21-May-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ANEKAL 2 | ANEKAL, SAMANDURU | 11:03 | 11:28 | 0:25 | LINE FAULT |
| 1209 | 21-May-2022 | BENGALURU | 66 | HV1 | ATTIBELE | 11:05 | 11:31 | 0:26 | MAIN SUPPLY FAILURE |
| 1210 | 21-May-2022 | BENGALURU | 66 | DB PURA 220 - CHIKKABALLAPURA I/A 2 | CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI | 16:08 | 16:17 | 0:09 | LINE FAULT |
| 1211 | 21-May-2022 | BENGALURU | 66 | HV2 | YEDUMADU | 10:39 | 10:43 | 0:04 | TRANSFORMER FAULT |
| 1212 | 21-May-2022 | BENGALURU | 66 | HV2 | VOLVO | 13:12 | 13:25 | 0:12 | LINE CLEAR AVAILED |
| 1213 | 21-May-2022 | BENGALURU | 66 | HV1 | N G HULKUR | 9:59 | 10:05 | 0:05 | LINE CLEAR AVAILED |
| 1214 | 21-May-2022 | BENGALURU | 220 | LV2 | GOWRIBIDANUR 220 | 15:39 | 16:05 | 0:26 | LINE CLEAR AVAILED |
| 1215 | 21-May-2022 | BENGALURU | 66 | HV2 | GOWRIBIDANUR 220 | 0:10 | 1:15 | 1:05 | TRANSFORMER FAULT |
| 1216 | 21-May-2022 | BENGALURU | 66 | HV1 | BAIRAKURU | 4:23 | 4:35 | 0:11 | TRANSFORMER FAULT |
| 1217 | 21-May-2022 | BENGALURU | 66 | YELAHANKA 220 - LINE8 | RAJANKUNTE | 5:55 | 6:15 | 0:20 | LINE FAULT |
| 1218 | 21-May-2022 | BENGALURU | 66 | HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR) | GRINDWELL (EHT), HOSKOTE 66 | 16:41 | 17:02 | 0:21 | LINE FAULT |
| 1219 | 21-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - AFTL SOLAR | AFTL SOLAR | 10:32 | 10:35 | 0:03 | LINE FAULT |
| 1220 | 21-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - AFTL SOLAR | AFTL SOLAR | 10:35 | 11:07 | 0:32 | LINE FAULT |
| 1221 | 21-May-2022 | GULBARGA | 400 | BTPSG-HIRIYUR2 | HIRIYUR_400 | 16:12(08.05.2022) | | | LINE OPEN,LINE FAULT |
| 1222 | 21-May-2022 | GULBARGA | 220 | ALIPUR-RAGALPADU | RAGALPADU_220 | 2:35(17.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1223 | 21-May-2022 | GULBARGA | 220 | LINGAPUR-BTPS | LINGAPUR_220 | 01:55(17.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1224 | 21-May-2022 | GULBARGA | 220 | KUDLIGI-HIREMALLANAHALLI 1&2 | KUDLIGI_220 | 17:25(08.05.2022) | | | LINE OPEN,LINE FAULT |
| 1225 | 21-May-2022 | GULBARGA | 220 | HV2 | KUDLIGI_220 | 16:18(12.08.2021) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1226 | 21-May-2022 | GULBARGA | 220 | HV1 & HV2 | MALLAT_220 | 11:20 | 11:35 | 0:15 | TRANSFORMER FAULT |
| 1227 | 21-May-2022 | GULBARGA | 220 | HV1 & HV2 | MALLAT_220 | 13:04 | 14:10 | 1:06 | TRANSFORMER FAULT |
| 1228 | 21-May-2022 | GULBARGA | 220 | HUMNABAD-SEDAM 1 & 2 | HUMNABAD_220 | 11:20 | 12:29 | 1:09 | LINE FAULT |
| 1229 | 21-May-2022 | GULBARGA | 220 | HALBARGA-HUMNABAD | HALBARGA_220 | 11:20 | 12:26 | 1:06 | LINE FAULT |
| 1230 | 21-May-2022 | GULBARGA | 220 | RAICHUR-JURALA_2_IPP | RAICHUR_220 | 2:05 | 2:15 | 0:10 | LINE FAULT |
| 1231 | 21-May-2022 | GULBARGA | 220 | RAICHUR-RTPS_2 | RAICHUR_220 | 11:23 | 12:20 | 0:57 | MAIN SUPPLY FAILURE |
| 1232 | 21-May-2022 | GULBARGA | 220 | RAICHUR-RTPS_1 | RAICHUR_220 | 11:23 | 12:38 | 1:15 | MAIN SUPPLY FAILURE |
| 1233 | 21-May-2022 | GULBARGA | 220 | MALLAT-RTPS | MALLAT_220 | 12:00 | 18:24 | 6:24 | LINE CLEAR AVAILED |
| 1234 | 21-May-2022 | GULBARGA | 220 | MALLAT-LINGASUGUR | MALLAT_220 | 11:21 | 12:15 | 0:54 | LINE FAULT |
| 1235 | 21-May-2022 | GULBARGA | 220 | SEDAM-RTPS_1 | SEDAM_220 | 11:20 | 12:15 | 0:55 | MAIN SUPPLY FAILURE |
| 1236 | 21-May-2022 | GULBARGA | 220 | SEDAM-RTPS_2 | SEDAM_220 | 11:20 | 12:30 | 1:10 | MAIN SUPPLY FAILURE |
| 1237 | 21-May-2022 | GULBARGA | 220 | SEDAM-SHAHAPUR | SEDAM_220 | 11:20 | 12:50 | 1:30 | MAIN SUPPLY FAILURE |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|------------------------------|---|--------------------|-----------|----------|------------------------------|
| 1238 | 21-May-2022 | GULBARGA | 220 | SEDAM-VASAVADATTA CEMENT_IPP | SEDAM_220 | 15:50 | 18:40 | 2:50 | LINE FAULT |
| 1239 | 21-May-2022 | GULBARGA | 220 | SEDAM-VASAVADATTA CEMENT_IPP | SEDAM_220 | 19:30 | 19:40 | 0:10 | LINE FAULT |
| 1240 | 21-May-2022 | GULBARGA | 220 | SHAHAPUR-RTPS_1 | SHAHAPUR_220 | 11:20 | 17:13 | 5:53 | MAIN SUPPLY FAILURE |
| 1241 | 21-May-2022 | GULBARGA | 220 | SHAHAPUR-RTPS_2 | SHAHAPUR_220 | 11:20 | 12:40 | 1:20 | MAIN SUPPLY FAILURE |
| 1242 | 21-May-2022 | GULBARGA | 220 | SHAHAPUR-LINGASUGUR | SHAHAPUR_220 | 12:05 | 12:09 | 0:04 | LINE CLEAR AVAILED |
| 1243 | 21-May-2022 | GULBARGA | 220 | LINGASUGUR-BAGEWADI1,2 | LINGASUGUR_220 | 13:00 | 15:00 | 2:00 | LINE CLEAR AVAILED |
| 1244 | 21-May-2022 | GULBARGA | 220 | LINGASUGUR-SINDHANOOR220 | SINDHANOOR_220 | 11:20 | 14:06 | 2:46 | LINE FAULT |
| 1245 | 21-May-2022 | GULBARGA | 220 | KAPANOOR-SHAHAPUR | KAPANOOR_220 | 11:20 | 12:15 | 0:55 | MAIN SUPPLY FAILURE |
| 1246 | 21-May-2022 | GULBARGA | 220 | KAPANOOR-HUMNABAD1,2 | KAPANOOR_220 | 11:20 | 12:26 | 1:06 | MAIN SUPPLY FAILURE |
| 1247 | 21-May-2022 | GULBARGA | 220 | KAPANOOR-SHAHABAD2 | KAPANOOR_220 | 11:20 | 12:29 | 1:09 | MAIN SUPPLY FAILURE |
| 1248 | 21-May-2022 | GULBARGA | 220 | SHAHABAD-SHAHAPUR | SHAHABAD_220 | 11:23 | 12:35 | 1:12 | MAIN SUPPLY FAILURE |
| 1249 | 21-May-2022 | GULBARGA | 110 | SHAHAPUR-KHANAPUR | KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP | 10:55 (11.04.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1250 | 21-May-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | YADGIR_110,SAIDAPUR_110,KHANAPUR_110,WADGERA_110 | 15:13 (21.05.2022) | | | LINE OPEN,LINE FAULT |
| 1251 | 21-May-2022 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 6:59 | 7:07 | 0:08 | TRANSFORMER FAULT |
| 1252 | 21-May-2022 | GULBARGA | 110 | LV1,LV2 | KAPANOOR_220 | 11:20 | 12:37 | 1:17 | MAIN SUPPLY FAILURE |
| 1253 | 21-May-2022 | GULBARGA | 110 | LV1,LV2 | SHAHAPUR_220 | 15:13 | 15:52 | 0:39 | TRANSFORMER FAULT |
| 1254 | 21-May-2022 | GULBARGA | 110 | HV3 | SHORAPUR_110 | 5:45 | 10:30 | 4:45 | TRANSFORMER FAULT |
| 1255 | 21-May-2022 | GULBARGA | 110 | SHAHAPUR-SHORAPUR | SHORAPUR_110 | 4:52 | 5:00 | 0:08 | LINE FAULT |
| 1256 | 21-May-2022 | GULBARGA | 110 | RAICHUR-SINDHNOOR2 | KURDICROSS_110,MADLAPUR_110,MANVI_110 | 2:05 | 2:15 | 0:10 | LINE FAULT |
| 1257 | 21-May-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 0:20 | 0:26 | 0:06 | LINE FAULT |
| 1258 | 21-May-2022 | GULBARGA | 110 | MALLAT-SIRWAR | SIRWAR_110 | 2:22 | 2:29 | 0:07 | LINE FAULT |
| 1259 | 21-May-2022 | GULBARGA | 110 | MALLAT-BYAGAWATH1 | BYAGAWATH_110,VALKAMDINNI_110 | 5:15 | 5:25 | 0:10 | LINE FAULT |
| 1260 | 21-May-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 5:15 | 5:25 | 0:10 | LINE FAULT |
| 1261 | 21-May-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 5:35 | 5:45 | 0:10 | LINE FAULT |
| 1262 | 21-May-2022 | GULBARGA | 110 | ALIPUR-BELLARY NORTH | SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PDHALLI_110,BISIHALLI_110,JANAKI_IPP,BASA STEELS | 5:51 | 5:59 | 0:08 | LINE FAULT |
| 1263 | 21-May-2022 | GULBARGA | 110 | GULBARGA UNIVERSITY-SHAHABAD | GULBARGA UNIVERSITY_110 | 11:20 | 12:40 | 1:20 | MAIN SUPPLY FAILURE |
| 1264 | 21-May-2022 | GULBARGA | 66 | ITTAGI-HIREHADAGALI_2 | HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP | 1:46 | 2:02 | 0:16 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|------------------------|---------------------------------------|--------------------|-------------------|----------|-------------------------------------|
| 1265 | 21-May-2022 | GULBARGA | 66 | NEELGUNDA-TELIGI | TELAGI_66,KURBHAHALLI_66,YEREGUNTA_66 | 10:26 | 10:32 | 0:06 | LINE FAULT |
| 1266 | 21-May-2022 | GULBARGA | 66 | NEELGUNDA-HALAVAGALU | HALAVAGALU_66 | 9:00 | 9:05 | 0:05 | LINE FAULT |
| 1267 | 21-May-2022 | HASSAN | 110 | HV2 | BARANGI_110 | 10:25(21.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1268 | 21-May-2022 | HASSAN | 110 | JOG-NK2 | mghejog_gen | 17:05(28.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1269 | 21-May-2022 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 12:15 (29.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1270 | 21-May-2022 | HASSAN | 110 | HV3 | JOG_110 | 10:55(05.04.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1271 | 21-May-2022 | HASSAN | 220 | HV3 | KAVOOR_220 | 19:55(30.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1272 | 21-May-2022 | HASSAN | 110 | HV2 | BARANGI_110 | 10:22(17.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1273 | 21-May-2022 | HASSAN | 110 | HV2 | ARASIKERE_110 | 19:20(19.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1274 | 21-May-2022 | HASSAN | 66 | ALDUR-BALEHONNUR | ALDUR_66 | 5:30(19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1275 | 21-May-2022 | HASSAN | 110 | JOG-JLT3 | gen_mghe | 15:14(21.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1276 | 21-May-2022 | HASSAN | 110 | JOG110-MGHE | JOG_110 | 15:14(21.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1277 | 21-May-2022 | HASSAN | 110 | HV2 | ARASIKERE_110 | 23:35(20.05.2022) | 14:10(21.05.2022) | 14:35HRS | TRANSFORMER CHARGED |
| 1278 | 21-May-2022 | HASSAN | 220 | KAVOOR2 | MSEZ_220 | 9:33 | 15:07 | 5:34 | NFBC ISSUED |
| 1279 | 21-May-2022 | HASSAN | 220 | HV2 | SHIRALKOPPA_220 | 15:01 | 17:07 | 2:06 | LINE CLEAR AVAILED |
| 1280 | 21-May-2022 | HASSAN | 220 | KEMR1 | KAVOOR_220 | 9:30 | 14:46 | 5:16 | LINE CLEAR AVAILED |
| 1281 | 21-May-2022 | HASSAN | 110 | HV2 | KONAJE_110 | 10:23 | 13:43 | 3:20 | LINE CLEAR AVAILED |
| 1282 | 21-May-2022 | HASSAN | 110 | SAGARA-ALKLA | SAGARA_110 | 8:30 | 10:15 | 1:45 | MAIN SUPPLY FAILURE |
| 1283 | 21-May-2022 | HASSAN | 110 | SAGARA-SORABA | SAGARA_110 | 8:30 | 10:00 | 1:30 | MAIN SUPPLY FAILURE |
| 1284 | 21-May-2022 | HASSAN | 110 | HV2 | TALAGUPPA_110 | 11:10 | 15:20 | 4:10 | LINE CLEAR AVAILED |
| 1285 | 21-May-2022 | HASSAN | 66 | MRSSHM-HOLUR | MRSMSG_220 | 14:38 | 16:10 | 1:32 | LINE FAULT |
| 1286 | 21-May-2022 | HASSAN | 66 | HV1 | SAKALE | 22:40 | 22:50 | 0:10 | TRANSFORMER FAULT |
| 1287 | 21-May-2022 | HASSAN | 66 | ALDUR-CHIKKAMAGLUR | ALDUR_66 | 11:58 | 13:30 | 1:32 | MAIN SUPPLY FAILURE |
| 1288 | 21-May-2022 | HASSAN | 66 | ALDUR-CHIKKAMAGLUR | ALDUR_66 | 14:08 | 14:13 | 0:05 | HAND TRIPPED |
| 1289 | 21-May-2022 | HASSAN | 66 | HV1 | SALAGAME_66 | 11:00 | 13:15 | 2:15 | LINE CLEAR AVAILED |
| 1290 | 21-May-2022 | HASSAN | 66 | HV1 | HOLALUR_66 | 13:20 | 16:20 | 3:00 | TRANSFORMER FAULT |
| 1291 | 21-May-2022 | HASSAN | 66 | KUDLIGE-ANVRPP | KUDLIGERE_66 | 10:40 | 11:00 | 0:20 | LINE FAULT |
| 1292 | 21-May-2022 | HASSAN | 66 | HV1 | MALALI_66 | 14:55 | 15:10 | 0:15 | TRANSFORMER FAULT |
| 1293 | 21-May-2022 | MYSURU | 66 | HAMPAPURA-HV2 | HAMPAPURA_66 | 11:01 | 11:30 | 0:29 | LINE FAULT |
| 1294 | 21-May-2022 | MYSURU | 66 | MADHUVANAHALLI-HEBBANI | NO STATIONS EFFECTED | 9:34 | 11:38 | 2:04 | LINE CLEAR AVAILED |
| 1295 | 21-May-2022 | MYSURU | 66 | HV2 | MADIKERI_66 | 17:54 | 18:19 | 0:25 | LINE CLEAR AVAILED |
| 1296 | 21-May-2022 | MYSURU | 66 | HV1 | MALAVALLI_66 | 11:02 | 11:52 | 0:49 | LINE CLEAR AVAILED |
| 1297 | 21-May-2022 | MYSURU | 66 | HV2 | MALAVALLI_66 | 11:02 | 11:52 | 0:49 | LINE CLEAR AVAILED |
| 1298 | 21-May-2022 | MYSURU | 66 | HV1 | PERIYAPATNA_66 | 13:03 | 13:09 | 0:06 | HAND TRIPPED |
| 1299 | 21-May-2022 | MYSURU | 66 | HV1 | SRIRANGAPATNA_66 | 10:00 | 12:31 | 2:30 | LINE CLEAR AVAILED |
| 1300 | 21-May-2022 | MYSURU | 66 | HV2 | SRIRANGAPATNA_66 | 12:32 | 14:40 | 2:08 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|-------------------------------------|---|----------------------------|-----------------|---------------|-------------------------------------|
| 1301 | 21-May-2022 | MYSURU | 66 | TUBINKERE-NAGAMANGALA 2 | BASARALU_66 HARADANAHALLI_66 KESLAGERE_66 SHIVALLY_66 | 6:50 | 6:54 | 0:04 | LINE FAULT |
| 1302 | 21-May-2022 | MYSURU | 66 | TUBINKERE-NAGAMANGALA 2 | BASARALU_66 HARADANAHALLI_66 KESLAGERE_66 SHIVALLY_66 | 2:40 | 2:45 | 0:05 | LINE FAULT |
| 1303 | 21-May-2022 | MYSURU | 66 | TUBINKERE-NAGAMANGALA 2 | BASARALU_66 HARADANAHALLI_66 KESLAGERE_66 SHIVALLY_66 | 5:31 | 5:36 | 0:05 | LINE FAULT |
| 1304 | 21-May-2022 | MYSURU | 66 | HV1 | VAJAMANGALA_220 | 10:52 | 12:46 | 1:54 | LINE CLEAR AVAILED |
| 1305 | 21-May-2022 | MYSURU | 66 | HV4 | KUSHALANAGARA_66 | 12:25 | 13:30 | 1:05 | LINE CLEAR AVAILED |
| 1306 | 21-May-2022 | MYSURU | 66 | HV1 | KOPPA_66 | 22:35 | 23:15 | 0:40 | TRANSFORMER FAULT |
| 1307 | 21-May-2022 | MYSURU | 66 | HV1 | MADIKERI_66 | 11:33:09 (21/05/2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1308 | 21-May-2022 | MYSURU | 66 | HEBBANI-TK HALLI | NO STATIONS EFFECTED | 12:03:00 (14.5.2022) | | | LINE OPEN,LINE FAULT |
| 1309 | 21-May-2022 | MYSURU | 66 | KHB STATION-BILIKERE | NO STATIONS EFFECTED | 10:57:05 (4/5/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1310 | 21-May-2022 | MYSURU | 66 | DUNDANAHALLY-HULIYURDURGA | NO STATIONS EFFECTED | 8:36:34 (30/04/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1311 | 21-May-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 6:26:00 PM (22/04/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1312 | 21-May-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16:00 (08/12/2021) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1313 | 21-May-2022 | TUMKUR | 66 | TR1 & 2 | KADAJJI_66 | 17:43(19.5.22) | 13:35(21.05.22) | 1DAY 19:52Hrs | TRANSFORMER CHARGED |
| 1314 | 21-May-2022 | TUMKUR | 66 | DAVANGERE SRS-KUKKAWADA | KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66 | 10:46 | 14:45 | 3:59 | LINE CLEAR AVAILED |
| 1315 | 21-May-2022 | TUMKUR | 66 | HIRIYUR220-THALLAK220 | HIRIYUR_220 | 10:45 | 11:35 | 0:50 | LINE CLEAR AVAILED |
| 1316 | 21-May-2022 | TUMKUR | 66 | HIRIYUR 220KV-P R PURA | P R PURA_66 | 10:50 | 11:45 | 0:55 | LINE CLEAR AVAILED |
| 1317 | 21-May-2022 | TUMKUR | 66 | HIRIYUR220-MATHOD 2&1 LINE CLUB | MATHOD_66,HINDASGHATT A_66,KANCHIPURA_66,GAR AGA_66,PANCHANAHALLI_66,HOSADURGA_66 | 9:50 | 10:05 | 0:15 | MAIN SUPPLY FAILURE |
| 1318 | 21-May-2022 | TUMKUR | 66 | TR-1 | HIRIYUR_220 | 15:20 | 16:35 | 1:15 | LINE CLEAR AVAILED |
| 1319 | 21-May-2022 | TUMKUR | 66 | TR-2 | HIRIYUR_220 | 16:45 | 17:50 | 1:05 | LINE CLEAR AVAILED |
| 1320 | 21-May-2022 | TUMKUR | 66 | HONNALLI 220KV- NYAMATHI | CHILLUR_66, NYAMATHI_66, SAVALANGA_66 | 12:25 | 12:55 | 0:30 | LINE FAULT |
| 1321 | 21-May-2022 | TUMKUR | 66 | HONNALLI 220kv- CHANNAGIRI(NALLUR) | DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66 | 12:25 | 12:55 | 0:30 | LINE FAULT |
| 1322 | 21-May-2022 | TUMKUR | 66 | HONNALLI 220kv- BANUVALLI | BANUVALLI_66, NANDIGUDI_66, KARGIL EHT 66 | 18:34 | 19:17 | 0:43 | LINE FAULT |
| 1323 | 22-May-2022 | BAGALKOT | 110 | PG HUNSHYAL-MUDALAGI (NAGANUR) | STATION NOT AFFECTED PG HUNSHYAL_110 | 16:13 (04.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--------------------------------|--|-----------------------|----------------------|-----------|-------------------------------------|
| 1324 | 22-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED LAXMESHVAR_110 | 17:55 (28.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1325 | 22-May-2022 | BAGALKOT | 220 | BELGAUM- AEQUS1 | STATION NOT AFFECTED BELGAUM_220 | 10:39 (16.05.2022) | 7:02 (22.05.2022) | 140:23HRS | LINE CHARGED |
| 1326 | 22-May-2022 | BAGALKOT | 220 | AMBEWADI-PONDA2 | STATION NOT AFFECTED AMBEWADI_220 | 14:10 (19.05.2022) | | | LINE OPEN,LINE FAULT |
| 1327 | 22-May-2022 | BAGALKOT | 220 | BAGEWADI-BIJAPUR1 | STATION NOT AFFECTED BAGEWADI_220 | 17:54 (19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1328 | 22-May-2022 | BAGALKOT | 220 | BAGEWADI-BIJAPUR2 | STATION NOT AFFECTED BAGEWADI_220 | 17:54 (19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1329 | 22-May-2022 | BAGALKOT | 110 | ALMEL-KPR SUGARS | STATION NOT AFFECTED ALMEL_110 | 20:30 | 20:34 | 0:04 | LINE FAULT |
| 1330 | 22-May-2022 | BAGALKOT | 110 | ALMEL-KPR JAMAKHANDI SUGARS | STATION NOT AFFECTED ALMEL_110 | 20:30 | 20:35 | 0:05 | LINE FAULT |
| 1331 | 22-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | BABLESHWAR_110 | 15:42 | 15:56 | 0:14 | LINE CLEAR AVAILED |
| 1332 | 22-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | BABLESHWAR_110 | 20:22 | 21:50 | 1:28 | LINE CLEAR AVAILED |
| 1333 | 22-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | BAILHONGAL_110 | 9:25 | 18:14 | 8:49 | LINE CLEAR AVAILED |
| 1334 | 22-May-2022 | BAGALKOT | 110 | DAMBAL-SUZLON2 | STATION NOT AFFECTED DAMBAL_110 | 14:55 | 15:39 | 0:44 | NFBC ISSUED |
| 1335 | 22-May-2022 | BAGALKOT | 110 | GARAG-KITTUR | KITTUR_110 | 14:10 | 17:37 | 3:27 | LINE CLEAR AVAILED |
| 1336 | 22-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | HALKI_110 | 0:02 | 1:10 | 1:08 | TRANSFORMER FAULT |
| 1337 | 22-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | HIEMASALI_110 | 4:12 | 4:16 | 0:04 | TRANSFORMER FAULT |
| 1338 | 22-May-2022 | BAGALKOT | 110 | JAMBAGI- VAJRAMATTI(MUDHOL) | MUDHOL_110 | 12:43 | 13:01 | 0:18 | LINE CLEAR AVAILED |
| 1339 | 22-May-2022 | BAGALKOT | 110 | BELGAUM-KANABARGI LAYOUT | KANABARGI LAYOUT_110 | 9:26 | 15:48 | 6:22 | LINE CLEAR AVAILED |
| 1340 | 22-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | KANABARGI LAYOUT_110 | 9:26 | 16:51 | 7:25 | LINE CLEAR AVAILED |
| 1341 | 22-May-2022 | BAGALKOT | 110 | 110/33KV,HV3&HV4(HV1&HV 2) | BALEKUNDRI_33,JARRISON_ 33,KAKATI_33,SUZLON_33, KANABARGI LAYOUT_110 | 9:26 | 16:52 | 7:26 | LINE CLEAR AVAILED |
| 1342 | 22-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | KUDUCHI_220 | 14:08 | 14:13 | 0:05 | TRANSFORMER FAULT |
| 1343 | 22-May-2022 | BAGALKOT | 110 | ISLAMPUR-ANKALAGI | ANKALAGI_110 | 5:45 | 6:18 | 0:33 | LINE FAULT |
| 1344 | 22-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | LAKAMANAHALLI_110 | 11:24 | 11:58 | 0:34 | TRANSFORMER FAULT |
| 1345 | 22-May-2022 | BAGALKOT | 110 | GOKAK-MAMADAPUR | MAMADAPUR(G)_110 | 14:12 | 15:21 | 1:09 | LINE CLEAR AVAILED |
| 1346 | 22-May-2022 | BAGALKOT | 110 | MAMADAPUR-SOUBAGYA LAXMI | MAMADAPUR(G)_110 | 14:11 | 15:22 | 1:11 | LINE CLEAR AVAILED |
| 1347 | 22-May-2022 | BAGALKOT | 110 | MK HUBLI- (NARENDRA)KITTUR | KITTUR_110 | 14:24 | 17:42 | 3:18 | LINE CLEAR AVAILED |
| 1348 | 22-May-2022 | BAGALKOT | 110 | MURDESHWAR- RAILWAY(KRCL) | MURDESHWAR_110 | 14:49 | 14:52 | 0:03 | LINE FAULT |
| 1349 | 22-May-2022 | BAGALKOT | 110 | MURDESHWAR- RAILWAY(KRCL) | MURDESHWAR_110 | 14:55 | 15:08 | 0:13 | LINE FAULT |
| 1350 | 22-May-2022 | BAGALKOT | 110 | MURDESHWAR- RAILWAY(KRCL) | MURDESHWAR_110 | 15:14 | 16:53 | 1:39 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|------------------------------------|--|------------------------|-----------------------|----------|-------------------------------------|
| 1351 | 22-May-2022 | BAGALKOT | 110 | MURDESHWAR- RAILWAY(KRCL) | MURDESHWAR_110 | 17:17 | 17:31 | 0:14 | LINE FAULT |
| 1352 | 22-May-2022 | BAGALKOT | 110 | 110/11KV,HV1 | NIDAGUNDI_110 | 13:48 | 13:52 | 0:04 | TRANSFORMER FAULT |
| 1353 | 22-May-2022 | BAGALKOT | 110 | BELGAUM220-UCHAGAON | STATION NOT AFFECTED UCHAGAON_110 | 11:05 | 12:35 | 1:30 | LINE CLEAR AVAILED |
| 1354 | 22-May-2022 | BAGALKOT | 220 | BAGEWADI- RBRK | BAGEWADI_220 | 17:28 | 17:54 | 0:26 | LINE FAULT |
| 1355 | 22-May-2022 | BAGALKOT | 110 | BELGAUM220- KANABARGI LAYOUT | KANABARGI LAYOUT_110 | 9:27 | 15:46 | 6:19 | LINE CLEAR AVAILED |
| 1356 | 22-May-2022 | BAGALKOT | 220 | BIDNAL- SOUDATTI | STATION NOT AFFECTED BIDNAL_220 | 13:06 | 17:44 | 4:38 | NFBC ISSUED |
| 1357 | 22-May-2022 | BAGALKOT | 220 | BIDNAL- SOUDATTI | STATION NOT AFFECTED BIDNAL_220 | 18:22 | 18:55 | 0:33 | HAND TRIPPED |
| 1358 | 22-May-2022 | BAGALKOT | 220 | BELGAUM- KANABARGI2 (NARENDRA2) | BELGAUM_220 | 7:22 | 7:56 | 0:34 | LINE CLEAR AVAILED |
| 1359 | 22-May-2022 | BAGALKOT | 220 | SOUDATTI- BIDNAL | STATION NOT AFFECTED SOUDATTI_220 | 13:04 | 17:44 | 4:40 | LINE CLEAR AVAILED |
| 1360 | 22-May-2022 | BAGALKOT | 220 | SOUDATTI- BIDNAL | STATION NOT AFFECTED SOUDATTI_220 | 18:23 | 18:54 | 0:31 | HAND TRIPPED |
| 1361 | 22-May-2022 | BAGALKOT | 110 | 110/33KV, HV3 | SHGGOAN_110, KPCL SOLAR_33, AMBUJA_33, SHIGGOAN_33 | 14:14 | 14:18 | 0:04 | TRANSFORMER FAULT |
| 1362 | 22-May-2022 | BAGALKOT | 110 | MAHALINGAPUR- RANNABELAGALI | RANNABELAGALI_110 | 15:10 (19.05.20222) | 12:56 (22.05.2022) | 69:46HRS | LINE CHARGED |
| 1363 | 22-May-2022 | BAGALKOT | 220 | HUBLI- SIRSI1 | STATION NOT AFFECTED HUBLI_220 | 10:22 | 15:33 | 5:11 | LINE CLEAR AVAILED |
| 1364 | 22-May-2022 | BAGALKOT | 110 | SHIRAHATTI-BPCL2 | STATION NOT AFFECTED SHIRAHATTI_110 | 16:40 (27.04.2022) | | | LINE OPEN,LINE FAULT |
| 1365 | 22-May-2022 | BAGALKOT | 220 | SIRSI- HUBLI1 | STATION NOT AFFECTED SIRSI_220 | 15:26 (13.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1366 | 22-May-2022 | BAGALKOT | 220 | SIRSI- HUBLI2 | STATION NOT AFFECTED SIRSI_220 | 15:26 (13.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1367 | 22-May-2022 | BAGALKOT | 220 | NARENDRA- BELGAUM1 | STATION NOT AFFECTED NARENDRA_220 | 9:01 (14.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1368 | 22-May-2022 | BAGALKOT | 220 | BELGAUM- NARENDRA1 | STATION NOT AFFECTED BELGAUM_220 | 9:01 (14.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1369 | 22-May-2022 | BAGALKOT | 110 | 110/33KV, HV3 | YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1370 | 22-May-2022 | BAGALKOT | 110 | YLWD-SAVALAGI | STATION NOT AFFECTED YELLAMANAWADI_110 | 24:00 (18.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1371 | 22-May-2022 | BAGALKOT | 220 | MUGALKHOD- NAGANUR | MUGALKHOD_220 | 6:47 | 7:06 | 0:19 | LINE FAULT |
| 1372 | 22-May-2022 | BAGALKOT | 220 | MUGALKHOD- RAIBAG1 | MUGALKHOD_220 | 9:16 | 18:05 | 8:49 | LINE CLEAR AVAILED |
| 1373 | 22-May-2022 | BAGALKOT | 220 | MUGALKHOD- RAIBAG2 | MUGALKHOD_220 | 9:17 | 18:02 | 8:45 | LINE CLEAR AVAILED |
| 1374 | 22-May-2022 | BAGALKOT | 110 | MUGALKHOD220- PG HUNSHYAL | MUGALKHOD_220 | 11:46 | 11:52 | 0:06 | LINE FAULT |
| 1375 | 22-May-2022 | BAGALKOT | 110 | MUGALKHOD-HIDIKAL | MUGALKHOD_220 | 21:22 | 21:27 | 0:05 | LINE FAULT |
| 1376 | 22-May-2022 | BAGALKOT | 110 | KD JAMBAGI-MUDHOL | KD JAMBAGI_110 | 13:02 | 14:40 | 1:38 | LINE CLEAR AVAILED |
| 1377 | 22-May-2022 | BAGALKOT | 110 | MK HUBLI220- BAILHONGAL | MK HUBLI_220 | 9:15 | 17:35 | 8:20 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--|--|-------------------|-----------|----------|-------------------------------------|
| 1378 | 22-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | RANEENNUR_220 | 18:58 | 20:53 | 1:55 | TRANSFORMER FAULT |
| 1379 | 22-May-2022 | BENGALURU | 66 | BYADRAHALLI - SRS PEENYA 220 | BYADRAHALLI | 10:56 | 16:02 | 5:06 | LINE CLEAR AVAILED |
| 1380 | 22-May-2022 | BENGALURU | 66 | KODIGEHALI - BYADRAHALLI | KODIGEHALI | 10:50 | 16:30 | 5:40 | LINE CLEAR AVAILED |
| 1381 | 22-May-2022 | BENGALURU | 66 | SRIGANDA KAVALU - BYADRAHALLI | SRIGANDA KAVALU | 10:50 | 16:07 | 5:17 | LINE CLEAR AVAILED |
| 1382 | 22-May-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ANEKAL 2 | ANEKAL, SAMANDURU | 12:04 | 12:57 | 0:53 | LINE CLEAR AVAILED |
| 1383 | 22-May-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ANEKAL 1 | SURYANAGAR | 13:27 | 14:37 | 1:10 | LINE CLEAR AVAILED |
| 1384 | 22-May-2022 | BENGALURU | 66 | HV1 | KUMBARANAHALLI | 10:10 | 10:35 | 0:25 | LINE CLEAR AVAILED |
| 1385 | 22-May-2022 | BENGALURU | 66 | YEDUMADU - SOMANAHALLI 220 | YEDUMADU | 5:43 | 6:05 | 0:22 | LINE FAULT |
| 1386 | 22-May-2022 | BENGALURU | 66 | VIDHURASHWATHA - GOWRIBIDANUR 220 | VIDHURASHWATHA, GUNDLU KOTTUR | 19:18 | 19:23 | 0:05 | LINE FAULT |
| 1387 | 22-May-2022 | BENGALURU | 66 | KONDASPURA - HBR LAYOUT 66 | KONDASPURA | 7:41 | 8:06 | 0:25 | LINE FAULT |
| 1388 | 22-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - PERESANDRA | D PALYA, GUDIBANDE, MANDIKAL, PERESANDRA | 9:12 | 9:22 | 0:10 | LINE FAULT |
| 1389 | 22-May-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - AFTL SOLAR | AFTL SOLAR | 9:12 | 9:22 | 0:10 | LINE FAULT |
| 1390 | 22-May-2022 | BENGALURU | 66 | HV1 | ATTIBELE | 11:40 | 11:45 | 0:05 | LOAD CHANGE OVER |
| 1391 | 22-May-2022 | BENGALURU | 66 | HV1 | ATTIBELE | 16:25 | 16:30 | 0:05 | LOAD CHANGE OVER |
| 1392 | 22-May-2022 | BENGALURU | 66 | DB PURA 220 - CHIKKABALLAPURA I/A 1 | TUBUGERE | 19:07 | 19:16 | 0:09 | LINE FAULT |
| 1393 | 22-May-2022 | BENGALURU | 66 | HV2 | YEDUMADU | 5:43 | 6:02 | 0:19 | TRANSFORMER FAULT |
| 1394 | 22-May-2022 | BENGALURU | 66 | HV1 | PATHPALYA | 16:53 | 17:04 | 0:11 | TRANSFORMER FAULT |
| 1395 | 22-May-2022 | BENGALURU | 66 | HV2 | HUKUNDA | 12:34 | 12:52 | 0:18 | TRANSFORMER FAULT |
| 1396 | 22-May-2022 | BENGALURU | 66 | HV2 | HUKUNDA | 13:21 | 13:31 | 0:09 | TRANSFORMER FAULT |
| 1397 | 22-May-2022 | BENGALURU | 66 | HV2 | TYAMAGONDGLU | 17:32 | 17:41 | 0:09 | TRANSFORMER FAULT |
| 1398 | 22-May-2022 | BENGALURU | 66 | VIDHURASHWATHA - GREEN SOLAR (IPP) | NO STATION AFFECTED | 19:18 | 19:23 | 0:05 | LINE FAULT |
| 1399 | 22-May-2022 | BENGALURU | 66 | TUBUGERE - AFTL SOLAR IPP | NO STATION AFFECTED | 19:07 | 19:32 | 0:25 | LINE FAULT |
| 1400 | 22-May-2022 | BENGALURU | 66 | KIADB DB PURA 220 - HIMAT SINGHA FACTORY (EHT) | HIMAT SINGHA FACTORY (EHT) | 11:26 | 14:33 | 3:07 | LINE CLEAR AVAILED |
| 1401 | 22-May-2022 | BENGALURU | 220 | GOWRIBIDANUR 220 - PGCIL 1 | NO STATION AFFECTED | 21:22(22-5-2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1402 | 22-May-2022 | GULBARGA | 400 | BTPSG-HIRIYUR2 | HIRIYUR_400 | 16:12(08.05.2022) | | | LINE OPEN,LINE FAULT |
| 1403 | 22-May-2022 | GULBARGA | 220 | ALIPUR-RAGALPADU | RAGALPADU_220 | 2:35(17.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1404 | 22-May-2022 | GULBARGA | 220 | LINGAPUR-BTPS | LINGAPUR_220 | 01:55(17.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1405 | 22-May-2022 | GULBARGA | 220 | KUDLIGI-HIREMALLANAHALLI 1&2 | KUDLIGI_220 | 17:25(08.05.2022) | | | LINE OPEN,LINE FAULT |
| 1406 | 22-May-2022 | GULBARGA | 220 | HV2 | KUDLIGI_220 | 16:18(12.08.2021) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1407 | 22-May-2022 | GULBARGA | 220 | LINGASUGUR-BAGEWADI1,2 | LINGASUGUR_220 | 10:00 | 17:12 | 7:12 | LINE CLEAR AVAILED |
| 1408 | 22-May-2022 | GULBARGA | 220 | LINGASUGUR-SINDHANOOR | SINDHANOOR_220 | 11:51 | 17:17 | 5:26 | LINE CLEAR AVAILED |
| 1409 | 22-May-2022 | GULBARGA | 220 | SHAHAPUR-LINGASUGUR | SHAHAPUR_220 | 0:05 | 0:30 | 0:25 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|------------------------|---|--------------------|--------------------|-----------|-------------------------------------|
| 1410 | 22-May-2022 | GULBARGA | 220 | SHAHAPUR-LINGASUGUR | SHAHAPUR_220 | 1:52 | 15:10 | 13:18 | LINE FAULT |
| 1411 | 22-May-2022 | GULBARGA | 110 | RAICHUR-SHAHPUR_2 | GOOGLE_110 | 17:05 (22.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1412 | 22-May-2022 | GULBARGA | 110 | SHAHAPUR-KHANAPUR | KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP | 10:55 (11.04.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1413 | 22-May-2022 | GULBARGA | 110 | SHAHAPUR-RAICHUR_2 | DEODURGA_110 | 16:15 (22.05.2022) | | | LINE OPEN,LINE FAULT |
| 1414 | 22-May-2022 | GULBARGA | 110 | LV2 | SHAHAPUR_220 | 10:24 | 11:37 | 1:13 | LINE CLEAR AVAILED |
| 1415 | 22-May-2022 | GULBARGA | 110 | HV1 | HARIVI_110 | 9:00 | 9:10 | 0:10 | LINE CLEAR AVAILED |
| 1416 | 22-May-2022 | GULBARGA | 110 | HV1 | HARIVI_110 | 16:20 | 16:45 | 0:25 | LINE CLEAR AVAILED |
| 1417 | 22-May-2022 | GULBARGA | 110 | HV1 | BENNUR_110 | 2:50 | 3:50 | 1:00 | TRANSFORMER FAULT |
| 1418 | 22-May-2022 | GULBARGA | 110 | LINGASUGUR-CHAYADEVI | CHAYADEVI_IPP,KAREPOWER_IPP | 5:35 | 6:46 | 1:11 | LINE FAULT |
| 1419 | 22-May-2022 | GULBARGA | 110 | KAPNOOR-GULBARGA NORH1 | GULBARGA NORTH_110,GULBARGA SOUTH_110,GULBARGA UNIVERSITY_110 | 8:30 | 9:08 | 0:38 | LINE CLEAR AVAILED |
| 1420 | 22-May-2022 | GULBARGA | 110 | SEDAM-GURUMITKAL | GURMITKAL_110,KONKAL_110 | 11:50 | 11:58 | 0:08 | LINE FAULT |
| 1421 | 22-May-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | YADGIR_110,SAIDAPUR_110,KHANAPUR_110,WADGERA_110 | 15:13 (21.05.2022) | 11:42 (22.05.2022) | 20:29 HRS | LINE CHARGED |
| 1422 | 22-May-2022 | GULBARGA | 110 | SHAHAPUR-RAICHUR_1 | DEODURGA_110 | 10:24 | 11:40 | 1:16 | LINE CLEAR AVAILED |
| 1423 | 22-May-2022 | GULBARGA | 110 | SHAHAPUR-RAICHUR_1 | DEODURGA_110 | 15:34 | 15:45 | 0:11 | LINE FAULT |
| 1424 | 22-May-2022 | GULBARGA | 110 | SHAHAPUR-RAICHUR_2 | DEODURGA_110 | 15:34 | 15:45 | 0:11 | LINE FAULT |
| 1425 | 22-May-2022 | GULBARGA | 110 | SHAHAPUR-RAICHUR_1 | DEODURGA_110 | 15:57 | 16:10 | 0:13 | LINE FAULT |
| 1426 | 22-May-2022 | GULBARGA | 110 | SHAHAPUR-RAICHUR_2 | DEODURGA_110 | 15:57 | 16:10 | 0:13 | LINE FAULT |
| 1427 | 22-May-2022 | GULBARGA | 110 | SHAHAPUR-RAICHUR_1 | DEODURGA_110 | 16:15 | 17:07 | 0:52 | LINE FAULT |
| 1428 | 22-May-2022 | GULBARGA | 110 | RAICHUR-SHAHPUR2 | GOOGLE_110 | 0:09 | 0:30 | 0:21 | LINE FAULT |
| 1429 | 22-May-2022 | GULBARGA | 110 | RAICHUR-SHAHPUR_1 | GOOGLE_110 | 17:05 | 17:25 | 0:20 | LINE CLEAR AVAILED |
| 1430 | 22-May-2022 | GULBARGA | 110 | YELBURGA-PARAMPOOJYA | YELBURGA_110 | 11:58 | 12:20 | 0:22 | LINE CLEAR AVAILED |
| 1431 | 22-May-2022 | GULBARGA | 110 | NALWAR-WARDHASOLAR_IPP | NALWAR_110 | 0:00 | 0:20 | 0:20 | LINE CLEAR AVAILED |
| 1432 | 22-May-2022 | GULBARGA | 110 | NALWAR-WARDHASOLAR_IPP | NALWAR_110 | 0:30 | 0:40 | 0:10 | LINE CLEAR AVAILED |
| 1433 | 22-May-2022 | GULBARGA | 66 | MUNIRABAD-MSDLIN | HANASI_66 | 9:05 | 15:35 | 6:30 | LINE FAULT |
| 1434 | 22-May-2022 | GULBARGA | 66 | GUDEKOTE-HANGAL2 | GUDEKOTE_66 | 10:30 | 10:40 | 0:10 | MAIN SUPPLY FAILURE |
| 1435 | 22-May-2022 | HASSAN | 110 | JOG-JLT3 | gen_mghe | 15:14(21.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1436 | 22-May-2022 | HASSAN | 110 | JOG110-MGHE | JOG_110 | 15:14(21.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1437 | 22-May-2022 | HASSAN | 110 | JOG-NK2 | mghejog_gen | 17:05(28.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1438 | 22-May-2022 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 12:15 (29.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1439 | 22-May-2022 | HASSAN | 110 | HV3 | JOG_110 | 10:55(05.04.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1440 | 22-May-2022 | HASSAN | 220 | HV3 | KAVOOR_220 | 19:55(30.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1441 | 22-May-2022 | HASSAN | 110 | HV2 | BARANGI_110 | 10:22(17.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1442 | 22-May-2022 | HASSAN | 66 | ALDUR-BALEHONNUR | ALDUR_66 | 5:30(19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|---------------------------|-------------------------------|----------------------------|-----------|----------|-------------------------------------|
| 1443 | 22-May-2022 | HASSAN | 220 | HV1 | MRSMSG_220 | 8:27 | 19:20 | 10:53 | TRANSFORMER FAULT |
| 1444 | 22-May-2022 | HASSAN | 110 | LV1 | MRSMSG_220 | 8:27 | 19:20 | 10:53 | TRANSFORMER FAULT |
| 1445 | 22-May-2022 | HASSAN | 110 | MRSSHM-SS1 | MRSMSG_220 | 8:25 | 19:21 | 10:56 | LINE FAULT |
| 1446 | 22-May-2022 | HASSAN | 110 | MRSSHM-SS2 | MRSMSG_220 | 8:25 | 19:22 | 10:57 | LINE FAULT |
| 1447 | 22-May-2022 | HASSAN | 110 | ALKOLA-MRS | ALKOLA_110 | 8:27 | 10:55 | 2:28 | LINE FAULT |
| 1448 | 22-May-2022 | HASSAN | 110 | ANANDA-LPH(LST-4) | ANANDAPURA_110 | 8:30 | 10:00 | 1:30 | MAIN SUPPLY FAILURE |
| 1449 | 22-May-2022 | HASSAN | 110 | ANANDA-SHIMOGA | ANANDAPURA_110 | 8:30 | 10:20 | 1:50 | MAIN SUPPLY FAILURE |
| 1450 | 22-May-2022 | HASSAN | 66 | RAMNAT-BNDSTHL | RAMNATHPURA_66 | 11:28 | 13:21 | 1:53 | LINE FAULT |
| 1451 | 22-May-2022 | HASSAN | 66 | HV2 | RAMNATHPURA_66 | 11:28 | 13:21 | 1:53 | TRANSFORMER FAULT |
| 1452 | 22-May-2022 | HASSAN | 66 | RAMNAT-KATTEPURA_MINIH | RAMNATHPURA_66 | 11:28 | 13:21 | 1:53 | HAND TRIPPED |
| 1453 | 22-May-2022 | HASSAN | 66 | HNPR2-RNPR1 | HNPUA_220 | 13:05 | 13:55 | 0:50 | LINE FAULT |
| 1454 | 22-May-2022 | MYSURU | 66 | HV1 | BANNIMANTAP_66 | 10:40 | 16:18 | 5:37 | LINE CLEAR AVAILED |
| 1455 | 22-May-2022 | MYSURU | 66 | HV1 | BGNAGARA_66 | 16:16 | 16:18 | 0:02 | LINE CLEAR AVAILED |
| 1456 | 22-May-2022 | MYSURU | 66 | CR NAGARA-BADANAGUPPE 2 | BADANAGUPPE_66 | 9:13 | 14:16 | 5:03 | LINE CLEAR AVAILED |
| 1457 | 22-May-2022 | MYSURU | 66 | CR NAGARA-PANNIYADHAHUNDI | NO STATIONS EFFECTED | 14:52 | 16:23 | 1:31 | LINE CLEAR AVAILED |
| 1458 | 22-May-2022 | MYSURU | 66 | HOOTAGALLY-HAMPAPURA | DODDAKADNUR(HAMPAPU RA) 66 | 16:00 | 16:10 | 0:10 | LINE FAULT |
| 1459 | 22-May-2022 | MYSURU | 220 | HOOTAGALLY-BASTIPURA1 | NO STATIONS EFFECTED | 9:53 | 12:29 | 2:36 | NFBC ISSUED |
| 1460 | 22-May-2022 | MYSURU | 66 | GUNDLUPETE-HANGLA | BHARGI_66 | 11:07 | 11:14 | 0:07 | LINE FAULT |
| 1461 | 22-May-2022 | MYSURU | 66 | KOLLEGALA-CR NAGARA | NO STATIONS EFFECTED | 9:57 | 17:20 | 7:22 | NFBC ISSUED |
| 1462 | 22-May-2022 | MYSURU | 66 | KOLLEGALA-MADHUVANAHALLI | KOLLEGALA_66 | 10:27 | 16:51 | 6:24 | NFBC ISSUED |
| 1463 | 22-May-2022 | MYSURU | 66 | KOLLEGALA-SATHEGALA | SATHEGALA_66 | 10:07 | 16:39 | 6:31 | NFBC ISSUED |
| 1464 | 22-May-2022 | MYSURU | 66 | KOLLEGALA-PARINAMIPURA | NO STATIONS EFFECTED | 10:15 | 16:54 | 6:38 | NFBC ISSUED |
| 1465 | 22-May-2022 | MYSURU | 66 | HV1 | PONNAMPET_66 | 23:41 | 23:48 | 0:07 | TRANSFORMER FAULT |
| 1466 | 22-May-2022 | MYSURU | 66 | PONNAMPETE-VIRAJPETE | VIRAJPET_66 | 23:41 | 0:00 | 0:18 | LINE FAULT |
| 1467 | 22-May-2022 | MYSURU | 66 | SATHEGALA-BPCL | NO STATIONS EFFECTED | 10:12 | 14:01 | 3:49 | LINE CLEAR AVAILED |
| 1468 | 22-May-2022 | MYSURU | 66 | SATHEGALA-HEBBANI | SATHEGALA_66 | 10:12 | 13:15 | 3:03 | HAND TRIPPED |
| 1469 | 22-May-2022 | MYSURU | 66 | HV1 | SATHEGALA_66 | 10:05 | 13:15 | 3:10 | LINE CLEAR AVAILED |
| 1470 | 22-May-2022 | MYSURU | 66 | HV2 | SATHEGALA_66 | 10:05 | 15:20 | 5:15 | LINE CLEAR AVAILED |
| 1471 | 22-May-2022 | MYSURU | 66 | THALAKADU-ADANI | NO STATIONS EFFECTED | 1:45 | 2:00 | 0:15 | LINE FAULT |
| 1472 | 22-May-2022 | MYSURU | 66 | HV1 | MADIKERI_66 | 11:33:09 (21/05/2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1473 | 22-May-2022 | MYSURU | 66 | HEBBANI-TK HALLI | NO STATIONS EFFECTED | 12:03:00 (14.5.2022) | | | LINE OPEN,LINE FAULT |
| 1474 | 22-May-2022 | MYSURU | 66 | KHB STATION-BILIKERE | NO STATIONS EFFECTED | 10:57:05 (4/5/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1475 | 22-May-2022 | MYSURU | 66 | DUNDANAHALLY-HULIYURDURGA | NO STATIONS EFFECTED | 8:36:34 (30/04/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1476 | 22-May-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 6:26:00 PM (22/04/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1477 | 22-May-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16:00 (08/12/2021) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1478 | 22-May-2022 | TUMKUR | 220 | HIRIYUR 220KV- PGCIL GRID | HIRIYUR_220 | 9:45 | 10:22 | 0:37 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--|---|-----------------------|-----------------------|----------|-------------------------------------|
| 1479 | 22-May-2022 | TUMKUR | 220 | HIRIYURkv 220kv- MADHUGIRI 220 | HIRIYUR_220 | 9:48 | 10:05 | 0:17 | LINE FAULT |
| 1480 | 22-May-2022 | TUMKUR | 220 | HIRIYUR220-THALLAK220 | HIRIYUR_220 | 9:50 | 10:09 | 0:19 | HAND TRIPPED |
| 1481 | 22-May-2022 | TUMKUR | 220 | HIRIYUR 220KV- AZURE POWER SOLAR IPP_66 | AZURE POWER SOLAR IPP_66 | 9:50 | 10:09 | 0:19 | MAIN SUPPLY FAILURE |
| 1482 | 22-May-2022 | TUMKUR | 220 | TR-1(HV SIDE) | HIRIYUR_220 | 9:50 | 10:09 | 0:19 | MAIN SUPPLY FAILURE |
| 1483 | 22-May-2022 | TUMKUR | 220 | TR-2(HV SIDE) | HIRIYUR_220 | 9:50 | 10:09 | 0:19 | MAIN SUPPLY FAILURE |
| 1484 | 22-May-2022 | TUMKUR | 220 | TR-2(HV SIDE) | HIRIYUR_220 | 13:05 | 14:10 | 1:05 | TRANSFORMER FAULT |
| 1485 | 22-May-2022 | TUMKUR | 220 | TR-3(HV SIDE) | HIRIYUR_220 | 9:50 | 10:09 | 0:19 | MAIN SUPPLY FAILURE |
| 1486 | 22-May-2022 | TUMKUR | 66 | HONNALLI 220kv- BANUVALLI | BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66 | 9:20 | 9:33 | 0:13 | LINE FAULT |
| 1487 | 22-May-2022 | TUMKUR | 66 | HONNALLI 220kv- KUNDUR66 | KUNDUR,_66,MALEBENNUR _66,DEVARABELKERE_66 | 9:20 | 9:33 | 0:13 | LINE FAULT |
| 1488 | 22-May-2022 | TUMKUR | 66 | HONNALLI 220kv- BANUVALLI | BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66 | 11:06 | 14:38 | 3:32 | LINE CLEAR AVAILED |
| 1489 | 22-May-2022 | TUMKUR | 66 | HONNALLI 220kv- KUNDUR66 | KUNDUR,_66,MALEBENNUR _66,DEVARABELKERE_66 | 11:06 | 14:38 | 3:32 | LINE CLEAR AVAILED |
| 1490 | 22-May-2022 | TUMKUR | 66 | DAVANGERE SRS- SOKKE | MELLEKATTE_66, SOKKE_66 | 11:48 | 11:58 | 0:10 | LINE FAULT |
| 1491 | 22-May-2022 | TUMKUR | 66 | DAVANGERE SRS- SOKKE | MELLEKATTE_66, SOKKE_66 | 12:11 | 12:55 | 0:44 | LINE FAULT |
| 1492 | 23-May-2022 | BAGALKOT | 110 | PG HUNSHYAL-MUDALAGI (NAGANUR) | STATION NOT AFFECTED PG HUNSHYAL_110 | 16:13 (04.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1493 | 23-May-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED LAXMESHWAR_110 | 17:55 (28.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1494 | 23-May-2022 | BAGALKOT | 220 | AMBEWADI-PONDA2 | STATION NOT AFFECTED AMBEWADI_220 | 14:10 (19.05.2022) | 13:59 (23.05.2022) | 95:49:00 | LINE FAULT |
| 1495 | 23-May-2022 | BAGALKOT | 220 | BAGEWADI-BIJAPUR1 | STATION NOT AFFECTED BAGEWADI_220 | 17:54 (19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1496 | 23-May-2022 | BAGALKOT | 220 | BAGEWADI-BIJAPUR2 | STATION NOT AFFECTED BAGEWADI_220 | 17:54 (19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1497 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | ALMEL_110 | 18:23 | 18:34 | 0:11 | HAND TRIPPED |
| 1498 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | AEQUS_220 | 12:11 | 18:28 | 6:17 | LINE CLEAR AVAILED |
| 1499 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | AEQUS_220 | 12:13 | 18:29 | 6:16 | LINE CLEAR AVAILED |
| 1500 | 23-May-2022 | BAGALKOT | 110 | BABALESHWAR- MAMADAPUR(B) | BABLESHWAR_110 | 12:15 | 12:20 | 0:05 | LINE FAULT |
| 1501 | 23-May-2022 | BAGALKOT | 110 | BABALESHWAR- MAMADAPUR(B) | BABLESHWAR_110 | 12:30 | 12:35 | 0:05 | LINE FAULT |
| 1502 | 23-May-2022 | BAGALKOT | 110 | 110/33KV, HV3 | BELLATTI_110, HOLETIGE_33, SURUGANI_33 | 9:02 | 9:20 | 0:18 | TRANSFORMER FAULT |
| 1503 | 23-May-2022 | BAGALKOT | 220 | BIDNAL- HUBLI3 (HUBLI2) | STATION NOT AFFECTED BIDNAL_220 | 22:33 (23.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1504 | 23-May-2022 | BAGALKOT | 110 | BIDNAL220- ANNIGERI | STATION NOT AFFECTED BIDNAL_220 | 5:41 | 10:07 | 4:26 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--|---|-----------------------|-----------|----------|----------------------|
| 1505 | 23-May-2022 | BAGALKOT | 110 | 110/33KV, HV2 | BISNAL_110, TEGGI_33 | 14:58 | 15:04 | 0:06 | TRANSFORMER FAULT |
| 1506 | 23-May-2022 | BAGALKOT | 110 | THORVI- BHUTANAL | STATION NOT AFFECTED THORVI_110 | 7:55 | 14:06 | 6:11 | NFBC ISSUED |
| 1507 | 23-May-2022 | BAGALKOT | 110 | THORVI- TIKOTA(TAKKALAKI) | STATION NOT AFFECTED THORVI_110 | 8:01 | 8:04 | 0:03 | HAND TRIPPED |
| 1508 | 23-May-2022 | BAGALKOT | 110 | THORVI- TIKOTA(TAKKALAKI) | STATION NOT AFFECTED THORVI_110 | 14:06 | 14:08 | 0:02 | HAND TRIPPED |
| 1509 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | THORVI_110 | 15:08 | 15:12 | 0:04 | TRANSFORMER FAULT |
| 1510 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | HALKI_110 | 10:01 | 10:11 | 0:10 | TRANSFORMER FAULT |
| 1511 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | HALKI_110 | 11:32 | 13:06 | 1:34 | LINE CLEAR AVAILED |
| 1512 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | HIREMASALI_110 | 22:45 | 22:50 | 0:05 | TRANSFORMER FAULT |
| 1513 | 23-May-2022 | BAGALKOT | 110 | KUMATA- SIRSI1(KRCL RAILWAY) | KUMATA_110 | 11:51 | 11:56 | 0:05 | LINE FAULT |
| 1514 | 23-May-2022 | BAGALKOT | 110 | KUMATA- SIRSI1(KRCL RAILWAY) | KUMATA_110 | 18:45 | 18:52 | 0:07 | LINE FAULT |
| 1515 | 23-May-2022 | BAGALKOT | 110 | KUMATA- SIRSI1(KRCL RAILWAY) | KUMATA_110 | 18:55 | 19:02 | 0:07 | LINE FAULT |
| 1516 | 23-May-2022 | BAGALKOT | 110 | MURDESHWAR- HONNAVAR (KRCL RAILWAY) | MURDESHWAR_110 | 10:41 | 14:40 | 3:59 | LINE CLEAR AVAILED |
| 1517 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV3 | SAVALAGI_110 | 14:25 | 14:59 | 0:34 | HAND TRIPPED |
| 1518 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | SAVALAGI_110 | 14:45 | 14:50 | 0:05 | HAND TRIPPED |
| 1519 | 23-May-2022 | BAGALKOT | 110 | TIKOTA- BHUTNAL(TAKKALAKI) | TIKOTA_110 | 9:37 | 9:41 | 0:04 | LINE FAULT |
| 1520 | 23-May-2022 | BAGALKOT | 110 | TIKOTA- BHUTNAL(TAKKALAKI) | TIKOTA_110 | 13:03 | 13:07 | 0:04 | HAND TRIPPED |
| 1521 | 23-May-2022 | BAGALKOT | 110 | TAKKALAKI- TIKOTA | TAKKALAKI_110 | 7:56 | 8:04 | 0:08 | HAND TRIPPED |
| 1522 | 23-May-2022 | BAGALKOT | 110 | TAKKALAKI- TIKOTA | TAKKALAKI_110 | 11:57 | 12:02 | 0:05 | LINE FAULT |
| 1523 | 23-May-2022 | BAGALKOT | 110 | TAKKALAKI- TIKOTA | TAKKALAKI_110 | 14:08 | 14:09 | 0:01 | HAND TRIPPED |
| 1524 | 23-May-2022 | BAGALKOT | 110 | TAKKALAKI- KN SOLAR | TAKKALAKI_110 | 8:03 | 8:05 | 0:02 | HAND TRIPPED |
| 1525 | 23-May-2022 | BAGALKOT | 110 | TAKKALAKI- KN SOLAR | TAKKALAKI_110 | 12:40 | 13:10 | 0:30 | HAND TRIPPED |
| 1526 | 23-May-2022 | BAGALKOT | 110 | TAKKALAKI-WARADA SOLAR | TAKKALAKI_110 | 13:10 | 14:10 | 1:00 | HAND TRIPPED |
| 1527 | 23-May-2022 | BAGALKOT | 110 | TAKKALAKI- TORVI | TAKKALAKI_110 | 12:36 | 12:42 | 0:06 | HAND TRIPPED |
| 1528 | 23-May-2022 | BAGALKOT | 110 | TAKKALAKI- TORVI | TAKKALAKI_110 | 13:03 | 13:10 | 0:07 | HAND TRIPPED |
| 1529 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | UKKALI_110 | 9:38 | 18:37 | 8:59 | LINE CLEAR AVAILED |
| 1530 | 23-May-2022 | BAGALKOT | 110 | UKKALI- F2 (BAGEWADI) | UKKALI_110 | 9:38 | 18:37 | 8:59 | LINE CLEAR AVAILED |
| 1531 | 23-May-2022 | BAGALKOT | 110 | YELLAMANAWADI- F2(SAVALAGI) | STATION NOT AFFECTED YELLAMANAWADI_110 | 8:26 | 18:40 | 10:14 | LINE CLEAR AVAILED |
| 1532 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | YELLAMANAWADI_110 | 14:25 | 15:44 | 1:19 | LINE CLEAR AVAILED |
| 1533 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | LOKAPUR_110 | 17:56 | 18:37 | 0:41 | TRANSFORMER FAULT |
| 1534 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | LOKAPUR_110 | 20:44 | 22:08 | 1:24 | TRANSFORMER FAULT |
| 1535 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | LOKAPUR_110 | 22:14 | 23:04 | 0:50 | TRANSFORMER FAULT |
| 1536 | 23-May-2022 | BAGALKOT | 110 | BAGALKOT-BAGALKOT2 | BAGAKOT_220 | 9:13 | 16:03 | 6:50 | LINE CLEAR AVAILED |
| 1537 | 23-May-2022 | BAGALKOT | 110 | 110/33KV,HV3 | KATAGERI_33,GADDANAKER I_33 BAGAKOT_220 | 7:31 | 7:46 | 0:15 | TRANSFORMER FAULT |
| 1538 | 23-May-2022 | BAGALKOT | 220 | HUBLI-SIRSI2 | HUBLI_220 | 16:59 (23.05.2022) | | | LINE OPEN,LINE FAULT |
| 1539 | 23-May-2022 | BAGALKOT | 220 | HUBLI-BIDNAL2 | HUBLI_220 | 22:33 (23.05.2022) | | | LINE OPEN,LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|-----------------------------|---|-----------------------|-----------------------|----------|-------------------------------------|
| 1540 | 23-May-2022 | BAGALKOT | 220 | MUGALKHOD-CHIKKODI2 | MUGALKHOD_220 | 10:02 | 13:04 | 3:02 | LINE CLEAR AVAILED |
| 1541 | 23-May-2022 | BAGALKOT | 220 | MUGALKHOD-CHIKKODI1 | MUGALKHOD_220 | 13:09 | 14:18 | 1:08 | LINE CLEAR AVAILED |
| 1542 | 23-May-2022 | BAGALKOT | 110 | RANEENNUR-HIREKERUR | HIREKERUR_110 | 10:15 | 10:44 | 0:29 | LINE FAULT |
| 1543 | 23-May-2022 | BAGALKOT | 220 | CHIKKODI-MUGALKHOD2 | CHIKKODI_220 | 10:03 | 13:04 | 3:04 | LINE CLEAR AVAILED |
| 1544 | 23-May-2022 | BAGALKOT | 220 | CHIKKODI-MUGALKHOD1 | CHIKKODI_220 | 13:10 | 14:18 | 1:08 | LINE CLEAR AVAILED |
| 1545 | 23-May-2022 | BAGALKOT | 220 | CHIKKODI-MUDASHINGI | CHIKKODI_220 | 12:05 | 19:11 | 7:06 | NFBC ISSUED |
| 1546 | 23-May-2022 | BAGALKOT | 220 | 220/110KV,HV1,LV1 | KARWAR_220 | 10:49 | 14:06 | 3:15 | LINE CLEAR AVAILED |
| 1547 | 23-May-2022 | BAGALKOT | 110 | MK HUBLI220-MK HUBLI LINE 1 | MK HUBLI_220 | 12:51 | 13:16 | 0:15 | LINE CLEAR AVAILED |
| 1548 | 23-May-2022 | BAGALKOT | 110 | AMBEWADI-NK1(HALIYAL) | AMBEWADI_220 | 8:54 (23.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1549 | 23-May-2022 | BAGALKOT | 110 | AMBEWADI-NK2(KAVALWADA) | AMBEWADI_220 | 8:55 (23.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1550 | 23-May-2022 | BAGALKOT | 110 | SHIRAHATTI-BPCL2 | STATION NOT AFFECTED SHIRAHATTI_110 | 16:40 (27.04.2022) | | | LINE OPEN,LINE FAULT |
| 1551 | 23-May-2022 | BAGALKOT | 220 | SIRSI- HUBLI1 | STATION NOT AFFECTED SIRSI_220 | 15:26 (13.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1552 | 23-May-2022 | BAGALKOT | 220 | SIRSI- HUBLI2 | STATION NOT AFFECTED SIRSI_220 | 15:26 (13.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1553 | 23-May-2022 | BAGALKOT | 220 | NARENDRA- BELGAUM1 | STATION NOT AFFECTED NARENDRA_220 | 9:01 (14.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1554 | 23-May-2022 | BAGALKOT | 220 | BELGAUM- NARENDRA1 | STATION NOT AFFECTED BELGAUM_220 | 9:01 (14.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1555 | 23-May-2022 | BAGALKOT | 110 | 110/33KV, HV3 | YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1556 | 23-May-2022 | BAGALKOT | 110 | YLWD-SAVALAGI | STATION NOT AFFECTED YELLAMANAWADI_110 | 24:00 (18.05.2022) | 11:30 (21.05.2022) | 59:30HRS | LINE CHARGED |
| 1557 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | CHADCHAN_110 | 7:20 (19.05.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1558 | 23-May-2022 | BAGALKOT | 110 | 110/11KV,HV1&2 | JAMBAGI_110 | 12:32 | 13:57 | 1:25 | HAND TRIPPED |
| 1559 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV1 | UTTUR_110 | 12:10 | 13:20 | 1:10 | LINE CLEAR AVAILED |
| 1560 | 23-May-2022 | BAGALKOT | 110 | 110/11KV, HV2 | UTTUR_110 | 12:15 | 14:06 | 1:51 | LINE CLEAR AVAILED |
| 1561 | 23-May-2022 | BENGALURU | 66 | HV1 | BANASHANKARI | 16:37 | 16:39 | 0:02 | LINE CLEAR AVAILED |
| 1562 | 23-May-2022 | BENGALURU | 66 | BANASAWADI - ITI 220 | BANASAWADI | 17:15 | 17:27 | 0:12 | MAIN SUPPLY FAILURE |
| 1563 | 23-May-2022 | BENGALURU | 66 | HV2 | BANASAWADI | 18:02 | 18:04 | 0:02 | LOAD CHANGE OVER |
| 1564 | 23-May-2022 | BENGALURU | 66 | HV1 | CHATRA | 7:24 | 7:26 | 0:02 | TRANSFORMER FAULT |
| 1565 | 23-May-2022 | BENGALURU | 66 | HV2 | CHATRA | 7:24 | 7:26 | 0:02 | TRANSFORMER FAULT |
| 1566 | 23-May-2022 | BENGALURU | 66 | HV1 | ISKON | 10:49 | 10:55 | 0:06 | LINE CLEAR AVAILED |
| 1567 | 23-May-2022 | BENGALURU | 66 | HV1 | ISKON | 15:12 | 15:15 | 0:03 | LOAD CHANGE OVER |
| 1568 | 23-May-2022 | BENGALURU | 66 | HV2 | NIMHANS 220 | 12:08 | 12:15 | 0:07 | LINE CLEAR AVAILED |
| 1569 | 23-May-2022 | BENGALURU | 66 | HV2 | NIMHANS 220 | 14:50 | 14:57 | 0:07 | LOAD CHANGE OVER |
| 1570 | 23-May-2022 | BENGALURU | 66 | ITI 220 - BANASAWADI | BANASAWADI | 17:15 | 17:27 | 0:12 | LINE FAULT |
| 1571 | 23-May-2022 | BENGALURU | 66 | TK HALLI 220 - SIMSHA | NO STATION AFFECTED | 17:13 | 17:25 | 0:12 | LINE FAULT |
| 1572 | 23-May-2022 | BENGALURU | 66 | KGF - T GOLAHALLI 220 | TEKAL, BUDIKOTE, TORLAKKI | 10:15 | 10:22 | 0:07 | LOAD CHANGE OVER |
| 1573 | 23-May-2022 | BENGALURU | 66 | HV2 | DALSANUR | 11:40 | 12:35 | 0:54 | LINE CLEAR AVAILED |
| 1574 | 23-May-2022 | BENGALURU | 66 | HV2 | TALAGUNDA | 12:43 | 13:04 | 0:20 | LINE CLEAR AVAILED |
| 1575 | 23-May-2022 | BENGALURU | 66 | HV1 | HUNSENAHALLI | 13:55 | 14:00 | 0:04 | LINE CLEAR AVAILED |
| 1576 | 23-May-2022 | BENGALURU | 66 | HV2 | HUNSENAHALLI | 12:00 | 12:05 | 0:05 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|------------------------------|---|--------------------|--------------------|-----------|-------------------------------------|
| 1577 | 23-May-2022 | BENGALURU | 66 | HV1 | GUNDLU KOTTUR | 13:02 | 13:05 | 0:02 | LINE CLEAR AVAILED |
| 1578 | 23-May-2022 | BENGALURU | 66 | HV1 | BIJAHALLI | 16:29 | 16:35 | 0:05 | LINE CLEAR AVAILED |
| 1579 | 23-May-2022 | BENGALURU | 66 | MALUR 220 - MALUR 66 | MALUR 66 | 13:48 | 14:38 | 0:50 | LINE CLEAR AVAILED |
| 1580 | 23-May-2022 | BENGALURU | 220 | HV2 | BEGUR 220 | 13:24 | 13:32 | 0:07 | TRANSFORMER FAULT |
| 1581 | 23-May-2022 | BENGALURU | 220 | LV2 | BEGUR 220 | 13:24 | 13:32 | 0:08 | TRANSFORMER FAULT |
| 1582 | 23-May-2022 | BENGALURU | 66 | BEGUR 220 - VIDYANAGAR | VIDYANAGAR | 13:24 | 13:34 | 0:09 | MAIN SUPPLY FAILURE |
| 1583 | 23-May-2022 | BENGALURU | 66 | BEGUR 220 - BIAL 2 | AIRPORT | 13:24 | 13:36 | 0:11 | MAIN SUPPLY FAILURE |
| 1584 | 23-May-2022 | BENGALURU | 220 | BEGUR 220 - KHW PARK 1 | NO STATION AFFECTED | 13:24 | 13:36 | 0:12 | MAIN SUPPLY FAILURE |
| 1585 | 23-May-2022 | BENGALURU | 220 | BEGUR 220 - KHW PARK 2 | NO STATION AFFECTED | 13:24 | 13:36 | 0:12 | LINE FAULT |
| 1586 | 23-May-2022 | BENGALURU | 66 | BEGUR 220 - ITC (EHT) | ITC (EHT) | 13:24 | 13:30 | 0:06 | LINE FAULT |
| 1587 | 23-May-2022 | BENGALURU | 220 | GOWRIBIDANUR 220 - PGCIL 1 | NO STATION AFFECTED | 21:22(22-5-2022) | 21:55(23-5-2022) | 24:32HRS | LINE CHARGED |
| 1588 | 23-May-2022 | GULBARGA | 400 | BTPSG-HIRIYUR2 | HIRIYUR_400 | 16:12(08.05.2022) | | | LINE OPEN,LINE FAULT |
| 1589 | 23-May-2022 | GULBARGA | 400 | BTPSG-HIRIYUR1 | HIRIYUR_400 | 10:46 | 16:25 | 5:39 | LINE CLEAR AVAILED |
| 1590 | 23-May-2022 | GULBARGA | 220 | MALLAT-RTPS LINE 3 | MALLAT_220 | 12:55(23/05/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1591 | 23-May-2022 | GULBARGA | 220 | ALIPUR-RAGALPADU | RAGALPADU_220 | 2:35(17.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1592 | 23-May-2022 | GULBARGA | 220 | LINGAPUR-BTPS | LINGAPUR_220 | 01:55(17.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1593 | 23-May-2022 | GULBARGA | 220 | KUDLIGI-HIREMALLANAHALLI 1&2 | KUDLIGI_220 | 17:25(08.05.2022) | | | LINE OPEN,LINE FAULT |
| 1594 | 23-May-2022 | GULBARGA | 220 | HV2 | KUDLIGI_220 | 16:18(12.08.2021) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1595 | 23-May-2022 | GULBARGA | 220 | LINGASUGUR-BAGEWADI1,2 | LINGASUGUR_220 | 10:38 | 18:08 | 7:30 | LOAD CURTAILMENT |
| 1596 | 23-May-2022 | GULBARGA | 220 | RAICHUR-JURALA_1 & 2_IPP | RAICHUR_220 | 10:10 | 17:01 | 6:51 | NFBC ISSUED |
| 1597 | 23-May-2022 | GULBARGA | 220 | LINGASUGUR-KUSTAGI | KUSTAGI_220 | 18:10 | 20:34 | 2:24 | LINE CLEAR AVAILED |
| 1598 | 23-May-2022 | GULBARGA | 110 | SHAHAPUR-KHANAPUR | KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP | 10:55 (11.04.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1599 | 23-May-2022 | GULBARGA | 110 | HV1 | METRI_110 | 10:30 | 15:30 | 5:00 | LINE CLEAR AVAILED |
| 1600 | 23-May-2022 | GULBARGA | 110 | HV2 | SREERAMANAGAR_110 | 11:40 | 11:52 | 0:12 | TRANSFORMER FAULT |
| 1601 | 23-May-2022 | GULBARGA | 110 | HV2 | MANVI_110 | 11:02 | 11:19 | 0:17 | LINE CLEAR AVAILED |
| 1602 | 23-May-2022 | GULBARGA | 110 | HV2 | MANVI_110 | 13:13 | 13:23 | 0:10 | TRANSFORMER FAULT |
| 1603 | 23-May-2022 | GULBARGA | 110 | HV2 | MANVI_110 | 13:28 | 13:41 | 0:13 | TRANSFORMER FAULT |
| 1604 | 23-May-2022 | GULBARGA | 110 | HV2 | DEODURGA_110 | 22:00 | 22:15 | 0:15 | TRANSFORMER FAULT |
| 1605 | 23-May-2022 | GULBARGA | 110 | SHAHAPUR-RAICHUR_2 | DEODURGA_110 | 16:15 (22.05.2022) | 15:26 (22.05.2022) | 23:11 HRS | LINE CHARGED |
| 1606 | 23-May-2022 | GULBARGA | 110 | SHAHAPUR-KEMBHAVI | KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNASAGI_110 | 4:35 | 4:40 | 0:05 | LINE FAULT |
| 1607 | 23-May-2022 | GULBARGA | 110 | RAICHUR-SHAHPUR_2 | GOOGLE_110 | 17:05 (22.05.2022) | 10:55 (23.05.2022) | 17:50 HRS | LINE CHARGED |
| 1608 | 23-May-2022 | GULBARGA | 110 | TEKKALKOTE-SIRIGUPPA | TEKKALKOTE_110 | 12:55 | 13:00 | 0:05 | LINE FAULT |
| 1609 | 23-May-2022 | GULBARGA | 110 | MALLAT-VALKAMDINNI | VALKAMDINNI_110 | 10:50 | 11:50 | 1:00 | LINE CLEAR AVAILED |
| 1610 | 23-May-2022 | GULBARGA | 110 | NAVALI-KANAKAGIRI | NAVALI_110 | 10:17 | 10:36 | 0:19 | MAIN SUPPLY FAILURE |
| 1611 | 23-May-2022 | GULBARGA | 110 | STARMETALLICS-MUNIRABAD | MUNIRABAD_220 | 9:44 | 10:31 | 0:47 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|----------------------------|--|--------------------|-------------------|----------|-------------------------------------|
| 1612 | 23-May-2022 | GULBARGA | 110 | HUNSIGI-KEMBHAVI | HUNSIGI_110 | 4:40 | 4:45 | 0:05 | MAIN SUPPLY FAILURE |
| 1613 | 23-May-2022 | GULBARGA | 110 | KAPANOOR-HUMNABAD2 | ALAND_110,KADAGANCHI_110 | 11:07 | 11:47 | 0:40 | LINE CLEAR AVAILED |
| 1614 | 23-May-2022 | GULBARGA | 110 | SINDHANOOR-MUNIRABAD2 | MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110 | 0:20 | 0:40 | 0:20 | LINE FAULT |
| 1615 | 23-May-2022 | GULBARGA | 110 | SINDHANOOR-NIRLOOTI | NIRLOOTI_IPP | 0:55 | 1:05 | 0:10 | LINE FAULT |
| 1616 | 23-May-2022 | GULBARGA | 110 | SINDHANOOR-ADAVIAMARESHWAR | MANVI_110,MADLAPUR_110,KURDICROSS_110,ADAVI AMARESHWAR_110 | 4:58 | 5:18 | 0:20 | LINE FAULT |
| 1617 | 23-May-2022 | GULBARGA | 66 | HV2 | TAMBRAHALLI_66 | 11:00 | 11:20 | 0:20 | LINE CLEAR AVAILED |
| 1618 | 23-May-2022 | GULBARGA | 66 | ITTAGI-HIREHADAGALI_2 | HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP | 9:50 | 18:08 | 8:18 | LINE CLEAR AVAILED |
| 1619 | 23-May-2022 | GULBARGA | 66 | ITTAGI-HIREHADAGALI_2 | HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP | 19:20 | 19:30 | 0:10 | LINE FAULT |
| 1620 | 23-May-2022 | GULBARGA | 66 | HOSAHALLI-CJHALLI | HOSAHALLI_66 | 5:50 | 5:55 | 0:05 | MAIN SUPPLY FAILURE |
| 1621 | 23-May-2022 | GULBARGA | 66 | HOSAHALLI-CJHALLI | HOSAHALLI_66 | 6:50 | 7:00 | 0:10 | MAIN SUPPLY FAILURE |
| 1622 | 23-May-2022 | GULBARGA | 66 | HOSAHALLI-CJHALLI | HOSAHALLI_66 | 18:40 | 18:45 | 0:05 | MAIN SUPPLY FAILURE |
| 1623 | 23-May-2022 | GULBARGA | 66 | HANASI-KUDLIGI | HANASI_66 | 18:05 | 18:15 | 0:10 | LINE FAULT |
| 1624 | 23-May-2022 | HASSAN | 110 | JOG-NK2 | mghejog_gen | 17:05(28.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1625 | 23-May-2022 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 12:15 (29.03.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1626 | 23-May-2022 | HASSAN | 110 | HV3 | JOG_110 | 10:55(05.04.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1627 | 23-May-2022 | HASSAN | 220 | HV3 | KAVOOR_220 | 19:55(30.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1628 | 23-May-2022 | HASSAN | 110 | HV2 | BARANGI_110 | 10:22(17.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1629 | 23-May-2022 | HASSAN | 110 | MOODAB-SOHAM1 | MOODABIDRE_110 | 14:05(23.05.2022) | | | LINE OPEN,LINE FAULT |
| 1630 | 23-May-2022 | HASSAN | 66 | ALDUR-BALEHONNUR | ALDUR_66 | 5:30(19.05.2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1631 | 23-May-2022 | HASSAN | 110 | HV2 | BARANGI_110 | 10:25(21.05.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1632 | 23-May-2022 | HASSAN | 110 | JOG-JLT3 | gen_mghe | 15:14(21.05.2022) | 11:45(23.05.2022) | 44:31HRS | LINE CHARGED |
| 1633 | 23-May-2022 | HASSAN | 220 | KEMAR-PUTUR2 | KEMAR:220 | 9:40 | 13:24 | 3:44 | NFBC ISSUED |
| 1634 | 23-May-2022 | HASSAN | 110 | KEMAR-NANDHIKUR1 | KEMAR:220 | 10:14 | 12:57 | 2:43 | LINE CLEAR AVAILED |
| 1635 | 23-May-2022 | HASSAN | 220 | KEMAR-Kavoor2 | KEMAR:220 | 10:42 | 13:06 | 2:24 | LINE CLEAR AVAILED |
| 1636 | 23-May-2022 | HASSAN | 110 | KAVOOR-Kulashkhara1 | KAVOOR_220 | 14:05 | 14:11 | 0:06 | LINE FAULT |
| 1637 | 23-May-2022 | HASSAN | 220 | KAVOOR-KEMAR | KAVOOR_220 | 10:05 | 16:45 | 6:40 | LINE CLEAR AVAILED |
| 1638 | 23-May-2022 | HASSAN | 220 | MSEZ-KEMAR2 | MSEZ:220 | 10:42 | 13:06 | 2:24 | NFBC ISSUED |
| 1639 | 23-May-2022 | HASSAN | 110 | HV1 | MSEZ:220 | 14:35 | 15:11 | 0:36 | LINE CLEAR AVAILED |
| 1640 | 23-May-2022 | HASSAN | 220 | PUTTUR-KEMAR2 | PUTTUR_220 | 9:40 | 13:24 | 3:44 | LINE CLEAR AVAILED |
| 1641 | 23-May-2022 | HASSAN | 220 | SHIMOGA1 | gen_varahi | 12:48 | 13:02 | 0:14 | LINE FAULT |
| 1642 | 23-May-2022 | HASSAN | 110 | HV1 | BARANGI_110 | 18:25 | 18:45 | 0:20 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|------------------------------|---|----------------------------|--------------------|----------|------------------------------|
| 1643 | 23-May-2022 | HASSAN | 110 | JOG110-LPH | JOG_110 | 14:55 | 15:55 | 1:00 | NFBC ISSUED |
| 1644 | 23-May-2022 | HASSAN | 110 | LPH-MGHE 1 | gen_lph | 14:42 | 15:55 | 1:13 | LINE FAULT |
| 1645 | 23-May-2022 | HASSAN | 110 | HV1 | SALATHUr_110 | 13:30 | 16:35 | 3:05 | TRANSFORMER FAULT |
| 1646 | 23-May-2022 | HASSAN | 66 | HV1 | BASAVAGATTA_66 | 11:14 | 14:17 | 3:03 | LINE CLEAR AVAILED |
| 1647 | 23-May-2022 | HASSAN | 66 | HV2 | BASAVAGATTA_66 | 10:21 | 14:17 | 3:56 | LINE CLEAR AVAILED |
| 1648 | 23-May-2022 | HASSAN | 66 | HV2 | HALEBEEDU_66 | 12:25 | 12:45 | 0:20 | LINE CLEAR AVAILED |
| 1649 | 23-May-2022 | HASSAN | 66 | HV1 | MANJUNATHPURA_66 | 11:10 | 11:40 | 0:30 | LINE CLEAR AVAILED |
| 1650 | 23-May-2022 | HASSAN | 66 | HV2 | MANJUNATHPURA_66 | 10:50 | 11:45 | 0:55 | LINE CLEAR AVAILED |
| 1651 | 23-May-2022 | HASSAN | 66 | HV1 | MOSALEHOSHALLY_66 | 16:00 | 17:15 | 1:15 | LINE CLEAR AVAILED |
| 1652 | 23-May-2022 | HASSAN | 66 | HV1 | RAMESHWARNAGARA_66 | 10:20 | 11:25 | 1:05 | LINE CLEAR AVAILED |
| 1653 | 23-May-2022 | HASSAN | 66 | HV2 | SAKALESHPPURA_66 | 4:44 | 4:55 | 0:11 | TRANSFORMER FAULT |
| 1654 | 23-May-2022 | HASSAN | 66 | SAKALE-IPCL1 | SAKALESHPPURA_66 | 12:00 | 17:30 | 5:30 | LINE CLEAR AVAILED |
| 1655 | 23-May-2022 | HASSAN | 66 | SAKALE-IPCL2 | SAKALESHPPURA_66 | 12:00 | 17:30 | 5:30 | LINE CLEAR AVAILED |
| 1656 | 23-May-2022 | HASSAN | 66 | UDDURKO-SUZLON2 | UDDURKOPPALU_66 | 8:25 | 9:25 | 1:00 | LINE FAULT |
| 1657 | 23-May-2022 | MYSURU | 66 | BEGUR-NANJANAGUDU | NO STATIONS EFFECTED | 17:15 | 17:25 | 0:10 | LINE FAULT |
| 1658 | 23-May-2022 | MYSURU | 66 | HV2 | HAMPAPURA_66 | 11:45 | 13:39 | 1:53 | LINE CLEAR AVAILED |
| 1659 | 23-May-2022 | MYSURU | 66 | HEBBANI-MEGHALAPURA | BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66 | 2:23 | 2:39 | 0:16 | LINE FAULT |
| 1660 | 23-May-2022 | MYSURU | 66 | HV2 | HULLAHALLI_66 | 12:04 | 13:18 | 1:13 | LINE CLEAR AVAILED |
| 1661 | 23-May-2022 | MYSURU | 66 | HV2 | HULLAHALLI_66 | 14:34 | 14:51 | 0:16 | LINE CLEAR AVAILED |
| 1662 | 23-May-2022 | MYSURU | 66 | KOLLEGALA-CR NAGARA | NO STATIONS EFFECTED | 12:12 | 12:20 | 0:08 | LINE FAULT |
| 1663 | 23-May-2022 | MYSURU | 66 | KOLLEGALA-SATHEGALA | NO STATIONS EFFECTED | 10:03 | 11:46 | 1:43 | NFBC ISSUED |
| 1664 | 23-May-2022 | MYSURU | 66 | HV2 | NAGAMANGALA_66 | 14:57 | 15:05 | 0:08 | TRANSFORMER FAULT |
| 1665 | 23-May-2022 | MYSURU | 66 | TUBINAKERE-G UKKADA | GARUDANAUKADDA_66 SRIRANGAPATNA_66 | 10:56 | 11:00 | 0:03 | LINE FAULT |
| 1666 | 23-May-2022 | MYSURU | 66 | VAJAMANGALA-BANNUR | NO STATIONS EFFECTED | 10:21 | 12:20 | 1:58 | NFBC ISSUED |
| 1667 | 23-May-2022 | MYSURU | 66 | HV1 | MADIKERI_66 | 11:33:09 (21/05/2022) | 18:34:22 | 55:01HRs | TRANSFORMER CHARGED |
| 1668 | 23-May-2022 | MYSURU | 66 | HEBBANI-TK HALLI | NO STATIONS EFFECTED | 12:03:00 (14.5.2022) | | | LINE OPEN,LINE FAULT |
| 1669 | 23-May-2022 | MYSURU | 66 | KHB STATION-BILIKERE | NO STATIONS EFFECTED | 10:57:05 (4/5/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1670 | 23-May-2022 | MYSURU | 66 | DUNDANAHALLY-HULIYURDURGA | NO STATIONS EFFECTED | 8:36:34 (30/04/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1671 | 23-May-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 6:26:00 PM (22/04/2022) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1672 | 23-May-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16:00 (08/12/2021) | | | LINE OPEN,LINE CLEAR AVAILED |
| 1673 | 23-May-2022 | TUMKUR | 400 | GUTTUR 400kV-Beeranahalli2 | GUTUR_400 | 19:34(23.05.2022 | 00:46(24.05.2022) | 1:12HRS | LINE CHARGED |
| 1674 | 23-May-2022 | TUMKUR | 220 | THALLAK 220kV- HIRIYUR 220KV | THALLAK_220 | 11:50 | 17:06 | 5:16 | HAND TRIPPED |
| 1675 | 23-May-2022 | TUMKUR | 66 | TR-3 (HV SIDE) | CHITRADURGA_220 | 1:52 | 2:11 | 0:19 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|---------------------------------|---|---------|-----------|----------|------------|
| 1676 | 23-May-2022 | TUMKUR | 66 | CHITRADURGA 220KV- TURUVANUR | MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66 | 6:05 | 6:20 | 0:15 | LINE FAULT |
| 1677 | 23-May-2022 | TUMKUR | 66 | DAVANGERE SRS- SOKKE | MELLEKATTE_66, SOKKE_66 | 4:48 | 11:45 | 6:57 | LINE FAULT |
| 1678 | 23-May-2022 | TUMKUR | 66 | DAVANGERE SRS- SOKKE | MELLEKATTE_66, SOKKE_66 | 5:21 | 5:52 | 0:31 | LINE FAULT |
| 1679 | 23-May-2022 | TUMKUR | 66 | HONNALLI 220KV- NYAMATHI | CHILLUR_66, NYAMATHI_66, SAVALANGA_66 | 9:30 | 9:45 | 0:15 | LINE FAULT |