

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM : 09.06.2020 TO 15.06.2020

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	9-Jun-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT 220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
2	9-Jun-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI 220	17:36 (18.05.2020)			LOAD CURTAILMENT
3	9-Jun-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI 220	17:39 (18.05.2020)			LOAD CURTAILMENT
4	9-Jun-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
5	9-Jun-2020	BAGALKOT	110	RATTIHALLI-HIREKERUR	NO STATION EFFECTED RATTIHALLI 110	16:34 (28.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
6	9-Jun-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR 110	18:26 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
7	9-Jun-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR 110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
8	9-Jun-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA 110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
9	9-Jun-2020	BAGALKOT	220	RAVIURJA2(KAKAMARI)-ATHANI	NO STATION EFFECTED ATHANI 220	17:49 (31.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
10	9-Jun-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL 110	18:43 (05.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
11	9-Jun-2020	BAGALKOT	110	DHARWADBIO- NAVALGUND	NO STATION EFFECTED NAVALGUND 110	17:11 (06.06.2020)	12:15 (09.06.2020)	67:04hrs	LINE CHARGED
12	9-Jun-2020	BAGALKOT	220	GUTTUR- RANEENNUR	NO STATION EFFECTED RANEENNUR 220	11:23 (06.06.2020)	8:52 (09.06.2020)	69:29hrs	LINE CHARGED
13	9-Jun-2020	BAGALKOT	220	BELGAUM-CHIKKODI 2	NO STATION EFFECTED BELGAUM 220	7:44 (08.06.2020)	14:43 (09.06.2020)	31:00hrs	LINE CHARGED
14	9-Jun-2020	BAGALKOT	220	ATHANI -RAVIURJA 1	ATHANI 220	18:56 (09.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
15	9-Jun-2020	BAGALKOT	110	110/11KV,HV1	ATHANI 220	18:51	19:24	0:33	TRANSFORMER FAULT
16	9-Jun-2020	BAGALKOT	110	ATHANI 220-SATTI	SATTI 110	18:51	19:50	0:59	LINE FAULT
17	9-Jun-2020	BAGALKOT	110	ATHANI 220-BALIGERI	BALIGERI 110	18:51	19:31	0:40	LINE FAULT
18	9-Jun-2020	BAGALKOT	110	ATHANI 220-AIGALI	AIGALI 110	18:51	19:36	0:45	LINE FAULT
19	9-Jun-2020	BAGALKOT	110	BAGALKOT220-KERUR	KERUR 110	5:50	6:01	0:11	LOAD CURTAILMENT
20	9-Jun-2020	BAGALKOT	110	BAGALKOT220-NEERBUDIHAL	NEERBUDIHAL 110	5:54	6:02	0:08	LOAD CURTAILMENT
21	9-Jun-2020	BAGALKOT	110	BANAHATTI-NAVALAGI	NAVALAGI 110	18:51	19:29	0:38	LINE FAULT
22	9-Jun-2020	BAGALKOT	110	110/33,HV2	NO STATION AFFECTED BELGAUM 110 (NEHRU NAGAR)	11:55	12:19	0:24	LINE CLEAR AVAILED
23	9-Jun-2020	BAGALKOT	220	BIDNAL-HUBLI 1	BIDNAL 220	9:10	13:29	4:19	NFBC ISSUED
24	9-Jun-2020	BAGALKOT	220	220/110KV,HV2 & LV2	NO STATION AFFECTED GADAG 220	11:07	16:15	5:08	LINE CLEAR AVAILED
25	9-Jun-2020	BAGALKOT	220	CHIKKODI-KUDACHI	NO STATION AFFECTED	16:53	20:51	3:58	LINE CLEAR AVAILED
26	9-Jun-2020	BAGALKOT	220	RANEENNUR-BALLIGAVI	NO STATION EFFECTED RANEENNUR 220	8:52	15:10	6:18	LOAD CURTAILMENT
27	9-Jun-2020	BAGALKOT	220	GUTTUR- RANEENNUR	NO STATION EFFECTED RANEENNUR 220	15:10 (09.06.2020.)			LOAD CURTAILMENT
28	9-Jun-2020	BAGALKOT	110	KUDACHI220- YELPARHATTI	YELPARHATTI 110	10:46	14:51	4:05	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
29	9-Jun-2020	BAGALKOT	110	110/11KV, HV1	YELPARHATTI_110	10:46	14:51	4:05	LINE CLEAR AVAILED
30	9-Jun-2020	BAGALKOT	110	110/11KV, HV2	YELPARHATTI_110	10:46	14:52	4:06	LINE CLEAR AVAILED
31	9-Jun-2020	BAGALKOT	110	220/110KV, LV1	VAJRAMATTI_220, MELLIGERI_110, BILAGI_110, VAJRAMATTI_110	18:56	19:00	0:04	LOAD CURTAILMENT
32	9-Jun-2020	BAGALKOT	110	VAJRAMATTI220- MELLIGERI	MELLIGERI_110	19:23	19:33	0:10	LOAD CURTAILMENT
33	9-Jun-2020	BAGALKOT	110	VAJRAMATTI220- VAJRAMATTI	VAJRAMATTI_110	19:24	19:33	0:09	LOAD CURTAILMENT
34	9-Jun-2020	BAGALKOT	220	HUBLI-BIDNAL1	HUBLI_220	9:08	13:27	4:19	LINE CLEAR AVAILED
35	9-Jun-2020	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	13:42	16:10	2:28	LINE CLEAR AVAILED
36	9-Jun-2020	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	13:44	16:14	2:30	LINE CLEAR AVAILED
37	9-Jun-2020	BAGALKOT	110	110/11KV, HV2	SHIROL_110	14:55	15:01	0:06	TRANSFORMER FAULT
38	9-Jun-2020	BAGALKOT	110	SATTI- RABAKAVI	RABAKAVI_110	20:02	20:25	0:23	LOAD CURTAILMENT
39	9-Jun-2020	BAGALKOT	220	NARENDRA-AMBEWADI1	AMBEWADI_220	15:39 (09.06.2020)			LINE OPEN, LINE FAULT
40	9-Jun-2020	BAGALKOT	110	RANNABELEGALI-MUDHOL(UTTUR)	UTTUR_110	17:07	17:36	0:29	LOAD CURTAILMENT
41	9-Jun-2020	BAGALKOT	110	110/11KV, HV1	NAVANAGAR(H)_110	13:01	15:09	2:08	LINE CLEAR AVAILED
42	9-Jun-2020	BAGALKOT	220	KUDUCHI-ATHANI	KUDUCHI_220	12:22	14:00	1:38	LINE CLEAR AVAILED
43	9-Jun-2020	BAGALKOT	220	KUDUCHI-ATHANI	KUDUCHI_220	19:02	19:16	0:14	MAIN SUPPLY FAILURE
44	9-Jun-2020	BAGALKOT	110	KUDUCHI-AINAPUR	AINAPUR_110	19:01	19:35	0:34	MAIN SUPPLY FAILURE
45	9-Jun-2020	BAGALKOT	110	KUDUCHI-YELPHARATTI	YELPHARATTI_110	19:01	19:30	0:29	MAIN SUPPLY FAILURE
46	9-Jun-2020	BAGALKOT	110	KUDUCHI-UGAR KHUD	UGAR KHUD_110	19:01	19:32	0:31	MAIN SUPPLY FAILURE
47	9-Jun-2020	BAGALKOT	110	KUDUCHI220-KUDUCHI	KUDUCHI_110	19:01	19:36	0:35	MAIN SUPPLY FAILURE
48	9-Jun-2020	BAGALKOT	110	KUDUCHI220-MORAB	MORAB_110	19:01	19:18	0:17	MAIN SUPPLY FAILURE
49	9-Jun-2020	BAGALKOT	110	KUDUCHI220-TERDAL	TERDAL_110	19:01	19:18	0:17	MAIN SUPPLY FAILURE
50	9-Jun-2020	BAGALKOT	220	MAHALINGAPUR-NARENDRA1&2	MAHALINGAPUR_220	17:14	20:52	3:38	LINE CLEAR AVAILED
51	9-Jun-2020	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI1&2,ATHANI,KUDUCHI	MAHALINGAPUR_220	18:54	19:21	0:27	MAIN SUPPLY FAILURE
52	9-Jun-2020	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	16:50	17:34	0:44	LOAD CURTAILMENT
53	9-Jun-2020	BAGALKOT	110	MAHALINGAPUR- ITNA,BANAHATTI,DAVALESHWAR	ITNAL_110,HDIKAL_110,BANAHATTI_110,DAVALESHWAR_110	18:54	19:10	0:16	LOAD CURTAILMENT
54	9-Jun-2020	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	18:54	19:46	0:52	LOAD CURTAILMENT
55	9-Jun-2020	BAGALKOT	110	110/11KV,HV1&2	MAHALINGAPUR_220	18:50	19:05	0:15	TRANSFORMER FAULT
56	9-Jun-2020	BAGALKOT	110	220/110KV,HV1,LV1	KARWAR_110	16:30	18:05	1:35	LINE CLEAR AVAILED
57	9-Jun-2020	BAGALKOT	110	110/11KV, HV1	KALADAGI_110	12:00	12:31	0:31	LINE CLEAR AVAILED
58	9-Jun-2020	BAGALKOT	110	HIDIKAL-ITNAL	NO STATION EFFECTED HIDIKAL_110	0:35 (09.06.2020)			LOAD CURTAILMENT
59	9-Jun-2020	BAGALKOT	110	INDI-LACHYAN-HIREBEVANUR	HIREBEVANUR_110	3:42	4:03	0:21	LINE FAULT
60	9-Jun-2020	BAGALKOT	110	INDI-LACHYAN-HIREBEVANUR	HIREBEVANUR_110	4:58	5:21	0:23	LINE FAULT
61	9-Jun-2020	BAGALKOT	110	INDI-LACHYAN-HIREBEVANUR	HIREBEVANUR_110	20:40	21:38	0:58	LINE FAULT
62	9-Jun-2020	BAGALKOT	220	DHONI-LINGAPUR1	DHONI_400	6:00	9:16	3:16	NFBC ISSUED
63	9-Jun-2020	BENGALURU	66	HV1	TUBUGERE	14:15	14:20	0:04	LINE CLEAR AVAILED
64	9-Jun-2020	BENGALURU	66	HV2	TEKAL	11:59	13:40	1:40	LINE CLEAR AVAILED
65	9-Jun-2020	BENGALURU	66	HV2	TEKAL	16:02	16:07	0:05	TRANSFORMER FAULT
66	9-Jun-2020	BENGALURU	66	HV1	NANGLI	12:16	13:15	0:58	LINE CLEAR AVAILED
67	9-Jun-2020	BENGALURU	66	HV2	NANGLI	13:00	13:44	0:44	LINE CLEAR AVAILED
68	9-Jun-2020	BENGALURU	66	HAROBEL - KODIHALLI	KODIHALLI, HUNESANAHALLI, BIJJAHALLI	18:30	18:40	0:10	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
69	9-Jun-2020	BENGALURU	66	HONNIGANAHALLI - HALAGURU	HALAGURU	10:12	15:46	5:34	LINE CLEAR AVAILED
70	9-Jun-2020	BENGALURU	66	HV1	HOSKOTE 66	15:14	15:24	0:10	LINE CLEAR AVAILED
71	9-Jun-2020	BENGALURU	66	HV2	HOSKOTE 66	13:19	13:38	0:18	LINE CLEAR AVAILED
72	9-Jun-2020	BENGALURU	66	HV3	HOSKOTE 66	8:29	8:50	0:20	TRANSFORMER FAULT
73	9-Jun-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	22:57	23:07	0:09	LINE FAULT
74	9-Jun-2020	BENGALURU	66	BAGHMANE WORLD TECH PARK - HOODY 2	BAGHMANE WORLD TECH PARK	8:15	8:30	0:15	LOAD CHANGE OVER
75	9-Jun-2020	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	16:25	16:35	0:09	LOAD CHANGE OVER
76	9-Jun-2020	BENGALURU	66	SOUTH CITY - BTM 4TH PHASE	SOUTH CITY	10:50	10:54	0:03	LOAD CHANGE OVER
77	9-Jun-2020	BENGALURU	66	HV2	REMCO	8:56	9:03	0:06	LINE CLEAR AVAILED
78	9-Jun-2020	BENGALURU	66	HV1	KADUBISANAHALLI	6:18	6:41	0:22	TRANSFORMER FAULT
79	9-Jun-2020	BENGALURU	66	HV1	BTM 4TH PHASE	11:04	11:09	0:04	LOAD CHANGE OVER
80	9-Jun-2020	BENGALURU	66	HV1	BTM 4TH PHASE	16:06	16:13	0:06	LOAD CHANGE OVER
81	9-Jun-2020	BENGALURU	66	HV2	BTM 4TH PHASE	11:04	11:09	0:04	LOAD CHANGE OVER
82	9-Jun-2020	BENGALURU	66	HV2	BTM 4TH PHASE	16:06	16:13	0:06	LOAD CHANGE OVER
83	9-Jun-2020	BENGALURU	66	HONNIGANAHALLI - HALAGUR	HALAGUR	10:12	15:46	5:34	LINE CLEAR AVAILED
84	9-Jun-2020	BENGALURU	66	HV1	KGF	19:50:14(06-06-2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
85	9-Jun-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
86	9-Jun-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
87	9-Jun-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
88	9-Jun-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN, LINE CLEAR AVAILED
89	9-Jun-2020	GULBARGA	220	ALIPUR-BTPS	BTPS_220	10:34	10:58	00:24	LINE CLEAR AVAILED
90	9-Jun-2020	GULBARGA	220	HV1	KUSTAGI_220	10:27	10:38	00:11	TRANSFORMER FAULT
91	9-Jun-2020	GULBARGA	220	HV1	KUSTAGI_220	10:53	11:10	00:17	TRANSFORMER FAULT
92	9-Jun-2020	GULBARGA	110	HV1	HANUMANAL_110	10:00	10:10	00:10	TRANSFORMER FAULT
93	9-Jun-2020	GULBARGA	110	HV2	HANUMANAL_110	10:25	10:30	00:05	TRANSFORMER FAULT
94	9-Jun-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	12:10	12:15	00:05	LINE FAULT
95	9-Jun-2020	GULBARGA	110	HV1	MADIYAL_110	12:55	13:20	00:25	LINE CLEAR AVAILED
96	9-Jun-2020	GULBARGA	110	HV2	MADIYAL_110	06:00	07:20	01:20	LINE CLEAR AVAILED
97	9-Jun-2020	GULBARGA	110	HV2	MADIYAL_110	11:40	12:20	00:40	LINE CLEAR AVAILED
98	9-Jun-2020	GULBARGA	110	HV2	MADIYAL_110	12:40	13:20	00:40	LINE CLEAR AVAILED
99	9-Jun-2020	GULBARGA	110	HV2	HATTI_110	20:41	20:48	00:07	TRANSFORMER FAULT
100	9-Jun-2020	GULBARGA	110	HV1	PDHALLI_110	17:45	17:55	00:10	TRANSFORMER FAULT
101	9-Jun-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	14:29 (01.06.2020)			LINE OPEN, LINE CLEAR AVAILED
102	9-Jun-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:30 (20.05.2020)	11:42	475:12hrs	LINE CHARGED
103	9-Jun-2020	HASSAN	66	HNPR2-HASS3	HNPR2	22:16(08.06.2020)	00:41	2:25hrs	LINE CHARGED
104	9-Jun-2020	HASSAN	400	UPCL-HASSAN1	UPCL	03:25	08:25	05:00	LINE CLEAR AVAILED
105	9-Jun-2020	HASSAN	220	HV1	MSEZ	12:59	13:29	00:30	LINE CLEAR AVAILED
106	9-Jun-2020	HASSAN	110	JOG110-AMBTR2	JOG110	10:36	12:27	01:51	LINE CLEAR AVAILED
107	9-Jun-2020	HASSAN	110	KADUR-NGNHL	KADUR	10:11	17:18	07:07	LINE CLEAR AVAILED
108	9-Jun-2020	HASSAN	110	HV2	KARAYA	09:37	17:38	08:01	LINE CLEAR AVAILED
109	9-Jun-2020	HASSAN	110	KEMAR-Manipal1	KEMAR	10:14	13:28	03:14	LINE CLEAR AVAILED
110	9-Jun-2020	HASSAN	110	HV2	BARANG	12:08	13:09	01:01	LINE CLEAR AVAILED
111	9-Jun-2020	HASSAN	110	MANIPAL-BRAMVR	MANIPAL	10:21	10:28	00:07	HAND TRIPPED
112	9-Jun-2020	HASSAN	110	MANIPAL-BRAMVR	MANIPAL	17:33	18:03	00:30	HAND TRIPPED
113	9-Jun-2020	HASSAN	110	MANIPAL-KEMAR1	MANIPAL	10:14	10:22	00:08	LINE CLEAR AVAILED
114	9-Jun-2020	HASSAN	110	MANIPAL-KEMAR1	MANIPAL	17:33	17:58	00:25	HAND TRIPPED
115	9-Jun-2020	HASSAN	110	MANIPAL-KEMAR1	MANIPAL	17:58	18:02	00:04	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
116	9-Jun-2020	HASSAN	110	MANIPAL-NITTUR	MANIPAL	10:29	10:39	00:10	HAND TRIPPED
117	9-Jun-2020	HASSAN	110	MOODAB-GURUPURA	MOODAB	09:16	16:33	07:17	LINE CLEAR AVAILED
118	9-Jun-2020	HASSAN	110	NITUR11-MANIPAL	NITUR11	10:07	18:05	07:58	MAIN SUPPLY FAILURE
119	9-Jun-2020	HASSAN	110	HV2	SAGARA	12:51	14:38	01:47	TRANSFORMER FAULT
120	9-Jun-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR	10:28	18:52	08:24	LINE CLEAR AVAILED
121	9-Jun-2020	HASSAN	66	ATTICHO-HNPURA	ATTICHO	11:55	13:29	01:34	NFBC ISSUED
122	9-Jun-2020	HASSAN	66	HV1	ATTICHO	11:39	13:29	01:50	NFBC ISSUED
123	9-Jun-2020	HASSAN	66	HV1	CHIKMA	10:32	19:37	09:05	LINE CLEAR AVAILED
124	9-Jun-2020	HASSAN	66	HV2	CHIKMA	10:32	18:41	08:09	LINE CLEAR AVAILED
125	9-Jun-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMA	10:32	18:47	08:15	LINE CLEAR AVAILED
126	9-Jun-2020	HASSAN	66	HIREMAN-CHIKAMANGALUR	HIREMAN	11:51	18:38	06:47	NFBC ISSUED
127	9-Jun-2020	HASSAN	66	MALALI-CRPATNA	MALALI	12:40	13:29	00:49	LINE CLEAR AVAILED
128	9-Jun-2020	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPA	13:36	13:54	00:18	LINE CLEAR AVAILED
129	9-Jun-2020	HASSAN	66	SAKALE-IPCL1	SAKALE	10:00	14:47	04:47	LINE CLEAR AVAILED
130	9-Jun-2020	HASSAN	66	SAKALE-IPCL2	SAKALE	10:00	15:06	05:06	LINE CLEAR AVAILED
131	9-Jun-2020	HASSAN	66	SHANTHI-UDYAPURA	SHANTHI	11:52	13:23	01:31	NFBC ISSUED
132	9-Jun-2020	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	17:35 (28.05.2020)	14:12 (09.06.2020)	284:37HRS	LINE CHARGED
133	9-Jun-2020	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	10:11	18:11	8:00	LINE CLEAR AVAILED
134	9-Jun-2020	MYSURU	66	CR NAGARA-BADANKUPPE-1	BADANAGUPPE_66	10:22	18:02	7:40	LINE CLEAR AVAILED
135	9-Jun-2020	MYSURU	66	CR NAGARA-BADANKUPPE-2	BADANAGUPPE_66	10:22	18:02	7:40	LINE CLEAR AVAILED
136	9-Jun-2020	MYSURU	66	CR NAGARA-HONNALLY	ATTIGULIPURA_66 HONNALLY_MYS_66	12:42	12:47	0:04	LINE FAULT
137	9-Jun-2020	MYSURU	66	HALAGUR-TK HALLI	HALAGUR_66	10:05	15:53	5:48	LINE CLEAR AVAILED
138	9-Jun-2020	MYSURU	66	HV2	HANNUR_66	13:26	13:28	0:01	HAND TRIPPED
139	9-Jun-2020	MYSURU	66	HARVEY-CR NAGARA	HARVEY_66	9:58	17:35	7:36	LINE CLEAR AVAILED
140	9-Jun-2020	MYSURU	66	HV1	HEBBAL_66	10:47	12:43	1:56	LINE CLEAR AVAILED
141	9-Jun-2020	MYSURU	66	HV2	HEBBAL_66	12:44	14:09	1:25	LINE CLEAR AVAILED
142	9-Jun-2020	MYSURU	66	HV1	HONNALLY_MYS_66	15:29	17:02	1:32	LINE CLEAR AVAILED
143	9-Jun-2020	MYSURU	66	HV2	HONNALLY_MYS_66	11:42	12:57	1:15	LINE CLEAR AVAILED
144	9-Jun-2020	MYSURU	220	KADAKOLA-BASTIPURA 2	NO STATIONS EFFECTED	9:43(9.6.20)			LINE OPEN ,LINE CLEAR AVAILED
145	9-Jun-2020	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	14:12	14:26	0:14	HAND TRIPPED
146	9-Jun-2020	MYSURU	66	KADAKOLA-NANJANGUDU 1	NANJANGUDU_66 THANDYA_66	9:35	12:30	2:54	LINE CLEAR AVAILED
147	9-Jun-2020	MYSURU	66	KADAKOLA-NANJANGUDU 2	NANJANGUDU_66 THANDYA_66	9:35	12:30	2:54	LINE CLEAR AVAILED
148	9-Jun-2020	MYSURU	66	HV1	KOLLEGALA_66	17:26	17:37	0:10	LINE CLEAR AVAILED
149	9-Jun-2020	MYSURU	66	HV2	KOLLEGALA_66	17:26	17:39	0:12	LINE CLEAR AVAILED
150	9-Jun-2020	MYSURU	66	HV2	KRPET_66	10:47	14:47	3:59	LINE CLEAR AVAILED
151	9-Jun-2020	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	19:03	19:12	0:09	LINE FAULT
152	9-Jun-2020	MYSURU	66	KUSHALNAGARA 220-RAMANTHAPURA1	ALUR SIDDAPUR_66 KANAGAL_66	12:27	12:44	0:17	HAND TRIPPED
153	9-Jun-2020	MYSURU	66	HV2	MADDUR_66	15:33	18:11	2:37	LINE CLEAR AVAILED
154	9-Jun-2020	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66.	5:19	5:23	0:04	LINE FAULT
155	9-Jun-2020	MYSURU	66	MADIKERI-SUNTIKOPPA	NO STATIONS EFFECTED	5:05	5:26	0:21	LINE FAULT
156	9-Jun-2020	MYSURU	66	HV1	MANDGERE_66	11:25	11:30	0:05	TRANSFORMER FAULT
157	9-Jun-2020	MYSURU	66	HV1	MANDGERE_66	13:00	13:05	0:05	TRANSFORMER FAULT
158	9-Jun-2020	MYSURU	66	SHANIVARSANTHE-MALLIPATNA	SANIVARASANTHE_66	10:08	14:15	4:07	NFBC ISSUED
159	9-Jun-2020	MYSURU	66	HV5	SFCSHIVA_66	10:16	15:06	4:50	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
160	9-Jun-2020	MYSURU	66	TUBINKERE-MC-2	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66 MANDYA_66	16:18	16:29	0:10	LINE FAULT
161	9-Jun-2020	MYSURU	66	TUBINKERE-MC-4	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66 MANDYA_66	16:18	16:29	0:10	LINE FAULT
162	9-Jun-2020	MYSURU	66	VIJAYANAGARA-HOOTAGALLY	NO STATIONS EFFECTED	9:35	12:18	2:42	NFBC ISSUED
163	9-Jun-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN, LINE FAULT
164	9-Jun-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
165	9-Jun-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
166	9-Jun-2020	TUMKUR	66	ANCHEPALYA 220kv- T G HALLI(HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	14:54	18:37	3:42	LINE CLEAR AVAILED
167	9-Jun-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66, BRAHMASANDRA_66, KALLAMBELLA_66	7:08	7:26	0:18	LINE FAULT
168	9-Jun-2020	TUMKUR	66	TR-1	CHALLAKERE_66	11:23	12:08	0:45	TRANSFORMER FAULT
169	9-Jun-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	8:01	8:04	0:02	TRANSFORMER FAULT
170	9-Jun-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	14:10	15:06	0:56	TRANSFORMER FAULT
171	9-Jun-2020	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	21:24	21:30	0:06	LINE FAULT
172	9-Jun-2020	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	14:08	14:17	0:08	HAND TRIPPED
173	9-Jun-2020	TUMKUR	66	TR-2	HONNUDIKE_66	10:17	11:17	1:00	LINE CLEAR AVAILED
174	9-Jun-2020	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	7:36	7:42	0:05	HAND TRIPPED
175	9-Jun-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	9:26	9:33	0:07	TRANSFORMER FAULT
176	9-Jun-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	10:12	10:22	0:09	TRANSFORMER FAULT
177	9-Jun-2020	TUMKUR	66	TR-2	NAYAKANAHATTI_66	6:27	13:55	7:28	LINE CLEAR AVAILED
178	9-Jun-2020	TUMKUR	66	TR-2	NAYAKANAHATTI_66	16:23	16:55	0:32	LINE CLEAR AVAILED
179	9-Jun-2020	TUMKUR	66	PULAMGHATTA66- MADHUGIRI 220kv 1	PULAMG_66	11:20	13:38	2:17	LINE CLEAR AVAILED
180	9-Jun-2020	TUMKUR	66	TR-1	RANGANATHAPURA_66	14:02	17:38	3:35	LINE CLEAR AVAILED
181	9-Jun-2020	TUMKUR	66	TR-2	SANIKERE_66	10:16	12:56	2:39	LINE CLEAR AVAILED
182	9-Jun-2020	TUMKUR	66	TR-2	THALLAKK_220	14:53	16:09	1:15	LINE CLEAR AVAILED
183	10-Jun-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
184	10-Jun-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
185	10-Jun-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
186	10-Jun-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
187	10-Jun-2020	BAGALKOT	110	RATTIHALLI-HIREKERUR	NO STATION EFFECTED RATTIHALLI_110	16:34 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
188	10-Jun-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
189	10-Jun-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
190	10-Jun-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
191	10-Jun-2020	BAGALKOT	220	RAVIURJA2(KAKAMARI)-ATHANI	NO STATION EFFECTED ATHANI_220	17:49 (31.05.2020)	16:07 (10.06.2020)	238:18hrs	LINE CHARGED
192	10-Jun-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL_110	18:43 (05.06.2020)	11:25 (10.06.2020)	112:44hrs	LINE CHARGED
193	10-Jun-2020	BAGALKOT	220	ATHANI -RAVIURJA 1	ATHANI_220	18:56 (09.06.2020)	16:07 (10.06.2020)	21:11hrs	LINE CHARGED
194	10-Jun-2020	BAGALKOT	220	GUTTUR- RANEENNUR	NO STATION EFFECTED RANEENNUR_220	15:10 (09.06.2020.)	8:20 (10.06.2020)	17:10hrs	LINE CHARGED
195	10-Jun-2020	BAGALKOT	220	NARENDRA-AMBEWADI1	NO STATION EFFECTED AMBEWADI_220	15:39 (09.06.2020)	15:35 (10.06.2020)	23:56hrs	LINE CHARGED
196	10-Jun-2020	BAGALKOT	110	HIDIKAL-ITNAL	NO STATION EFFECTED HIDIKAL_110	0:35 (09.06.2020)			LOAD CURTAILMENT
197	10-Jun-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, HALSANGI_33	21:13	21:19	0:06	TRANSFORMER FAULT
198	10-Jun-2020	BAGALKOT	110	SATTI- RABKAVI	RABKAVI_110	06:19	15:21	9:02	LINE CLEAR AVAILED
199	10-Jun-2020	BAGALKOT	220	BELLIGAVI(SHIROLKOPPA)-RANEENNUR	RANEENNUR_220	8:20 (10.06.2020)			LOAD CURTAILMENT
200	10-Jun-2020	BAGALKOT	110	RANEENNUR- HIREKERUR	HIREKERUR_110	17:37	17:51	0:14	LINE FAULT
201	10-Jun-2020	BAGALKOT	220	220/110KV, HV1&LV1	NARENDRA_220	11:34	14:10	2:36	LINE CLEAR AVAILED
202	10-Jun-2020	BAGALKOT	110	NARENDRA- KUD1	KUD DHARWAD_110	11:33	14:15	2:42	LINE CLEAR AVAILED
203	10-Jun-2020	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	15:31	16:50	1:19	LINE CLEAR AVAILED
204	10-Jun-2020	BAGALKOT	110	MAHALINGAPUR- RABKAVI	RABKAVI_110	14:52	15:02	0:10	HAND TRIPPED
205	10-Jun-2020	BAGALKOT	110	SHIRHATTI- LAXMESHVAR	LAXMESHVAR_110	10:05	17:28	7:23	LINE CLEAR AVAILED
206	10-Jun-2020	BAGALKOT	110	KUDUCHI220-AINAPUR	AINAPUR_110	15:25	17:14	1:49	LINE CLEAR AVAILED
207	10-Jun-2020	BAGALKOT	110	KUDUCHI220-AINAPUR	AINAPUR_110	7:55	8:10	0:15	LINE FAULT
208	10-Jun-2020	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110	6:31	6:45	0:14	LOAD CURTAILMENT
209	10-Jun-2020	BAGALKOT	110	110/11KV, HV2	HIDIKAL_110	20:38	20:43	0:05	TRANSFORMER FAULT
210	10-Jun-2020	BAGALKOT	110	GADAG ROAD-GOPPANAKOPPA	GOPPANAKOPPA_110	9:40	10:30	0:50	LINE CLEAR AVAILED
211	10-Jun-2020	BAGALKOT	110	110/33KV,HV1&2	GOPPANAKOPPA_110,KUSUGAL_3 3,KMC	9:50	10:30	0:40	LINE CLEAR AVAILED
212	10-Jun-2020	BAGALKOT	110	110/11KV, HV4	GOPPANAKOPPA_110	9:40	10:30	0:50	LINE CLEAR AVAILED
213	10-Jun-2020	BAGALKOT	110	GOPPANAKOPPA-NARGUNG	NARGUND_110	9:50	11:30	1:40	LINE CLEAR AVAILED
214	10-Jun-2020	BAGALKOT	110	110/11KV, HV3	GOPPANAKOPPA_110	9:52	10:30	0:38	LINE CLEAR AVAILED
215	10-Jun-2020	BAGALKOT	110	110/11KV, HV4,HV4	GOPPANAKOPPA_110	10:40	15:13	4:33	LINE CLEAR AVAILED
216	10-Jun-2020	BAGALKOT	220	220/110KV, HV2&LV2	GADAG_220	10:26	14:26	4:00	LINE CLEAR AVAILED
217	10-Jun-2020	BAGALKOT	110	GADAG-SHIRAHATTI	SHIRAHATTI_110	9:45	19:17	9:32	LINE CLEAR AVAILED
218	10-Jun-2020	BAGALKOT	220	CHIKKODI-KUDUCHI	CHIKKODI_220	6:55	14:54	7:59	LOAD CURTAILMENT
219	10-Jun-2020	BAGALKOT	110	110/11KV, HV4	GAJENDRAGAD_1100	6:45	6:55	0:10	LOAD CURTAILMENT
220	10-Jun-2020	BAGALKOT	110	BAGALKOT-RAMDURGA	RAMDURGA_110	19:04	19:20	0:16	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
221	10-Jun-2020	BAGALKOT	110	BAGALKOT-KALADAGI	KALADAGI_110	8:30	9:05	0:35	LOAD CURTAILMENT
222	10-Jun-2020	BAGALKOT	110	110/33KV, HV2	ANKOLA_110	19:51	20:07	0:16	TRANSFORMER FAULT
223	10-Jun-2020	BAGALKOT	110	110/33KV, HV2	ANKOLA_110,MASTKAKKA_33,SEA BIRD_33	20:15	20:28	0:13	TRANSFORMER FAULT
224	10-Jun-2020	BAGALKOT	110	110/11KV, HV1	ANKALAGI_110	13:45	14:30	0:45	LINE CLEAR AVAILED
225	10-Jun-2020	BAGALKOT	110	110/11KV, HV1	AINAPUR_110	14:20	14:55	0:35	LINE CLEAR AVAILED
226	10-Jun-2020	BAGALKOT	110	110/11KV, HV2	AINAPUR_110	6:30	6:40	0:10	LOAD CURTAILMENT
227	10-Jun-2020	BAGALKOT	220	NARENDRA-AMBEWADI2	NO STATION EFFECTED AMBEWADI_220	11:33	15:37	4:04	LINE CLEAR AVAILED
228	10-Jun-2020	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	KAVALWADA_110	10:24	12:56	2:32	LINE CLEAR AVAILED
229	10-Jun-2020	BENGALURU	66	HV1	VIJAYPURA	9:07	9:20	0:12	LINE CLEAR AVAILED
230	10-Jun-2020	BENGALURU	66	HV1	MITTEMARI 220	14:05	14:46	0:41	LINE CLEAR AVAILED
231	10-Jun-2020	BENGALURU	220	HV1	MITTEMARI 220	11:19	13:40	2:21	LINE CLEAR AVAILED
232	10-Jun-2020	BENGALURU	66	HV2	SARJAPURA 220	15:23	15:33	0:09	TRANSFORMER FAULT
233	10-Jun-2020	BENGALURU	220	HV2	DB PURA 220	10:06	10:44	0:38	TRANSFORMER FAULT
234	10-Jun-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	13:16	13:20	0:04	LINE CLEAR AVAILED
235	10-Jun-2020	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	13:16	13:20	0:04	LINE CLEAR AVAILED
236	10-Jun-2020	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	10:06	10:44	0:38	MAIN SUPPLY FAILURE
237	10-Jun-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	10:06	10:47	0:41	MAIN SUPPLY FAILURE
238	10-Jun-2020	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	10:06	10:47	0:41	MAIN SUPPLY FAILURE
239	10-Jun-2020	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	13:16	13:20	0:04	LINE CLEAR AVAILED
240	10-Jun-2020	BENGALURU	66	HV2	YELLARBANDE	9:58	10:05	0:07	LINE CLEAR AVAILED
241	10-Jun-2020	BENGALURU	66	HV2	YELLARBANDE	12:35	12:38	0:03	LINE CLEAR AVAILED
242	10-Jun-2020	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	16:52	17:20	0:28	LINE FAULT
243	10-Jun-2020	BENGALURU	220	HAL 220 - HOODY 1	HAL 220	14:51	15:20	0:29	LINE FAULT
244	10-Jun-2020	BENGALURU	220	HAL 220 - HOODY 2	HAL 220	14:51	15:21	0:30	LINE FAULT
245	10-Jun-2020	BENGALURU	220	HAL 220 - EDC 220	EDC 220	14:51	15:24	0:33	LINE FAULT
246	10-Jun-2020	BENGALURU	66	HAL 220 - HAL (EHT)	HAL (EHT)	14:51	15:20	0:29	MAIN SUPPLY FAILURE
247	10-Jun-2020	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK (EHT)	14:51	15:20	0:29	MAIN SUPPLY FAILURE
248	10-Jun-2020	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	14:51	15:20	0:29	MAIN SUPPLY FAILURE
249	10-Jun-2020	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARIYOTHI	14:51	15:20	0:29	MAIN SUPPLY FAILURE
250	10-Jun-2020	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	14:51	15:20	0:29	MAIN SUPPLY FAILURE
251	10-Jun-2020	BENGALURU	220	HV1	EDC 220	14:58	15:00	0:02	MAIN SUPPLY FAILURE
252	10-Jun-2020	BENGALURU	66	HV1	EDC 220	15:19	15:26	0:06	MAIN SUPPLY FAILURE
253	10-Jun-2020	BENGALURU	220	HV2	EDC 220	14:58	15:00	0:02	MAIN SUPPLY FAILURE
254	10-Jun-2020	BENGALURU	66	HV2	EDC 220	15:20	15:22	0:02	MAIN SUPPLY FAILURE
255	10-Jun-2020	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	14:51	15:24	0:33	MAIN SUPPLY FAILURE
256	10-Jun-2020	BENGALURU	66	EDC 220 - BMTC	BMTC	14:51	15:31	0:40	MAIN SUPPLY FAILURE
257	10-Jun-2020	BENGALURU	66	EDC 220 - B STATION	B STATION	14:51	15:23	0:32	MAIN SUPPLY FAILURE
258	10-Jun-2020	BENGALURU	220	EDC 220 - HAL 220	EDC 220	14:51	15:15	0:24	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
259	10-Jun-2020	BENGALURU	66	HV1	BANASHANKARI	9:20	9:22	0:24	LINE CLEAR AVAILED
260	10-Jun-2020	BENGALURU	220	EDC 220 - A STATION 220	A STATION 220	14:55(10.06.2020)			LINE OPEN, LINE FAULT
261	10-Jun-2020	BENGALURU	66	HV1	KGF	19:50(06-06-2020)	18:05(10-6-2020)	118:10hrs	LINE CLEAR AVAILED
262	10-Jun-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
263	10-Jun-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
264	10-Jun-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
265	10-Jun-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN, LINE CLEAR AVAILED
266	10-Jun-2020	GULBARGA	220	ALIPUR- GOOTY	ALIPUR_220	03:07	09:54	06:47	LINE FAULT
267	10-Jun-2020	GULBARGA	220	SEDAM-ORIENTCEMENTS_IPP	SEDAM_220	14:41	15:10	00:29	LINE FAULT
268	10-Jun-2020	GULBARGA	110	HV2	ALAND_110	06:35	06:55	00:20	LOAD CURTAILMENT
269	10-Jun-2020	GULBARGA	110	HV1	CHINCHOLI_110	06:30	06:40	00:10	LOAD CURTAILMENT
270	10-Jun-2020	GULBARGA	110	HV2	HATTI_110	15:05	15:10	00:05	TRANSFORMER FAULT
271	10-Jun-2020	GULBARGA	110	HV2	JEWARGI_110	06:35	06:40	00:05	LOAD CURTAILMENT
272	10-Jun-2020	GULBARGA	110	HV1	KEMBHAVI_110	06:30	06:35	00:05	LOAD CURTAILMENT
273	10-Jun-2020	GULBARGA	110	HV1	MAHAGOAN_110	06:30	06:55	00:25	LOAD CURTAILMENT
274	10-Jun-2020	GULBARGA	110	HV1	PDHALLI_110	06:30	06:35	00:05	LOAD CURTAILMENT
275	10-Jun-2020	GULBARGA	110	HV1	TEKKALKOTE_110	06:30	06:45	00:15	LOAD CURTAILMENT
276	10-Jun-2020	GULBARGA	110	HV2	TEKKALKOTE_110	10:50	11:00	00:10	TRANSFORMER FAULT
277	10-Jun-2020	GULBARGA	110	HV2	TEKKALKOTE_110	11:10	11:15	00:05	TRANSFORMER FAULT
278	10-Jun-2020	GULBARGA	110	HV2	TEKKALKOTE_110	11:20	11:25	00:05	TRANSFORMER FAULT
279	10-Jun-2020	GULBARGA	110	SIDHANOOR220-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB, BTPS WATERWORKS	19:10	19:30	00:20	LINE FAULT
280	10-Jun-2020	GULBARGA	110	SIDHANOOR220-TURVIHAL	TURVIHAL_110	20:50	21:15	00:25	LINE FAULT
281	10-Jun-2020	GULBARGA	110	SIDHANOOR220-RAICHUR2	MANVI_110,MADLAPUR_110,KUR DICROSS_110	23:40	23:50	00:10	LINE FAULT
282	10-Jun-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	23:16	23:21	00:05	LINE FAULT
283	10-Jun-2020	GULBARGA	110	KAPANOOR-HUMNABAD1,2	MAHAGAON_110,MARAGUTTI_11 0,ALAND_110	12:30	12:42	00:12	HAND TRIPPED
284	10-Jun-2020	GULBARGA	110	KAPANOOR-HUMNABAD2	ALAND_110	21:08	21:15	00:07	LINE FAULT
285	10-Jun-2020	GULBARGA	110	KAPANOOR-GULBARGAWEST_110	GULBARGAWEST_110,GULBARGAS OUTH_110	21:25	23:17	01:52	LINE FAULT
286	10-Jun-2020	GULBARGA	110	HV1	KAPANOOR_220	21:25	23:17	01:52	TRANSFORMER FAULT
287	10-Jun-2020	GULBARGA	110	KAPANOOR-HUMNABAD1	MAHAGOAN_110,MARAGUTTI_11 0	12:30			LINE OPEN, LINE FAULT
288	10-Jun-2020	GULBARGA	110	YELBURGA-PRPJSRLR	YELBURGA_110	23:07			LINE OPEN, LINE FAULT
289	10-Jun-2020	GULBARGA	110	GULBARGA UNIVERSITY-GULBARGA NORTH	GULBARGAUNIVERSITY_110	21:30	21:35	00:05	MAIN SUPPLY FAILURE
290	10-Jun-2020	GULBARGA	66	HV2	TAMBRAHALLI_66	06:30	06:45	00:15	LINE CLEAR AVAILED
291	10-Jun-2020	GULBARGA	66	HV2	TAMBRAHALLI_66	11:20	12:40	01:20	LINE CLEAR AVAILED
292	10-Jun-2020	GULBARGA	66	TBHALLI-ITTAGGI	TAMBRAHALLI_66	11:40	11:50	00:10	MAIN SUPPLY FAILURE
293	10-Jun-2020	GULBARGA	66	HV1	SOVENAHALLI_66	13:10	13:20	00:10	TRANSFORMER FAULT
294	10-Jun-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	14:29 (01.06.2020)			LINE OPEN, LINE CLEAR AVAILED
295	10-Jun-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	9:33(10.06.2020)			LINE OPEN, LINE CLEAR AVAILED
296	10-Jun-2020	HASSAN	220	UPCL-KEMAR2	upcl_gen	04:11	05:01	00:50	LINE FAULT
297	10-Jun-2020	HASSAN	220	CRPATNA-HUYGNH	CRPATNA_220	10:34	13:00	02:26	NFBC ISSUED
298	10-Jun-2020	HASSAN	220	CRPATNA-HUYGNH	CRPATNA_220	10:34	13:00	02:26	NFBC ISSUED
299	10-Jun-2020	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	13:28	16:35	03:07	LINE FAULT
300	10-Jun-2020	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	10:59	18:20	07:21	NFBC ISSUED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
301	10-Jun-2020	HASSAN	220	MRSSH-HASSAN	MRSMSG_220	13:28	16:35	03:07	LINE FAULT
302	10-Jun-2020	HASSAN	220	HV1	MSEZ_220	10:32	12:57	02:25	LINE CLEAR AVOIDED
303	10-Jun-2020	HASSAN	110	LV1	MSEZ_220	10:32	12:57	02:25	LINE CLEAR AVOIDED
304	10-Jun-2020	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	13:11	13:27	00:16	LINE FAULT
305	10-Jun-2020	HASSAN	110	HV1	HALADY_110	10:52	11:37	00:45	LINE CLEAR AVOIDED
306	10-Jun-2020	HASSAN	110	HV2	HALADY_110	10:52	11:37	00:45	LINE CLEAR AVOIDED
307	10-Jun-2020	HASSAN	110	HV1	ESSUR_110	12:00	13:02	01:02	LINE CLEAR AVOIDED
308	10-Jun-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	13:11	13:26	00:15	LINE FAULT
309	10-Jun-2020	HASSAN	110	HV2	MOODABIDRE_110	14:33	14:52	00:19	MAIN SUPPLY FAILURE
310	10-Jun-2020	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	04:44	05:03	00:19	MAIN SUPPLY FAILURE
311	10-Jun-2020	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:33	14:52	00:19	LINE FAULT
312	10-Jun-2020	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	04:44	05:03	00:19	MAIN SUPPLY FAILURE
313	10-Jun-2020	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	14:33	14:52	00:19	LINE FAULT
314	10-Jun-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	10:11	13:06	02:55	LINE CLEAR AVOIDED
315	10-Jun-2020	HASSAN	66	HV1	HNPURA_66	03:30	03:34	00:04	TRANSFORMER FAULT
316	10-Jun-2020	HASSAN	66	HV2	HOLEHONNUR_66	10:13	18:10	07:57	LINE CLEAR AVOIDED
317	10-Jun-2020	HASSAN	66	HV1	CHANNARAYAPATNA_66	16:03	16:14	00:11	LINE CLEAR AVOIDED
318	10-Jun-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	05:51	05:55	00:04	TRANSFORMER FAULT
319	10-Jun-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	09:33	09:45	00:12	TRANSFORMER FAULT
320	10-Jun-2020	MYSURU	220	KADAKOLA-BASTIPURA 2	NO STATIONS EFFECTED	9:43(9.6.2020)			LINE OPEN ,LINE CLEAR AVOIDED
321	10-Jun-2020	MYSURU	66	HV1	JAKKANAHALLY_66	10:31	12:53	2:21	LINE CLEAR AVOIDED
322	10-Jun-2020	MYSURU	66	HV1	K_HONNALGERE_66	16:53	17:23	0:29	MAIN SUPPLY FAILURE
323	10-Jun-2020	MYSURU	66	HV2	K_HONNALGERE_66	16:53	17:23	0:29	MAIN SUPPLY FAILURE
324	10-Jun-2020	MYSURU	66	HV1	KIADBMANDYA_66	10:18	11:00	0:41	LINE CLEAR AVOIDED
325	10-Jun-2020	MYSURU	66	HV1	NANJANGUDU_66	16:02	16:13	0:10	TRANSFORMER FAULT
326	10-Jun-2020	MYSURU	66	HV1	PANDAVAPURA_66	18:12	20:12	1:59	TRANSFORMER FAULT
327	10-Jun-2020	MYSURU	66	HV2	PANDAVAPURA_66	14:40	15:15	0:35	LINE CLEAR AVOIDED
328	10-Jun-2020	MYSURU	66	HV2	SUTTUR_66	14:25	15:46	1:21	LINE CLEAR AVOIDED
329	10-Jun-2020	MYSURU	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	3:18	3:30	0:12	LINE FAULT
330	10-Jun-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
331	10-Jun-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
332	10-Jun-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:27(26.05.20)			LINE OPEN, LINE FAULT
333	10-Jun-2020	TUMKUR	66	HARIHARA-DAVANGERE SRS	HARIHAR_66	10:35	17:36	7:01	LINE CLEAR AVOIDED
334	10-Jun-2020	TUMKUR	66	TR-1	HARIHAR_66	10:35	17:37	7:02	LINE CLEAR AVOIDED
335	10-Jun-2020	TUMKUR	66	TR-2	HARIHAR_66	10:35	17:39	7:04	LINE CLEAR AVOIDED
336	10-Jun-2020	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	14:20	14:39	0:19	HAND TRIPPED
337	10-Jun-2020	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	14:20	14:39	0:19	HAND TRIPPED
338	10-Jun-2020	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	16:47	17:48	1:01	LINE CLEAR AVOIDED
339	10-Jun-2020	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	17:57	18:29	0:31	LINE FAULT
340	10-Jun-2020	TUMKUR	66	TR-1	KORATAGERE_66	21:14	21:32	0:17	TRANSFORMER FAULT
341	10-Jun-2020	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 1	HOLAVINAHALLY_66	15:51	16:13	0:21	HAND TRIPPED
342	10-Jun-2020	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	5:40	5:50	0:10	LINE FAULT
343	10-Jun-2020	TUMKUR	66	PAVAGADA66-MADHUGIRI 1	PAVAGADA_66	5:40	5:49	0:09	LINE FAULT
344	10-Jun-2020	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	RANGANATHAPURA_66	18:34	19:32	0:57	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
345	10-Jun-2020	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	RANGANATHAPURA_66	18:34	19:31	0:57	LINE FAULT
346	10-Jun-2020	TUMKUR	66	TR-1	SHYLAPURA_66	14:59	15:08	0:09	TRANSFORMER FAULT
347	10-Jun-2020	TUMKUR	66	SIRA- BUKKAPATNA	SIRA_66	11:38	11:49	0:11	LINE FAULT
348	11-Jun-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
349	11-Jun-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
350	11-Jun-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
351	11-Jun-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
352	11-Jun-2020	BAGALKOT	110	RATTIHALLI-HIREKERUR	NO STATION EFFECTED RATTIHALLI_110	16:34 (28.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
353	11-Jun-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
354	11-Jun-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
355	11-Jun-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
356	11-Jun-2020	BAGALKOT	110	HIDIKAL-ITNAL	NO STATION EFFECTED HIDIKAL_110	0:35 (09.06.2020)			MAIN SUPPLY FAILURE
357	11-Jun-2020	BAGALKOT	220	BELLIGAVI(SHIROLKOPPA)-RANEENNUR	RANEENNUR_220	8:20 (10.06.2020)			LOAD CURTAILMENT
358	11-Jun-2020	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	12:25	12:30	0:05	TRANSFORMER FAULT
359	11-Jun-2020	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	23:58 (11.06.2020)			LINE CLEAR AVAILED
360	11-Jun-2020	BAGALKOT	110	PG HUNSHYAL- MUDALGI (NAGNUR)	NAGNUR_110, MUDALGI_110	08:30	8:46	0:16	LINE FAULT
361	11-Jun-2020	BAGALKOT	110	110/11KV, HV2	HUNGUND_110,KARADI_33,AMIN AGAD_33,MYTRA SOLAR_330	0:56	1:02	0:06	TRANSFORMER FAULT
362	11-Jun-2020	BAGALKOT	110	SIRSI-KUMTA1	SIRSI_110	12:54	13:26	0:32	LINE FAULT
363	11-Jun-2020	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	12:54 (11.06.2020)			LINE OPEN, LINE FAULT
364	11-Jun-2020	BAGALKOT	110	110/11KV, HV1	SIRSI_110	10:10	14:57	4:47	TRANSFORMER FAULT
365	11-Jun-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	08:07 (11.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
366	11-Jun-2020	BAGALKOT	110	DKSSCOGEN-CHIKKODI	CHIKKODI_220	13:03	14:18	1:15	LINE CLEAR AVAILED
367	11-Jun-2020	BAGALKOT	110	HAVERI220-BYADAGI	NO STATION EFFECTED BYADAGI_110	14:02 (11.02.2020)			LINE OPEN, LINE FAULT
368	11-Jun-2020	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	3:20	3:31	0:11	LINE FAULT
369	11-Jun-2020	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	KAVAKVADA_110	10:50	14:32	3:42	LINE CLEAR AVAILED
370	11-Jun-2020	BAGALKOT	110	AMBEWADI-PONDA1	AMBEWADI_220	13:54	15:27	1:33	LINE CLEAR AVAILED
371	11-Jun-2020	BAGALKOT	110	SUZLON-BYADAGI	BYADAGI_110	14:52	15:04	0:12	HAND TRIPPED
372	11-Jun-2020	BAGALKOT	110	ADANI SOLAR-BYADADI	BYADAGI_110	14:52	15:04	0:12	HAND TRIPPED
373	11-Jun-2020	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,MASTIKATTA_33,SEA BIRD_33	9:56	10:03	0:07	TRANSFORMER FAULT
374	11-Jun-2020	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,MASTIKATTA_33,SEA BIRD_33	18:17	18:36	0:19	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
375	11-Jun-2020	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,MASTIKATTA_33,SEA BIRD_33	18:47	19:08	0:21	TRANSFORMER FAULT
376	11-Jun-2020	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,MASTIKATTA_33,SEA BIRD_33	19:16	19:22	0:06	TRANSFORMER FAULT
377	11-Jun-2020	BENGALURU	400	NELMANGALA 400 - HIRIYUR 400	NO STATION AFFECTED	2:02	7:01	4:59	LINE FAULT
378	11-Jun-2020	BENGALURU	66	HV1	VIJAYPURA	11:09	11:23	0:14	LINE CLEAR AVOIDED
379	11-Jun-2020	BENGALURU	66	HV1	VIJAYPURA	16:59	18:55	1:56	LINE CLEAR AVOIDED
380	11-Jun-2020	BENGALURU	66	HV2	SARJAPURA	3:18	3:24	0:06	TRANSFORMER FAULT
381	11-Jun-2020	BENGALURU	66	HV1	RANGANDODDI	12:05	14:22	2:16	LINE CLEAR AVOIDED
382	11-Jun-2020	BENGALURU	66	HV2	NANGLI	10:30	10:37	0:07	TRANSFORMER FAULT
383	11-Jun-2020	BENGALURU	66	HV2	JIGANI	17:18	17:39	0:20	LINE CLEAR AVOIDED
384	11-Jun-2020	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	10:04	15:02	4:57	LINE CLEAR AVOIDED
385	11-Jun-2020	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE, SOMENAHALLI	12:05	13:28	1:23	LINE CLEAR AVOIDED
386	11-Jun-2020	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI, ID HALLI	12:05	13:28	1:23	LINE CLEAR AVOIDED
387	11-Jun-2020	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA, NITRALLI	12:05	15:22	3:17	LINE CLEAR AVOIDED
388	11-Jun-2020	BENGALURU	220	HV3	GOWRIBIDANUR 220	12:05	13:24	1:19	LINE CLEAR AVOIDED
389	11-Jun-2020	BENGALURU	66	PERESANDRA - GOWRIBIDANUR 220	PERESANDRA, MANDIKALLU, SOMENAHALLI	14:10	14:40	0:30	LOAD CHANGE OVER
390	11-Jun-2020	BENGALURU	66	SANKALGERE - KANAKAPURA 220	SANKALGERE	10:05	16:00	5:55	LINE CLEAR AVOIDED
391	11-Jun-2020	BENGALURU	66	SANKALGERE - KANAKAPURA 220	SANKALGERE	16:35	17:04	0:29	LINE CLEAR AVOIDED
392	11-Jun-2020	BENGALURU	66	JAKKASANDRA - ADUGODI	ADUGODI	6:03	6:23	0:20	LINE FAULT
393	11-Jun-2020	BENGALURU	66	HV1	BANASWADI	11:41	11:45	0:04	LINE CLEAR AVOIDED
394	11-Jun-2020	BENGALURU	66	HV2	DEVARBISANAHALLI	20:48	21:02	0:14	TRANSFORMER FAULT
395	11-Jun-2020	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	19:47	19:53	0:06	TRANSFORMER FAULT
396	11-Jun-2020	BENGALURU	66	HV2	HANUMANTHNAGAR	11:58	12:42	0:44	LINE CLEAR AVOIDED
397	11-Jun-2020	BENGALURU	66	HV3	A STATION 66	10:27	10:44	0:16	TRANSFORMER FAULT
398	11-Jun-2020	BENGALURU	66	HV1	SOUTH CITY	21:09	21:18	0:08	TRANSFORMER FAULT
399	11-Jun-2020	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	9:56	10:02	0:05	LOAD CHANGE OVER
400	11-Jun-2020	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	17:53	17:58	0:05	LOAD CHANGE OVER
401	11-Jun-2020	BENGALURU	220	EDC 220 - A STATION 220	A STATION 220	14:55(10.06.2020)			LINE OPEN, LINE FAULT
402	11-Jun-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
403	11-Jun-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
404	11-Jun-2020	BENGALURU	400	NELMANGALA 400 - HIRIYUR 400	NO STATION AFFECTED	19:58(11-06-2020)			LINE OPEN, LINE FAULT
405	11-Jun-2020	BENGALURU	66	HV1	SARJAPURA	19:21(11-06-2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
406	11-Jun-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
407	11-Jun-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN, LINE CLEAR AVOIDED
408	11-Jun-2020	GULBARGA	110	YELBURGA-PRPJS LR	YELBURGA_110	23:07(10.6.2020)	12:15 (11.6.20)	1:08 hrs	LINE CHARGED
409	11-Jun-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADLAPUR_110,KUR DICROSS_110	04:30	04:40	00:10	LINE FAULT
410	11-Jun-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITGUPPA_110	12:54	13:00	00:06	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
411	11-Jun-2020	GULBARGA	110	KAPANOOR-HUMNABAD1	MAHAGOAN_110,MARAGUTTI_110	12:30(10.06.2020)	13:40 (11.6.20)	25:10hrs	LINE CHARGED
412	11-Jun-2020	GULBARGA	110	CHITAGUPPA-HUMNABAD	CHITAGUPPA_110	11:10	11:15	00:05	LINE FAULT
413	11-Jun-2020	GULBARGA	110	CHITAGUPPA-HUMNABAD	CHITAGUPPA_110	13:00	13:05	00:05	MAIN SUPPLY FAILURE
414	11-Jun-2020	GULBARGA	110	HV4	KUSTAGI_220	03:30	03:35	00:05	TRANSFORMER FAULT
415	11-Jun-2020	GULBARGA	110	HV4	KUSTAGI_220	07:45	07:55	00:10	TRANSFORMER FAULT
416	11-Jun-2020	GULBARGA	110	HV1	MASKI_110	9:30(10.6.2020)	15:14 (11.6.20)	17:44hrs	LINE CLEAR AVAILED
417	11-Jun-2020	GULBARGA	66	ITTAGI-SUZLON1_IPP	ITTAGI_220	08:40	08:49	00:09	LINE FAULT
418	11-Jun-2020	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINAHADAGALI_66,HOLAGUNDI_66	10:15(11.6.2020)			LINE OPEN ,LINE CLEAR AVAILED
419	11-Jun-2020	GULBARGA	66	ITTAGI-KUDLIGI1	KOGALI_66,KUDLIGI_66,HANASI_66	11:55	12:05	00:10	LINE FAULT
420	11-Jun-2020	GULBARGA	66	ITTAGI-KUDLIGI2	CJHALLI_66,GUDEKOTE_66,HOSAHALLI_66,BANVEKAL_66,CHORNOOR_66	11:55	12:05	00:10	LINE FAULT
421	11-Jun-2020	GULBARGA	66	CHORNOOR-KUDLIGI	CHORNOOR_66	12:10	12:35	00:25	MAIN SUPPLY FAILURE
422	11-Jun-2020	GULBARGA	66	BANAVEKAL-KUDLIGI	BANVEKAL_66	12:10	12:12	00:02	MAIN SUPPLY FAILURE
423	11-Jun-2020	GULBARGA	66	ITTAGI-HOSAHALLI	HOSAHALLI_66	06:01	06:04	00:03	MAIN SUPPLY FAILURE
424	11-Jun-2020	GULBARGA	66	HV1	HANASI_66	15:40	15:50	00:10	TRANSFORMER FAULT
425	11-Jun-2020	GULBARGA	66	HV1	HANASI_66	15:55	16:00	00:05	TRANSFORMER FAULT
426	11-Jun-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	14:29 (1.06.2020)	7:48 (11.6.20)	233:18 hrs	LINE CHARGED
427	11-Jun-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	9:33 (10.06.2020)	11:33 (11.6.20)	25:59 hrs	LINE CHARGED
428	11-Jun-2020	HASSAN	400	HASSAN4-UPCL1	SHANTHIGRAMA_400	2:02 (11.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
429	11-Jun-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:41 (11.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
430	11-Jun-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	2:02 (11.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
431	11-Jun-2020	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	10:16	11:19	01:03	NFBC ISSUED
432	11-Jun-2020	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	01:35	07:13	05:38	LINE CLEAR AVAILED
433	11-Jun-2020	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	17:18	17:45	00:27	LINE FAULT
434	11-Jun-2020	HASSAN	220	HV2	KEMAR_220	11:21	11:56	00:35	LINE CLEAR AVAILED
435	11-Jun-2020	HASSAN	110	LV2	KEMAR_220	11:21	11:56	00:35	LINE CLEAR AVAILED
436	11-Jun-2020	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	01:27	07:11	05:44	LINE CLEAR AVAILED
437	11-Jun-2020	HASSAN	220	KEMAR-Kavoor3	KEMAR_220	10:16	11:19	01:03	LINE CLEAR AVAILED
438	11-Jun-2020	HASSAN	220	KEMAR-UPCL2	KEMAR_220	04:11	05:01	00:50	LINE FAULT
439	11-Jun-2020	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	01:35	07:13	05:38	LINE CLEAR AVAILED
440	11-Jun-2020	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	01:27	07:11	05:44	LINE CLEAR AVAILED
441	11-Jun-2020	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	04:44	08:40	03:56	LINE FAULT
442	11-Jun-2020	HASSAN	220	HV1	SHIRALKOPPA_220	10:47	11:59	01:12	MAIN SUPPLY FAILURE
443	11-Jun-2020	HASSAN	220	HV2	SHIRALKOPPA_220	12:02	12:34	00:32	MAIN SUPPLY FAILURE
444	11-Jun-2020	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	10:47	11:58	01:11	LINE CLEAR AVAILED
445	11-Jun-2020	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	12:02	12:33	00:31	HAND TRIPPED
446	11-Jun-2020	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	10:47	11:59	01:12	MAIN SUPPLY FAILURE
447	11-Jun-2020	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	12:02	12:34	00:32	MAIN SUPPLY FAILURE
448	11-Jun-2020	HASSAN	110	HV1	SHIRALKOPPA_220	10:47	11:59	01:12	MAIN SUPPLY FAILURE
449	11-Jun-2020	HASSAN	110	HV1	SHIRALKOPPA_220	12:02	12:34	00:32	MAIN SUPPLY FAILURE
450	11-Jun-2020	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	10:47	11:58	01:11	MAIN SUPPLY FAILURE
451	11-Jun-2020	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	12:02	12:34	00:32	MAIN SUPPLY FAILURE
452	11-Jun-2020	HASSAN	110	LV1	SHIRALKOPPA_220	10:47	11:59	01:12	MAIN SUPPLY FAILURE
453	11-Jun-2020	HASSAN	110	LV2	SHIRALKOPPA_220	12:02	12:34	00:32	MAIN SUPPLY FAILURE
454	11-Jun-2020	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	10:47	11:59	01:12	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
455	11-Jun-2020	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:02	12:34	00:32	MAIN SUPPLY FAILURE
456	11-Jun-2020	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	10:47	11:59	01:12	MAIN SUPPLY FAILURE
457	11-Jun-2020	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	12:02	12:34	00:32	MAIN SUPPLY FAILURE
458	11-Jun-2020	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	13:15	13:37	00:22	HAND TRIPPED
459	11-Jun-2020	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	10:47	11:56	01:09	LINE CLEAR AVAILED
460	11-Jun-2020	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	12:02	12:32	00:30	HAND TRIPPED
461	11-Jun-2020	HASSAN	110	HV2	ANANDPURA_110	11:21	12:27	01:06	LINE CLEAR AVAILED
462	11-Jun-2020	HASSAN	110	HV2	BAIKAMPADI_110	17:19	18:23	01:04	MAIN SUPPLY FAILURE
463	11-Jun-2020	HASSAN	110	HV2	KULASHEKARA_110	15:22	15:24	00:02	TRANSFORMER FAULT
464	11-Jun-2020	HASSAN	110	HV2	KULASHEKARA_110	15:41	16:15	00:34	TRANSFORMER FAULT
465	11-Jun-2020	HASSAN	110	HV1	NAVUNDA_110	10:07	19:39	09:32	LINE CLEAR AVAILED
466	11-Jun-2020	HASSAN	110	HV2	NAVUNDA_110	10:07	19:41	09:34	LINE CLEAR AVAILED
467	11-Jun-2020	HASSAN	110	NAVINDA-MADHUVANA	NAVUNDA_110	10:08	19:39	09:31	LINE CLEAR AVAILED
468	11-Jun-2020	HASSAN	66	HASSN22-HN PURA	HASSAN_220	10:38	13:25	02:47	LINE CLEAR AVAILED
469	11-Jun-2020	HASSAN	66	HASSN22-SKPURA	HASSAN_220	10:17	15:08	04:51	LINE CLEAR AVAILED
470	11-Jun-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:30	17:01	06:31	LINE CLEAR AVAILED
471	11-Jun-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	10:22	14:15	03:53	LINE CLEAR AVAILED
472	11-Jun-2020	HASSAN	66	HV1	HIRESAVE_66	12:03	12:06	00:03	LINE CLEAR AVAILED
473	11-Jun-2020	HASSAN	66	KANDLI-HASSAN	KANDLI_66	10:14	15:09	04:55	LINE CLEAR AVAILED
474	11-Jun-2020	HASSAN	66	HV1	KANDLI_66	10:07	15:24	05:17	LINE CLEAR AVAILED
475	11-Jun-2020	HASSAN	66	HV2	KANDLI_66	10:07	15:25	05:18	LINE CLEAR AVAILED
476	11-Jun-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	10:07	15:23	05:16	LINE CLEAR AVAILED
477	11-Jun-2020	HASSAN	66	HV1	KUDLIGERE_66	10:10	15:32	05:22	LINE CLEAR AVAILED
478	11-Jun-2020	HASSAN	66	HV1	CHANNARAYAPATNA_66	08:59	13:19	04:20	LINE CLEAR AVAILED
479	11-Jun-2020	MYSURU	220	KADAKOLA-BASTIPURA 2	NO STATIONS EFFECTED	09:43 (9.6.20)	16:58 (11.6.20)	55:15 hrs	LINE CHARGED
480	11-Jun-2020	MYSURU	66	HV1	ATTIGULIPURA_66	10:57	11:21	0:23	LINE CLEAR AVAILED
481	11-Jun-2020	MYSURU	66	HV2	DATTAGALLY_66	13:15	13:34	0:18	LINE CLEAR AVAILED
482	11-Jun-2020	MYSURU	66	HV2	HDKOTE_66	13:41	17:58	4:17	LINE CLEAR AVAILED
483	11-Jun-2020	MYSURU	66	HV1	JAIPUR_66	11:25	12:51	1:25	LINE CLEAR AVAILED
484	11-Jun-2020	MYSURU	66	HV2	JAIPUR_66	12:45	13:50	1:05	LINE CLEAR AVAILED
485	11-Jun-2020	MYSURU	66	JAIPURA-KADAKOLA	JAIPUR_66	16:55	17:20	0:24	HAND TRIPPED
486	11-Jun-2020	MYSURU	66	KHB STATION-BILIKERE	DMG_HALLI_66	18:30	18:51	0:21	LINE FAULT
487	11-Jun-2020	MYSURU	66	HV1	KHBCOLONY_66	11:13	18:28	7:15	LINE CLEAR AVAILED
488	11-Jun-2020	MYSURU	66	HV1	KHBCOLONY_66	19:25	19:50	0:24	LINE CLEAR AVAILED
489	11-Jun-2020	MYSURU	66	HV2	KHBCOLONY_66	11:13	19:05	7:52	LINE CLEAR AVAILED
490	11-Jun-2020	MYSURU	66	KIRUGAVALU-VADKEPURA	KIRUGAVALU_66	5:49	6:27	0:38	LINE FAULT
491	11-Jun-2020	MYSURU	66	KALAMANDIR-BOGADHI	KALAMANDIRA_66	10:00	14:52	4:52	LINE CLEAR AVAILED
492	11-Jun-2020	MYSURU	66	HV1	KOPPA_66	15:03	15:35	0:31	LINE CLEAR AVAILED
493	11-Jun-2020	MYSURU	66	KUSHALNAGARA 220-HARANGI	NO STATIONS EFFECTED	10:13	17:06	6:52	LINE CLEAR AVAILED
494	11-Jun-2020	MYSURU	66	HV1	PANDAVAPURA_66	9:03	10:11	1:08	TRANSFORMER FAULT
495	11-Jun-2020	MYSURU	66	HV2	PANDAVAPURA_66	9:35	9:36	0:01	HAND TRIPPED
496	11-Jun-2020	MYSURU	66	HV1	SATHEGALA_66	12:51	13:14	0:22	LINE CLEAR AVAILED
497	11-Jun-2020	TUMKUR	220	CHITRADURGA 220KV- THALLAK 220	CHITRADURGA_220	4:51:09 PM(11.06.2020)			LINE OPEN, LINE FAULT
498	11-Jun-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
499	11-Jun-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
500	11-Jun-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN, LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
501	11-Jun-2020	TUMKUR	66	THALLAK 220kV-CHITRADURGA	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	4:50:13 PM(11.06.2020)			LINE OPEN, LINE FAULT
502	11-Jun-2020	TUMKUR	110	TR-1	HANDANKERE_110	10:23	12:53	2:30	LINE CLEAR AVAILED
503	11-Jun-2020	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	16:55	18:06	1:11	LINE CLEAR AVAILED
504	11-Jun-2020	TUMKUR	110	TR-1	KALLUR_110	12:46	12:58	0:11	LINE CLEAR AVAILED
505	11-Jun-2020	TUMKUR	110	TR-1	SHETYKERE_110	12:19	13:54	1:34	LINE CLEAR AVAILED
506	11-Jun-2020	TUMKUR	110	TR-2	SHETYKERE_110	13:48	15:19	1:31	LINE CLEAR AVAILED
507	11-Jun-2020	TUMKUR	66	TR-2	CHITRADURGA_66	16:23	16:32	0:08	TRANSFORMER FAULT
508	11-Jun-2020	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	18:04	18:05	0:01	HAND TRIPPED
509	11-Jun-2020	TUMKUR	66	TR-2	HOLALKERE_66	17:44	17:55	0:11	TRANSFORMER FAULT
510	11-Jun-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	19:03	19:13	0:09	LINE FAULT
511	11-Jun-2020	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_66 ,SASALUHALLA_66	19:04	19:13	0:09	HAND TRIPPED
512	11-Jun-2020	TUMKUR	66	HONNALLI 66KV- HONNALLI	HONNALLI_66	8:02	9:05	1:02	LINE FAULT
513	11-Jun-2020	TUMKUR	66	HONNALLI 66KV- HONNALLI	HONNALLI_66	10:09	10:34	0:25	LINE FAULT
514	11-Jun-2020	TUMKUR	66	TR-1	HONNALLI_66	8:26	10:08	1:42	LINE CLEAR AVAILED
515	11-Jun-2020	TUMKUR	66	TR-1	HONNALLI_66	10:09	15:25	5:16	LINE CLEAR AVAILED
516	11-Jun-2020	TUMKUR	66	TR-2	HANAGAL_66	10:17	16:24	6:06	LINE CLEAR AVAILED
517	11-Jun-2020	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	15:12	15:54	0:42	TRANSFORMER FAULT
518	11-Jun-2020	TUMKUR	66	TR-2	KUKKAWADA_66	1:54	2:02	0:07	TRANSFORMER FAULT
519	11-Jun-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:32	12:33	0:01	LINE FAULT
520	11-Jun-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:36	15:39	0:02	LINE FAULT
521	11-Jun-2020	TUMKUR	66	TR-2	KUNIGAL_66	10:04	17:33	7:28	LINE CLEAR AVAILED
522	11-Jun-2020	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	7:46	17:37	9:51	LINE CLEAR AVAILED
523	11-Jun-2020	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	AZURESOLAR_IPP_66	17:27	17:32	0:05	LINE FAULT
524	11-Jun-2020	TUMKUR	66	TR-2	RANGANATHAPURA_66	15:38	16:52	1:14	LINE CLEAR AVAILED
525	11-Jun-2020	TUMKUR	66	SIRA- KALLAMBELLA	SIRA_66	16:21	16:57	0:36	LINE FAULT
526	11-Jun-2020	TUMKUR	66	SIRA- MADHUGIRI 2	SIRA_66	16:21	16:56	0:35	LINE FAULT
527	11-Jun-2020	TUMKUR	66	TR-1	THIMMASANDRA_66	17:27	18:52	1:24	LINE CLEAR AVAILED
528	11-Jun-2020	TUMKUR	66	TR-2	THIMMASANDRA_66	17:27	18:52	1:24	LINE CLEAR AVAILED
529	12-Jun-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
530	12-Jun-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
531	12-Jun-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
532	12-Jun-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
533	12-Jun-2020	BAGALKOT	110	RATTIHALLI-HIREKERUR	NO STATION EFFECTED RATTIHALLI_110	16:34 (28.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
534	12-Jun-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
535	12-Jun-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
536	12-Jun-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
537	12-Jun-2020	BAGALKOT	110	HIDIKAL-ITNAL	NO STATION EFFECTED HIDIKAL_110	0:35 (09.06.2020)			LOAD CURTAILMENT
538	12-Jun-2020	BAGALKOT	220	BELLIGAVI(SHIROLKOPPA)- RANEENNUR	RANEENNUR_220	8:20 (10.06.2020)	19:27 (12.06.2020)	59:07 hrs	LINE CHARGED
539	12-Jun-2020	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	23:58 (11.06.2020)	2:41 (12.06.2020)	2:43hrs	LINE CLEAR AVAILED
540	12-Jun-2020	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	12:54 (11.06.2020)	13:45 (12.06.2020)	24:51 hrs	LINE CHARGED
541	12-Jun-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	08:07 (11.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
542	12-Jun-2020	BAGALKOT	110	HAVERI220-BYADAGI	NO STATION EFFECTED BYADAGI_110	14:02 (11.02.2020)	13:12 (12.06.2020)	23:10hrs	LINE CHARGED
543	12-Jun-2020	BAGALKOT	110	110/11KV, HV1	SIRSI_220	12:54	14:14	1:20	LINE CLEAR AVAILED
544	12-Jun-2020	BAGALKOT	110	SIRSI-KUMATA 2	NO STATION AFFECTED SIRSI_110	13:46	13:48	0:02	HAND TRIPPED
545	12-Jun-2020	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	16:50	18:00	1:10	LINE CLEAR AVAILED
546	12-Jun-2020	BAGALKOT	110	110/11KV,HV2	SIDDAPUR_110	0:45	1:10	0:25	LINE CLEAR AVAILED
547	12-Jun-2020	BAGALKOT	110	110/11KV,HV2	SHIRAGOAN_110	7:16	8:26	1:10	LINE CLEAR AVAILED
548	12-Jun-2020	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	7:08	9:25	2:17	LINE CLEAR AVAILED
549	12-Jun-2020	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	KAVALWADA_110	3:57	4:07	0:10	LINE FAULT
550	12-Jun-2020	BAGALKOT	110	ARGA- ANKOLA	ANKOLA_110	9:50	14:11	4:21	LINE CLEAR AVAILED
551	12-Jun-2020	BAGALKOT	110	110/33KV, HV2	ANKOLA_110, MASTIKATTI_33, SEABIRD_33	16:25	16:38	0:13	LINE CLEAR AVAILED
552	12-Jun-2020	BAGALKOT	110	110/33KV, HV2	ANKOLA_110, MASTIKATTI_33, SEABIRD_33	18:07	18:14	0:07	TRANSFORMER FAULT
553	12-Jun-2020	BAGALKOT	110	110/33KV, HV2	ANKOLA_110, MASTIKATTI_33, SEABIRD_33	22:38	23:18	0:40	LINE CLEAR AVAILED
554	12-Jun-2020	BAGALKOT	110	110/11KV, HV2	HIDIKAL_110	15:20	15:40	0:20	TRANSFORMER FAULT
555	12-Jun-2020	BAGALKOT	110	110/11KV, HV2	HIDIKAL_110	18:07	18:08	0:01	HAND TRIPPED
556	12-Jun-2020	BAGALKOT	110	110/11KV, HV1	NO STATION EFFECTED BEDI_110	21:20 (12.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
557	12-Jun-2020	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	9:52	13:23	3:31	LINE CLEAR AVAILED
558	12-Jun-2020	BAGALKOT	110	110/11KV, HV1	LAKMANHALLI_110	10:24	13:19	2:55	LINE CLEAR AVAILED
559	12-Jun-2020	BAGALKOT	110	110/11KV, HV1	LAKMANHALLI_110	13:30	14:19	0:49	LINE CLEAR AVAILED
560	12-Jun-2020	BAGALKOT	110	110/11KV, HV2	LAKMANHALLI_110	10:24	16:24	6:00	LINE CLEAR AVAILED
561	12-Jun-2020	BAGALKOT	110	110/33KV,HV3	NO STATION AFFECTED MACHE_110	11:20 (12.06.2020)			LINE CLEAR AVAILED
562	12-Jun-2020	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	18:00	18:04	0:04	TRANSFORMER FAULT
563	12-Jun-2020	BAGALKOT	220	GUTTUR- RANEENNUR	NO STATION EFFECTED RANEENNUR_220	19:27 (12.06.2020)			LOAD CURTAILMENT
564	12-Jun-2020	BENGALURU	66	ANEKAL - ATTIBELE	ANEKAL	13:41	13:48	0:07	LOAD CHANGE OVER
565	12-Jun-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN ,LINE FAULT
566	12-Jun-2020	BENGALURU	66	ELITE PROMENEDE - RBI	ELITE PROMENEDE	6:28	6:51	0:23	LOAD CHANGE OVER
567	12-Jun-2020	BENGALURU	66	GANIJUGUNTE - CHINTAMANI 1	GANIJUGUNTE	10:08	13:05	2:57	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
568	12-Jun-2020	BENGALURU	66	GANIJUGUNTE - CHINTAMANI 2	GANJIGUNTE	10:08	13:05	2:57	LINE FAULT
569	12-Jun-2020	BENGALURU	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR, SIRIGEREPURA	10:57	15:28	4:30	MAIN SUPPLY FAILURE
570	12-Jun-2020	BENGALURU	66	HV1	YARANDANAHALLI 220	12:19	13:40	1:20	MAIN SUPPLY FAILURE
571	12-Jun-2020	BENGALURU	66	HV1	YARANDANAHALLI 220	17:31	17:41	0:10	LINE CLEAR AVOIDED
572	12-Jun-2020	BENGALURU	66	HV1	DALASNUR	15:47	15:49	0:02	LINE CLEAR AVOIDED
573	12-Jun-2020	BENGALURU	66	HV1	DEVANAHALLI	13:16	13:22	0:05	TRANSFORMER FAULT
574	12-Jun-2020	BENGALURU	66	HV1	GANJIGUNTE	10:08	15:15	5:07	TRANSFORMER FAULT
575	12-Jun-2020	BENGALURU	66	HV1	H GOLLAHALLI	13:35	13:48	0:13	TRANSFORMER FAULT
576	12-Jun-2020	BENGALURU	66	HV1	HULLENAHALLI	15:28	16:30	1:02	LINE CLEAR AVOIDED
577	12-Jun-2020	BENGALURU	66	HV1	KONDASPURA	0:10	0:26	0:15	LINE CLEAR AVOIDED
578	12-Jun-2020	BENGALURU	66	HV1	PATH PALYA	20:15	20:20	0:04	TRANSFORMER FAULT
579	12-Jun-2020	BENGALURU	66	HV1	NAGANATHPURA 220	12:23	12:40	0:17	TRANSFORMER FAULT
580	12-Jun-2020	BENGALURU	66	HV1	VIJAYANAGARA	13:26	14:23	0:57	LINE CLEAR AVOIDED
581	12-Jun-2020	BENGALURU	66	HV1	SARJAPURA	19:21:00(11-06-2020)	13:30(12-06-2020)	18:08hrs	TRANSFORMER CHARGED
582	12-Jun-2020	BENGALURU	66	HV2	NELEMANGALA 66	18:27	18:33	0:06	LINE CLEAR AVOIDED
583	12-Jun-2020	BENGALURU	66	HV2	VIJAYANAGARA	13:26	14:23	0:57	LINE CLEAR AVOIDED
584	12-Jun-2020	BENGALURU	66	HV3	YARANDANAHALLI 220	12:19	13:40	1:20	MAIN SUPPLY FAILURE
585	12-Jun-2020	BENGALURU	66	HV3	YARANDANAHALLI 220	17:31	17:41	0:10	LINE CLEAR AVOIDED
586	12-Jun-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
587	12-Jun-2020	BENGALURU	66	JIGANI 66 - SOMANAHALLI 220	JIGANI 66	17:30	17:42	0:12	LOAD CHANGE OVER
588	12-Jun-2020	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	14:23	14:28	0:05	LOAD CHANGE OVER
589	12-Jun-2020	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN, LINE FAULT
590	12-Jun-2020	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	17:26	17:42	0:16	LINE FAULT
591	12-Jun-2020	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	6:29	6:52	0:23	LINE CLEAR AVOIDED
592	12-Jun-2020	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	11:07	11:12	0:05	LOAD CHANGE OVER
593	12-Jun-2020	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	14:45	15:15	0:30	LOAD CHANGE OVER
594	12-Jun-2020	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	6:29	6:55	0:26	LINE CLEAR AVOIDED
595	12-Jun-2020	BENGALURU	66	SRS PEENYA 220 - NANDINI LAYOUT	NANDINI LAYOUT	12:32	12:46	0:14	LINE FAULT
596	12-Jun-2020	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	12:19	13:35	1:15	MAIN SUPPLY FAILURE
597	12-Jun-2020	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	12:19	13:08	0:48	MAIN SUPPLY FAILURE
598	12-Jun-2020	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	17:31	17:42	0:11	LINE CLEAR AVOIDED
599	12-Jun-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	12:19	13:43	1:23	MAIN SUPPLY FAILURE
600	12-Jun-2020	BENGALURU	66	YARANDANAHALLI 220 - HOSUR 220	YERANDANAHALLI 220	13:25	13:40	0:15	LINE CLEAR AVOIDED
601	12-Jun-2020	BENGALURU	66	YARANDANAHALLI 220 - SOMANAHALLI 220	YERANDANAHALLI 220	12:19	17:47	5:27	LINE FAULT
602	12-Jun-2020	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	12:19	13:51	1:31	MAIN SUPPLY FAILURE
603	12-Jun-2020	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	17:31	17:45	0:14	LINE CLEAR AVOIDED
604	12-Jun-2020	BENGALURU	220	EDC 220 - A STATION 220	A STATION 220	14:54:59HRS(10.06.2020)			LINE OPEN, LINE FAULT
605	12-Jun-2020	BENGALURU	220	HOODY 220 - MANYATHA TECH PARK 220	NO STATION AFFECTED	12:35	16:04	3:29	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
606	12-Jun-2020	BENGALURU	220	SOMANAHALLI 220 - YARANDANAHALLI 220	JIGANI 220, YARANDANAHALLI 220	12:25	13:40	1:15	LINE FAULT
607	12-Jun-2020	BENGALURU	400	NELMANGALA 400 - HIRIYUR 400	NO STATION AFFECTED	19:58:03(11-06-2020)	8:28(12-06-2020)	12:28 hrs	LINE CHARGED
608	12-Jun-2020	GULBARGA	66	HV1	HANASI_66	11:05	11:10	0:05	TRANSFORMER FAULT
609	12-Jun-2020	GULBARGA	66	HV1	HANASI_66	12:05	12:10	0:05	TRANSFORMER FAULT
610	12-Jun-2020	GULBARGA	66	HV1	HOSAHALLI_66	3:20	3:30	0:10	TRANSFORMER FAULT
611	12-Jun-2020	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINAHADAGALI_66,HOLAGUND I_66	10:15(11.06.2020)	11:50(12.6.20)	25:35HRS	LINE CHARGED
612	12-Jun-2020	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110	6:56	6:59	00:03	LINE FAULT
613	12-Jun-2020	GULBARGA	110	HUMNABAD-KOLHAR	KOLHAR_110	1:45	1:52	00:07	MAIN SUPPLY FAILURE
614	12-Jun-2020	GULBARGA	110	HV1	LADHA_110	9:05	9:10	00:05	TRANSFORMER FAULT
615	12-Jun-2020	GULBARGA	110	HV2	HATTI_110	16:32	16:42	00:10	TRANSFORMER FAULT
616	12-Jun-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	19:52	20:02	00:10	LINE FAULT
617	12-Jun-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI IPP	SINDHANOOR_220	2:49	2:59	00:10	LINE FAULT
618	12-Jun-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI IPP	SINDHANOOR_220	21:52	22:05	00:13	LINE FAULT
619	12-Jun-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI IPP	SINDHANOOR_220	22:57	23:17	00:20	LINE FAULT
620	12-Jun-2020	GULBARGA	110	SINDHANOOR-SINDHANOOR1	MASKI_110,MUDDAPUR_110	5:16	5:26	00:10	LINE FAULT
621	12-Jun-2020	GULBARGA	220	HV1	RAICGUR_220	10:42	12:25	01:43	LINE CLEAR AVOIDED
622	12-Jun-2020	GULBARGA	220	KAPNOOR-SHAHABAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN ,LINE CLEAR AVOIDED
623	12-Jun-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN ,LINE FAULT
624	12-Jun-2020	GULBARGA	220	LINGAPUR-JSVL2	LINGAPUR_220	12:30	14:59	02:29	LINE CLEAR AVOIDED
625	12-Jun-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:33	15:16	04:43	LINE CLEAR AVOIDED
626	12-Jun-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	9:49	10:02	00:13	TRANSFORMER FAULT
627	12-Jun-2020	HASSAN	66	HV1	BAGUR_66	15:16	17:04	01:48	LINE CLEAR AVOIDED
628	12-Jun-2020	HASSAN	66	HV1	BASAVAGHATTA_66	11:38	11:50	00:12	LINE CLEAR AVOIDED
629	12-Jun-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	15:10	17:06	01:56	LINE CLEAR AVOIDED
630	12-Jun-2020	HASSAN	66	SAKALE-HANBAL	SAKALESHUPURA_66	14:47	14:57	00:10	LINE FAULT
631	12-Jun-2020	HASSAN	110	HV2	KULASHEKARA_110	16:15	17:56	01:41	LINE CLEAR AVOIDED
632	12-Jun-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	0:06	6:06	06:00	LINE FAULT
633	12-Jun-2020	HASSAN	110	LV1	KEMAR_220	10:41	10:46	00:05	LINE CLEAR AVOIDED
634	12-Jun-2020	HASSAN	110	LV2	KEMAR_220	10:49	10:52	00:03	LINE CLEAR AVOIDED
635	12-Jun-2020	HASSAN	110	LV3	KEMAR_220	10:57	10:59	00:02	LINE CLEAR AVOIDED
636	12-Jun-2020	HASSAN	220	GERSOPA-SHIMOGA	gerusoppa_gen	13:43 (12.06.2020)			LINE OPEN ,LINE FAULT
637	12-Jun-2020	HASSAN	220	HV1	KEMAR_220	10:41	10:46	00:05	LINE CLEAR AVOIDED
638	12-Jun-2020	HASSAN	220	HV2	KEMAR_220	10:49	10:52	00:03	LINE CLEAR AVOIDED
639	12-Jun-2020	HASSAN	220	HV3	KEMAR_220	10:57	10:59	00:02	LINE CLEAR AVOIDED
640	12-Jun-2020	HASSAN	220	KEMAR-BAJPE1	KEMAR_220	11:38	12:35	00:57	LINE CLEAR AVOIDED
641	12-Jun-2020	HASSAN	220	KEMAR-BAJPE2	KEMAR_220	11:09	11:28	00:19	LINE FAULT
642	12-Jun-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:09	12:40	02:31	LINE CLEAR AVOIDED
643	12-Jun-2020	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	11:37	12:35	00:58	NFBC ISSUED
644	12-Jun-2020	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	0:08	0:20	00:12	LINE FAULT
645	12-Jun-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	13:43(12.06.2020)			LINE OPEN ,LINE FAULT
646	12-Jun-2020	HASSAN	220	VARAHI-KEMAR3	varahi_gen	10:09	12:40	02:31	NFBC ISSUED
647	12-Jun-2020	HASSAN	400	HASSAN4-UPCL1	SHANTHIGRAMA_400	2:02 (11.06.2020)	6:52(12.6.20)	28:49 hrs	LINE CHARGED
648	12-Jun-2020	HASSAN	400	HASSAN4-UPCL1	SHANTHIGRAMA_400	22:52 (12.06.2020)			LINE OPEN ,LINE CLEAR AVOIDED
649	12-Jun-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	2:02 (11.06.2020)	6:52(12.6.20)	28:49 hrs	LINE CHARGED
650	12-Jun-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:52 (12.06.2020)			LINE OPEN ,LINE CLEAR AVOIDED
651	12-Jun-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:41 (11.06.2020)			LINE OPEN ,LINE CLEAR AVOIDED
652	12-Jun-2020	MYSURU	66	G UKKADA-PANDAVAPURA	NO STATIONS EFFECTED	13:02	15:23	2:20	NFBC ISSUED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
653	12-Jun-2020	MYSURU	66	HV1	BANNUR_66	13:05	13:13	0:08	TRANSFORMER FAULT
654	12-Jun-2020	MYSURU	66	HV1	CHUNCHUNKATTE_66	13:40	14:15	0:35	LINE CLEAR AVOIDED
655	12-Jun-2020	MYSURU	66	HV1	JAKKANAHALLY_66	10:45	14:00	3:15	LINE CLEAR AVOIDED
656	12-Jun-2020	MYSURU	66	HV1	JAKKANAHALLY_66	14:49	16:00	1:10	LINE CLEAR AVOIDED
657	12-Jun-2020	MYSURU	66	HV1	KHBCOLONY_66	16:44	17:34	0:49	LINE CLEAR AVOIDED
658	12-Jun-2020	MYSURU	66	HV1	PONNAMPET_66	9:50	10:10	0:19	MAIN SUPPLY FAILURE
659	12-Jun-2020	MYSURU	66	HV2	AKKIHEBBAL_66	13:55	14:09	0:13	TRANSFORMER FAULT
660	12-Jun-2020	MYSURU	66	HV2	JAKKANAHALLY_66	10:45	14:00	3:15	LINE CLEAR AVOIDED
661	12-Jun-2020	MYSURU	66	HV2	NAGAMANGALA_66	14:12	14:56	0:43	HAND TRIPPED
662	12-Jun-2020	MYSURU	66	HV2	PONNAMPET_66	9:50	10:04	0:14	MAIN SUPPLY FAILURE
663	12-Jun-2020	MYSURU	66	HV3	PONNAMPET_66	9:43	10:16	0:33	MAIN SUPPLY FAILURE
664	12-Jun-2020	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	10:28	10:32	0:04	LINE FAULT
665	12-Jun-2020	MYSURU	66	VJAYANAGARA-FTS	VIJAYANAGRAMYS_66	13:35	18:08	4:32	NFBC ISSUED
666	12-Jun-2020	MYSURU	66	VJAYANAGARA-HOOTAGALY	VIJAYANAGRAMYS_66	13:35	17:26	3:51	NFBC ISSUED
667	12-Jun-2020	TUMKUR	66	ANCHEPALYA 220kv- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	11:12	12:06	0:53	LINE CLEAR AVOIDED
668	12-Jun-2020	TUMKUR	66	ANCHEPALYA 220kv- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	14:49	15:07	0:17	LINE CLEAR AVOIDED
669	12-Jun-2020	TUMKUR	66	ANCHEPALYA 220kv- VIJAYA STEEL	ANCHEPALYA_220	13:59	15:33	1:33	LINE CLEAR AVOIDED
670	12-Jun-2020	TUMKUR	66	CHITRADURGA 66kv- PANDARAHALLI 2	CHITRADURGA_66	0:52	1:18	0:26	LINE FAULT
671	12-Jun-2020	TUMKUR	66	CHITRADURGA 66kv- PANDARAHALLI 2	CHITRADURGA_66	1:29	1:45	0:15	LINE FAULT
672	12-Jun-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN, LINE FAULT
673	12-Jun-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	2:47	2:56	0:09	LINE FAULT
674	12-Jun-2020	TUMKUR	66	RANGANATHAPURA- WLSPNSOLAR1	RANGENAHALLI_66	18:31	23:37	5:05	LINE CLEAR AVOIDED
675	12-Jun-2020	TUMKUR	66	RANGANATHAPURA- WLSPNSOLAR2	RANGENAHALLI_66	18:31	23:37	5:05	LINE CLEAR AVOIDED
676	12-Jun-2020	TUMKUR	66	SAVALANGA 66kv-HNLI220_NYMT	SAVALANGA_66	12:09	14:03	1:54	LINE CLEAR AVOIDED
677	12-Jun-2020	TUMKUR	66	THALLAK 220kv-CHITRADURGA	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	16:50:13 (11.06.2020)	10:59	18:11hrs	LINE CHARGED
678	12-Jun-2020	TUMKUR	66	TR-1	BAGUR TMK_66	20:45	21:00	0:14	TRANSFORMER FAULT
679	12-Jun-2020	TUMKUR	66	TR-1	CHITRADURGA_220	12:13	14:51	2:38	LINE CLEAR AVOIDED
680	12-Jun-2020	TUMKUR	66	TR-1	CHITRADURGA_66	10:00	13:36	3:35	LINE CLEAR AVOIDED
681	12-Jun-2020	TUMKUR	66	TR-1	CHITRADURGA_66	15:19	15:23	0:04	LINE CLEAR AVOIDED
682	12-Jun-2020	TUMKUR	66	TR-1	MATHOD_66	12:58	13:04	0:06	TRANSFORMER FAULT
683	12-Jun-2020	TUMKUR	66	TR-1	PAVAGADA_220	14:13	14:17	0:04	TRANSFORMER FAULT
684	12-Jun-2020	TUMKUR	66	TR-1	RANGANATHAPURA_66	12:01	17:28	5:27	LINE CLEAR AVOIDED
685	12-Jun-2020	TUMKUR	66	TR-1	SAVALANGA_66	10:14	14:04	3:49	LINE CLEAR AVOIDED
686	12-Jun-2020	TUMKUR	66	TR-1	CHALLAKERE_66	10:05	18:46	8:41	LINE CLEAR AVOIDED
687	12-Jun-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
688	12-Jun-2020	TUMKUR	66	TR-2	BELLAVI_66	11:15	11:29	0:13	TRANSFORMER FAULT
689	12-Jun-2020	TUMKUR	66	TR-2	GULIGENAHALLI_66	14:34	14:55	0:21	LINE CLEAR AVOIDED
690	12-Jun-2020	TUMKUR	66	TR-2	HOSAKERE_66	14:49	14:59	0:10	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
691	12-Jun-2020	TUMKUR	66	TR-2	HULIYURDURGA_66	18:16	18:26	0:09	TRANSFORMER FAULT
692	12-Jun-2020	TUMKUR	66	TR-2	MATHOD_66	7:20	7:30	0:09	TRANSFORMER FAULT
693	12-Jun-2020	TUMKUR	66	TR-2	MATHOD_66	8:53	8:59	0:06	TRANSFORMER FAULT
694	12-Jun-2020	TUMKUR	66	TR-2	MATHOD_66	9:18	9:24	0:06	TRANSFORMER FAULT
695	12-Jun-2020	TUMKUR	66	TR-2	MATHOD_66	9:47	9:55	0:08	TRANSFORMER FAULT
696	12-Jun-2020	TUMKUR	66	TR-2	MATHOD_66	22:08	22:28	0:20	TRANSFORMER FAULT
697	12-Jun-2020	TUMKUR	66	TR-2	TELAGI_66	9:07	9:32	0:24	LINE CLEAR AVAILED
698	12-Jun-2020	TUMKUR	66	TR-2	THIMMASANDRA_66	15:14	16:16	1:02	LINE CLEAR AVAILED
699	12-Jun-2020	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	17:22	18:53	1:30	LINE CLEAR AVAILED
700	12-Jun-2020	TUMKUR	110	HONNAVALI 110- KADUR	HONNAVALI_110	13:09	13:14	0:04	LINE FAULT
701	12-Jun-2020	TUMKUR	110	HONNAVALI 110- KADUR	HONNAVALI_110	13:26	13:32	0:05	LINE FAULT
702	12-Jun-2020	TUMKUR	110	HONNAVALI 110-TIPTUR	HALKURKE_110,KEREKODI_110,HU NSEGHATTA_110	12:13	14:10	1:57	LINE CLEAR AVAILED
703	12-Jun-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
704	12-Jun-2020	TUMKUR	220	CHITRADURGA 220KV- THALLAK 220	CHITRADURGA_220	16:51:09(11.06.2020)	10:57(12.6.20)	18:07hrs	LINE CHARGED
705	13-Jun-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
706	13-Jun-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
707	13-Jun-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
708	13-Jun-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
709	13-Jun-2020	BAGALKOT	110	RATTIHALLI-HIREKERUR	NO STATION EFFECTED RATTIHALLI_110	16:34 (28.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
710	13-Jun-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
711	13-Jun-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
712	13-Jun-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
713	13-Jun-2020	BAGALKOT	110	HIDIKAL-ITNAL	NO STATION EFFECTED HIDIKAL_110	0:35 (09.06.2020)			LOAD CURTAILMENT
714	13-Jun-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	NO STATION EFFECTED BELGAUM_220	08:07 (11.06.2020)	21:48 (13.06.2020)	13:41hrs	LINE OPEN ,LINE CLEAR AVAILED
715	13-Jun-2020	BAGALKOT	110	110/11KV, HV1	NO STATION EFFECTED BEDI_110	21:20 (12.06.2020)	17:55 (13.06.2020)	20:35hrs	LINE OPEN ,LINE CLEAR AVAILED
716	13-Jun-2020	BAGALKOT	110	110/33KV,HV3	NO STATION AFFECTED MACHE_110	11:20 (12.06.2020)			LINE CLEAR AVAILED
717	13-Jun-2020	BAGALKOT	220	GUTTUR- RANEBENNUR	NO STATION EFFECTED RANEBENNUR_220	19:27 (12.06.2020)			LOAD CURTAILMENT
718	13-Jun-2020	BAGALKOT	220	VAJRAMATTI -MLPURA 2	NO STATION AFFECTED VAJRAMATTI_220	13:33	14:59	1:26	NFBC ISSUED
719	13-Jun-2020	BAGALKOT	110	110/33KV,HV3	HEBBAL_33,KANGALA_33	17:01	17:11	0:10	LINE CLEAR AVAILED
720	13-Jun-2020	BAGALKOT	110	110/11KV,HV2	SADALAGA_110	9:30	10:15	0:45	LINE CLEAR AVAILED
721	13-Jun-2020	BAGALKOT	110	110/11KV,HV3	RAIBAG_110	10:01	17:40	7:39	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
722	13-Jun-2020	BAGALKOT	110	RAIBAG-CHIKKODI 1& 2	RAIBAG_110	10:10	17:39	7:29	LINE CLEAR AVAILED
723	13-Jun-2020	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	1:22	6:50	5:28	LINE CLEAR AVAILED
724	13-Jun-2020	BAGALKOT	110	MK HUBLI 220-KHANAPUR	KHANAPUR_110	9:32	16:50	7:18	LINE CLEAR AVAILED
725	13-Jun-2020	BAGALKOT	110	MK HUBLI 220-BEDI	BEDI_110	9:38	17:07	7:29	LINE CLEAR AVAILED
726	13-Jun-2020	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	KAVALWADA_110	14:34	14:59	0:25	LINE FAULT
727	13-Jun-2020	BAGALKOT	220	220/110KV, HV1&LV1	BAGALKOT_220	17:21	18:35	1:14	LINE CLEAR AVAILED
728	13-Jun-2020	BAGALKOT	220	220/110KV, HV2&LV2	BAGALKOT_220	12:40	17:20	4:40	LINE CLEAR AVAILED
729	13-Jun-2020	BAGALKOT	110	BAGALKOT220- NAVANAGAR1	NAVANAGAR(B)_110	10:08	17:42	7:34	LINE CLEAR AVAILED
730	13-Jun-2020	BAGALKOT	110	BAGALKOT220- NAVANAGAR2	NAVANAGAR(B)_110	10:08	19:17	9:09	LINE CLEAR AVAILED
731	13-Jun-2020	BAGALKOT	110	BAGALKOT220- KERUR	KERUR_110	13:00	17:00	4:00	LINE CLEAR AVAILED
732	13-Jun-2020	BAGALKOT	110	BAGALKOT220- KERUR	KERUR_110, BADA	17:08	17:20	0:12	LINE CLEAR AVAILED
733	13-Jun-2020	BAGALKOT	110	BAGALKOT220- KERUR	KERUR_110	17:43	18:53	1:10	LINE CLEAR AVAILED
734	13-Jun-2020	BAGALKOT	220	BELGAUM- CHIKKODI1	BELGAUM_220	12:20	16:08	3:48	LINE CHARGED
735	13-Jun-2020	BAGALKOT	220	BELGAUM- NARENDRA1	BELGAUM_220	12:33	16:06	3:33	LINE CLEAR AVAILED
736	13-Jun-2020	BAGALKOT	220	400/220KV, ICT1	DHONI_220	11:15	12:51	1:36	LINE CLEAR AVAILED
737	13-Jun-2020	BAGALKOT	110	ITANAL- RAIBAG1&2	RAIBAG_110	10:42	17:54	7:12	LINE CLEAR AVAILED
738	13-Jun-2020	BAGALKOT	110	KARWAR220-SOLARIS(BINAGA)	BINAGA_EHT	11:50	14:41	2:51	LINE CLEAR AVAILED
739	13-Jun-2020	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	13:50	15:09	1:19	LINE CLEAR AVAILED
740	13-Jun-2020	BAGALKOT	110	GAMESHA- KULIGOD	KULIGOD_110	20:56	21:18	0:22	LINE FAULT
741	13-Jun-2020	BAGALKOT	110	LOKAPUR- SALAHALLI	SALAHALLI_110	18:40	19:04	0:24	LINE FAULT
742	13-Jun-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
743	13-Jun-2020	BENGALURU	66	GANIJUGUNTE - CHINTAMANI 1	GANJIGUNTE	16:10	17:00	0:50	LINE CLEAR AVAILED
744	13-Jun-2020	BENGALURU	66	GANIJUGUNTE - CHINTAMANI 1	GANJIGUNTE	17:40	18:20	0:40	LINE CLEAR AVAILED
745	13-Jun-2020	BENGALURU	66	GANIJUGUNTE - CHINTAMANI 1	GANJIGUNTE	19:15	19:25	0:10	LINE CLEAR AVAILED
746	13-Jun-2020	BENGALURU	66	GOKULA - BEL (EHT)	BEL (EHT)	11:30	11:54	0:24	LINE CLEAR AVAILED
747	13-Jun-2020	BENGALURU	66	HV1	GANJIGUNTE	9:20	11:35	2:15	TRANSFORMER FAULT
748	13-Jun-2020	BENGALURU	66	HV1	HOSKOTE 66	13:43	14:10	0:26	LINE CLEAR AVAILED
749	13-Jun-2020	BENGALURU	66	HV1	H GOLLAHALLI	10:50	10:55	0:05	LINE CLEAR AVAILED
750	13-Jun-2020	BENGALURU	66	HV1	WEL CAST STEEL	7:45	8:06	0:21	LINE CLEAR AVAILED
751	13-Jun-2020	BENGALURU	66	IRGAMPALLI - CHINTAMANI 220	IRGAMPALLI	6:48	6:55	0:06	LINE FAULT
752	13-Jun-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
753	13-Jun-2020	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN, LINE FAULT
754	13-Jun-2020	BENGALURU	220	EDC 220 - A STATION 220	A STATION 220	14:54:59HRS(10.06.2020)			LINE OPEN, LINE FAULT
755	13-Jun-2020	GULBARGA	66	HV1	HANASI_66	14:00	14:05	0:05	TRANSFORMER FAULT
756	13-Jun-2020	GULBARGA	66	ITTAGI-CLEANMAX2	ITTAGI_220	15:55	16:12	00:17	LINE CLEAR AVAILED
757	13-Jun-2020	GULBARGA	66	ITTAGI-KUDLIGI1,2	KOGALI_66, KUDLIGI_66, HANSI_66, CJHALLI_66, GUDEKOTE_66, HOSAHALLI_66, BANAVEKAL_66, CHORNOOR_66	9:50	9:59	00:09	LINE FAULT
758	13-Jun-2020	GULBARGA	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	12:19	12:29	00:10	LINE CLEAR AVAILED
759	13-Jun-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110, UGARSUGAR_IPP	5:17	5:27	00:10	LINE FAULT
760	13-Jun-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB, BTPS WATERWORKS	0:49	0:59	00:10	LINE FAULT
761	13-Jun-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB, BTPS WATERWORKS	23:17	23:27	00:10	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
762	13-Jun-2020	GULBARGA	220	HV1,HV2	ITTAGI_220	10:32	10:52	00:20	TRANSFORMER FAULT
763	13-Jun-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE_OPEN,LINE CLEAR AVOID
764	13-Jun-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE_OPEN,LINE FAULT
765	13-Jun-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:15	14:21	04:06	LINE CLEAR AVOID
766	13-Jun-2020	HASSAN	110	HV1	NITTUR_110	11:49	13:35	01:46	LINE CLEAR AVOID
767	13-Jun-2020	HASSAN	110	KADUR-YGTI	KADUR_220	5:24	14:28	09:04	LINE FAULT
768	13-Jun-2020	HASSAN	110	KADUR-YGTI	KADUR_220	17:20	18:33	01:13	LINE CLEAR AVOID
769	13-Jun-2020	HASSAN	220	GERSOPA-SHIMOGA	gerusoppa_gen	13:43 (12.06.2020)	14:37(13.6.20)	24:53 hrs	LINE CHARGED
770	13-Jun-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	13:43(12.06.2020)	14:37(13.6.20)	24:53 hrs	LINE CHARGED
771	13-Jun-2020	HASSAN	400	HASSAN4-UPCL1	SHANTHIGRAMA_400	22:52 (12.06.2020)	7:29(13.6.20)	8:36 hrs	LINE CHARGED
772	13-Jun-2020	HASSAN	400	HASSAN4-UPCL1	SHANTHIGRAMA_400	22:47 (13.06.2020)			LINE_OPEN,LINE CLEAR AVOID
773	13-Jun-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:52 (12.06.2020)	7:29(13.6.20)	8:36 hrs	LINE CHARGED
774	13-Jun-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:47 (13.06.2020)			LINE_OPEN,LINE CLEAR AVOID
775	13-Jun-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:41 (11.06.2020)			LINE_OPEN,LINE CLEAR AVOID
776	13-Jun-2020	MYSURU	66	G UKKADA-METAGALLY	SRIRANGAPATNA_66	1:34	1:41	0:07	LINE FAULT
777	13-Jun-2020	MYSURU	66	HV1	BGPURA_66	14:17	14:36	0:18	TRANSFORMER FAULT
778	13-Jun-2020	MYSURU	66	HV1	GUNDULPET_66	17:29	18:21	0:52	TRANSFORMER FAULT
779	13-Jun-2020	MYSURU	66	HV1	HOSURGATE_66	11:33	13:24	1:51	LINE CLEAR AVOID
780	13-Jun-2020	MYSURU	66	HV1	PANDAVAPURA_66	16:33	17:16	0:42	LINE CLEAR AVOID
781	13-Jun-2020	MYSURU	66	HV1	SANIVARASANTHE_66	12:21	12:32	0:11	TRANSFORMER FAULT
782	13-Jun-2020	MYSURU	66	HV2	HANAGODU_66	14:49	15:33	0:44	LINE CLEAR AVOID
783	13-Jun-2020	MYSURU	66	HV2	PANDAVAPURA_66	12:00	12:10	0:10	LINE CLEAR AVOID
784	13-Jun-2020	MYSURU	66	HV2	PONNAMPET_66	14:41	14:56	0:14	HAND TRIPPED
785	13-Jun-2020	MYSURU	66	TUBINKERE-MC-2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	0:07	0:18	0:11	LINE FAULT
786	13-Jun-2020	MYSURU	66	TUBINKERE-MC-2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	10:41	10:46	0:05	LINE FAULT
787	13-Jun-2020	MYSURU	66	TUBINKERE-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	0:07	0:17	0:10	LINE FAULT
788	13-Jun-2020	MYSURU	66	TUBINKERE-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	10:39	10:46	0:07	LINE FAULT
789	13-Jun-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE_OPEN,LINE FAULT
790	13-Jun-2020	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	1:51	2:05	0:13	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
791	13-Jun-2020	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	RANGANATHAPURA_66	18:37	23:51	5:14	LINE CLEAR AVAILED
792	13-Jun-2020	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	RANGANATHAPURA_66	18:37	23:51	5:14	LINE CLEAR AVAILED
793	13-Jun-2020	TUMKUR	66	TR-1	KANCHIPURA_66	14:36	16:51	2:14	LINE CLEAR AVAILED
794	13-Jun-2020	TUMKUR	66	TR-1	PAVAGADA_220	13:46	13:55	0:09	TRANSFORMER FAULT
795	13-Jun-2020	TUMKUR	66	TR-1	PAVAGADA_220	14:31	14:33	0:02	TRANSFORMER FAULT
796	13-Jun-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
797	13-Jun-2020	TUMKUR	66	TR-2	LINGDHALLI_66	19:34	20:00	0:26	LINE CLEAR AVAILED
798	13-Jun-2020	TUMKUR	66	TR-2	MANGALWADA_66	8:01	9:27	1:25	LINE CLEAR AVAILED
799	13-Jun-2020	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	16:55	17:20	0:24	LINE FAULT
800	13-Jun-2020	TUMKUR	110	NITTUR 220kV- SOMALAPURA	NITTUR_220	14:19	16:11	1:51	LOAD CURTAILMENT
801	13-Jun-2020	TUMKUR	110	TR-1	SAMPIGE_110	13:03	15:55	2:52	LINE CLEAR AVAILED
802	13-Jun-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
803	14-Jun-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
804	14-Jun-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
805	14-Jun-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
806	14-Jun-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
807	14-Jun-2020	BAGALKOT	110	RATTIHALLI-HIREKERUR	NO STATION EFFECTED RATTIHALLI_110	16:34 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
808	14-Jun-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
809	14-Jun-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
810	14-Jun-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
811	14-Jun-2020	BAGALKOT	110	HIDIKAL-ITNAL	NO STATION EFFECTED HIDIKAL_110	0:35 (09.06.2020)			LOAD CURTAILMENT
812	14-Jun-2020	BAGALKOT	110	110/33KV,HV3	NO STATION AFFECTED MACHE_110	11:20 (12.06.2020)			LINE CLEAR AVAILED
813	14-Jun-2020	BAGALKOT	220	GUTTUR- RANEBENNUR	NO STATION EFFECTED RANEBENNUR_220	19:27 (12.06.2020)			LOAD CURTAILMENT
814	14-Jun-2020	BAGALKOT	220	NAGZARI 2-HUBLI	HUBLI_220	0:23	0:24	0:01	LINE FAULT
815	14-Jun-2020	BAGALKOT	110	HUBLI 220-KALGHATAGI	NO STATION AFFECTED	11:09	14:50	3:41	LINE CLEAR AVAILED
816	14-Jun-2020	BAGALKOT	110	HUBLI 220-KADANAKOPPA	NO STATION AFFECTED	11:11	14:49	3:38	LINE CLEAR AVAILED
817	14-Jun-2020	BAGALKOT	110	110/11KV,HV2	SADALAGA_110	12:25	13:25	1:00	LINE CLEAR AVAILED
818	14-Jun-2020	BAGALKOT	110	PGHUNSYAL-NAGANUR	NAGANUR_110	5:29	5:40	0:11	LINE FAULT
819	14-Jun-2020	BAGALKOT	110	110/11KV,HV2	PG HUNSYAL_110	13:10	14:25	1:15	LINE CLEAR AVAILED
820	14-Jun-2020	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	1:34	7:12	5:38	LINE CLEAR AVAILED
821	14-Jun-2020	BAGALKOT	110	220/110KV,LV2	NO STATION AFFECTED MK HUBLI_220	17:55 (14.06.2020)			LINE OPEN, LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
822	14-Jun-2020	BAGALKOT	220	PONDA2- AMBEWADI	AMBEWADI_220	11:11	15:09	3:58	LINE CLEAR AVAILED
823	14-Jun-2020	BAGALKOT	110	GOPPANAKOPPA- NARAGUND	NARAGUND_110	10:13	15:54	5:41	LINE FAULT
824	14-Jun-2020	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	9:15	18:27	9:12	LINE CLEAR AVAILED
825	14-Jun-2020	BAGALKOT	220	BELGAUM- NARENDRA2	BELGAUM_220	10:36	15:33	4:57	LINE CLEAR AVAILED
826	14-Jun-2020	BAGALKOT	220	DHONI- GUDDADAHALLI	DHONI_220	4:02	7:01	2:59	LINE FAULT
827	14-Jun-2020	BAGALKOT	110	KUDACHI220- UGARKHUD (KUDACHI)	KUDACHI_110	10:00	16:56	6:56	LINE CLEAR AVAILED
828	14-Jun-2020	BAGALKOT	110	KUDACHI220- TERDAL (MORAB)	MORAB_110	10:17	17:07	6:50	LINE CLEAR AVAILED
829	14-Jun-2020	BAGALKOT	110	GAMESHA- KULIGOD	KULIGOD_110	12:19	13:27	1:08	LINE FAULT
830	14-Jun-2020	BAGALKOT	110	110/11KV, HV4	KULIGOD_110	12:19	13:25	1:06	TRANSFORMER FAULT
831	14-Jun-2020	BAGALKOT	110	HUKKERI- KOTWAGI_LIS	KOTWAGI_LIS	11:59	12:25	0:26	LINE FAULT
832	14-Jun-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
833	14-Jun-2020	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	17:36	17:42	0:06	LOAD CHANGE OVER
834	14-Jun-2020	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	11:02	11:21	0:19	LINE CLEAR AVAILED
835	14-Jun-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	10:19	10:33	0:14	LINE FAULT
836	14-Jun-2020	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT),JAKKASANDRA	18:08	18:28	0:20	LINE CLEAR AVAILED
837	14-Jun-2020	BENGALURU	66	HV1	KYALANUR	1:35	2:03	0:28	TRANSFORMER FAULT
838	14-Jun-2020	BENGALURU	66	HV2	THIMMAMPALLI	22:08	22:11	0:02	TRANSFORMER FAULT
839	14-Jun-2020	BENGALURU	66	JAYADEVA - ADUGODI 1	NO STATION AFFECTED	18:41(14/06/2020)			LINE OPEN, LINE FAULT
840	14-Jun-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
841	14-Jun-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	17:00:00(14-06-2020)			LINE OPEN, LINE FAULT
842	14-Jun-2020	BENGALURU	66	KORAMANGALA 220 - KORAMANGALA	KORAMANGALA	18:08	18:26	0:18	LINE CLEAR AVAILED
843	14-Jun-2020	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	1:35	2:00	0:24	LINE FAULT
844	14-Jun-2020	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN, LINE FAULT
845	14-Jun-2020	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	18:06	18:30	0:24	LINE CLEAR AVAILED
846	14-Jun-2020	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	18:06	18:30	0:24	LINE CLEAR AVAILED
847	14-Jun-2020	BENGALURU	66	RANGANADODDI - KANAKAPURA 220	RANGANDODDI	17:00	23:59	6:59	LINE CLEAR AVAILED
848	14-Jun-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:50	13:26	0:35	LINE FAULT
849	14-Jun-2020	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66, ISKON	22:46	22:57	0:11	LOAD CHANGE OVER
850	14-Jun-2020	BENGALURU	66	YEDUMADU - KANAKAPURA 220	YEDUMADU	21:27	21:58	0:31	LOAD CHANGE OVER
851	14-Jun-2020	BENGALURU	220	EDC 220 - A STATION 220	A STATION 220	14:54:59HRS(10.06.2020)			LINE OPEN, LINE FAULT
852	14-Jun-2020	BENGALURU	220	HSR LAYOUT 220 - EPIP 220	KORAMANGALA 220, NIMHANS 220	18:05	18:26	0:21	LINE FAULT
853	14-Jun-2020	BENGALURU	220	KORAMANGALA 220 - GOLF LINK 1 & 2	GOLF LINK	18:08	18:26	0:18	LINE CLEAR AVAILED
854	14-Jun-2020	GULBARGA	66	ITTAGI-HADAGALLI1	HIREHADAGALI_66	22:33	22:42	00:09	LINE FAULT
855	14-Jun-2020	GULBARGA	66	ITTAGI-RENEWSOLAR1 IPP	ITTAGI_220	14:45	14:55	00:10	LINE CLEAR AVAILED
856	14-Jun-2020	GULBARGA	110	HANUMANAL-KUSTAGI	HANUMANAL_110	13:10	13:30	00:20	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
857	14-Jun-2020	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110	12:20	12:27	00:07	LINE FAULT
858	14-Jun-2020	GULBARGA	110	HV2	HATTI_110	17:55	18:05	00:10	TRANSFORMER FAULT
859	14-Jun-2020	GULBARGA	110	HV2	DEODURGA_110	9:55	10:05	00:10	TRANSFORMER FAULT
860	14-Jun-2020	GULBARGA	110	HV2	DEODURGA_110	13:45	13:55	00:10	TRANSFORMER FAULT
861	14-Jun-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	3:23	3:33	00:10	LINE FAULT
862	14-Jun-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB, BTPS_WATERWORKS	23:11	23:21	00:10	LINE FAULT
863	14-Jun-2020	GULBARGA	220	HV1	KUSTAGI_220	11:12	11:32	00:20	TRANSFORMER FAULT
864	14-Jun-2020	GULBARGA	220	HV1	KUSTAGI_220	13:02	13:21	00:19	TRANSFORMER FAULT
865	14-Jun-2020	GULBARGA	220	HV2	KUSTAGI_220	11:21	11:32	00:11	TRANSFORMER FAULT
866	14-Jun-2020	GULBARGA	220	HV2	KUSTAGI_220	13:02	13:21	00:19	TRANSFORMER FAULT
867	14-Jun-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN ,LINE CLEAR AVAILED
868	14-Jun-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN ,LINE FAULT
869	14-Jun-2020	HASSAN	66	HV2	UDAYAPURA_66	16:01	16:06	00:05	TRANSFORMER FAULT
870	14-Jun-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	12:51	13:07	00:16	LINE FAULT
871	14-Jun-2020	HASSAN	110	HV1	ALKOLA_110	10:23	16:53	06:30	LINE CLEAR AVAILED
872	14-Jun-2020	HASSAN	110	HV2	ALKOLA_110	10:23	16:54	06:31	LINE CLEAR AVAILED
873	14-Jun-2020	HASSAN	110	HV2	KONDENALU_110	11:15	12:00	00:45	LINE CLEAR AVAILED
874	14-Jun-2020	HASSAN	110	HV3	ALKOLA_110	10:23	16:54	06:31	LINE CLEAR AVAILED
875	14-Jun-2020	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	10:27	12:11	01:44	LINE CLEAR AVAILED
876	14-Jun-2020	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	11:33	13:52	02:19	NFBC ISSUED
877	14-Jun-2020	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:33	13:44	02:11	LINE CLEAR AVAILED
878	14-Jun-2020	HASSAN	400	HASSAN4-UPCL1	SHANTHIGRAMA_400	22:47 (13.06.2020)	7:20(14.6.20)	8:32 hrs	LINE CHARGED
879	14-Jun-2020	HASSAN	400	HASSAN4-UPCL1	SHANTHIGRAMA_400	23:16 (14.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
880	14-Jun-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:47 (13.06.2020)	7:20(14.6.20)	8:32 hrs	LINE CHARGED
881	14-Jun-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:16 (14.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
882	14-Jun-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:41 (11.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
883	14-Jun-2020	MYSURU	66	HEBBAL-HOOTAGALLY	HEBBAL_66	10:26	14:53	4:26	NFBC ISSUED
884	14-Jun-2020	MYSURU	66	HEBBAL-METAGALLY	HEBBAL_66	10:19	15:05	4:45	NFBC ISSUED
885	14-Jun-2020	MYSURU	66	HV1	DATTAGALLY_66	7:31	13:39	6:07	TRANSFORMER FAULT
886	14-Jun-2020	MYSURU	66	HV1	KIADBMANDYA_66	10:12	16:18	6:05	LINE CLEAR AVAILED
887	14-Jun-2020	MYSURU	66	HV1	METAGALLY_66	10:43	14:15	3:32	LINE CLEAR AVAILED
888	14-Jun-2020	MYSURU	66	HV2	DEVANOORMYS_66	14:07	14:58	0:51	TRANSFORMER FAULT
889	14-Jun-2020	MYSURU	66	HV2	KIADBMANDYA_66	10:12	16:20	6:08	LINE CLEAR AVAILED
890	14-Jun-2020	MYSURU	66	HV2	METAGALLY_66	14:17	16:56	2:39	LINE CLEAR AVAILED
891	14-Jun-2020	MYSURU	66	KHB STATION-BILIKERE	DMG_HALLI_66	6:37	6:46	0:09	LINE FAULT
892	14-Jun-2020	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66 SOMANAHALLI_66	14:31	16:35	2:03	LINE CLEAR AVAILED
893	14-Jun-2020	MYSURU	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66 TUMBEKERE_66	14:30	16:19	1:49	LINE CLEAR AVAILED
894	14-Jun-2020	MYSURU	66	KR PETE 220- MAHADESHWARAPURA	MADESWARAPURA_66 JAKKANAHALLY_66 BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, NAGAMANGALA_66	8:35	8:42	0:07	LINE FAULT
895	14-Jun-2020	MYSURU	66	METAGALLI-G UKKADA	METAGALLY_66	10:16	10:18	0:01	HAND TRIPPED
896	14-Jun-2020	MYSURU	66	METAGALLI-G UKKADA	NO STATIONS EFFECTED	15:05	15:09	0:03	HAND TRIPPED
897	14-Jun-2020	MYSURU	66	SFC SIVA-HEBBANI 8	NO STATIONS EFFECTED	3:14	3:24	0:10	LINE FAULT
898	14-Jun-2020	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	3:14	3:20	0:05	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
899	14-Jun-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALI	BEVINAHALI_66	13:43	13:46	0:03	LINE FAULT
900	14-Jun-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN, LINE FAULT
901	14-Jun-2020	TUMKUR	66	TR-1	BAGUR_TM_K_66	7:14	7:24	0:09	TRANSFORMER FAULT
902	14-Jun-2020	TUMKUR	66	TR-1	HULIYURDURGA_66	1:05	1:35	0:29	TRANSFORMER FAULT
903	14-Jun-2020	TUMKUR	66	TR-1	PAVAGADA_220	9:54	10:00	0:06	TRANSFORMER FAULT
904	14-Jun-2020	TUMKUR	66	TR-1	PAVAGADA_220	10:49	10:51	0:01	TRANSFORMER FAULT
905	14-Jun-2020	TUMKUR	66	TR-1	PAVAGADA_220	15:09	15:12	0:03	TRANSFORMER FAULT
906	14-Jun-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
907	14-Jun-2020	TUMKUR	66	TR-2	BADDIHALI_66	17:15	17:50	0:35	LINE CLEAR AVOIDED
908	14-Jun-2020	TUMKUR	66	TR-2	BALENAHALI_66	12:07	12:19	0:12	TRANSFORMER FAULT
909	14-Jun-2020	TUMKUR	66	TR-2	HOSAKERE_66	12:03	12:10	0:07	TRANSFORMER FAULT
910	14-Jun-2020	TUMKUR	66	TR-2	HULIYURDURGA_66	14:56	15:07	0:11	TRANSFORMER FAULT
911	14-Jun-2020	TUMKUR	110	HONNAVALI 110- KADUR	HONNAVALI_110	15:45	15:59	0:13	LINE FAULT
912	14-Jun-2020	TUMKUR	110	KB CROSS 220KV- MAYASANDRA	MAYASANDRA_110,TALKERE_110	21:53	22:59	1:06	LINE CLEAR AVOIDED
913	14-Jun-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
914	14-Jun-2020	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	17:48	18:30	0:41	TRANSFORMER FAULT
915	14-Jun-2020	TUMKUR	220	TR-2	KBCROSS_220	17:48	18:29	0:40	TRANSFORMER FAULT
916	15-Jun-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
917	15-Jun-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
918	15-Jun-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
919	15-Jun-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
920	15-Jun-2020	BAGALKOT	110	RATTIHALI-HIREKERUR	NO STATION EFFECTED RATTIHALI_110	16:34 (28.05.2020)			LINE OPEN ,LINE CLEAR AVOIDED
921	15-Jun-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN ,LINE CLEAR AVOIDED
922	15-Jun-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVOIDED
923	15-Jun-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVOIDED
924	15-Jun-2020	BAGALKOT	110	HIDIKAL-ITNAL	NO STATION EFFECTED HIDIKAL_110	0:35 (09.06.2020)	17:23 (15.06.2020)	160:41hrs	LINE CHARGED
925	15-Jun-2020	BAGALKOT	110	110/33KV,HV3	NO STATION AFFECTED MACHE_110	11:20 (12.06.2020)	20:10 (15.06.2020)	32:50hrs	LINE CLEAR AVOIDED
926	15-Jun-2020	BAGALKOT	220	GUTTUR- RANEBENNUR	NO STATION EFFECTED RANEBENNUR_220	19:27 (12.06.2020)			LOAD CURTAILMENT
927	15-Jun-2020	BAGALKOT	110	220/110KV,LV2	NO STATION AFFECTED MK HUBLI_220	17:55 (14.06.2020)	7:58 (15.06.2020)	14:03hrs	LINE CHARGED
928	15-Jun-2020	BAGALKOT	110	110/11KV, HV2	MRUTHYUNJAY NAGAR_110	9:58	14:08	4:10	LINE CLEAR AVOIDED
929	15-Jun-2020	BAGALKOT	110	110/11KV, HV1	MRUTHYUNJAY NAGAR_110	10:33	14:08	3:35	LINE CLEAR AVOIDED
930	15-Jun-2020	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	11:23	19:59	8:36	LINE FAULT
931	15-Jun-2020	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	13:37	19:58	6:21	LINE FAULT
932	15-Jun-2020	BAGALKOT	110	HUNGUND-JINDAL_EHT	JINDAL_EHT	13:49	19:40	5:51	LINE FAULT
933	15-Jun-2020	BAGALKOT	110	LACHYAN- HIREBEVNUR	HIREBEVNUR_110, RODAGI_110	5:20	6:15	0:55	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
934	15-Jun-2020	BAGALKOT	220	CHIKKODI220- KOLHAPUR2 (MUDSHINGI)	CHIKKODI_220	8:29	18:58	10:29	NFBC ISSUED
935	15-Jun-2020	BAGALKOT	220	HARTI1- BIDNAL	BIDNAL_220	12:04	17:54	5:50	NFBC ISSUED
936	15-Jun-2020	BAGALKOT	220	ADPH2- BAGEWADI	BAGEWADI_220	13:44	17:39	3:55	NFBC ISSUED
937	15-Jun-2020	BAGALKOT	220	ADPH2- BAGEWADI	BAGEWADI_220	18:20	20:11	1:51	LINE CLEAR AVAILED
938	15-Jun-2020	BAGALKOT	220	ADPH2- BAGEWADI	BAGEWADI_220	23:00	23:41	0:41	LINE FAULT
939	15-Jun-2020	BAGALKOT	220	PONDA1(XELDOM)- AMBEWADI	AMBEWADI_220	7:58 (15.06.2020)			LINE OPEN, LINE FAULT
940	15-Jun-2020	BAGALKOT	220	ALAMATTI2- BAGALKOT	BAGALKOT_220	11:56	18:03	6:07	LINE CLEAR AVAILED
941	15-Jun-2020	BAGALKOT	220	ALAMATTI2- BAGALKOT	BAGALKOT_220	19:09	19:16	0:07	LINE CLEAR AVAILED
942	15-Jun-2020	BAGALKOT	220	ALAMATTI2- BAGALKOT	BAGALKOT_220	22:27	23:06	0:39	LINE CLEAR AVAILED
943	15-Jun-2020	BAGALKOT	110	KIADB BIJAPUR- BHUTNAL	BHUTNAL_110	13:32	13:34	0:02	LINE FAULT
944	15-Jun-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA		18:21	18:45	0:24	LINE CLEAR AVAILED
945	15-Jun-2020	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	14:10	14:15	0:05	LOAD CHANGE OVER
946	15-Jun-2020	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	11:20	11:25	0:05	LOAD CHANGE OVER
947	15-Jun-2020	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	15:00	15:05	0:05	LOAD CHANGE OVER
948	15-Jun-2020	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	13:06	13:50	0:43	LINE FAULT
949	15-Jun-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	13:39	13:53	0:13	LINE FAULT
950	15-Jun-2020	BENGALURU	66	PADMANABHANAGAR - SUBRAMANYAPURA 220	PADMANABHANAGAR	6:03	6:06	0:02	LOAD CHANGE OVER
951	15-Jun-2020	BENGALURU	66	HV1	ALUR	11:47	11:50	0:02	LINE CLEAR AVAILED
952	15-Jun-2020	BENGALURU	66	HV2	ALUR	11:58	12:01	0:03	LINE CLEAR AVAILED
953	15-Jun-2020	BENGALURU	66	HV2	DEVARBISANAHALLI	11:50	12:06	0:16	TRANSFORMER FAULT
954	15-Jun-2020	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	20:56	21:00	0:04	TRANSFORMER FAULT
955	15-Jun-2020	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	21:13	21:17	0:04	TRANSFORMER FAULT
956	15-Jun-2020	BENGALURU	66	HV2	GANJIGUNTE	15:01	15:21	0:20	LINE CLEAR AVAILED
957	15-Jun-2020	BENGALURU	220	HV2	MITTEMARI 220	16:26	17:03	0:37	TRANSFORMER FAULT
958	15-Jun-2020	BENGALURU	66	HV1	MITTEMARI 220	16:37	16:41	0:04	MAIN SUPPLY FAILURE
959	15-Jun-2020	BENGALURU	66	HV2	NARASAPURA	18:01	18:16	0:14	TRANSFORMER FAULT
960	15-Jun-2020	BENGALURU	66	HV1	KAMASAMUDRA	11:58	12:00	0:01	HAND TRIPPED
961	15-Jun-2020	BENGALURU	66	HV1	RAJANKUNTE	13:49	14:16	0:26	TRANSFORMER FAULT
962	15-Jun-2020	BENGALURU	66	HV1	MELEHALLI	14:57	18:32	3:35	TRANSFORMER FAULT
963	15-Jun-2020	BENGALURU	66	HV2	SOUTH CITY	20:45	21:09	0:23	TRANSFORMER FAULT
964	15-Jun-2020	BENGALURU	66	HV2	THIMMAMPALLI	11:13	11:25	0:12	TRANSFORMER FAULT
965	15-Jun-2020	BENGALURU	66	HV2	SARJAPURA 220	10:06	10:13	0:06	TRANSFORMER FAULT
966	15-Jun-2020	BENGALURU	66	HV2	THIMMAMPALLI	16:25	16:40	0:15	TRANSFORMER FAULT
967	15-Jun-2020	BENGALURU	66	HV1	WEL CAST STEEL	13:01	14:34	1:32	LINE CLEAR AVAILED
968	15-Jun-2020	BENGALURU	66	JAYADEVA - ADUGODI 1	NO STATION AFFECTED	18:41(14/06/2020)			LINE OPEN, LINE FAULT
969	15-Jun-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	17:00(14-06-2020)			LINE OPEN, LINE FAULT
970	15-Jun-2020	BENGALURU	220	EDC 220 - A STATION 220	A STATION 220	14:55(10.06.2020)			LINE OPEN, LINE FAULT
971	15-Jun-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
972	15-Jun-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
973	15-Jun-2020	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN, LINE FAULT
974	15-Jun-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
975	15-Jun-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN ,LINE CLEAR AVAILED
976	15-Jun-2020	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110,NIRNA_110	5:28	5:36	0:08	LINE FAULT
977	15-Jun-2020	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110,NIRNA_110	12:35	12:44	0:09	LINE FAULT
978	15-Jun-2020	GULBARGA	110	HV2	HATTI_110	17:02	18:50	1:48	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
979	15-Jun-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB, BTPS_WATERWORKS	23:12	23:24	0:12	LINE FAULT
980	15-Jun-2020	GULBARGA	110	HV2	KEMBHAVI_110	16:40	17:05	0:25	TRANSFORMER FAULT
981	15-Jun-2020	GULBARGA	110	HV1	KEMBHAVI_110	13:40	14:40	01:00	LINE CLEAR AVOIDED
982	15-Jun-2020	GULBARGA	110	HV1	KEMBHAVI_110	16:00	19:20	03:20	LINE CLEAR AVOIDED
983	15-Jun-2020	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	9:24	9:33	0:09	LINE FAULT
984	15-Jun-2020	GULBARGA	66	HV1	HANASI_66	16:13	16:23	0:10	TRANSFORMER FAULT
985	15-Jun-2020	GULBARGA	66	ITTAGI-HOSAHALLI	HOSAHALLI_66	09:10	09:15	00:05	MAIN SUPPLY FAILURE
986	15-Jun-2020	GULBARGA	66	ITTAGI-HOSAHALLI	HOSAHALLI_66	14:15	14:20	00:05	MAIN SUPPLY FAILURE
987	15-Jun-2020	HASSAN	400	HASSAN4-UPCL1	SHANTHIGRAMA_400	23:16 (14.06.2020)	7:46(15.6.20)	8:29 hrs	LINE CHARGED
988	15-Jun-2020	HASSAN	400	HASSAN4-UPCL1	SHANTHIGRAMA_400	23:11 (15.06.2020)			LINE OPEN ,LINE CLEAR AVOIDED
989	15-Jun-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:16 (14.06.2020)	7:46(15.6.20)	8:29 hrs	LINE CHARGED
990	15-Jun-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:11 (15.06.2020)			LINE OPEN ,LINE CLEAR AVOIDED
991	15-Jun-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:41(11.06.2020)	11:47(15.6.20)	85:05hrs	LINE CHARGED
992	15-Jun-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	17:08 (15.06.2020)			LINE OPEN ,LINE CLEAR AVOIDED
993	15-Jun-2020	HASSAN	220	GOPALAP-HSN400	GOPALAPURA_220	7:39	8:28	0:49	LINE FAULT
994	15-Jun-2020	HASSAN	110	HV2	AJAMPURA_110	13:08	14:55	1:47	TRANSFORMER FAULT
995	15-Jun-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	11:09	13:38	02:29	LINE CLEAR AVOIDED
996	15-Jun-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	11:09	13:38	02:29	LINE CLEAR AVOIDED
997	15-Jun-2020	HASSAN	66	HASSN22-HN PURA	HASSAN_220	10:33	13:57	03:24	LINE CLEAR AVOIDED
998	15-Jun-2020	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	13:18	16:01	02:43	LINE CLEAR AVOIDED
999	15-Jun-2020	HASSAN	66	HV2	UDAYAPURA_66	8:09	8:23	0:14	TRANSFORMER FAULT
1000	15-Jun-2020	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	12:44	13:13	0:29	LINE FAULT
1001	15-Jun-2020	MYSURU	66	HV1	BANNUR_66	12:55	13:10	0:15	HAND TRIPPED
1002	15-Jun-2020	MYSURU	66	HV2	BANNUR_66	13:15	13:30	0:15	HAND TRIPPED
1003	15-Jun-2020	MYSURU	66	HV2	CHANDAKAVADI_66	14:51	14:58	0:06	HAND TRIPPED
1004	15-Jun-2020	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66	5:25	5:36	0:10	LINE FAULT
1005	15-Jun-2020	MYSURU	66	KUNTHUR-DODDRAIPETE	NO STATIONS EFFECTED	8:51	8:55	0:03	LINE FAULT
1006	15-Jun-2020	MYSURU	66	MUGUR-THAYUR	THAYURU_66 TNARASIPURA_66	8:48	8:53	0:05	LINE FAULT
1007	15-Jun-2020	MYSURU	220	KUSHALNAGARA-BASTIPURA 2	NO STATIONS EFFECTED	10:24	10:42	0:18	HAND TRIPPED
1008	15-Jun-2020	MYSURU	220	KUSHALNAGARA-BASTIPURA 2	NO STATIONS EFFECTED	10:42	18:11	7:29	NFBC ISSUED
1009	15-Jun-2020	MYSURU	66	HV2	MYSORESOUTH_66	11:17	13:18	2:01	LINE CLEAR AVOIDED
1010	15-Jun-2020	MYSURU	66	PANDAVAPURA-ATRIA 2	NO STATIONS EFFECTED	5:46	6:40	0:54	LINE FAULT
1011	15-Jun-2020	MYSURU	66	HV1	RAVANDUR_66	11:46	12:10	0:23	LINE CLEAR AVOIDED
1012	15-Jun-2020	MYSURU	66	HV2	TUBINAKERE_220	11:11	13:12	2:00	LINE CLEAR AVOIDED
1013	15-Jun-2020	MYSURU	66	HV2	TUBINAKERE_220	15:34	15:43	0:08	TRANSFORMER FAULT
1014	15-Jun-2020	MYSURU	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66	5:45	5:54	0:09	LINE FAULT
1015	15-Jun-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN, LINE FAULT
1016	15-Jun-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
1017	15-Jun-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
1018	15-Jun-2020	TUMKUR	66	CHITRADURGA 66kv- PANDARAHALLI 2	CHITRADURGA_66	14:27(15.6.20)			LINE OPEN ,LINE CLEAR AVOIDED
1019	15-Jun-2020	TUMKUR	110	TR-1	SAMPIGE_110	13:05	13:15	0:09	LINE CLEAR AVOIDED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1020	15-Jun-2020	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	5:09	6:01	0:52	LINE FAULT
1021	15-Jun-2020	TUMKUR	66	TR-2	AVAREGERE_66	16:44	16:59	0:15	LINE CLEAR AVAILED
1022	15-Jun-2020	TUMKUR	66	TR-2	BADDIHALLI_66	2:31	3:06	0:35	LINE CLEAR AVAILED
1023	15-Jun-2020	TUMKUR	66	TR-2	BADDIHALLI_66	11:52	12:30	0:37	LINE CLEAR AVAILED
1024	15-Jun-2020	TUMKUR	66	TR-1	CHIKKABANAGERE_66	16:20	17:20	1:00	LINE CLEAR AVAILED
1025	15-Jun-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	15:08	18:19	3:10	LINE CLEAR AVAILED
1026	15-Jun-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	15:08	18:19	3:10	LINE CLEAR AVAILED
1027	15-Jun-2020	TUMKUR	66	TR-2	HALUVAGALU_66	10:52	11:07	0:14	TRANSFORMER FAULT
1028	15-Jun-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:11	19:23	5:11	LINE CLEAR AVAILED
1029	15-Jun-2020	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_66 ,SASALUHALLA_66	14:11	19:23	5:12	LINE CLEAR AVAILED
1030	15-Jun-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	15:46	16:09	0:22	HAND TRIPPED
1031	15-Jun-2020	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	14:55	18:20	3:24	LINE CLEAR AVAILED
1032	15-Jun-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66, BASAVAPATNA_66	15:17	18:20	3:02	LINE CLEAR AVAILED
1033	15-Jun-2020	TUMKUR	66	TR-2	HOSADURGA_66	10:47	11:08	0:20	HAND TRIPPED
1034	15-Jun-2020	TUMKUR	66	TR-1	KANCHIPURA_66	12:43	17:20	4:37	LINE CLEAR AVAILED
1035	15-Jun-2020	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	20:59	21:11	0:12	LINE FAULT
1036	15-Jun-2020	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	22:49	22:56	0:07	LINE FAULT
1037	15-Jun-2020	TUMKUR	66	TR-1	MATHOD_66	6:31	6:39	0:08	TRANSFORMER FAULT
1038	15-Jun-2020	TUMKUR	66	PAVAGADA-SHYLAPURA	SHYLAPURA_66,YNHOSKOTE_66,LI NGDHALLI_66,MANGALWADA_66	11:10	11:12	0:01	LINE FAULT
1039	15-Jun-2020	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	11:10	11:15	0:05	MAIN SUPPLY FAILURE