

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 27.10.2020 TO 02.11.2020**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	27-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN :LINE FAULT
2	27-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA 110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
3	27-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
4	27-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM 110	13:05 (19.08.2020)			LINE OPEN:LINE CLEAR AVAILED
5	27-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA 110	15:20 (23.10.2020)			LINE OPEN:LINE CLEAR AVAILED
6	27-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
7	27-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA 110	20:38 (22.09.2020)			LINE OPEN:LINE CLEAR AVAILED
8	27-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL 110	14:14 (16.09.2020)	17:42 (27.10.2020)	987:28hrs	TRANSFORMER CHARGED
9	27-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI 220	10:29 (21.09.2020)			LINE OPEN:LINE CLEAR AVAILED
10	27-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR 110	16:02 (28.09.2020)			LINE OPEN:LINE CLEAR AVAILED
11	27-Oct-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI 220	11:17 (16.10.2020)			LINE OPEN:LINE CLEAR AVAILED
12	27-Oct-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI 220	11:18 (16.10.2020)			LINE OPEN:LINE CLEAR AVAILED
13	27-Oct-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT 220	11:29 (12.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
14	27-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	19:25 (21.10.2020)			LINE OPEN:LINE CLEAR AVAILED
15	27-Oct-20	BAGALKOT	220	NARENDRA- AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	18:0 (27.10.2020)			LINE OPEN :LINE FAULT
16	27-Oct-20	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED ITNAL 110	(16:22) 23.10.2020)			LINE OPEN:LINE CLEAR AVAILED
17	27-Oct-20	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	STATION NOT AFFECTED GAJENDRAGAD 110	18:26 (24.10.2020)			LINE OPEN:LINE CLEAR AVAILED
18	27-Oct-20	BAGALKOT	110	220/110, LV2	STATION NOT AFFECTED MK HUBLI 220	23:34 (24.10.2020)	9:50 (27.10.2020)	58:16hrs	LOAD CURTAILMENT
19	27-Oct-20	BAGALKOT	220	NARENDRA-HAVERI	STATION NOT AFFECTED HAVERI 220	17:05 (25.10.2020)			LINE OPEN :LINE FAULT
20	27-Oct-20	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM 220	23:12 (26.10.2020)	8:05 (27.10.2020)	8:53hrs	LINE CLEAR AVAILED
21	27-Oct-20	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM 220	23:10 (26.10.2020)	7:59 (27.10.2020)	8:49hrs	LOAD CURTAILMENT
22	27-Oct-20	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI 220	13:05 (26.10.2020)	18:03 (27.10.2020)	28:53hrs	LINE CHARGED
23	27-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI 220	13:05 (26.10.2020)			LINE OPEN :LINE FAULT
24	27-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI 220	16:35 (26.10.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
25	27-Oct-20	BAGALKOT	220	NARENDRA- AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	18:0 (27.10.2020)			LINE OPEN :LINE FAULT
26	27-Oct-20	BAGALKOT	110	VAJRAMATTI220- LOKAPUR	STATION NOT AFFECTED LOKAPUR_110	8:15	8:35	0:20	LINE FAULT
27	27-Oct-20	BAGALKOT	110	110/11KV, HV1	SIRSI_110	11:39	11:59	0:20	LINE CLEAR AVAILED
28	27-Oct-20	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:01	14:20	2:19	LINE CLEAR AVAILED
29	27-Oct-20	BAGALKOT	110	ATHANI220- SATTI	STATION NOT AFFECTED SATTI_110	13:46	16:13	2:27	LINE FAULT
30	27-Oct-20	BAGALKOT	110	110/11KV, HV2	MUDEBIHAL_110	15:11	15:46	0:35	LINE CLEAR AVAILED
31	27-Oct-20	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	22:04 (27.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
32	27-Oct-20	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	10:42	12:57	2:15	LINE CLEAR AVAILED
33	27-Oct-20	BAGALKOT	220	KADRA1- KARWAR	STATION NOT AFFECTED KARWAR_220	10:47	11:55	1:08	LINE FAULT
34	27-Oct-20	BAGALKOT	110	KARWAR220- BINAGA	KARWAR_220	10:47	15:10	4:23	LINE FAULT
35	27-Oct-20	BAGALKOT	110	KARWAR220- ARGA	ARGA_110	13:27	15:17	1:50	LINE CLEAR AVAILED
36	27-Oct-20	BAGALKOT	110	AMBEWADI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	13:19 (27.10.2020)			LINE OPEN :LINE FAULT
37	27-Oct-20	BAGALKOT	110	110/11KV,HV1	KALAGATAGI_110	11:30	13:12	1:42	LINE CLEAR AVAILED
38	27-Oct-20	BAGALKOT	110	110/11KV,HV2	KALAGATAGI_110	11:30	14:35	3:05	LINE CLEAR AVAILED
39	27-Oct-20	BAGALKOT	110	110/11KV,HV2	ITNAL_110	9:04	9:57	0:53	TRANSFORMER FAULT
40	27-Oct-20	BAGALKOT	220	HUBLI-NAGJHARI2	STATION NOT AFFECTED HUBLI_220	11:22	11:23	0:01	LINE FAULT
41	27-Oct-20	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	22:53 (27.10.2020)			LOAD CURTAILMENT
42	27-Oct-20	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	22:54 (27.10.2020)			LOAD CURTAILMENT
43	27-Oct-20	BAGALKOT	110	110/11KV,HV2	GOKAK_110	12:56	13:02	0:06	LINE CLEAR AVAILED
44	27-Oct-20	BAGALKOT	110	110/11KV,HV2	GHATAPRABHA_110,KALLOLLI_33,GO KAK MILLS_33	14:06	14:21	0:15	TRANSFORMER FAULT
45	27-Oct-20	BAGALKOT	110	GHATAPRABHA-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	0:41	1:04	0:23	LINE FAULT
46	27-Oct-20	BAGALKOT	110	AMBEWADI-KAVALWADA	STATION NOT AFFECTED KAVALWADA_110	13:19	16:38	3:19	LINE FAULT
47	27-Oct-20	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	22:43 (27.10.2020)			LOAD CURTAILMENT
48	27-Oct-20	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	22:46 (27.10.2020)			LOAD CURTAILMENT
49	27-Oct-20	BAGALKOT	220	AMBEWADI-PONDA1	STATION NOT AFFECTED AMBEWADI_220	13:10	17:28	4:18	LINE FAULT
50	27-Oct-20	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	17:55 (27.10.2020)			LINE OPEN :LINE FAULT
51	27-Oct-20	BAGALKOT	110	HAVERI220-SAVANUR	STATION NOT AFFECTED SAVANUR_110	9:37	17:49	8:12	LINE CLEAR AVAILED
52	27-Oct-20	BAGALKOT	110	HAVERI220-TILUVALI(HANAGAL)	STATION NOT AFFECTED TILUVALI_110	10:12	16:28	6:16	LINE CLEAR AVAILED
53	27-Oct-20	BAGALKOT	110	HAVERI220-BYADAGI	STATION NOT AFFECTED BYADAGI_110	10:11	17:02	6:51	LINE CLEAR AVAILED
54	27-Oct-20	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA2	GHATAPRABHA_110	0:41	1:04	0:23	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
55	27-Oct-20	BENGALUR U	66	HV1	HULIMANGALA	11:33	13:40	02:07	LINE CLEAR AVAILED
56	27-Oct-20	BENGALUR U	66	HV2	HULIMANGALA	11:33	13:40	02:07	LINE CLEAR AVAILED
57	27-Oct-20	BENGALUR U	66	MEI LAYOUT - SRS PEENYA 220	MEI LAYOUT, WIDIA	12:57	13:43	00:46	LINE CLEAR AVAILED
58	27-Oct-20	BENGALUR U	66	HV2	NIMHANS 220	14:36	14:38	00:02	LINE CLEAR AVAILED
59	27-Oct-20	BENGALUR U	66	HV1	MUDIYANUR	13:47:48	14:30	00:42	LINE CLEAR AVAILED
60	27-Oct-20	BENGALUR U	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN :LINE FAULT
61	27-Oct-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN :LINE FAULT
62	27-Oct-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN:LINE CLEAR AVAILED
63	27-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
64	27-Oct-20	GULBARGA	220	KUSHTAGI-LINGSUGUR	LINGSUGUR_220	12:56	15:35	02:39	LINE FAULT
65	27-Oct-20	GULBARGA	220	HV1	KAPNOOR_220	10:40	12:22	01:42	LINE CLEAR AVAILED
66	27-Oct-20	GULBARGA	110	KAPNOOR-MADIYAL_110	MADIYAL_110	05:00	05:05	00:05	LINE FAULT
67	27-Oct-20	GULBARGA	110	GABBUR-BPSLR_IPP	GABBUR_110	05:10	05:50	00:40	LINE FAULT
68	27-Oct-20	GULBARGA	66	HV1	BANAVEKAL_66	11:10	11:15	00:05	TRANSFORMER FAULT
69	27-Oct-20	GULBARGA	66	HV1	BANAVEKAL_66	16:30	16:50	00:20	LINE CLEAR AVAILED
70	27-Oct-20	GULBARGA	66	HV2	BANAVEKAL_66	13:35	13:40	00:05	LINE CLEAR AVAILED
71	27-Oct-20	GULBARGA	66	BANAVEKAL-SLRYS	BANAVEKAL_66	13:40	13:50	00:10	LINE FAULT
72	27-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN:LINE CLEAR AVAILED
73	27-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN:LINE CLEAR AVAILED
74	27-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:52 (18.10.2020)			LINE OPEN:LINE CLEAR AVAILED
75	27-Oct-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:27(23.10.2020)			LINE OPEN:LINE CLEAR AVAILED
76	27-Oct-20	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	9:18 (27.10.2020)			LINE OPEN:LINE CLEAR AVAILED
77	27-Oct-20	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	9:18 (27.10.2020)			LINE OPEN:LINE CLEAR AVAILED
78	27-Oct-20	HASSAN	220	HV1	KEMAR_220	11:14	13:39	02:25	LINE CLEAR AVAILED
79	27-Oct-20	HASSAN	220	HV1	KEMAR_220	16:19	17:43	01:24	LINE CLEAR AVAILED
80	27-Oct-20	HASSAN	110	HV1	KEMAR_220	15:04	15:57	00:53	LINE CLEAR AVAILED
81	27-Oct-20	HASSAN	110	HV2	KEMAR_220	16:03	16:13	00:10	LINE CLEAR AVAILED
82	27-Oct-20	HASSAN	110	LV1	KEMAR_220	11:14	13:39	02:25	LINE CLEAR AVAILED
83	27-Oct-20	HASSAN	110	LV1	KEMAR_220	16:19	17:43	01:24	LINE CLEAR AVAILED
84	27-Oct-20	HASSAN	220	SHRAVTY-SHIMOGA 2	sharavathy_gen	12:14	13:03	00:49	LINE FAULT
85	27-Oct-20	HASSAN	220	TALAGU-STRP1	TALAGUPPA_400	12:14	13:03	00:49	LINE FAULT
86	27-Oct-20	HASSAN	110	HV2	ANAVATTI_110	10:15	10:20	00:05	TRANSFORMER FAULT
87	27-Oct-20	HASSAN	110	HV1	BANTWAL_110	10:08	15:32	05:24	LINE CLEAR AVAILED
88	27-Oct-20	HASSAN	110	HV2	BANTWAL_110	10:08	15:52	05:44	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
89	27-Oct-20	HASSAN	110	HV2	BHADRAVATHI_110	12:05	13:14	01:09	LINE CLEAR AVAILED
90	27-Oct-20	HASSAN	110	HV1	BELAGUMBA_110	07:05	07:45	00:40	LINE CLEAR AVAILED
91	27-Oct-20	HASSAN	110	HV2	BELAGUMBA_110	07:05	07:45	00:40	LINE CLEAR AVAILED
92	27-Oct-20	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	08:30	16:44	08:14	HAND TRIPPED
93	27-Oct-20	HASSAN	110	HV2	KARAYA_110	10:22	12:44	02:22	LINE CLEAR AVAILED
94	27-Oct-20	HASSAN	110	HV2	PUTTUR_110	11:52	16:13	04:21	LINE CLEAR AVAILED
95	27-Oct-20	HASSAN	110	HV4	SHIRALKOPPA_110	11:00	11:25	00:25	LINE CLEAR AVAILED
96	27-Oct-20	HASSAN	110	HV1	SHIVPURA_110	11:10	11:23	00:13	LINE CLEAR AVAILED
97	27-Oct-20	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	11:18	11:26	00:08	HAND TRIPPED
98	27-Oct-20	HASSAN	66	HV1	AREHALLI_HSN_66	11:09	17:33	06:24	LINE CLEAR AVAILED
99	27-Oct-20	HASSAN	66	HV2	BALEHONNUR_66	15:23	17:53	02:30	LINE CLEAR AVAILED
100	27-Oct-20	HASSAN	66	HV2	BALEHONNUR_66	18:16	18:20	00:04	HAND TRIPPED
101	27-Oct-20	MYSURU	66	HV1	DKMAIDANA_66	15:41	15:54	0:13	LINE CLEAR AVAILED
102	27-Oct-20	MYSURU	220	CR NAGARA-BEGUR 1	NO STATION EFFECTED	13:56	14:02	0:06	HAND TRIPPED
103	27-Oct-20	MYSURU	220	CR NAGARA-BEGUR 1	NO STATION EFFECTED	14:08	16:04	1:56	HAND TRIPPED
104	27-Oct-20	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	6:05	6:10	0:05	LINE FAULT
105	27-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
106	27-Oct-20	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	10:03(26.10.2020)			LINE OPEN:LINE CLEAR AVAILED
107	27-Oct-20	TUMKUR	220	TR-3	CHITRADURGA_220	12:26	13:58	1:32	HAND TRIPPED
108	27-Oct-20	TUMKUR	220	TR-1	MADHUGIRI_220	8:04	8:35	0:30	TRANSFORMER FAULT
109	27-Oct-20	TUMKUR	110	TR-1	BANDIHALLI_110	11:53	13:36	1:42	LINE CLEAR AVAILED
110	27-Oct-20	TUMKUR	110	BANDIHALLI- TIPTUR	TIPTUR_110, HONNAVALLI_110	12:52	13:36	0:43	LINE CLEAR AVAILED
111	27-Oct-20	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	13:23	15:34	2:10	LINE CLEAR AVAILED
112	27-Oct-20	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	6:55	8:21	1:26	MAIN SUPPLY FAILURE
113	27-Oct-20	TUMKUR	66	GULIGENAHALLI- MADHUGIRI	GULIGENAHALLI_66	6:55	8:25	1:30	MAIN SUPPLY FAILURE
114	27-Oct-20	TUMKUR	66	TR-2	HARIYABBE_66	15:35	15:57	0:22	TRANSFORMER FAULT
115	27-Oct-20	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	AVNTI_SLR_IPP_66	18:04	20:27	2:23	LINE FAULT
116	27-Oct-20	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDU RGA_66,PALLAGATTE_66, SOKKE_66	3:02	3:17	0:14	LINE FAULT
117	28-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
118	28-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN :LINE FAULT
119	28-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
120	28-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
121	28-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN:LINE CLEAR AVAILED
122	28-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	15:20 (23.10.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
123	28-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN:LINE CLEAR AVAILED
124	28-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN:LINE CLEAR AVAILED
125	28-Oct-20	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED ITNAL_110	(16:22) 23.10.2020)			LINE OPEN:LINE CLEAR AVAILED
126	28-Oct-20	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	STATION NOT AFFECTED GAJENDRAGAD_110	18:26 (24.10.2020)			LINE OPEN:LINE CLEAR AVAILED
127	28-Oct-20	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	22:04 (27.10.2020)	8:58 (28.10.2020)	10:54	TRANSFORMER CHARGED
128	28-Oct-20	BAGALKOT	110	AMBEWADI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	13:19 (27.10.2020)			LINE OPEN :LINE FAULT
129	28-Oct-20	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	4:53	4:57	0:04	TRANSFORMER FAULT
130	28-Oct-20	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	5:01	5:06	0:05	TRANSFORMER FAULT
131	28-Oct-20	BAGALKOT	110	110/33KV,HV3	KIADB BIJAPUR_110	16:58	18:11	1:13	TRANSFORMER FAULT
132	28-Oct-20	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	22:06 (28.10.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
133	28-Oct-20	BAGALKOT	110	HAVERI220-SAVANUR	STATION NOT AFFECTED SAVANUR_110	8:28	17:49	9:21	LINE CLEAR AVAILED
134	28-Oct-20	BAGALKOT	110	110/11KV, HV2	MRUTHYUNJAYNAGAR_110	12:25	18:04	5:39	LINE CLEAR AVAILED
135	28-Oct-20	BAGALKOT	110	110/11KV, HV3	LOKAPUR_110	10:31	10:46	0:15	TRANSFORMER FAULT
136	28-Oct-20	BAGALKOT	110	BAGALKOT220-LOKAPUR	LOKAPUR_110	20:55	21:05	0:10	LINE FAULT
137	28-Oct-20	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI_220	23:00 (28.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
138	28-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN:LINE CLEAR AVAILED
139	28-Oct-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN:LINE CLEAR AVAILED
140	28-Oct-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN:LINE CLEAR AVAILED
141	28-Oct-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
142	28-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	19:25 (21.10.2020)			LINE OPEN:LINE CLEAR AVAILED
143	28-Oct-20	BAGALKOT	220	NARENDRA-HAVERI	STATION NOT AFFECTED HAVERI_220	17:05 (25.10.2020)			LINE OPEN :LINE FAULT
144	28-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	13:05 (26.10.2020)			LINE OPEN :LINE FAULT
145	28-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	16:35 (26.10.2020)			LOAD CURTAILMENT
146	28-Oct-20	BAGALKOT	220	NARENDRA- AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	18:0 (27.10.2020)			LINE OPEN :LINE FAULT
147	28-Oct-20	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	22:53 (27.10.2020)	8:12 (28.10.2020)	9:19	LINE CHARGED
148	28-Oct-20	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	22:54 (27.10.2020)	8:12 (28.10.2020)	9:18	LINE CHARGED
149	28-Oct-20	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	22:43 (27.10.2020)	7:48 (28.10.2020)	9:05	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
150	28-Oct-20	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	22:46 (27.10.2020)	7:47 (28.10.2020)	9:01	LINE CHARGED
151	28-Oct-20	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	17:55 (27.10.2020)			LINE OPEN :LINE FAULT
152	28-Oct-20	BAGALKOT	220	BIDNAL-NARENDRA	STATION NOT AFFECTED BIDNAL_220	10:33	15:15	4:42	LINE CLEAR AVAILED
153	28-Oct-20	BAGALKOT	220	NARENDRA-HAVERI	STATION NOT AFFECTED NARENDRA_220	11:08	15:32	4:24	LINE CLEAR AVAILED
154	28-Oct-20	BAGALKOT	220	NARENDRA-BIDNAL	STATION NOT AFFECTED NARENDRA_220	10:27	15:23	4:56	LINE CLEAR AVAILED
155	28-Oct-20	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	11:22	13:43	2:21	LINE FAULT
156	28-Oct-20	BENGALUR U	66	HV2	ELECTRONIC CITY P2 S1	16:39	16:58	0:19	LINE CLEAR AVAILED
157	28-Oct-20	BENGALUR U	66	HV2	ELECTRONIC CITY P2 S2	9:30	9:35	0:05	TRANSFORMER FAULT
158	28-Oct-20	BENGALUR U	66	HANUMANTHNAGARA - KANAKAPURA 220	CHATRA,MARALWADI,YEDUMADU	9:10	10:00	0:50	LINE CLEAR AVAILED
159	28-Oct-20	BENGALUR U	66	HANUMANTHNAGARA - KANAKAPURA 220	CHATRA,MARALWADI,YEDUMADU	17:05	18:15	1:10	LINE CLEAR AVAILED
160	28-Oct-20	BENGALUR U	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	8:13	8:22	0:09	LOAD CHANGE OVER
161	28-Oct-20	BENGALUR U	66	HV1	KOTIPURA 220	8:13	8:15	0:02	LOAD CHANGE OVER
162	28-Oct-20	BENGALUR U	66	HV1	KOTIPURA 220	8:15	14:50	6:35	LINE CLEAR AVAILED
163	28-Oct-20	BENGALUR U	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	15:28	15:46	0:18	LINE FAULT
164	28-Oct-20	BENGALUR U	66	HV3	CHIKKABALLAPURA I/A	12:20	12:38	0:18	TRANSFORMER FAULT
165	28-Oct-20	BENGALUR U	66	HV1	D CROSS	18:22	18:33	0:11	TRANSFORMER FAULT
166	28-Oct-20	BENGALUR U	66	HV1	D CROSS	18:50	19:01	0:11	TRANSFORMER FAULT
167	28-Oct-20	BENGALUR U	66	HV1	SADALI	12:30	13:00	0:30	LINE CLEAR AVAILED
168	28-Oct-20	BENGALUR U	66	HV1	SADALI	14:50	15:10	0:20	LINE CLEAR AVAILED
169	28-Oct-20	BENGALUR U	66	JIGANI 220 - JIGANI	JIGANI,JIGANI LINK ROAD	16:40	17:06	0:26	LOAD CHANGE OVER
170	28-Oct-20	BENGALUR U	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI	16:40	17:49	1:09	LOAD CHANGE OVER
171	28-Oct-20	BENGALUR U	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN :LINE FAULT
172	28-Oct-20	BENGALUR U	220	HV1	JIGANI 220	16:41	17:41	1:00	LOAD CHANGE OVER
173	28-Oct-20	GULBARGA	66	ITTAGI-HIREHADAGALLI	HEREHADAGALLI_66	18:23	18:31	0:08	LINE FAULT
174	28-Oct-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN :LINE FAULT
175	28-Oct-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN:LINE CLEAR AVAILED
176	28-Oct-20	GULBARGA	110	ALIPURA-BELLARY NORTH	BELLARY NORTH_110	13:02	13:08	0:06	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
177	28-Oct-20	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	20:36	20:38	0:02	LINE FAULT
178	28-Oct-20	GULBARGA	110	KUDITINI-BELLARY	KUDITINI_110,TORANGALLU_110	18:13	18:26	0:13	LINE FAULT
179	28-Oct-20	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	23:24	23:32	0:08	LINE FAULT
180	28-Oct-20	GULBARGA	110	LINGSUGUR-KARE_IPP	KARE_IPP	3:30	3:50	0:20	LINE FAULT
181	28-Oct-20	GULBARGA	110	LINGSUGUR-MUDGAL_110	MUDGAL_IPP	3:30	3:50	0:20	LINE FAULT
182	28-Oct-20	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	0:40	0:45	0:05	LINE FAULT
183	28-Oct-20	GULBARGA	110	GURUMITKAL-KONKAL	KONKAL_110	0:40	0:45	0:05	LINE FAULT
184	28-Oct-20	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	3:35	3:45	0:10	LINE FAULT
185	28-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
186	28-Oct-20	GULBARGA	220	SEDAM-RTPS1	RTPS_220	16:02	17:02	1:00	LINE CLEAR AVAILED
187	28-Oct-20	GULBARGA	220	BMMISPAT_IPP-LINGAPUR	LINGAPUR_220	10:00	16:40	6:40	NFBC ISSUED
188	28-Oct-20	GULBARGA	220	HKTMINING_IPP-LINGAPUR	LINGAPUR_220	9:36	16:40	7:04	LINE CLEAR AVAILED
189	28-Oct-20	GULBARGA	220	LINGSUGUR-SHAHPUR220	SHAHPUR_220	3:30	13:27	9:57	LINE FAULT
190	28-Oct-20	GULBARGA	220	HV1	LINGSUGUR_220	3:30	3:46	0:16	TRANSFORMER FAULT
191	28-Oct-20	GULBARGA	220	HV2	LINGSUGUR_220	3:30	3:59	0:29	TRANSFORMER FAULT
192	28-Oct-20	GULBARGA	220	LINGSUGUR-KUSTAGI220	LINGSUGUR_220	12:54	15:07	2:13	LINE FAULT
193	28-Oct-20	HASSAN	66	HV1	AREHALLI_HSN_66	8:45	9:48	1:03	LINE CLEAR AVAILED
194	28-Oct-20	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	10:05	10:20	0:15	LINE FAULT
195	28-Oct-20	HASSAN	66	TAVAREC-IDLE	TAVARECHATNAHALLI_66	6:28	6:35	0:07	LINE FAULT
196	28-Oct-20	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_110	16:05	17:00	0:55	LINE CLEAR AVAILED
197	28-Oct-20	HASSAN	110	HOSNGD-VTRG1	HOSANGADI_110	9:32	12:50	3:18	LINE CLEAR AVAILED
198	28-Oct-20	HASSAN	110	HV1	JOG_110	11:30	12:50	1:20	LINE CLEAR AVAILED
199	28-Oct-20	HASSAN	110	HV1	KONAJE_110	7:10	7:17	0:07	HAND TRIPPED
200	28-Oct-20	HASSAN	110	HV1	KONAJE_110	18:25	18:28	0:03	HAND TRIPPED
201	28-Oct-20	HASSAN	110	HV2	KONAJE_110	7:10	7:17	0:07	HAND TRIPPED
202	28-Oct-20	HASSAN	110	HV2	KONAJE_110	18:25	18:28	0:03	HAND TRIPPED
203	28-Oct-20	HASSAN	110	HV3	KONAJE_110	7:10	7:17	0:07	HAND TRIPPED
204	28-Oct-20	HASSAN	110	HV3	KONAJE_110	18:25	18:28	0:03	HAND TRIPPED
205	28-Oct-20	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	10:15	12:59	2:44	LINE CLEAR AVAILED
206	28-Oct-20	HASSAN	110	HV1	MSEZ_220	9:43	14:20	4:37	LINE CLEAR AVAILED
207	28-Oct-20	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	7:22	18:18	10:56	LINE CLEAR AVAILED
208	28-Oct-20	HASSAN	110	HV2	PUTTUR_110	9:30	17:07	7:37	LINE CLEAR AVAILED
209	28-Oct-20	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	7:22	18:20	10:58	NFBC ISSUED
210	28-Oct-20	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	9:18 (27.10.2020)	12:52(28.10.2020 )	27:33 hrs	LINE CHARGED
211	28-Oct-20	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	9:18 (27.10.2020)	12:52(28.10.2020 )	27:33 hrs	LINE CHARGED
212	28-Oct-20	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	13:49 (28.10.2020)			LINE OPEN :LINE FAULT
213	28-Oct-20	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	13:09 (28.10.2020)			LINE OPEN:LINE CLEAR AVAILED
214	28-Oct-20	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	13:49 (28.10.2020)			LINE OPEN :LINE FAULT
215	28-Oct-20	HASSAN	220	VARAH1-SHMG3	varahi_gen	13:09 (28.10.2020)			LINE OPEN:LINE CLEAR AVAILED
216	28-Oct-20	HASSAN	220	HNPR2-GPLPR1	HOLENARASIPURA_220	11:40	13:42	2:02	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
217	28-Oct-20	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	13:55	14:58	1:03	LINE FAULT
218	28-Oct-20	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	13:55	14:58	1:03	LINE FAULT
219	28-Oct-20	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	13:55	14:58	1:03	LINE FAULT
220	28-Oct-20	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	13:55	14:58	1:03	LINE FAULT
221	28-Oct-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:27(23.10.2020)	17:37 (28.10.2020)	115:09 hrs	LINE CHARGED
222	28-Oct-20	MYSORE	66	KUSHALNAGARA 220-PERIAPATNA-1	PERIYAPATNA_66 VIRAJPET_66 PONNAMPET_66 HUNSUR_66 GAVADAGERE_66 HOSURGATE_66 BANNIKUPPE_66 ELAVALA_66 HANAGODU_66	11:45	11:52	0:07	LINE FAULT
223	28-Oct-20	MYSORE	66	KUSHALNAGARA 220-BYLUKUPPE	BYLUKUPPE_66	11:45	11:52	0:07	HAND TRIPPED
224	28-Oct-20	MYSORE	66	KUSHALNAGARA 220-PERIAPATNA-1	HANAGODU_66 PERIYAPATNA_66 VIRAJPET_66 PONNAMPET_66	17:11	19:32	2:20	LINE CLEAR AVAILED
225	28-Oct-20	MYSORE	66	KUSHALNAGARA 220-BYLUKUPPE	HANAGODU_66 PERIYAPATNA_66 VIRAJPET_66 PONNAMPET_66	17:11	19:32	2:20	LINE CLEAR AVAILED
226	28-Oct-20	MYSORE	66	KUSHALNAGARA 220-BYLUKUPPE	BYLUKUPPE_66	12:00	12:17	0:17	LINE FAULT
227	28-Oct-20	MYSORE	66	PERIAPATNA-1-KUSHALNAGARA	HANAGODU_66 PERIYAPATNA_66 VIRAJPET_66 PONNAMPET_66	12:02	12:16	0:14	HAND TRIPPED
228	28-Oct-20	MYSORE	66	PERIAPATNA-1-BYLUKUPPE	HANAGODU_66 PERIYAPATNA_66 VIRAJPET_66 PONNAMPET_66	12:02	12:16	0:14	HAND TRIPPED
229	28-Oct-20	MYSORE	66	PERIAPATNA-1-HANAGODU	HANAGODU_66 PERIYAPATNA_66 VIRAJPET_66 PONNAMPET_66	12:02	12:16	0:14	HAND TRIPPED
230	28-Oct-20	MYSORE	66	KOLLEGALA-SATHEGALA	NO STATION EFFECTED	9:14	9:23	0:09	LINE FAULT
231	28-Oct-20	MYSORE	66	HV1	SATHEGALA_66	11:20	14:10	2:50	LINE CLEAR AVAILED
232	28-Oct-20	MYSORE	66	HV2	SATHEGALA_66	11:20	19:00	7:40	LINE CLEAR AVAILED
233	28-Oct-20	MYSORE	66	HV2	SANTHEMARAHALLI_66	12:21	17:48	5:27	LINE CLEAR AVAILED
234	28-Oct-20	MYSORE	66	KIRUGAVALU-MALIYUR	NO STATION EFFECTED	6:12	6:18	0:06	LINE FAULT
235	28-Oct-20	MYSORE	220	TUBINKERE-KOTHIPURA 2	NO STATION EFFECTED	8:50(28.10.20)			LINE OPEN:LINE CLEAR AVAILED
236	28-Oct-20	MYSORE	220	HV3	HOOTAGALLY_220	10:53	11:50	0:57	LINE CLEAR AVAILED
237	28-Oct-20	MYSORE	220	HV1	KRPET_220	9:14	18:04	8:49	LINE CLEAR AVAILED
238	28-Oct-20	MYSORE	220	HV2	KRPET_220	18:07	18:53	0:46	LINE CLEAR AVAILED
239	28-Oct-20	TUMKUR	66	TR-2	BALENAHALLI_66	16:23	16:41	0:17	TRANSFORMER FAULT
240	28-Oct-20	TUMKUR	66	BANUVALLI- NANDUGUDI	BANUVALLI_66	12:22	12:30	0:08	LINE FAULT
241	28-Oct-20	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	14:52	15:09	0:16	LINE FAULT
242	28-Oct-20	TUMKUR	66	TR-1	BELADARA_66	12:21	12:51	0:30	LINE CLEAR AVAILED
243	28-Oct-20	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	9:42	10:17	0:35	LINE FAULT
244	28-Oct-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	14:21	14:29	0:07	LINE CLEAR AVAILED
245	28-Oct-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	14:19	14:27	0:08	LINE CLEAR AVAILED
246	28-Oct-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:05	6:09	0:04	LINE FAULT
247	28-Oct-20	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	14:52	15:05	0:13	LINE FAULT
248	28-Oct-20	TUMKUR	66	TR-1	KOLALA_66	15:44	16:36	0:52	LINE CLEAR AVAILED
249	28-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:59	11:10	0:11	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
250	28-Oct-20	TUMKUR	66	MATHOD-RAMCO CEMENT _EHT_66	RAMCO CEMENT _EHT_66	15:49	19:48	3:59	LINE FAULT
251	28-Oct-20	TUMKUR	66	MATHOD-RAMCO CEMENT _EHT_66	RAMCO CEMENT _EHT_66	15:49	19:48	3:59	LINE FAULT
252	28-Oct-20	TUMKUR	66	THALLAK 220kV- CHALLAKERE-1	CHALLAKERE_66, SANIKERE_66	15:56	17:14	1:18	LINE CLEAR AVAILED
253	28-Oct-20	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	15:55	17:12	1:17	LINE CLEAR AVAILED
254	28-Oct-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:26	11:59	1:32	LINE FAULT
255	28-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
256	28-Oct-20	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	10:03:28 AM(26.10.2020)			LINE OPEN:LINE CLEAR AVAILED
257	29-Oct-20	BAGALKOT	66	66/11KV, HV1	HARIHAR HOSPET_66	12:30	13:05	0:35	LINE CLEAR AVAILED
258	29-Oct-20	BAGALKOT	66	66/11KV, HV2	HARIHAR HOSPET_66	13:26	14:12	0:46	LINE CLEAR AVAILED
259	29-Oct-20	BAGALKOT	66	66/11KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	13:26	15:35	2:09	LINE CLEAR AVAILED
260	29-Oct-20	BAGALKOT	66	66/33KV, HV4	HARIHAR HOSPET_66 AREMALLAPUR_33	13:26	15:35	2:09	LINE CLEAR AVAILED
261	29-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
262	29-Oct-20	BAGALKOT	110	110/11, HV1	ZALAKI_110	11:19	11:22	0:03	TRANSFORMER FAULT
263	29-Oct-20	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	13:05	14:05	1:00	LINE CLEAR AVAILED
264	29-Oct-20	BAGALKOT	110	110/11KV, HV2	MAMDAPUR(B)_110	11:46	13:06	1:20	LINE CLEAR AVAILED
265	29-Oct-20	BAGALKOT	110	110/11KV,HV1	ANANDNAGAR_110	11:02	13:13	2:11	LINE CLEAR AVAILED
266	29-Oct-20	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	22:06 (28.10.2020)	7:10 (29.10.2020)	9:04	TRANSFORMER CHARGED
267	29-Oct-20	BAGALKOT	110	110/33KV,HV2	HUNGUND_110 & AMINAGAD_33 KARADI_33	14:04	14:11	0:07	TRANSFORMER FAULT
268	29-Oct-20	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI_220	23:00 (28.10.2020)	7:37 (29.10.2020)	8:37	LINE CLEAR AVAILED
269	29-Oct-20	BAGALKOT	110	AMBEWADI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	13:19 (27.10.2020)			LINE OPEN :LINE FAULT
270	29-Oct-20	BAGALKOT	110	BELGAUM220-(HUKKERI)UDYAMBAG	UDYAMBAG_110	8:49	9:03	0:14	LINE FAULT
271	29-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN:LINE CLEAR AVAILED
272	29-Oct-20	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	12:00	13:01	1:01	LINE CLEAR AVAILED
273	29-Oct-20	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	9:04	18:36	9:32	LINE CLEAR AVAILED
274	29-Oct-20	BAGALKOT	110	GAMESHA- KULIGOD	KULIGOD_110	10:12	18:36	8:24	LINE CLEAR AVAILED
275	29-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	15:20 (23.10.2020)			LINE OPEN:LINE CLEAR AVAILED
276	29-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
277	29-Oct-20	BAGALKOT	110	HATTARGI-DADDI	DADDI_110	9:31	9:45	0:14	LINE FAULT
278	29-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
279	29-Oct-20	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	8:25	18:20	9:55	LINE CLEAR AVAILED
280	29-Oct-20	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED ITNAL_110	(16:22) 23.10.2020)			LINE OPEN:LINE CLEAR AVAILED
281	29-Oct-20	BAGALKOT	110	KARAWAR-ARGA	ARGA_110	9:10	13:28	4:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
282	29-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN:LINE CLEAR AVAILED
283	29-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN :LINE FAULT
284	29-Oct-20	BAGALKOT	110	KUDACHI-KUACHI110	KUDACHI_110	10:12	16:51	6:39	LINE CLEAR AVOIDED
285	29-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN:LINE CLEAR AVAILED
286	29-Oct-20	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	STATION NOT AFFECTED GAJENDRAGAD_110	18:26 (24.10.2020)	11:57 (29.10.2020)	17:33	LINE CHARGED
287	29-Oct-20	BAGALKOT	110	MANALI SUGARS- MALGHAN(S)	MALGHAN(S)_110	5:20	5:33	0:13	LINE FAULT
288	29-Oct-20	BAGALKOT	110	MRUTHYUNJAY NAGAR- GOPPANAKOPPA1	STATION NOT AFFECTED MRUTHYUNJAY NAGAR_110	3:17	14:53	11:36	LINE FAULT
289	29-Oct-20	BAGALKOT	110	MUDALGI- PG HUNSHYAL	PG HUNSHYAL_110	10:44	18:19	7:35	LINE CLEAR AVOIDED
290	29-Oct-20	BAGALKOT	110	NAREGAL- RON	RON_110	11:56	13:04	1:08	LINE CLEAR AVOIDED
291	29-Oct-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVOIDED
292	29-Oct-20	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	17:55 (27.10.2020)			LINE OPEN :LINE FAULT
293	29-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	19:25 (21.10.2020)			LINE OPEN:LINE CLEAR AVAILED
294	29-Oct-20	BAGALKOT	220	BELGAUM-NARENDRA1	BELGAUM_220	1:06	7:46	6:40	LOAD CURTAILMENT
295	29-Oct-20	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	18:58 (29.10.2020)			LINE OPEN :LINE FAULT
296	29-Oct-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN:LINE CLEAR AVAILED
297	29-Oct-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN:LINE CLEAR AVAILED
298	29-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN:LINE CLEAR AVAILED
299	29-Oct-20	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	1:10	9:08	7:58	LOAD CURTAILMENT
300	29-Oct-20	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	1:10	9:09	7:59	LOAD CURTAILMENT
301	29-Oct-20	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	9:15	15:28	6:13	LINE CLEAR AVOIDED
302	29-Oct-20	BAGALKOT	220	NARENDRA- AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	18:0 (27.10.2020)	15:28 (29.10.2020)	21:28	LINE CHARGED
303	29-Oct-20	BAGALKOT	220	NARENDRA-HAVERI	STATION NOT AFFECTED HAVERI_220	17:05 (25.10.2020)	17:55 (29.10.2020)	0:50	LINE CHARGED
304	29-Oct-20	BAGALKOT	220	SHARAVATHY1- SIRSI	SIRSI_220	10:08	15:33	5:25	LOAD CURTAILMENT
305	29-Oct-20	BAGALKOT	220	SHARAVATHY2- SIRSI	SIRSI_220	10:09	15:33	5:24	LOAD CURTAILMENT
306	29-Oct-20	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	15:32 (29.10.2020)			LOAD CURTAILMENT
307	29-Oct-20	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	15:32 (29.10.2020)			LOAD CURTAILMENT
308	29-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	13:05 (26.10.2020)	10:09 (29.10.2020)	21:04	LINE FAULT
309	29-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	16:35 (26.10.2020)	10:09 (29.10.2020)	17:34	LINE CHARGED
310	29-Oct-20	BENGALUR U	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN :LINE FAULT
311	29-Oct-20	BENGALUR U	66	BRIGADE METROPOLIS - HOODY 220	BRIGADE METROPOLIS	20:50	21:29	0:39	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
312	29-Oct-20	BENGALUR U	66	ELITE PROMENEDE - RBI	ELITE PROMENEDE	11:15	11:20	0:05	LOAD CHANGE OVER
313	29-Oct-20	BENGALUR U	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT), HMT (EHT)	17:25	18:52	1:27	LINE CLEAR AVAILED
314	29-Oct-20	BENGALUR U	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	17:23	18:18	0:55	LINE CLEAR AVAILED
315	29-Oct-20	BENGALUR U	66	HV1	ELITE PROMENEDE	14:26	15:12	0:46	LINE CLEAR AVAILED
316	29-Oct-20	BENGALUR U	66	HV1	ATTUR YELAHANKA	13:16	13:20	0:04	LINE CLEAR AVAILED
317	29-Oct-20	BENGALUR U	66	HV1	DEVANAHALLI	19:05	19:11	0:05	TRANSFORMER FAULT
318	29-Oct-20	BENGALUR U	66	HV1	KOLAR 220	12:25	12:48	0:23	LINE CLEAR AVAILED
319	29-Oct-20	BENGALUR U	66	HV1	YELAHANKA 220	13:16	13:22	0:06	LINE CLEAR AVAILED
320	29-Oct-20	BENGALUR U	66	HV2	BRIGADE METROPOLIS	20:50	22:34	1:44	TRANSFORMER FAULT
321	29-Oct-20	BENGALUR U	66	HV2	ATTUR YELAHANKA	11:07	11:10	0:03	LINE CLEAR AVAILED
322	29-Oct-20	BENGALUR U	66	HV2	YELAHANKA 220	11:03	11:18	0:15	LINE CLEAR AVAILED
323	29-Oct-20	BENGALUR U	66	HV2	SADLI	14:35	17:08	2:33	LINE CLEAR AVAILED
324	29-Oct-20	BENGALUR U	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	5:30	5:37	0:07	LINE FAULT
325	29-Oct-20	BENGALUR U	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	17:50	17:59	0:09	LOAD CHANGE OVER
326	29-Oct-20	BENGALUR U	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	6:28	6:36	0:08	LINE FAULT
327	29-Oct-20	BENGALUR U	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	11:21	11:26	0:05	LINE FAULT
328	29-Oct-20	BENGALUR U	66	RBI - ELITA PROMENEDE	RBI	16:07	16:10	0:03	LOAD CHANGE OVER
329	29-Oct-20	BENGALUR U	66	RBI - SOMANAHALLI 220	RBI	11:25	11:32	0:07	LOAD CHANGE OVER
330	29-Oct-20	BENGALUR U	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	10:16	10:18	0:02	LOAD CHANGE OVER
331	29-Oct-20	BENGALUR U	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	23:00	23:05	0:05	LOAD CHANGE OVER
332	29-Oct-20	BENGALUR U	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	13:05	13:47	0:42	LINE CLEAR AVAILED
333	29-Oct-20	BENGALUR U	66	SOMENAHALLI - AFTL (IPP)	NO STATION AFFECTED	6:28	6:33	0:05	LINE FAULT
334	29-Oct-20	BENGALUR U	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	17:21	17:27	0:06	LOAD CHANGE OVER
335	29-Oct-20	BENGALUR U	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	11:09	11:15	0:06	LOAD CHANGE OVER
336	29-Oct-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN :LINE FAULT
337	29-Oct-20	GULBARGA	110	HV1	YELBURGA_110	14:03	15:00	0:57	LINE CLEAR AVAILED
338	29-Oct-20	GULBARGA	110	HV2	SINDHNOOR_110	10:20	10:30	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
339	29-Oct-20	GULBARGA	110	HV3	KAMPLI_110	9:15	18:18	9:03	LINE CLEAR AVAILED
340	29-Oct-20	GULBARGA	110	HV3	MANTHAL_110	13:32	13:56	0:24	TRANSFORMER FAULT
341	29-Oct-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN:LINE CLEAR AVAILED
342	29-Oct-20	GULBARGA	110	SHAHBAD-RAICHUR 1	RAICHUR_1_110	20:37	20:42	0:05	LINE FAULT
343	29-Oct-20	GULBARGA	220	HUMNABAD2-HALBARGA	HALBARGA_220	17:44	18:24	0:40	LINE FAULT
344	29-Oct-20	GULBARGA	220	HUMNABAD-KAPNOOR	KAPNOOR_220	15:10	16:26	1:16	LINE CLEAR AVAILED
345	29-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
346	29-Oct-20	GULBARGA	220	HV2	RAICHUR_220	9:07	14:31	5:24	LINE CLEAR AVAILED
347	29-Oct-20	GULBARGA	220	HV2	HALBARGA_220	17:08	17:53	0:45	LINE CLEAR AVAILED
348	29-Oct-20	GULBARGA	220	LINGSUGUR-BASVANBAGEWAADI1	LINGSUGUR_220	15:06	16:26	1:20	LINE CLEAR AVAILED
349	29-Oct-20	GULBARGA	220	LINGSUGUR-KUSHTAGI	LINGSUGUR_220	11:14	12:56	1:42	LINE CLEAR AVAILED
350	29-Oct-20	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	3:22	14:18	10:56	LINE FAULT
351	29-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	3:21	14:18	10:57	LINE FAULT
352	29-Oct-20	HASSAN	66	HV2	SINGAPURA_66	11:43	12:17	0:34	TRANSFORMER FAULT
353	29-Oct-20	HASSAN	110	HV1	KEMAR_220	8:28	10:26	1:58	LINE CLEAR AVAILED
354	29-Oct-20	HASSAN	110	HV1	BAIKAMPADI_110	12:48	13:55	1:07	LINE CLEAR AVAILED
355	29-Oct-20	HASSAN	110	HV1	BHADRAVATHI_110	9:21	10:44	1:23	LINE CLEAR AVAILED
356	29-Oct-20	HASSAN	110	HV1	KONAJE_110	14:00	14:03	0:03	HAND TRIPPED
357	29-Oct-20	HASSAN	110	HV2	PUTTUR_110	9:26	16:32	7:06	LINE CLEAR AVAILED
358	29-Oct-20	HASSAN	110	HV2	KONAJE_110	14:00	14:06	0:06	HAND TRIPPED
359	29-Oct-20	HASSAN	110	HV3	KONAJE_110	14:00	14:03	0:03	HAND TRIPPED
360	29-Oct-20	HASSAN	220	HV2	GOPALAPURA_220	17:35(29.10.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
361	29-Oct-20	HASSAN	220	HV2	GOPALAPURA_220	13:15	14:55	1:40	TRANSFORMER FAULT
362	29-Oct-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:02	11:51	1:49	LINE CLEAR AVAILED
363	29-Oct-20	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	8:11	10:05	1:54	NFBC ISSUED
364	29-Oct-20	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	13:49 (28.10.2020)	8:36 (29.10.2020)	18:46 hrs	LINE CHARGED
365	29-Oct-20	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	13:09 (28.10.2020)	18:07 (29.10.2020)	28:57 hrs	LINE CHARGED
366	29-Oct-20	HASSAN	220	SHRAVITY-ST3	sharavathy_gen	13:51	14:45	0:54	LINE FAULT
367	29-Oct-20	HASSAN	220	TALAGU-STRP1	TALAGUPPA_400	13:51	14:39	0:48	LINE FAULT
368	29-Oct-20	HASSAN	220	VARAH1-KEMAR1	varahi_gen	10:02	11:53	1:51	LINE CLEAR AVAILED
369	29-Oct-20	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	13:49 (28.10.2020)	8:36 (29.10.2020)	18:46 hrs	LINE CHARGED
370	29-Oct-20	HASSAN	220	VARAH1-SHMG3	varahi_gen	13:09 (28.10.2020)	18:07 (29.10.2020)	28:57 hrs	LINE CHARGED
371	29-Oct-20	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	14:04	14:10	0:05	LINE FAULT
372	29-Oct-20	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	14:18	14:51	0:33	LINE FAULT
373	29-Oct-20	MYSORE	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	19:09	19:30	0:20	LINE FAULT
374	29-Oct-20	MYSORE	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	21:05	21:15	0:09	LINE FAULT
375	29-Oct-20	MYSORE	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	22:05	22:44	0:39	LINE FAULT
376	29-Oct-20	MYSORE	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	23:30			LINE OPEN :LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
377	29-Oct-20	MYSORE	66	HV1	BETTADHAPURA_66	15:45	16:05	0:20	LINE CLEAR AVAILED
378	29-Oct-20	MYSORE	66	HV1	NANJANGUDU_66	11:16	12:37	1:20	LINE CLEAR AVAILED
379	29-Oct-20	MYSORE	66	KUSHALNAGARA 220-BYLUKUPPE	BYLUKUPPE_66	20:51	20:57	0:06	LINE FAULT
380	29-Oct-20	MYSORE	66	PERIYAPATNA-HANGODU	PONNAMPET_66 VIRAJPET_66	10:16	10:22	0:06	HAND TRIPPED
381	29-Oct-20	MYSORE	220	HV1	TUBINAKERE_220	13:30	18:05	4:35	LINE CLEAR AVAILED
382	29-Oct-20	MYSORE	220	HV2	TUBINAKERE_220	10:24	13:20	2:55	LINE CLEAR AVAILED
383	29-Oct-20	MYSORE	220	HV2	KRPET_220	10:02	14:35	4:33	LINE CLEAR AVAILED
384	29-Oct-20	MYSORE	220	TUBINKERE-KOTHIPURA 2	NO STATIONS EFFECTED	8:50 (28/10/2020)	17:30	32:40Hrs	LINE CHARGED
385	29-Oct-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:00	11:09	0:08	LINE FAULT
386	29-Oct-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	4:47	4:55	0:08	LINE FAULT
387	29-Oct-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66, BASAVAPATNA_66	9:42	9:53	0:10	LINE FAULT
388	29-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:25	8:36	0:10	LINE FAULT
389	29-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:58	10:14	0:15	LINE FAULT
390	29-Oct-20	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66, UCHCHANGIDU RGA_66, PALLAGATTE_66, SOKKE_66	2:23	2:34	0:10	LINE FAULT
391	29-Oct-20	TUMKUR	66	NEELAGUNDA220kv-HARAPANAHALLI-1	HARAPPANAHALLI_66	7:29	8:07	0:38	LINE FAULT
392	29-Oct-20	TUMKUR	66	THALLAK 220kv- CHALLAKERE-1	CHALLAKERE_66, SANIKERE_66	7:26	9:29	2:03	LINE CLEAR AVAILED
393	29-Oct-20	TUMKUR	66	THALLAK 220kv- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	7:26	9:29	2:02	LINE CLEAR AVAILED
394	29-Oct-20	TUMKUR	66	TR-1(LV SIDE)		11:54	12:26	0:32	LINE CLEAR AVAILED
395	29-Oct-20	TUMKUR	66	TR-2	HIREGUNTANUR_66	11:21	11:37	0:15	TRANSFORMER FAULT
396	29-Oct-20	TUMKUR	66	TR-2(LV SIDE)	CHITRADURGA_220	12:12	13:47	1:35	LINE CLEAR AVAILED
397	29-Oct-20	TUMKUR	110	TR-1	AMMASANDRA_110	13:21	13:57	0:36	LINE CLEAR AVAILED
398	29-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
399	29-Oct-20	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	10:03:28 (26.10.2020)	13:26:30 (29.10.2020)	75:23 hrs	HAND TRIPPED
400	29-Oct-20	TUMKUR	220	NEELAGUNDA220kv- GUTTUR 220kv	NEELAGUNDA_220	11:44	16:32	4:47	NFBC ISSUED
401	29-Oct-20	TUMKUR	220	TR-1	CHITRADURGA_220	11:54	12:17	0:23	LINE CLEAR AVAILED
402	30-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
403	30-Oct-20	BAGALKOT	110	110/33KV, HV4	ZALAKI_110, NEVARGI_33, DHULKEDH_33	14:51	15:04	0:13	TRANSFORMER FAULT
404	30-Oct-20	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	HALIYAL_110	16:14	18:54	2:40	LINE CLEAR AVAILED
405	30-Oct-20	BAGALKOT	110	AMBEWADI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	13:19 (27.10.2020)	20:34 (30.10.2020)	7:15	LINE CHARGED
406	30-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN:LINE CLEAR AVAILED
407	30-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	15:20 (23.10.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
408	30-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
409	30-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
410	30-Oct-20	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	8:16	18:38	10:22	LINE CLEAR AVAILED
411	30-Oct-20	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED ITNAL_110	(16:22) 23.10.2020)			LINE OPEN:LINE CLEAR AVAILED
412	30-Oct-20	BAGALKOT	110	KARAWAR-ARGA	ARGA_110	20:07 (30.10.2020)			LINE OPEN :LINE FAULT
413	30-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN:LINE CLEAR AVAILED
414	30-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN :LINE FAULT
415	30-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN:LINE CLEAR AVAILED
416	30-Oct-20	BAGALKOT	110	ZALAKI-CHADACHAN	CHADCHAN_110	8:45	9:30	0:45	HAND TRIPPED
417	30-Oct-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
418	30-Oct-20	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	17:55 (27.10.2020)	16:14 (30.10.2020)	20:13	LINE CHARGED
419	30-Oct-20	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	18:54 (30.10.2020)			LINE OPEN :LINE FAULT
420	30-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	19:25 (21.10.2020)			LINE OPEN:LINE CLEAR AVAILED
421	30-Oct-20	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	18:58 (29.10.2020)	14:08 (30.10.2020)	19:10	LINE CHARGED
422	30-Oct-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN:LINE CLEAR AVAILED
423	30-Oct-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN:LINE CLEAR AVAILED
424	30-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN:LINE CLEAR AVAILED
425	30-Oct-20	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	0:26	8:47	8:21	LOAD CURTAILMENT
426	30-Oct-20	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	0:26	8:45	8:19	LOAD CURTAILMENT
427	30-Oct-20	BAGALKOT	220	SHARAVATHY1- SIRSI	SIRSI_220	20:31 (30.10.2020)			LOAD CURTAILMENT
428	30-Oct-20	BAGALKOT	220	SHARAVATHY2- SIRSI	SIRSI_220	20:31 (30.10.2020)			LOAD CURTAILMENT
429	30-Oct-20	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	15:32 (29.10.2020)	20:22 (30.10.2020)	4:50	LINE CHARGED
430	30-Oct-20	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	15:32 (29.10.2020)	20:22 (30.10.2020)	4:50	LINE CHARGED
431	30-Oct-20	BENGALUR U	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN :LINE FAULT
432	30-Oct-20	BENGALUR U	66	BOODIGERE - BEGUR 220	BOODIGERE	9:01	12:10	3:09	MAIN SUPPLY FAILURE
433	30-Oct-20	BENGALUR U	66	CHELUR - YENNIGADALE	CHELUR	23:31	23:59	0:27	LINE FAULT
434	30-Oct-20	BENGALUR U	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	7:02	7:07	0:05	LOAD CHANGE OVER
435	30-Oct-20	BENGALUR U	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	11:43	11:48	0:05	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
436	30-Oct-20	BENGALUR U	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	15:17	15:20	0:03	LOAD CHANGE OVER
437	30-Oct-20	BENGALUR U	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	8:58	9:16	0:18	MAIN SUPPLY FAILURE
438	30-Oct-20	BENGALUR U	66	HOSKOTE 220 - HOSKOTE 1	HOSKOTE 220	10:58	11:40	0:42	LINE FAULT
439	30-Oct-20	BENGALUR U	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	12:10	12:30	0:20	LINE CLEAR AVAILED
440	30-Oct-20	BENGALUR U	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	8:58	9:18	0:20	MAIN SUPPLY FAILURE
441	30-Oct-20	BENGALUR U	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	10:58	11:41	0:43	MAIN SUPPLY FAILURE
442	30-Oct-20	BENGALUR U	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	8:08	9:19	1:11	MAIN SUPPLY FAILURE
443	30-Oct-20	BENGALUR U	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	10:58	11:43	0:45	MAIN SUPPLY FAILURE
444	30-Oct-20	BENGALUR U	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	8:58	9:17	0:19	MAIN SUPPLY FAILURE
445	30-Oct-20	BENGALUR U	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	10:58	11:43	0:45	MAIN SUPPLY FAILURE
446	30-Oct-20	BENGALUR U	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	8:58	9:16	0:18	MAIN SUPPLY FAILURE
447	30-Oct-20	BENGALUR U	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	10:58	11:43	0:45	MAIN SUPPLY FAILURE
448	30-Oct-20	BENGALUR U	66	HV1	ANJANAPURA	13:14	13:34	0:20	TRANSFORMER FAULT
449	30-Oct-20	BENGALUR U	66	HV1	ANJANAPURA	17:34	21:40	4:06	LINE CLEAR AVAILED
450	30-Oct-20	BENGALUR U	66	HV1	ALUR	16:30	18:33	2:03	LINE CLEAR AVAILED
451	30-Oct-20	BENGALUR U	66	HV1	KIADB DB PURA 220	12:40	12:56	0:16	LINE CLEAR AVAILED
452	30-Oct-20	BENGALUR U	66	HV2	TAVAREKERE	13:06	15:00	1:54	LINE CLEAR AVAILED
453	30-Oct-20	BENGALUR U	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	19:50	20:01	0:11	LINE FAULT
454	30-Oct-20	BENGALUR U	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	20:17	20:28	0:11	LINE FAULT
455	30-Oct-20	BENGALUR U	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	19:50	20:01	0:11	LINE FAULT
456	30-Oct-20	BENGALUR U	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	20:17	20:28	0:11	LINE FAULT
457	30-Oct-20	BENGALUR U	220	DEVANAHALLI HARDWARE PARK 220 - HOSKOTE 220	HOSKOTE 220	8:58	11:30	2:32	LINE CLEAR AVAILED
458	30-Oct-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN :LINE FAULT
459	30-Oct-20	GULBARGA	110	HV2	KAVITHAL_110	17:40	17:50	0:10	LINE CLEAR AVAILED
460	30-Oct-20	GULBARGA	110	KAPNOOR-MADIYAL_110	MADIYAL_110,CHOWDAPUR_110	6:13	6:30	0:17	LINE FAULT
461	30-Oct-20	GULBARGA	110	KOLHAR-JANWADA	JANAWADA_110	18:25	18:40	0:15	LINE FAULT
462	30-Oct-20	GULBARGA	110	LINGSUGUR-CHAYADEVI_IPP	LINGSUGUR_220	22:30	22:38	0:08	LINE FAULT
463	30-Oct-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	3:16	3:26	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
464	30-Oct-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	4:40	4:50	0:10	LINE FAULT
465	30-Oct-20	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110	5:45	6:10	0:25	MAIN SUPPLY FAILURE
466	30-Oct-20	GULBARGA	110	MALLAT-BYAGWAT1	VALKAMDINI_110,BYAGWAT_110	5:20	5:45	0:25	LINE FAULT
467	30-Oct-20	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	20:33	20:43	0:10	LINE FAULT
468	30-Oct-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN:LINE CLEAR AVAILED
469	30-Oct-20	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	6:35	12:40	6:05	LINE CLEAR AVAILED
470	30-Oct-20	GULBARGA	220	HALBARGA-HUMNABAD1	HALBARGA_220	12:26	12:31	0:05	LINE FAULT
471	30-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
472	30-Oct-20	GULBARGA	220	HV1	LINGSUGUR_220	22:30	22:35	0:05	TRANSFORMER FAULT
473	30-Oct-20	GULBARGA	220	HV1 & HV2	HALBARGA_220	13:45	13:55	0:10	TRANSFORMER FAULT
474	30-Oct-20	GULBARGA	220	HV2	SHAHAPUR_220	5:26	5:44	0:18	TRANSFORMER FAULT
475	30-Oct-20	GULBARGA	220	HV2	LINGSUGUR_220	22:30	22:36	0:06	TRANSFORMER FAULT
476	30-Oct-20	GULBARGA	220	LINGSUGUR-SHAHAPUR	SHAHAPUR_220	23:05	23:35	0:30	LINE FAULT
477	30-Oct-20	GULBARGA	220	LINGSUGUR-SINDNOOR	SINDNOOR_220	13:05	13:53	0:48	LINE FAULT
478	30-Oct-20	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	23:05(30.10.2020)			LINE OPEN :LINE FAULT
479	30-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	1:57	13:00	11:03	LINE FAULT
480	30-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:28(30.10.2020)			LINE OPEN:LINE CLEAR AVAILED
481	30-Oct-20	HASSAN	66	HV1	BAGUR_66	10:29	14:02	3:33	LINE CLEAR AVAILED
482	30-Oct-20	HASSAN	66	HV2	BAGUR_66	10:29	14:02	3:33	LINE CLEAR AVAILED
483	30-Oct-20	HASSAN	110	HOSNGD-VTRG2	HOSANGADI_110	9:52	14:13	4:21	LINE CLEAR AVAILED
484	30-Oct-20	HASSAN	110	HV2	PUTTUR_110	9:32	17:08	7:36	LINE CLEAR AVAILED
485	30-Oct-20	HASSAN	110	JOG-JST3	JOG_110	12:00	12:40	0:40	MAIN SUPPLY FAILURE
486	30-Oct-20	HASSAN	110	SAGARA-JST2	SAGARA_110	12:01(30.10.2020)			LINE OPEN :LINE FAULT
487	30-Oct-20	HASSAN	220	HV2	GOPALAPURA_220	17:35(29.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
488	30-Oct-20	HASSAN	220	KEMAR-Varahi2	KEMAR_220	8:42 (30.10.2020)			LINE OPEN:LINE CLEAR AVAILED
489	30-Oct-20	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	10:24	15:58	5:34	NFBC ISSUED
490	30-Oct-20	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	10:24	15:58	5:34	LINE CLEAR AVAILED
491	30-Oct-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	8:42 (30.10.2020)			LINE OPEN:LINE CLEAR AVAILED
492	30-Oct-20	MYSORE	66	HANAGODU-HUNSURU	NO STATIONS EFFECTED	9:21	11:34	2:13	HAND TRIPPED
493	30-Oct-20	MYSORE	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	23:30 (29/10/2020)	11:15	11:45Hrs	LINE CHARGED
494	30-Oct-20	MYSORE	66	HV1	ADDIHALLI_66	11:20	11:30	0:10	LINE CLEAR AVAILED
495	30-Oct-20	MYSORE	66	HV1	CHINAKURALI_66	16:35	17:50	1:14	LINE CLEAR AVAILED
496	30-Oct-20	MYSORE	66	HV2	CHINAKURALI_66	15:31	16:37	1:06	LINE CLEAR AVAILED
497	30-Oct-20	MYSORE	66	KM DODDI-KK DODDI	KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	19:52	20:03	0:11	MAIN SUPPLY FAILURE



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
498	30-Oct-20	MYSORE	66	KM DODDI-KK DODDI	KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	20:17	20:28	0:11	MAIN SUPPLY FAILURE
499	30-Oct-20	MYSORE	66	KUNTHUR-MADHUVANALLI	NO STATIONS EFFECTED	4:00	4:05	0:05	LINE FAULT
500	30-Oct-20	MYSORE	66	KUNTHUR-MADHUVANALLI	NO STATIONS EFFECTED	9:03	9:10	0:06	LINE FAULT
501	30-Oct-20	MYSORE	66	MEGALAPURA -SFC	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	16:50	17:00	0:10	LINE FAULT
502	30-Oct-20	MYSORE	220	KADAKOLA-KHOZIKODE	NO STATIONS EFFECTED	8:55	13:24	4:29	NFBC ISSUED
503	30-Oct-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	13:08	13:19	0:10	LINE FAULT
504	30-Oct-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66, BASAVAPATNA_66	13:39	13:48	0:08	LINE FAULT
505	30-Oct-20	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	18:16	18:25	0:08	LINE FAULT
506	30-Oct-20	TUMKUR	66	PAVAGADA66-MADHUGIRI	PAVAGADA_66	17:27	18:06	0:39	LINE FAULT
507	30-Oct-20	TUMKUR	66	PAVAGADA66-MADHUGIRI	PAVAGADA_66	22:36	23:35	0:59	LINE FAULT
508	30-Oct-20	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN SOLAR_IPP_66	17:11	18:53	1:42	LINE FAULT
509	30-Oct-20	TUMKUR	66	THALLAK 220kV- CHALLAKERE-1	CHALLAKERE_66, SANIKERE_66	12:38	13:04	0:25	LINE CLEAR AVAILED
510	30-Oct-20	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	12:38	13:02	0:24	LINE CLEAR AVAILED
511	30-Oct-20	TUMKUR	66	TR-1	KOLALA_66	15:30	17:20	1:50	LINE CLEAR AVAILED
512	30-Oct-20	TUMKUR	66	TR-2	KUKKAWADA_66	12:20	13:18	0:57	LINE CLEAR AVAILED
513	30-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
514	31-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
515	31-Oct-20	BAGALKOT	110	110/11KV, HV2	RON_110	14:50	15:40	0:50	TRANSFORMER FAULT
516	31-Oct-20	BAGALKOT	110	110/33KV, HV3	RANEBENNUR_220	16:08	20:05	3:57	TRANSFORMER FAULT
517	31-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
518	31-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	15:20 (23.10.2020)			LINE OPEN: LINE CLEAR AVAILED
519	31-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
520	31-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
521	31-Oct-20	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	8:21	18:21	10:00	LINE CLEAR AVAILED
522	31-Oct-20	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED ITNAL_110	(16:22) 23.10.2020)			LINE OPEN: LINE CLEAR AVAILED
523	31-Oct-20	BAGALKOT	110	KARAWAR-ARGA	ARGA_110	20:07 (29.10.2020)	11:56 (31.10.2020)	15:49	LINE CHARGED
524	31-Oct-20	BAGALKOT	110	KARAWAR-SOLARIS	KARAWAR_220 (STATION NOT AFFECTED)	9:15	11:57	2:42	LINE CLEAR AVAILED
525	31-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
526	31-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN :LINE FAULT
527	31-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN:LINE CLEAR AVAILED
528	31-Oct-20	BAGALKOT	110	TADASINKOPPA- TARIHAL	TADASINKOPPA_110	7:58	8:10	0:12	HAND TRIPPED
529	31-Oct-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
530	31-Oct-20	BAGALKOT	220	ADPH 2-BAGALAKOT	BAGALKOT_220	10:42	16:16	5:34	NFBC ISSUED
531	31-Oct-20	BAGALKOT	220	ADPH 2-BAGEWADI	BAGEWADI_220	11:08	16:20	5:12	NFBC ISSUED
532	31-Oct-20	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	18:54 (30.10.2020)			LINE OPEN :LINE FAULT
533	31-Oct-20	BAGALKOT	220	AMBEWADI-PONDA1	AMBEWADI_220	10:01	16:37	6:36	LINE CLEAR AVAILED
534	31-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	19:25 (21.10.2020)			LINE OPEN:LINE CLEAR AVAILED
535	31-Oct-20	BAGALKOT	220	BELGAUM- CHIKKODI 1	BELGAUM_220	9:08 (31.10.2020)			LINE OPEN:LINE CLEAR AVAILED
536	31-Oct-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN:LINE CLEAR AVAILED
537	31-Oct-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN:LINE CLEAR AVAILED
538	31-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN:LINE CLEAR AVAILED
539	31-Oct-20	BAGALKOT	220	SHARAVATHY1- SIRSI	SIRSI_220	20:31 (30.10.2020)	17:57 (31.10.2020)	20:26	LINE CHARGED
540	31-Oct-20	BAGALKOT	220	SHARAVATHY2- SIRSI	SIRSI_220	20:31 (30.10.2020)	17:57 (31.10.2020)	20:26	LINE CHARGED
541	31-Oct-20	BAGALKOT	220	SIRSI- SHARAVATHY1	SIRSI_220	21:45 (31.10.2020)			LINE OPEN:LINE CLEAR AVAILED
542	31-Oct-20	BAGALKOT	220	SIRSI- SHARAVATHY2	SIRSI_220	21:45 (31.10.2020)			LINE OPEN:LINE CLEAR AVAILED
543	31-Oct-20	BENGALUR U	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN :LINE FAULT
544	31-Oct-20	BENGALUR U	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	10:40	10:45	0:05	LINE CLEAR AVAILED
545	31-Oct-20	BENGALUR U	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	14:40	14:45	0:05	LINE CLEAR AVAILED
546	31-Oct-20	BENGALUR U	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	16:39	16:42	0:03	LOAD CHANGE OVER
547	31-Oct-20	BENGALUR U	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	18:40	18:44	0:04	LOAD CHANGE OVER
548	31-Oct-20	BENGALUR U	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	13:00	14:01	1:01	LINE CLEAR AVAILED
549	31-Oct-20	BENGALUR U	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	7:17	8:10	0:53	LINE FAULT
550	31-Oct-20	BENGALUR U	66	HV1	GODUR	9:26	18:16	8:50	LINE CLEAR AVAILED
551	31-Oct-20	BENGALUR U	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	8:45	9:42	0:57	LINE CLEAR AVAILED
552	31-Oct-20	BENGALUR U	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	13:05	13:15	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
553	31-Oct-20	BENGALUR U	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	17:16	18:10	0:54	LINE CLEAR AVAILED
554	31-Oct-20	BENGALUR U	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	3:28	3:53	0:25	LINE FAULT
555	31-Oct-20	BENGALUR U	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	9:14	9:26	0:12	LINE FAULT
556	31-Oct-20	BENGALUR U	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	9:14	9:26	0:12	LINE FAULT
557	31-Oct-20	BENGALUR U	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	10:22	12:22	2:00	LINE CLEAR AVAILED
558	31-Oct-20	BENGALUR U	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	16:26	18:14	1:48	LINE FAULT
559	31-Oct-20	GULBARGA	66	ITTAGI-HIREHADAGALLI1	HIREHADAGALI_66	12:40	16:02	3:22	LINE FAULT
560	31-Oct-20	GULBARGA	66	ITTAGI-HIREHADAGALLI2	HIREHADAGALI_66,GIRIYAPUR_66MA GALA_66,SOVENHALLI_66,TUNGABHA DRA IPP	14:34	16:02	1:28	LINE CHARGED
561	31-Oct-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN :LINE FAULT
562	31-Oct-20	GULBARGA	110	LINGAPUR-JVSL2_IPP	LINGAPUR_220	12:15	15:40	3:25	LINE FAULT
563	31-Oct-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN:LINE CLEAR AVAILED
564	31-Oct-20	GULBARGA	110	MUNIRABAD-STARMETALLICS_IPP	MUNIRABAD_220	12:20	12:40	0:20	LINE FAULT
565	31-Oct-20	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110	2:14	2:26	0:12	LINE FAULT
566	31-Oct-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	8:58	9:16	0:18	LINE FAULT
567	31-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
568	31-Oct-20	GULBARGA	220	LINGSUGUR-SHAHAPUR	SHAHPUR_220	23:35(30/10/2020)	7:44(31/10/2020)	8:09HRS	NFBC ISSUED
569	31-Oct-20	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	23:05(30.10.2020)	7:45(31.10.2020)	8:40HRS	LINE CLEAR AVAILED
570	31-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:28(30.10.2020)	6:18(31.10.2020)	7:54HRS	LINE CHARGED
571	31-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:16(31.10.2020)			LINE OPEN:LINE CLEAR AVAILED
572	31-Oct-20	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	20:28	20:32	0:04	HAND TRIPPED
573	31-Oct-20	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	18:11	18:49	0:38	LINE FAULT
574	31-Oct-20	HASSAN	110	HV1	SINGATGERE_110	10:21	14:11	3:50	LINE CLEAR AVAILED
575	31-Oct-20	HASSAN	110	HV2	PUTTUR_110	9:35	12:47	3:12	LINE CLEAR AVAILED
576	31-Oct-20	HASSAN	110	KADUR-YGTI	KADUR_220	6:48	7:07	0:19	LINE FAULT
577	31-Oct-20	HASSAN	110	SAGARA-JST2	SAGARA_110	12:01(30.10.2020)			LINE OPEN :LINE FAULT
578	31-Oct-20	HASSAN	110	SAGARA-SORABA	SAGARA_110	11:00	11:12	0:12	HAND TRIPPED
579	31-Oct-20	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	10:51	10:56	0:05	HAND TRIPPED
580	31-Oct-20	HASSAN	110	SINGATG-YAGATI	SINGATGERE_110	10:21	14:11	3:50	LINE CLEAR AVAILED
581	31-Oct-20	HASSAN	220	HV2	GOPALAPURA_220	17:35(29.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
582	31-Oct-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	11:09	18:34	7:25	NFBC ISSUED
583	31-Oct-20	HASSAN	220	KEMAR-Varahi2	KEMAR_220	8:42 (30.10.2020)	11:04 (31.10.2020)	26:21 hrs	NFBC ISSUED
584	31-Oct-20	HASSAN	220	KEMAR-Varahi2	KEMAR_220	12:08	21:30	9:22	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
585	31-Oct-20	HASSAN	220	KEMAR-Varahi3	KEMAR_220	16:36	18:34	1:58	HAND TRIPPED
586	31-Oct-20	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	18:43	20:03	1:20	NFBC ISSUED
587	31-Oct-20	HASSAN	220	VARAHI-KEMAR1	varahi_gen	11:09	18:40	7:31	LINE CLEAR AVAILED
588	31-Oct-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	8:42 (30.10.2020)	11:06 (31.10.2020)	26:23 hrs	LINE CHARGED
589	31-Oct-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	12:08	21:30	9:22	LINE FAULT
590	31-Oct-20	HASSAN	220	VARAHI-KEMAR3	varahi_gen	16:36	18:34	1:58	HAND TRIPPED
591	31-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:52 (18.10.2020)	9:19 (31.10.2020)	304:26 hrs	LINE CHARGED
592	31-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	9:20 (31.10.2020)			LINE OPEN :LINE FAULT
593	31-Oct-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:53 (31.10.2020)			LINE OPEN:LINE CLEAR AVAILED
594	31-Oct-20	MYSORE	66	CHUNCHANAKATTE-RAVANDUR	BILIKERE_66 CHUNCHUNKATTE_66 DMG_HALLI_66 GVGUDI_66 KRNAGARA_66	10:15	10:25	0:10	LINE FAULT
595	31-Oct-20	MYSORE	66	DR PETE-KUNTHUR	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 SANTHEMARAHALLI_66	12:25	12:56	0:31	LINE FAULT
596	31-Oct-20	MYSORE	66	HOOTAGALLI-RBI	NO STATIONS EFFECTED	9:47	17:28	7:41	LINE CLEAR AVAILED
597	31-Oct-20	MYSORE	66	HV2	ADDIHALLI_66	10:45	15:15	4:29	LINE CLEAR AVAILED
598	31-Oct-20	MYSORE	66	KIRUGAVALU-MALIYUR	NO STATIONS EFFECTED	6:04	6:26	0:21	LINE FAULT
599	31-Oct-20	MYSORE	66	KM DODDI-KK DODDI	KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	9:17	9:26	0:09	MAIN SUPPLY FAILURE
600	31-Oct-20	MYSORE	66	KOLLEGALA-PARINAMIPURA	CHANDALLI_66, PARINAMIPURA_66 , THALAKADU_66	11:34	11:39	0:05	LINE FAULT
601	31-Oct-20	MYSORE	66	KUSHALNAGARA 220-BYLKUPPE	BYLUKUPPE_66	2:12	2:40	0:27	LINE FAULT
602	31-Oct-20	MYSORE	66	KUSHALNAGARA 220-BYLKUPPE	BYLUKUPPE_66	2:40	2:50	0:10	LINE FAULT
603	31-Oct-20	MYSORE	66	KUSHALNAGARA 220-BYLKUPPE	BYLUKUPPE_66	2:50	7:52	5:02	LINE FAULT
604	31-Oct-20	MYSORE	66	KUSHALNAGARA 220-BYLKUPPE	BYLUKUPPE_66 PERIYAPATNA_66 VIRAJPET_66 PONNAMPET_66	7:52	9:17	1:25	LINE CLEAR AVAILED
605	31-Oct-20	MYSORE	66	KUSHALNAGARA 220-MYSORE 1	MIRLE_66	10:15	10:25	0:10	LINE FAULT
606	31-Oct-20	MYSORE	66	KUSHALNAGARA 220-PERIYAPATNA-1	BYLUKUPPE_66 PERIYAPATNA_66 VIRAJPET_66 PONNAMPET_66	7:52	9:17	1:25	LINE CLEAR AVAILED
607	31-Oct-20	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	22:57	23:03	0:06	LINE FAULT
608	31-Oct-20	MYSORE	66	MANDYA-MC -2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	9:14	9:21	0:06	LINE FAULT
609	31-Oct-20	MYSORE	66	MEGALAPURA -SFC	BGPURA_66 CHIDRAVALI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	15:10	15:25	0:15	LINE FAULT
610	31-Oct-20	MYSORE	66	METAGALLI-SR PATNA	NO STATIONS EFFECTED	10:36	17:16	6:39	NFBC ISSUED
611	31-Oct-20	MYSORE	66	PARINAMIPURA-TALKADU	CHANDALLI_66, THALAKADU_66	9:53	10:00	0:07	LINE FAULT
612	31-Oct-20	MYSORE	66	SATHEGALA-BPCL	NO STATIONS EFFECTED	14:59	16:55	1:55	LINE CLEAR AVAILED
613	31-Oct-20	MYSORE	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	14:59	18:10	3:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
614	31-Oct-20	MYSORE	66	SATHEGALA-KOLLEGALA	SATHEGALA_66	17:10	18:20	1:10	LINE CLEAR AVAILED
615	31-Oct-20	MYSORE	66	SFC SIVA-HEBBANI 6	SATHEGALA_66	6:04	6:25	0:20	LINE FAULT
616	31-Oct-20	MYSORE	66	SFC SIVA-PGL	NO STATIONS EFFECTED	6:04	6:06	0:02	LINE FAULT
617	31-Oct-20	MYSORE	66	TUBINKERE-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	9:15	9:21	0:06	LINE FAULT
618	31-Oct-20	TUMKUR	66	BANUVALLI- NANDUGUDI	BANUVALLI_66	11:14	11:24	0:09	LINE FAULT
619	31-Oct-20	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUND A_66	5:16	5:21	0:04	LINE FAULT
620	31-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:32	11:40	0:08	LINE FAULT
621	31-Oct-20	TUMKUR	66	THALLAK 220kV- CHALLAKERE-1	CHALLAKERE_66, SANIKERE_66	15:48	15:50	0:01	LINE CLEAR AVAILED
622	31-Oct-20	TUMKUR	66	TR-2	HALUVAGALU_66	16:25	16:32	0:06	TRANSFORMER FAULT
623	31-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
624	1-Nov-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
625	1-Nov-20	BAGALKOT	110	110/33KV HV2	HUNGUND_110 & AMINAGAD,KARADI_33	8:01	8:09	0:08	TRANSFORMER FAULT
626	1-Nov-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	13:04 (01.11.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
627	1-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN:LINE CLEAR AVAILED
628	1-Nov-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	15:20 (23.10.2020)	00:11 (01.11.2020)	7:51	LINE CHARGED
629	1-Nov-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
630	1-Nov-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
631	1-Nov-20	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	8:24	18:11	9:47	LINE CLEAR AVAILED
632	1-Nov-20	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED ITNAL_110	(16:22) 23.10.2020)			LINE OPEN:LINE CLEAR AVAILED
633	1-Nov-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN:LINE CLEAR AVAILED
634	1-Nov-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN :LINE FAULT
635	1-Nov-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN:LINE CLEAR AVAILED
636	1-Nov-20	BAGALKOT	110	MRUTYUNJAYANAGAR-GOPANAKOPPA 1	MRUTYUNJAYANAGAR_110	2:18	8:13	5:55	HAND TRIPPED
637	1-Nov-20	BAGALKOT	110	NARENDRA- BELUR1	STATION NOT AFFECTED BELUR_110	7:58	13:21	5:23	LINE FAULT
638	1-Nov-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
639	1-Nov-20	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	18:54 (30.10.2020)			LINE OPEN :LINE FAULT
640	1-Nov-20	BAGALKOT	220	BAGALKOT-GADAG 1	BAGALKOT_220	21:20 (01.11.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
641	1-Nov-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI 2	BAGALKOT_220	21:30 (01.11.2020)			LOAD CURTAILMENT
642	1-Nov-20	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	19:25 (21.10.2020)			LINE OPEN:LINE CLEAR AVAILED
643	1-Nov-20	BAGALKOT	220	BELGAUM- CHIKKODI 1	BELGAUM_220	9:08 (31.10.2020)			LINE OPEN:LINE CLEAR AVAILED
644	1-Nov-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN:LINE CLEAR AVAILED
645	1-Nov-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN:LINE CLEAR AVAILED
646	1-Nov-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN:LINE CLEAR AVAILED
647	1-Nov-20	BAGALKOT	220	HUBLI- NAGJHARI2	HUBLI_220	14:48 (01.11.2020)			LINE OPEN :LINE FAULT
648	1-Nov-20	BAGALKOT	220	SIRSI- SHARAVATHY1	SIRSI_220	21:45 (31.10.2020)	4:28 (01.11.2020)	6:43	LINE CHARGED
649	1-Nov-20	BAGALKOT	220	SIRSI- SHARAVATHY2	SIRSI_220	21:45 (31.10.2020)	4:29 (01.11.2020)	6:44	LINE CHARGED
650	1-Nov-20	BENGALUR U	66	ANJANAPURA - KHODAYS 220	ANJANAPURA	12:52	13:46	0:54	MAIN SUPPLY FAILURE
651	1-Nov-20	BENGALUR U	66	ANJANAPURA - KHODAYS 220	ANJANAPURA	16:56	17:33	0:37	MAIN SUPPLY FAILURE
652	1-Nov-20	BENGALUR U	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN :LINE FAULT
653	1-Nov-20	BENGALUR U	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	12:52	13:50	0:58	MAIN SUPPLY FAILURE
654	1-Nov-20	BENGALUR U	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	16:56	17:35	0:39	MAIN SUPPLY FAILURE
655	1-Nov-20	BENGALUR U	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	12:52	13:17	0:25	MAIN SUPPLY FAILURE
656	1-Nov-20	BENGALUR U	66	HV1	ELECTRONIC CITY P2 S2	13:18	13:40	0:22	TRANSFORMER FAULT
657	1-Nov-20	BENGALUR U	66	HV1	ATTIBELE	11:40	11:45	0:05	LINE CLEAR AVAILED
658	1-Nov-20	BENGALUR U	66	HV2	HANUMANTHNAGARA	12:02	12:55	0:53	LINE CLEAR AVAILED
659	1-Nov-20	BENGALUR U	66	SHOBHA FOREST - KHODAYS 220	SHOBHA FOREST,BRIGADE MEDOWS	12:52	14:05	1:13	MAIN SUPPLY FAILURE
660	1-Nov-20	BENGALUR U	66	SHOBHA FOREST - KHODAYS 220	SHOBHA FOREST,BRIGADE MEDOWS	16:56	17:45	0:49	MAIN SUPPLY FAILURE
661	1-Nov-20	BENGALUR U	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	12:52	13:06	0:14	MAIN SUPPLY FAILURE
662	1-Nov-20	BENGALUR U	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	12:52	13:06	0:14	MAIN SUPPLY FAILURE
663	1-Nov-20	BENGALUR U	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	12:52	13:06	0:14	MAIN SUPPLY FAILURE
664	1-Nov-20	BENGALUR U	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	12:52	13:06	0:14	MAIN SUPPLY FAILURE
665	1-Nov-20	BENGALUR U	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66, ISKON	12:52	13:06	0:14	MAIN SUPPLY FAILURE
666	1-Nov-20	BENGALUR U	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66, ISKON	18:12	18:14	0:02	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
667	1-Nov-20	BENGALUR U	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66, ISKON	13:45	13:47	0:02	LOAD CHANGE OVER
668	1-Nov-20	BENGALUR U	220	KHODAYS 220 - SOMANAHALLI 220	KHODAYS 220	12:52	13:15	0:23	MAIN SUPPLY FAILURE
669	1-Nov-20	BENGALUR U	220	KHODAYS 220 - SUBRAMANYAPURA 220	KHODAYS 220	16:56	17:30	0:34	LOAD CHANGE OVER
670	1-Nov-20	BENGALUR U	220	SOMANAHALLI 220 - KHODAYS 220	KHODAYS 220, SUBRAMANYAPURA 220	12:53	16:48	3:55	LINE FAULT
671	1-Nov-20	BENGALUR U	220	SUBRAMANYAPURA 220 - SOMANAHALLI 220	SUBRAMANYAPURA 220	12:52	13:04	0:12	MAIN SUPPLY FAILURE
672	1-Nov-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN :LINE FAULT
673	1-Nov-20	GULBARGA	110	HV1	CHITGUPPA_110	9:15	9:45	0:30	LINE CLEAR AVAILED
674	1-Nov-20	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110	8:00	8:07	0:07	LINE CLEAR AVAILED
675	1-Nov-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN:LINE CLEAR AVAILED
676	1-Nov-20	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110	2:30	2:40	0:10	LINE FAULT
677	1-Nov-20	GULBARGA	110	SINDHANOOR-MUNIRABAD 2	MUKUNDA_110,KAMPLI_110,YERADO NA_110,SRERAMNAGAR_110,MALLAPUR_110	10:55	11:05	0:10	LINE FAULT
678	1-Nov-20	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	14:19	14:29	0:10	LINE FAULT
679	1-Nov-20	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	9:30	9:52	0:22	LINE CLEAR AVAILED
680	1-Nov-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
681	1-Nov-20	GULBARGA	220	HV2	SEDAM_220	20:15	22:35	2:20	LINE CLEAR AVAILED
682	1-Nov-20	GULBARGA	220	SEDAM-CLNMAX_IPP	SEDAM_220	1:30	1:40	0:10	LINE CLEAR AVAILED
683	1-Nov-20	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:16(31.10.2020)	6:16(1.11.2020)	8:00HRS	LINE CHARGED
684	1-Nov-20	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	23:22			LINE OPEN:LINE CLEAR AVAILED
685	1-Nov-20	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	9:48	10:02	0:14	LINE FAULT
686	1-Nov-20	HASSAN	66	HASSN22-BELUR	HASSAN_220	13:27	14:18	0:51	MAIN SUPPLY FAILURE
687	1-Nov-20	HASSAN	66	HASSN22-CRP1	HASSAN_220	13:27	15:25	1:58	MAIN SUPPLY FAILURE
688	1-Nov-20	HASSAN	66	HASSN22-CRP2	HASSAN_220	13:27	15:25	1:58	MAIN SUPPLY FAILURE
689	1-Nov-20	HASSAN	66	HASSN22-HN PURA	HASSAN_220	13:27	14:18	0:51	MAIN SUPPLY FAILURE
690	1-Nov-20	HASSAN	66	HASSN22-HSN66	HASSAN_220	13:27	14:18	0:51	MAIN SUPPLY FAILURE
691	1-Nov-20	HASSAN	66	HASSN22-SKPURA	HASSAN_220	13:27	14:18	0:51	MAIN SUPPLY FAILURE
692	1-Nov-20	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	13:27	14:18	0:51	MAIN SUPPLY FAILURE
693	1-Nov-20	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	5:18	5:30	0:12	LINE FAULT
694	1-Nov-20	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	5:31	5:55	0:24	LINE FAULT
695	1-Nov-20	HASSAN	66	HNPURA-SOMANAHALLI	MAGGE_66	5:25	6:09	0:44	MAIN SUPPLY FAILURE
696	1-Nov-20	HASSAN	66	HV1	HNPURA_66	5:20	6:02	0:42	MAIN SUPPLY FAILURE
697	1-Nov-20	HASSAN	66	HV1	MAGGE_66	13:27	14:21	0:54	MAIN SUPPLY FAILURE
698	1-Nov-20	HASSAN	66	HV2	HNPURA_66	5:20	6:07	0:47	MAIN SUPPLY FAILURE
699	1-Nov-20	HASSAN	66	HV2	MAGGE_66	13:27	14:21	0:54	MAIN SUPPLY FAILURE
700	1-Nov-20	HASSAN	66	LV1	HASSAN_220	13:27	14:18	0:51	MAIN SUPPLY FAILURE
701	1-Nov-20	HASSAN	66	LV2	HASSAN_220	13:27	14:18	0:51	MAIN SUPPLY FAILURE
702	1-Nov-20	HASSAN	110	LV2	MRSMSG_220	10:47	13:51	3:04	LINE CLEAR AVAILED
703	1-Nov-20	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	8:53	16:49	7:56	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
704	1-Nov-20	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	8:53	16:50	7:57	LINE CLEAR AVAILED
705	1-Nov-20	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	10:42	17:18	6:36	LINE CLEAR AVAILED
706	1-Nov-20	HASSAN	110	MRSSHM-SS1	MRSMSG_220	10:09	10:10	0:01	HAND TRIPPED
707	1-Nov-20	HASSAN	110	MRSSHM-SS1	MRSMSG_220	14:46	14:48	0:02	HAND TRIPPED
708	1-Nov-20	HASSAN	110	MRSSHM-SS2	MRSMSG_220	10:10	10:40	0:30	HAND TRIPPED
709	1-Nov-20	HASSAN	110	MRSSHM-SS2	MRSMSG_220	14:47	14:50	0:03	HAND TRIPPED
710	1-Nov-20	HASSAN	110	SAGARA-JST2	SAGARA_110	12:01(30.10.2020)			LINE OPEN:LINE CLEAR AVAILED
711	1-Nov-20	HASSAN	220	GER SOPA-TALGUPA1	gerusoppa_gen	9:02	12:48	3:46	LINE FAULT
712	1-Nov-20	HASSAN	220	HASSN22-NITTUR	HASSAN_220	13:27	18:13	4:46	LINE FAULT
713	1-Nov-20	HASSAN	220	HV1	HASSAN_220	13:27	14:18	0:51	MAIN SUPPLY FAILURE
714	1-Nov-20	HASSAN	220	HV2	GOPALAPURA_220	17:35(29.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
715	1-Nov-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	9:06	13:28	4:22	NFBC ISSUED
716	1-Nov-20	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	9:01	12:48	3:47	LINE FAULT
717	1-Nov-20	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	14:11 (1.11.2020)			LINE OPEN:LINE CLEAR AVAILED
718	1-Nov-20	HASSAN	220	VARAH1-KEMAR1	varahi_gen	9:06	13:28	4:22	LINE CLEAR AVAILED
719	1-Nov-20	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	14:11 (1.11.2020)			LINE OPEN:LINE CLEAR AVAILED
720	1-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	9:20 (31.10.2020)			LINE OPEN:LINE CLEAR AVAILED
721	1-Nov-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:53 (31.10.2020)	7:52 (1.11.2020)	7:58 hrs	LINE CHARGED
722	1-Nov-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:27 (1.11.2020)			LINE OPEN:LINE CLEAR AVAILED
723	1-Nov-20	MYSORE	66	CR NAGARA -KOLLEGALA	NO STATIONS EFFECTED	12:45	14:16	1:31	NFBC ISSUED
724	1-Nov-20	MYSORE	66	KOLLEGALA-MADHUVANAHALLI	KOLLEGALA_66	13:05	14:10	1:05	NFBC ISSUED
725	1-Nov-20	MYSORE	66	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	12:30	14:30	2:00	HAND TRIPPED
726	1-Nov-20	MYSORE	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	11:35	11:40	0:05	LINE FAULT
727	1-Nov-20	MYSORE	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	12:30	14:21	1:51	HAND TRIPPED
728	1-Nov-20	MYSORE	66	KUSHALNAGARA 220-BETTADAPURA	NO STATIONS EFFECTED	13:58	14:08	0:10	LINE FAULT
729	1-Nov-20	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	13:17	13:25	0:08	LINE FAULT
730	1-Nov-20	MYSORE	220	HV2	KUSHALNAGARA_220	13:58	14:30	0:32	TRANSFORMER FAULT
731	1-Nov-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:08	6:23	0:15	LINE FAULT
732	1-Nov-20	TUMKUR	66	HONNALLI 220KV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	15:10	15:19	0:08	LINE FAULT
733	1-Nov-20	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	11:01	11:39	0:38	LINE FAULT
734	1-Nov-20	TUMKUR	66	TR-1	TUMKUR_66	18:21	18:26	0:05	HAND TRIPPED
735	1-Nov-20	TUMKUR	66	TR-2	BALENAHALLI_66	19:49	20:06	0:16	HAND TRIPPED
736	1-Nov-20	TUMKUR	66	TR-2	TUMKUR_66	18:21	18:26	0:05	HAND TRIPPED
737	1-Nov-20	TUMKUR	66	TR-2	TELAGI_66	12:40	12:56	0:15	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
738	1-Nov-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
739	2-Nov-20	BAGALKOT	66	66/11KV,HV2	HARIHAR-HOSPET_66	12:30	13:05	0:35	LINE CLEAR AVAILED
740	2-Nov-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
741	2-Nov-20	BAGALKOT	110	110/11KV, HV2	HATTARGI_110	12:09	12:49	0:40	LINE CLEAR AVAILED
742	2-Nov-20	BAGALKOT	110	110/11KV,HV1	SIDAPUR_110	18:53	21:18	2:25	LINE CLEAR AVAILED
743	2-Nov-20	BAGALKOT	110	110/33KV, HV3	GHATAPRABHA_110, MANTUR_33, KALLOLLI_33, GOKAK MILLS_33	10:35	18:38	8:03	LINE CLEAR AVAILED
744	2-Nov-20	BAGALKOT	110	110/33KV, HV4	GHATAPRABHA_110, MANTUR_33, KALLOLLI_33, GOKAK MILLS_33	10:35	18:24	7:49	LINE CLEAR AVAILED
745	2-Nov-20	BAGALKOT	110	110/33KV,HV2	SAVALAGI_110,HIREPADASALAGI LIS_33,KALABILAGI_33,TUNGA LIS_33	12:43	13:17	0:34	LINE CLEAR AVAILED
746	2-Nov-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	13:04 (01.11.2020)	9:44 (02.11.2020)	20:38	TRANSFORMER CHARGED
747	2-Nov-20	BAGALKOT	110	BAGALKOT220- LOKAPUR	STATION NOT AFFECTED LOKAPUR_110	23:18 (02.11.2020)			LINE OPEN :LINE FAULT
748	2-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN:LINE CLEAR AVAILED
749	2-Nov-20	BAGALKOT	110	GAMESH-RON	RON_110	22:40	23:19	0:39	HAND TRIPPED
750	2-Nov-20	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA1	GHATAPRABHA_110	12:11	18:33	6:22	LINE CLEAR AVAILED
751	2-Nov-20	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA1	GHATAPRABHA_110	12:11	20:24	8:13	LINE CLEAR AVAILED
752	2-Nov-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
753	2-Nov-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
754	2-Nov-20	BAGALKOT	110	HAVERI220- HANGAL	HANGAL_110	13:00	13:29	0:29	LINE CLEAR AVAILED
755	2-Nov-20	BAGALKOT	110	HAVERI220- SAVANUR	STATION NOT AFFECTED SAVANUR_110	8:11	18:28	10:17	LINE CLEAR AVAILED
756	2-Nov-20	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED ITNAL_110	(16:22) 23.10.2020)			LINE OPEN:LINE CLEAR AVAILED
757	2-Nov-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN:LINE CLEAR AVAILED
758	2-Nov-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN :LINE FAULT
759	2-Nov-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN:LINE CLEAR AVAILED
760	2-Nov-20	BAGALKOT	110	RON-HIREHAL	STATION NOT AFFECTED HIREHAL_110	22:40	23:19	0:39	HAND TRIPPED
761	2-Nov-20	BAGALKOT	110	SODATTI220-UDIKERI(RAMDURGA1)	STATION NOT AFFECTED UDIKERI_110	11:52	12:29	0:37	LINE FAULT
762	2-Nov-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
763	2-Nov-20	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	18:54 (30.10.2020)	10:29 (02.11.2020)	15:35	LINE CHARGED
764	2-Nov-20	BAGALKOT	220	BAGALKOT-GADAG 1	BAGALKOT_220	21:20 (01.11.2020)	9:02 (02.11.2020)	11:42	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
765	2-Nov-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1	BAGALKOT_220	21:30 (01.11.2020)	9:46 (02.11.2020)	11:32	LINE CHARGED
766	2-Nov-20	BAGALKOT	220	BAGEWADI- ATRIA1	BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN:LINE CLEAR AVAILED
767	2-Nov-20	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	19:25 (21.10.2020)	15:45 (02.11.2020)	20:20	LINE CHARGED
768	2-Nov-20	BAGALKOT	220	BELGAUM- CHIKKODI 1	BELGAUM_220	9:08 (31.10.2020)	14:45 (02.11.2020)	5:37	LINE CHARGED
769	2-Nov-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN:LINE CLEAR AVAILED
770	2-Nov-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN:LINE CLEAR AVAILED
771	2-Nov-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN:LINE CLEAR AVAILED
772	2-Nov-20	BAGALKOT	220	HUBLI- NAGJHARI1	STATION NOT AFFECTED HUBLI_220	10:55	15:36	4:41	LINE CLEAR AVAILED
773	2-Nov-20	BAGALKOT	220	HUBLI- NAGJHARI2	HUBLI_220	14:48 (01.11.2020)	15:36 (02.11.2020)	0:48	LINE CHARGED
774	2-Nov-20	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	12:16	19:01	6:45	LINE FAULT
775	2-Nov-20	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	12:16 (02.11.2020)			LINE OPEN :LINE FAULT
776	2-Nov-20	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	12:17 (02.11.2020)			LINE OPEN :LINE FAULT
777	2-Nov-20	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	12:17 (02.11.2020)			LINE OPEN :LINE FAULT
778	2-Nov-20	BENGALUR U	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN :LINE FAULT
779	2-Nov-20	BENGALUR U	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN :LINE FAULT
780	2-Nov-20	BENGALUR U	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	17:01	17:09	0:08	LINE FAULT
781	2-Nov-20	BENGALUR U	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	17:01	17:09	0:08	LINE FAULT
782	2-Nov-20	BENGALUR U	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	13:41	13:57	0:16	LINE FAULT
783	2-Nov-20	BENGALUR U	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	13:41	13:57	0:16	LINE FAULT
784	2-Nov-20	BENGALUR U	66	HSR LAYOUT 220 - ADUGODI 1	JAKKASANDRA	13:15	13:18	0:03	LOAD CHANGE OVER
785	2-Nov-20	BENGALUR U	66	HSR LAYOUT 220 - ADUGODI 1	JAKKASANDRA	13:15	13:18	0:03	LOAD CHANGE OVER
786	2-Nov-20	BENGALUR U	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	13:15	13:18	0:03	LOAD CHANGE OVER
787	2-Nov-20	BENGALUR U	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	13:15	13:18	0:03	LOAD CHANGE OVER
788	2-Nov-20	BENGALUR U	66	HV1	GOLF LINK	10:56	14:00	3:04	TRANSFORMER FAULT
789	2-Nov-20	BENGALUR U	66	HV1	GOLF LINK	10:56	14:00	3:04	TRANSFORMER FAULT
790	2-Nov-20	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	17:30	19:10	1:40	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
791	2-Nov-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN :LINE FAULT
792	2-Nov-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN:LINE CLEAR AVAILED
793	2-Nov-20	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	2:38	2:46	0:08	LINE FAULT
794	2-Nov-20	GULBARGA	110	SHAHABAD-RAICHUR2	SHAHABAD_220	2:28	2:36	0:08	LINE FAULT
795	2-Nov-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
796	2-Nov-20	GULBARGA	220	HV2	ITTAGI_220	22:15	22:45	0:30	TRANSFORMER FAULT
797	2-Nov-20	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	23:22(01.11.2020)	7:25(02.11.2020)	8:03HRS	LINE CHARGED
798	2-Nov-20	HASSAN	66	SAKALE-IPCL2	SAKALESH PURA_66	11:40	11:56	0:16	HAND TRIPPED
799	2-Nov-20	HASSAN	110	HULICA-KVR	HULICAL_110	9:45	13:50	4:05	LINE CLEAR AVAILED
800	2-Nov-20	HASSAN	110	HV1	ALKOLA_110	11:06	12:00	0:54	LINE CLEAR AVAILED
801	2-Nov-20	HASSAN	110	HV1	KONAJE_110	9:40	9:44	0:04	HAND TRIPPED
802	2-Nov-20	HASSAN	110	HV2	KONAJE_110	9:40	9:44	0:04	HAND TRIPPED
803	2-Nov-20	HASSAN	110	HV3	KONAJE_110	9:40	9:44	0:04	HAND TRIPPED
804	2-Nov-20	HASSAN	110	JOG-JST1	mghejog_gen	9:50	10:40	0:50	LINE FAULT
805	2-Nov-20	HASSAN	110	SAGARA-JST1	SAGARA_110	10:25	10:55	0:30	HAND TRIPPED
806	2-Nov-20	HASSAN	110	SAGARA-JST2	SAGARA_110	12:01(30.10.2020)			LINE OPEN:LINE CLEAR AVAILED
807	2-Nov-20	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	8:25	9:35	1:10	LINE FAULT
808	2-Nov-20	HASSAN	110	SINGATG-YAGATI	SINGATGERE_110	8:30	12:15	3:45	LINE CLEAR AVAILED
809	2-Nov-20	HASSAN	220	HV2	GOPALAPURA_220	17:35(29.10.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
810	2-Nov-20	HASSAN	220	MRSSHM-VARAH1	MRS MG_220	14:11 (1.11.2020)	19:18 (2.11.2020)	29:6 hrs	LINE CHARGED
811	2-Nov-20	HASSAN	220	MRSSHM-VARAH1	MRS MG_220	19:51 (2.11.2020)			LINE OPEN:LINE CLEAR AVAILED
812	2-Nov-20	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	14:11 (1.11.2020)	19:18 (2.11.2020)	29:6 hrs	LINE CHARGED
813	2-Nov-20	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	19:51 (2.11.2020)			LINE OPEN:LINE CLEAR AVAILED
814	2-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	9:20 (31.10.2020)	7:35 (2.11.2020)	46:14 hrs	LINE CHARGED
815	2-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	7:43(2.11.2020)			LINE OPEN:LINE CLEAR AVAILED
816	2-Nov-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:27 (1.11.2020)	6:34 (2.11.2020)	9:6 hrs	LINE CHARGED
817	2-Nov-20	MYSORE	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66 AJJIPURA_66	13:45	13:55	0:10	LINE FAULT
818	2-Nov-20	MYSORE	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66 AJJIPURA_66	18:57	19:04	0:07	HAND TRIPPED
819	2-Nov-20	MYSORE	66	HV1	MADHUVANAHALLI_220	18:45	18:50	0:05	TRANSFORMER FAULT
820	2-Nov-20	MYSORE	66	HV2	SANTHEMARAHALLI_66	12:25	15:56	3:31	LINE CLEAR AVAILED
821	2-Nov-20	MYSORE	66	HV2	SUTTUR_66	12:35	13:33	0:58	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
822	2-Nov-20	MYSORE	66	HV2	MADHUVANAHALLI_220	13:48 (02/11/2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
823	2-Nov-20	MYSORE	66	SFC SIVA-HEBBANI 6	NO STATIONS EFFECTED	2:25	2:50	0:24	LINE FAULT
824	2-Nov-20	MYSORE	66	SFC SIVA-PGL	NO STATIONS EFFECTED	2:24	2:37	0:12	LINE FAULT
825	2-Nov-20	MYSORE	220	HV1	MADHUVANAHALLI_220	13:48	14:00	0:12	TRANSFORMER FAULT
826	2-Nov-20	MYSORE	220	HV1	MADHUVANAHALLI_220	18:45	18:50	0:05	TRANSFORMER FAULT
827	2-Nov-20	MYSORE	220	HV2	MADHUVANAHALLI_220	18:45	18:50	0:05	TRANSFORMER FAULT
828	2-Nov-20	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	8:04	9:07	1:03	LINE CLEAR AVAILED
829	2-Nov-20	TUMKUR	66	GULIGENAHALLI- SIRA	GULIGENAHALLI_66	7:46	7:53	0:07	LINE FAULT
830	2-Nov-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:18	13:29	0:11	LINE FAULT
831	2-Nov-20	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	14:17	14:25	0:07	LINE FAULT
832	2-Nov-20	TUMKUR	66	SIRA- MADHUGIRI 1	BUKKAPATNA_66, KALLAMBELLA_66	7:55	7:57	0:01	MAIN SUPPLY FAILURE
833	2-Nov-20	TUMKUR	66	TR-1	AMRUTHUR_66	7:59	8:09	0:10	MAIN SUPPLY FAILURE
834	2-Nov-20	TUMKUR	66	TR-1	TUMKUR_66	9:10	9:15	0:05	LINE CLEAR AVAILED
835	2-Nov-20	TUMKUR	66	TR-2	BALENAHALLI_66	10:46	12:22	1:35	LINE CLEAR AVAILED
836	2-Nov-20	TUMKUR	66	TR-2	BALENAHALLI_66	16:13	16:30	0:17	LINE CLEAR AVAILED
837	2-Nov-20	TUMKUR	66	TR-2	HALUVAGALU_66	8:34	8:42	0:07	TRANSFORMER FAULT
838	2-Nov-20	TUMKUR	66	TR-2	HARIYABBE_66	7:31	7:40	0:08	TRANSFORMER FAULT
839	2-Nov-20	TUMKUR	66	TR-2	TUMKUR_66	9:10	9:13	0:02	LINE CLEAR AVAILED
840	2-Nov-20	TUMKUR	110	TR-1	NITTUR_220	9:26	17:32	8:05	LINE CLEAR AVAILED
841	2-Nov-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
842	2-Nov-20	TUMKUR	220	TR-1	NITTUR_220	9:27	17:30	8:03	LINE CLEAR AVAILED
843	3-Nov-20	MYSORE	66	HV2	MADHUVANAHALLI_220	13:48 (02/11/2020)	10:27 (03/11/2020)	20.39 HRS	LINE CHARGED