

**400/220/110/66 kV TRANSMISSION OUTAGES FROM : 19.07.22 TO 25.07.22**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	19-Jul-22	BAGALKOT	110	110/11KV, HV1	ANMOD_110	10:50	13:01	2:11	LINE CLEAR AVAILED
2	19-Jul-22	BAGALKOT	110	110/11KV,HV1	HIRESASALI_110	22:15	22:20	0:05	TRANSFORMER FAULT
3	19-Jul-22	BAGALKOT	110	110/11KV,HV1	RATTIHALI_110	16:49	18:35	1:46	LINE CLEAR AVAILED
4	19-Jul-22	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	16:14	18:13	1:59	LINE CLEAR AVAILED
5	19-Jul-22	BAGALKOT	110	110/11KV,HV2	MUKARTIHAL_110	6:09	6:30	0:21	LINE CLEAR AVAILED
6	19-Jul-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED TODALBAGI_110	19:13 (17.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
7	19-Jul-22	BAGALKOT	110	110/11KV,HV2	THORVI_110	20:44	20:49	0:05	TRANSFORMER FAULT
8	19-Jul-22	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
9	19-Jul-22	BAGALKOT	110	110/33KV, HV-3	STATION NOT AFFECTED ANKALI_110	12:05	13:05	1:00	LINE CLEAR AVAILED
10	19-Jul-22	BAGALKOT	110	110/33KV,HV1	BAILHONGAL_110 &SAMPGOAN,MURGOD_33	15:43	17:34	1:51	LINE CLEAR AVAILED
11	19-Jul-22	BAGALKOT	110	110/33KV,HV3	ANKALI_110 & NANDIKULRAI_33	12:09	13:04	0:55	LINE CLEAR AVAILED
12	19-Jul-22	BAGALKOT	110	110/33KV,HV3	GHATAPRABHA_110 & KALLOLI,HYDRO_33	13:30	13:39	0:09	TRANSFORMER FAULT
13	19-Jul-22	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	18:07	18:21	0:14	HAND TRIPPED
14	19-Jul-22	BAGALKOT	110	220/110KV, LV2 (LV4)	STATION NOT AFFECTED GADAG_220	11:51	19:23	7:32	LINE CLEAR AVAILED
15	19-Jul-22	BAGALKOT	110	AIGALI-SAVALAGI	AIGALI_110 (STATION NOT AFFECTED)	17:24	17:33	0:09	HAND TRIPPED
16	19-Jul-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVAILED
17	19-Jul-22	BAGALKOT	110	ANKOLA-ARGA(L1)	ANKOLA_110	10:09	16:58	6:49	LINE CLEAR AVAILED
18	19-Jul-22	BAGALKOT	110	ATHANI-AIGALI	AIGALI_110 (STATION NOT AFFECTED)	10:00	17:24	7:24	LINE CLEAR AVAILED
19	19-Jul-22	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	0:43	0:52	0:09	LINE FAULT
20	19-Jul-22	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	2:06	2:16	0:10	LINE FAULT
21	19-Jul-22	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	10:50 (26.03.2022)			LINE OPEN:LINE CLEAR AVAILED
22	19-Jul-22	BAGALKOT	110	GHATAPRABHA220- SOEPL (SURYODAYA SOLAR)	SURYODAYA SOLAR STATION NOT AFFECTED GHATAPRABHA_220	7:32	8:08	0:36	LINE FAULT
23	19-Jul-22	BAGALKOT	110	GHATAPRABHA220-KABBUR	NAGARMUNAVALLI_110	0:40	1:01	0:21	LINE FAULT
24	19-Jul-22	BAGALKOT	110	HAVERI220- BYADAGI	STATION NOT AFFECTED BYADAGI_110	10:53	15:08	4:15	LINE CLEAR AVAILED
25	19-Jul-22	BAGALKOT	110	HAVERI220- BYADAGI	STATION NOT AFFECTED HAVERI_220	10:33	14:50	4:17	LINE CLEAR AVAILED
26	19-Jul-22	BAGALKOT	110	HUNGUND-KUDALASANGAM	KUDALSANGAM_110	21:36	21:49	0:13	LINE FAULT
27	19-Jul-22	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	8:50 (06.07.2022)			LINE OPEN:LINE FAULT
28	19-Jul-22	BAGALKOT	110	KARWAR220- ARGA	ARGA_110	14:01	14:02	0:01	HAND TRIPPED
29	19-Jul-22	BAGALKOT	110	KUD DHARAWAD-LAKAMANAHALLI	LAKAMANAHALLI_110	14:33	16:57	2:24	LINE CLEAR AVAILED
30	19-Jul-22	BAGALKOT	110	MR-NAGAR-UAS DHARWAD	STATION NOT AFFECTED MR NAGAR_110	20:15 (18.07.2022)	11:08 (19.07.2022)	14:53 hrs	LINE CHARGED
31	19-Jul-22	BAGALKOT	110	MUGALKHOD220-MAHALINGAPUR220	STATION NOT AFFECTED MUGALKHOD_220	14:30 (18.07.2022)	13:36 (19.7.22)	23:06 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
32	19-Jul-22	BAGALKOT	110	NARENDRA220-MR NAGAR	STATION NOT AFFECTED MR NAGAR_110	20:15 (18.07.2022)	11:08 (19.07.2022)	14:53 hrs	LINE CHARGED
33	19-Jul-22	BAGALKOT	110	NARENDRA-KUD DHARWAD	KUD DHARWAD_110	12:54	14:32	1:38	LINE CLEAR AVAIED
34	19-Jul-22	BAGALKOT	110	VAJJRAMATTI220- BILAGI (SHIRAGUPPI)	SHIRGUPPI_110 BILAGI_110 BISNAL_110 GIRISAGAR_110 TOLAMATTI_110	5:55	6:00	0:05	LINE FAULT
35	19-Jul-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	18:07	18:19	0:12	HAND TRIPPED
36	19-Jul-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
37	19-Jul-22	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED KUDACHI_220	10:30	15:55	5:25	LINE CLEAR AVAIED
38	19-Jul-22	BAGALKOT	220	220/110KV, HV2 & LV2	STATION NOT AFFECTED KARWAR_220	10:32 (18.07.2022)	17:50 (19.07.2022)	31:18 hrs	TRANSFORMER CHARGED
39	19-Jul-22	BAGALKOT	220	220/110KV, HV2 (HV4)	STATION NOT AFFECTED GADAG_220	11:51	19:21	7:30	LINE CLEAR AVAIED
40	19-Jul-22	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED ATHANI_220	9:41 (06.07.2022)			TRANSFORMER:LINE CLEAR AVAIED
41	19-Jul-22	BAGALKOT	220	220/110KV, HV3 & LV3	STATION NOT AFFECTED SOUDATTI_220	10:52 (19.07.2022)			TRANSFORMER:LINE CLEAR AVAIED
42	19-Jul-22	BAGALKOT	220	DHONI-LGPR(HALAVARTHI)-1	STATION NOT AFFECTED DHONI_400	15:31	20:38	5:07	LINE CLEAR AVAIED
43	19-Jul-22	BAGALKOT	220	DHONI-LGPR(HALAVARTHI)-2	STATION NOT AFFECTED DHONI_400	15:29	20:38	5:09	LINE CLEAR AVAIED
44	19-Jul-22	BAGALKOT	220	GADAG-HARTI-1	STATION NOT AFFECTED GADAG_220	10:55 (19.07.2020)			LINE OPEN:LINE CLEAR AVAIED
45	19-Jul-22	BAGALKOT	220	GADAG-HARTI-2	STATION NOT AFFECTED GADAG_220	10:55 (19.07.2020)			LINE OPEN:LINE CLEAR AVAIED
46	19-Jul-22	BAGALKOT	220	KADRA - KARWAR-2	STATION NOT AFFECTED KARWAR_220	13:46	13:51	0:05	HAND TRIPPED
47	19-Jul-22	BAGALKOT	220	KARWAR-KADRA-1	STATION NOT AFFECTED KARWAR_220	13:51	13:54	0:03	HAND TRIPPED
48	19-Jul-22	BAGALKOT	220	NAGAJHARI-AMBEWADI-1 (NA1)	STATION NOT AFFECTED AMBEWADI_220	17:08	17:12	0:04	HAND TRIPPED
49	19-Jul-22	BAGALKOT	220	NAGAJHARI-AMBEWADI-1 (NA1)	STATION NOT AFFECTED AMBEWADI_220	17:20	18:48	1:28	LINE CLEAR AVAIED
50	19-Jul-22	BAGALKOT	220	NAGAJHARI-AMBEWADI-1 (NA1)	STATION NOT AFFECTED AMBEWADI_220	19:16	19:59	0:43	LOAD CHANGEOVER
51	19-Jul-22	BAGALKOT	220	NAGAJHARI-AMBEWADI-2 (NA2)	STATION NOT AFFECTED AMBEWADI_220	17:09	18:26	1:17	LINE FAULT
52	19-Jul-22	BAGALKOT	220	NAGAJHARI-AMBEWADI-2 (NA2)	STATION NOT AFFECTED AMBEWADI_220	19:26	19:59	0:33	LOAD CHANGEOVER
53	19-Jul-22	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN:LINE CLEAR AVAIED
54	19-Jul-22	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN:LINE CLEAR AVAIED
55	19-Jul-22	BENGALURU	66	BAIRPATNA(SANKALGERE) - SOLAR (IPP)	NO STATION AFFECTED	15:22	17:20	1:58	LINE CLEAR AVAIED
56	19-Jul-22	BENGALURU	66	CHIKKENAHALLI - CHANNAPTANA	SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	16:09	16:20	0:11	LINE CLEAR AVAIED
57	19-Jul-22	BENGALURU	66	DOMMASANDRA - KACHMARANAHALLI	DOMMASANDRA	14:40	14:50	0:10	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
58	19-Jul-22	BENGALURU	66	DRDO(EHT) - MALLASANDRA	MALLASANDRA/TD HALLI, DALSNUR, YELDUR	19:30	20:00	0:30	LOAD CURTAILMENT
59	19-Jul-22	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL, PERESANDRA	7:20	8:15	0:55	LOAD CURTAILMENT
60	19-Jul-22	BENGALURU	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	11:00	13:00	2:00	LINE CLEAR AVOIDED
61	19-Jul-22	BENGALURU	66	HOODY 220 - BMRCL	NO STATION AFFECTED	12:31(17/07/2022)			LINE OPEN:LINE FAULT
62	19-Jul-22	BENGALURU	66	HV1	BAIRPATNA(SANKALGERE)	10:00	17:21	7:20	LINE CLEAR AVOIDED
63	19-Jul-22	BENGALURU	66	HV1	BRIGADE GATEWAY	11:08	11:10	0:02	LINE CLEAR AVOIDED
64	19-Jul-22	BENGALURU	66	HV1	BRIGADE GATEWAY	15:43	15:45	0:02	LOAD CHANGEOVER
65	19-Jul-22	BENGALURU	66	HV1	DASHAVARA	10:03	17:43	7:40	LINE CLEAR AVOIDED
66	19-Jul-22	BENGALURU	66	HV1	JIGANI 220	16:20	16:30	0:10	MAIN SUPPLY FAILURE
67	19-Jul-22	BENGALURU	66	HV1	JIGANI 220	17:32	17:48	0:16	MAIN SUPPLY FAILURE
68	19-Jul-22	BENGALURU	66	HV1	KANAKPURA 66	15:05	17:04	1:59	LINE CLEAR AVOIDED
69	19-Jul-22	BENGALURU	66	HV1	MATHIKERE NELAMANGALA	12:35	12:58	0:23	LINE CLEAR AVOIDED
70	19-Jul-22	BENGALURU	66	HV1	TUBGERE	11:08	11:33	0:25	LINE CLEAR AVOIDED
71	19-Jul-22	BENGALURU	66	HV1	VR DODDI	6:49	6:54	0:05	TRANSFORMER FAULT
72	19-Jul-22	BENGALURU	66	HV2	JIGANI 220	16:20	16:30	0:10	MAIN SUPPLY FAILURE
73	19-Jul-22	BENGALURU	66	HV2	JIGANI 220	17:32	17:48	0:16	MAIN SUPPLY FAILURE
74	19-Jul-22	BENGALURU	66	HV2	KANAKPURA 66	10:04	17:00	6:55	LINE CLEAR AVOIDED
75	19-Jul-22	BENGALURU	66	HV2	SARJAPURA 220	15:13	15:54	0:41	LINE CLEAR AVOIDED
76	19-Jul-22	BENGALURU	66	HV2	SIDLAGHATTA	10:54	11:00	0:06	LINE CLEAR AVOIDED
77	19-Jul-22	BENGALURU	66	HV2	SIDLAGHATTA	16:26	16:28	0:01	TRANSFORMER FAULT
78	19-Jul-22	BENGALURU	66	HV2	TYMAGONDLU	11:53	12:13	0:19	LINE CLEAR AVOIDED
79	19-Jul-22	BENGALURU	66	HV3	SARAKKI	15:10	16:26	1:16	LINE CLEAR AVOIDED
80	19-Jul-22	BENGALURU	66	JAGANI 220 - JIGANI 66	JIGANI 66, JIGANI LINK ROAD, KIRLOSKAR (EHT)	17:32	17:38	0:06	MAIN SUPPLY FAILURE
81	19-Jul-22	BENGALURU	66	JAGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGANDODDI	16:20	16:30	0:10	MAIN SUPPLY FAILURE
82	19-Jul-22	BENGALURU	66	JAGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGANDODDI	17:32	17:48	0:16	MAIN SUPPLY FAILURE
83	19-Jul-22	BENGALURU	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	15:15	17:00	1:45	LINE CLEAR AVOIDED
84	19-Jul-22	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR	11:20	12:41	1:21	LINE CLEAR AVOIDED
85	19-Jul-22	BENGALURU	66	KOLAR 220 - THAYLUR	TAMAKA	10:02	12:41	2:39	LINE CLEAR AVOIDED
86	19-Jul-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	7:15	7:50	0:35	LOAD CURTAILMENT
87	19-Jul-22	BENGALURU	66	KORAMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	12:57	13:39	0:42	LINE FAULT
88	19-Jul-22	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	10:22	10:26	0:04	LOAD CHANGEOVER
89	19-Jul-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:19	11:35	0:15	LINE CLEAR AVOIDED
90	19-Jul-22	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	NO STATION AFFECTED	4:47	6:29	1:42	LINE FAULT
91	19-Jul-22	BENGALURU	66	T GOLLAHALLI 220 - ANDERSONPETE	DODDAKARI, KYASAMBALLI, ANDERSONPETE	16:19	16:34	0:15	LINE FAULT
92	19-Jul-22	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	5:40	5:50	0:10	MAIN SUPPLY FAILURE
93	19-Jul-22	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	5:40	5:50	0:10	MAIN SUPPLY FAILURE
94	19-Jul-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR,K HONALGERE, YATHAMBADI	5:40	5:50	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
95	19-Jul-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	5:40	5:50	0:10	MAIN SUPPLY FAILURE
96	19-Jul-22	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	5:40	5:50	0:10	MAIN SUPPLY FAILURE
97	19-Jul-22	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	5:40	5:57	0:17	LINE FAULT
98	19-Jul-22	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	HALAGUR, HONNIGANAHALLI, DODDALAHALLI, SATHNUR (ACHLU)	5:40	5:50	0:10	MAIN SUPPLY FAILURE
99	19-Jul-22	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTUR	NO STATION AFFECTED	14:17	14:22	0:05	LINE FAULT
100	19-Jul-22	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	NO STATION AFFECTED	12:03	13:26	1:22	LINE FAULT
101	19-Jul-22	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	NO STATION AFFECTED	13:32	15:07	1:34	LINE FAULT
102	19-Jul-22	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	NO STATION AFFECTED	15:15	15:43	0:28	LINE FAULT
103	19-Jul-22	BENGALURU	220	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	13:54	15:26	1:31	LOAD CURTAILMENT
104	19-Jul-22	BENGALURU	220	HV1	JIGANI 220	16:20	17:48	1:28	LINE CLEAR AVOIDED
105	19-Jul-22	BENGALURU	220	HV2	JIGANI 220	17:32	17:38	0:06	MAIN SUPPLY FAILURE
106	19-Jul-22	BENGALURU	220	HV2	TK HALLI 220	5:40	5:48	0:08	TRANSFORMER FAULT
107	19-Jul-22	BENGALURU	220	JIGANI 220 - MYLASANDRA 400	JIGANI 220	17:32	17:37	0:05	LINE FAULT
108	19-Jul-22	GULBARGA	66	HIREHADAGALI-SUZLON2WIND	HIREHADAGALI_66	17:45	18:10	0:25	LINE CLEAR AVOIDED
109	19-Jul-22	GULBARGA	66	HIREHADAGALI-SUZLON2WIND	HIREHADAGALI_66	18:12	18:20	0:08	LINE CLEAR AVOIDED
110	19-Jul-22	GULBARGA	66	HV1	BENNEHALLI_66	9:35	9:45	0:10	TRANSFORMER FAULT
111	19-Jul-22	GULBARGA	110	ADAVI AMARESHWAR-JAWALGERA	ADAVI AMARESHWAR_110	12:11	12:25	0:14	LINE CLEAR AVOIDED
112	19-Jul-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110	12:45	13:00	0:15	MAIN SUPPLY FAILURE
113	19-Jul-22	GULBARGA	110	GULBARGA UNIVERCITY-GUBARGA NORTH -2	GUBARGA NORTH_110	10:40	14:56	4:16	LINE CLEAR AVOIDED
114	19-Jul-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	0:23	0:26	0:03	LINE FAULT
115	19-Jul-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	12:59	13:34	0:35	LOAD CURTAILMENT
116	19-Jul-22	GULBARGA	110	HUMNABAD-MANEIKHELLI	MANAIKHELLI_110	12:58	13:36	0:38	LOAD CURTAILMENT
117	19-Jul-22	GULBARGA	110	HV1	NAVALI_110	16:20	18:22	2:02	LINE CLEAR AVOIDED
118	19-Jul-22	GULBARGA	110	HV2	SREERAMANAGAR_110	8:45	8:51	0:06	TRANSFORMER FAULT
119	19-Jul-22	GULBARGA	110	LV1	ITTAGI_220	23:35 (19.07.2022)			TRANSFORMER:LINE CLEAR AVOIDED
120	19-Jul-22	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110, MANVI_110	20:44	20:48	0:04	LINE FAULT
121	19-Jul-22	GULBARGA	110	MUDDAPUR-MASKI	MUDDAPUR_110	0:50	0:55	0:05	LINE FAULT
122	19-Jul-22	GULBARGA	110	NEELGUNDA-HARAPANAHALLI	HARAPANAHALLI_110	6:37	6:51	0:14	LINE FAULT
123	19-Jul-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	7:28	8:03	0:35	LOAD CURTAILMENT
124	19-Jul-22	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORWAR TEMPLE_110	6:55	7:15	0:20	LINE FAULT
125	19-Jul-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	5:24	5:45	0:21	LINE FAULT
126	19-Jul-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	0:25	0:37	0:12	LINE FAULT
127	19-Jul-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	3:49	9:24	5:35	LINE FAULT
128	19-Jul-22	GULBARGA	110	SINDHNOOR-SINDHNOOR2	SINDHNOOR_110,VALKAMDINNI_110,BYAGWAT_110	20:25	20:35	0:10	LINE FAULT
129	19-Jul-22	GULBARGA	110	SINDHNOOR-VALABELLARI	MANVI_110,MADLAPUR_110,KURDICROSS_110,ADVIAMRESHWAR_110,JAWALGERA_110	21:00	21:15	0:15	LINE FAULT
130	19-Jul-22	GULBARGA	110	SULEKAL-MARALIHALLI	MUKUNDA_110, YEREDONA_110,BENNUR SOLAR_IPP	19:44	19:51	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
131	19-Jul-22	GULBARGA	220	HALAWARTHY-DHONI1	HALAWARTHY_220	7:12 (5.07.2022)	20:38(19.07.2022)	349:26HRS	LINE CHARGED
132	19-Jul-22	GULBARGA	220	HALAWARTHY-DHONI2	HALAWARTHY_220	7:45 (5.07.2022)	20:38(19.07.2022)	348:53HRS	LINE CHARGED
133	19-Jul-22	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	23:05(18/07/2022)	06:28(19/07/2022)	07:23HRS	LINE CHARGED
134	19-Jul-22	GULBARGA	220	HV1	ITTAGI_220	17:44	19:40	1:56	LINE CLEAR AVAILED
135	19-Jul-22	GULBARGA	220	HV2	ITTAGI_220	19:43	20:08	0:25	LINE CLEAR AVAILED
136	19-Jul-22	GULBARGA	220	HV2	SINDHNOOR_220	17:00	17:30	0:30	LINE CLEAR AVAILED
137	19-Jul-22	GULBARGA	220	ITTAGI-BMMISPAT	ITTAGI_220	23:00	23:35	0:35	LINE CLEAR AVAILED
138	19-Jul-22	GULBARGA	220	ITTAGI-EMBASSY_IPP	EMBASSY_IPP	20:20	22:43	2:23	LINE CLEAR AVAILED
139	19-Jul-22	GULBARGA	220	ITTAGI-HARAKNAL_IPP	ITTAGI_220	21:05	22:55	1:50	LINE CLEAR AVAILED
140	19-Jul-22	GULBARGA	220	ITTAGI-NEELAGUNDA	ITTAGI_220	16:00	17:40	1:40	LINE CLEAR AVAILED
141	19-Jul-22	GULBARGA	220	KAPNOOR-WEST1	GULBARGA WEST_110,GULBARGA SOUTH_110	10:35	14:56	4:21	LINE CLEAR AVAILED
142	19-Jul-22	GULBARGA	220	KAPNOOR-WEST2	GULBARGA WEST_110,GULBARGA SOUTH_110	19:18	19:30	0:12	LINE FAULT
143	19-Jul-22	GULBARGA	220	LINGASUGUR-RTPS1	RTPS_220	2:46	3:06	0:20	LINE FAULT
144	19-Jul-22	GULBARGA	220	NEELGUNDA-ITTAGI	ITTAGI_220	16:49	17:37	0:48	LINE CLEAR AVAILED
145	19-Jul-22	GULBARGA	220	SEDAM_SHAHAPUR	SEDAM_220	05:48(10/06/2022)			LINE OPEN:LINE CLEAR AVAILED
146	19-Jul-22	GULBARGA	220	SEDAM-RTPS_1	SEDAM_220	3:40	4:23	0:43	LINE FAULT
147	19-Jul-22	GULBARGA	400	BTPS-HIRIYUR2	HIRYUR_400	01:07(16/07/2022)	10:27 (19.07.2022)	81:20 HRS	LINE CHARGED
148	19-Jul-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
149	19-Jul-22	GULBARGA	400	YTPS-BPS_2	BPS_400	12:22	14:30	2:08	LINE CLEAR AVAILED
150	19-Jul-22	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	17:00	17:31	0:31	LINE FAULT
151	19-Jul-22	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	17:00	17:24	0:24	LINE FAULT
152	19-Jul-22	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	12:18	12:21	0:03	LINE FAULT
153	19-Jul-22	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	12:35	12:45	0:10	LINE FAULT
154	19-Jul-22	HASSAN	66	CHIKABO-SIDPR	CHIKABOMMENAHALLI_66	12:48	12:50	0:02	HAND TRIPPED
155	19-Jul-22	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	10:36	10:38	0:02	HAND TRIPPED
156	19-Jul-22	HASSAN	66	HV1	BALEHONNUR_66	16:29	17:33	1:04	LINE CLEAR AVAILED
157	19-Jul-22	HASSAN	66	HV1	SINGAPURA_66	11:15	12:01	0:46	LINE CLEAR AVAILED
158	19-Jul-22	HASSAN	66	HV2	HALEBEEDU_66	14:35	15:39	1:04	LINE CLEAR AVAILED
159	19-Jul-22	HASSAN	66	SAKALE-HASSAN1	SAKLESH PURA_66	12:11	12:20	0:09	LINE FAULT
160	19-Jul-22	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	18:28	18:36	0:08	LINE FAULT
161	19-Jul-22	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	10:30	16:30	6:00	LINE CLEAR AVAILED
162	19-Jul-22	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJANUR_110	8:56	12:28	3:32	NFBC ISSUED
163	19-Jul-22	HASSAN	110	GURUPUR-MDBDRE	GURUPURA_110	12:13	13:20	1:07	MAIN SUPPLY FAILURE
164	19-Jul-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER:LINE CLEAR AVAILED
165	19-Jul-22	HASSAN	110	HV4	SHIRALKOPPA_110	10:09	12:24	2:15	LINE CLEAR AVAILED
166	19-Jul-22	HASSAN	110	KADUR-AJAMPURA	KADUR_220	14:11	15:33	1:22	MAIN SUPPLY FAILURE
167	19-Jul-22	HASSAN	110	KADUR-NERELEKERE	KADUR_220	14:11	15:33	1:22	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
168	19-Jul-22	HASSAN	110	KADUR-NGNHL	KADUR_220	14:11	15:33	1:22	MAIN SUPPLY FAILURE
169	19-Jul-22	HASSAN	110	KADUR-TNGL	KADUR_220	14:11	15:34	1:23	MAIN SUPPLY FAILURE
170	19-Jul-22	HASSAN	110	KADUR-YGTI	KADUR_220	14:11	15:33	1:22	MAIN SUPPLY FAILURE
171	19-Jul-22	HASSAN	110	KAVOOR-AMR	KAVOOR_220	9:33	16:48	7:15	LINE CLEAR AVAIED
172	19-Jul-22	HASSAN	110	LV2	SHIRALKOPPA_220	11:10	18:22	7:12	LINE CLEAR AVAIED
173	19-Jul-22	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	9:02	12:26	3:24	LINE CLEAR AVAIED
174	19-Jul-22	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_110	10:07	10:16	0:09	HAND TRIPPED
175	19-Jul-22	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_110	17:40	17:42	0:02	HAND TRIPPED
176	19-Jul-22	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	10:48	17:40	6:52	LINE CLEAR AVAIED
177	19-Jul-22	HASSAN	110	VITTAL-PUTR_SLTUR	VITLA_110	10:32	14:42	4:10	LINE CLEAR AVAIED
178	19-Jul-22	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN:LINE FAULT
179	19-Jul-22	HASSAN	220	DABUSET	KADUR_220	13:55	15:31	1:36	LINE FAULT
180	19-Jul-22	HASSAN	220	HV1	PUTTUR_220	11:59	12:30	0:31	LINE CLEAR AVAIED
181	19-Jul-22	HASSAN	220	HV2	PUTTUR_220	12:00	12:01	0:01	LINE CLEAR AVAIED
182	19-Jul-22	HASSAN	220	HV2	SHIRALKOPPA_220	11:10	18:22	7:12	LINE CLEAR AVAIED
183	19-Jul-22	HASSAN	220	KADUR-SHIMOGA	KADUR_220	6:40(18.07.2022)			LINE OPEN:LINE FAULT
184	19-Jul-22	HASSAN	220	MRSSHM-ARSIKERE	MRSMSG_220	18:46	19:35	0:49	LINE CLEAR AVAIED
185	19-Jul-22	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	7:35(18.07.2022)			LINE OPEN:LINE FAULT
186	19-Jul-22	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	10:19	15:21	5:02	LINE CLEAR AVAIED
187	19-Jul-22	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	12:36	19:03	6:27	LINE CLEAR AVAIED
188	19-Jul-22	HASSAN	220	SHMG	ARASIKERE_220	18:46	19:36	0:50	NFBC ISSUED
189	19-Jul-22	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	10:19	15:22	5:03	NFBC ISSUED
190	19-Jul-22	HASSAN	400	HASSAN2	upcl_gen	10:43	20:28	9:45	LINE CLEAR AVAIED
191	19-Jul-22	MYSURU	66	220KV KUSHALNAGAR-HARANGI	NO STATIONS EFFECTED	9:01	10:12	1:11	LINE FAULT
192	19-Jul-22	MYSURU	66	220KV KUSHALNAGAR-MADIKERI	NO STATIONS EFFECTED	9:01	10:13	1:12	LINE FAULT
193	19-Jul-22	MYSURU	66	220KV KUSHALNAGAR-MYSURU 1	MIRLE_66	9:01	10:13	1:12	LINE FAULT
194	19-Jul-22	MYSURU	66	220KV KUSHALNAGAR-PERIYAPATNA1	HANAGODU_66, KAMPALAPURA_66, PERIYAPATNA_66, PONNAMPET_66, VIRAJPET_66,	9:01	10:13	1:12	LINE FAULT
195	19-Jul-22	MYSURU	66	220KV KUSHALNAGAR-PERIYAPATNA2	BYLUKUPPE_66	9:01	10:13	1:12	LINE FAULT
196	19-Jul-22	MYSURU	66	220KV KUSHALNAGAR-RAMNATHPURA1	ALUR SIDDAPURA_66 KANAGAL_66	9:01	10:13	1:12	LINE FAULT
197	19-Jul-22	MYSURU	66	BGPURA-HEBBANI	BGPURA_66	10:30	11:57	1:27	LINE CLEAR AVAIED
198	19-Jul-22	MYSURU	66	BGPURA-TALAKADU	BGPURA_66	10:30	13:50	3:20	LINE CLEAR AVAIED
199	19-Jul-22	MYSURU	66	DATTAGALLI-HOOTGALLI	NO STATIONS EFFECTED	18:28	14:07	19:38	LINE CLEAR AVAIED
200	19-Jul-22	MYSURU	66	DK MAIDANA-VAJAMANGALA	NO STATIONS EFFECTED	15:44	7:16	15:31	LINE CLEAR AVAIED
201	19-Jul-22	MYSURU	66	DVNMYO-VAJAMANGALA	NO STATIONS EFFECTED	15:21	12:47	21:25	LINE FAULT
202	19-Jul-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAIED
203	19-Jul-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAIED
204	19-Jul-22	MYSURU	66	HOOTGALLI-Hampapur	KAGGERE HAMPAPURA_66	14:29	15:37	1:08	LINE FAULT
205	19-Jul-22	MYSURU	66	HUNSUR-ILAWALA	NO STATIONS EFFECTED	23:03	23:14	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
206	19-Jul-22	MYSURU	66	HV1	AYRALLI_66	12:45	13:10	0:25	LINE CLEAR AVAILED
207	19-Jul-22	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00 (12.07.2022)			TRANSFORMER:LINE CLEAR AVAILED
208	19-Jul-22	MYSURU	66	HV1	HAMPAPURA_66	12:22	19:25	7:02	LINE CLEAR AVAILED
209	19-Jul-22	MYSURU	66	HV1	KADAKOLA_220	12:40	13:15	0:35	LINE CLEAR AVAILED
210	19-Jul-22	MYSURU	66	HV1	KIADBMANDYA_66	5:40	5:48	0:07	MAIN SUPPLY FAILURE
211	19-Jul-22	MYSURU	66	HV1	KIRUGAVALU_66	14:37	14:54	0:17	LINE CLEAR AVAILED
212	19-Jul-22	MYSURU	66	HV1	LOKKANAHALLI_66	12:15	14:00	1:45	LINE CLEAR AVAILED
213	19-Jul-22	MYSURU	66	HV2	AYRALLI_66	13:40	14:50	1:10	LINE CLEAR AVAILED
214	19-Jul-22	MYSURU	66	HV2	BGPURA_66	10:30	17:45	7:15	LINE CLEAR AVAILED
215	19-Jul-22	MYSURU	66	HV2	HAMPAPURA_66	13:34	14:49	1:15	LINE CLEAR AVAILED
216	19-Jul-22	MYSURU	66	HV2	KADAKOLA_220	11:27	12:36	1:08	LINE CLEAR AVAILED
217	19-Jul-22	MYSURU	66	HV2	KIADBMANDYA_66	5:40	5:48	0:07	MAIN SUPPLY FAILURE
218	19-Jul-22	MYSURU	66	KALAMANDIR-MYSURU SOUTH	NO STATIONS EFFECTED	16:03	16:42	0:39	LINE CLEAR AVAILED
219	19-Jul-22	MYSURU	66	KIADBMANDYA-MADDUR	MADDUR_66 SOMANAHALLI KIADB_66	5:40	5:50	0:09	MAIN SUPPLY FAILURE
220	19-Jul-22	MYSURU	66	KIADBMANDYA-TUMBEGERE	TUMBEKERE_66	5:40	5:50	0:09	MAIN SUPPLY FAILURE
221	19-Jul-22	MYSURU	66	MALAVALLI-HV1	MALAVALLI_66	5:43	6:04	0:21	MAIN SUPPLY FAILURE
222	19-Jul-22	MYSURU	66	MALAVALLI-HV2	MALAVALLI_66	5:43	6:04	0:21	MAIN SUPPLY FAILURE
223	19-Jul-22	MYSURU	66	METAGALLI-VIKRANTH	NO STATIONS EFFECTED	15:35	18:45	3:09	MAIN SUPPLY FAILURE
224	19-Jul-22	MYSURU	66	TUBINKERE-MC2	NO STATIONS EFFECTED	10:50	11:59	1:09	LINE CLEAR AVAILED
225	19-Jul-22	MYSURU	66	TUBINKERE-MC4	NO STATIONS EFFECTED	12:01	14:27	2:25	LINE CLEAR AVAILED
226	19-Jul-22	MYSURU	220	HV11	HOOTAGALLY_220	14:29	14:57	0:28	TRANSFORMER FAULT
227	19-Jul-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
228	19-Jul-22	MYSURU	220	HV22	HOOTAGALLY_220	14:29	14:57	0:28	TRANSFORMER FAULT
229	19-Jul-22	TUMKUR	66	ANTHRASANAHALLI 220KV- BELLAVI	BELLAVI_66,MALLASANDRA_66, HEGGERE_66, DODDASARANGI_66	19:40	20:24	0:44	LOAD CURTAILMENT
230	19-Jul-22	TUMKUR	66	BELLAVI-ANTHRASANAHALLI	BELLAVI_66	13:07	15:11	2:04	LINE CLEAR AVAILED
231	19-Jul-22	TUMKUR	66	HONNALLI 220kv- KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	6:25	6:35	0:10	LINE FAULT
232	19-Jul-22	TUMKUR	66	HOSAKRE66-MEDIGESHI66	HOSAKRE_66	12:26	12:34	0:07	LINE FAULT
233	19-Jul-22	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	NIDSALE_66,DUNDANAHALLI_66	12:00	14:07	2:07	LINE CLEAR AVAILED
234	19-Jul-22	TUMKUR	66	MELKOTE-BADDIHALLI	MELKOTE_66	19:37	20:22	0:45	LOAD CURTAILMENT
235	19-Jul-22	TUMKUR	66	NIDISALE66-DUNDANAHALLY	NIDISALE_66	12:38	14:06	1:28	LINE CLEAR AVAILED
236	19-Jul-22	TUMKUR	66	NIDISALE66-HULIYURDURGA66	NIDISALE_66	12:38	14:06	1:27	LINE CLEAR AVAILED
237	19-Jul-22	TUMKUR	66	TR-1	BHARAMAGIRI_66	10:00	10:30	0:30	TRANSFORMER FAULT
238	19-Jul-22	TUMKUR	66	TR-2	BELLAVI_66	13:07	15:11	2:04	LINE CLEAR AVAILED
239	19-Jul-22	TUMKUR	66	TR-2	HONNUDIKE_66	8:50	8:55	0:05	TRANSFORMER FAULT
240	19-Jul-22	TUMKUR	66	TR-2	HULIYURDURGA_66	12:00	14:07	2:07	LINE CLEAR AVAILED
241	19-Jul-22	TUMKUR	66	TR-2(LV SIDE)	BENKIKERE_220	12:49	16:20	3:31	LINE CLEAR AVAILED
242	19-Jul-22	TUMKUR	110	NITTUR 220-SOMLAPURA110	SOMLAPURA_110	11:43	12:30	0:47	LINE CLEAR AVAILED
243	19-Jul-22	TUMKUR	110	TR-1	MAYASANDRA_66	16:07	17:48	1:40	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
244	19-Jul-22	TUMKUR	110	TR-2	HULIYAR_110	22:52	23:47	0:55	LINE CLEAR AVAILED
245	19-Jul-22	TUMKUR	220	BENKIKERE-220-HONNALL 2	HOSADURGA_66	12:50	16:19	3:28	LINE CLEAR AVAILED
246	19-Jul-22	TUMKUR	220	BENKIKERE-220-HOSADURGA 1	HOSADURGA_66	13:19	13:51	0:31	LINE FAULT
247	19-Jul-22	TUMKUR	220	BENKIKERE-220-HOSADURGA 2	HOSADURGA_66	13:19	13:51	0:31	LINE FAULT
248	19-Jul-22	TUMKUR	220	HONNALLI 220KV- BENKIKERE	BENKIKERE_220	12:54	16:17	3:23	LINE CLEAR AVAILED
249	19-Jul-22	TUMKUR	220	HOSADURGA-BENKTKERE 1&2	HOSADURGA_66	11:45	13:45	2:00	MAIN SUPPLY FAILURE
250	19-Jul-22	TUMKUR	220	TR-1	GUTUR_400	6:28	6:48	0:20	LINE CLEAR AVAILED
251	19-Jul-22	TUMKUR	220	TR-2	BENKIKERE_220	12:49	16:20	3:31	LINE CLEAR AVAILED
252	19-Jul-22	TUMKUR	220	TR-2	GUTUR_400	6:28	6:48	0:20	LINE CLEAR AVAILED
1	20-Jul-22	BAGALKOT	110	110/11KV, HV1	ANMOD_110	12:53	14:28	1:35	LINE CLEAR AVAILED
2	20-Jul-22	BAGALKOT	110	110/11KV, HV1	ANMOD_110	23:11	23:28	0:17	TRANSFORMER FAULT
3	20-Jul-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED HAVERI_110	11:35	13:30	1:55	LINE CLEAR AVAILED
4	20-Jul-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KARWAR_110	10:00	11:54	1:54	LINE CLEAR AVAILED
5	20-Jul-22	BAGALKOT	110	110/11KV, HV-1	STATION NOT AFFECTED BILAGI_110	9:50	10:00	0:10	TRANSFORMER FAULT
6	20-Jul-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED HIREMASALI_110	7:38	7:41	0:03	TRANSFORMER FAULT
7	20-Jul-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED ALMEL_110	22:29	23:56	1:27	TRANSFORMER FAULT
8	20-Jul-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED TODALBAGI_110	19:13 (17.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
9	20-Jul-22	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
10	20-Jul-22	BAGALKOT	110	110/33KV,HV4	HALASANGI_33, NEVARGI_33 DULAKHED_33 STATION NOT AFFECTED ZALKI_110	9:04	11:55	2:51	LINE CLEAR AVAILED
11	20-Jul-22	BAGALKOT	110	AMBEWADI-NK2	STATION NOT AFFECTED AMBEWADI_220	13:15	14:20	1:05	LINE FAULT
12	20-Jul-22	BAGALKOT	110	AMBEWADI-NK2	STATION NOT AFFECTED AMBEWADI_220	14:20	15:54	1:34	LINE FAULT
13	20-Jul-22	BAGALKOT	110	AMBEWADI-NK2	STATION NOT AFFECTED AMBEWADI_220	15:54 (20.07.2022)			LINE OPEN:LINE FAULT
14	20-Jul-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)	13:15 (20.07.2022)	1396:20 hrs	LINE CHARGED
15	20-Jul-22	BAGALKOT	110	ANMOD-GOA-2	ANMOD_110	9:34	10:00	0:26	MAIN SUPPLY FAILURE
16	20-Jul-22	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	5:35	5:49	0:14	LINE FAULT
17	20-Jul-22	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	10:50 (26.03.2022)			LINE OPEN:LINE CLEAR AVAILED
18	20-Jul-22	Bagalkot	110	GADAG220-RON	RON_110	13:45	16:02	2:17	LINE CLEAR AVAILED
19	20-Jul-22	BAGALKOT	110	GHTAPRABHA220-SOEPL(SURYODAYA SOLAR)	SURYODAYA SOLAR_110 STATION NOT AFFECTED GHTAPRABHA_220	7:10	7:25	0:15	LINE FAULT
20	20-Jul-22	BAGALKOT	110	GHTAPRABHA220-SOEPL(SURYODAYA SOLAR)	SURYODAYA SOLAR_110 STATION NOT AFFECTED GHTAPRABHA_220	7:44	8:00	0:16	LINE FAULT
21	20-Jul-22	BAGALKOT	110	HUKKERI-KOTAWAGI	HUKKERI_110	14:49	18:18	3:29	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
22	20-Jul-22	BAGALKOT	110	INDI220-ZALKI-1	ZALKI_110 CHADACHAN_110 INCHAGERI_110	08:45	08:55	0:10	LINE FAULT
23	20-Jul-22	BAGALKOT	110	INDI220-ZALKI-2	ZALKI_110 CHADACHAN_110 INCHAGERI_110	08:45	08:55	0:10	LINE FAULT
24	20-Jul-22	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	8:50 (06.07.2022)			LINE OPEN:LINE FAULT
25	20-Jul-22	BAGALKOT	110	KUDACHI220-TERDAL	STATION NOT AFFECTED TERDAL_110	12:25 (23.12.2021)			LINE OPEN:LINE CLEAR AVAILED
26	20-Jul-22	BAGALKOT	110	RAMANAKOPPA-MUNDAGOD	MUNDGOD_110	5:58	6:33	0:35	LINE FAULT
27	20-Jul-22	BAGALKOT	110	RON-HIREHAL	RON_110	13:35	19:00	5:25	LINE CLEAR AVAILED
28	20-Jul-22	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED UMMACHAGI_110	18:46 (20.07.2022)			LINE OPEN:LINE CLEAR AVAILED
29	20-Jul-22	BAGALKOT	110	SIRSI-KUMATA2	KUMATA_110	11:02	13:00	1:58	LINE CLEAR AVAILED
30	20-Jul-22	BAGALKOT	110	TODALBAGI-SAVALAGI	TODALBAGI_110	18:00 (20.07.2022)			LINE OPEN:LINE FAULT
31	20-Jul-22	BAGALKOT	220	220/110KV, HV1	KARWAR_220	15:26	18:38	3:12	LINE CLEAR AVAILED
32	20-Jul-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
33	20-Jul-22	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED ATHANI_220	9:41 (06.07.2022)	18:21 (20.07.2022)	344:40 hrs	TRANSFORMER CHARGED
34	20-Jul-22	BAGALKOT	220	220/110KV, HV3 & LV3	STATION NOT AFFECTED SOUNDATTI_220	10:52 (19.07.2022)			TRANSFORMER:LINE CLEAR AVAILED
35	20-Jul-22	Bagalkot	220	220/110KV, HV4	STATION NOT AFFECTED GADAG_220	14:01	18:30	4:29	LINE CLEAR AVAILED
36	20-Jul-22	BAGALKOT	220	BAGALKOT - GADAG-1	STATION NOT AFFECTED BAGALKOT_220	13:15	18:26	5:11	NFBC ISSUED
37	20-Jul-22	BAGALKOT	220	BAGALKOT - GADAG-2	STATION NOT AFFECTED BAGALKOT_220	13:16 (20.07.2022)			LINE OPEN:LINE CLEAR AVAILED
38	20-Jul-22	BAGALKOT	220	CHIKKODI-KOLAHAPUR-1 (TALANDAGE)	STATION NOT AFFECTED CHIKKODI_220	14:59	17:11	2:12	LINE CLEAR AVAILED
39	20-Jul-22	BAGALKOT	220	CHIKKODI-KOLAHAPUR-2 (MUDASHINGI)	STATION NOT AFFECTED CHIKKODI_220	10:53	17:53	7:00	LINE CLEAR AVAILED
40	20-Jul-22	Bagalkot	220	GADAG-BAGALKOT-1	STATION NOT AFFECTED GADAG_220	13:15	18:26	5:11	LINE CLEAR AVAILED
41	20-Jul-22	Bagalkot	220	GADAG-BAGALKOT-2	STATION NOT AFFECTED GADAG_220	13:16 (20.07.2022)			LINE OPEN:LINE CLEAR AVAILED
42	20-Jul-22	Bagalkot	220	GADAG-HARTI-1	STATION NOT AFFECTED GADAG_220	10:55 (19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
43	20-Jul-22	Bagalkot	220	GADAG-HARTI-2	STATION NOT AFFECTED GADAG_220	10:55 (19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
44	20-Jul-22	Bagalkot	220	HAVERI-GUTTUR-2	STATION NOT AFFECTED HAVERI_220	13:33	18:25	4:52	LINE FAULT
45	20-Jul-22	BAGALKOT	220	MAHALINGAPUR220-TERADAL	STATION NOT AFFECTED MAHALINGAPUR_220	6:47	6:50	0:03	NFBC ISSUED
46	20-Jul-22	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN:LINE CLEAR AVAILED
47	20-Jul-22	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN:LINE CLEAR AVAILED
48	20-Jul-22	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	10:00	17:18	7:18	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
49	20-Jul-22	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLIC CROSS, YENIGADALE	0:56	1:03	0:07	LINE FAULT
50	20-Jul-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	13:45	13:56	0:11	MAIN SUPPLY FAILURE
51	20-Jul-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	13:45	13:56	0:11	LINE FAULT
52	20-Jul-22	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL	10:03	10:10	0:07	LINE CLEAR AVAILED
53	20-Jul-22	BENGALURU	66	HOODY 220 - BMRCL	NO STATION AFFECTED	12:31(17/07/2022)	9:55(20/07/2022)	69:24HRS	LINE CHARGED
54	20-Jul-22	BENGALURU	66	HV1	VR DODDI	17:04	17:09	0:05	TRANSFORMER FAULT
55	20-Jul-22	BENGALURU	66	HV2	SARJAPURA 220	15:50	16:16	0:26	LINE CLEAR AVAILED
56	20-Jul-22	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR	13:32	13:39	0:07	LOAD CHANGEOVER
57	20-Jul-22	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR	14:15	14:40	0:25	LINE CLEAR AVAILED
58	20-Jul-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	12:51	12:59	0:08	LINE FAULT
59	20-Jul-22	BENGALURU	66	KORAMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	12:47	13:19	0:32	LINE FAULT
60	20-Jul-22	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	15:53	15:58	0:05	LOAD CHANGEOVER
61	20-Jul-22	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	12:50	12:56	0:06	LOAD CHANGEOVER
62	20-Jul-22	BENGALURU	66	MANDIKAL - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL	13:10	13:15	0:05	LOAD CHANGEOVER
63	20-Jul-22	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	10:20	15:38	5:18	LINE CLEAR AVAILED
64	20-Jul-22	BENGALURU	66	PURVANKARA - HENNUR CROSS	PURVANKARA	2:59	3:15	0:16	LINE FAULT
65	20-Jul-22	BENGALURU	66	SOBHA FOREST - BRIGADE MEADOWS	SOBHA FOREST	10:30	13:08	2:38	LINE CLEAR AVAILED
66	20-Jul-22	BENGALURU	66	T GOLLAHALLI 220 - ANDERSONPETE	DODDAKARI, KYASAMBALLI, ANDERSONPETE	13:53	14:55	1:02	LINE CLEAR AVAILED
67	20-Jul-22	BENGALURU	66	T GOLLAHALLI 220 - ANDERSONPETE	DODDAKARI, KYASAMBALLI, ANDERSONPETE	15:10	16:47	1:37	LINE CLEAR AVAILED
68	20-Jul-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	KGF	13:33	14:50	1:17	LINE CLEAR AVAILED
69	20-Jul-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 2	KAMASAMUDRA, BEML	13:33	14:52	1:19	LINE CLEAR AVAILED
70	20-Jul-22	BENGALURU	66	VIDHURASHWATHA - GREEN SOLAR(IPP)	NO STATION AFFECTED	18:51	19:12	0:21	LINE CLEAR AVAILED
71	20-Jul-22	BENGALURU	220	DB PURA 220 - NELAMANGALA 1	NO STATION AFFECTED	11:04	15:47	4:43	LINE CLEAR AVAILED
72	20-Jul-22	BENGALURU	220	DEVANAHALLI 400 - KIADB HARDWARE PARK 220 2	NO STATION AFFECTED	16:44	17:08	0:24	LINE FAULT
73	20-Jul-22	BENGALURU	220	KIADB HARDWARE PARK 220 - DEVANAHALLI 400 2	NO STATION AFFECTED	16:44	17:08	0:24	LINE FAULT
74	20-Jul-22	BENGALURU	220	NELAMANGALA 400 - DB PURA 1	NO STATION AFFECTED	11:04	15:47	4:43	LINE CLEAR AVAILED
75	20-Jul-22	GULBARGA	66	HOSAHALLI-BADALADKU(KUDLIGI 220)	HOSAHALLI_66,AVADA SOLAR_IPP,CLEEN MAX WIND-IPP	10:15	17:30	7:15	MAIN SUPPLY FAILURE
76	20-Jul-22	GULBARGA	66	HV1	BENNEHALLI_66	9:30	9:35	0:05	TRANSFORMER FAULT
77	20-Jul-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	11:16	16:13	4:57	NFBC ISSUED
78	20-Jul-22	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELS	5:38	6:01	0:23	LINE FAULT
79	20-Jul-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110	19:20	19:30	0:10	MAIN SUPPLY FAILURE
80	20-Jul-22	GULBARGA	110	CHOWDAPUR-AFZALPUR	AFZALPUR_110	6:50	7:00	0:10	LINE FAULT
81	20-Jul-22	GULBARGA	110	HALBARGA-HUMNABAD	HUMNABAD_110	9:07	20:55	11:48	NFBC ISSUED
82	20-Jul-22	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110,HABSIKOTE_110	19:44	19:52	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
83	20-Jul-22	GULBARGA	110	HALBARGA-KOLHAR1	KOLHAR_110,JANAWADA_110,NSSK SUGAR FACTORY	15:52	16:53	1:01	LINE CLEAR AVAIED
84	20-Jul-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_110,DIGGI_110	19:19	19:28	0:09	LINE FAULT
85	20-Jul-22	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110,DUBALGUNDI_110,LADHA_110,MGS SK_IPP,BSSK_IPP	17:18	20:25	3:07	LINE CLEAR AVAIED
86	20-Jul-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	15:54(20.07.22)			LINE OPEN:LINE CLEAR AVAIED
87	20-Jul-22	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	9:34(20.07.22)			LINE OPEN:LINE CLEAR AVAIED
88	20-Jul-22	GULBARGA	110	HUMNABAD-SASTHAPUR	RAJESHWAR_110,SASTHAPUR_110,MANTHAL_110	12:10(20.07.22)			LINE OPEN:LINE CLEAR AVAIED
89	20-Jul-22	GULBARGA	110	HV1	CHOWDAPUR_110	12:05	13:20	1:15	LINE CLEAR AVAIED
90	20-Jul-22	GULBARGA	110	KAPNOOR-GULBARGA WEST1	GULBARGA WEST_110,GULBARGA SOUTH_110	12:48	18:27	5:39	LINE CLEAR AVAIED
91	20-Jul-22	GULBARGA	110	LV1	ITTAGI_220	23:35 (19.07.2022)	00:17 (20.07.2022)	00:42 HRS	TRANSFORMER CHARGED
92	20-Jul-22	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110, ADVIAMRESHWAR_110	11:03	16:39	5:36	LINE CLEAR AVAIED
93	20-Jul-22	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110, ADVIAMRESHWAR_110	14:32	14:42	0:10	LINE FAULT
94	20-Jul-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	1:45	2:05	0:20	LINE FAULT
95	20-Jul-22	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORAWAR_110	2:05	2:10	0:05	LINE FAULT
96	20-Jul-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	4:30	4:35	0:05	LINE FAULT
97	20-Jul-22	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	10:12	17:33	7:21	LINE CLEAR AVAIED
98	20-Jul-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	10:12	17:32	7:20	LINE CLEAR AVAIED
99	20-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110,NALWAR_110	19:00	19:20	0:20	NFBC ISSUED
100	20-Jul-22	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	22:13	22:19	0:06	LINE FAULT
101	20-Jul-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	12:53	20:15	7:22	LINE CLEAR AVAIED
102	20-Jul-22	GULBARGA	110	YAKATPUR-KAMTHANA	YAKATPUR_110	19:45	19:55	0:10	MAIN SUPPLY FAILURE
103	20-Jul-22	GULBARGA	220	HV1	SHAHABAD_220	22:25	23:02	0:37	TRANSFORMER FAULT
104	20-Jul-22	GULBARGA	220	KAPNOOR-SHAHABAD	KAPNOOR_220	2:57	3:11	0:14	LINE FAULT
105	20-Jul-22	GULBARGA	220	LINGAPUR-BTPS	BTPS_220	4:53	9:07	4:14	LINE FAULT
106	20-Jul-22	GULBARGA	220	LINGAPUR-BTPS	BTPS_220	4:53	9:07	4:14	LINE FAULT
107	20-Jul-22	GULBARGA	220	LINGASUGUR-RTPS 2	RTPS_220	9:52	10:06	0:14	LINE FAULT
108	20-Jul-22	GULBARGA	220	SEDAM_SHAHAPUR	SEDAM_220	05:48(10/06/2022)			LINE OPEN:LINE CLEAR AVAIED
109	20-Jul-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAIED
110	20-Jul-22	HASSAN	66	HV2	HOLEHONNUR_66	12:35	14:05	1:30	LINE CLEAR AVAIED
111	20-Jul-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER:LINE CLEAR AVAIED
112	20-Jul-22	HASSAN	110	HV5	KAVOOR_220	9:04	17:20	8:16	LINE CLEAR AVAIED
113	20-Jul-22	HASSAN	110	HV6	PUTTUR_220	12:30(20.07.2022)			TRANSFORMER:LINE CLEAR AVAIED
114	20-Jul-22	HASSAN	110	LV2	PUTTUR_220	17:16(20.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
115	20-Jul-22	HASSAN	110	LV7	PUTTUR_220	17:16	17:25	0:09	TRANSFORMER FAULT
116	20-Jul-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	9:05	9:58	0:53	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
117	20-Jul-22	HASSAN	220	ARSK2-SHMG	ARSIKERE_220	11:44	17:09	5:25	LINE CLEAR AVAILED
118	20-Jul-22	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN:LINE FAULT
119	20-Jul-22	HASSAN	220	HV2	PUTTUR_220	17:16(20.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
120	20-Jul-22	HASSAN	220	HV7	PUTTUR_220	17:16	17:25	0:09	TRANSFORMER FAULT
121	20-Jul-22	HASSAN	220	KADUR-SHIMOGA	KADUR_220	6:40(18.07.2022)	18:04(20.07.2022)	39:44HRS	LINE CHARGED
122	20-Jul-22	HASSAN	220	KEMAR-UPCL2	KEMAR_220	10:55	17:10	6:15	NFBC ISSUED
123	20-Jul-22	HASSAN	220	MRSSHM-ARSKR	MRSMSG_220	11:44	17:09	5:25	LINE CLEAR AVAILED
124	20-Jul-22	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	7:35(18.07.2022)	18:04(20.07.2022)	38:49HRS	LINE CHARGED
125	20-Jul-22	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	10:38	17:10	6:32	LINE CLEAR AVAILED
126	20-Jul-22	HASSAN	220	UPCL-KEMAR2	gen_upcl	10:55	16:55	6:00	LINE CLEAR AVAILED
127	20-Jul-22	HASSAN	220	VARAHI-SHIMOGA2	gen_varahi	10:39	17:10	6:31	NFBC ISSUED
154	20-Jul-22	TUMKUR	66	ANCHEPALYA 220KV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66,NIDSALE_66,DUNDANAHALLI_66	7:07	7:17	0:10	LINE FAULT
155	20-Jul-22	TUMKUR	66	ANTHRASANAHALLI 220KV- BELLAVI	BELLAVI_66,MALLASANDRA_66, HEGGERE_66, DODDASARANGI_66	9:56	16:27	6:31	LINE CLEAR AVAILED
156	20-Jul-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA &URDIGERE66	KOLALA_66, URDIGERE_66	9:56	17:58	8:02	LINE CLEAR AVAILED
157	20-Jul-22	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66,HONNUDIKE_66	9:57	17:58	8:01	LINE CLEAR AVAILED
158	20-Jul-22	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66,KADAJJI_66,MELEKATTE_66	10:11	17:46	7:35	LINE CLEAR AVAILED
159	20-Jul-22	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	10:05	16:11	6:06	LINE CLEAR AVAILED
160	20-Jul-22	TUMKUR	66	TR-1	BHARAMAGIRI_66	7:32	7:37	0:05	TRANSFORMER FAULT
161	20-Jul-22	TUMKUR	66	TR-1	CHALLAKERE_66	11:05	13:05	2:00	LINE CLEAR AVAILED
162	20-Jul-22	TUMKUR	66	TR-1	GARAGA_66	8:09	9:11	1:02	LINE CLEAR AVAILED
163	20-Jul-22	TUMKUR	66	TR-1	GARAGA_66	10:10	12:00	1:50	LINE CLEAR AVAILED
164	20-Jul-22	TUMKUR	66	TR-1	SOMLAPURA_110	16:25	16:50	0:25	MAIN SUPPLY FAILURE
165	20-Jul-22	TUMKUR	110	NITTUR 220-SOMLAPURA110	SOMLAPURA_110	16:20	16:45	0:25	LINE FAULT
166	20-Jul-22	TUMKUR	110	SOMLAPURA 110-NITTUR220	SOMLAPURA_110	16:25	16:50	0:25	MAIN SUPPLY FAILURE
167	20-Jul-22	TUMKUR	110	TR-2	KBCROSS_220	11:04	11:12	0:08	LINE CLEAR AVAILED
168	20-Jul-22	TUMKUR	110	TR-2	UNGRA_110	11:55	18:11	6:16	LINE CLEAR AVAILED
169	20-Jul-22	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	17:47	20:19	2:32	LINE CLEAR AVAILED
170	20-Jul-22	TUMKUR	400	JAGLUR_400KV -CHIKKANAYAKANAHALLI	JAGLUR_400	11:05	16:38	5:32	LINE CLEAR AVAILED
171	20-Jul-22	MYSURU	66	HV1	BGPURA_66	13:15	13:32	0:17	HAND TRIPPED
172	20-Jul-22	MYSURU	66	BILIKERE-KHB COLONY	DMG HALLI, KHB COLONY	11:40	11:49	0:09	LINE FAULT
173	20-Jul-22	MYSURU	66	HV1	HANAGODU_66	10:58	14:50	3:51	LINE CLEAR AVAILED
174	20-Jul-22	MYSURU	66	HANNUR-MADUVANHALLI 1	NO STATIONS EFFECTED	13:15	13:20	0:05	LINE FAULT
175	20-Jul-22	MYSURU	66	HOOTAGALLI-DATAGALLI	NO STATIONS EFFECTED	14:13	14:17	0:04	LOAD CHANGEOVER
176	20-Jul-22	MYSURU	66	HOOTAGALLI-DATAGALLI	NO STATIONS EFFECTED	17:45	17:49	0:04	LOAD CHANGEOVER
177	20-Jul-22	MYSURU	220	HOOTAGALLI-HV2	HEBBAL_66 METGALLI_66	15:11	20:11	5:00	LINE FAULT
178	20-Jul-22	MYSURU	66	HOOTAGALLI-RBI	NO STATIONS EFFECTED	17:43	20:16	2:33	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
179	20-Jul-22	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	12:46	19:23	6:37	LINE FAULT
180	20-Jul-22	MYSURU	66	KADAKOLA-RK NAGAR	MANDKALLI_66	7:33	13:39	6:05	LINE FAULT
181	20-Jul-22	MYSURU	66	KADAKOLA-MYSURU SOUTH	NO STATIONS EFFECTED	12:06	13:42	1:36	LINE CLEAR AVAIED
182	20-Jul-22	MYSURU	66	HV2	KIRUGAVLU_66	22:36	23:50	1:13	LINE CLEAR AVAIED
183	20-Jul-22	MYSURU	66	KUSHALNAGAR 220-RAMANTHAPURA1	KANAGALU, RUHRAPATNA, CB HALLI, ALUR SIDAPPUR	19:06	19:13	0:07	LINE FAULT
184	20-Jul-22	MYSURU	66	MADHUVANHALLY-HANNUR 1	NO STATIONS EFFECTED	13:13	13:18	0:05	LINE FAULT
185	20-Jul-22	MYSURU	66	MADIKERI-SUNIKOPPA	NO STATIONS EFFECTED	17:15	18:10	0:55	HAND TRIPPED
186	20-Jul-22	MYSURU	66	MADIKERI-KUSHALNAGAR	NO STATIONS EFFECTED	17:15	18:10	0:55	HAND TRIPPED
187	20-Jul-22	MYSURU	66	NANJANGUDU-SINDUVALLIPURA	NO STATIONS EFFECTED	6:17	6:25	0:07	LINE FAULT
188	20-Jul-22	MYSURU	66	SANTHESARGURU-BEGUR	NO STATIONS EFFECTED	13:18	13:20	0:02	LINE FAULT
189	20-Jul-22	MYSURU	66	HV1	SANTHESARGURU_66	13:20	13:25	0:05	TRANSFORMER FAULT
190	20-Jul-22	MYSURU	66	VAJAMANGALA-DEVNUR MYSURU	NO STATIONS EFFECTED	11:26	12:41	1:15	LINE CLEAR AVAIED
191	20-Jul-22	MYSURU	66	HV1	MYSURU SOUTH_66	12:08	12:53	0:45	TRANSFORMER FAULT
192	20-Jul-22	MYSURU	66	HV2	BGPURA_66	10:30	17:45	7:15	LINE CLEAR AVAIED
193	20-Jul-22	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00 (12.07.2022)			TRANSFORMER:LINE CLEAR AVAIED
194	20-Jul-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18(31.5.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
195	20-Jul-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAIED
196	20-Jul-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAIED
1	21-Jul-22	BAGALKOT	110	110/11,HV2	KADAKLAT_110	11:15	13:04	1:49	LINE CLEAR AVAIED
2	21-Jul-22	BAGALKOT	110	110/11KV,HV1	ANNKOLA_110	13:35	13:41	0:06	HAND TRIPPED
3	21-Jul-22	BAGALKOT	110	110/11KV,HV1	KAMBAGI_110	11:21	11:33	0:12	TRANSFORMER FAULT
4	21-Jul-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED TODALBAGI_110	19:13 (17.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
5	21-Jul-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	0:14	18:49	18:35	TRANSFORMER FAULT
6	21-Jul-22	BAGALKOT	110	110/11KV,HV2	BEDI_110	9:13	15:38	6:25	TRANSFORMER FAULT
7	21-Jul-22	BAGALKOT	110	110/11KV,HV2	KALAGHATGI_110	6:42	6:50	0:08	TRANSFORMER FAULT
8	21-Jul-22	BAGALKOT	110	110/11KV,HV2	KAMBAGI_110	11:21	11:33	0:12	TRANSFORMER FAULT
9	21-Jul-22	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
10	21-Jul-22	BAGALKOT	110	AMBEWADI220-NK-1	AMBEWADI_220	10:20	18:23	8:03	LINE CLEAR AVAIED
11	21-Jul-22	BAGALKOT	110	AMBEWADI-NK2	STATION NOT AFFECTED AMBEWADI_220	15:54 (20.07.2022)			LINE OPEN:LINE FAULT
12	21-Jul-22	Bagalkot	110	BELAGAVI220-KANABARGI	KANABARGI_110	21:30	22:07	0:38	LINE FAULT
13	21-Jul-22	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	10:50 (26.03.2022)			LINE OPEN:LINE CLEAR AVAIED
14	21-Jul-22	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	11:23	15:28	4:05	LINE CLEAR AVAIED
15	21-Jul-22	BAGALKOT	110	GAJENDRAGAD-RON1&2	GAJENDRAGAD_110	3:57	9:49	5:52	LINE CLEAR AVAIED
16	21-Jul-22	BAGALKOT	110	HALIYAL-NK-1	STATION NOT AFFECTED HALIYAL_110	10:20 (21.07.2022)			LINE OPEN:LINE CLEAR AVAIED
17	21-Jul-22	Bagalkot	110	HAVERI220-GUTTAL	GUTTAL_110	5:25	5:30	0:05	MAIN SUPPLY FAILURE
18	21-Jul-22	BAGALKOT	110	ITNAL-BORUKA &BPCL	ITANAL_110	9:56	12:26	2:30	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
19	21-Jul-22	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	8:50 (06.07.2022)			LINE OPEN:LINE FAULT
20	21-Jul-22	BAGALKOT	110	KANABARGI-BELAGAVI (NEHARUNAGAR)	STATION NOT AFFECTED KANABARGI_110	21:34	22:09	2:24	LINE CLEAR AVAILED
21	21-Jul-22	BAGALKOT	110	KUSHTAGI-GAJENDRAGAD	GAJENDRAGAD_110	9:49	11:40	1:51	LINE CLEAR AVAILED
22	21-Jul-22	BAGALKOT	110	RANEENNUR220-HONNATTI	HONNATTI_110	5:22	5:30	0:08	LINE FAULT
23	21-Jul-22	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED UMMACHAGI_110	18:46 (20.07.2022)	10:19 (21.07.2022)	15:34 hrs	LINE CHARGED
24	21-Jul-22	BAGALKOT	110	TODALBAGI-SAVALAGI	TODALBAGI_110	18:00 (20.07.2022)			LINE OPEN:LINE FAULT
25	21-Jul-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	10:47	13:55	3:10	LINE CLEAR AVAILED
26	21-Jul-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
27	21-Jul-22	BAGALKOT	220	220/110KV, HV3 & LV3	STATION NOT AFFECTED SOUDATTI_220	10:52 (19.07.2022)			TRANSFORMER:LINE CLEAR AVAILED
28	21-Jul-22	BAGALKOT	220	BAGALKOT - GADAG-1	STATION NOT AFFECTED BAGALKOT_220	11:40	17:43	6:01	NFBC ISSUED
29	21-Jul-22	BAGALKOT	220	BAGALKOT - GADAG-2	STATION NOT AFFECTED BAGALKOT_220	13:16 (20.07.2022)	17:44 (21.07.2022)	28:28 hrs	LINE CHARGED
30	21-Jul-22	Bagalkot	220	GADAG-BAGALKOT-1	STATION NOT AFFECTED GADAG_220	11:39	17:42	6:03	LINE CLEAR AVAILED
31	21-Jul-22	BAGALKOT	220	GADAG-BAGALKOT-2	STATION NOT AFFECTED GADAG_220	13:16 (20.07.2022)	17:43 (21.07.2022)	4:27 hrs	LINE CHARGED
32	21-Jul-22	Bagalkot	220	GADAG-HARTI-1	STATION NOT AFFECTED GADAG_220	10:55 (19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
33	21-Jul-22	Bagalkot	220	GADAG-HARTI-2	STATION NOT AFFECTED GADAG_220	10:55 (19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
34	21-Jul-22	BAGALKOT	220	HAVERI220-GUTTUR-2	STATION NOT AFFECTED HAVERI_220	11:26	15:01	3:35	LINE CLEAR AVAILED
35	21-Jul-22	BAGALKOT	220	HAVERI220-GUTTUR-2	STATION NOT AFFECTED HAVERI_220	21:53 (21.07.2022)			LINE OPEN:LINE CLEAR AVAILED
36	21-Jul-22	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN:LINE CLEAR AVAILED
37	21-Jul-22	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN:LINE CLEAR AVAILED
38	21-Jul-22	BENGALURU	66	BRIGADE MEADOWS - SHOBHA FOREST	SHOBHA FOREST	13:35	13:43	0:08	LINE FAULT
39	21-Jul-22	BENGALURU	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	11:10	16:08	4:58	LINE CLEAR AVAILED
40	21-Jul-22	BENGALURU	66	D PALYA - PERESANDRA	GUDIBANDE, MANDIKAL	14:25	14:30	0:05	LINE CLEAR AVAILED
41	21-Jul-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	9:35	9:37	0:02	LOAD CHANGEVER
42	21-Jul-22	BENGALURU	66	GUNDAMGERE - GOWRIBIDANUR 220	MANCHENAHALLI, GUNDAMGERE	9:25	9:35	0:10	LOAD CHANGEVER
43	21-Jul-22	BENGALURU	66	HV1	SOLADEVANAHALLI	16:32	16:42	0:10	LINE CLEAR AVAILED
44	21-Jul-22	BENGALURU	66	HV1	DALSANUR	13:35	13:45	0:10	LINE CLEAR AVAILED
45	21-Jul-22	BENGALURU	66	HV1	KAMASAMUDRA	14:40	15:55	1:15	LINE CLEAR AVAILED
46	21-Jul-22	BENGALURU	66	HV2	SOMAYAJANAHALLI	15:00	16:20	1:20	LINE CLEAR AVAILED
47	21-Jul-22	BENGALURU	66	HV2	KAMASAMUDRA	7:20	12:55	5:34	LINE CLEAR AVAILED
48	21-Jul-22	BENGALURU	66	HV2	ALUR	7:20	7:36	0:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
49	21-Jul-22	BENGALURU	66	HV3	BANASHANKARI	15:28	15:30	0:02	LINE CLEAR AVAILED
50	21-Jul-22	BENGALURU	66	JADIGENAHALLI - HOSKOTE 220	JADIGENAHALLI	14:25	14:42	0:17	LOAD CHANGEOVER
51	21-Jul-22	BENGALURU	66	KAMASAMUSRA - KGF	KAMASAMUDRA	15:25	15:50	0:25	LINE CLEAR AVAILED
52	21-Jul-22	BENGALURU	66	KGF - KAMASAMUDRA	KAMASAMUDRA	6:55	7:05	0:10	LINE FAULT
53	21-Jul-22	BENGALURU	66	KIADB HARDWARE PARK 220 - SHELL(EHT)	SHELL(EHT)	11:59	16:05	4:06	LINE CLEAR AVAILED
54	21-Jul-22	BENGALURU	66	LR BANDE - HBR LAYOUT 66	LR BANDE	6:30	6:36	0:06	LOAD CHANGEOVER
55	21-Jul-22	BENGALURU	66	LR BANDE - HEBBALA 220	LR BANDE	16:15	16:20	0:05	LOAD CHANGEOVER
56	21-Jul-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	10:05	10:20	0:15	LINE CLEAR AVAILED
57	21-Jul-22	BENGALURU	66	MANDIKAL - PERESANDRA	GUDIBANDE, MANDIKAL	17:00	17:05	0:05	LOAD CHANGEOVER
58	21-Jul-22	BENGALURU	66	NGEF - ITI 220	NGEF	10:00	16:33	6:33	LINE CLEAR AVAILED
59	21-Jul-22	BENGALURU	66	PERESANDRA - GOWRIBIDANUR 220	PERESANDRA	13:00	13:05	0:05	LOAD CHANGEOVER
60	21-Jul-22	BENGALURU	66	PERESANDRA - MITTEMARI 220	PERESANDRA	9:10	9:15	0:05	LOAD CHANGEOVER
61	21-Jul-22	BENGALURU	66	SHOBHA FOREST - SUBRAMANYAPURA 220	SHOBHA FOREST	16:32	16:37	0:05	LOAD CHANGEOVER
62	21-Jul-22	BENGALURU	66	SOMAYAJANAHALLI - TATA SOLAR (IPP)	NO STATION AFFECTED	15:00	15:45	0:45	LINE CLEAR AVAILED
63	21-Jul-22	BENGALURU	66	SOMAYAJANAHALLI - TATA SOLAR (IPP)	NO STATION AFFECTED	16:40	17:00	0:20	LINE CLEAR AVAILED
64	21-Jul-22	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	8:05	18:56	10:51	LINE CLEAR AVAILED
65	21-Jul-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR, K HONALGERE, YATHAMBADI	8:05	18:56	10:51	LINE CLEAR AVAILED
66	21-Jul-22	BENGALURU	66	VOKKALERI - KC VALLEY (EHT)	KC VALLEY (EHT)	12:00	13:50	1:50	LINE CLEAR AVAILED
67	21-Jul-22	GULBARGA	66	HV2	BENNEHALLI_66	15:50	16:00	0:10	TRANSFORMER FAULT
68	21-Jul-22	GULBARGA	66	HV3	HALAVAGALI_66	9:10	10:50	1:40	LINE CLEAR AVAILED
69	21-Jul-22	GULBARGA	66	KUDLIGI-BANVIKAL	BANVIKAL_66	11:25	11:35	0:10	LINE FAULT
70	21-Jul-22	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJ HALLI_66,HOSAHALLI_66	16:50	17:00	0:10	LINE FAULT
71	21-Jul-22	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJAINI_66	13:50	14:05	0:15	LINE CLEAR AVAILED
72	21-Jul-22	GULBARGA	66	TELAGI-YARAGUNTA	OBAJJIHALLI_66,YARAGUNTA_66	11:30	15:15	3:45	NFBC ISSUED
73	21-Jul-22	GULBARGA	66	UCHHANGIDURGA-BILCHOD	BILCHOD_66	6:10	6:20	0:10	LINE FAULT
74	21-Jul-22	GULBARGA	110	CHICKSUGUR-SHAKTINAGAR	SHAKTINAGAR_110	11:05	12:23	1:18	LINE CLEAR AVAILED
75	21-Jul-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	4:57	5:15	0:18	LINE FAULT
76	21-Jul-22	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110,DUBALGUNDI_110,LADHA_110,MGS SK_IPP,BSSK_IPP	9:55	14:59	5:04	LINE CLEAR AVAILED
77	21-Jul-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	3:54(20/07/2022)			LINE OPEN:LINE CLEAR AVAILED
78	21-Jul-22	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	9:34(20/07/2022)			LINE OPEN:LINE CLEAR AVAILED
79	21-Jul-22	GULBARGA	110	HUMNABAD-SASTHAPUR	RAJESHWAR_110,SASTHAPUR_110,MANTHAL_11 0	12:10(20/07/2022)	17:53(21/07/2 022)	29:43HRS	LINE CHARGED
80	21-Jul-22	GULBARGA	110	HV1	ALIPUR_220	15:32	16:14	0:42	LINE CLEAR AVAILED
81	21-Jul-22	GULBARGA	110	HV1	ALIPUR_220	16:20	16:26	0:06	LINE CLEAR AVAILED
82	21-Jul-22	GULBARGA	110	HV2	HANUMANAL_110	8:05	9:30	1:25	LINE CLEAR AVAILED
83	21-Jul-22	GULBARGA	110	KAVITHAL-MALLAT	KAVITHAL_110	2:34	22:45	2:45	MAIN SUPPLY FAILURE
84	21-Jul-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	23:01	23:11	0:10	LINE FAULT
85	21-Jul-22	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110,ADVIAMRESHWAR_ 110	23:08	23:18	0:10	LINE FAULT
86	21-Jul-22	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	21:56	22:04	3:45	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
87	21-Jul-22	GULBARGA	110	MUNIRABAD-DONIMALAI1(IDLE LINE)	DONIMALAI_110	17:01	18:34	1:33	LINE CLEAR AVAILED
88	21-Jul-22	GULBARGA	110	MUNIRABAD-DONIMALAI1(IDLE LINE)	DONIMALAI_110	19:54	19:57	0:03	LINE CLEAR AVAILED
89	21-Jul-22	GULBARGA	110	RAICHUR-SINDHNOOR1	SIRWAR_110	23:25	23:30	0:05	LINE FAULT
90	21-Jul-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	22:20	22:30	0:10	LINE FAULT
91	21-Jul-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	22:50	22:56	0:06	LINE FAULT
92	21-Jul-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN:LINE CLEAR AVAILED
93	21-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
94	21-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
95	21-Jul-22	GULBARGA	110	SINDHNOOR-VALLABELLARI	MANVI_110,MADLAPUR_110,KURDICROSS_110,A DVIAMRESHWAR_110,JAWALGERA_110	3:30	3:40	0:10	LINE FAULT
96	21-Jul-22	GULBARGA	110	SINDHNOOR-VALLABELLARI	MANVI_110,MADLAPUR_110,KURDICROSS_110,A DVIAMRESHWAR_110,JAWALGERA_110	19:40	19:50	0:10	LINE FAULT
97	21-Jul-22	GULBARGA	110	SINDHNOOR-VALLABELLARI	MANVI_110,MADLAPUR_110,KURDICROSS_110,A DVIAMRESHWAR_110,JAWALGERA_110	23:19	23:29	0:10	LINE FAULT
98	21-Jul-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	16:01	16:19	0:18	LINE FAULT
99	21-Jul-22	GULBARGA	110	SULEKAL-MARALIHALLI	MUKUNDA_110, YEREDONA_110,BENNUR SOLAR_IPP	3:50	4:00	0:10	LINE FAULT
100	21-Jul-22	GULBARGA	110	YELBURGA-PARAMPOOJYA	YELBURGA_110	10:43	10:53	0:10	LINE FAULT
101	21-Jul-22	GULBARGA	110	YERADONA-SULEKAL	YERADONA_110,BENNUR_110	3:50	4:00	0:10	MAIN SUPPLY FAILURE
102	21-Jul-22	GULBARGA	220	LINGAPUR-MUNIRABAD1	MUNIRABAD_220	9:48	12:34	2:46	LINE FAULT
103	21-Jul-22	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	5:02	5:10	0:08	LINE FAULT
104	21-Jul-22	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	6:22	6:28	0:06	LINE FAULT
105	21-Jul-22	GULBARGA	220	MALLAT-RTPS2	RTPS_220	20:10	20:28	0:18	LINE FAULT
106	21-Jul-22	GULBARGA	220	MUNIRABAD-LINGAPUR1	MUNIRABAD_220	9:27	10:05	0:38	LINE FAULT
107	21-Jul-22	GULBARGA	220	SEDAM_SHAHAPUR	SEDAM_220	05:48(10/06/2022)			LINE OPEN:LINE CLEAR AVAILED
108	21-Jul-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
109	21-Jul-22	HASSAN	66	HANUBAL-SAKLES PUR	HANBALU_66	13:00	18:07	5:07	LINE CLEAR AVAILED
110	21-Jul-22	HASSAN	66	HNPR2-RNPR2	HNPURA_220	19:02	19:17	0:15	LINE FAULT
111	21-Jul-22	HASSAN	66	HV1	HANBALU_66	13:00	18:07	5:07	LINE CLEAR AVAILED
112	21-Jul-22	HASSAN	66	HV1	HNPURA_66	11:55	12:32	0:37	LINE CLEAR AVAILED
113	21-Jul-22	HASSAN	66	HV1	HOLALUR_66	12:50	13:24	0:34	LINE CLEAR AVAILED
114	21-Jul-22	HASSAN	66	HV1	SAKALESH PURA_66	20:15	20:25	0:10	TRANSFORMER FAULT
115	21-Jul-22	HASSAN	66	HV2	HOLEHONNUR_66	12:35	14:05	1:30	LINE CLEAR AVAILED
116	21-Jul-22	HASSAN	66	HV2	SINGAPURA_66	10:17	10:50	0:33	LINE CLEAR AVAILED
117	21-Jul-22	HASSAN	66	LV4	MRS MG_220	9:16	13:50	4:34	LINE CLEAR AVAILED
118	21-Jul-22	HASSAN	110	HV1	KEMAR_220	23:36(21.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
119	21-Jul-22	HASSAN	110	HV1	GERUMARA_110	13:39	15:44	2:05	LINE CLEAR AVAILED
120	21-Jul-22	HASSAN	110	HV2	ANAVATTI_110	19:30	19:40	0:10	TRANSFORMER FAULT
121	21-Jul-22	HASSAN	110	HV2	MRS MG_220	12:11	13:48	1:37	LINE CLEAR AVAILED
122	21-Jul-22	HASSAN	110	HV3	JO G_110	10:55(05.04.2022)			TRANSFORMER:LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
123	21-Jul-22	HASSAN	110	HV3	MRSMSG_220	12:11	13:48	1:37	LINE CLEAR AVAILED
124	21-Jul-22	HASSAN	110	HV4	MRSMSG_220	9:16	13:50	4:34	LINE CLEAR AVAILED
125	21-Jul-22	HASSAN	110	HV6	PUTTUR_220	12:30(20.07.2022)			TRANSFORMER:LINE CLEAR AVAILED
126	21-Jul-22	HASSAN	110	LV2	PUTTUR_220	17:16(20.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
127	21-Jul-22	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN:LINE FAULT
128	21-Jul-22	HASSAN	220	HGUNJE-KMWR1	HEGGUNJE_20	12:28	13:15	0:47	NFBC ISSUED
129	21-Jul-22	HASSAN	220	HV1	HEGGUNJE_20	10:29	12:56	2:27	LINE CLEAR AVAILED
130	21-Jul-22	HASSAN	220	HV2	PUTTUR_220	17:16(20.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
131	21-Jul-22	HASSAN	220	KEMAR-Varahi3	KEMAR_220	12:28	13:15	0:47	LINE CLEAR AVAILED
132	21-Jul-22	HASSAN	220	PUTUR-KEMAR1	PUTTUR_220	10:49	13:45	2:56	LINE CLEAR AVAILED
133	21-Jul-22	MYSURU	66	CRNAGAR-HONGANUR	HONGANUR & YELANDUR	18:57	19:04	0:07	LINE FAULT
134	21-Jul-22	MYSURU	66	HANAGODU-HUNSURU	NO STATIONS EFFECTED	10:14	16:41	6:27	NFBC ISSUED
135	21-Jul-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
136	21-Jul-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
137	21-Jul-22	MYSURU	66	HOSURGATE-HUNSUR	HOSURGATE_66	10:00	18:00	8:00	LINE CLEAR AVAILED
138	21-Jul-22	MYSURU	66	HUNSUR-HOOTGALLI	HUNSUR_66	10:08	17:48	7:39	LINE CLEAR AVAILED
139	21-Jul-22	MYSURU	66	HUNSUR-ILAWALA	HUNSUR_66	10:08	16:57	6:48	LINE CLEAR AVAILED
140	21-Jul-22	MYSURU	66	HV1	BANNIMANTAP_66	10:50	12:23	1:32	LINE CLEAR AVAILED
141	21-Jul-22	MYSURU	66	HV1	HANAGODU_66	7:57	8:04	0:06	TRANSFORMER FAULT
142	21-Jul-22	MYSURU	66	HV1	KADAKOLA_66	18:04	19:57	1:52	LINE CLEAR AVAILED
143	21-Jul-22	MYSURU	66	HV1	KADAKOLA_66	20:23	22:00	1:36	LINE CLEAR AVAILED
144	21-Jul-22	MYSURU	66	HV1	MALLAVALLI_66	15:14	15:41	0:26	LINE CLEAR AVAILED
145	21-Jul-22	MYSURU	66	HV1	SRIRANGAPATNA_66	10:02	10:14	0:12	TRANSFORMER FAULT
146	21-Jul-22	MYSURU	66	HV1	CHIKKAMANDYA_66	14:25	15:05	0:40	LINE CLEAR AVAILED
147	21-Jul-22	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00 (12.07.2022)			TRANSFORMER:LINE CLEAR AVAILED
148	21-Jul-22	MYSURU	66	HV2	GUDDENAHALLI_66	14:44	15:31	0:47	LINE CLEAR AVAILED
149	21-Jul-22	MYSURU	66	HV2	KMDODDI_66	12:31	13:00	0:28	LINE CLEAR AVAILED
150	21-Jul-22	MYSURU	66	HV2	TN PURA_66	7:38	14:25	6:47	TRANSFORMER FAULT
151	21-Jul-22	MYSURU	66	HV2	CHIKKAMANDYA_66	9:35	14:22	4:47	LINE CLEAR AVAILED
152	21-Jul-22	MYSURU	66	KADAKOLA-SARGUR2	NO STATIONS EFFECTED	17:59	18:05	0:05	LINE FAULT
153	21-Jul-22	MYSURU	66	KADAKOLA-SARGUR2	NO STATIONS EFFECTED	20:02	20:04	0:02	LINE FAULT
154	21-Jul-22	MYSURU	66	KADAKOLA-SRGUR1	JAYAPURA_66 HAMPAPURA_66	17:59	18:04	0:04	LINE FAULT
155	21-Jul-22	MYSURU	66	KADAKOLA-SRGUR1	JAYAPURA_66 HAMPAPURA_66	20:02	20:04	0:02	LINE FAULT
156	21-Jul-22	MYSURU	66	KHONALGERE-IGLOOR	NO STATIONS EFFECTED	8:18	12:52	4:34	LINE CLEAR AVAILED
157	21-Jul-22	MYSURU	66	TUBINKERE-ARKERE	ARKERE, TARIPURA GAMANAHALLY	7:10	7:17	0:07	LINE FAULT
158	21-Jul-22	MYSURU	66	VAJMANGALA-BANNUR	NO STATIONS EFFECTED	12:00	13:28	1:28	LINE CLEAR AVAILED
159	21-Jul-22	MYSURU	66	YTHAMBADI-TKHALLI	YETHAMBADI	19:13	19:20	0:07	NFBC ISSUED
160	21-Jul-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
161	21-Jul-22	MYSURU	220	KADAKOLA-HV1	KADAKOLA_220	13:41:14			LINE OPEN:LINE FAULT
162	21-Jul-22	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAGALUR_66	6:11	6:18	0:06	LINE FAULT
163	21-Jul-22	TUMKUR	66	BILCHODU66-PALLAGATTE66	BILCHODU_66	6:10	6:20	0:10	LINE CLEAR AVAIED
164	21-Jul-22	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	10:29	10:47	0:18	LINE CLEAR AVAIED
165	21-Jul-22	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	16:33	16:36	0:03	HAND TRIPPED
166	21-Jul-22	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	4:06	4:33	0:26	LINE FAULT
167	21-Jul-22	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	16:36	16:39	0:02	HAND TRIPPED
168	21-Jul-22	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	16:39	16:42	0:03	HAND TRIPPED
169	21-Jul-22	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_220	4:06	4:32	0:25	LINE FAULT
170	21-Jul-22	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_220	16:13	16:18	0:05	LINE FAULT
171	21-Jul-22	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 1	CHITRADURGA_66	4:06	4:32	0:25	LINE FAULT
172	21-Jul-22	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 1	CHITRADURGA_66	16:13	16:18	0:05	HAND TRIPPED
173	21-Jul-22	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:24	16:30	6:06	LINE CLEAR AVAIED
174	21-Jul-22	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:13	12:15	0:02	LINE FAULT
175	21-Jul-22	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	12:15	12:22	0:06	LINE FAULT
176	21-Jul-22	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	13:36	14:05	0:29	LINE FAULT
177	21-Jul-22	TUMKUR	66	MATHOD- PANCHANAHALLI	GARAGA_66,PANCHANAHALLI_66	16:50	18:15	1:25	LINE CLEAR AVAIED
178	21-Jul-22	TUMKUR	66	MATHOD- PANCHANAHALLI	GARAGA_66,PANCHANAHALLI_66	20:00	20:31	0:31	HAND TRIPPED
179	21-Jul-22	TUMKUR	66	TR-1	LOKIKERE_66	9:58	17:52	7:53	LINE CLEAR AVAIED
180	21-Jul-22	TUMKUR	66	TR-1	NIDISALE_66	17:05	17:17	0:12	LINE CLEAR AVAIED
181	21-Jul-22	TUMKUR	66	TR-1	NIDISALE_66	17:25	17:30	0:05	LINE CLEAR AVAIED
182	21-Jul-22	TUMKUR	66	TR-1(LV SIDE)	DAVANGERE_SRS_220	11:30	19:04	7:33	LOAD CHANGEOVER
183	21-Jul-22	TUMKUR	66	TR-2	CHITRADURGA_220	4:29	4:33	0:03	TRANSFORMER FAULT
184	21-Jul-22	TUMKUR	66	TR-2	KADDAJJI_66	17:02	18:49	1:46	LINE CLEAR AVAIED
185	21-Jul-22	TUMKUR	66	TR-2	MALEBENNUR_66	16:28	16:44	0:16	LINE CLEAR AVAIED
186	21-Jul-22	TUMKUR	66	TR-2	NIDISALE_66	13:40	15:00	1:20	LINE CLEAR AVAIED
187	21-Jul-22	TUMKUR	66	TR-2	NIDISALE_66	17:00	17:50	0:50	LINE CLEAR AVAIED
188	21-Jul-22	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	11:54	19:50	7:55	NFBC ISSUED
189	21-Jul-22	TUMKUR	220	TR-3(HV SIDE )	CHITRADURGA_220	8:54	9:43	0:48	TRANSFORMER FAULT
190	21-Jul-22	TUMKUR	400	GUTUR_400-BTPS	GUTUR_400	10:30	17:25	6:55	LINE CLEAR AVAIED
1	22-Jul-22	BAGALKOT	110	110/11KV, HV1	ANMOD_110	8:17	8:35	0:18	TRANSFORMER FAULT
2	22-Jul-22	BAGALKOT	110	110/11KV, HV-1	STATION NOT AFFECTED VAJJRAMATTI_220	12:25	15:35	3:10	LINE CLEAR AVAIED
3	22-Jul-22	BAGALKOT	110	110/11KV, HV-2	STATION NOT AFFECTED HAVERI_110	13:20	14:15	0:55	LINE CLEAR AVAIED
4	22-Jul-22	BAGALKOT	110	110/11KV, HV3	SAVALAGI_110	15:17	15:44	0:27	HAND TRIPPED
5	22-Jul-22	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	7:28	7:36	0:08	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
6	22-Jul-22	BAGALKOT	110	110/11KV,HV1	LAXMESHWAR_110	15:04	16:02	0:58	LINE CLEAR AVAILED
7	22-Jul-22	BAGALKOT	110	110/11KV,HV1	MANTUR(G)_110	11:07	13:39	2:32	LINE CLEAR AVAILED
8	22-Jul-22	BAGALKOT	110	110/11KV,HV1	MANTUR(G)_110	14:35	18:23	3:48	LINE CLEAR AVAILED
9	22-Jul-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	19:03	21:06	2:03	TRANSFORMER FAULT
10	22-Jul-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED TODALBAGI_110	19:13 (17.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
11	22-Jul-22	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
12	22-Jul-22	BAGALKOT	110	AMBEWADI220-NK-1	STATION NOT AFFECTED AMBEWADI_220	10:09	12:44	2:35	LINE CLEAR AVAILED
13	22-Jul-22	BAGALKOT	110	AMBEWADI-NK2	STATION NOT AFFECTED AMBEWADI_220	15:54 (20.07.2022)	12:49 (22.07.2022)	44:55:00	LINE CHARGED
14	22-Jul-22	BAGALKOT	110	BAGLKOT220-GULEDGUDDA	GULEDGUDDA_110	17:13	17:17	0:04	HAND TRIPPED
15	22-Jul-22	BAGALKOT	110	GADAG220-DAMBAL	DAMBAL_110	17:20	17:56	0:36	HAND TRIPPED
16	22-Jul-22	BAGALKOT	110	GADAG220-SAMBAPUR	SAMBAPUR_110	16:17	17:53	1:36	LINE CLEAR AVAILED
17	22-Jul-22	BAGALKOT	110	HALIYAL-NK-1	STATION NOT AFFECTED HALIYAL_110	10:20 (21.07.2022)	12:41 (22.07.2022)	26:21:00	LINE CHARGED
18	22-Jul-22	BAGALKOT	110	HUBLI220- RAMANAKOPPA	RAMANKOPPA_110	9:05	9:50	00:45	LINE CLEAR AVAILED
19	22-Jul-22	BAGALKOT	110	HUKKERI-V S	HUKKERI_110	12:05	12:44	0:39	LINE CLEAR AVAILED
20	22-Jul-22	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	8:50(06.07.2022)	17:30 (22.07.2022)	392:40 hrs	LINE CHARGED
21	22-Jul-22	BAGALKOT	110	KUMATA-SIRSI 1	KUMATA_110	5:16	13:28	8:12	LINE FAULT
22	22-Jul-22	BAGALKOT	110	MUNDGOD-SRS HUBLI(RAMANAKOPPA)	MUNDGOD_110	9:02	10:07	1:05	LINE CLEAR AVAILED
23	22-Jul-22	BAGALKOT	110	RAMANAKOPPA-SAVANUR( MUNDGOD)	RAMANAKOPPA_110	9:05	10:10	1:05	LINE CLEAR AVAILED
24	22-Jul-22	BAGALKOT	110	SAMBAPUR-DAMBAL	SAMBAPUR_110	18:03	18:13	0:10	LINE CLEAR AVAILED
25	22-Jul-22	BAGALKOT	110	SAMBAPUR-RLY Cbreaker	SAMBAPUR_110	13:10	18:02	4:52	LINE CLEAR AVAILED
26	22-Jul-22	BAGALKOT	110	SIRSI220-KAWALAWADA	STATION NOT AFFECTED SIRSI_220	13:03	14:19	1:16	LINE CLEAR AVAILED
27	22-Jul-22	BAGALKOT	110	SIRSI220-SIRSI-I	STATION NOT AFFECTED SIRSI_220	13:02	14:12	1:10	LINE CLEAR AVAILED
28	22-Jul-22	BAGALKOT	110	SIRSI220-SIRSI-II	STATION NOT AFFECTED SIRSI_220	13:02	14:12	1:10	LINE CLEAR AVAILED
29	22-Jul-22	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	12:45	14:10	1:25	LINE CLEAR AVAILED
30	22-Jul-22	BAGALKOT	110	SIRSI-JOG1	STATION NOT AFFECTED SIRSI_110	11:15 (09.07.2022)	13:01 (22.07.2022)	313:46:00	LINE CHARGED
31	22-Jul-22	BAGALKOT	110	SIRSI-KAVALWADA	STATION NOT AFFECTED SIRSI_110	12:55 (22.07.2022)			LINE OPEN:LINE CLEAR AVAILED
32	22-Jul-22	BAGALKOT	110	SIRSI-KUMATA2	SIRSI_110	5:15	12:55	07:40	LINE FAULT
33	22-Jul-22	BAGALKOT	110	SIRSI-KUMATA2	STATION NOT AFFECTED SIRSI_110	11:02	12:54	1:52	LINE CLEAR AVAILED
34	22-Jul-22	BAGALKOT	110	TODALBAGI-SAVALAGI	TODALBAGI_110	18:00 (20.07.2022)			LINE OPEN:LINE FAULT
35	22-Jul-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
36	22-Jul-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED SIRSI_220	13:12	13:54	0:42	LINE CLEAR AVAIED
37	22-Jul-22	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED SOUDATTI_220	10:52 (19.07.2022)			TRANSFORMER:LINE CLEAR AVAIED
38	22-Jul-22	BAGALKOT	220	AEQUS-BELAGAVI-1	STATION NOT AFFECTED AEQUS_220	11:27 (22.07.2022)			LINE OPEN:LINE CLEAR AVAIED
39	22-Jul-22	BAGALKOT	220	AMBEWADI-NARENDRA-2	STATION NOT AFFECTED AMBEWADI_220	14:52	15:21	0:29	LINE FAULT
40	22-Jul-22	BAGALKOT	220	BAGEWADI-BIJAPUR-1&2	STATION NOT AFFECTED BAGEWADI_220	18:31 (22.07.2022)			LINE OPEN:LINE CLEAR AVAIED
41	22-Jul-22	BAGALKOT	220	BELAGAVI-AEQUS-1	STATION NOT AFFECTED BELAGAVI_220	11:27 (22.07.2022)			LINE OPEN:LINE CLEAR AVAIED
42	22-Jul-22	BAGALKOT	220	GADAG-HARTI-1	STATION NOT AFFECTED GADAG_220	10:55 (19.07.2020)			LINE OPEN:LINE CLEAR AVAIED
43	22-Jul-22	BAGALKOT	220	GADAG-HARTI-2	STATION NOT AFFECTED GADAG_220	10:55 (19.07.2020)			LINE OPEN:LINE CLEAR AVAIED
44	22-Jul-22	BAGALKOT	220	HAVERI220-GUTTUR-2	STATION NOT AFFECTED HAVERI_220	21:53 (21.07.2022)	12:05 (22.07.2022)	14:12:00	LINE CHARGED
45	22-Jul-22	BAGALKOT	220	NAGAJHARI-AMBEWADI-1	STATION NOT AFFECTED AMBEWADI_220	13:21	17:06	3:45	LINE CLEAR AVAIED
46	22-Jul-22	BAGALKOT	220	NARENDRA AMBEWADI-2	STATION NOT AFFECTED NARENDRA_220	14:53	15:17	0:24	LINE FAULT
47	22-Jul-22	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN:LINE CLEAR AVAIED
48	22-Jul-22	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN:LINE CLEAR AVAIED
49	22-Jul-22	BENGALURU	66	BANGARPETE - MALUR 220	BANGARPETE	17:15	17:20	0:05	LINE CLEAR AVAIED
50	22-Jul-22	BENGALURU	66	HV1	ALUR	15:31	15:34	0:03	LINE CLEAR AVAIED
51	22-Jul-22	BENGALURU	66	HV1	ALUR	15:34	15:42	0:07	LINE CLEAR AVAIED
52	22-Jul-22	BENGALURU	66	HV1	BANGARPETE	15:30	15:35	0:05	LINE CLEAR AVAIED
53	22-Jul-22	BENGALURU	66	HV1	BANGARPETE	19:15	19:20	0:05	LINE CLEAR AVAIED
54	22-Jul-22	BENGALURU	66	HV1	KHODAYS 220	10:19	13:04	2:45	LINE CLEAR AVAIED
55	22-Jul-22	BENGALURU	66	HV1	KHODAYS 220	15:45	15:50	0:05	LINE CLEAR AVAIED
56	22-Jul-22	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	10:20	10:34	0:14	TRANSFORMER FAULT
57	22-Jul-22	BENGALURU	66	HV1	VIDHURASHWATHA	11:00	12:10	1:10	LINE CLEAR AVAIED
58	22-Jul-22	BENGALURU	66	HV2	BANGARPETE	10:50	10:55	0:05	LINE CLEAR AVAIED
59	22-Jul-22	BENGALURU	66	HV2	BANGARPETE	19:15	19:20	0:05	LINE CLEAR AVAIED
60	22-Jul-22	BENGALURU	66	HV2	KHODAYS 220	13:09	15:55	2:46	LINE CLEAR AVAIED
61	22-Jul-22	BENGALURU	66	HV2	KONDASPURA	12:48	13:14	0:25	LINE CLEAR AVAIED
62	22-Jul-22	BENGALURU	66	HV2	MAGADI 66	10:09	10:15	0:05	LINE CLEAR AVAIED
63	22-Jul-22	BENGALURU	66	HV3	BANGARPETE	16:00	16:30	0:30	LINE CLEAR AVAIED
64	22-Jul-22	BENGALURU	66	HV3	BANGARPETE	19:15	19:20	0:05	LINE CLEAR AVAIED
65	22-Jul-22	BENGALURU	66	NRS 220 - NANDINI LAYOUT	NO STATION AFFECTED	17:52	21:15	3:23	LINE FAULT
66	22-Jul-22	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:36	13:00	0:23	MAIN SUPPLY FAILURE
67	22-Jul-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:36	12:55	0:19	MAIN SUPPLY FAILURE
68	22-Jul-22	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	6:05	6:54	0:49	LINE FAULT
69	22-Jul-22	BENGALURU	220	LV1	SARJAPURA 220	12:36	12:55	0:18	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
70	22-Jul-22	GULBARGA	66	HV2	BENNEHALLI_66	11:20	11:25	0:05	TRANSFORMER FAULT
71	22-Jul-22	GULBARGA	66	HV2	BENNEHALLI_66	12:25	12:35	0:10	TRANSFORMER FAULT
72	22-Jul-22	GULBARGA	66	ITTAGI-HIREHADAGALI_2	HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66, SOVENHALLI_66, TUNGA BHADRA_IPP	19:10	19:13	0:03	LINE CLEAR AVAIED
73	22-Jul-22	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELS	18:40	18:56	0:16	LINE FAULT
74	22-Jul-22	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_110	16:45	17:30	0:45	LINE CLEAR AVAIED
75	22-Jul-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	3:54(20/07/2022)			LINE OPEN:LINE CLEAR AVAIED
76	22-Jul-22	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	9:34(20/07/2022)			LINE OPEN:LINE CLEAR AVAIED
77	22-Jul-22	GULBARGA	110	HV1	NIRNA_110	20:07	20:11	0:04	TRANSFORMER FAULT
78	22-Jul-22	GULBARGA	110	HV3	KOPPAL_110	06:55(22.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
79	22-Jul-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	20:08	20:18	0:10	LINE FAULT
80	22-Jul-22	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110,ADVIAMRESHWAR_110	21:25	21:38	0:13	LINE FAULT
81	22-Jul-22	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORWAR TEMPLE_110	22:15	23:56	1:41	LINE FAULT
82	22-Jul-22	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110,KONKAL_110	16:13	16:32	0:19	LINE FAULT
83	22-Jul-22	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110,KONKAL_110	17:11	17:30	0:19	LINE CLEAR AVAIED
84	22-Jul-22	GULBARGA	110	SEDAM-ULTRATECH CEMENT_IPP	SEDAM_220	21:09	22:12	1:03	LINE FAULT
85	22-Jul-22	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	21:53	22:03	0:10	LINE FAULT
86	22-Jul-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	20:25	21:38	1:13	LINE FAULT
87	22-Jul-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN:LINE CLEAR AVAIED
88	22-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAIED
89	22-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAIED
90	22-Jul-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	1:20	1:25	0:05	LINE FAULT
91	22-Jul-22	GULBARGA	110	SHAHAPUR-RAICHUR_1	DEODURGA_110	4:50	4:55	0:05	LINE FAULT
92	22-Jul-22	GULBARGA	110	SHAHAPUR-RAICHUR_1	DEODURGA_110	21:54	22:08	0:14	LINE FAULT
93	22-Jul-22	GULBARGA	110	SHAHAPUR-RAICHUR_2	DEODURGA_110	4:50	5:10	0:20	LINE FAULT
94	22-Jul-22	GULBARGA	110	SHAHAPUR-RAICHUR_2	DEODURGA_110	21:54	22:08	0:14	LINE FAULT
95	22-Jul-22	GULBARGA	110	SINDHNOOR-SUZLON	SINDHNOOR_220	2:15	2:25	0:10	LINE FAULT
96	22-Jul-22	GULBARGA	110	SINDHNOOR-SUZLON	SINDHNOOR_220	3:58	4:08	0:10	LINE FAULT
97	22-Jul-22	GULBARGA	110	SINDHNOOR-SUZLON	SINDHNOOR_220	5:25	5:45	0:20	LINE FAULT
98	22-Jul-22	GULBARGA	110	SINDHNOOR-VALABELLARI	MANVI_110,MADLAPUR_110,KURDICROSS_110,ADVIAMRESHWAR_110,JAWALGERA_110	3:35	4:05	0:30	LINE FAULT
99	22-Jul-22	GULBARGA	110	SINDHNOOR-VALABELLARI	MANVI_110,MADLAPUR_110,KURDICROSS_110,ADVIAMRESHWAR_110,JAWALGERA_110	22:40	22:50	0:10	LINE FAULT
100	22-Jul-22	GULBARGA	110	SULEKAL-GANGAVATI	GANGAVATI_110	18:20	21:02	2:42	LINE FAULT
101	22-Jul-22	GULBARGA	110	YARADONA- GANAGAVATHI(SULEKAL)	YARADONA_110	5:40	5:50	0:10	MAIN SUPPLY FAILURE
102	22-Jul-22	GULBARGA	220	HV1	SINDHNOOR_220	11:30	14:30	3:00	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
103	22-Jul-22	GULBARGA	220	HV2	KUDLIGI_220 (BADELADUKU)	5:55	6:45	0:50	TRANSFORMER FAULT
104	22-Jul-22	GULBARGA	220	LINGASUGUR-BAGEWADI 1&2	BAGEWADI_220	12:22	16:30	4:08	NFBC ISSUED
105	22-Jul-22	GULBARGA	220	SEDAM_SHAHAPUR	SEDAM_220	05:48(10/06/2022)			LINE OPEN:LINE CLEAR AVAILED
106	22-Jul-22	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	23:21	23:30	0:09	LINE FAULT
107	22-Jul-22	GULBARGA	220	SHAHAPUR-RTPS_1	SHAHAPUR_220	23:21	23:30	0:09	LINE FAULT
108	22-Jul-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
109	22-Jul-22	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	9:37	11:17	1:40	LINE CLEAR AVAILED
110	22-Jul-22	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLI_66	10:50	11:15	0:25	LINE CLEAR AVAILED
111	22-Jul-22	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	10:20	15:50	5:30	NFBC ISSUED
112	22-Jul-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	12:26(22.07.2022)			LINE OPEN:LINE CLEAR AVAILED
113	22-Jul-22	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	6:22	6:32	0:10	LINE FAULT
114	22-Jul-22	HASSAN	66	HV1	ALDUR_66	20:15	20:26	0:11	TRANSFORMER FAULT
115	22-Jul-22	HASSAN	66	HV1	DODDAKADANUR_66	18:45	19:06	0:21	LINE CLEAR AVAILED
116	22-Jul-22	HASSAN	66	HV1	HNPURA_66	11:32	15:20	3:48	LINE CLEAR AVAILED
117	22-Jul-22	HASSAN	66	HV1	MALLAPURA_66	11:40	13:22	1:42	LINE CLEAR AVAILED
118	22-Jul-22	HASSAN	66	HV1	RAMESHWARANAGARA_66	11:01	13:18	2:17	LINE CLEAR AVAILED
119	22-Jul-22	HASSAN	66	HV1	RAMESHWARANAGARA_66	14:30	14:35	0:05	TRANSFORMER FAULT
120	22-Jul-22	HASSAN	66	HV1	SHANTHIGRAMA_66	12:08	12:57	0:49	LINE CLEAR AVAILED
121	22-Jul-22	HASSAN	66	HV1	MANJUNATHPURA_66	11:24	12:46	1:22	TRANSFORMER FAULT
122	22-Jul-22	HASSAN	66	HV2	MALLAPURA_66	11:40	13:21	1:41	LINE CLEAR AVAILED
123	22-Jul-22	HASSAN	66	HV2	RAMPURA_66	10:26	15:55	5:29	MAIN SUPPLY FAILURE
124	22-Jul-22	HASSAN	66	HV2	S.BELAGOLA_66	16:04	16:40	0:36	LINE CLEAR AVAILED
125	22-Jul-22	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	11:17	12:51	1:34	LINE CLEAR AVAILED
126	22-Jul-22	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	11:41	13:21	1:40	LINE CLEAR AVAILED
127	22-Jul-22	HASSAN	66	RAMPUR-BEGUR	RAMPURA_66	10:26	15:52	5:26	MAIN SUPPLY FAILURE
128	22-Jul-22	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	12:40	17:52	5:12	LINE CLEAR AVAILED
129	22-Jul-22	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	14:52	15:37	0:45	LINE CLEAR AVAILED
130	22-Jul-22	HASSAN	110	HV1	KEMAR_220	23:36(21.07.2022)	10:55(22.07.2022)	11:31HRS	TRANSFORMER CHARGED
131	22-Jul-22	HASSAN	110	HV2	KARAYA_110	14:32	18:35	4:03	LINE CLEAR AVAILED
132	22-Jul-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER:LINE CLEAR AVAILED
133	22-Jul-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER:LINE CLEAR AVAILED
134	22-Jul-22	HASSAN	110	HV6	PUTTUR_220	12:30(20.07.2022)			TRANSFORMER:LINE CLEAR AVAILED
135	22-Jul-22	HASSAN	110	KEMAR-MSEZ2	KEMAR_220	10:53	12:02	1:09	NFBC ISSUED
136	22-Jul-22	HASSAN	110	LV2	PUTTUR_220	17:16(20.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
137	22-Jul-22	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN:LINE FAULT
138	22-Jul-22	HASSAN	220	HV2	PUTTUR_220	17:16(20.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
139	22-Jul-22	HASSAN	220	KEMAR-MSEZ1	KEMAR_220	12:08	13:52	1:44	NFBC ISSUED
140	22-Jul-22	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	15:30	15:43	0:13	LINE CLEAR AVAILED
141	22-Jul-22	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	14:32	15:10	0:38	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
142	22-Jul-22	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	12:24	13:53	1:29	LINE CLEAR AVAILED
143	22-Jul-22	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	11:08	12:03	0:55	LINE CLEAR AVAILED
144	22-Jul-22	MYSURU	66	BGNAGA-YEDIYUR	AC GIRI & VADERAHALLI	13:31	13:45	0:13	NFBC ISSUED
145	22-Jul-22	MYSURU	66	COWDALLI-HV1	COWDALLI	0:55	1:10	0:15	LINE FAULT
146	22-Jul-22	MYSURU	66	COWDALLI-HV2	COWDALLI	0:55	1:10	0:15	LINE FAULT
147	22-Jul-22	MYSURU	66	DEVANOR NANJANGUDU-BAS2	NO STATIONS EFFECTED	14:45	17:44	2:58	LINE CLEAR AVAILED
148	22-Jul-22	MYSURU	66	HANAGODU-HV1	NO STATIONS EFFECTED	17:13	17:23	0:10	LINE FAULT
149	22-Jul-22	MYSURU	66	HANAGODU-HV1	NO STATIONS EFFECTED	18:22	18:28	0:06	LINE FAULT
150	22-Jul-22	MYSURU	66	HANAGODU-HV1	NO STATIONS EFFECTED	18:45	18:50	0:04	LINE FAULT
151	22-Jul-22	MYSURU	66	HANAGODU-HV1	NO STATIONS EFFECTED	18:58	19:26	0:28	LINE FAULT
152	22-Jul-22	MYSURU	66	HARADANAHALLI JAK-HV1	NO STATIONS EFFECTED	12:18	13:29	1:11	LINE CLEAR AVAILED
153	22-Jul-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00(08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
154	22-Jul-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
155	22-Jul-22	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00 (12.07.2022)			TRANSFORMER:LINE CLEAR AVAILED
156	22-Jul-22	MYSURU	66	KMDODDI-HV2	NO STATIONS EFFECTED	15:47	16:17	0:30	LINE CLEAR AVAILED
157	22-Jul-22	MYSURU	66	MADHUVANAHALLI-HANNUR1	HANNUR, KOTHANUR	6:33	7:49	1:15	LINE FAULT
158	22-Jul-22	MYSURU	66	MADHUVANAHALLI-HANNUR2	HANNUR, KOTHANUR	6:33	7:49	1:16	LINE FAULT
159	22-Jul-22	MYSURU	66	MADHUVANAHALLI-PGPALYA	LOKKANHALLI & PGPALYA	12:39	12:45	0:06	LINE FAULT
160	22-Jul-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
161	22-Jul-22	MYSURU	220	KADAKOLA-HV1	KADAKOLA_220	1:41:14 (21/07/2022)			LINE OPEN:LINE FAULT
162	22-Jul-22	TUMKUR	66	CHITRADURGA 220kv- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	17:19	17:50	0:31	LINE FAULT
163	22-Jul-22	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR(HGML)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	10:45	16:30	5:45	LINE CLEAR AVAILED
164	22-Jul-22	TUMKUR	66	CHITRADURGA 220kv- SUZLON 2	SUZLON2_IPP_66	17:19	17:50	0:31	LINE FAULT
165	22-Jul-22	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	17:19	17:50	0:31	LINE FAULT
166	22-Jul-22	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66,	12:00	12:10	0:10	LINE FAULT
167	22-Jul-22	TUMKUR	66	HANAGAL-RAMPURA	HANAGAL_66	12:00	12:10	0:10	LINE FAULT
168	22-Jul-22	TUMKUR	66	HANAGAL-THALLAK 1	HANAGAL_66	11:50	12:00	0:10	LINE FAULT
169	22-Jul-22	TUMKUR	66	HANAGAL-THALLAK2	HANAGAL_66	11:50	12:00	0:10	LINE FAULT
170	22-Jul-22	TUMKUR	66	HIEMALLANAHOLE66-NAYAKANA HATTI	NAYAKANAHATTY_66	6:45	7:00	0:15	LINE FAULT
171	22-Jul-22	TUMKUR	66	HONNALLI 220kv- KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	15:39	16:20	0:41	MAIN SUPPLY FAILURE
172	22-Jul-22	TUMKUR	66	HOSADURGA_220-HALRAMESHWARA_66 LINE-2	HOSADURGA_220	17:00	17:30	0:30	LINE FAULT
173	22-Jul-22	TUMKUR	66	KUNDUR- SUZLON_IPP_66	SUZLON_IPP_66	15:55	16:30	0:35	MAIN SUPPLY FAILURE
174	22-Jul-22	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	11:17	12:50	1:33	MAIN SUPPLY FAILURE
175	22-Jul-22	TUMKUR	66	MADANAYAKANAHALLI-CHITRADURGA220	MADANAYAKANAHALLI_66	17:20	17:50	0:30	MAIN SUPPLY FAILURE
176	22-Jul-22	TUMKUR	66	MATHOD- PANCHANAHALLI	GARAGA_66,PANCHANAHALLI_66	15:10	16:20	1:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
177	22-Jul-22	TUMKUR	66	PKOTE-HARIYABBE	PKOTE_66	17:05	18:35	1:30	NFBC ISSUED
178	22-Jul-22	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	11:47	11:57	0:10	LINE FAULT
179	22-Jul-22	TUMKUR	66	THALLAK 220kV -BGKERE 2	HANAGAL_66,	11:47	11:57	0:10	LINE FAULT
180	22-Jul-22	TUMKUR	66	TMTC_66	KIADB	11:31	12:42	1:11	LINE CLEAR AVAILED
181	22-Jul-22	TUMKUR	66	TR1	DAVANGERE_66	5:02	9:35	4:33	LINE CLEAR AVAILED
182	22-Jul-22	TUMKUR	66	TR1	KIADB	11:31	12:30	0:59	LINE CLEAR AVAILED
183	22-Jul-22	TUMKUR	66	TR1	KIADB	15:05	17:46	2:41	LINE CLEAR AVAILED
184	22-Jul-22	TUMKUR	66	TR2	DAVANGERE_66	6:30	11:30	5:00	LINE CLEAR AVAILED
185	22-Jul-22	TUMKUR	66	TR2	DAVANGERE_66	15:50	16:30	0:40	LINE CLEAR AVAILED
186	22-Jul-22	TUMKUR	66	TR2	KIADB	11:31	15:10	3:39	LINE CLEAR AVAILED
187	22-Jul-22	TUMKUR	66	TR-2	GUTUR_66	11:35	12:15	0:40	LINE CLEAR AVAILED
188	22-Jul-22	TUMKUR	66	TR-2	HOLALKERE_66	12:30	12:35	0:05	TRANSFORMER FAULT
189	22-Jul-22	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	8:02(22.07.22)			LINE OPEN:LINE CLEAR AVAILED
190	22-Jul-22	TUMKUR	220	GUTTUR_400DAVANGERE LINE -1	GUTTUR_400	9:23	20:21	10:58	LINE CLEAR AVAILED
191	22-Jul-22	TUMKUR	220	HIRIYUR220-MADHUGIRI220	HIRIYUR_220	11:22	16:40	5:18	NFBC ISSUED
192	22-Jul-22	TUMKUR	220	TR1	KIADB	11:29	12:23	0:54	TRANSFORMER FAULT
193	22-Jul-22	TUMKUR	220	TR2	KIADB	11:23	11:26	0:03	TRANSFORMER FAULT
194	22-Jul-22	TUMKUR	220	TR-3	CHITRADURGA_220	17:19	17:50	0:31	TRANSFORMER FAULT
195	23-Jul-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NAVANAGAR(H)_110	13:30	15:45	2:15	LINE CLEAR AVAILED
196	23-Jul-22	BAGALKOT	110	110/11KV, HV2	SAVALAGI_110	14:55	16:05	01:10	LINE CLEAR AVAILED
197	23-Jul-22	BAGALKOT	110	110/11KV, HV-2	STATION NOT AFFECTED HAVERI_110	11:10	11:55	0:45	LINE CLEAR AVAILED
198	23-Jul-22	BAGALKOT	110	110/11KV, HV-2	STATION NOT AFFECTED NAVANAGAR(H)_110	13:30	14:03	0:33	LINE CLEAR AVAILED
199	23-Jul-22	BAGALKOT	110	110/11KV,HV1	MAMADPUR(G)_110	9:18	10:45	1:27	LINE CLEAR AVAILED
200	23-Jul-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED TODALBAGI_110	19:13 (17.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
201	23-Jul-22	BAGALKOT	110	110/11KV,HV3( HV2)	TIKOTA_110	9:48	13:19	3:31	TRANSFORMER FAULT
202	23-Jul-22	BAGALKOT	110	110/11KV,HV4	BAILHONGAL_110	0:31	0:52	0:21	TRANSFORMER FAULT
203	23-Jul-22	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
204	23-Jul-22	BAGALKOT	110	BAGLKOT220-LOKAPUR	STATION NOT AFFECTED BAGLKOT_220	8:07	18:22	10:15	LINE CLEAR AVAILED
205	23-Jul-22	BAGALKOT	110	INDI-HIREMASALI	HIREMASALI_110 &ATHARGA_110	17:49	18:01	0:12	HAND TRIPPED
206	23-Jul-22	BAGALKOT	110	LOKAPUR-SALAHALL	SALAHALII_110	8:06	18:55	10:49	MAIN SUPPLY FAILURE
207	23-Jul-22	BAGALKOT	110	RANEENNUR220- AREMALLAPUR (HONNATTI)	HONNATTI_110	5:27	5:38	0:11	LINE FAULT
208	23-Jul-22	BAGALKOT	110	RANEENNUR-AREMALLAPURA( HONNATTI)	HONNATTI_110	5:27	5:38	0:11	LINE FAULT
209	23-Jul-22	BAGALKOT	110	SALAHALL-GMNVR	SALAHALLI_110	12:45	19:11	6:26	LINE CLEAR AVAILED
210	23-Jul-22	BAGALKOT	110	SALAHALL-HOSKOTE	SALAHALII_110	9:00	19:15	10:15	LINE CLEAR AVAILED
211	23-Jul-22	BAGALKOT	110	SAMBAPUR-RLY Cbreaker	SAMBAPUR_110	12:06	14:13	2:07	NFBC ISSUED
212	23-Jul-22	BAGALKOT	110	SIRSI-KAVALWADA	STATION NOT AFFECTED SIRSI_110	12:55 (22.07.2022)			LINE OPEN:LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
213	23-Jul-22	BAGALKOT	110	TODALBAGI-SAVALAGI	TODALBAGI_110	18:00 (20.07.2022)			LINE OPEN:LINE FAULT
214	23-Jul-22	BAGALKOT	110	VAJJRAMATTI220-LOKAPUR	STATION NOT AFFECTED VAJJRAMATTI_220	7:38	18:45	11:07	LINE CLEAR AVAIED
215	23-Jul-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
216	23-Jul-22	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED SOUDATTI_220	10:52 (19.07.2022)	19:29 (23.07.2022)	104:37:00	TRANSFORMER CHARGED
217	23-Jul-22	BAGALKOT	220	AEQUS-BELAGAVI-1	STATION NOT AFFECTED AEQUS_220	11:27 (22.07.2022)			LINE OPEN:LINE CLEAR AVAIED
218	23-Jul-22	BAGALKOT	220	BAGEWADI-BIJAPUR-1&2	STATION NOT AFFECTED BAGEWADI_220	18:31 (22.07.2022)			LINE OPEN:LINE CLEAR AVAIED
219	23-Jul-22	BAGALKOT	220	BELAGAVI-AEQUS-1	STATION NOT AFFECTED BELAGAVI_220	11:27 (22.07.2022)			LINE OPEN:LINE CLEAR AVAIED
220	23-Jul-22	Bagalkot	220	GADAG-HARTI-1	STATION NOT AFFECTED GADAG_220	10:55 (19.07.2020)			LINE OPEN:LINE CLEAR AVAIED
221	23-Jul-22	Bagalkot	220	GADAG-HARTI-2	STATION NOT AFFECTED GADAG_220	10:55 (19.07.2020)			LINE OPEN:LINE CLEAR AVAIED
222	23-Jul-22	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN:LINE CLEAR AVAIED
223	23-Jul-22	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN:LINE CLEAR AVAIED
224	23-Jul-22	BENGALURU	66	A STATION 220 - A STATION 66 1	A STATION 66	7:03	7:10	0:07	MAIN SUPPLY FAILURE
225	23-Jul-22	BENGALURU	66	A STATION 220 - SHOBHA INDRAPRASTA	SHOBHA INDRAPRASTA	7:03	7:10	0:07	MAIN SUPPLY FAILURE
226	23-Jul-22	BENGALURU	66	AUSTIN TOWN - EAST DIVISION COMPOUND 220	AUSTIN TOWN	7:03	7:40	0:37	MAIN SUPPLY FAILURE
227	23-Jul-22	BENGALURU	66	BMTC - EAST DIVISION COMPOUND 220	BMTC	7:03	7:34	0:31	MAIN SUPPLY FAILURE
228	23-Jul-22	BENGALURU	66	HOODY 220 - BAGHMANE WORLD TECH PARK 2	NO STATION AFFECTED	8:37	10:47	2:10	LINE FAULT
229	23-Jul-22	BENGALURU	66	HV1	M GOLLAHALLI	18:19	18:40	0:21	TRANSFORMER FAULT
230	23-Jul-22	BENGALURU	66	HV2	MAGADI 66	12:45	12:53	0:08	LINE CLEAR AVAIED
231	23-Jul-22	BENGALURU	66	HV2	VIDHURASHWATHA	16:17	16:28	0:10	TRANSFORMER FAULT
232	23-Jul-22	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	7:22	7:26	0:04	LOAD CHANGEVER
233	23-Jul-22	BENGALURU	220	A STATION 220 - EAST DIVISION COMPOUND 220	A STATION 220	7:03	7:10	0:07	MAIN SUPPLY FAILURE
234	23-Jul-22	BENGALURU	220	EAST DIVISION COMPOUND 220 - A STATION 220	NO STATION AFFECTED	7:03	8:38	1:35	LINE FAULT
235	23-Jul-22	BENGALURU	220	EAST DIVISION COMPOUND 220 - A STATION 220	NO STATION AFFECTED	08:38:00(23/07/2022)			LINE OPEN:LINE FAULT
236	23-Jul-22	BENGALURU	220	EAST DIVISION COMPOUND 220 - HAL 220	EAST DIVISION COMPOUND 220	7:03	7:35	0:32	MAIN SUPPLY FAILURE
237	23-Jul-22	BENGALURU	220	EAST DIVISION COMPOUND 220 - HAL 220	EAST DIVISION COMPOUND 220	8:38	8:43	0:05	MAIN SUPPLY FAILURE
238	23-Jul-22	BENGALURU	220	HAL 220 - EAST DIVISION COMPOUND 220	EAST DIVISION COMPOUND 220	7:03	7:34	0:31	LINE FAULT
239	23-Jul-22	BENGALURU	220	HAL 220 - EAST DIVISION COMPOUND 220	EAST DIVISION COMPOUND 220	8:38	8:42	0:04	LINE FAULT
240	23-Jul-22	BENGALURU	220	HV1	EAST DIVISION COMPOUND 220	7:03	8:45	1:42	TRANSFORMER FAULT
241	23-Jul-22	GULBARGA	66	HOLAGINDI-ITTAGGI	HOLAGUNDI_66	7:15	7:28	0:13	LINE FAULT
242	23-Jul-22	GULBARGA	66	HV1	HOSAHALLI_66	14:00	14:15	0:15	TRANSFORMER FAULT
243	23-Jul-22	GULBARGA	66	HV1	HOSAHALLI_66	15:40	15:50	0:10	TRANSFORMER FAULT
244	23-Jul-22	GULBARGA	66	HV2	PUNABGHATA_66	10:50	11:00	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
245	23-Jul-22	GULBARGA	66	NEELGUNDA-PUNABGHATA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJAINI_66	10:50	11:00	0:10	LINE FAULT
246	23-Jul-22	GULBARGA	66	UJJAINI-BREIPL_IPP	UJJAINI_66	10:08	10:41	0:33	LINE FAULT
247	23-Jul-22	GULBARGA	66	UJJAINI-BREIPL_IPP	UJJAINI_66	10:54	11:30	0:36	LINE FAULT
248	23-Jul-22	GULBARGA	110	ADAVI AMARESHWAR-JAWALGERA	JAWALGERA_110	1:02	1:19	0:17	LINE FAULT
249	23-Jul-22	GULBARGA	110	ADAVI AMARESHWAR-JAWALGERA	JAWALGERA_110	5:45	5:58	0:13	LINE FAULT
250	23-Jul-22	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELS	6:02	6:07	0:05	LINE FAULT
251	23-Jul-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110	0:15	0:30	0:15	LINE FAULT
252	23-Jul-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110	5:40	5:45	0:05	LINE FAULT
253	23-Jul-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_110,DIGGI_110	5:42	5:47	0:05	LINE FAULT
254	23-Jul-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	16:00	23:18	7:18	LINE FAULT
255	23-Jul-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	0:55	0:59	0:04	LINE FAULT
256	23-Jul-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	18:47	18:52	0:05	LINE FAULT
257	23-Jul-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	3:54(20/07/2022)			LINE OPEN:LINE CLEAR AVAILED
258	23-Jul-22	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	9:34(20/07/2022)			LINE OPEN:LINE CLEAR AVAILED
259	23-Jul-22	GULBARGA	110	HV1	KUDLIGI_220 (BADELADUKU)	15:26	15:35	0:09	TRANSFORMER FAULT
260	23-Jul-22	GULBARGA	110	HV2	CHIDRI_110	12:15	15:45	3:30	LINE CLEAR AVAILED
261	23-Jul-22	GULBARGA	110	HV3	KOPPAL_110	06:55(22.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
262	23-Jul-22	GULBARGA	110	HV3	VALKAMDINNI_110	11:38	11:42	0:04	TRANSFORMER FAULT
263	23-Jul-22	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110,ADVIAMRESHWAR_110	5:47	5:57	0:10	LINE FAULT
264	23-Jul-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	1:20	1:50	0:30	LINE FAULT
265	23-Jul-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	4:45	4:55	0:10	LINE FAULT
266	23-Jul-22	GULBARGA	110	NALWAR-SHAHABAD2	JEEWARGI_110	5:15	6:05	0:50	LINE FAULT
267	23-Jul-22	GULBARGA	110	NANDUR-GULBARGA UNIVERCITY	GULBARGA UNIVERCITY_110	4:41	4:46	0:05	LINE FAULT
268	23-Jul-22	GULBARGA	110	RAICHUR-APMC1&2	APMC_110,CHICKSUGUR_110,SHAKTINAGAR_110	4:28	4:35	0:07	LINE FAULT
269	23-Jul-22	GULBARGA	110	RAICHUR-SINDHNOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	21:25	21:30	0:05	LINE FAULT
270	23-Jul-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	20:59	21:24	0:25	LINE FAULT
271	23-Jul-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	6:04	6:16	0:12	LINE FAULT
272	23-Jul-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN:LINE CLEAR AVAILED
273	23-Jul-22	GULBARGA	110	SHAHABAD-FARATHABAD	FARTHABAD_110,GULBARGA SOUTH_110	04:35(23/07/2022)			LINE OPEN:LINE FAULT
274	23-Jul-22	GULBARGA	110	SHAHABAD-GULBARGAUNIVERSITY2	GULBARGAUNIVERSITY_110	4:42	8:35	3:53	LINE FAULT
275	23-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
276	23-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
277	23-Jul-22	GULBARGA	110	SHAHAPUR-SHAHAPUR_1	SHAHAPUR_110,JEEWARGI_110	5:41	15:55	10:14	LINE FAULT
278	23-Jul-22	GULBARGA	110	SHAKTINAGAR-RAICHUR BIOMASS	SHAKTINAGAR_110	2:35	2:45	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
279	23-Jul-22	GULBARGA	110	SINDHNOOR-SINDHNOOR2	SINDHNOOR_110,VALKAMDINNI_110,BYAGWAT_110	23:45	23:55	0:10	LINE FAULT
280	23-Jul-22	GULBARGA	110	SINDHNOOR-VALABELLARI	MANVI_110,MADLAPUR_110,KURDICROSS_110,ADVIAMRESHWAR_110,JAWALGERA_110	1:42	1:52	0:10	LINE FAULT
281	23-Jul-22	GULBARGA	110	SINDHNOOR-VALABELLARI	MANVI_110,MADLAPUR_110,KURDICROSS_110,ADVIAMRESHWAR_110,JAWALGERA_110	23:15	23:25	0:10	LINE FAULT
282	23-Jul-22	GULBARGA	220	KAPNOOR-WEST2	GULBARGA WEST_110,GULBARGA SOUTH_110	5:20	5:42	0:22	LINE FAULT
283	23-Jul-22	GULBARGA	220	SEDAM_SHAHAPUR	SEDAM_220	05:48(10/06/2022)			LINE OPEN:LINE CLEAR AVAILED
284	23-Jul-22	GULBARGA	220	SEDAM-RTPS_2	SEDAM_220	2:03	3:18	1:15	LINE FAULT
285	23-Jul-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
286	23-Jul-22	GULBARGA	400	RTPS-RAICHURPG1	RTPS_400	9:26	20:14	10:48	NFBC ISSUED
287	23-Jul-22	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	2:11	2:58	0:47	LINE FAULT
288	23-Jul-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	12:26(22.07.2022)			LINE OPEN:LINE CLEAR AVAILED
289	23-Jul-22	HASSAN	66	HASSN22-BELUR	HASSAN_220	18:58	19:20	0:22	LINE FAULT
290	23-Jul-22	HASSAN	66	HASSN22-SKPURA1	HASSAN_220	2:11	2:44	0:33	LINE FAULT
291	23-Jul-22	HASSAN	66	HASSN22-SKPURA2	HASSAN_220	2:11	2:47	0:36	LINE FAULT
292	23-Jul-22	HASSAN	66	HV1	SAKLESH PURA_66	2:12	3:01	0:49	TRANSFORMER FAULT
293	23-Jul-22	HASSAN	66	HV2	ARAKALGUD_66	4:19	4:41	0:22	TRANSFORMER FAULT
294	23-Jul-22	HASSAN	66	KANDLI-SAKLESH PUR	KANDLI_66	2:12	3:00	0:48	MAIN SUPPLY FAILURE
295	23-Jul-22	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	10:52	12:11	1:19	LINE CLEAR AVAILED
296	23-Jul-22	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	2:12	13:30	11:18	LINE FAULT
297	23-Jul-22	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	11:12	18:23	7:11	LINE CLEAR AVAILED
298	23-Jul-22	HASSAN	110	HV2	KARAYA_110	9:45	16:26	6:41	LINE CLEAR AVAILED
299	23-Jul-22	HASSAN	110	HV6	PUTTUR_220	12:30(20.07.2022)	18:55(23.07.2022)	77:85HRS	TRANSFORMER CHARGED
300	23-Jul-22	HASSAN	110	LV2	PUTTUR_220	17:16(20.07.2022)	16:18(23.07.2022)	70:62HRS	TRANSFORMER CHARGED
301	23-Jul-22	HASSAN	110	VITTAL-PUTR_SLTUR	VITLA_110	7:38	18:40	11:02	LINE CLEAR AVAILED
302	23-Jul-22	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN:LINE FAULT
303	23-Jul-22	HASSAN	220	HV2	PUTTUR_220	17:16(20.07.2022)	16:18(23.07.2022)	70:62HRS	TRANSFORMER CHARGED
304	23-Jul-22	HASSAN	220	KEMAR-VARAH12	KEMAR_220	9:07	18:36	9:29	LINE CLEAR AVAILED
305	23-Jul-22	HASSAN	220	VARAHI-KEMAR2	varahi_gen	9:09	18:38	9:29	NFBC ISSUED
306	23-Jul-22	MYSURU	66	CHIKKAMANDYA-HAMPAPURA	HAMPAPURA_66	22:39	22:48	0:09	LINE FAULT
307	23-Jul-22	MYSURU	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	21:38	21:46	0:08	LINE FAULT
308	23-Jul-22	MYSURU	66	HEBBANI 220-VADKEPURA	MALIVURU_66 KIRUGAVALU_66 VADKEPURA_66	8:55	9:04	0:09	LINE FAULT
309	23-Jul-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00(08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
310	23-Jul-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
311	23-Jul-22	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00(12.07.2022)			TRANSFORMER:LINE CLEAR AVAILED
312	23-Jul-22	MYSURU	66	HV1	HANAGODU_66	8:16	8:20	0:04	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
313	23-Jul-22	MYSURU	66	HV1	HANAGODU_66	10:15	10:22	0:07	TRANSFORMER FAULT
314	23-Jul-22	MYSURU	66	HV1	KADAKOLA-66	11:28	15:43	4:15	LINE CLEAR AVAIED
315	23-Jul-22	MYSURU	66	HV1	SRIRANGAPATNA_66	8:48	9:22	0:34	TRANSFORMER FAULT
316	23-Jul-22	MYSURU	66	HV2	GAMANAHALLY_66	17:55	18:38	0:43	LINE CLEAR AVAIED
317	23-Jul-22	MYSURU	66	HV2	SRIRANGAPATNA_66	8:49	10:01	1:12	LINE CLEAR AVAIED
318	23-Jul-22	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	22:36	22:41	0:05	LINE FAULT
319	23-Jul-22	MYSURU	66	KADAKOLA-SARAGURU 1	JAIPUR_66 HAMPAPURA(K)_66	6:03	6:12	0:09	LINE FAULT
320	23-Jul-22	MYSURU	66	KUSHALANAGARA 220-RAMANTHAPURA 1	ALUR SIDDAPURA_66 KANAGAL_66	6:01	6:08	0:06	LINE FAULT
321	23-Jul-22	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	0:10	0:20	0:09	LINE FAULT
322	23-Jul-22	MYSURU	66	SANTHE SARAGURU-KABINI 2	NO STATIONS EFFECTED	6:21	6:40	0:19	LINE FAULT
323	23-Jul-22	MYSURU	66	SFC SIVA-HEBBANI 6	NO STATIONS EFFECTED	8:56	9:07	0:11	LINE FAULT
324	23-Jul-22	MYSURU	220	HV1	KADAKOLA_220	1:41:14 (21/07/2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
325	23-Jul-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
326	23-Jul-22	TUMKUR	66	ANCHEPALYA 66kV-HEBBUR66	HEBBUR_66,THIMMASANDRA_66,HONNENAHALLI_66	16:27	16:37	0:10	LINE FAULT
327	23-Jul-22	TUMKUR	66	ANCHEPALYA 66kV-HEBBUR66	HEBBUR_66,THIMMASANDRA_66,HONNENAHALLI_66	16:58	17:35	0:37	LINE FAULT
328	23-Jul-22	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	10:11	13:45	3:34	LINE CLEAR AVAIED
329	23-Jul-22	TUMKUR	66	BRAHMASANDRA- SIRA	BRAHMASANDRA_66	13:45	14:25	0:40	LINE CLEAR AVAIED
330	23-Jul-22	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	14:13	16:50	2:37	LINE CLEAR AVAIED
331	23-Jul-22	TUMKUR	66	GUTTUR_400DAVANGERE LINE -1	GUTTUR_400	0:008(23.07.22)			LINE OPEN:LINE CLEAR AVAIED
332	23-Jul-22	TUMKUR	66	HANAGAL-THALLAK 1	HANAGAL_66	3:30	3:40	0:10	MAIN SUPPLY FAILURE
333	23-Jul-22	TUMKUR	66	HARIYABBE_66-HIRIYUR_220	HARIYABBE_66	10:30	17:45	7:15	NFBC ISSUED
334	23-Jul-22	TUMKUR	66	HIRIYUR 220KV-PARSHAMPURA_66	HIRIYUR_220	10:33	17:45	7:12	LINE CLEAR AVAIED
335	23-Jul-22	TUMKUR	66	MADANAYAKANAHALLI-CHITRADURGA220	MADANAYAKANAHALLI_66	14:13	16:50	2:37	MAIN SUPPLY FAILURE
336	23-Jul-22	TUMKUR	66	MADHUGIRI_220 -NITRAHALLI_66	MADHUGIRI_220	10:06	14:47	4:41	LINE CLEAR AVAIED
337	23-Jul-22	TUMKUR	66	PAVAGADA_220-PAVAGADA66	PAVAGADA_66	15:15	15:36	0:21	LINE CLEAR AVAIED
338	23-Jul-22	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	3:29	3:39	0:10	LINE FAULT
339	23-Jul-22	TUMKUR	66	THALLAK 220kV -BGKERE 2	HANAGAL_66,	3:29	3:40	0:11	LINE FAULT
340	23-Jul-22	TUMKUR	66	TR-2	GUTUR_66	8:50	10:10	1:20	LINE CLEAR AVAIED
341	23-Jul-22	TUMKUR	66	TR-2	GUTUR_66	11:10	12:20	1:10	LINE CLEAR AVAIED
342	23-Jul-22	TUMKUR	66	UCHANGIDURGA- PUNABHAGATTA(neelagunda)	BILCHODU_66	10:50	10:55	0:05	MAIN SUPPLY FAILURE
343	23-Jul-22	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	8:02(22.07.22)			LINE OPEN:LINE CLEAR AVAIED
344	23-Jul-22	TUMKUR	220	TR2	KBCROSS	17:28(23.07.22)			TRANSFORMER OPEN:TRANSFORMER FAULT
345	23-Jul-22	TUMKUR	220	TR2	KBCROSS	5:28(23.07.2022)	12:46(24.07.2022)	19:74 hrs	TRANSFORMER CHARGED
346	24-Jul-22	BAGALKOT	110	110/11KV, HV1	ANMOD_110	0:45	1:00	0:15	TRANSFORMER FAULT
347	24-Jul-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SHIRAGUPPI	13:30	15:10	1:40	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
348	24-Jul-22	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	16:08	17:29	1:21	LINE CLEAR AVAILED
349	24-Jul-22	BAGALKOT	110	110/11KV,HV2	KALAGHATGI_110	6:40	6:47	0:07	TRANSFORMER FAULT
350	24-Jul-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED TODALBAGI_110	19:13 (17.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
351	24-Jul-22	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
352	24-Jul-22	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
353	24-Jul-22	BAGALKOT	110	110/33KV,HV3	NIPPANI_110 & BENADI&GLASS FACTORY_33	19:49	19:56	0:07	TRANSFORMER FAULT
354	24-Jul-22	BAGALKOT	110	110/KV,HV2	NIPPANI_110	19:49	19:56	0:07	TRANSFORMER FAULT
355	24-Jul-22	BAGALKOT	110	ALMEL-KPR SUGAR&JAMAKHANDI SUGARS	ALMEL_110 (STATION NOT AFFECTED)	8:40	16:30	7:50	LINE CLEAR AVAILED
356	24-Jul-22	BAGALKOT	110	CHIKKODI220- NIPPANI (KHADAKLAT)	KHADAKALAT_110	19:30	19:45	0:15	LINE FAULT
357	24-Jul-22	BAGALKOT	110	GARAG-KITTUR	KITTUR_110	16:33	17:36	1:03	LINE CLEAR AVAILED
358	24-Jul-22	BAGALKOT	110	KADAKLAT-NIPPANI	NIPPANI_110	19:34	19:46	0:12	HAND TRIPPED
359	24-Jul-22	BAGALKOT	110	KUDACHI220-UGAR	UGAR_110	19:20	20:00	0:40	LINE FAULT
360	24-Jul-22	BAGALKOT	110	KUSHTAGI-GAJENDRAGAD	GAJENDRAGAD_110	9:56	10:27	0:31	LINE CLEAR AVAILED
361	24-Jul-22	BAGALKOT	110	SIRSI-KAVALWADA	STATION NOT AFFECTED SIRSI_110	12:55 (22.07.2022)			LINE OPEN:LINE CLEAR AVAILED
362	24-Jul-22	BAGALKOT	110	TODALBAGI-SAVALAGI	TODALBAGI_110	18:00 (20.07.2022)			LINE OPEN:LINE FAULT
363	24-Jul-22	BAGALKOT	110	UTTUR-F1 JAMB CB( MUDHOL)	STATION NOT AFFECTED UTTUR_110	9:51 (24.07.2022)			LINE OPEN:LINE CLEAR AVAILED
364	24-Jul-22	BAGALKOT	110	UTTUR-M L PURA	STATION NOT AFFECTED UTTUR_110	8:44 (25.06.2022)	9:51 (24.07.2022)	697:07:00	LINE CHARGED
365	24-Jul-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
366	24-Jul-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
367	24-Jul-22	BAGALKOT	220	AEQUS-BELAGAVI-1	STATION NOT AFFECTED AEQUS_220	11:27 (22.07.2022)			LINE OPEN:LINE CLEAR AVAILED
368	24-Jul-22	BAGALKOT	220	BAGEWADI-BIJAPUR-1&2	STATION NOT AFFECTED BAGEWADI_220	18:31 (22.07.2022)	11:34 (24.07.2022)	41:03:00	LINE CHARGED
369	24-Jul-22	BAGALKOT	220	BELAGAVI-AEQUS-1	STATION NOT AFFECTED BELAGAVI_220	11:27 (22.07.2022)			LINE OPEN:LINE CLEAR AVAILED
370	24-Jul-22	BAGALKOT	220	BELAGAVI-AEQUS-1	STATION NOT AFFECTED BELAGAVI_220	11:27 (22.07.2022)	19:50 (25.07.2022)	80:23:00	LINE CHARGED
371	24-Jul-22	Bagalkot	220	GADAG-HARTI-1	STATION NOT AFFECTED GADAG_220	10:55 (19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
372	24-Jul-22	BAGALKOT	220	GADAG-HARTI-1	STATION NOT AFFECTED GADAG_220	10:55 (19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
373	24-Jul-22	Bagalkot	220	GADAG-HARTI-2	STATION NOT AFFECTED GADAG_220	10:55 (19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
374	24-Jul-22	BAGALKOT	220	GADAG-HARTI-2	STATION NOT AFFECTED GADAG_220	10:55 (19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
375	24-Jul-22	BAGALKOT	220	HUBLI-NAGZARI-1	STATION NOT AFFECTED HUBLI_220	13:04	14:57	1:53	LINE FAULT
376	24-Jul-22	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
377	24-Jul-22	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN:LINE CLEAR AVOIDED
378	24-Jul-22	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	6:39	7:05	0:25	LINE FAULT
379	24-Jul-22	BENGALURU	66	APPAREL PARK - KIADB DB PURA 220	APPAREL PARK	10:00	17:00	7:00	LINE CLEAR AVOIDED
380	24-Jul-22	BENGALURU	66	AUSTIN TOWN - KORAMANGALA 220	AUSTIN TOWN	6:12	6:15	0:03	LOAD CHANGE OVER
381	24-Jul-22	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALIC CROSS, YENIGADALE	20:09	20:19	0:09	LINE FAULT
382	24-Jul-22	BENGALURU	66	HOSKOTE 220 - BIAL BEGUR	NO STATION AFFECTED	10:20	15:54	5:34	LINE CLEAR AVOIDED
383	24-Jul-22	BENGALURU	66	HOSKOTE 220 - BOODIGERE	NO STATION AFFECTED	10:20	15:54	5:34	LINE CLEAR AVOIDED
384	24-Jul-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT)	10:20	16:01	5:41	LINE CLEAR AVOIDED
385	24-Jul-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	BELL CERAMICS (EHT), KONDASPURA	10:20	15:52	5:32	LINE CLEAR AVOIDED
386	24-Jul-22	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	10:20	15:28	5:08	LINE CLEAR AVOIDED
387	24-Jul-22	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	10:20	15:53	5:33	LINE CLEAR AVOIDED
388	24-Jul-22	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	10:20	15:57	5:37	LINE CLEAR AVOIDED
389	24-Jul-22	BENGALURU	66	HV1	CHINTAMANI 66	5:49	6:05	0:16	TRANSFORMER FAULT
390	24-Jul-22	BENGALURU	66	HV1	KIADB DB PURA 220	10:00	16:47	6:47	LINE CLEAR AVOIDED
391	24-Jul-22	BENGALURU	66	HV1	KIADB HARDWARE PARK 220	10:50	14:49	3:59	LINE CLEAR AVOIDED
392	24-Jul-22	BENGALURU	66	HV1	RANGANDODDI	11:20	11:48	0:27	LINE CLEAR AVOIDED
393	24-Jul-22	BENGALURU	66	HV2	KIADB DB PURA 220	10:00	16:47	6:47	LINE CLEAR AVOIDED
394	24-Jul-22	BENGALURU	66	HV2	RANGANDODDI	11:55	12:35	0:40	LINE CLEAR AVOIDED
395	24-Jul-22	BENGALURU	66	HV3	KIADB DB PURA 220	10:00	16:47	6:47	LINE CLEAR AVOIDED
396	24-Jul-22	BENGALURU	66	HV3	NRS 220	1:48	3:16	1:28	TRANSFORMER FAULT
397	24-Jul-22	BENGALURU	66	KIADB DB PURA 220 - APPEAREL PARK	APPEAREL PARK	10:22	13:19	2:57	LINE CLEAR AVOIDED
398	24-Jul-22	BENGALURU	66	KIADB DB PURA 220 - HIMAT SINGHA FACTORY (EHT)	HIMAT SINGHA FACTORY (EHT)	10:22	17:08	6:46	LINE CLEAR AVOIDED
399	24-Jul-22	BENGALURU	66	KIADB DB PURA 220 - INDO MM (EHT)	INDO MM (EHT)	10:22	16:58	6:36	LINE CLEAR AVOIDED
400	24-Jul-22	BENGALURU	66	KIADB HARDWARE PARK 220 - BPH(EHT)	BPH(EHT)	11:11	15:26	4:15	LINE CLEAR AVOIDED
401	24-Jul-22	BENGALURU	66	KIADB HARDWARE PARK 220 - SHELL(EHT)	SHELL(EHT)	10:06	15:17	5:11	LINE CLEAR AVOIDED
402	24-Jul-22	BENGALURU	66	KONDASPURA - EPIP 220	KONDASPURA	16:05	16:08	0:03	LOAD CHANGE OVER
403	24-Jul-22	BENGALURU	66	KONDASPURA - HOSKOTE 220	KONDASPURA	10:20	10:35	0:15	LOAD CHANGE OVER
404	24-Jul-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	7:14	7:25	0:11	LINE FAULT
405	24-Jul-22	BENGALURU	220	EAST DIVISION COMPOUND 220 - A STATION 220	NO STATION AFFECTED	08:38:00(23/07/2022)			LINE OPEN:LINE FAULT
406	24-Jul-22	BENGALURU	220	HOSKOTE 220 - KIADB HARDWARE PARK 1	HOSKOTE 220	10:20	15:10	4:50	LINE CLEAR AVOIDED
407	24-Jul-22	BENGALURU	220	HOSKOTE 220 - KIADB HARDWARE PARK 1	HOSKOTE 220	10:20	15:17	4:57	LINE CLEAR AVOIDED
408	24-Jul-22	BENGALURU	220	HV1	HOSKOTE 220	10:20	15:10	4:50	LINE CLEAR AVOIDED
409	24-Jul-22	BENGALURU	220	HV1	KIADB DB PURA 220	10:00	16:46	6:46	LINE CLEAR AVOIDED
410	24-Jul-22	BENGALURU	220	HV1	KIADB HARDWARE PARK 220	11:11	14:45	3:34	LINE CLEAR AVOIDED
411	24-Jul-22	BENGALURU	220	HV1	SOMANAHALLI 220	0:06	3:21	3:15	TRANSFORMER FAULT
412	24-Jul-22	BENGALURU	220	HV2	HOSKOTE 220	10:20	15:10	4:50	LINE CLEAR AVOIDED
413	24-Jul-22	BENGALURU	220	HV2	KIADB DB PURA 220	10:00	16:46	6:46	LINE CLEAR AVOIDED
414	24-Jul-22	BENGALURU	220	HV2	KIADB HARDWARE PARK 220	11:11	14:45	3:34	LINE CLEAR AVOIDED
415	24-Jul-22	BENGALURU	220	KIADB DB PURA 220 - DB PURA 220	NO STATION AFFECTED	10:40	12:58	2:18	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
416	24-Jul-22	BENGALURU	220	KIADB DB PURA 220 - GOWRIBIDANUR 220	KIADB DB PURA 220	10:01	16:44	6:43	LINE CLEAR AVAILED
417	24-Jul-22	BENGALURU	220	KIADB HARDWARE PARK 220 - HOSKOTE 1	HOSKOTE 220	10:32	15:13	4:41	LINE CLEAR AVAILED
418	24-Jul-22	BENGALURU	220	KIADB HARDWARE PARK 220 - HOSKOTE 2	HOSKOTE 220	10:32	15:13	4:41	LINE CLEAR AVAILED
419	24-Jul-22	GULBARGA	66	HOSAHALLI- CJ HALLI	HOSAHALLI_66,AVADA SOLAR_IPP,CLEEN MAX WIND-IPP	5:40	5:50	0:10	MAIN SUPPLY FAILURE
420	24-Jul-22	GULBARGA	66	HV1	HARAPANAHALLI_66	7:05	7:30	0:25	TRANSFORMER FAULT
421	24-Jul-22	GULBARGA	66	UJJAINI-BREIPL_IPP	UJJANI_66	12:08	12:32	0:24	LINE FAULT
422	24-Jul-22	GULBARGA	110	GURMITKAL-KAONKAL	KONKAL_110	20:30	20:40	0:10	LINE CLEAR AVAILED
423	24-Jul-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	3:54(20/07/2022)			LINE OPEN:LINE CLEAR AVAILED
424	24-Jul-22	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	9:34(20/07/2022)			LINE OPEN:LINE CLEAR AVAILED
425	24-Jul-22	GULBARGA	110	HV3	KOPPAL_110	06:55(22.07.2022)	16:00(24.07.2022)	57:05HRS	TRANSFORMER CHARGED
426	24-Jul-22	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONNAGAR_110,HANUMANAL_110	10:10	17:55	7:45	NFBC ISSUED
427	24-Jul-22	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	21:11	21:22	0:11	LINE FAULT
428	24-Jul-22	GULBARGA	110	MUNIRABAD-SINDHNOOR2	KAMPLI_110, KEREHALLI_110,MALLAPUR_110	8:13	8:28	0:15	LINE FAULT
429	24-Jul-22	GULBARGA	110	NEELGUNDA-HARAPANAHALLI	HARAPANAHALLI_110	18:44	19:00	0:16	LINE FAULT
430	24-Jul-22	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	19:51	19:57	0:06	LINE FAULT
431	24-Jul-22	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	21:55	21:59	0:04	LINE FAULT
432	24-Jul-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	20:36	20:42	0:06	LINE FAULT
433	24-Jul-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN:LINE CLEAR AVAILED
434	24-Jul-22	GULBARGA	110	SHAHABAD-FARATHABAD	FARTHABAD_110,GULBARGA SOUTH_110	04:35(23/07/2022)	13:38(24/07/2022)	33:03HRS	LINE CHARGED
435	24-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
436	24-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
437	24-Jul-22	GULBARGA	110	SHJAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNASAGI_110	19:20	19:24	0:04	LINE FAULT
438	24-Jul-22	GULBARGA	110	SINDHNOOR-VALABELLARI	MANVI_110,MADLAPUR_110,KURDICROSS_110,ADVIAMRESHWAR_110,JAWALGERA_110	0:20	0:30	0:10	LINE FAULT
439	24-Jul-22	GULBARGA	110	SINDHNOOR-VALABELLARI	MANVI_110,MADLAPUR_110,KURDICROSS_110,ADVIAMRESHWAR_110,JAWALGERA_110	1:45	1:55	0:10	LINE FAULT
440	24-Jul-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	8:14	8:22	0:08	LINE FAULT
441	24-Jul-22	GULBARGA	220	KUSTAGI-SULEKAL	KUSTAGI_220	11:18	12:02	0:44	LINE FAULT
442	24-Jul-22	GULBARGA	220	LINGASUGUR-KUSTAGI	LINGASUGUR_220	11:15	11:41	0:26	LINE CLEAR AVAILED
443	24-Jul-22	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	5:20	5:45	0:25	LINE FAULT
444	24-Jul-22	GULBARGA	220	LINGASUGUR-SINDHANOOR	LINGASUGUR_220	11:16	11:41	0:25	LINE CLEAR AVAILED
445	24-Jul-22	GULBARGA	220	SEDAM_SHAHAPUR	SEDAM_220	05:48(10/06/2022)			LINE OPEN:LINE CLEAR AVAILED
446	24-Jul-22	GULBARGA	400	RTPS-BTPS	RTPS_400	11:10	12:24	1:14	LINE FAULT
447	24-Jul-22	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400	11:10	12:08	0:58	LINE FAULT
448	24-Jul-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
449	24-Jul-22	GULBARGA	400	RTPS-RAICHURPG1	RAICHURNEW1_440	11:10	12:06	0:56	LINE FAULT
450	24-Jul-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	12:26(22.07.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
451	24-Jul-22	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	5:13	5:23	0:10	LINE FAULT
452	24-Jul-22	HASSAN	66	HV1	RAMESHWARANAGARA_66	0:08	0:41	0:33	TRANSFORMER FAULT
453	24-Jul-22	HASSAN	66	HV2	MANJUNATHPURA_66	7:05	7:32	0:27	TRANSFORMER FAULT
454	24-Jul-22	HASSAN	66	SAKALE-IPCL1	SAKLESHUPURA_66	10:29	14:29	4:00	LINE CLEAR AVAIED
455	24-Jul-22	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	9:24	17:53	8:29	LINE CLEAR AVAIED
456	24-Jul-22	HASSAN	110	HV1	TOGARS_110	10:20	14:45	4:25	LINE CLEAR AVAIED
457	24-Jul-22	HASSAN	110	HV2	BAIKAMPADY_110	11:35	12:57	1:22	LINE CLEAR AVAIED
458	24-Jul-22	HASSAN	110	HV2	KARAYA_110	8:41(24.07.2022)			TRANSFORMER:LINE CLEAR AVAIED
459	24-Jul-22	HASSAN	110	HV5	BAIKAMPADY_110	10:18	11:27	1:09	LINE CLEAR AVAIED
460	24-Jul-22	HASSAN	110	HV6	KAVOOR_220	11:09	13:07	1:58	LINE CLEAR AVAIED
461	24-Jul-22	HASSAN	110	HV6	PUTTUR_220	10:05	17:30	7:25	LINE CLEAR AVAIED
462	24-Jul-22	HASSAN	110	LV2	SHIRALKOPPA_220	12:34	16:25	3:51	LINE CLEAR AVAIED
463	24-Jul-22	HASSAN	110	SAGARA-SORABA	SAGARA_110	13:07	16:08	3:01	LINE CLEAR AVAIED
464	24-Jul-22	HASSAN	110	SALATHU-BNTWAL	SALATHU_110	15:13	18:45	3:32	NFBC ISSUED
465	24-Jul-22	HASSAN	110	SALATHU-NTMDNOR	SALATHU_110	6:30	15:13	8:43	NFBC ISSUED
466	24-Jul-22	HASSAN	110	VITTAL-PUTR_SLTUR	VITLA_110	6:30	15:11	8:41	LINE CLEAR AVAIED
467	24-Jul-22	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN:LINE FAULT
468	24-Jul-22	HASSAN	220	HV2	SHIRALKOPPA_220	12:34	16:24	3:50	LINE CLEAR AVAIED
469	24-Jul-22	HASSAN	220	KEMAR-VARAH1	KEMAR_220	9:18	18:08	8:50	LINE CLEAR AVAIED
470	24-Jul-22	HASSAN	220	VARAHI-KEMAR1	varahi_gen	9:20	18:09	8:49	NFBC ISSUED
471	24-Jul-22	MYSURU	66	HANAGODU-HV1	NO STATIONS EFFECTED	8:35	8:50	0:14	LINE FAULT
472	24-Jul-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00(08/12/2021)			LINE OPEN:LINE CLEAR AVAIED
473	24-Jul-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAIED
474	24-Jul-22	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00(12.07.2022)			TRANSFORMER:LINE CLEAR AVAIED
475	24-Jul-22	MYSURU	66	JAKKANAHALLY-NAGAMANGLA	G MALLIGERE	8:21	8:33	0:11	LINE FAULT
476	24-Jul-22	MYSURU	66	KADAKOLA-DEVANUR	NO STATIONS EFFECTED	12:29	16:19	3:49	LINE CLEAR AVAIED
477	24-Jul-22	MYSURU	66	KADAKOLA-TVS	NO STATIONS EFFECTED	10:26	11:54	1:28	LINE CLEAR AVAIED
478	24-Jul-22	MYSURU	66	MYSORE SOUTH-MANDKALLI	NO STATIONS EFFECTED	16:22	16:31	0:09	HAND TRIPPED
479	24-Jul-22	MYSURU	66	SRIRANGAPATNA-HV1	NO STATIONS EFFECTED	16:21	16:37	0:15	LINE FAULT
480	24-Jul-22	MYSURU	220	HV1	KADAKOLA_220	1:41:14 (21/07/2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
481	24-Jul-22	MYSURU	220	HV2	MADHUVANAHALI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
482	24-Jul-22	TUMKUR	66	ANCHEPALYA 66kv-ANCHEPALYA 1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	17:09	17:23	0:14	LINE FAULT
483	24-Jul-22	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA	KOLALA_66, URDIGERE_66	10:30	18:00	7:30	LINE CLEAR AVAIED
484	24-Jul-22	TUMKUR	66	HIRIYUR 220KV-PARSHAMPURA_66	HIRIYUR_220	10:25	11:30	1:05	LINE CLEAR AVAIED
485	24-Jul-22	TUMKUR	66	HIRIYURKV 220kv-THALLAK_66	HIRIYUR_220	10:25	11:30	1:05	LINE CLEAR AVAIED
486	24-Jul-22	TUMKUR	66	HOSADURGA_220-HALRAMESHWARA_66 LINE-2	HOSADURGA_220	17:55	18:15	0:20	LINE FAULT
487	24-Jul-22	TUMKUR	66	I D HALLI- CLEAN MAX SOLAR1_IPP_66	CLEANMAXSOLAR_1_IPP_66	22:55	23:15	0:20	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
488	24-Jul-22	TUMKUR	66	I D HALLI- MEDIGESHI	IDHALLY_66	22:55	23:05	0:10	LINE FAULT
489	24-Jul-22	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI66	MADHUGIRI_66, BADAVANAHALLI_66	6:00	6:19	0:19	LINE FAULT
490	24-Jul-22	TUMKUR	66	POKOTE-HARIYABBE	POKOTE_66	10:00	18:45	8:45	NFBC ISSUED
491	24-Jul-22	TUMKUR	66	TR1	ANTHRASANAHALLI_220	10:00	17:40	7:40	LINE CLEAR AVAILED
492	24-Jul-22	TUMKUR	66	TR2	ANTHRASANAHALLI_220	10:00	17:40	7:40	LINE CLEAR AVAILED
493	24-Jul-22	TUMKUR	66	TR2	BEVINAHALLI_66	18:45	19:05	0:20	LINE CLEAR AVAILED
494	24-Jul-22	TUMKUR	66	TR3	ANTHRASANAHALLI_220	10:00	17:40	7:40	LINE CLEAR AVAILED
495	24-Jul-22	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	8:02(22.07.22)			LINE OPEN:LINE CLEAR AVAILED
496	25-Jul-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED LOKAPUR_110	11:51	21:35	9:44	TRANSFORMER FAULT
497	25-Jul-22	BAGALKOT	110	110/11KV, HV-1	STATION NOT AFFECTED BABALESHWAR_110	15:27	16:44	1:17	LINE CLEAR AVAILED
498	25-Jul-22	BAGALKOT	110	110/11KV, HV-2	STATION NOT AFFECTED BABALESHWAR_110	7:05	7:38	0:33	LINE CLEAR AVAILED
499	25-Jul-22	BAGALKOT	110	110/11KV, HV-2	STATION NOT AFFECTED DADDI_110	9:02	9:28	0:26	TRANSFORMER FAULT
500	25-Jul-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED SAVANUR_110	14:30	15:05	0:35	LINE CLEAR AVAILED
501	25-Jul-22	BAGALKOT	110	110/11KV,HV1	MAMADAPUR(G)_110	16:38	16:47	0:09	TRANSFORMER FAULT
502	25-Jul-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED TODALBAGI_110	19:13 (17.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
503	25-Jul-22	BAGALKOT	110	110/11KV,HV2	TARIHAL_110	16:44	16:52	0:08	TRANSFORMER FAULT
504	25-Jul-22	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	12:30	12:35	0:05	HAND TRIPPED
505	25-Jul-22	BAGALKOT	110	110/33KV, HV-3	NANDIKURLI_33 STATION NOT AFFECTED ANKALI_110	12:23	12:56	0:33	LINE CLEAR AVAILED
506	25-Jul-22	BAGALKOT	110	110/33KV,HV4	MACHE_110	16:10	18:35	2:25	LINE CLEAR AVAILED
507	25-Jul-22	BAGALKOT	110	220/110KV, LV-2	STATION NOT AFFECTED BELAGAVI_220	11:18	18:08	6:50	LINE CLEAR AVAILED
508	25-Jul-22	BAGALKOT	110	220/110KV. LV-2	STATION NOT AFFECTED BIJAPUR_220	9:12	19:05	9:53	LINE CLEAR AVAILED
509	25-Jul-22	BAGALKOT	110	GHATAPRABAHA220-GHATAPRABAHA-2	STATION NOT AFFECTED GHATAPRABAHA_110	12:44	19:08	6:24	LINE CLEAR AVAILED
510	25-Jul-22	BAGALKOT	110	GHATAPRABAHA220-GHATAPRABAHA-2	STATION NOT AFFECTED GHATAPRABAHA_220	12:44	19:08	6:24	LINE CLEAR AVAILED
511	25-Jul-22	BAGALKOT	110	NARENDRA220- GAERAG (SHEDBAL)	SHEDBAL_110	10:47	16:04	5:17	LINE CLEAR AVAILED
512	25-Jul-22	BAGALKOT	110	SIRSI-KAVALWADA	STATION NOT AFFECTED SIRSI_110	12:55 (22.07.2022)			LINE OPEN:LINE CLEAR AVAILED
513	25-Jul-22	BAGALKOT	110	TODALBAGI-SAVALAGI	TODALBAGI_110	18:00 (20.07.2022)			LINE OPEN:LINE FAULT
514	25-Jul-22	BAGALKOT	110	UTTUR - F1 JAMB CB( MUDHOL)	STATION NOT AFFECTED UTTUR_110	9:51 (24.07.2022)			LINE OPEN:LINE CLEAR AVAILED
515	25-Jul-22	BAGALKOT	110	VAJJARMATTI220-KD JAMBAGI	KD JAMBAGI_110	13:30	13:45	0:15	LINE FAULT
516	25-Jul-22	BAGALKOT	220	220/110KV, HV-2	STATION NOT AFFECTED BELAGAVI_220	11:18	18:09	6:51	LINE CLEAR AVAILED
517	25-Jul-22	BAGALKOT	220	220/110KV, HV-3 & LV3	220KV ATHANI	10:26 (25.07.2022)			TRANSFORMER:LINE CLEAR AVAILED
518	25-Jul-22	BAGALKOT	220	220/110KV. HV-2	STATION NOT AFFECTED BIJAPUR_220	9:12	19:04	9:52	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
519	25-Jul-22	BAGALKOT	220	AEQUS-BELAGAVI-1	STATION NOT AFFECTED AEQUS_220	11:27 (22.07.2022)	19:49 (25..07.2022)	80:22:00	LINE CHARGED
520	25-Jul-22	BAGALKOT	220	AEQUS-BELAGAVI-2	STATION NOT AFFECTED AEQUS_220	11:43	12:23	0:40	LINE FAULT
521	25-Jul-22	BAGALKOT	220	AEQUS-CHIKKODI-2	STATION NOT AFFECTED AEQUS_220	11:43	21:18	9:35	LINE FAULT
522	25-Jul-22	BAGALKOT	220	BELAGAVI- AEQUS-2	STATION NOT AFFECTED BELAGAVI_220	11:43	12:20	0:37	LINE FAULT
523	25-Jul-22	BAGALKOT	220	HAVERI220-BASAVANAKATTI	BASAVANAKATTI_110	6:14	6:34	0:20	LINE FAULT
524	25-Jul-22	BAGALKOT	220	HUBLI-NAGAZHARI-3	STATION NOT AFFECTED HUBLI_220	14:02	19:27	5:25	LINE FAULT
525	25-Jul-22	BAGALKOT	220	HUBLI-SIRSI-2	STATION NOT AFFECTED HUBLI_220	12:32	20:58	8:26	LINE FAULT
526	25-Jul-22	BAGALKOT	220	NARENDRA-GHATAPRABAHA-1	STATION NOT AFFECTED GHATAPRABAHA_220	3:36	4:28	0:52	LINE FAULT
527	25-Jul-22	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN:LINE CLEAR AVAILED
528	25-Jul-22	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN:LINE CLEAR AVAILED
529	25-Jul-22	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	15:05	15:15	0:09	LINE FAULT
530	25-Jul-22	BENGALURU	66	DB PURA 220 - DG2	DODDABELAVANGALA, GUNDAMGERE	11:25	11:30	0:05	LINE FAULT
531	25-Jul-22	BENGALURU	66	DIVYASHREE TECH PARK - EPIP 220	DIVYASHREE TECH PARK	17:46	18:00	0:14	LINE FAULT
532	25-Jul-22	BENGALURU	66	DIVYASHREE TECH PARK - EPIP 220	DIVYASHREE TECH PARK	18:24	18:31	0:07	LINE FAULT
533	25-Jul-22	BENGALURU	66	DIVYASHREE TECH PARK - KACHMARANAHALLI	KACHMARANAHALLI	17:46	18:24	0:38	LINE FAULT
534	25-Jul-22	BENGALURU	66	DIVYASHREE TECH PARK - KACHMARANAHALLI	KACHMARANAHALLI	18:24	19:40	1:16	LINE FAULT
535	25-Jul-22	BENGALURU	66	EPIP 220 - DIVYASHREE TECH PARK	DIVYASHREE TECH PARK	18:24	18:31	0:07	LINE FAULT
536	25-Jul-22	BENGALURU	66	EPIP 220 - DIVYASHREE TECH PARK	DIVYASHREE TECH PARK, KACHMARANAHALLI	17:46	18:00	0:14	LINE FAULT
537	25-Jul-22	BENGALURU	66	HALAGURU - HONNIGANAHALLI	HALAGURU	12:53	12:56	0:03	MAIN SUPPLY FAILURE
538	25-Jul-22	BENGALURU	66	HALAGURU - TK HALLI 220	HALAGURU	16:55	16:58	0:03	LOAD CHANGEOVER
539	25-Jul-22	BENGALURU	66	HONNIGANAHALLI - KANAKAPURA 220	HONNIGANAHALLI	14:26	16:50	2:23	LINE CLEAR AVAILED
540	25-Jul-22	BENGALURU	66	HV1	AUSTIN TOWN	8:48	9:02	0:14	TRANSFORMER FAULT
541	25-Jul-22	BENGALURU	66	HV1	ELECTRONIC CITY P2 S1	4:56	5:06	0:10	TRANSFORMER FAULT
542	25-Jul-22	BENGALURU	66	HV1	EXORA	20:30	20:36	0:06	TRANSFORMER FAULT
543	25-Jul-22	BENGALURU	66	HV1	GANJIGUNTE	10:46	10:51	0:05	TRANSFORMER FAULT
544	25-Jul-22	BENGALURU	66	HV1	H GOLLAHALLI	15:25	15:30	0:05	LINE CLEAR AVAILED
545	25-Jul-22	BENGALURU	66	HV1	MAGADI 66	15:27	16:50	1:23	TRANSFORMER FAULT
546	25-Jul-22	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	13:39	13:45	0:06	LINE CLEAR AVAILED
547	25-Jul-22	BENGALURU	66	HV1	SARJAPURA 220	15:05	15:17	0:11	MAIN SUPPLY FAILURE
548	25-Jul-22	BENGALURU	66	HV1	SARJAPURA 220	16:25	16:31	0:05	LOAD CHANGEOVER
549	25-Jul-22	BENGALURU	66	HV2	H GOLLAHALLI	16:40	16:45	0:05	LINE CLEAR AVAILED
550	25-Jul-22	BENGALURU	66	HV2	NRS 220	10:13	10:18	0:05	LOAD CHANGEOVER
551	25-Jul-22	BENGALURU	66	ISKON - SOMANAHALLI 220	ISKON	10:06	14:05	3:59	LINE CLEAR AVAILED
552	25-Jul-22	BENGALURU	66	LV2	SARJAPURA 220	15:10	15:17	0:07	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
553	25-Jul-22	BENGALURU	66	LV2	SARJAPURA 220	16:16	16:31	0:14	LOAD CHANGEOVER
554	25-Jul-22	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	9:35	9:52	0:17	LOAD CHANGEOVER
555	25-Jul-22	BENGALURU	66	SAMANDURU - ANEKAL	SAMANDURU	12:40	13:44	1:04	LINE CLEAR AVAILED
556	25-Jul-22	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	15:05	15:19	0:13	MAIN SUPPLY FAILURE
557	25-Jul-22	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	16:26	16:43	0:17	LOAD CHANGEOVER
558	25-Jul-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	14:01	14:11	0:10	LINE FAULT
559	25-Jul-22	BENGALURU	66	YETTAMBADI - TK HALLI 220	YETTAMBADI, IGGUR, HONALGERE	10:06	10:14	0:08	LINE FAULT
560	25-Jul-22	BENGALURU	220	EAST DIVISION COMPOUND 220 - A STATION 220	NO STATION AFFECTED	08:38:00(23/07/2022)			LINE OPEN:LINE FAULT
561	25-Jul-22	BENGALURU	220	HV2	SARJAPURA 220	15:04	16:24	1:20	LINE CLEAR AVAILED
562	25-Jul-22	GULBARGA	66	ITTAGI-HIREHADAGALI_1	HIREHADAGALI_66	5:52	6:32	0:40	LINE FAULT
563	25-Jul-22	GULBARGA	66	ITTAGI-HIREHADAGALI_1	HIREHADAGALI_66	9:23	17:10	7:47	LINE CLEAR AVAILED
564	25-Jul-22	GULBARGA	66	ITTAGI-HIREHADAGALI_2	HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66, SOVENHALLI_66, TUNGA BHADRA_IPP	9:23	10:05	0:42	LINE CLEAR AVAILED
565	25-Jul-22	GULBARGA	66	KUDALIGI-HANSI	HANSI_66	18:15	18:25	0:10	LINE FAULT
566	25-Jul-22	GULBARGA	66	PUNAMGATTA-UCHHANGIDURGA	UCHHANGIDURGA_66,BELCHOD_66	5:40	9:40	4:00	LINE FAULT
567	25-Jul-22	GULBARGA	66	YALBURGA-PARAMPOJAYA	PARAMPOJYA SOLAR_IPP	11:34	11:44	0:10	LINE FAULT
568	25-Jul-22	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	1:13	1:18	0:05	LINE FAULT
569	25-Jul-22	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	4:25	4:30	0:05	LINE FAULT
570	25-Jul-22	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_110	18:50	19:00	0:10	LINE FAULT
571	25-Jul-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_110,DIGGI_110	2:51	3:22	0:31	LINE FAULT
572	25-Jul-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	3:06	3:12	0:06	LINE FAULT
573	25-Jul-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	5:05	5:14	0:09	LINE FAULT
574	25-Jul-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	5:49	5:52	0:03	LINE FAULT
575	25-Jul-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	3:54(20/07/2022)			LINE OPEN:LINE CLEAR AVAILED
576	25-Jul-22	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	9:34(20/07/2022)			LINE OPEN:LINE CLEAR AVAILED
577	25-Jul-22	GULBARGA	110	HUNASAGI-KEMBHAVI	HUNASAGI_110	20:50	20:55	0:05	MAIN SUPPLY FAILURE
578	25-Jul-22	GULBARGA	110	HUNASAGI-KEMBHAVI	HUNASAGI_110	21:20	21:45	0:25	MAIN SUPPLY FAILURE
579	25-Jul-22	GULBARGA	110	HV1	HUMNABAD_220	11:20	12:45	1:25	LINE CLEAR AVAILED
580	25-Jul-22	GULBARGA	110	HV2	BENNEHALLI_110	7:45	7:50	0:05	TRANSFORMER FAULT
581	25-Jul-22	GULBARGA	110	HV2	MATAMARI_110	16:55	17:02	0:07	TRANSFORMER FAULT
582	25-Jul-22	GULBARGA	110	HV3	HALAVAGALU_66	15:00	16:20	1:20	LINE CLEAR AVAILED
583	25-Jul-22	GULBARGA	110	JAWALAGERA-ADVIA MARESHWAR	JAWALAGERA_110	20:20	20:30	0:10	LINE FAULT
584	25-Jul-22	GULBARGA	110	JAWALAGERA-ADVIA MARESHWAR	JAWALAGERA_110	20:56	21:30	0:34	LINE FAULT
585	25-Jul-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPURA_110,NSL SUGARS FACTORY	4:38	4:51	0:13	LINE FAULT
586	25-Jul-22	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	0:34	0:44	0:10	LINE FAULT
587	25-Jul-22	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	5:17	5:32	0:15	LINE FAULT
588	25-Jul-22	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	12:05	12:15	0:10	LINE FAULT
589	25-Jul-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	0:13	0:18	0:05	LINE FAULT
590	25-Jul-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	4:18	17:27	13:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
591	25-Jul-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	20:09	20:14	0:05	LINE FAULT
592	25-Jul-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)	12:38 (25.07.2022)	49:08 hrs	LINE CHARGED
593	25-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
594	25-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
595	25-Jul-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_110,SDAIDHAPUR_110,SANATHI_IPP,CORE GREEN SUGAR_IPP,YADGIR_110,SAIDAPUR_110	19:49	19:57	0:08	LINE FAULT
596	25-Jul-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_110,SDAIDHAPUR_110,SANATHI_IPP,CORE GREEN SUGAR_IPP,YADGIR_110,SAIDAPUR_110	19:58	20:03	0:05	LINE FAULT
597	25-Jul-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,SAIDAPUR_110	22:02	22:12	0:10	LINE FAULT
598	25-Jul-22	GULBARGA	110	SINDHNOOR-SINDHNOOR2	SINDHNOOR_110,VALKAMDINNI_110,BYAGWAT_110	2:40	2:50	0:10	LINE FAULT
599	25-Jul-22	GULBARGA	110	SINDHNOOR-SINDHNOOR2	SINDHNOOR_110,VALKAMDINNI_110,BYAGWAT_110	22:05	22:15	0:10	LINE FAULT
600	25-Jul-22	GULBARGA	110	SINDHNOOR-VALABELLARI	MANVI_110,MADLAPUR_110,KURDICROSS_110,A DVIAMRESHWAR_110,JAWALGERA_110	0:44	0:59	0:15	LINE FAULT
601	25-Jul-22	GULBARGA	110	SINDHNOOR-VALABELLARI	MANVI_110,MADLAPUR_110,KURDICROSS_110,A DVIAMRESHWAR_110,JAWALGERA_110	1:27	1:37	0:10	LINE FAULT
602	25-Jul-22	GULBARGA	110	SINDHNOOR-VALABELLARI	MANVI_110,MADLAPUR_110,KURDICROSS_110,A DVIAMRESHWAR_110,JAWALGERA_110	20:02	20:12	0:10	LINE FAULT
603	25-Jul-22	GULBARGA	110	SULEKAL-MARALIHALLI	MUKUNDA_110, YEREDONA_110,BENNUR SOLAR_IPP	23:09	23:27	0:18	LINE FAULT
604	25-Jul-22	GULBARGA	110	YARADONA- GANAGAVATHI(SULEKAL)	YARADONA_110	23:10	23:25	0:15	MAIN SUPPLY FAILURE
605	25-Jul-22	GULBARGA	220	GHATTARGA-SHAHABAD	GHATTARGA_110	4:35	4:45	0:10	LINE FAULT
606	25-Jul-22	GULBARGA	220	HUMNABAD-KAPNOOR_1	HUMNABAD_220	1:17	6:36	5:19	LINE CLEAR AVAILED
607	25-Jul-22	GULBARGA	220	LINGASUGUR-MALLAT	MALLAT_220	5:15	5:32	0:17	LINE FAULT
608	25-Jul-22	GULBARGA	220	LINGASUGUR-RTPS1	RTPS-220	4:47	5:07	0:20	LINE FAULT
609	25-Jul-22	GULBARGA	220	LINGASUGUR-RTPS2	RTPS_220	12:33	15:08	2:35	LINE CLEAR AVAILED
610	25-Jul-22	GULBARGA	220	LINGASUGUR-RTPS2	RTPS_220	20:00	20:21	0:21	LINE FAULT
611	25-Jul-22	GULBARGA	220	LINGASUGUR-RTPS2	RTPS_220	21:39	23:27	1:48	LINE FAULT
612	25-Jul-22	GULBARGA	220	SEDAM_SHAHAPUR	SEDAM_220	05:48(10/06/2022)			LINE OPEN:LINE CLEAR AVAILED
613	25-Jul-22	GULBARGA	220	SEDAM_SHAHAPUR	SEDAM_220	05:48(10/06/2022)			LINE OPEN:LINE CLEAR AVAILED
614	25-Jul-22	GULBARGA	220	SEDAM-RTPS_1	SEDAM_220	4:18	4:36	0:18	LINE FAULT
615	25-Jul-22	GULBARGA	400	BTPS-HIRIYUR_2	HIRIYUR_400	3:32	6:12	2:40	LINE CLEAR AVAILED
616	25-Jul-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
617	25-Jul-22	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:10	12:00	0:50	LINE CLEAR AVAILED
618	25-Jul-22	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLI_66	8:50	17:55	9:05	NFBC ISSUED
619	25-Jul-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	12:26(22.07.2022)			LINE OPEN:LINE CLEAR AVAILED
620	25-Jul-22	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_2022	12:10	17:28	5:18	LINE CLEAR AVAILED
621	25-Jul-22	HASSAN	66	HV1	RAMESHWARNAGAR_2022	11:38	12:18	0:40	LINE CLEAR AVAILED
622	25-Jul-22	HASSAN	66	HV1	RAMESHWARNAGAR_2022	16:21	16:49	0:28	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
623	25-Jul-22	HASSAN	66	HV2	KANDLI_66	11:02	12:10	1:08	LINE CLEAR AVAILED
624	25-Jul-22	HASSAN	66	SHANTHI-RMWNGR	SHANTHIGRAMA_66	12:10	17:37	5:27	MAIN SUPPLY FAILURE
625	25-Jul-22	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	8:51	18:08	9:17	LINE CLEAR AVAILED
626	25-Jul-22	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	9:05	9:24	0:19	LOAD CHANGEOVER
627	25-Jul-22	HASSAN	110	BARANG-SHR220	BARANGI_110	9:00	18:50	9:50	LINE CLEAR AVAILED
628	25-Jul-22	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	15:05	17:20	2:15	LINE CLEAR AVAILED
629	25-Jul-22	HASSAN	110	HV1	GAJNUR_110	18:48	19:10	0:22	LINE CLEAR AVAILED
630	25-Jul-22	HASSAN	110	HV1	KAVOOR_220	10:02	16:14	6:12	LINE CLEAR AVAILED
631	25-Jul-22	HASSAN	110	HV2	ANAVATTI_110	9:24	9:38	0:14	TRANSFORMER FAULT
632	25-Jul-22	HASSAN	110	HV2	BARANGI_110	9:13	9:46	0:33	LINE CLEAR AVAILED
633	25-Jul-22	HASSAN	110	HV2	KARAYA_110	8:41(24.07.2022)	17:47(25.07.2022)	33:06HRS	TRANSFORMER CHARGED
634	25-Jul-22	HASSAN	110	HV2	TOGARSI_110	9:00	19:20	10:20	MAIN SUPPLY FAILURE
635	25-Jul-22	HASSAN	110	HV3	JOGE_110	10:55(05.04.2022)			TRANSFORMER:LINE CLEAR AVAILED
636	25-Jul-22	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	9:39	14:02	4:23	LINE CLEAR AVAILED
637	25-Jul-22	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	8:20	18:48	10:28	LINE CLEAR AVAILED
638	25-Jul-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_110	9:03	19:18	10:15	LINE CLEAR AVAILED
639	25-Jul-22	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN:LINE FAULT
640	25-Jul-22	HASSAN	220	GERSOPA-TALGUPA1	gen_gersoppa	11:56	13:19	1:23	LINE CLEAR AVAILED
641	25-Jul-22	HASSAN	220	GERSOPA-TALGUPA2	gen_gersoppa	11:57	13:21	1:24	LINE CLEAR AVAILED
642	25-Jul-22	HASSAN	220	KEMAR-Varahi2	KEMAR_220	11:17	16:51	5:34	LINE CLEAR AVAILED
643	25-Jul-22	HASSAN	220	VARAHI-KEMAR2	VARAHI_gen	11:17	16:51	5:34	NFBC ISSUED
644	25-Jul-22	MYSURU	66	ATTIGULIPURA-HV1	NO STATIONS EFFECTED	11:45	12:47	1:02	LINE CLEAR AVAILED
645	25-Jul-22	MYSURU	66	HAMPAPURA-HV2	NO STATIONS EFFECTED	12:01	13:04	1:02	LINE CLEAR AVAILED
646	25-Jul-22	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
647	25-Jul-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
648	25-Jul-22	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00(12.07.2022)			TRANSFORMER:LINE CLEAR AVAILED
649	25-Jul-22	MYSURU	66	MADDUR-HV1	NO STATIONS EFFECTED	16:04	17:35	1:30	LINE CLEAR AVAILED
650	25-Jul-22	MYSURU	66	MADHUVANAHALLY-LOKKANAHALLI	PG PALYA & LOKKANAHALLI	12:23	12:29	0:06	LINE FAULT
651	25-Jul-22	MYSURU	66	SATHEGALA-HV2	NO STATIONS EFFECTED	20:20	20:25	0:04	LINE FAULT
652	25-Jul-22	MYSURU	66	SFCSIVA-SATHEGALA	NO STATIONS EFFECTED	19:12	19:25	0:13	LINE FAULT
653	25-Jul-22	MYSURU	66	TALAKADU-HV2	NO STATIONS EFFECTED	13:20	13:30	0:10	HAND TRIPPED
654	25-Jul-22	MYSURU	66	TALAKADU-HV2	NO STATIONS EFFECTED	14:02	14:07	0:04	HAND TRIPPED
655	25-Jul-22	MYSURU	220	HV1	KADAKOLA_220	1:41:14 (21/07/2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
656	25-Jul-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
657	25-Jul-22	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAGALUR_66	5:40	7:30	1:50	MAIN SUPPLY FAILURE
658	25-Jul-22	TUMKUR	66	GUTTUR_400DAVANGERE LINE -1	GUTTUR_400	0:08(23.07.22)			LINE OPEN:LINE CLEAR AVAILED
659	25-Jul-22	TUMKUR	66	HONNALLI 220KV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	13:11	13:21	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
660	25-Jul-22	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:22	15:31	0:09	LINE FAULT
661	25-Jul-22	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	17:22	17:39	0:17	LINE FAULT
662	25-Jul-22	TUMKUR	66	HONNALLI 220kV- KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	6:21	6:42	0:21	LINE FAULT
663	25-Jul-22	TUMKUR	66	HONNALLI 220kV- KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	17:22	17:38	0:16	LINE FAULT
664	25-Jul-22	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	17:22	17:38	0:16	LINE FAULT
665	25-Jul-22	TUMKUR	66	HOSAKERE_66-MIDIGESHI_66	HOSAKERE_66	2:30	3:04	0:34	LINE FAULT
666	25-Jul-22	TUMKUR	66	I D HALLI- MEDIGESHI	IDHALLY_66	2:30	3:11	0:40	LINE FAULT
667	25-Jul-22	TUMKUR	66	KORATAGERE66-MADHUGIRI	KORATAGERE_66	12:43	13:58	1:14	LINE CLEAR AVAILED
668	25-Jul-22	TUMKUR	66	KUNDUR- HONNALLI 220	KUNDUR_66	6:35	6:55	0:19	MAIN SUPPLY FAILURE
669	25-Jul-22	TUMKUR	66	MADHUGIRI_220HOSAKERE_66	HOSAKERE_66	2:30	3:04	0:34	LINE FAULT
670	25-Jul-22	TUMKUR	66	TR1	ANTHRASANAHALLI_220	14:15	14:26	0:11	TRANSFORMER FAULT
671	25-Jul-22	TUMKUR	66	TR-1	HALURAMESHWARA_66	9:08	9:19	0:11	TRANSFORMER FAULT
672	25-Jul-22	TUMKUR	66	TR-1	KORATAGERE_66	12:43	13:26	0:43	LINE CLEAR AVAILED
673	25-Jul-22	TUMKUR	66	TR2	ANTHRASANAHALLI_220	14:15	14:27	0:12	TRANSFORMER FAULT
674	25-Jul-22	TUMKUR	66	TR-2	BILCHODU_66	12:27	12:41	0:14	TRANSFORMER FAULT
675	25-Jul-22	TUMKUR	66	TR-2	HULIYURDURGA_66	14:46	18:12	3:25	LINE CLEAR AVAILED
676	25-Jul-22	TUMKUR	66	TR-2	KORATAGERE_66	13:41	13:58	0:16	LINE CLEAR AVAILED
677	25-Jul-22	TUMKUR	66	TR3	ANTHRASANAHALLI_220	14:15	14:27	0:12	TRANSFORMER FAULT
678	25-Jul-22	TUMKUR	110	NITTUR 220-GUBBI	GUBBI_110	16:18	16:25	0:07	LINE FAULT
679	25-Jul-22	TUMKUR	110	NITTUR 220-K G TEMPLE	KGTEMPLE_110	16:18	16:25	0:07	LINE FAULT
680	25-Jul-22	TUMKUR	110	NITTUR 220-SOMLAPURA110	SOMLAPURA_110	14:30	15:05	0:35	LINE FAULT
681	25-Jul-22	TUMKUR	110	NITTUR 220-SOMLAPURA110	SOMLAPURA_110	16:50	18:22	1:32	LINE CLEAR AVAILED
682	25-Jul-22	TUMKUR	220	ANCHEPALYA 220kV- NElMANGALA 2(MAGADI)	ANCHEPALYA_220	14:26	15:31	1:05	LINE CLEAR AVAILED
683	25-Jul-22	TUMKUR	220	ANCHEPALYA 220kV- NElMANGALA-1	ANCHEPALYA_220	11:43	14:23	2:40	LINE CLEAR AVAILED
684	25-Jul-22	TUMKUR	220	ANTHRASANAHALLI 220kV- KBCROSS	ANTHRASANAHALLI_220	14:01	14:14	0:13	LINE FAULT
685	25-Jul-22	TUMKUR	220	ANTHRASANAHALLI 220kV- KBCROSS	ANTHRASANAHALLI_220	14:48	14:56	0:08	LINE FAULT
686	25-Jul-22	TUMKUR	220	ANTHRASANAHALLI 220KV- KORA	KORA_66, BRAHMASANDRA_66,THOVINAKERE_66,ANKASANDRA_66	14:15	14:24	0:09	LINE FAULT
687	25-Jul-22	TUMKUR	220	ANTHRASANAHALLI 220kV- SHIMOGA	ANTHRASANAHALLI_220	13:46	14:38	0:52	LINE FAULT
688	25-Jul-22	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 1	ANTHRASANAHALLI_220	14:34	14:37	0:03	LINE FAULT
689	25-Jul-22	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	14:31	14:34	0:03	LINE FAULT
690	25-Jul-22	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	8:02(22.07.22)			LINE OPEN:LINE CLEAR AVAILED
691	25-Jul-22	TUMKUR	220	TR1	ANTHRASANAHALLI_220	14:39	14:48	0:09	TRANSFORMER FAULT
692	25-Jul-22	TUMKUR	220	TR1	HONNALI_220	17:22	17:35	0:13	TRANSFORMER FAULT
693	25-Jul-22	TUMKUR	220	TR2	ANTHRASANAHALLI_220	14:01	14:36	0:35	TRANSFORMER FAULT
694	25-Jul-22	TUMKUR	220	TR3	ANTHRASANAHALLI_220	14:16	14:23	0:07	TRANSFORMER FAULT