

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 30.06.2020 TO 06.07.2020

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	30-Jun-2020	BAGALKOT	110	HIDIKAL DAM-ANKALAGI	NO STATION EFFECTED HIDIKAL DAM_110	12:42 (20.06.2020)	14:25 (30.06.2020)	241:43hrs	LINE CHARGED
2	30-Jun-2020	BAGALKOT	110	DHARWAD BIO-NAVALGUND	NAVALGUND_110	13:20 (20.06.2020)			LINE OPEN: LINE CLEAR AVAILED
3	30-Jun-2020	BAGALKOT	110	RATTIHALLI-HIREKERUR	NO STATION EFFECTED RATTIHALLI_110	14:38 (20.06.2020)			LINE OPEN: LINE CLEAR AVAILED
4	30-Jun-2020	BAGALKOT	110	JAMAKHANDI-SHIROL	SHIROL_110	10:41 (24.06.2020)			LINE OPEN: LINE CLEAR AVAILED
5	30-Jun-2020	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN: LINE CLEAR AVAILED
6	30-Jun-2020	BAGALKOT	110	TARIHAL-SRS HUBLI 2	TARIHAL_110,NAVANAGR(H)_110	16:32 (29.06.2020)	12:11 (30.06.2020)	7:39hrs	LINE CHARGED
7	30-Jun-2020	BAGALKOT	110	JAMAKHANDI-BANAHATTI	BANAHATTI_110	16:41	16:59	0:18	LINE FAULT
8	30-Jun-2020	BAGALKOT	110	GHATAPRABHA110-HIDIKAL DAM	HIDIKAL DAM	23:11	23:33	0:22	LINE FAULT
9	30-Jun-2020	BAGALKOT	110	GHATAPRABHA220-MUDALAGI(PG HUNSHYAL)	MUDALAGI_110	15:22	15:31	0:09	HAND TRIPPED
10	30-Jun-2020	BAGALKOT	110	110/11KV, HV2	HIDIKAL_110	19:40	20:13	0:33	TRANSFORMER FAULT
11	30-Jun-2020	BAGALKOT	110	110/11KV, HV2	NAVALAGUND_110	14:53	16:50	1:57	TRANSFORMER FAULT
12	30-Jun-2020	BAGALKOT	110	MMCL- SOUDATTI220	SOUDATTI_220	10:23	18:49	8:26	LINE CLEAR AVOID
13	30-Jun-2020	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	18:08	18:28	0:20	LINE CLEAR AVOID
14	30-Jun-2020	BAGALKOT	110	RANEBENNUR- HIREKERUR	HIREKERUR_110	5:56	6:04	0:08	LINE FAULT
15	30-Jun-2020	BAGALKOT	110	GHATAPRABHA- HIDIKAL DAM	HIDIKAL DAM_110	14:23	17:49	3:26	LINE CLEAR AVOID
16	30-Jun-2020	BAGALKOT	220	GUTTUR-RANEBENNUR	RANEBENNUR_220	17:15 (25.06.2020)			LOAD CURTAILMENT
17	30-Jun-2020	BAGALKOT	220	220/110KV, HV1&LV1	MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
18	30-Jun-2020	BAGALKOT	220	HAVERI-GUTTUR2	HAVERI_220	2:54	17:56	15:02	LINE FAULT
19	30-Jun-2020	BAGALKOT	220	HAVERI-GUTTUR1	HAVERI_220	4:06	17:56	13:50	LINE FAULT
20	30-Jun-2020	BAGALKOT	220	220/110KV,HV1,LV1&HV2,LV2	GHATAPRABHA_220, MANTUR_110, SHIRGOAN_110, PG HUNSHYAL_110, GHATAPRABHA_110	13:20	15:25	2:05	TRANSFORMER FAULT
21	30-Jun-2020	BENGALURU	66	AMAR JYOTHI - HAL 220	AMAR JYOTHI	13:00	13:05	0:05	LINE FAULT
22	30-Jun-2020	BENGALURU	66	KORAMANGALA 220 - AUSTIN TOWN 2	NO STATION AFFECTED	8:50	9:41	0:51	LINE FAULT
23	30-Jun-2020	BENGALURU	66	HV1	VICTORIA	12:44	12:48	0:04	LINE CLEAR AVOID
24	30-Jun-2020	BENGALURU	66	HV2	VICTORIA	14:44	14:46	0:02	LINE CLEAR AVOID
25	30-Jun-2020	BENGALURU	66	SADLI - MITTEMARI 220	SADLI, JULLUPALYA	1:20	1:50	0:30	LOAD CHANGE OVER
26	30-Jun-2020	BENGALURU	66	PATHPALYA - SOMANATHPURA	SOMANTHPURA, THIMAMPALLI	21:14	21:21	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
27	30-Jun-2020	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	11:15	12:30	1:15	LINE CLEAR AVAILED
28	30-Jun-2020	BENGALURU	66	HV2	MUDIYANUR	12:45	15:30	2:45	LINE CLEAR AVAILED
29	30-Jun-2020	BENGALURU	66	HV1	MUDIYANUR	15:30	15:32	0:02	LINE CLEAR AVAILED
30	30-Jun-2020	BENGALURU	66	HV1	SURYANAGAR	9:00	9:06	0:05	LINE CLEAR AVAILED
31	30-Jun-2020	BENGALURU	66	HV2	THAYALUR	23:27	23:33	0:05	TRANSFORMER FAULT
32	30-Jun-2020	BENGALURU	66	HV1	MUDIYANUR	12:37	12:42	0:05	TRANSFORMER FAULT
33	30-Jun-2020	BENGALURU	66	HV1	BANGARPET	4:11	4:17	0:06	TRANSFORMER FAULT
34	30-Jun-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN:LINE FAULT
35	30-Jun-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	NO STATION AFFECTED	1:45:00(25-6-2020)			LINE OPEN: LINE CLEAR AVAILED
36	30-Jun-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	NO STATION AFFECTED	1:49:00(25-6-2020)			LINE OPEN: LINE CLEAR AVAILED
37	30-Jun-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
38	30-Jun-2020	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
39	30-Jun-2020	BENGALURU	220	HV2	MITTEMARI 220	1:24	2:20	0:56	MAIN SUPPLY FAILURE
40	30-Jun-2020	BENGALURU	220	HV1	MITTEMARI 220	1:24	2:20	0:56	MAIN SUPPLY FAILURE
41	30-Jun-2020	BENGALURU	220	HV1	MITTEMARI 220	2:20	8:10	5:50	LINE CLEAR AVAILED
42	30-Jun-2020	BENGALURU	220	HV2	MITTEMARI 220	2:20	4:55	2:35	LINE CLEAR AVAILED
43	30-Jun-2020	BENGALURU	220	HV2	MITTEMARI 220	4:55	8:09	3:14	TRANSFORMER FAULT
44	30-Jun-2020	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 220	MITTEMARI 220	1:24	2:20	0:56	LINE FAULT
45	30-Jun-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
46	30-Jun-2020	BENGALURU	400	NELAMANGALA 400 - TALGUPPA 400	TALGUPPA 400	1:48	7:56	6:08	LINE FAULT
47	30-Jun-2020	BENGALURU	400	NELAMANGALA 400 - HIRIYUR 2	NO STATION AFFECTED	23:44:51(30-6-2020)			LINE OPEN: LINE CLEAR AVAILED
48	30-Jun-2020	GULBARGA	66	HV1	HANASI_66	12:00	12:49	00:49	LINE CLEAR AVAILED
49	30-Jun-2020	GULBARGA	66	HV1	HANASI_66	13:35	13:40	00:05	TRANSFORMER FAULT
50	30-Jun-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	NO STATION AFFECTED	5:45(30.6.20)			LINE OPEN:LINE FAULT
51	30-Jun-2020	GULBARGA	110	MALLAT-MADALAPUR	MADLAPUR_110, MANVI_110	23:45(29.06.2020)	6:45(30.6.20)	7:10hrs	LINE FAULT
52	30-Jun-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	6:05(28.06.2020)	10:53(30.6.20)	52:48hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
53	30-Jun-2020	GULBARGA	110	HV1	HANUMASAGAR_110	00:05	00:30	00:25	TRANSFORMER FAULT
54	30-Jun-2020	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	05:27	05:35	00:08	LINE FAULT
55	30-Jun-2020	GULBARGA	110	LADHA-RENEWOLAR	LADHA_110	12:54	13:06	00:12	LINE CLEAR AVAILED
56	30-Jun-2020	GULBARGA	110	LADHA-BHALKI	LADHA_110	05:10	05:20	00:10	MAIN SUPPLY FAILURE
57	30-Jun-2020	GULBARGA	110	LADHA-BHALKI	LADHA_110	05:30	05:40	00:10	MAIN SUPPLY FAILURE
58	30-Jun-2020	GULBARGA	110	KAPNOOR-GULBARGANORTH1&2	GULBARGASOUTH_110,GULBARGAU NIVERSITY_110,GULBARGANORTH_1 10	21:30	21:40	00:10	LINE CLEAR AVAILED
59	30-Jun-2020	GULBARGA	110	MASKI-SINDHNOOR	MASKI_110	21:11	21:30	00:19	MAIN SUPPLY FAILURE
60	30-Jun-2020	GULBARGA	110	ALIPUR-BELLARYNORTH	BELLARYNORTH_110,SOMASAMUDR A_110,MOKA_110,PDHALLI_110,BISI HALLI_110,JANAKI_IPP,BASAISTEELS IPP	05:58	06:15	00:17	LINE FAULT
61	30-Jun-2020	GULBARGA	110	SHAHAPUR_KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	23:15	23:26	00:11	LINE FAULT
62	30-Jun-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	23:49	23:53	00:04	LINE FAULT
63	30-Jun-2020	GULBARGA	110	SINDHANOOR-RAICHUR1	SINDHANOOR_110	21:11	21:22	00:11	LINE FAULT
64	30-Jun-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT
65	30-Jun-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN: LINE CLEAR AVAILED
66	30-Jun-2020	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	22:00(29.06.2020)	15:43(30.6.20)	17:43hrs	LINE CHARGED
67	30-Jun-2020	GULBARGA	400	GDHALLI-RTPS	GDHALLI_400	02:08	08:10	06:02	LINE FAULT
68	30-Jun-2020	HASSAN	66	LV1	NO STN AFFECTED	13:17 (26.06.2020)			LINE OPEN: LINE CLEAR AVAILED
69	30-Jun-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:12	13:45	02:33	LINE CLEAR AVAILED
70	30-Jun-2020	HASSAN	66	HV1	CHANNARAYAPATNA_66	11:40	12:39	00:59	LINE CLEAR AVAILED
71	30-Jun-2020	HASSAN	66	HV1	MALLAPURA_66	13:58	15:02	01:04	LINE CLEAR AVAILED
72	30-Jun-2020	HASSAN	110	HV1	NO STN AFFECTED	13:17 (26.06.2020)			LINE OPEN: LINE CLEAR AVAILED
73	30-Jun-2020	HASSAN	110	HV3	BANTWAL_110	11:13	13:16	02:03	LINE CLEAR AVAILED
74	30-Jun-2020	HASSAN	110	KADUR-NGNHL	KADUR_220	10:43	13:16	02:33	LINE CLEAR AVAILED
75	30-Jun-2020	HASSAN	110	HV2	MSEZ_220	14:14	15:02	00:48	LINE CLEAR AVAILED
76	30-Jun-2020	HASSAN	400	UPCL-HASSAN2	NO STN AFFECTED	21:29 (25.06.2020)			LINE OPEN: LINE CLEAR AVAILED
77	30-Jun-2020	HASSAN	400	HASSAN4-UPCL1	NO STN AFFECTED	20:33 (29.06.2020)			LINE OPEN: LINE CLEAR AVAILED
78	30-Jun-2020	HASSAN	400	UPCL-HASSAN1	NO STN AFFECTED	20:33 (29.06.2020)			LINE OPEN: LINE CLEAR AVAILED
79	30-Jun-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	01:48	07:56	06:08	LINE FAULT
80	30-Jun-2020	MYSURU	66	HV1	BASARALU_66	13:26	15:18	1:51	LINE CLEAR AVAILED
81	30-Jun-2020	MYSURU	66	HV2	BASARALU_66	11:58	14:36	2:38	LINE CLEAR AVAILED
82	30-Jun-2020	MYSURU	66	SANTE SARGUR -B MATTGERE	B MATKERE_66	7:55	17:25	9:29	NFBC ISSUED
83	30-Jun-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
84	30-Jun-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
85	30-Jun-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14:44(28.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
86	30-Jun-2020	TUMKUR	66	TR-1	CHIKKABANAGERE_66	16:40	17:31	0:51	LINE CLEAR AVAILED
87	30-Jun-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	14:43	14:51	0:08	LINE FAULT
88	30-Jun-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:43	14:51	0:08	LINE FAULT
89	30-Jun-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:02	14:05	3:02	LINE CLEAR AVAILED
90	30-Jun-2020	TUMKUR	66	HANAGAL-AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	9:37	10:03	0:25	LINE FAULT
91	30-Jun-2020	TUMKUR	66	HANAGAL-AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	12:39	13:22	0:42	LINE FAULT
92	30-Jun-2020	TUMKUR	66	HANAGAL- B G KERE	BGKERE_66,GUDEKOTE_66	9:30	9:40	0:10	LINE FAULT
93	30-Jun-2020	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	9:37	9:48	0:10	HAND TRIPPED
94	30-Jun-2020	TUMKUR	66	TR-1	HIRIYUR_66	19:08	21:49	2:40	TRANSFORMER FAULT
95	30-Jun-2020	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	11:46	11:57	0:10	HAND TRIPPED
96	30-Jun-2020	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	11:24	11:37	0:12	LINE FAULT
97	30-Jun-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	11:24	13:10	1:45	LINE CLEAR AVAILED
98	30-Jun-2020	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_66,S ASALUHALLA_66	11:37	13:10	1:33	LINE CLEAR AVAILED
99	30-Jun-2020	TUMKUR	66	TR-2(HV SIDE)	HONNALLI_220	10:53	18:36	7:43	LINE CLEAR AVAILED
100	30-Jun-2020	TUMKUR	66	TR-1(LV SIDE)	HONNALLI_220	10:56	18:04	7:07	LINE CLEAR AVAILED
101	30-Jun-2020	TUMKUR	66	TR-2	HONNUDIKE_66	16:09	16:38	0:29	LINE CLEAR AVAILED
102	30-Jun-2020	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	13:18	15:19	2:00	LINE CLEAR AVAILED
103	30-Jun-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	10:52	15:37	4:44	LINE CLEAR AVAILED
104	30-Jun-2020	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	11:36	11:38	0:01	LINE FAULT
105	30-Jun-2020	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	13:43	14:09	0:26	LINE FAULT
106	30-Jun-2020	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	7:37	17:43	10:06	LINE CLEAR AVAILED
107	30-Jun-2020	TUMKUR	66	TR-1(HV SIDE)	ANTHRASANAHALLI_220	16:16	16:55	0:39	LINE CLEAR AVAILED
108	30-Jun-2020	TUMKUR	66	TR-1(HV SIDE)	ANTHRASANAHALLI_220	18:06	19:40	1:33	LINE CLEAR AVAILED
109	30-Jun-2020	TUMKUR	66	TR-1(HV SIDE)	ANTHRASANAHALLI_220	20:41	20:45	0:03	LINE CLEAR AVAILED
110	30-Jun-2020	TUMKUR	66	TR-2(HV SIDE)	ANTHRASANAHALLI_220	16:16	17:03	0:47	LINE CLEAR AVAILED
111	30-Jun-2020	TUMKUR	66	TR-2(HV SIDE)	ANTHRASANAHALLI_220	18:06	19:31	1:25	LINE CLEAR AVAILED
112	30-Jun-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66, BRAHMASANDRA_66, KALLAMBELLA_66	16:16	16:55	0:38	HAND TRIPPED
113	30-Jun-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66, BRAHMASANDRA_66, KALLAMBELLA_66	18:06	18:28	0:22	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
114	30-Jun-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
115	30-Jun-2020	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	13:03	13:27	0:23	MAIN SUPPLY FAILURE
116	30-Jun-2020	TUMKUR	110	TR-1	HANDANKERE_110	9:07	13:47	4:39	LINE CLEAR AVAILED
117	30-Jun-2020	TUMKUR	110	HANDANKERE_110-K B CROSS 220	HANDANKERE_110	7:18	13:47	6:28	LINE CLEAR AVAILED
118	30-Jun-2020	TUMKUR	110	TR-2	HULIYAR_110	13:38	13:43	0:05	LINE CLEAR AVAILED
119	30-Jun-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETTYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	8:44	13:03	4:18	LINE CLEAR AVAILED
120	30-Jun-2020	TUMKUR	110	SHETTYKERE- HANDANKERE(CN HALLI110)	SHETTYKERE_110	13:19	13:39	0:20	LINE CLEAR AVAILED
121	30-Jun-2020	TUMKUR	110	TR-1	SHETTYKERE_110	12:48	13:51	1:02	LINE CLEAR AVAILED
122	30-Jun-2020	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	14:59	15:49	0:49	LINE CLEAR AVAILED
123	30-Jun-2020	TUMKUR	220	TR-1(HV SIDE)	HONNALLI_220	10:57	17:52	6:55	LINE CLEAR AVAILED
124	30-Jun-2020	TUMKUR	220	PAVAGADA 220kV- GREEN KO_IPP_66	GREEN KO_IPP_66	1:01	1:10	0:08	LINE FAULT
125	30-Jun-2020	TUMKUR	220	PAVAGADA 220kV- GREEN KO_IPP_66	GREEN KO_IPP_66	1:46	1:53	0:07	LINE FAULT
126	30-Jun-2020	TUMKUR	220	PAVAGADA220-MADHUGIRI 2	PAVAGADA_220	0:59	5:29	4:30	LINE FAULT
127	01-Jul-20	BAGALKOT	110	110/11KV,HV1	LAXMESHWAR_110	20:36	20:40	0:04	HAND TRIPPED
128	01-Jul-20	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	15:57	18:08	2:11	LINE CLEAR AVAILED
129	01-Jul-20	BAGALKOT	110	110/11KV,HV2	VAJRAMATTI_110	15:05	15:41	0:36	HAND TRIPPED
130	01-Jul-20	BAGALKOT	110	110/33KV,HV3(HV4)	KULIGOD_110,ARALIMATTI_33,TIGADI_33	14:26	14:52	0:26	TRANSFORMER FAULT
131	01-Jul-20	BAGALKOT	110	AB SOLAR -BELLATTI	BELLATTI_110	19:56	20:43	0:47	HAND TRIPPED
132	01-Jul-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	BELGAUM_110	15:16 (20.06.2020)			LINE OPEN: LINE CLEAR AVAILED
133	01-Jul-20	BAGALKOT	110	CHIKKODI220-SADALAGA	SADALAGA_110	6:37	6:56	0:19	LINE FAULT
134	01-Jul-20	BAGALKOT	110	DHARWAD BIO-NAVALGUND	NAVALGUND_110	13:20 (20.06.2020)	12:27 (01.07.2020)	263 hrs	LINE CHARGED
135	01-Jul-20	BAGALKOT	110	ENERCON2-BELLATTI	BELLATTI_110	19:56	20:43	0:47	HAND TRIPPED
136	01-Jul-20	BAGALKOT	110	GADAG220-LAXMESHWAR	LAXMESHWAR_110	19:54	20:28	0:34	LINE FAULT
137	01-Jul-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
138	01-Jul-20	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	9:0 (19.06.2020)			LINE OPEN: LINE CLEAR AVAILED
139	01-Jul-20	BAGALKOT	110	HUBLI220-ANANDNAGAR	ANANDNAGAR_110,AKSHYA COLONY_110	16:05	18:21	2:16	LINE FAULT
140	01-Jul-20	BAGALKOT	110	JAMAKHANDI(NAVALGI)-BANAHATTI	BANAHATTI_110	8:51	9:07	0:16	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
141	01-Jul-20	BAGALKOT	110	JAMAKHANDI-SHIROL	SHIROL_110	10:41 (24.06.2020)			LINE OPEN: LINE CLEAR AVAILED
142	01-Jul-20	BAGALKOT	110	KIADB BIJAPUR-BHUTNAL	BHUTNAL_110	13:46	13:50	0:04	LINE FAULT
143	01-Jul-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
144	01-Jul-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
145	01-Jul-20	BAGALKOT	110	LAXMESHWAR-BELLATTI	BELLATTI_110	19:54	20:35	0:41	HAND TRIPPED
146	01-Jul-20	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110	16:10	16:34	0:24	HAND TRIPPED
147	01-Jul-20	BAGALKOT	110	RANEENNUR-RATTIHALLI (TUMMINKATTI)	TUMMINKATTI_110	8:30 (01.07.2020)			LINE OPEN: LINE CLEAR AVAILED
148	01-Jul-20	BAGALKOT	110	RATTIHALLI-HIREKERUR	NO STATION EFFECTED RATTIHALLI_110	14:38 (20.06.2020)	8:30 (01.07.2020)	257 hrs	LINE CHARGED
149	01-Jul-20	BAGALKOT	110	SADALAGA-BORGOAN	BORGOAN_110	6:37	7:53	1:16	LINE FAULT
150	01-Jul-20	BAGALKOT	110	SHIRATTI-LAXMESHWAR	STATION NOT AFFECTED	19:52	20:40	0:48	LINE FAULT
151	01-Jul-20	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN: LINE CLEAR AVAILED
152	01-Jul-20	BAGALKOT	110	THORVI- TAKKALKI	TAKKALKI_110	13:51	13:55	0:04	HAND TRIPPED
153	01-Jul-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
154	01-Jul-20	BAGALKOT	110	VAJRAMATTI220-VAJRAMATTI	STATION NOT AFFECTED	15:10	15:22	0:12	HAND TRIPPED
155	01-Jul-20	BAGALKOT	220	220/110KV, HV1&LV1	MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
156	01-Jul-20	BAGALKOT	220	220/110KV, HV1&LV1	RANEENNUR_220	8:52	17:34	8:42	LINE CLEAR AVOIDED
157	01-Jul-20	BAGALKOT	220	220/110KV, HV2&LV2	MAHALINGAPUR_220, DAVLESHWAR_110	17:24	17:34	0:10	LINE CLEAR AVOIDED
158	01-Jul-20	BAGALKOT	220	220/110KV, HV2&LV2	RANEENNUR_220	17:17	17:36	0:19	HAND TRIPPED
159	01-Jul-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
160	01-Jul-20	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	15:39	16:14	0:35	HAND TRIPPED
161	01-Jul-20	BAGALKOT	220	BELLIGAVI(SHIRALKOPPA)- RANEENNUR	RANEENNUR_220	17:19	17:30	0:11	HAND TRIPPED
162	01-Jul-20	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	17:15 (25.06.2020)			LOAD CURTAILMENT
163	01-Jul-20	BAGALKOT	220	HUBLI220-SIRSI1	HUBLI_220 STATION NOT AFFECTED	11:46	14:09	2:23	LINE CLEAR AVOIDED
164	01-Jul-20	BAGALKOT	220	NAGJARI1&2-AMBEWADI_220	AMBEWADI_220	10:03	13:51	3:48	LINE CLEAR AVOIDED
165	01-Jul-20	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
166	01-Jul-20	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
167	01-Jul-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
168	01-Jul-20	BENGALURU	66	HV2	NIMHANS 220	14:31	14:35	0:04	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
169	01-Jul-20	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN:LINE FAULT
170	01-Jul-20	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI	13:08	13:50	0:42	LINE CLEAR AVAILED
171	01-Jul-20	BENGALURU	66	MITTEMARI 220 - PATHPALYA	NO STATION AFFECTED	1:49:00(25-6-2020)			LINE OPEN: LINE CLEAR AVAILED
172	01-Jul-20	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	NO STATION AFFECTED	1:45:00(25-6-2020)			LINE OPEN: LINE CLEAR AVAILED
173	01-Jul-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
174	01-Jul-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
175	01-Jul-20	BENGALURU	400	NELAMANGALA 400 - HIRIYUR 2	NO STATION AFFECTED	23:44:51(30-6-2020)	07:25:00(1-7-2020)	7:39	LINE CHARGED
176	01-Jul-20	GULBARGA	110	HATTI-GAMESHA_IPP	HATTI_110	23:24	23:37	0:13	LINE FAULT
177	01-Jul-20	GULBARGA	110	HV2	HATTI_110	17:36	17:41	0:05	TRANSFORMER FAULT
178	01-Jul-20	GULBARGA	110	HV2	HATTI_110	17:53	17:58	0:05	TRANSFORMER FAULT
179	01-Jul-20	GULBARGA	110	HV3	HALIKHED_110	23:05	23:10	0:05	TRANSFORMER FAULT
180	01-Jul-20	GULBARGA	110	KAPANOOR-GULBARGAWEST	GULBARGAWEST_110	5:22	16:20	10:58	LINE FAULT
181	01-Jul-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	4:30	4:48	0:18	LINE FAULT
182	01-Jul-20	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	4:25	4:46	0:21	LINE FAULT
183	01-Jul-20	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	5:18	5:23	0:05	LINE FAULT
184	01-Jul-20	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	0:25	0:36	0:11	LINE FAULT
185	01-Jul-20	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	4:55	5:05	0:10	LINE FAULT
186	01-Jul-20	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110	23:13			LINE OPEN:LINE FAULT
187	01-Jul-20	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	2:40(28.06.2020)			LINE OPEN: LINE CLEAR AVAILED
188	01-Jul-20	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	4:18	4:23	0:05	LINE FAULT
189	01-Jul-20	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	22:16	22:33	0:17	LINE FAULT
190	01-Jul-20	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SIDHANOOR_220	22:33	22:47	0:14	LINE FAULT
191	01-Jul-20	GULBARGA	110	SINDHANOOR-RAICHUR2	NO STATION AFFECTED	5:45(28.06.2020)			LINE OPEN:LINE FAULT
192	01-Jul-20	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	0:10	0:20	0:10	LINE FAULT
193	01-Jul-20	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	3:15	3:25	0:10	LINE FAULT
194	01-Jul-20	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	4:16	4:30	0:14	LINE FAULT
195	01-Jul-20	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	20:40	20:58	0:18	LINE FAULT
196	01-Jul-20	GULBARGA	220	HV1	KAPANOOR_220	5:22	10:30	5:08	TRANSFORMER FAULT
197	01-Jul-20	GULBARGA	220	HV1	KAPANOOR_220	10:30	16:04	5:34	LINE CLEAR AVAILED
198	01-Jul-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN: LINE CLEAR AVAILED
199	01-Jul-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT
200	01-Jul-20	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	23:27	23:42	0:15	LINE FAULT
201	01-Jul-20	GULBARGA	220	RTPS-SHAHAPUR1	SHAHAPUR_220	23:04			LINE OPEN:LINE FAULT
202	01-Jul-20	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	23:17			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
203	01-Jul-20	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	23:17			LINE OPEN:LINE FAULT
204	01-Jul-20	GULBARGA	220	SINDHANOOR-LINGAPUR	SIDHANOOR_220	18:34	20:00	1:26	LINE FAULT
205	01-Jul-20	GULBARGA	220	SINDHANOOR-LINGASUGUR	SIDHANOOR_220	23:23	23:42	0:19	LINE FAULT
206	01-Jul-20	HASSAN	66	HASSN220-R R NAGAR	HASSAN_220	15:39	15:43	0:04	HAND TRIPPED
207	01-Jul-20	HASSAN	66	LV1	NO STN AFFECTED	13:17 (26.06.2020)			LINE OPEN: LINE CLEAR AVAILED
208	01-Jul-20	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	6:25	6:38	0:13	LINE FAULT
209	01-Jul-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	17:25	18:59	1:34	LINE CLEAR AVOID
210	01-Jul-20	HASSAN	110	HV1	NO STN AFFECTED	13:17 (26.06.2020)			LINE OPEN: LINE CLEAR AVAILED
211	01-Jul-20	HASSAN	110	HV1	KITTADAHALLI_66	15:13	15:51	0:38	LINE CLEAR AVOID
212	01-Jul-20	HASSAN	110	KADUR-YGTI	KADUR_220	17:01	17:22	0:21	LINE FAULT
213	01-Jul-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	17:26	18:59	1:33	LINE CLEAR AVOID
214	01-Jul-20	HASSAN	220	GERSOPA-SHIMOGA	gerusoppa_gen	17:04(01.07.2020)			LINE OPEN:LINE FAULT
215	01-Jul-20	HASSAN	220	MRSSHM-STRP	MRSMSG_220	17:04(01.07.2020)			LINE OPEN:LINE FAULT
216	01-Jul-20	HASSAN	400	HASSAN40-UPCL1	SHNATHIGRAMA_400	20:33 (29.06.2020)	10:46	38:12 hrs	LINE CHARGED
217	01-Jul-20	HASSAN	400	HASSAN40-UPCL1	SHNATHIGRAMA_400	15:41 (1.07.2020)			LINE OPEN: LINE CLEAR AVAILED
218	01-Jul-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:33 (29.06.2020)	10:46	38:12 hrs	LINE CHARGED
219	01-Jul-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	15:41 (1.07.2020)			LINE OPEN: LINE CLEAR AVAILED
220	01-Jul-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:29 (25.06.2020)	9:56	132:26 hrs	LINE CHARGED
221	01-Jul-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:30 (1.07.2020)			LINE OPEN: LINE CLEAR AVAILED
222	01-Jul-20	MYSURU	66	HV1	DKMAIDANA_66	18:31	18:35	0:04	TRANSFORMER FAULT
223	01-Jul-20	MYSURU	66	HV1	DKMAIDANA_66	20:41	20:45	0:04	TRANSFORMER FAULT
224	01-Jul-20	MYSURU	220	HV1	CRNAGAR_220	11:23	14:54	3:30	LINE CLEAR AVOID
225	01-Jul-20	TUMKUR	66	NAGALAMADIKE-SUNDER RAJU SOLAR_IPP_66	SUNDER RAJU SOLAR_IPP_66	9:25	9:30	0:05	HAND TRIPPED
226	01-Jul-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN:LINE FAULT
227	01-Jul-20	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	RANGANATHAPURA_66	0:20	7:23	7:02	LINE FAULT
228	01-Jul-20	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	RANGANATHAPURA_66	0:20	1:02	0:42	LINE FAULT
229	01-Jul-20	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	7:16	17:51	10:34	LINE CLEAR AVOID
230	01-Jul-20	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14:44(28.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
231	01-Jul-20	TUMKUR	66	TR-1	CHANNAGIRI_66	7:55	8:05		TRANSFORMER FAULT
232	01-Jul-20	TUMKUR	66	TR-1	HULIYURDURGA_66	14:17	15:35	1:18	LINE CLEAR AVOID
233	01-Jul-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
234	01-Jul-20	TUMKUR	66	TR-3	HARIYABBE_66	2:38	2:44	0:06	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
235	01-Jul-20	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	1:02	18::25		LINE CLEAR AVAILED
236	01-Jul-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
237	2-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
238	2-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
239	2-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
240	2-Jul-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
241	2-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	9:0 (19.06.2020)	16:22 (02.07.2020)	319:22hrs	LINE CHARGED
242	2-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	BELGAUM_110	15:16 (20.06.2020)			LINE OPEN: LINE CLEAR AVAILED
243	2-Jul-2020	BAGALKOT	110	JAMAKHANDI-SHIROL	SHIROL_110	10:41 (24.06.2020)			LINE OPEN: LINE CLEAR AVAILED
244	2-Jul-2020	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN: LINE CLEAR AVAILED
245	2-Jul-2020	BAGALKOT	110	RANEBENNUR-RATTIHALLI (TUMMINKATTI)	TUMMINKATTI_110	8:30 (01.07.2020)	16:39 (02.07.2020)	32:09hrs	LINE CHARGED
246	2-Jul-2020	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	10:23	13:16	2:53	LINE CLEAR AVAILED
247	2-Jul-2020	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL(ACHANUR)	MUDEDEBIHAL_110	20:43	20:58	0:15	LINE FAULT
248	2-Jul-2020	BAGALKOT	110	110/33KV,HV1	BILAGI_110	10:40	10:42	0:02	TRANSFORMER FAULT
249	2-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
250	2-Jul-2020	BAGALKOT	110	110/11KV,HV2	HIDIKAL DAM_110	15:10	16:20	1:10	LINE CLEAR AVAILED
251	2-Jul-2020	BAGALKOT	110	GHATAPRABHA220-HIDIKAL DAM	HIDIKAL DAM_110	16:13	18:14	2:01	LINE CLEAR AVAILED
252	2-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
253	2-Jul-2020	BAGALKOT	110	110/33KV,HV2	HUNGUND_110, AMINGAD_33, KARADI_33	8:41	8:44	0:03	TRANSFORMER FAULT
254	2-Jul-2020	BAGALKOT	110	BALAGI SUGARS- MUDEDEBIHAL	MUDEDEBIHAL_110	20:43	21:00	0:17	HAND TRIPPED
255	2-Jul-2020	BAGALKOT	110	110/11KV, HV3	RAIBAG_110	12:52	13:03	0:11	LINE CLEAR AVAILED
256	2-Jul-2020	BAGALKOT	110	110/11KV, HV3	RAIBAG_110	16:01	18:59	2:58	LINE CLEAR AVAILED
257	2-Jul-2020	BAGALKOT	110	110/11KV,HV2	VAJRAMATTI_110	16:44	16:50	0:06	TRANSFORMER FAULT
258	2-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
259	2-Jul-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
260	2-Jul-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
261	2-Jul-2020	BAGALKOT	220	GUTTUR-RANEBENNUR	RANEBENNUR_220	17:15 (25.06.2020)	21:24 (02.07.2020)	172:09hrs	LINE CHARGED
262	2-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
263	2-Jul-2020	BAGALKOT	220	CHIKKODI-MUDASHINGI	CHIKKODI_220	9:39	13:32	3:53	LINE CLEAR AVAILED
264	2-Jul-2020	BAGALKOT	220	220/110KV,HV1, LV1	CHIKKODI_220	11:53	13:28	1:35	LINE CLEAR AVAILED
265	2-Jul-2020	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	CHIKKODI_220	14:31	16:29	1:58	LINE CLEAR AVAILED
266	2-Jul-2020	BAGALKOT	220	220/110KV, HV2&LV2	RANEBENNUR_220	10:47	16:12	5:25	LINE CLEAR AVAILED
267	2-Jul-2020	BAGALKOT	220	BALLIGAVI(SHIROLKOPPA)-RANEBENNUR	RANEBENNUR_220	21:20	21:37	0:17	HAND TRIPPED
268	2-Jul-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	17:51	18:12	0:21	LINE FAULT
269	2-Jul-2020	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	8:01	11:45	3:44	LINE FAULT
270	2-Jul-2020	BENGALURU	66	HV2	KODIHALLI KANAKAPURA	15:03	15:03	0:00	TRANSFORMER FAULT
271	2-Jul-2020	BENGALURU	66	HV1	RR NAGAR	8:01	8:17	0:16	MAIN SUPPLY FAILURE
272	2-Jul-2020	BENGALURU	66	HV1	RR NAGAR	16:25	16:29	0:03	LOAD CHANGEOVER
273	2-Jul-2020	BENGALURU	66	HV2	RR NAGAR	8:01	8:17	0:16	MAIN SUPPLY FAILURE
274	2-Jul-2020	BENGALURU	66	HV2	RR NAGAR	16:25	16:29	0:03	LOAD CHANGEOVER
275	2-Jul-2020	BENGALURU	66	HV2	THAYALUR	18:27	18:32	0:05	TRANSFORMER FAULT
276	2-Jul-2020	BENGALURU	66	HV1	TK HALLI 220	10:33	10:52	0:19	TRANSFORMER FAULT
277	2-Jul-2020	BENGALURU	66	JALAMANGALA - MELEHALLI	JALAMANGALA, KUTAGALLU, CHIKKAGANGANAWADI	15:15	15:25	0:10	LINE FAULT
278	2-Jul-2020	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK (EHT)	10:58	11:20	0:21	LINE FAULT
279	2-Jul-2020	BENGALURU	66	JAKKASANDRA - HSR 1	JAKKASANDRA	14:18	14:23	0:05	LINE FAULT
280	2-Jul-2020	BENGALURU	66	JAKKASANDRA - ADUGODI	ADUGODI	14:18	14:26	0:08	LINE FAULT
281	2-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN:LINE FAULT
282	2-Jul-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	NO STATION AFFECTED	1:45:00(25-6-2020)			LINE OPEN: LINE CLEAR AVAILED
283	2-Jul-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	NO STATION AFFECTED	1:49:00(25-6-2020)			LINE OPEN: LINE CLEAR AVAILED
284	2-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
285	2-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
286	2-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
287	2-Jul-2020	GULBARGA	66	GUDEKOTE-KUDLIGI	GUDEKOTE_66	05:40	06:00	00:20	MAIN SUPPLY FAILURE
288	2-Jul-2020	GULBARGA	66	GUDEKOTE-KUDLIGI	GUDEKOTE_66	09:15	11:00	01:45	LINE CLEAR AVAILED
289	2-Jul-2020	GULBARGA	66	TBHALLI-ITTAGGI	TAMBRAHALLI_66	08:34	08:42	00:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
290	2-Jul-2020	GULBARGA	66	HV1	TAMBRAHALLI_66	10:48	10:53	00:05	TRANSFORMER FAULT
291	2-Jul-2020	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	2:40(28.06.2020)			LINE OPEN: LINE CLEAR AVAILED
292	2-Jul-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,ASKI_110,HUNSAGI_110	23:13(01.07.2020)	0:10(2.7.20)	0:57HRS	LINE CHARGED
293	2-Jul-2020	GULBARGA	110	KAPANOOR-ALAND	ALAND_110	05:33	05:40	00:07	LINE FAULT
294	2-Jul-2020	GULBARGA	110	KAPANOOR-GULBARGAWEST	GULBARGAWEST_110	14:44	14:50	00:06	LINE FAULT
295	2-Jul-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	03:23	03:26	00:03	LINE FAULT
296	2-Jul-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	03:30	03:35	00:05	LINE FAULT
297	2-Jul-2020	GULBARGA	110	SIDHANOOR220-NIRLOOTI	NIRLOOTI_110	02:12	02:24	00:12	LINE FAULT
298	2-Jul-2020	GULBARGA	110	KEMBHAVI-UGAR-SUGAR_IPP	KEMBHAVI_110	23:15(1.6.2020)	0:36(2.7.20)	1:16HRS	LINE CHARGED
299	2-Jul-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,ASKI_110,HUNSAGI_110	23:15(1.6.2020)	0:11(2.7.20)	0:56 HRS	LINE CHARGED
300	2-Jul-2020	GULBARGA	110	HV1	HATTI_110	01:11	01:29	00:18	TRANSFORMER FAULT
301	2-Jul-2020	GULBARGA	110	GULBARGA UNIVERSITY-GULBARGA SOUTH	GULBARGA UNIVERSITY_110	14:54	15:05	00:11	MAIN SUPPLY FAILURE
302	2-Jul-2020	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	02:23	02:33	00:10	LINE FAULT
303	2-Jul-2020	GULBARGA	110	HV2	MANVI_110	10:42	10:55	00:13	TRANSFORMER FAULT
304	2-Jul-2020	GULBARGA	110	HV3	VALKAMDINNI_110	01:10	01:19	00:09	TRANSFORMER FAULT
305	2-Jul-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	03:48	03:57	00:09	LINE FAULT
306	2-Jul-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	04:56	05:10	00:14	LINE FAULT
307	2-Jul-2020	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	04:12	05:00	00:48	LINE FAULT
308	2-Jul-2020	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	05:00	07:34	02:34	LINE CLEAR AVAILED
309	2-Jul-2020	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	19:40	19:46	00:06	LINE FAULT
310	2-Jul-2020	GULBARGA	110	KAVITAL-GAMESHA_IPP	KAVITAL_110	19:05	19:30	00:25	LINE CLEAR AVAILED
311	2-Jul-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	23:46	23:58	00:12	LINE FAULT
312	2-Jul-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	NO STATION AFFECTED	5:45(28.06.2020)	16:03(2.7.20)	34:18HRS	LINE CHARGED
313	2-Jul-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPS WATERWORKS	21:40	21:53	00:13	LINE FAULT
314	2-Jul-2020	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	23:45	23:56	00:11	LINE FAULT
315	2-Jul-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT
316	2-Jul-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN: LINE CLEAR AVAILED
317	2-Jul-2020	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	15:19(2.7.20)			NFBC ISSUED
318	2-Jul-2020	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	23:17(01.07.2020)	0:06(2.7.20)	0:49HRS	LINE CHARGED
319	2-Jul-2020	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	23:17(01.07.2020)	0:19(2.7.20)	1:02HRS	LINE CHARGED
320	2-Jul-2020	GULBARGA	220	RTPS-SHAHAPUR1	SHAHAPUR_220	23:04(01.07.2020)	0:40(2.7.20)	1:36HRS	LINE CHARGED
321	2-Jul-2020	HASSAN	66	LV1	NO STN AFFECTED	13:17 (26.06.2020)			LINE OPEN: LINE CLEAR AVAILED
322	2-Jul-2020	HASSAN	66	HV2	HOLEHONNUR_66	18:25	18:37	00:12	TRANSFORMER FAULT
323	2-Jul-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	19:24	19:52	00:28	LINE FAULT
324	2-Jul-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	19:52	20:22	00:30	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
325	2-Jul-2020	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	23:25	23:48	00:23	LINE FAULT
326	2-Jul-2020	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	11:45	11:59	00:14	LINE FAULT
327	2-Jul-2020	HASSAN	110	HV1	NO STN AFFECTED	13:17 (26.06.2020)			LINE OPEN: LINE CLEAR AVAILED
328	2-Jul-2020	HASSAN	110	JOG-JLT3	mghejog_gen	22:33 (2.07.2020)			LINE OPEN: LINE CLEAR AVAILED
329	2-Jul-2020	HASSAN	110	JOG-JLT4	mghejog_gen	13:30 (2.07.2020)			LINE OPEN:LINE FAULT
330	2-Jul-2020	HASSAN	110	JOG110-MGHE	JOG_110	13:30(02.07.2020)			LINE OPEN:LINE FAULT
331	2-Jul-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	13:19	13:30	00:11	LINE FAULT
332	2-Jul-2020	HASSAN	110	KEMAR-BELMAN	KEMAR_220	15:27	16:10	00:43	LINE FAULT
333	2-Jul-2020	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	13:35	13:44	00:09	HAND TRIPPED
334	2-Jul-2020	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	21:18	21:40	00:22	MAIN SUPPLY FAILURE
335	2-Jul-2020	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	21:18	21:42	00:24	MAIN SUPPLY FAILURE
336	2-Jul-2020	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	21:18	21:44	00:26	MAIN SUPPLY FAILURE
337	2-Jul-2020	HASSAN	110	JOG-JST1	mghejog_gen	22:32	22:35	00:03	LINE FAULT
338	2-Jul-2020	HASSAN	110	HV1	NANDIKUR_110	13:43	14:33	00:50	LINE CLEAR AVAILED
339	2-Jul-2020	HASSAN	110	NNADIKU-KEMAR1	NANDIKUR_110	15:27	16:37	01:10	LINE FAULT
340	2-Jul-2020	HASSAN	220	MRSSHM-STRP	MRSMSG_220	17:04(01.07.2020)	12:57(2.7.20)	19:52 hrs	LINE CHARGED
341	2-Jul-2020	HASSAN	220	GERSOPA-SHIMOGA	gerusoppa_gen	17:04(01.07.2020)	12:57(2.7.20)	19:52 hrs	LINE CHARGED
342	2-Jul-2020	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	21:18(02.07.2020)			MAIN SUPPLY FAILURE
343	2-Jul-2020	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	05:51	14:15	08:24	LINE FAULT
344	2-Jul-2020	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	05:51	14:18	08:27	LINE FAULT
345	2-Jul-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:38	13:11	02:33	LINE CLEAR AVAILED
346	2-Jul-2020	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	13:19	13:29	00:10	LINE FAULT
347	2-Jul-2020	HASSAN	400	HASSAN40-UPCL1	SHNATHIGRAMA_400	15:41 (1.07.2020)	13:32(2.7.20)	31:50 hrs	LINE CHARGED
348	2-Jul-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	15:41 (1.07.2020)	13:32(2.7.20)	31:50 hrs	LINE CHARGED
349	2-Jul-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:30 (1.07.2020)	7:29(2.7.20)	7:58 hrs	LINE CHARGED
350	2-Jul-2020	HASSAN	400	HASSAN40-UPCL1	SHNATHIGRAMA_400	20:55 (2.07.2020)			LINE OPEN: LINE CLEAR AVAILED
351	2-Jul-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:55 (2.07.2020)			LINE OPEN: LINE CLEAR AVAILED
352	2-Jul-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	17:16 (2.07.2020)			LINE OPEN: LINE CLEAR AVAILED
353	2-Jul-2020	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	1:30	1:41	0:11	LINE FAULT
354	2-Jul-2020	MYSURU	66	HV2	MEGALAPURA_66	11:16	11:19	0:03	HAND TRIPPED
355	2-Jul-2020	MYSURU	66	MUGUR-CLEAN SOLAR	NO STATIONS EFFECTED	8:07	8:24	0:17	LINE FAULT
356	2-Jul-2020	MYSURU	66	HV1	PONNAMPET_66	7:53	9:12	1:19	LINE CLEAR AVAILED
357	2-Jul-2020	MYSURU	66	HV2	SANTHE MARALLI-	17:25	17:34	0:08	HAND TRIPPED
358	2-Jul-2020	MYSURU	220	HV1	CRNAGAR_220	11:23	14:54	3:30	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
359	2-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN:LINE FAULT
360	2-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
361	2-Jul-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14:44(28.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
362	2-Jul-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	11:36	12:41	1:05	LINE CLEAR AVAILED
363	2-Jul-2020	TUMKUR	66	TR-1	CHIKKABANAGERE_66	16:31	16:53	0:22	LINE CLEAR AVAILED
364	2-Jul-2020	TUMKUR	66	CHITRADURGA 220kv- HGML	HGML_IPP_66	16:32	16:51	0:19	LINE FAULT
365	2-Jul-2020	TUMKUR	66	TR-3	DAVANGERE_SRS_220	9:53	11:19	1:26	LINE CLEAR AVAILED
366	2-Jul-2020	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	16:48	17:01	0:13	LINE FAULT
367	2-Jul-2020	TUMKUR	66	TR-2	HALUVAGALU_66	7:07	7:12	0:04	TRANSFORMER FAULT
368	2-Jul-2020	TUMKUR	66	HANAGAL-AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	9:55	10:47	0:51	LINE CLEAR AVAILED
369	2-Jul-2020	TUMKUR	66	HANAGAL- B G KERE	BGKERE_66,GUDEKOTE_66	9:53	10:47	0:53	LINE CLEAR AVAILED
370	2-Jul-2020	TUMKUR	66	TR-1	HANAGAL_66	9:52	10:47	0:54	LINE CLEAR AVAILED
371	2-Jul-2020	TUMKUR	66	TR-2	HANAGAL_66	9:52	10:47	0:54	LINE CLEAR AVAILED
372	2-Jul-2020	TUMKUR	66	TR-3	HARIYABBE_66	10:54	11:02	0:07	TRANSFORMER FAULT
373	2-Jul-2020	TUMKUR	66	TR-3	HARIYABBE_66	14:36	14:43	0:06	TRANSFORMER FAULT
374	2-Jul-2020	TUMKUR	66	TR-3	HARIYABBE_66	15:01	15:14	0:13	TRANSFORMER FAULT
375	2-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
376	2-Jul-2020	TUMKUR	110	BANDIHALLI- TIPTUR	TIPTUR_110, HONNAVALLI_110	14:46	14:50	0:03	LINE CLEAR AVAILED
377	2-Jul-2020	TUMKUR	220	TR-3	DAVANGERE_SRS_220	9:52	11:20	1:27	LINE CLEAR AVAILED
378	3-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
379	3-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
380	3-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
381	3-Jul-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
382	3-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	BELGAUM_110	15:16 (20.06.2020)			LINE OPEN: LINE CLEAR AVAILED
383	3-Jul-2020	BAGALKOT	110	JAMAKHANDI-SHIROL	SHIROL_110	10:41 (24.06.2020)			LINE OPEN: LINE CLEAR AVAILED
384	3-Jul-2020	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT EFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN: LINE CLEAR AVAILED
385	3-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
386	3-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
387	3-Jul-2020	BAGALKOT	110	ENERCON2-BELLATTI	BELLATTI_110	16:31	17:50	1:19	LINE CLEAR AVAILED
388	3-Jul-2020	BAGALKOT	110	110/33KV, HV2	GULEDGUDDA_110, KAMATAGI_33, SHIRUR_33	17:21	17:52	0:31	TRANSFORMER FAULT
389	3-Jul-2020	BAGALKOT	110	VAJRAMATTI220-MANTUR1	STATION NOT EFFECTED	16:31	17:50	1:19	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
390	3-Jul-2020	BAGALKOT	110	SIRSI 220(ESALE)-UMMACHAGI	STATION NOT AFFECTED	12:25 (03.07.2020)			LINE OPEN: LINE CLEAR AVAILED
391	3-Jul-2020	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	12:40	17:21	4:41	LINE CLEAR AVOIDED
392	3-Jul-2020	BAGALKOT	110	110/11KV, HV1	KANABARGI LAYOUT_110	11:02	11:31	0:29	LINE CLEAR AVOIDED
393	3-Jul-2020	BAGALKOT	110	110/33KV, HV1	KANABARGI LAYOUT_110, KAKTI_33, SUZLON_33	15:21	16:19	0:58	LINE CLEAR AVOIDED
394	3-Jul-2020	BAGALKOT	110	MAHALINGAPUR- TERDAL	TERDAL_110	22:49 (03.07.2020)			LINE OPEN: LINE CLEAR AVAILED
395	3-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
396	3-Jul-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
397	3-Jul-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
398	3-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
399	3-Jul-2020	BAGALKOT	220	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	12:42	14:53	2:11	NFBC ISSUED
400	3-Jul-2020	BAGALKOT	220	GUTTUR- RANEENNUR	RANEENNUR_220	16:16 (03.07.2020)			LINE OPEN: LINE CLEAR AVAILED
401	3-Jul-2020	BENGALURU	66	HV1	AMARJYOTHI	12:45	13:05	00:20	MAIN SUPPLY FAILURE
402	3-Jul-2020	BENGALURU	66	HV3	HEBBALA 220	14:05	14:29	00:24	LINE CLEAR AVOIDED
403	3-Jul-2020	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1 & 2	JAKKASANDRA, ADUGODI, BOSCH (EHT)	12:44	13:10	00:26	LINE CLEAR AVOIDED
404	3-Jul-2020	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1 & 2	JAKKASANDRA, ADUGODI, BOSCH (EHT)	20:55	21:16	00:21	LINE CLEAR AVOIDED
405	3-Jul-2020	BENGALURU	66	HV1	KADUGODI	22:15	22:23	00:08	TRANSFORMER FAULT
406	3-Jul-2020	BENGALURU	66	KORAMANGALA 220 - KORAMANGALA 66	KORAMANGALA 66	12:44	13:05	00:21	MAIN SUPPLY FAILURE
407	3-Jul-2020	BENGALURU	66	KORAMANGALA 220 - K&C VALLEY	K&C VALLEY	12:44	13:05	00:21	MAIN SUPPLY FAILURE
408	3-Jul-2020	BENGALURU	66	HV2	KUMBALAGODU	19:06	19:45	00:39	TRANSFORMER FAULT
409	3-Jul-2020	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	12:45	13:10	00:25	MAIN SUPPLY FAILURE
410	3-Jul-2020	BENGALURU	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	13:01	13:15	0:13	MAIN SUPPLY FAILURE
411	3-Jul-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	13:01	13:15	0:13	MAIN SUPPLY FAILURE
412	3-Jul-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	HALLIMARANAHALLI	13:01	13:15	0:13	MAIN SUPPLY FAILURE
413	3-Jul-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU	13:01	14:00	0:58	MAIN SUPPLY FAILURE
414	3-Jul-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	13:01	13:15	0:13	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
415	3-Jul-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	13:01	13:15	0:13	MAIN SUPPLY FAILURE
416	3-Jul-2020	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	19:10	19:40	0:29	MAIN SUPPLY FAILURE
417	3-Jul-2020	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	19:10	19:40	0:29	MAIN SUPPLY FAILURE
418	3-Jul-2020	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	19:10	19:40	0:29	MAIN SUPPLY FAILURE
419	3-Jul-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	15:47	16:05	0:17	MAIN SUPPLY FAILURE
420	3-Jul-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	15:47	16:05	0:17	MAIN SUPPLY FAILURE
421	3-Jul-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	15:47	16:05	0:17	MAIN SUPPLY FAILURE
422	3-Jul-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	15:47	16:05	0:17	MAIN SUPPLY FAILURE
423	3-Jul-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	15:47	16:05	0:17	MAIN SUPPLY FAILURE
424	3-Jul-2020	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	15:47	16:05	0:17	MAIN SUPPLY FAILURE
425	3-Jul-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	19:10	19:46	0:35	MAIN SUPPLY FAILURE
426	3-Jul-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	19:10	19:47	0:36	MAIN SUPPLY FAILURE
427	3-Jul-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	19:10	19:47	0:36	MAIN SUPPLY FAILURE
428	3-Jul-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	12:46	13:00	0:13	LOAD CHANGEOVER
429	3-Jul-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	12:46	13:00	0:13	LOAD CHANGEOVER
430	3-Jul-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	17:43	17:51	0:07	LOAD CHANGEOVER
431	3-Jul-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	17:43	17:51	0:07	LOAD CHANGEOVER
432	3-Jul-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	12:42	13:01	0:19	LOAD CHANGEOVER
433	3-Jul-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	14:08	14:17	0:09	LOAD CHANGEOVER
434	3-Jul-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	15:47	16:11	0:24	MAIN SUPPLY FAILURE
435	3-Jul-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	17:43	17:51	0:07	LOAD CHANGEOVER
436	3-Jul-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	15:12	16:32	1:20	LINE CLEAR AVAILED
437	3-Jul-2020	BENGALURU	66	HV1	SM MANGALA	15:33	15:43	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
438	3-Jul-2020	BENGALURU	66	HV2	SOMAYAJJANAHALLI	17:05	17:21	0:16	LINE CLEAR AVAILED
439	3-Jul-2020	BENGALURU	66	HV2	YEDUMADU	13:02	14:18	1:16	TRANSFORMER FAULT
440	3-Jul-2020	BENGALURU	66	HV1	NANGALI	13:57	14:25	0:27	LINE CLEAR AVAILED
441	3-Jul-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	12:05	12:13	0:07	LINE CLEAR AVAILED
442	3-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN:LINE FAULT
443	3-Jul-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	NO STATION AFFECTED	1:45:00(25-6-2020)			LINE OPEN: LINE CLEAR AVAILED
444	3-Jul-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	NO STATION AFFECTED	1:49:00(25-6-2020)			LINE OPEN: LINE CLEAR AVAILED
445	3-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
446	3-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTc	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
447	3-Jul-2020	BENGALURU	220	HAL 220 - HOODY 1	NO STATION AFFECTED	12:44	13:57	01:13	LINE FAULT
448	3-Jul-2020	BENGALURU	220	HOODY 400 - HAL -2	NO STATION AFFECTED	12:44	13:56	01:12	LINE FAULT
449	3-Jul-2020	BENGALURU	220	HSR LAYOUT 220 - EPIP 220	KORAMANGALA 220, NIMHANS 220	12:44	13:00	00:16	LINE FAULT
450	3-Jul-2020	BENGALURU	220	HV2	HSR LAYOUT	20:55	21:11	00:16	TRANSFORMER FAULT
451	3-Jul-2020	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	19:10	19:43	0:32	MAIN SUPPLY FAILURE
452	3-Jul-2020	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	19:10	19:38	0:27	LINE CLEAR AVAILED
453	3-Jul-2020	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	15:47	16:02	0:15	LINE FAULT
454	3-Jul-2020	BENGALURU	220	HV1	MALUR 220	15:47	17:49	2:02	MAIN SUPPLY FAILURE
455	3-Jul-2020	BENGALURU	220	HV1	KANAKAPURA 220	13:02	13:13	0:11	TRANSFORMER FAULT
456	3-Jul-2020	BENGALURU	220	HV2	KANAKAPURA 220	13:02	13:13	0:11	TRANSFORMER FAULT
457	3-Jul-2020	BENGALURU	220	HV1	VIKAS TECH PARK 220	19:10	19:40	0:29	MAIN SUPPLY FAILURE
458	3-Jul-2020	BENGALURU	220	HV2	VIKAS TECH PARK 220	19:10	19:40	0:29	MAIN SUPPLY FAILURE
459	3-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
460	3-Jul-2020	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	2:40(28.06.2020)			LINE OPEN: LINE CLEAR AVAILED
461	3-Jul-2020	GULBARGA	110	KAPANOOR-HUMNABAD1	MAHAGAON_110,MARAGUTTI_110	02:15	02:43	00:28	LINE FAULT
462	3-Jul-2020	GULBARGA	110	MASKI-RENEWSOLAR_IPP	MASKI_110	09:45	09:50	00:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
463	3-Jul-2020	GULBARGA	110	HV2	MANVI_110	11:12	11:30	00:18	TRANSFORMER FAULT
464	3-Jul-2020	GULBARGA	110	HV2	MANVI_110	13:00	13:11	00:11	TRANSFORMER FAULT
465	3-Jul-2020	GULBARGA	110	HV2	MANVI_110	14:37	14:51	00:14	TRANSFORMER FAULT
466	3-Jul-2020	GULBARGA	110	HALIKHED-HALBARGA	HALIKHED_110	11:40	12:05	00:25	LINE FAULT
467	3-Jul-2020	GULBARGA	110	GULBARGA UNIVERSITY-SHAHABAD2	GULBARGA UNIVERSITY_110	04:00	04:10	00:10	MAIN SUPPLY FAILURE
468	3-Jul-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	13:17	16:30	01:10	LINE CLEAR AVAILED
469	3-Jul-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,ASKI_110,HUNSAGI_110,CORE GREEN SUGAR_IPP	04:30	04:38	02:10	LINE FAULT
470	3-Jul-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	22:45	22:55	00:10	LINE FAULT
471	3-Jul-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADLAPUR_110,KURU DICROSS_110	21:35	21:45	00:10	LINE FAULT
472	3-Jul-2020	GULBARGA	110	HV2	MANVI_110	19:53	19:58	00:05	TRANSFORMER FAULT
473	3-Jul-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT
474	3-Jul-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN: LINE CLEAR AVAILED
475	3-Jul-2020	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	15:19(2.7.2020)			NFBC ISSUED
476	3-Jul-2020	HASSAN	66	LV1	NO STN AFFECTED	13:17 (26.06.2020)			LINE OPEN: LINE CLEAR AVAILED
477	3-Jul-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	15:06	15:25	00:19	LINE FAULT
478	3-Jul-2020	HASSAN	66	HV1	AREHALLI_HSN_66	12:21	14:05	01:44	LINE CLEAR AVAILED
479	3-Jul-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	13:57	14:03	00:06	TRANSFORMER FAULT
480	3-Jul-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	13:54	14:01	00:07	HAND TRIPPED
481	3-Jul-2020	HASSAN	66	HV2	SALAGAME_66	10:53	11:54	01:01	LINE CLEAR AVAILED
482	3-Jul-2020	HASSAN	110	HV1	NO STN AFFECTED	13:17 (26.06.2020)			LINE OPEN: LINE CLEAR AVAILED
483	3-Jul-2020	HASSAN	110	JOG-JLT3	NO STN AFFECTED	22:33 (2.07.2020)			LINE OPEN: LINE CLEAR AVAILED
484	3-Jul-2020	HASSAN	110	JOG-JLT4	NO STN AFFECTED	13:30 (2.07.2020)			LINE OPEN: LINE CLEAR AVAILED
485	3-Jul-2020	HASSAN	110	JOG110-MGHE	NO STN AFFECTED	13:30(02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
486	3-Jul-2020	HASSAN	110	HV3	HIRIYADKA_110	10:29(03.07.2020)			LINE OPEN: LINE CLEAR AVAILED
487	3-Jul-2020	HASSAN	110	KAVOOR-BAIKAMPADY	KAVOOR_220	05:57	06:09	00:12	LINE FAULT
488	3-Jul-2020	HASSAN	110	HV1	MOODABIDRE_110	15:12	15:23	00:11	TRANSFORMER FAULT
489	3-Jul-2020	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	21:18(02.07.2020)	15:58 (3.07.2020)	18:39 hrs	LINE CHARGED
490	3-Jul-2020	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	10:18	13:36	03:18	LINE CLEAR AVAILED
491	3-Jul-2020	HASSAN	220	MRSSHM-KBCRS	MRSMG_220	02:24	02:58	00:34	LINE FAULT
492	3-Jul-2020	HASSAN	220	MRSSHM-VARAH1	MRSMG_220	11:46	12:22	00:36	LINE CLEAR AVAILED
493	3-Jul-2020	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	10:18	13:35	03:17	NFBC ISSUED
494	3-Jul-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	17:16(2.07.2020)	7:29 (3.07.2020)	14:12 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
495	3-Jul-2020	HASSAN	400	HASSAN40-UPCL1	NO STN AFFECTED	20:55 (2.07.2020)			LINE OPEN: LINE CLEAR AVAILED
496	3-Jul-2020	HASSAN	400	UPCL-HASSAN1	NO STN AFFECTED	20:55 (2.07.2020)			LINE OPEN: LINE CLEAR AVAILED
497	3-Jul-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:02 (3.07.2020)			LINE OPEN: LINE CLEAR AVAILED
498	3-Jul-2020	MYSURU	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS EFFECTED	18:38	18:44	0:06	LINE FAULT
499	3-Jul-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
500	3-Jul-2020	MYSURU	66	HV2	HOOTAGALLY_220	14:20	21:05	6:45	LINE CLEAR AVAILED
501	3-Jul-2020	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	13:51	14:54	1:03	LINE FAULT
502	3-Jul-2020	MYSURU	66	HV2	K_HONNALGERE_66	13:44	14:03	0:19	LINE CLEAR AVAILED
503	3-Jul-2020	MYSURU	66	KUSHALANAGARA 220- BETTADAPURA	NO STATIONS EFFECTED	13:09	13:14	0:05	HAND TRIPPED
504	3-Jul-2020	MYSURU	66	MEGHALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	5:59	6:17	0:18	LINE FAULT
505	3-Jul-2020	MYSURU	66	HV1	PONNAMPET_66	20:47	21:25	0:37	TRANSFORMER FAULT
506	3-Jul-2020	MYSURU	66	HV1	PONNAMPET_66	21:40	22:00	0:19	LINE CLEAR AVAILED
507	3-Jul-2020	MYSURU	66	HV2	YELANDUR_66	9:35	11:32	1:56	LINE CLEAR AVAILED
508	3-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN:LINE FAULT
509	3-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
510	3-Jul-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14(28.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
511	3-Jul-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,RAMAG IRI_66	23:14(03.07.2020)			LINE CLEAR AVAILED
512	3-Jul-2020	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	19:57(03.07.2020)			LINE OPEN:LINE FAULT
513	3-Jul-2020	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	14:40	18:08	3:27	LINE CLEAR AVAILED
514	3-Jul-2020	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 3	CHITRADURGA_66	18:54	19:09	0:15	LINE FAULT
515	3-Jul-2020	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 3	CHITRADURGA_66	20:10	20:15	0:04	LINE FAULT
516	3-Jul-2020	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 3	CHITRADURGA_66	20:17	20:21	0:04	LINE FAULT
517	3-Jul-2020	TUMKUR	66	TR-1	GARAGA_66	10:57	17:59	7:02	LINE CLEAR AVAILED
518	3-Jul-2020	TUMKUR	66	GULIGENAHALLI- SIRA	GULIGENAHALLI_66	16:05	16:22	0:16	LINE FAULT
519	3-Jul-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	0:08	0:10	0:02	HAND TRIPPED
520	3-Jul-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:23	9:35	0:11	HAND TRIPPED
521	3-Jul-2020	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_66,S ASALUHALLA_66	0:08	0:10	0:02	HAND TRIPPED
522	3-Jul-2020	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_66,S ASALUHALLA_66	9:23	9:35	0:11	HAND TRIPPED
523	3-Jul-2020	TUMKUR	66	MIDIGESHI-IDHALLI	IDHALLY_66,KODIGENAHALLI_6	16:05	16:10	0:04	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
524	3-Jul-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	8:11	8:18	0:06	TRANSFORMER FAULT
525	3-Jul-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,RAMAGIRI_66	18:54	20:10	1:16	LINE FAULT
526	3-Jul-2020	TUMKUR	66	TR-2	PATTANAYAKANAHALLI_66	10:27	11:13	0:46	LINE CLEAR AVAILED
527	3-Jul-2020	TUMKUR	66	PAVAGADA-NAGALAMADIKE	PAVAGADA_220	5:50	6:06	0:16	LINE FAULT
528	3-Jul-2020	TUMKUR	66	TR-2	RAMPURA_66	12:34	12:40	0:06	TRANSFORMER FAULT
529	3-Jul-2020	TUMKUR	66	RAMPURA66-WELSPUN SOLAR	WELSPUN SOLAR_IPP_66	14:11	14:39	0:27	HAND TRIPPED
530	3-Jul-2020	TUMKUR	66	SIRA- BUKKAPATNA	SIRA_66	11:23	11:33	0:09	LINE FAULT
531	3-Jul-2020	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	13:55	14:22	0:27	LINE FAULT
532	3-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
533	3-Jul-2020	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	14:06	15:29	1:23	LINE CLEAR AVAILED
534	4-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
535	4-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
536	4-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
537	4-Jul-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
538	4-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN: LINE CLEAR AVAILED
539	4-Jul-2020	BAGALKOT	110	JAMAKHANDI-SHIROL	STATION NOT AFFECTED SHIROL_110	10:41 (24.06.2020)			LINE OPEN: LINE CLEAR AVAILED
540	4-Jul-2020	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN: LINE CLEAR AVAILED
541	4-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
542	4-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
543	4-Jul-2020	BAGALKOT	110	SIRSI 220(ESALE J)-UMMACHAGI	STATION NOT AFFECTED	12:25 (03.07.2020)			LINE OPEN: LINE CLEAR AVAILED
544	4-Jul-2020	BAGALKOT	110	MAHALINGAPUR- TERDAL	STATION NOT AFFECTED TERDAL_110	22:49 (03.07.2020)	10:07 (04.07.2020)	11:18hrs	LINE CHARGED
545	4-Jul-2020	BAGALKOT	110	110/11KV,HV 2	ANKOLA_110	11:19	11:32	0:13	HAND TRIPPED
546	4-Jul-2020	BAGALKOT	110	ATHANI 220-KSSKN	ATHANI_220	14:26	15:21	0:55	LINE CLEAR AVAILED
547	4-Jul-2020	BAGALKOT	110	110/11KV,HV 4	BAILHONGAL_110	11:55	18:48	6:53	LINE CLEAR AVAILED
548	4-Jul-2020	BAGALKOT	110	BELGAUM-HUKKERI	HUKKERI_110	18:03	18:35	0:32	LINE FAULT
549	4-Jul-2020	BAGALKOT	110	BELGAUM-ANKALAGI	ANKALAGI_110	18:03	18:28	0:25	LINE FAULT
550	4-Jul-2020	BAGALKOT	110	110/33KV,HV3	GAJENDRAGAD_110 & WIND 3&4 33KV	18:24	18:59	0:35	TRANSFORMER FAULT
551	4-Jul-2020	BAGALKOT	110	MAHALINGPUR-HIDIKAL	HIDIKAL_110	15:40	15:47	0:07	HAND TRIPPED
552	4-Jul-2020	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	10:15	10:16	0:01	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
553	4-Jul-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, HALSANGI_33	14:44	15:38	0:54	TRANSFORMER FAULT
554	4-Jul-2020	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	12:44	12:52	0:08	HAND TRIPPED
555	4-Jul-2020	BAGALKOT	110	VAJRAMATTI220- VAJRAMATTI	VAJRAMATTI_110	16:15	17:26	1:11	LINE CLEAR AVAILED
556	4-Jul-2020	BAGALKOT	110	110/11KV, HV2	SHIROL_110	16:59	17:44	0:45	LINE CLEAR AVAILED
557	4-Jul-2020	BAGALKOT	110	110/11KV, HV2	SHIROL_110	21:58	22:09	0:11	TRANSFORMER FAULT
558	4-Jul-2020	BAGALKOT	110	110/11KV, HV2	MUDEBIHAL_110	6:58	7:12	0:14	TRANSFORMER FAULT
559	4-Jul-2020	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	3:20	7:17	3:57	LINE CLEAR AVAILED
560	4-Jul-2020	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(G)_110	6:34	6:51	0:17	LINE CLEAR AVAILED
561	4-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
562	4-Jul-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
563	4-Jul-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
564	4-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
565	4-Jul-2020	BAGALKOT	220	GUTTUR- RANEBENNUR	STATION NOT AFFECTED RANEBENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
566	4-Jul-2020	BENGALURU	66	HV2	YERANDANAHALLI 220	8:50	8:56	0:06	LOAD CHANGEOVER
567	4-Jul-2020	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	10:00	10:12	0:12	LOAD CHANGEOVER
568	4-Jul-2020	BENGALURU	66	HV1	YERANDANAHALLI 220	10:00	10:20	0:20	LOAD CHANGEOVER
569	4-Jul-2020	BENGALURU	66	HV2	YERANDANAHALLI 220	10:00	10:20	0:20	LOAD CHANGEOVER
570	4-Jul-2020	BENGALURU	66	HV3	YERANDANAHALLI 220	10:00	10:18	0:18	LOAD CHANGEOVER
571	4-Jul-2020	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	17:50	18:03	0:13	LOAD CHANGEOVER
572	4-Jul-2020	BENGALURU	66	HV1	YERANDANAHALLI 220	17:50	18:03	0:13	LOAD CHANGEOVER
573	4-Jul-2020	BENGALURU	66	HV2	YERANDANAHALLI 220	17:50	18:03	0:13	LOAD CHANGEOVER
574	4-Jul-2020	BENGALURU	66	HV3	YERANDANAHALLI 220	17:50	18:03	0:13	LOAD CHANGEOVER
575	4-Jul-2020	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	17:50	18:03	0:13	LOAD CHANGEOVER
576	4-Jul-2020	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	17:50	18:03	0:13	LOAD CHANGEOVER
577	4-Jul-2020	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	10:00	10:12	0:12	LOAD CHANGEOVER
578	4-Jul-2020	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	10:00	10:12	0:12	LOAD CHANGEOVER
579	4-Jul-2020	BENGALURU	66	HV2	YERANDANAHALLI 220	18:10	18:15	0:05	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
580	4-Jul-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	13:08	13:35	0:26	LINE CLEAR AVAILED
581	4-Jul-2020	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	13:08	13:35	0:26	LINE CLEAR AVAILED
582	4-Jul-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	13:08	13:34	0:25	LINE CLEAR AVAILED
583	4-Jul-2020	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	13:47	14:01	0:14	LINE CLEAR AVAILED
584	4-Jul-2020	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI 1	ELECTRONIC CITY, INFOSYS (EHT)	8:55	9:00	0:04	LOAD CHANGEOVER
585	4-Jul-2020	BENGALURU	66	PADMANABHANAGAR - SUBRAMANYAPURA 220	PADMANABHANAGAR	6:09	6:12	0:03	LOAD CHANGEOVER
586	4-Jul-2020	BENGALURU	66	HV2	NIMHANS 220	14:16	14:20	0:03	LOAD CHANGEOVER
587	4-Jul-2020	BENGALURU	66	HV1	MUDIYANUR	8:02	8:21	0:18	TRANSFORMER FAULT
588	4-Jul-2020	BENGALURU	66	HV1	AMARJYOTHI	12:48	12:50	0:01	LINE CLEAR AVAILED
589	4-Jul-2020	BENGALURU	66	HV2	BMTC	10:47	10:50	0:02	LINE CLEAR AVAILED
590	4-Jul-2020	BENGALURU	66	HV2	HANUMANTHNAGAR	2:35	2:42	0:07	TRANSFORMER FAULT
591	4-Jul-2020	BENGALURU	66	HV2	HANUMANTHNAGAR	2:48	2:53	0:05	TRANSFORMER FAULT
592	4-Jul-2020	BENGALURU	66	HV2	KUMBULGODU	12:33	12:45	0:11	LINE CLEAR AVAILED
593	4-Jul-2020	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	NO STATION AFFECTED	11:15	14:00	2:44	LINE FAULT
594	4-Jul-2020	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA, ADUGODI	10:12	10:21	0:09	LOAD CHANGEOVER
595	4-Jul-2020	BENGALURU	66	ADUGODI - JAKKASANDRA	ADUGODI, BOSCH (EHT)	8:50	9:21	0:31	LOAD CHANGEOVER
596	4-Jul-2020	BENGALURU	66	ADUGODI - JAKKASANDRA	ADUGODI, BOSCH (EHT)	15:54	15:59	0:05	LOAD CHANGEOVER
597	4-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN:LINE FAULT
598	4-Jul-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	NO STATION AFFECTED	1:45:00(25-6-2020)			LINE OPEN: LINE CLEAR AVAILED
599	4-Jul-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	NO STATION AFFECTED	1:49:00(25-6-2020)			LINE OPEN: LINE CLEAR AVAILED
600	4-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
601	4-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
602	4-Jul-2020	BENGALURU	66	NIMHANS 220 - ADUGODI	ADUGODI, BOSCH (EHT), JAKKASANDRA	13:47 (4-07-2020)			LINE OPEN:LINE FAULT
603	4-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
604	4-Jul-2020	BENGALURU	400	NELAMANGALA 400 - HIRIYUR 2	NO STATIONS AFFECTED	0:46	8:27	7:40	LOAD CURTAILMENT
605	4-Jul-2020	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	2:40(28.06.2020)			LINE OPEN: LINE CLEAR AVAILED
606	4-Jul-2020	GULBARGA	110	SIDHANOOR220-SINDHANOOR1	MASKI_110,MUDDAPUR_110	23:55	23:59	00:04	LINE FAULT
607	4-Jul-2020	GULBARGA	110	SIDHANOOR220-SINDHANOOR	MASKI_110,MUDDAPUR_110	00:55	01:05	00:10	LINE FAULT
608	4-Jul-2020	GULBARGA	110	SHAHAPUR-KEMBHAV1	KEMBHAVI_110,UGARSUGAR_IPP,H UNASAGI_110,ASKI_110	05:06	05:16	00:10	LINE FAULT
609	4-Jul-2020	GULBARGA	110	HV2	SINDHANOOR_110	12:54	13:05	00:11	TRANSFORMER FAULT
610	4-Jul-2020	GULBARGA	110	HV2	MANVI_110	12:14	12:24	00:10	TRANSFORMER FAULT
611	4-Jul-2020	GULBARGA	110	HV2	MANVI_110	16:47	16:53	00:06	TRANSFORMER FAULT
612	4-Jul-2020	GULBARGA	110	HV3	SHAHAPUR	21:12	21:32	00:20	TRANSFORMER FAULT
613	4-Jul-2020	GULBARGA	110	HV2	HALIKHED_110	16:10	19:10	03:00	LINE CLEAR AVOID
614	4-Jul-2020	GULBARGA	110	HV3	HALIKHED_110	20:20	20:28	00:08	TRANSFORMER FAULT
615	4-Jul-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT
616	4-Jul-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN: LINE CLEAR AVAILED
617	4-Jul-2020	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	15:19(02.07.2020)	15:20(04.07.2020)	0:01hrs	NFBC ISSUED
618	4-Jul-2020	GULBARGA	220	HV2	KAPANOOR_220	10:15	16:30	06:15	LINE CLEAR AVOID
619	4-Jul-2020	GULBARGA	220	MALLAT-LINGASUGUR	LINGASUGUR_220	15:20	15:48	00:28	LINE CLEAR AVOID
620	4-Jul-2020	HASSAN	66	LV1	MRSMSG_220	13:17 (26.06.2020)	11:45 (4.07.2020)	190:27 hrs	LINE CHARGED
621	4-Jul-2020	HASSAN	66	LV2	MRSMSG_220	10:24	11:45	01:21	LINE CLEAR AVOID
622	4-Jul-2020	HASSAN	66	HV2	BAGUR_66	15:28	16:04	00:36	LINE CLEAR AVOID
623	4-Jul-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	06:40	06:55	00:15	HAND TRIPPED
624	4-Jul-2020	HASSAN	66	HV2	HALEBEEDU_66	08:00	12:15	04:15	LINE CLEAR AVOID
625	4-Jul-2020	HASSAN	66	HASSN220-R R NAGAR	HASSAN_220	15:38	15:58	00:20	HAND TRIPPED
626	4-Jul-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	08:17	08:38	00:21	LINE FAULT
627	4-Jul-2020	HASSAN	66	HV1	MAGGE_66	08:18	08:40	00:22	MAIN SUPPLY FAILURE
628	4-Jul-2020	HASSAN	66	HV2	MAGGE_66	08:18	08:40	00:22	MAIN SUPPLY FAILURE
629	4-Jul-2020	HASSAN	66	SAKALE-HASSAN1	SAKLESHPUA_66	08:17	08:37	00:20	LINE FAULT
630	4-Jul-2020	HASSAN	110	HV3	NO STN AFFECTED	10:29(03.07.2020)			LINE OPEN: LINE CLEAR AVAILED
631	4-Jul-2020	HASSAN	110	HV1	MRSMSG_220	13:17 (26.06.2020)	11:45 (4.07.2020)	190:27 hrs	LINE CHARGED
632	4-Jul-2020	HASSAN	110	JOG-JLT3	mghejog_gen	22:33 (2.07.2020)	11:58 (4.07.2020)	37:24 hrs	LINE CHARGED
633	4-Jul-2020	HASSAN	110	JOG-JLT4	mghejog_gen	13:30 (2.07.2020)	12:28 (4.07.2020)	46:57 hrs	LINE CHARGED
634	4-Jul-2020	HASSAN	110	JOG110-MGHE	JOG_110	13:30(02.07.2020)	11:49 (4.07.2020)	46:18 hrs	LINE CHARGED
635	4-Jul-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	11:41	12:10	00:29	LINE CLEAR AVOID
636	4-Jul-2020	HASSAN	110	HV2	MRSMSG_220	10:24	11:45	01:21	LINE CLEAR AVOID
637	4-Jul-2020	HASSAN	110	HV1	BANTWAL_110	10:46	15:45	04:59	LINE CLEAR AVOID
638	4-Jul-2020	HASSAN	110	HV1	BANTWAL_110	16:33	17:15	00:42	LINE CLEAR AVOID
639	4-Jul-2020	HASSAN	110	GRUVA-KEMAR1	GURUVAYANAKERE_110	11:40	12:10	00:30	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
640	4-Jul-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	10:07	11:06	00:59	HAND TRIPPED
641	4-Jul-2020	HASSAN	400	HASSAN40-UPCL1	NO STN AFFECTED	20:55 (2.07.2020)			LINE OPEN: LINE CLEAR AVAILED
642	4-Jul-2020	HASSAN	400	UPCL-HASSAN1	NO STN AFFECTED	20:55 (2.07.2020)			LINE OPEN: LINE CLEAR AVAILED
643	4-Jul-2020	HASSAN	400	UPCL-HASSAN2	NO STN AFFECTED	22:02 (3.07.2020)			LINE OPEN: LINE CLEAR AVAILED
644	4-Jul-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
645	4-Jul-2020	MYSURU	66	KUSHALNAGARA 220-MERCERA-1	MADIKERI_66	4:03	4:12	0:09	LINE FAULT
646	4-Jul-2020	MYSURU	66	KUSHALNAGARA 220-MERCERA-1	MADIKERI_66	4:12	7:26	3:13	LINE FAULT
647	4-Jul-2020	MYSURU	66	KUSHALNAGARA 220-MERCERA-1	MADIKERI_66	7:26	11:54	4:28	LINE FAULT
648	4-Jul-2020	MYSURU	66	KUSHALNAGARA 220-MERCERA-1	MADIKERI_66	11:55	13:03	1:08	LINE FAULT
649	4-Jul-2020	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	MADIKERI_66SUNTIKOPPA_66	8:34	13:03	4:28	LINE CLEAR AVAILED
650	4-Jul-2020	MYSURU	66	SHIVALLI-TUBINKERE	SHIVALLY_66	11:13	11:46	0:33	LINE CLEAR AVAILED
651	4-Jul-2020	MYSURU	66	SUNTIKOPPA-MADIKERI	MADIKERI_66	4:02	13:15	9:13	LINE FAULT
652	4-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN:LINE FAULT
653	4-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020			TRANSFORMER OPEN: TRANSFORMER FAULT
654	4-Jul-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14(28.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
655	4-Jul-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,RAMAG IRI_66	23:14(03.07.2020)	11:57(04.07.2020)	24:43hrs	LINE CHARGED
656	4-Jul-2020	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	19:57(03.07.2020	02:37(04.07.2020)	28:5hrs	LINE CHARGED
657	4-Jul-2020	TUMKUR	66	TR-2	BELLAVI_66	4:25	13:13	8:48	TRANSFORMER FAULT
658	4-Jul-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	5:54	6:22	0:28	LINE FAULT
659	4-Jul-2020	TUMKUR	66	TR-2	GARAGA_66	10:40	12:31	1:51	LINE CLEAR AVAILED
660	4-Jul-2020	TUMKUR	66	TR-2	GARAGA_66	13:08	18:23	5:14	LINE CLEAR AVAILED
661	4-Jul-2020	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	12:50	16:53	4:03	LINE CLEAR AVAILED
662	4-Jul-2020	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	12:50	16:54	4:04	LINE CLEAR AVAILED
663	4-Jul-2020	TUMKUR	66	TR-2	HARIYABBE_66	12:50	17:00	4:09	LINE CLEAR AVAILED
664	4-Jul-2020	TUMKUR	66	TR-3	HARIYABBE_66	12:50	16:55	4:04	LINE CLEAR AVAILED
665	4-Jul-2020	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	5:54	6:24	0:30	MAIN SUPPLY FAILURE
666	4-Jul-2020	TUMKUR	66	TR-2	NAYAKANAHATTI_66	11:24	11:43	0:18	LINE CLEAR AVAILED
667	4-Jul-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	10:35	10:55	0:20	TRANSFORMER FAULT
668	4-Jul-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	14:43	15:54	1:11	TRANSFORMER FAULT
669	4-Jul-2020	TUMKUR	66	TR-1	PAVAGADA_66	17:39	17:53	0:14	TRANSFORMER FAULT
670	4-Jul-2020	TUMKUR	66	SIRA- KALLAMBELLA	SIRA_66	11:17	12:34	1:17	LINE CLEAR AVAILED
671	4-Jul-2020	TUMKUR	66	SIRA- KALLAMBELLA	SIRA_66	14:42	14:56	0:14	LINE FAULT
672	4-Jul-2020	TUMKUR	66	TR-2	THIMMASANDRA_66	8:01	8:25	0:24	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
673	4-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
674	4-Jul-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	12:02	12:13	0:10	LINE CLEAR AVAILED
675	4-Jul-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	15:07	16:16	1:08	LINE CLEAR AVAILED
676	4-Jul-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	12:09	14:16	2:06	LINE CLEAR AVAILED
677	4-Jul-2020	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	12:08	14:16	2:07	LINE CLEAR AVAILED
678	5-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
679	5-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
680	5-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
681	5-Jul-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
682	5-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN: LINE CLEAR AVAILED
683	5-Jul-2020	BAGALKOT	110	JAMAKHANDI-SHIROL	STATION NOT AFFECTED SHIROL_110	10:41 (24.06.2020)			LINE OPEN: LINE CLEAR AVAILED
684	5-Jul-2020	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN: LINE CLEAR AVAILED
685	5-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
686	5-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
687	5-Jul-2020	BAGALKOT	110	SIRSI 220(ESALE)-UMMACHAGI	STATION NOT AFFECTED	12:25 (03.07.2020)			LINE OPEN: LINE CLEAR AVAILED
688	5-Jul-2020	BAGALKOT	110	110/11KV,HV 2	BIJAPUR KIADB_110	10:03	10:29	0:26	LINE CLEAR AVAILED
689	5-Jul-2020	BAGALKOT	110	110/11KV,HV2A	JAMAKHANDI_110	17:25	19:09	1:44	LINE CLEAR AVAILED
690	5-Jul-2020	BAGALKOT	110	BASAVESHWAR SUGARS-MALGHAN(B)	MALGHAN(B)_110	6:41	12:58	6:17	LINE CLEAR AVAILED
691	5-Jul-2020	BAGALKOT	110	UTTUR- RANNABELAGALI	STATION NOT AFFECTED RANNABELAGALI_110	3:24	8:01	4:37	LINE FAULT
692	5-Jul-2020	BAGALKOT	110	MAREGUDDI- MUNDUGANUR	MUNDUGANUR_110	6:44	6:48	0:04	LINE FAULT
693	5-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
694	5-Jul-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
695	5-Jul-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
696	5-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
697	5-Jul-2020	BAGALKOT	220	GUTTUR- RANEENNUR	STATION NOT AFFECTED RANEENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
698	5-Jul-2020	BAGALKOT	220	220/110KV,HV 1&LV 1	BELGAUM_220	10:39	13:16	2:37	LINE CLEAR AVAILED
699	5-Jul-2020	BENGALURU	66	HV1	HANUMANTHNAGAR	10:59	12:03	1:04	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
700	5-Jul-2020	BENGALURU	66	HV2	HANUMANTHNAGAR	10:59	12:03	1:04	LINE CLEAR AVAILED
701	5-Jul-2020	BENGALURU	66	HV2	HANUMANTHNAGAR	12:06	12:17	0:11	TRANSFORMER FAULT
702	5-Jul-2020	BENGALURU	66	SURYANAGAR - YERANDANAHALLI	SURYANAGAR	19:02	19:13	0:10	LINE FAULT
703	5-Jul-2020	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	8:27	8:46	0:18	LINE FAULT
704	5-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN:LINE FAULT
705	5-Jul-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	NO STATION AFFECTED	1:45:00(25-6-2020)			LINE OPEN: LINE CLEAR AVAILED
706	5-Jul-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	NO STATION AFFECTED	1:49:00(25-6-2020)			LINE OPEN: LINE CLEAR AVAILED
707	5-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
708	5-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
709	5-Jul-2020	BENGALURU	66	NIMHANS 220 - ADUGODI	ADUGODI, BOSCH (EHT), JAKKASANDRA	13:47 (4-07-2020)			LINE OPEN:LINE FAULT
710	5-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
711	5-Jul-2020	BENGALURU	400	NELAMANGALA 400 - HIRIYUR 2	NO STATIONS AFFECTED	23:22:25(5-07-2020)			LOAD CURTAILMENT
712	5-Jul-2020	GULBARGA	66	HV1	CHORNOOR_66	09:11	09:18	00:07	TRANSFORMER FAULT
713	5-Jul-2020	GULBARGA	66	HV2	CHORNOOR_66	14:20	15:20	01:00	LINE CLEAR AVAILED
714	5-Jul-2020	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	09:07	10:10	01:03	LINE CLEAR AVAILED
715	5-Jul-2020	GULBARGA	66	HV1	HANASI_66	11:12	11:22	00:10	LINE CLEAR AVAILED
716	5-Jul-2020	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	2:40(28.06.2020)			LINE OPEN: LINE CLEAR AVAILED
717	5-Jul-2020	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110	03:20	03:30	00:10	LINE FAULT
718	5-Jul-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	03:44	03:54	00:10	LINE FAULT
719	5-Jul-2020	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	04:27	04:38	00:11	LINE FAULT
720	5-Jul-2020	GULBARGA	110	SEDAM-VICATSAGAR	VICATSAGAR_110	04:08	04:25	00:17	LINE FAULT
721	5-Jul-2020	GULBARGA	110	SIDHANOOR220-SINDHANOOR1	MASKI_110,MUDDAPUR_110	00:00	00:05	00:05	LINE FAULT
722	5-Jul-2020	GULBARGA	110	SIDHANOOR220-SINDHANOOR1	MASKI_110,MUDDAPUR_110	22:58	23:13	00:15	LINE FAULT
723	5-Jul-2020	GULBARGA	110	SIDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPS WATERWORKS	03:38	03:48	00:10	LINE FAULT
724	5-Jul-2020	GULBARGA	110	HV3	BEVOOR_110	15:01	17:14	02:13	LINE CLEAR AVAILED
725	5-Jul-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	19:38	19:49	00:11	LINE FAULT
726	5-Jul-2020	GULBARGA	110	HV2	DEODURGA_110	11:30	11:54	00:24	TRANSFORMER FAULT
727	5-Jul-2020	GULBARGA	110	HV1	KOPPAL_110	09:31	13:47	04:16	LINE CLEAR AVAILED
728	5-Jul-2020	GULBARGA	110	MASKI-HATTI	HATTI_110	09:10	12:50	03:40	LINE CLEAR AVAILED
729	5-Jul-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	12:50	13:57	01:07	LINE CLEAR AVAILED
730	5-Jul-2020	GULBARGA	110	MASKI-HATTI	HATTI_110	16:52	17:50	00:58	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
731	5-Jul-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	17:50	18:12	00:22	LINE CLEAR AVAILED
732	5-Jul-2020	GULBARGA	110	VALKAMDINNI-RAICHUR	VALKAMDINNI_110	03:25	03:35	00:10	MAIN SUPPLY FAILURE
733	5-Jul-2020	GULBARGA	110	VALKAMDINNI-RAICHUR	VALKAMDINNI_110	10:20	18:35	08:15	LINE CLEAR AVAILED
734	5-Jul-2020	GULBARGA	110	HV2	SINDHANOOR_110	21:12	21:17	00:05	TRANSFORMER FAULT
735	5-Jul-2020	GULBARGA	110	YELBURGA-PRPJ_SLR	YELBURGA_110	07:04	07:32	00:28	LINE FAULT
736	5-Jul-2020	GULBARGA	110	BETAGERA-KESHAVCEMENTS	BETAGERA_110	06:21	06:28	00:07	LINE FAULT
737	5-Jul-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT
738	5-Jul-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN: LINE CLEAR AVAILED
739	5-Jul-2020	HASSAN	66	LV1	MRSMSG_220	9:10 (5.07.2020)			LINE OPEN: LINE CLEAR AVAILED
740	5-Jul-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	6:19	6:22	0:03	TRANSFORMER FAULT
741	5-Jul-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	6:51	7:08	0:17	TRANSFORMER FAULT
742	5-Jul-2020	HASSAN	110	HV3	NO STN AFFECTED	10:29(03.07.2020)			LINE OPEN: LINE CLEAR AVAILED
743	5-Jul-2020	HASSAN	110	HV1	MRSMSG_220	9:10 (5.07.2020)			LINE OPEN: LINE CLEAR AVAILED
744	5-Jul-2020	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_110	20:30	20:32	0:02	HAND TRIPPED
745	5-Jul-2020	HASSAN	400	HASSAN40-UPCL1	SHNATHIGRAMA_400	20:55 (2.07.2020)	19:31 (5.07.2020)	70:34 hrs	LINE CHARGED
746	5-Jul-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:55 (2.07.2020)	19:31 (5.07.2020)	70:34 hrs	LINE CHARGED
747	5-Jul-2020	HASSAN	400	UPCL-HASSAN2	NO STN AFFECTED	22:02 (3.07.2020)			LINE OPEN: LINE CLEAR AVAILED
748	5-Jul-2020	HASSAN	400	HASSAN40-UPCL1	SHNATHIGRAMA_400	22:25 (5.07.2020)			LINE OPEN: LINE CLEAR AVAILED
749	5-Jul-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:25 (5.07.2020)			LINE OPEN: LINE CLEAR AVAILED
750	5-Jul-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	2:01	10:09	8:08	LINE FAULT
751	5-Jul-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
752	5-Jul-2020	MYSURU	66	AKKIEBBAL-KAVERI HYDRO	NO STATIONS EFFECTED	12:30	15:01	2:31	LINE CLEAR AVAILED
753	5-Jul-2020	MYSURU	66	DEVNUR(N'GUD)-KADAKOLA	NO STATIONS EFFECTED	7:43	10:20	2:37	LINE CLEAR AVAILED
754	5-Jul-2020	MYSURU	66	HV2	HULLAHALLI_66	15:22	16:04	0:42	LINE CLEAR AVAILED
755	5-Jul-2020	MYSURU	66	KADAKOLA-SARGUR2	DOORA_66HURA_66HULLAHALLI_66 CHANDRAVADI_66	23:40	23:46	0:06	LINE FAULT
756	5-Jul-2020	MYSURU	66	MEGALAPURA-SFC	NO STATIONS EFFECTED	11:08	11:23	0:15	HAND TRIPPED
757	5-Jul-2020	MYSURU	66	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	6:33	11:18	4:44	LINE CLEAR AVAILED
758	5-Jul-2020	MYSURU	66	MANDYA-MC-3	HAMPAPURA_66CHIKKA_MANDYA_66 KOPPA_66BESAGARAHALLI_66	12:55	13:03	0:08	LINE FAULT
759	5-Jul-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66HARADANAHALLI_66B GNAGARA_66BASARALU_66VADERA LLI_66ADICHUNCHANAGIRI_66KESLAG ERE 66	21:52	21:57	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
760	5-Jul-2020	MYSURU	220	KADAKOLA-BASTIPURA 1	NO STATIONS EFFECTED	4:22	9:45	5:23	LINE FAULT
761	5-Jul-2020	MYSURU	220	KADAKOLA-BASTIPURA2	NO STATIONS EFFECTED	4:22	7:56	3:34	LINE FAULT
762	5-Jul-2020	MYSURU	220	KADAKOLA-CR NAGARA 1	NO STATIONS EFFECTED	4:22	7:07	2:45	LINE FAULT
763	5-Jul-2020	MYSURU	220	KADAKOLA-CR NAGARA 2	NO STATIONS EFFECTED	4:22	7:41	3:19	LINE FAULT
764	5-Jul-2020	MYSURU	220	KADAKOLA-HV1	SANTHESARAGUR_66NANJANGUDU_66RKNAGARA_66MYSORESOUTH_66DEVANOORNGUDU_66	4:22	7:11	2:49	LINE FAULT
765	5-Jul-2020	MYSURU	220	KADAKOLA-HV2	SANTHESARAGUR_66NANJANGUDU_66RKNAGARA_66MYSORESOUTH_66DEVANOORNGUDU_66	4:22	7:11	2:49	LINE FAULT
766	5-Jul-2020	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	4:22	8:54	4:31	LINE FAULT
767	5-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN:LINE FAULT
768	5-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
769	5-Jul-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14(28.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
770	5-Jul-2020	TUMKUR	66	TR-1	AMMASANDRA_110	6:57	10:47	3:50	TRANSFORMER FAULT
771	5-Jul-2020	TUMKUR	66	TR-2	BENNEHALLI_66	7:54	8:01	0:06	TRANSFORMER FAULT
772	5-Jul-2020	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 1	CHITRADURGA_66	10:56	12:36	1:39	LINE CLEAR AVAILED
773	5-Jul-2020	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	CHITRADURGA_66	10:51	10:57	0:06	NFBC ISSUED
774	5-Jul-2020	TUMKUR	66	TR-1	CHITRADURGA_66	10:56	12:39	1:42	LINE CLEAR AVAILED
775	5-Jul-2020	TUMKUR	66	TR-2	CHITRADURGA_66	10:56	13:16	2:20	LINE CLEAR AVAILED
776	5-Jul-2020	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	10:16	12:57	2:40	LINE CLEAR AVAILED
777	5-Jul-2020	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 1_IPP_66	10:16	12:58	2:41	LINE CLEAR AVAILED
778	5-Jul-2020	TUMKUR	66	TR-2	GARAGA_66	10:54	11:29	0:35	LINE CLEAR AVAILED
779	5-Jul-2020	TUMKUR	66	TR-2	GARAGA_66	16:06	16:10	0:03	LINE CLEAR AVAILED
780	5-Jul-2020	TUMKUR	66	TR-3	HARIYABBE_66	11:07	12:59	1:51	TRANSFORMER FAULT
781	5-Jul-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	16:12	16:28	0:16	HAND TRIPPED
782	5-Jul-2020	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	MADHUGIRI_66	12:38	12:53	0:15	LINE FAULT
783	5-Jul-2020	TUMKUR	66	MADHUGIRI 66kV- MADHUGIRI	MADHUGIRI_66	12:38	13:00	0:22	LINE FAULT
784	5-Jul-2020	TUMKUR	66	TR-1	MATHOD_66	9:19	9:24	0:04	TRANSFORMER FAULT
785	5-Jul-2020	TUMKUR	66	TR-2	NITRAHALLI_66	20:37	21:09	0:32	TRANSFORMER FAULT
786	5-Jul-2020	TUMKUR	66	TR-1	PAVAGADA_220	21:42	21:48	0:06	TRANSFORMER FAULT
787	5-Jul-2020	TUMKUR	66	SIRA- MADHUGIRI 2	SIRA_66	16:06	16:11	0:04	LINE FAULT
788	5-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
789	06-Jul-20	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:15	15:00	2:45	LINE CLEAR AVAILED
790	06-Jul-20	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	16:25	16:36	0:11	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
791	06-Jul-20	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, AMINGAD_33, KARADI_33, SOLAR_33	6:26	6:30	0:04	TRANSFORMER FAULT
792	06-Jul-20	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, AMINGAD_33, KARADI_33, SOLAR_33	10:24	10:29	0:05	TRANSFORMER FAULT
793	06-Jul-20	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, AMINGAD_33, KARADI_33, SOLAR_33	13:10	13:15	0:05	TRANSFORMER FAULT
794	06-Jul-20	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, AMINGAD_33, KARADI_33, SOLAR_33	16:33	16:38	0:05	TRANSFORMER FAULT
795	06-Jul-20	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
796	06-Jul-20	BAGALKOT	110	ARGA-ANKOLA	ANKOLA_110	11:22	12:35	1:13	LINE CLEAR AVAILED
797	06-Jul-20	BAGALKOT	110	ATHANI220- TAUSHI(BALIGERI)	TAUSHI_110	2:07	2:23	0:16	LINE FAULT
798	06-Jul-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN: LINE CLEAR AVAILED
799	06-Jul-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
800	06-Jul-20	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN: LINE CLEAR AVAILED
801	06-Jul-20	BAGALKOT	110	JAMAKHANDI-SHIROL	STATION NOT AFFECTED SHIROL_110	10:41 (24.06.2020)			LINE OPEN: LINE CLEAR AVAILED
802	06-Jul-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
803	06-Jul-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
804	06-Jul-20	BAGALKOT	110	SIRSI 220(ESALE J)-UMMACHAGI	STATION NOT AFFECTED	12:25 (03.07.2020)			LINE OPEN: LINE CLEAR AVAILED
805	06-Jul-20	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN: LINE CLEAR AVAILED
806	06-Jul-20	BAGALKOT	110	VAJRAMATTI220- VAJRAMATTI	VAJRAMATTI_110	14:00	16:49	2:49	LINE CLEAR AVAILED
807	06-Jul-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN: LINE CLEAR AVAILED
808	06-Jul-20	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
809	06-Jul-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
810	06-Jul-20	BAGALKOT	220	BAGEWADI- BIJAPUR1 (NANDIHAL1)	BAGEWADI_220	12:23	12:40	0:17	HAND TRIPPED
811	06-Jul-20	BAGALKOT	220	GUTTUR- RANEBENNUR	STATION NOT AFFECTED RANEBENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
812	06-Jul-20	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
813	06-Jul-20	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
814	06-Jul-20	BENGALURU	66	ADUGODI - KORMANGALA 220	ADUGODI, BOSCH (EHT)	6:12	6:21	0:09	LOAD CHANGEOVER
815	06-Jul-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
816	06-Jul-20	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	16:10	16:45	0:35	LINE CLEAR AVAILED
817	06-Jul-20	BENGALURU	66	DB PURA 220 - VIJAYPURA	VIJAYPURA	10:19	16:55	6:36	LINE CLEAR AVAILED
818	06-Jul-20	BENGALURU	66	HV1	SM MANGALA	8:49	10:00	1:10	LINE CLEAR AVAILED
819	06-Jul-20	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	15:15	16:32	1:17	TRANSFORMER FAULT
820	06-Jul-20	BENGALURU	66	HV1	AMARJYOTHI	10:55	11:32	0:37	LOAD CHANGEOVER
821	06-Jul-20	BENGALURU	66	HV2	SM MANGALA	9:31	10:28	0:57	LINE CLEAR AVAILED
822	06-Jul-20	BENGALURU	66	HV2	MAHALAKSHMI LAYOUT	11:45	11:49	0:04	LINE CLEAR AVAILED
823	06-Jul-20	BENGALURU	66	JAGAMKOTE - DB PURA 220	JAGAMKOTE	10:10	10:50	0:40	LOAD CHANGEOVER
824	06-Jul-20	BENGALURU	66	JAGAMKOTE - MELUR	JAGAMKOTE	13:07	13:32	0:25	LINE CLEAR AVAILED
825	06-Jul-20	BENGALURU	66	JAGAMKOTE - MELUR	JAGAMKOTE	17:40	17:55	0:15	LOAD CHANGEOVER
826	06-Jul-20	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN:LINE FAULT
827	06-Jul-20	BENGALURU	66	MITTEMARI 220 - PATHPALYA	NO STATION AFFECTED	1:49:00(25-6-2020)			LINE OPEN: LINE CLEAR AVAILED
828	06-Jul-20	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	NO STATION AFFECTED	1:45:00(25-6-2020)			LINE OPEN: LINE CLEAR AVAILED
829	06-Jul-20	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN:LINE FAULT
830	06-Jul-20	BENGALURU	66	NIMHANS 220 - BMTc	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
831	06-Jul-20	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	NO STATION AFFECTED	10:40(6-7-2020)			LINE OPEN: LINE CLEAR AVAILED
832	06-Jul-20	BENGALURU	66	SUBRAMANYAPURA 220 - SOMANAHALLI 1	ISKON, SUBRAMANYAPURA 66	10:18	10:25	0:07	LOAD CHANGEOVER
833	06-Jul-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
834	06-Jul-20	BENGALURU	400	NELAMANGALA 400 - HIRIYUR 2	NO STATIONS AFFECTED	23:22:25(5-07-2020)	06:37:33(6-7-2020)	7:14 hrs	LOAD CURTAILMENT
835	06-Jul-20	BENGALURU	400	NELAMANGALA 400 - MYS 2	NO STATION AFFECTED	1:12	4:41	3:29	LINE FAULT
836	06-Jul-20	GULBARGA	66	ITTAGI-HANASI	HANASI_66	10:15	13:25	03:10	LINE CLEAR AVAILED
837	06-Jul-20	GULBARGA	66	ITTAGI-HANASI	HANASI_66	13:35	13:40	00:05	LINE CLEAR AVAILED
838	06-Jul-20	GULBARGA	66	KUSHTAGI-TAMBRAHALLI	TAMBRAHALLI_66	11:05	11:15	00:10	MAIN SUPPLY FAILURE
839	06-Jul-20	GULBARGA	66	KUSHTAGI-TAMBRAHALLI	TAMBRAHALLI_66	11:20	11:55	00:35	MAIN SUPPLY FAILURE
840	06-Jul-20	GULBARGA	110	KAPANOOR-MADIYAL	MADIYAL_110	19:10	19:20	00:10	LINE FAULT
841	06-Jul-20	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UUGARSUGAR_110	05:16	05:26	00:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
842	06-Jul-20	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	2:40(28.06.2020)			LINE OPEN: LINE CLEAR AVAILED
843	06-Jul-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN: LINE CLEAR AVAILED
844	06-Jul-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT
845	06-Jul-20	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	09:20	15:50	06:30	LINE CLEAR AVOIDED
846	06-Jul-20	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	12:41	18:33	05:52	LINE CLEAR AVOIDED
847	06-Jul-20	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	09:20	15:50	06:30	LINE CLEAR AVOIDED
848	06-Jul-20	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	12:41	18:33	05:52	LINE CLEAR AVOIDED
849	06-Jul-20	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	09:01	15:26	06:25	LINE CLEAR AVOIDED
850	06-Jul-20	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	17:02	17:08	00:06	MAIN SUPPLY FAILURE
851	06-Jul-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	11:12	11:56	00:44	LINE CLEAR AVOIDED
852	06-Jul-20	HASSAN	66	HV1	HALEBEEDU-66	12:41	14:43	02:02	LINE CLEAR AVOIDED
853	06-Jul-20	HASSAN	66	HV2	HOLEHONNUR_66	07:16	13:32	06:16	TRANSFORMER FAULT
854	06-Jul-20	HASSAN	66	LV1	NO STN AFFECTED	9:10 (5.07.2020)			LINE OPEN: LINE CLEAR AVAILED
855	06-Jul-20	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	19:21	19:53	00:32	LINE FAULT
856	06-Jul-20	HASSAN	110	HV1	NO STN AFFECTED	9:10 (5.07.2020)			LINE OPEN: LINE CLEAR AVAILED
857	06-Jul-20	HASSAN	110	HV1	KEMAR_220	10:33	14:45	04:12	LINE CLEAR AVOIDED
858	06-Jul-20	HASSAN	110	HV2	MOODABIDRE_110	16:11	16:41	00:30	LINE CLEAR AVOIDED
859	06-Jul-20	HASSAN	110	HV3	NO STN AFFECTED	10:29(03.07.2020)			LINE OPEN: LINE CLEAR AVAILED
860	06-Jul-20	HASSAN	110	JOG110-LPH	JOG_110	15:10	16:45	01:35	LINE CLEAR AVOIDED
861	06-Jul-20	HASSAN	110	JOG-JLT4	mghejog_gen	16:00	16:22	00:22	LINE CLEAR AVOIDED
862	06-Jul-20	HASSAN	110	KAVOOR-AMR	KAVOOR_220	10:30	12:56	02:26	LINE CLEAR AVOIDED
863	06-Jul-20	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	10:16	13:00	02:44	LINE CLEAR AVOIDED
864	06-Jul-20	HASSAN	400	HASSAN40-UPCL1	SHNATHIGRAMA_400	22:25 (5.07.2020)	11:30(6.07.2020)	13:34 hrs	LINE CHARGED
865	06-Jul-20	HASSAN	400	HASSAN40-UPCL1	SHNATHIGRAMA_400	21:49 (6.07.2020)			LINE OPEN: LINE CLEAR AVAILED
866	06-Jul-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	00:58	07:42	06:44	LINE FAULT
867	06-Jul-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:25 (5.07.2020)	11:31 (6.07.2020)	13:35 hrs	LINE CHARGED
868	06-Jul-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:50 (6.07.2020)			LINE OPEN: LINE CLEAR AVAILED
869	06-Jul-20	HASSAN	400	UPCL-HASSAN2	NO STN AFFECTED	22:02 (3.07.2020)			LINE OPEN: LINE CLEAR AVAILED
870	06-Jul-20	MYSURU	66	PGPalya	PGPalya	18:58	19:05	0:07	LINE FAULT
871	06-Jul-20	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	7:03	7:11	0:08	LINE FAULT
872	06-Jul-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN:LINE FAULT
873	06-Jul-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	2:29	15:17	12:48	LINE CLEAR AVOIDED
874	06-Jul-20	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	12:09	12:11	0:01	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
875	06-Jul-20	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	7:29	17:53	10:23	LINE CLEAR AVAILED
876	06-Jul-20	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14:44(28.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
877	06-Jul-20	TUMKUR	66	TR-1	SHYLAPURA_66	2:14	2:40	0:25	LINE CLEAR AVAILED
878	06-Jul-20	TUMKUR	66	TR-1	TUMKUR_66	12:22	12:38	0:15	TRANSFORMER FAULT
879	06-Jul-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
880	06-Jul-20	TUMKUR	66	TR-2	HARIHAR_66	12:23	13:25	1:01	LINE CLEAR AVAILED
881	06-Jul-20	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	9:31	10:05	0:33	TRANSFORMER FAULT
882	06-Jul-20	TUMKUR	66	TR-2	RANGANATHAPURA_66	2:22	4:00	1:37	LINE CLEAR AVAILED
883	06-Jul-20	TUMKUR	66	TR-3	AVAREGERE_66	5:25	5:56	0:31	TRANSFORMER FAULT
884	06-Jul-20	TUMKUR	66	TR-3	HARIYABBE_66	11:18	11:28	0:10	HAND TRIPPED
885	06-Jul-20	TUMKUR	66	TR-3	HARIYABBE_66	1:16	13:22	12:05	TRANSFORMER FAULT
886	06-Jul-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT