

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 26.07.22 TO 01.08.2022

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|----------------------------------|---|-----------------------|-----------|----------|-------------------------------------|
| 1 | 26-Jul-2022 | BAGALKOT | 220 | SIRSI-HUBLI-1 | STATION NOT AFFECTED SIRSI_220 | 19:46 (15.07.2022) | | | LINE OPEN , LINE CLEAR AVOIDED |
| 2 | 26-Jul-2022 | BAGALKOT | 220 | SIRSI-HUBLI-2 | STATION NOT AFFECTED SIRSI_220 | 19:46 (15.07.2022) | | | LINE OPEN , LINE CLEAR AVOIDED |
| 3 | 26-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED TODALBAGI_110 | 19:13 (17.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 4 | 26-Jul-2022 | BAGALKOT | 110 | TODALBAGI-SAVALAGI | TODALBAGI_110 | 18:00 (20.07.2022) | | | LINE OPEN , LINE CLEAR AVOIDED |
| 5 | 26-Jul-2022 | BAGALKOT | 110 | SIRSI-KAVALWADA | STATION NOT AFFECTED SIRSI_110 | 12:55 (22.07.2022) | | | LINE OPEN , LINE CLEAR AVOIDED |
| 6 | 26-Jul-2022 | BAGALKOT | 110 | UTTUR - F1 JAMB CB(MUDHOL) | STATION NOT AFFECTED UTTUR_110 | 9:51 (24.07.2022) | | | LINE OPEN , LINE CLEAR AVOIDED |
| 7 | 26-Jul-2022 | BAGALKOT | 220 | AMBEWADI-NAGAJHARI-2 | STATION NOT AFFECTED AMBEWADI_220 | 8:46 (26.07.2022) | | | LINE OPEN, LINE FAULT |
| 8 | 26-Jul-2022 | BAGALKOT | 110 | BAGEWADI220-CHIMMALAGI | CHIMMALAGI_LISSTATION NOT AFFECTED BAGEWADI_220 | 6:10 | 6:20 | 0:10 | LINE FAULT |
| 9 | 26-Jul-2022 | BAGALKOT | 110 | NARENDRA220-KUDHARWAD | STATION NOT AFFECTED NARENDRA_220 | 8:50 | 9:26 | 0:36 | HAND TRIPPED |
| 10 | 26-Jul-2022 | BAGALKOT | 220 | HUBLI-SIRSI-2 | STATION NOT AFFECTED HUBLI_220 | 12:15 | 13:27 | 1:12 | LINE CLEAR AVOIDED |
| 11 | 26-Jul-2022 | BAGALKOT | 110 | BAGEWADI-MUDEBIHAL | MDDEBIHAL_110 | 20:07 | 20:10 | 0:03 | LINE FAULT |
| 12 | 26-Jul-2022 | BAGALKOT | 110 | DAMBAL-MUNDARAGI | MUNDARAGI_110 | 11:50 | 13:46 | 1:56 | LINE CLEAR AVOIDED |
| 13 | 26-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | DEVAR GENNUR_110 | 8:43 | 8:57 | 0:14 | TRANSFORMER FAULT |
| 14 | 26-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | DEVAR GENNUR_110 | 9:50 | 10:04 | 6:24 | LINE CLEAR AVOIDED |
| 15 | 26-Jul-2022 | BAGALKOT | 110 | GOPANAKOPPA-MR NAGAR2 | GOPANAKOPPA_110 | 10:29 | 12:25 | 1:56 | LINE CLEAR AVOIDED |
| 16 | 26-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | KANABARGI LAY OUT_110 | 16:34 | 17:02 | 0:28 | LINE CLEAR AVOIDED |
| 17 | 26-Jul-2022 | BAGALKOT | 110 | NARENDRA-KUD DHARWAD_110 | KUD DHARWAD_110 | 8:50 | 9:33 | 0:43 | HAND TRIPPED |
| 18 | 26-Jul-2022 | BAGALKOT | 110 | KULIGOD -GAMESH | KULIGOD_110 | 21:21 | 21:29 | 0:08 | LINE FAULT |
| 19 | 26-Jul-2022 | BAGALKOT | 110 | MRUTYUNJAY NAGAR- GOPANAKOPPA | GOPANAKOPPA_110 | 10:32 | 12:25 | 1:53 | LINE CLEAR AVOIDED |
| 20 | 26-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | MUDEBIHAL_110 | 0:00 | 0:02 | 0:02 | TRANSFORMER FAULT |
| 21 | 26-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | RATTIHALI_110 | 10:48 | 14:35 | 3:47 | LINE CLEAR AVOIDED |
| 22 | 26-Jul-2022 | BAGALKOT | 110 | RON-GAMESH | RON_110 | 5:53 | 6:04 | 0:11 | LINE FAULT |
| 23 | 26-Jul-2022 | BAGALKOT | 110 | RON-GAMESH | RON_110 | 5:53 | 10:22 | 4:29 | LINE FAULT |
| 24 | 26-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV3 | HUBLI_110 | 12:43 | 14:26 | 1:43 | LINE CLEAR AVOIDED |
| 25 | 26-Jul-2022 | BAGALKOT | 110 | 110/33KV, HV4(HV2) | ZALKI_110, HALASANGI_33, DHULAKHED_33, NEVARAGI_33 | 12:47 | 12:54 | 0:07 | TRANSFORMER FAULT |
| 26 | 26-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED YARAGATTI_110 | 19:28 | 20:18 | 0:50 | TRANSFORMER FAULT |
| 27 | 26-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED UCHAGAON_110 | 11:57 | 16:09 | 4:12 | LINE CLEAR AVOIDED |
| 28 | 26-Jul-2022 | BAGALKOT | 110 | 110/33KV,HV1 | BIJJARGI_33 STATION NOT AFFECTED TIKOTA_110 | 17:25 | 17:31 | 0:06 | TRANSFORMER FAULT |
| 29 | 26-Jul-2022 | BAGALKOT | 110 | 110/33KV, HV3 | STATION NOT AFFECTED YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 30 | 26-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV1 | STATION NOT AFFECTED AMBEWADI_220 | 20:00 (09.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 31 | 26-Jul-2022 | BAGALKOT | 220 | GADAG-HARTI-1 | STATION NOT AFFECTED GADAG_220 | 10:55 (19.07.2020) | | | LINE OPEN , LINE CLEAR AVOIDED |
| 32 | 26-Jul-2022 | BAGALKOT | 220 | GADAG-HARTI-2 | STATION NOT AFFECTED GADAG_220 | 10:55 (19.07.2020) | | | LINE OPEN , LINE CLEAR AVOIDED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|---|--------------------------------------|--------------------------|-----------|----------|-------------------------------------|
| 33 | 26-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV-3 & LV3 | STATION NOT AFFECTED ATHANI_220 | 10:26 (25.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVOIDED |
| 34 | 26-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV-1 | BILAGI_110 | 17:20 | 17:50 | 0:30 | LINE CLEAR AVOIDED |
| 35 | 26-Jul-2022 | BAGALKOT | 220 | AMBEWADI-NAGAJHARI-1 | STATION NOT AFFECTED AMBEWADI_220 | 9:11 (26.07.2022) | | | LINE OPEN , LINE CLEAR AVOIDED |
| 36 | 26-Jul-2022 | BAGALKOT | 110 | BAGEWADI220-MUDDEBIHAL | MUDDEBIHAL_110 | 20:07 | 20:10 | 0:03 | LINE FAULT |
| 37 | 26-Jul-2022 | BAGALKOT | 220 | NARENDRA-BELAGAVI-2 | STATION NOT AFFECTED NARENDRA_220 | 11:09 (26.07.2022) | | | LINE OPEN , LINE CLEAR AVOIDED |
| 38 | 26-Jul-2022 | BENGALURU | 66 | MAHALAKSHMI LAYOUT - SRS PEENYA 220 | MAHALAKSHMI LAYOUT | 10:40 | 10:46 | 0:06 | LOAD CHANGE OVER |
| 39 | 26-Jul-2022 | BENGALURU | 66 | MAHALAKSHMI LAYOUT - NRS 220 | MAHALAKSHMI LAYOUT | 16:20 | 16:25 | 0:05 | LOAD CHANGE OVER |
| 40 | 26-Jul-2022 | BENGALURU | 66 | HV2 | NRS 220 | 10:38 | 10:46 | 0:08 | LINE CLEAR AVOIDED |
| 41 | 26-Jul-2022 | BENGALURU | 66 | HV1 | VIJAYANAGARA | 10:33 | 10:43 | 0:10 | LOAD CHANGE OVER |
| 42 | 26-Jul-2022 | BENGALURU | 66 | HV2 | VIJAYANAGARA | 10:33 | 10:43 | 0:10 | LOAD CHANGE OVER |
| 43 | 26-Jul-2022 | BENGALURU | 66 | HV1 | VIJAYANAGARA | 22:19 | 22:26 | 0:07 | LOAD CHANGE OVER |
| 44 | 26-Jul-2022 | BENGALURU | 66 | HV2 | VIJAYANAGARA | 22:20 | 22:27 | 0:07 | LOAD CHANGE OVER |
| 45 | 26-Jul-2022 | BENGALURU | 66 | PADMANABHANAGARA - NATIONAL COLLEGE | PADMANABHANAGARA | 5:38 | 5:42 | 0:04 | LOAD CHANGE OVER |
| 46 | 26-Jul-2022 | BENGALURU | 66 | HV2 | PADMANABHANAGARA | 12:19 | 12:21 | 0:02 | LINE CLEAR AVOIDED |
| 47 | 26-Jul-2022 | BENGALURU | 66 | HV2 | PADMANABHANAGARA | 16:21 | 16:22 | 0:01 | LOAD CHANGE OVER |
| 48 | 26-Jul-2022 | BENGALURU | 66 | T GOLLAHALLI 220 - NANGLI | NANGLI, BAIRKURU | 12:31 | 12:33 | 0:02 | LOAD CHANGE OVER |
| 49 | 26-Jul-2022 | BENGALURU | 66 | T GOLLAHALLI 220 - NANGLI | NANGLI, BAIRKURU | 13:31 | 13:33 | 0:02 | LOAD CHANGE OVER |
| 50 | 26-Jul-2022 | BENGALURU | 66 | VIDHURASHWATHA - GUNDLU KOTTUR | GUNDLU KOTTUR | 21:43 | 21:47 | 0:04 | LINE FAULT |
| 51 | 26-Jul-2022 | BENGALURU | 66 | MALLASANDRA - DALASANUR | DALASANUR, YELDUR | 11:16 | 11:37 | 0:21 | LINE CLEAR AVOIDED |
| 52 | 26-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - SIDLAGHATTA | SIDLAGHATTA, MELUR | 9:01 | 9:04 | 0:03 | LOAD CURTAILMENT |
| 53 | 26-Jul-2022 | BENGALURU | 66 | HV1 | SANKALGERE(BAIRPATNA) | 11:27 | 11:45 | 0:18 | LINE CLEAR AVOIDED |
| 54 | 26-Jul-2022 | BENGALURU | 66 | AVANI - MULBAGLU | MULBAGLU | 12:02 | 12:35 | 0:32 | LINE CLEAR AVOIDED |
| 55 | 26-Jul-2022 | BENGALURU | 66 | MULBAGLU - NANGLI | MULBAGLU | 13:32 | 13:39 | 0:07 | LOAD CHANGE OVER |
| 56 | 26-Jul-2022 | BENGALURU | 220 | EAST DIVISION COMPOUND 220 - A STATION 220 | NO STATION AFFECTED | 08:38:00(23/07/2022) | | | LINE OPEN, LINE FAULT |
| 57 | 26-Jul-2022 | GULBARGA | 400 | RTPS-MUNIRABAD | MUNIRABAD_400 | 10:04 (14.06.2022) | | | LOAD CURTAILMENT |
| 58 | 26-Jul-2022 | GULBARGA | 220 | SHAHAPUR-LINGASUGUR | SHAHAPUR_220 | 21:47 (26.07.2022) | | | LINE OPEN, LINE FAULT |
| 59 | 26-Jul-2022 | GULBARGA | 220 | SEDAM_SHAHAPUR | SEDAM_220 | 05:48(10/06/2022) | | | LINE OPEN , LINE CLEAR AVOIDED |
| 60 | 26-Jul-2022 | GULBARGA | 220 | MALLAT-RTPS | MALLAT_220 | 23:20(26.07.2022) | | | LINE OPEN, LINE FAULT |
| 61 | 26-Jul-2022 | GULBARGA | 220 | LINGASUGUR-SHAHAPUR | LINGASUGUR_220 | 21:47(26.07.2022) | | | LINE OPEN, LINE FAULT |
| 62 | 26-Jul-2022 | GULBARGA | 220 | HV2,LV2 | LINGASUGUR_220 | 5:00 | 5:33 | 0:33 | TRANSFORMER FAULT |
| 63 | 26-Jul-2022 | GULBARGA | 220 | HV2 | LINGASUGUR_220 | 12:12 | 12:20 | 0:08 | TRANSFORMER FAULT |
| 64 | 26-Jul-2022 | GULBARGA | 220 | HV1 | KAPNOOR_220 | 12:04 | 15:55 | 3:51 | LINE CLEAR AVOIDED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|-----------------------------------|---|--------------------|-----------|----------|--------------------------------|
| 65 | 26-Jul-2022 | GULBARGA | 220 | HV2 | KAPNOOR_220 | 12:04 | 15:55 | 3:51 | LINE CLEAR AVAILED |
| 66 | 26-Jul-2022 | GULBARGA | 220 | HV1 | ALIPUR_110 | 7:14 | 7:30 | 0:16 | TRANSFORMER FAULT |
| 67 | 26-Jul-2022 | GULBARGA | 220 | HV1 & LV1 | HALBARGA_220 | 6:55 | 7:07 | 0:12 | TRANSFORMER FAULT |
| 68 | 26-Jul-2022 | GULBARGA | 220 | MALLAT-RTPS | MALLAT_220 | 23:03 | 23:20 | 0:17 | LINE FAULT |
| 69 | 26-Jul-2022 | GULBARGA | 220 | MALLAT-RTPS | MALLAT_220 | 23:03 | 23:20 | 0:17 | LINE FAULT |
| 70 | 26-Jul-2022 | GULBARGA | 220 | LINGASUGUR-RTPS2 | LINGASUGUR_220 | 20:47 | 21:05 | 0.0125 | LINE FAULT |
| 71 | 26-Jul-2022 | GULBARGA | 220 | MALLAT-RTPS | RTPS_220 | 2:44 | 3:29 | 0:45 | LINE FAULT |
| 72 | 26-Jul-2022 | GULBARGA | 220 | KAPNOOR-HUMNABAD1 | HUMNABAD1_220 | 1:40 | 7:20 | 5:40 | LINE CLEAR AVAILED |
| 73 | 26-Jul-2022 | GULBARGA | 220 | KAPNOOR-SHAHABAD2 | KAPNOOR_220 | 7:15 | 7:28 | 0:13 | LINE FAULT |
| 74 | 26-Jul-2022 | GULBARGA | 220 | SEDAM-RTPS_2 | SEDAM_220 | 4:27 | 6:09 | 1:42 | LINE FAULT |
| 75 | 26-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR1 | JEWARGI_110 | 12:15(15/06/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 76 | 26-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR2 | NALWAR_110 | 15:10(14/06/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 77 | 26-Jul-2022 | GULBARGA | 110 | HUMNABAD-HALLIKHED | HALLIKHED_110 | 9:34(20/07/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 78 | 26-Jul-2022 | GULBARGA | 110 | HUMNABAD-HALBARGA | HALBARGA_110 | 3:54(20/07/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 79 | 26-Jul-2022 | GULBARGA | 110 | HALBARGA-BHALKI | BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP | 06:55 (26/07/2022) | | | LINE OPEN, LINE FAULT |
| 80 | 26-Jul-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVIAMARESHWARA_110,MANVI_110 | 23:51(26.07.2022) | | | LINE OPEN, LINE FAULT |
| 81 | 26-Jul-2022 | GULBARGA | 110 | HV1 | KONKAL_110 | 3:30 | 3:55 | 0:25 | TRANSFORMER FAULT |
| 82 | 26-Jul-2022 | GULBARGA | 110 | HV1 | ADAVI AMARESHWAR_110 | 7:55 | 9:50 | 1:55 | LINE CLEAR AVAILED |
| 83 | 26-Jul-2022 | GULBARGA | 110 | HV3 | KUSTAGI_220 | 21:00 | 21:15 | 0:15 | TRANSFORMER FAULT |
| 84 | 26-Jul-2022 | GULBARGA | 110 | HV3 | KUSTAGI_220 | 21:51 | 22:03 | 0:12 | LINE CLEAR AVAILED |
| 85 | 26-Jul-2022 | GULBARGA | 110 | LV1 | LINGASUGUR_220 | 5:00 | 5:12 | 0:12 | TRANSFORMER FAULT |
| 86 | 26-Jul-2022 | GULBARGA | 110 | MUDDAPURA-MASKI | MASKI_110,HATTI_110 | 0:05 | 0:15 | 0:10 | LINE FAULT |
| 87 | 26-Jul-2022 | GULBARGA | 110 | MUDDAPURA-SINDHANOOR | MUDDAPUR_110,MASKI_110,HATTI_110 | 20:59 | 21:05 | 0:06 | LINE FAULT |
| 88 | 26-Jul-2022 | GULBARGA | 110 | MASKI-SINDHANOOR | MASKI_110,HATTI_110 | 20:30 | 20:35 | 0:05 | LINE FAULT |
| 89 | 26-Jul-2022 | GULBARGA | 110 | MASKI-SINDHANOOR | MASKI_110,HATTI_110 | 4:58 | 5:05 | 0:07 | MAIN SUPPLY FAILURE |
| 90 | 26-Jul-2022 | GULBARGA | 110 | HV1 | NIRNA_110 | 2:08 | 2:12 | 0:04 | TRANSFORMER FAULT |
| 91 | 26-Jul-2022 | GULBARGA | 110 | AURAD-SANTHAPUR | AURAD_110,DONGARGOA_110 | 6:55 | 7:00 | 0:05 | MAIN SUPPLY FAILURE |
| 92 | 26-Jul-2022 | GULBARGA | 110 | AURAD-SANTHAPUR | AURAD_110,DONGARGOA_110 | 21:20 | 21:30 | 0:10 | MAIN SUPPLY FAILURE |
| 93 | 26-Jul-2022 | GULBARGA | 110 | YARADONA- GANAGAVATHI(SULEKAL) | YARADONA_110 | 3:55 | 4:05 | 0:10 | MAIN SUPPLY FAILURE |
| 94 | 26-Jul-2022 | GULBARGA | 110 | YARADONA- GANAGAVATHI(SULEKAL) | YARADONA_110 | 19:45 | 19:53 | 0:08 | MAIN SUPPLY FAILURE |
| 95 | 26-Jul-2022 | GULBARGA | 110 | NANDUR-GULBARGA UNIVERCITY | GULBARGA UNIVERCITY_110 | 9:41 | 9:46 | 0:05 | LINE FAULT |
| 96 | 26-Jul-2022 | GULBARGA | 110 | CHOWDAPUR-AFZALPUR | AFZALPUR_110 | 8:10 | 8:15 | 0:05 | LINE FAULT |
| 97 | 26-Jul-2022 | GULBARGA | 110 | GATTHARAGA-SHAHABAD | GATTHARAGA_110, AFZALPUR_110 | 4:22 | 4:26 | 0:04 | LINE FAULT |
| 98 | 26-Jul-2022 | GULBARGA | 110 | GATTHARAGA-SHAHABAD | GATTHARAGA_110, AFZALPUR_110 | 5:30 | 5:32 | 0:02 | LINE FAULT |
| 99 | 26-Jul-2022 | GULBARGA | 110 | GATTHARAGA-SHAHABAD | GATTHARAGA_110, AFZALPUR_110 | 19:42 | 19:45 | 0:03 | LINE FAULT |
| 100 | 26-Jul-2022 | GULBARGA | 110 | GULBARGA WEST-GULBARGA SOUTH 1 | GULBARGA SOUTH_110 | 6:43 | 8:09 | 1:26 | LINE FAULT |
| 101 | 26-Jul-2022 | GULBARGA | 110 | GULBARGA WEST-GULBARGA SOUTH 2 | GULBARGA SOUTH_110 | 6:43 | 7:00 | 0:17 | LINE FAULT |
| 102 | 26-Jul-2022 | GULBARGA | 110 | HATTI-SINDHANOOR | HATTI_110,KAVITHAL_110 | 20:04 | 20:15 | 0:11 | LINE FAULT |
| 103 | 26-Jul-2022 | GULBARGA | 110 | GURMITKAL-KONKAL | KONKAL_110 | 12:40 | 12:45 | 0:05 | LINE FAULT |
| 104 | 26-Jul-2022 | GULBARGA | 110 | GANDHINAGAR-TURVIHAL | TURVIHAL_110 | 1:13 | 1:18 | 0:05 | LINE FAULT |
| 105 | 26-Jul-2022 | GULBARGA | 110 | GANDHINAGAR-TURVIHAL | TURVIHAL_110 | 4:25 | 4:30 | 0:05 | LINE FAULT |
| 106 | 26-Jul-2022 | GULBARGA | 110 | HUNSAGI-KEMBHAVI | HUNASAGI_110 | 19:45 | 20:00 | 0:15 | MAIN SUPPLY FAILURE |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|-------------------------|--|---------|-----------|----------|---------------------|
| 107 | 26-Jul-2022 | GULBARGA | 110 | YAKATPUR-KAMTHANA | YAKATPUR_110 | 5:35 | 18:05 | 12:30 | MAIN SUPPLY FAILURE |
| 108 | 26-Jul-2022 | GULBARGA | 110 | SHAHAPUR-KHANAPUR | KHANAPUR_110,WADIGERA_110,SDAIDHAPUR_110,SANATHI_IPP,CORE GREEN SUGAR_IPP,YADGIR_110,SAIDAPUR_110 | 5:55 | 6:00 | 0:05 | LINE FAULT |
| 109 | 26-Jul-2022 | GULBARGA | 110 | SHAHAPUR-KHANAPUR | KHANAPUR_110,WADIGERA_110,SDAIDHAPUR_110,SANATHI_IPP,CORE GREEN SUGAR_IPP,YADGIR_110,SAIDAPUR_110 | 6:45 | 6:50 | 0:05 | LINE FAULT |
| 110 | 26-Jul-2022 | GULBARGA | 110 | SHAHAPUR-KHANAPUR | KHANAPUR_110,WADIGERA_110,SDAIDHAPUR_110,SANATHI_IPP,CORE GREEN SUGAR_IPP,YADGIR_110,SAIDAPUR_110 | 15:04 | 19:02 | 3:58 | LINE CLEAR AVAILED |
| 111 | 26-Jul-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | YADGIR_110,SAIDAPUR_110 | 20:23 | 20:29 | 0:06 | LINE FAULT |
| 112 | 26-Jul-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | YADGIR_110,SAIDAPUR_110 | 20:54 | 21:00 | 0:06 | LINE FAULT |
| 113 | 26-Jul-2022 | GULBARGA | 110 | SHAHAPUR-SHAHAPUR_1 | SHAHAPUR_110,NALWAR_110,JEWARGI_110 | 20:33 | 20:41 | 0:08 | LINE FAULT |
| 114 | 26-Jul-2022 | GULBARGA | 110 | SHAHAPUR-KBJNL | KBJNL_110 | 21:22 | 21:28 | 0:06 | LINE FAULT |
| 115 | 26-Jul-2022 | GULBARGA | 110 | SINDHNOOR-VALABELLARI | MANVI_110,MADLAPUR_110,KURDICROSS_110, ADVIAMRESHWAR_110,JAWALGERA_110 | 5:42 | 5:52 | 0:10 | LINE FAULT |
| 116 | 26-Jul-2022 | GULBARGA | 110 | SEDAM-CHINCHOLI | CHINCHOLI_110 | 1:41 | 1:50 | 0:09 | LINE FAULT |
| 117 | 26-Jul-2022 | GULBARGA | 110 | SEDAM-CHINCHOLI | CHINCHOLI_110 | 3:55 | 4:05 | 0:10 | LINE FAULT |
| 118 | 26-Jul-2022 | GULBARGA | 110 | SEDAM-KURKUNTA | KURKUNTA_110 | 5:55 | 6:15 | 0:20 | LINE FAULT |
| 119 | 26-Jul-2022 | GULBARGA | 110 | SEDAM-KURKUNTA | KURKUNTA_110 | 12:50 | 15:02 | 2:12 | LINE CLEAR AVAILED |
| 120 | 26-Jul-2022 | GULBARGA | 110 | SEDAM-CHITTAPUR | CHITTAPUR_110,KORWAR TEMPLE_110 | 22:15 | 22:20 | 0:05 | LINE FAULT |
| 121 | 26-Jul-2022 | GULBARGA | 110 | SEDAM-CHITTAPUR | CHITTAPUR_110,KORWAR TEMPLE_110 | 22:30 | 22:35 | 0:05 | LINE CLEAR AVAILED |
| 122 | 26-Jul-2022 | GULBARGA | 110 | HALBARGA-SANTAPUR | SANTAPUR_110,DONGARGOAN_110,DIGGI_110 | 4:52 | 4:58 | 0:06 | LINE FAULT |
| 123 | 26-Jul-2022 | GULBARGA | 110 | HALBARGA-SANTAPUR | SANTAPUR_110,DONGARGOAN_110,DIGGI_110 | 5:50 | 5:59 | 0:09 | LINE FAULT |
| 124 | 26-Jul-2022 | GULBARGA | 110 | SHAHAPUR-KHANAPUR | KHANAPUR_110,WADIGERA_110,SDAIDHAPUR_110,SANATHI_IPP,CORE GREEN SUGAR_IPP,YADGIR_110,SAIDAPUR_110 | 21:56 | 22:03 | 0:07 | LINE FAULT |
| 125 | 26-Jul-2022 | GULBARGA | 110 | NEELGUNDA-HARAPANAHALLI | HARAPANAHALLI_110 | 6:48 | 6:59 | 0:11 | LINE FAULT |
| 126 | 26-Jul-2022 | GULBARGA | 110 | SULEKAL-MARALIHALLI | MUKUNDA_110, YEREDONA_110,BENNUR SOLAR_IPP | 3:56 | 4:04 | 0:08 | LINE FAULT |
| 127 | 26-Jul-2022 | GULBARGA | 110 | SULEKAL-MARALIHALLI | MUKUNDA_110, YEREDONA_110,BENNUR SOLAR_IPP | 19:43 | 19:53 | 0:10 | LINE FAULT |
| 128 | 26-Jul-2022 | GULBARGA | 110 | SULEKAL-MALLAPUR | MALLAPUR_110 | 16:20 | 16:40 | 0:20 | LINE FAULT |
| 129 | 26-Jul-2022 | GULBARGA | 110 | HUMNABAD-ALAND | ALAND_110,KADAGANCHI_110 | 0:14 | 0:17 | 0:03 | LINE FAULT |
| 130 | 26-Jul-2022 | GULBARGA | 110 | HUMNABAD-ALAND | ALAND_110,KADAGANCHI_110 | 2:32 | 2:35 | 0:03 | LINE FAULT |
| 131 | 26-Jul-2022 | GULBARGA | 110 | HUMNABAD-CHITAGUPPA | CHITAGUPPA_110, NIRNA_110 | 9:08 | 9:13 | 0:05 | LINE FAULT |
| 132 | 26-Jul-2022 | GULBARGA | 110 | SHAHABAD-FARATHABAD | FARTHABAD_110,GULBARGA SOUTH_110 | 7:45 | 15:08 | 7:23 | LINE CLEAR AVAILED |
| 133 | 26-Jul-2022 | GULBARGA | 110 | SHAHABAD-BAGEWADI1 | MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110 | 8:45 | 12:10 | 3:25 | LINE CLEAR AVAILED |
| 134 | 26-Jul-2022 | GULBARGA | 110 | SHAHABAD-FARATHABAD | FARTHABAD_110,GULBARGA SOUTH_110 | 16:39 | 20:19 | 3:40 | LINE CLEAR AVAILED |
| 135 | 26-Jul-2022 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR_110 | 19:41 | 19:49 | 0:08 | LINE FAULT |
| 136 | 26-Jul-2022 | GULBARGA | 110 | SHAHABAD-BAGEWADI2 | YADRAMI_110,MORATAGI_110 | 1:58 | 2:05 | 0:35 | LINE FAULT |
| 137 | 26-Jul-2022 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR_110 | 4:30 | 4:38 | 0:08 | LINE FAULT |
| 138 | 26-Jul-2022 | GULBARGA | 110 | SHAHABAD-FARATHABAD | FARTHABAD_110,GULBARGA SOUTH_110 | 6:35 | 6:44 | 0:09 | LINE FAULT |
| 139 | 26-Jul-2022 | GULBARGA | 110 | SHAHABAD-BAGEWADI2 | YADRAMI_110,MORATAGI_110 | 6:18 | 6:23 | 0:35 | LINE FAULT |
| 140 | 26-Jul-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVIAMARESHWARA_110,MANVI_110 | 0:24 | 0:34 | 0:10 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|-----------------------------|--|-------------------|-----------------------|------------|--------------------------------|
| 141 | 26-Jul-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVIAMARESHWARA_110,MANVI_110 | 1:05 | 1:09 | 0:04 | LINE FAULT |
| 142 | 26-Jul-2022 | GULBARGA | 110 | MALLAT-KONDAPURAM SOLAR_IPP | MALLAT_220 | 19:36 | 22:10 | 2:34 | LINE CLEAR AVAILED |
| 143 | 26-Jul-2022 | GULBARGA | 110 | LINGASUGUR-HATTI | HATTI_110 | 20:04 | 20:12 | 0:08 | LINE FAULT |
| 144 | 26-Jul-2022 | GULBARGA | 66 | HV2 | BENNEHALLI_66 | 7:45 | 7:50 | 0:05 | TRANSFORMER FAULT |
| 145 | 26-Jul-2022 | GULBARGA | 66 | HV1 | CHORNOOR_66 | 15:05 | 15:40 | 0:35 | LINE CLEAR AVAILED |
| 146 | 26-Jul-2022 | GULBARGA | 66 | HV3 | KUDLIGI_66 | 4:05 | 4:37 | 0:32 | TRANSFORMER FAULT |
| 147 | 26-Jul-2022 | GULBARGA | 66 | HV1 | KUDLIGI_66 | 8:25 | 9:15 | 0:50 | LINE CLEAR AVAILED |
| 148 | 26-Jul-2022 | GULBARGA | 66 | HV3 | KUDLIGI_66 | 18:55 | 19:45 | 0:50 | LINE CLEAR AVAILED |
| 149 | 26-Jul-2022 | GULBARGA | 66 | HV1 | HARAPANAHALLI_66 | 16:40 | 16:50 | 0:10 | LINE CLEAR AVAILED |
| 150 | 26-Jul-2022 | GULBARGA | 66 | BADELADAKU(KUDLIGI)-KUDLIGI | KUDLIGI_66,HANSI_66,KOGALI_66 | 4:05 | 4:35 | 0:30 | LINE FAULT |
| 151 | 26-Jul-2022 | GULBARGA | 66 | BADELADAKU(KUDLIGI)-KUDLIGI | KUDLIGI_66,HANSI_66,KOGALI_66 | 19:00 | 19:35 | 0:35 | LINE CLEAR AVAILED |
| 152 | 26-Jul-2022 | GULBARGA | 66 | ITTAGI-HIREHADAGALI_2 | HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66, SOVENHALLI_66, TUNGA BHADRA_IPP | 23:10 | 23:20 | 0:10 | LINE FAULT |
| 153 | 26-Jul-2022 | GULBARGA | 66 | NEELGUNDA-HALAVAGALU | HALAVAGALU_66 | 16:40 | 17:20 | 0:40 | LINE CLEAR AVAILED |
| 154 | 26-Jul-2022 | GULBARGA | 66 | UJJAINI-BREIPL_IPP | UJJANI_66 | 12:36 | 14:02 | 1:26 | LINE CLEAR AVAILED |
| 155 | 26-Jul-2022 | GULBARGA | 66 | UJJAINI-BREIPL_IPP | UJJANI_66 | 14:07 | 15:15 | 1:08 | LINE CLEAR AVAILED |
| 156 | 26-Jul-2022 | GULBARGA | 66 | UJJAINI-BREIPL_IPP | UJJANI_66 | 15:55 | 16:50 | 0:55 | LINE CLEAR AVAILED |
| 157 | 26-Jul-2022 | GULBARGA | 66 | UJJAINI-BREIPL_IPP | UJJANI_66 | 16:52 | 17:13 | 0:21 | LINE CLEAR AVAILED |
| 158 | 26-Jul-2022 | GULBARGA | 66 | HALVAGALU-NEELAGUNDA | HALVAGALU_66 | 16:40 | 17:20 | 0:40 | LINE CLEAR AVAILED |
| 159 | 26-Jul-2022 | GULBARGA | 66 | KUDLIGI-ITTAGGI | KUDLIGI_66,BANVEKAL_66,CHORNOOR_66,GUD EKOTE_66 | 7:55 | 8:25 | 0:30 | LINE CLEAR AVAILED |
| 160 | 26-Jul-2022 | GULBARGA | 66 | KUDLIGI-HANASI | HANASI_66 | 7:36 | 8:25 | 0:49 | LINE CLEAR AVAILED |
| 161 | 26-Jul-2022 | GULBARGA | 66 | KUDLIGI-ITTAGGI | KUDLIGI_66,BANVEKAL_66,CHORNOOR_66,GUD EKOTE_66 | 18:55 | 19:35 | 0:40 | LINE CLEAR AVAILED |
| 162 | 26-Jul-2022 | GULBARGA | 66 | KUDLIGI-HANASI | HANASI_66 | 18:55 | 19:35 | 0:40 | LINE CLEAR AVAILED |
| 163 | 26-Jul-2022 | GULBARGA | 66 | KUDLIGI-ITTAGGI | KUDLIGI_66,BANVEKAL_66,CHORNOOR_66,GUD EKOTE_66 | 18:55 | 19:35 | 0:40 | LINE CLEAR AVAILED |
| 164 | 26-Jul-2022 | HASSAN | 220 | CRPATNA-HSN400 | CRPATNA_220 | 13:34(15.07.2022) | | | LINE OPEN, LINE FAULT |
| 165 | 26-Jul-2022 | HASSAN | 66 | CHANNAR-MALLALI | CHANNARAYAPATNA_66 | 12:26(22.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 166 | 26-Jul-2022 | HASSAN | 110 | HV3 | JOG_110 | 10:55(05.04.2022) | 12:55(26.07.20 22) | 2690:00HRS | TRANSFORMER CHARGED |
| 167 | 26-Jul-2022 | HASSAN | 220 | KEMAR-Varahi1 | KEMAR_220 | 11:46 | 14:24 | 2:38 | LINE CLEAR AVAILED |
| 168 | 26-Jul-2022 | HASSAN | 220 | MRSSHM-KBCRS | MRSMSG_110 | 10:18 | 15:28 | 5:10 | LINE CLEAR AVAILED |
| 169 | 26-Jul-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY4 | MRSMSG_110 | 10:35 | 11:24 | 0:49 | LINE FAULT |
| 170 | 26-Jul-2022 | HASSAN | 220 | HV2 | PUTTUR_220 | 11:23 | 15:15 | 3:52 | LINE CLEAR AVAILED |
| 171 | 26-Jul-2022 | HASSAN | 220 | SHRAVTY-SHIMOGA4 | sharavathy_gen | 10:35 | 11:24 | 0:49 | LINE FAULT |
| 172 | 26-Jul-2022 | HASSAN | 220 | VARAHI-KEMAR1 | varahi_gen | 11:46 | 14:25 | 2:39 | NFBC ISSUED |
| 173 | 26-Jul-2022 | HASSAN | 110 | JOG-JLT3 | mghejog_gen | 15:29 | 16:01 | 0:32 | LINE FAULT |
| 174 | 26-Jul-2022 | HASSAN | 110 | HV2 | KARAYA_110 | 7:12 | 17:51 | 10:39 | LINE CLEAR AVAILED |
| 175 | 26-Jul-2022 | HASSAN | 110 | KAVOOR-KVR KONJE | KAVOOR_220 | 8:04 | 19:15 | 11:11 | LINE CLEAR AVAILED |
| 176 | 26-Jul-2022 | HASSAN | 110 | KAVOOR-GURUPURA | KAVOOR_220 | 11:23 | 12:46 | 1:23 | LINE CLEAR AVAILED |
| 177 | 26-Jul-2022 | HASSAN | 110 | LPH-MGHE 1 | lph_gen | 15:29 | 16:00 | 0:31 | LINE FAULT |
| 178 | 26-Jul-2022 | HASSAN | 220 | MSEZ-KAVRBAJP1 | MSEZ_220 | 11:48 | 12:19 | 0:31 | LINE FAULT |
| 179 | 26-Jul-2022 | HASSAN | 220 | MSEZ-KAVRBAJP2 | MSEZ_220 | 11:48 | 12:19 | 0:31 | LINE FAULT |
| 180 | 26-Jul-2022 | HASSAN | 220 | MSEZ-KAVRBAJP1 | MSEZ_220 | 12:37 | 14:47 | 2:10 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|--------------------------------|--|--------------------------|-----------|----------|-------------------------------------|
| 181 | 26-Jul-2022 | HASSAN | 220 | MSEZ-KAVRBAJP2 | MSEZ_220 | 12:37 | 14:47 | 2:10 | LINE FAULT |
| 182 | 26-Jul-2022 | HASSAN | 110 | LV2 | PUTTUR_220 | 11:23 | 15:15 | 3:52 | LINE CLEAR AVAIED |
| 183 | 26-Jul-2022 | HASSAN | 110 | SALATHU-BNTWAL | SALATHUR_110 | 12:53 | 15:59 | 3:06 | NFBC ISSUED |
| 184 | 26-Jul-2022 | HASSAN | 110 | SHRLKP-BARANG | SHIRALKOPPA_220 | 11:27 | 18:42 | 7:15 | LINE CLEAR AVAIED |
| 185 | 26-Jul-2022 | HASSAN | 66 | CRPATNA2-MATTANAVILE | CRPATNA_220 | 14:26 | 14:36 | 0:10 | LINE FAULT |
| 186 | 26-Jul-2022 | HASSAN | 66 | HV1 | DODDAHALLI_66 | 13:03 | 13:17 | 0:14 | MAIN SUPPLY FAILURE |
| 187 | 26-Jul-2022 | HASSAN | 66 | HV2 | RAMESHWARNAGARA_66 | 16:36 | 16:58 | 0:22 | LINE CLEAR AVAIED |
| 188 | 26-Jul-2022 | HASSAN | 66 | UDAYAP-SHANTIGRAMA | UDAYAPURA_66 | 9:00 | 18:35 | 9:35 | LINE CLEAR AVAIED |
| 189 | 26-Jul-2022 | MYSURU | 220 | KADAKOLA-KOZIKODE | NO STATIONS EFFECTED | 9:42 | 17:48 | 8:06 | NFBC ISSUED |
| 190 | 26-Jul-2022 | MYSURU | 66 | KIADB MANDYA-TUMBEKERE | TUMBEKERE_66 | 14:52 | 16:39 | 1:47 | LINE CLEAR AVAIED |
| 191 | 26-Jul-2022 | MYSURU | 66 | HV2 | KMDODDI_66 | 10:20 | 17:32 | 7:11 | LINE CLEAR AVAIED |
| 192 | 26-Jul-2022 | MYSURU | 66 | HV2 | KMDODDI_66 | 17:34 | 17:59 | 0:25 | HAND TRIPPED |
| 193 | 26-Jul-2022 | MYSURU | 66 | PERIAPATNA -HANGODU | HANAGODU_66 PONNAMPET_66 VIRAJPET_66 | 12:11 | 12:24 | 0:13 | LINE FAULT |
| 194 | 26-Jul-2022 | MYSURU | 66 | HV1 | TERAKANAMBE_66 | 12:21 | 13:53 | 1:32 | LINE CLEAR AVAIED |
| 195 | 26-Jul-2022 | MYSURU | 66 | HV2 | TERAKANAMBE_66 | 13:53 | 18:46 | 4:52 | LINE CLEAR AVAIED |
| 196 | 26-Jul-2022 | MYSURU | 66 | TUBINKERE-G UKKADA | SRIRANGAPATNA_66 GARUDANAUKADDA_66 | 15:41 | 15:46 | 0:05 | LINE FAULT |
| 197 | 26-Jul-2022 | MYSURU | 220 | VAJAMANGALA-TKHALLI | NO STATIONS EFFECTED | 14:39 | 17:09 | 2:30 | LINE CLEAR AVAIED |
| 198 | 26-Jul-2022 | MYSURU | 66 | KOPPA-NSL SUGARS | NO STATIONS EFFECTED | 3:51 | 4:12 | 0:21 | LINE FAULT |
| 199 | 26-Jul-2022 | MYSURU | 66 | CHINAKURLI-BOOKANAKERE | CHINAKURALI_66 | 12:53 | 13:25 | 0:32 | LINE CLEAR AVAIED |
| 200 | 26-Jul-2022 | MYSURU | 66 | HV1 | GUNDLUPETE_66 | 17:02:00(12.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAIED |
| 201 | 26-Jul-2022 | MYSURU | 220 | HV2 | MADHUVANAHALLI_220 | 18:57:18 (31.5.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 202 | 26-Jul-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 18:26:00 (22/04/2022) | | | LINE OPEN , LINE CLEAR AVAIED |
| 203 | 26-Jul-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16:00(08/12/2021) | | | LINE OPEN , LINE CLEAR AVAIED |
| 204 | 26-Jul-2022 | MYSURU | 220 | HV1 | KADAKOLA_220 | 1:41:14 (21/07/2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAIED |
| 205 | 26-Jul-2022 | TUMKUR | 220 | DAVANGERE SRS- GUTTUR-1 | DAVANGERE_SRS_220 | 08:02(22.07.2022) | | | LINE OPEN , LINE CLEAR AVAIED |
| 206 | 26-Jul-2022 | TUMKUR | 66 | NARENDRA LINE-1-GUTTUR | GUTTUR_400 | 00:01(23.07.2022) | | | LOAD CURTAILMENT |
| 207 | 26-Jul-2022 | TUMKUR | 66 | GUTTUR_400DAVANGERE LINE -1 | GUTTUR_400 | 00:08(23.07.2022) | | | LINE OPEN , LINE CLEAR AVAIED |
| 208 | 26-Jul-2022 | TUMKUR | 220 | TR2 | KBCROSS | 17:28(23.07.22) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 209 | 26-Jul-2022 | TUMKUR | 220 | KB CROSS 220kV- SHIMOGA1 | KBCROSS_220 | 10:10 | 15:30 | 5:20 | LINE CLEAR AVAIED |
| 210 | 26-Jul-2022 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- BELLAVI | BELLAVI_66,MALLASANDRA_66, HEGGERE_66, DODDASARANGI_66 | 19:01 | 19:30 | 0:29 | LINE FAULT |
| 211 | 26-Jul-2022 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- KORA | KORA_66, BRAKMASANDRA_66,THOVINAKERE_66,ANKASA NDRA_66 | 18:38 | 18:50 | 0:12 | LINE FAULT |
| 212 | 26-Jul-2022 | TUMKUR | 66 | HONNALLI 220KV- NYAMATHI | CHILLUR_66, NYAMATHI_66, SAVALANGA_66 | 6:53 | 7:03 | 0:10 | LINE FAULT |
| 213 | 26-Jul-2022 | TUMKUR | 220 | TR1 | HONNALI_220 | 13:08 | 14:45 | 1:37 | LINE CLEAR AVAIED |
| 214 | 26-Jul-2022 | TUMKUR | 220 | TR2 | HONNALI_220 | 14:44 | 16:53 | 2:09 | LINE CLEAR AVAIED |
| 215 | 26-Jul-2022 | TUMKUR | 66 | MADHUGIRI 220kV- KORATAGERE 2 | KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66 | 22:05 | 22:12 | 0:07 | LOAD CURTAILMENT |
| 216 | 26-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- HARIHARA | HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66 | 17:17 | 17:19 | 0:02 | LINE CLEAR AVAIED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|---------------------------------|--|-----------------------|-----------------------|----------|-------------------------------------|
| 217 | 26-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- KUKKAWADA | KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66 | 17:16 | 17:17 | 0:01 | LINE CLEAR AVAILED |
| 218 | 26-Jul-2022 | TUMKUR | 66 | HIRIYUR 220KV-PARSHAMPURA_66 | HIRIYUR_220 | 7:48 | 10:07 | 2:19 | LINE FAULT |
| 219 | 26-Jul-2022 | TUMKUR | 66 | HOLALKERE- RAMGIRI 1 | HOLALKERE_66 | 9:10 | 9:15 | 0:05 | LINE FAULT |
| 220 | 26-Jul-2022 | TUMKUR | 66 | TR2 | HOLALKERE_66 | 20:30 | 20:40 | 0:10 | TRANSFORMER FAULT |
| 221 | 26-Jul-2022 | TUMKUR | 66 | TR2 | URDIGERE_66 | 9:05 | 12:55 | 3:50 | LINE CLEAR AVAILED |
| 222 | 26-Jul-2022 | TUMKUR | 66 | NAGALAMADIKE-MADHUGIRI | NAGALMADIKE_66 | 15:55 | 16:50 | 0:55 | LINE CLEAR AVAILED |
| 223 | 26-Jul-2022 | TUMKUR | 66 | TR2 | BENKIKERE | 11:55 | 12:00 | 0:05 | HAND TRIPPED |
| 224 | 26-Jul-2022 | TUMKUR | 66 | TR1 | NITTARAHALLI | 17:55 | 18:10 | 0:15 | LINE CLEAR AVAILED |
| 225 | 26-Jul-2022 | TUMKUR | 66 | TR2 | NITTARAHALLI | 15:50 | 16:00 | 0:10 | LINE CLEAR AVAILED |
| 226 | 26-Jul-2022 | TUMKUR | 66 | TR2 | SASUVEHALLI_66 | 12:00 | 15:10 | 3:10 | LINE CLEAR AVAILED |
| 227 | 26-Jul-2022 | TUMKUR | 66 | TR2 | KADDAJJI_66 | 9:10 | 9:20 | 0:10 | TRANSFORMER FAULT |
| 228 | 26-Jul-2022 | TUMKUR | 66 | TR2 | KADDAJJI_66 | 12:20 | 13:55 | 1:35 | LINE CLEAR AVAILED |
| 229 | 26-Jul-2022 | TUMKUR | 66 | SSHTY SOLAR | RAMPURA_66 | 6:40 | 7:30 | 0:50 | LINE CLEAR AVAILED |
| 230 | 27-Jul-2022 | BAGALKOT | 220 | SIRSI-HUBLI-1 | STATION NOT AFFECTED SIRSI_220 | 19:46 (15.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 231 | 27-Jul-2022 | BAGALKOT | 220 | SIRSI-HUBLI-2 | STATION NOT AFFECTED SIRSI_220 | 19:46 (15.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 232 | 27-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED TODALBAGI_110 | 19:13 (17.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 233 | 27-Jul-2022 | BAGALKOT | 110 | TODALBAGI-SAVALAGI | TODALBAGI_110 | 18:00 (20.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 234 | 27-Jul-2022 | BAGALKOT | 110 | SIRSI-KAVALWADA | STATION NOT AFFECTED SIRSI_110 | 12:55 (22.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 235 | 27-Jul-2022 | BAGALKOT | 110 | UTTUR - F1 JAMB CB(MUDHOL) | STATION NOT AFFECTED UTTUR_110 | 9:51 (24.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 236 | 27-Jul-2022 | BAGALKOT | 220 | AMBEWADI-NAGAJHARI-2 | STATION NOT AFFECTED AMBEWADI_220 | 8:46 (26.07.2022) | 16:11 (27.07.2022) | 31:00HRS | LINE CHARGED |
| 237 | 27-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | AKSHAY COLONY_110 | 10:36 | 11:35 | 0:59 | LINE CLEAR AVAILED |
| 238 | 27-Jul-2022 | BAGALKOT | 110 | HOSAHONNATTI-AREMALLAPUR | AREMALLAPUR&BELUR_110 | 12:07 | 16:13 | 4:06 | LINE CLEAR AVAILED |
| 239 | 27-Jul-2022 | BAGALKOT | 110 | KAGWAD-SHIRGUPPI SUGARS | KAGAWAD_110 | 15:00 | 16:32 | 1:32 | LINE CLEAR AVAILED |
| 240 | 27-Jul-2022 | BAGALKOT | 110 | 110/11KV,VHV2 | KAMBAGI_110 | 8:36 | 8:44 | 0:08 | TRANSFORMER FAULT |
| 241 | 27-Jul-2022 | BAGALKOT | 110 | 110/11KV,VHV2 | KAMBAGI_110 | 10:04 | 10:15 | 0:11 | TRANSFORMER FAULT |
| 242 | 27-Jul-2022 | BAGALKOT | 110 | BAGALKOT-LOKAPUR | LOKAPUR_110 (STATION NOT AFFECTED) | 17:09 | 22:48 | 5:39 | LINE CLEAR AVAILED |
| 243 | 27-Jul-2022 | BAGALKOT | 110 | MACHE -UDYAMBAG | MACHE_110 | 16:18 | 17:32 | 1:14 | LINE CLEAR AVAILED |
| 244 | 27-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | MALGHAN(S)_110 | 12:48 | 14:21 | 1:33 | LINE CLEAR AVAILED |
| 245 | 27-Jul-2022 | BAGALKOT | 110 | MUKARTIHAL-NIDAGUNDI | NIDAGUNDI_110 | 5:57 | 6:08 | 0:11 | LINE FAULT |
| 246 | 27-Jul-2022 | BAGALKOT | 110 | ITNAL(MUGALKHOD)-RAIBAG | RAIBAG_110 (STATION NOT AFFECTED) | 10:24 | 14:20 | 3:56 | NFBC ISSUED |
| 247 | 27-Jul-2022 | BAGALKOT | 110 | 110/11KV, LV3 | YARAGATTI_110 | 18:46 | 19:09 | 0:23 | TRANSFORMER FAULT |
| 248 | 27-Jul-2022 | BAGALKOT | 110 | VADAGOAN-BELGAUM | VADAGOAN_110 | 16:00 | 16:03 | 0:03 | HAND TRIPPED |
| 249 | 27-Jul-2022 | BAGALKOT | 110 | VADAGOAN-BELGAUM | VADAGOAN_110 | 16:32 | 19:35 | 3:03 | NFBC ISSUED |
| 250 | 27-Jul-2022 | BAGALKOT | 110 | UCHAGOAN-UDYAMBHAG | UCHAGOAN_110 | 13:45 | 13:54 | 0:09 | LINE FAULT |
| 251 | 27-Jul-2022 | BAGALKOT | 110 | UCHAGOAN-UDYAMBHAG | UCHAGOAN_110 | 13:54 | 15:41 | 1:47 | LINE FAULT |
| 252 | 27-Jul-2022 | BAGALKOT | 110 | UCHAGOAN-UDYAMBHAG | STATION NOT AFFECTED UCHAGOAN_110 | 15:41 | 16:24 | 0:43 | LINE CLEAR AVAILED |
| 253 | 27-Jul-2022 | BAGALKOT | 110 | UCHAGOAN-UDYAMBHAG | STATION NOT AFFECTED UCHAGOAN_110 | 16:24 | 16:44 | 0:20 | HAND TRIPPED |
| 254 | 27-Jul-2022 | BAGALKOT | 110 | TADASINA-KUD DHARWAD(NARENDRA) | STATION NOT AFFECTED TADASINKOPPA_110 | 11:14 | 14:16 | 3:02 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|------------------------------------|--|-----------------------|-----------------------|-----------|--------------------|
| 255 | 27-Jul-2022 | BAGALKOT | 110 | TADASINA-KUD DHARWAD(NARENDRA) | STATION NOT AFFECTED TADASINKOPPA_110 | 23:00 (05.07.2022) | 11:14 (27.07.2022) | 516:14HRS | LINE CHARGED |
| 256 | 27-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-GULEDGUDDA | GULEDGUDDA_110 | 12:34 | 12:47 | 0:13 | HAND TRIPPED |
| 257 | 27-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-LOKAPUR | STATION NOT AFFECTED LOKAPUR_110 | 13:10 | 18:15 | 5:05 | LINE CLEAR AVAILED |
| 258 | 27-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-LOKAPUR | STATION NOT AFFECTED LOKAPUR_110 | 22:40 | 22:43 | 0:03 | HAND TRIPPED |
| 259 | 27-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-KATARKI (NEERABUDIHAL) | NEERABUDIHAL_110 | 12:34 | 12:46 | 0:12 | HAND TRIPPED |
| 260 | 27-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-KATARKI (NEERABUDIHAL) | NEERABUDIHAL_110 | 22:41 | 22:42 | 0:01 | HAND TRIPPED |
| 261 | 27-Jul-2022 | BAGALKOT | 220 | NARENDRA-KNBRG1 (BELAGAVI-1) | STATION NOT AFFECTED NARENDRA_220 | 11:21 | 12:00 | 0:39 | LINE FAULT |
| 262 | 27-Jul-2022 | BAGALKOT | 110 | GHATAPRABHA220- KABBUR | KABBUR_110 | 10:21 | 17:56 | 7:35 | LINE CLEAR AVAILED |
| 263 | 27-Jul-2022 | BAGALKOT | 220 | HUBLI-SIRSI-1 | STATION NOT AFFECTED HUBLI_220 | 9:56 | 17:59 | 8:03 | LINE FAULT |
| 264 | 27-Jul-2022 | BAGALKOT | 220 | HUBLI-SIRSI-2 | STATION NOT AFFECTED HUBLI_220 | 9:56 | 17:59 | 8:03 | LINE FAULT |
| 265 | 27-Jul-2022 | BAGALKOT | 220 | HUBLI-NAGAZARI-2 | STATION NOT AFFECTED HUBLI_220 | 11:32 | 13:52 | 2:20 | LINE FAULT |
| 266 | 27-Jul-2022 | BAGALKOT | 220 | HUBLI-NAGAZARI-3 | STATION NOT AFFECTED HUBLI_220 | 10:20 | 18:30 | 8:10 | LINE FAULT |
| 267 | 27-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV3 | STATION NOT AFFECTED HUBLI_220 | 9:56 | 13:52 | 3:56 | TRANSFORMER FAULT |
| 268 | 27-Jul-2022 | BAGALKOT | 220 | HAVERI-GUTTR-1 | STATION NOT AFFECTED HAVERI_220 | 11:05 | 13:25 | 2:20 | LINE CLEAR AVAILED |
| 269 | 27-Jul-2022 | BAGALKOT | 220 | HAVERI-NARENDRA | STATION NOT AFFECTED HAVERI_220 | 13:11 | 19:17 | 6:06 | LINE FAULT |
| 270 | 27-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV1 | STATION NOT AFFECTED MUGALAKHOD_220 | 10:26 | 11:37 | 1:11 | LINE CLEAR AVAILED |
| 271 | 27-Jul-2022 | BAGALKOT | 110 | 220/110KV, LV1 | STATION NOT AFFECTED MUGALAKHOD_220 | 10:25 | 11:39 | 1:14 | LINE CLEAR AVAILED |
| 272 | 27-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV2 | STATION NOT AFFECTED MUGALAKHOD_220 | 11:41 | 12:58 | 1:17 | LINE CLEAR AVAILED |
| 273 | 27-Jul-2022 | BAGALKOT | 110 | 220/110KV, LV2 | STATION NOT AFFECTED MUGALAKHOD_220 | 11:40 | 12:59 | 1:19 | LINE CLEAR AVAILED |
| 274 | 27-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV1 | STATION NOT AFFECTED KUDACHI_220 | 16:38 | 17:11 | 0:33 | LINE CLEAR AVAILED |
| 275 | 27-Jul-2022 | BAGALKOT | 110 | 220/110KV, LV1 | STATION NOT AFFECTED KUDACHI_220 | 16:38 | 17:12 | 0:34 | LINE CLEAR AVAILED |
| 276 | 27-Jul-2022 | BAGALKOT | 110 | KARWAR220-ARGA (KUMTA) | ARGA_110, KUMTA_110 | 9:50 | 14:50 | 5:00 | LINE CLEAR AVAILED |
| 277 | 27-Jul-2022 | BAGALKOT | 110 | KARWAR220- SOLARIS (BINAGA) | BINAGA_110 | 10:03 | 14:57 | 4:54 | LINE CLEAR AVAILED |
| 278 | 27-Jul-2022 | BAGALKOT | 110 | 220/110KV, LV1 | STATION NOT AFFECTED KARWAR_220 | 10:05 | 14:40 | 4:35 | LINE CLEAR AVAILED |
| 279 | 27-Jul-2022 | BAGALKOT | 220 | KARWAR-KADRA-1 | STATION NOT AFFECTED KARWAR_220 | 10:15 | 14:32 | 4:17 | LINE CLEAR AVAILED |
| 280 | 27-Jul-2022 | BAGALKOT | 110 | 220/110KV, LV1 | STATION NOT AFFECTED BELAGAVI_220 | 11:20 | 11:46 | 0:26 | TRANSFORMER FAULT |
| 281 | 27-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV1 | STATION NOT AFFECTED BELAGAVI_220 | 11:20 | 11:46 | 0:26 | TRANSFORMER FAULT |
| 282 | 27-Jul-2022 | BAGALKOT | 110 | BELAGAVI220-ANKALAGI | STATION NOT AFFECTED ANKALAGI_110 | 11:12 | 13:50 | 2:38 | LINE CLEAR AVAILED |
| 283 | 27-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV3 | STATION NOT AFFECTED BELAGAVI_220 | 16:03 | 18:29 | 2:26 | LINE CLEAR AVAILED |
| 284 | 27-Jul-2022 | BAGALKOT | 110 | 220/110KV, LV3 | STATION NOT AFFECTED BELAGAVI_220 | 13:56 | 18:29 | 4:33 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|-------------------------------|--|-----------------------|-----------------------|-----------|-------------------------------------|
| 285 | 27-Jul-2022 | BAGALKOT | 110 | BELAGAVI220-VADAGAON | STATION NOT AFFECTED BELAGAVI_220 | 15:35 | 19:27 | 3:52 | LINE FAULT |
| 286 | 27-Jul-2022 | BAGALKOT | 220 | BIDNAL-HARTI-2 | STATION NOT AFFECTED BIDNAL_220 | 11:51 | 19:47 | 7:56 | LINE FAULT |
| 287 | 27-Jul-2022 | BAGALKOT | 220 | BIDNAL-HARTI-1 | STATION NOT AFFECTED BIDNAL_220 | 12:08 | 19:38 | 7:30 | LINE FAULT |
| 288 | 27-Jul-2022 | BAGALKOT | 220 | BIDNAL-NAGAJHARI-2 | STATION NOT AFFECTED BIDNAL_220 | 14:01 | 18:31 | 4:30 | LINE CLEAR AVAILED |
| 289 | 27-Jul-2022 | BAGALKOT | 110 | 110/33KV, HV3 | STATION NOT AFFECTED YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 290 | 27-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV1 | STATION NOT AFFECTED AMBEWADI_220 | 20:00 (09.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 291 | 27-Jul-2022 | BAGALKOT | 220 | GADAG-HARTI-1 | STATION NOT AFFECTED GADAG_220 | 10:55 (19.07.2020) | 12:51 (27.07.2022) | 193:56HRS | LINE CHARGED |
| 292 | 27-Jul-2022 | BAGALKOT | 220 | GADAG-HARTI-2 | STATION NOT AFFECTED GADAG_220 | 10:55 (19.07.2020) | | | LINE OPEN , LINE CLEAR AVAILED |
| 293 | 27-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV-3 & LV3 | STATION NOT AFFECTED ATHANI_220 | 10:26 (25.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 294 | 27-Jul-2022 | BAGALKOT | 220 | AMBEWADI-NAGAJHARI-1 | STATION NOT AFFECTED AMBEWADI_220 | 9:11 (26.07.2022) | 16:11 (27.07.2022) | 31:00HRS | LINE CHARGED |
| 295 | 27-Jul-2022 | BAGALKOT | 220 | NARENDRA-BELAGAVI-2 | STATION NOT AFFECTED NARENDRA_220 | 11:09 (26.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 296 | 27-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED BILAGI_110 | 8:50 | 9:00 | 0:10 | TRANSFORMER FAULT |
| 297 | 27-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED KATARAKI_110 | 16:35 | 17:25 | 0:50 | LINE CLEAR AVAILED |
| 298 | 27-Jul-2022 | BAGALKOT | 110 | NARENDRA-TADASINAKOPPA | STATION NOT AFFECTED NARENDRA_220 | 11:05 | 14:14 | 3:09 | LINE CLEAR AVAILED |
| 299 | 27-Jul-2022 | BAGALKOT | 220 | NARENDRA-HAVERI | STATION NOT AFFECTED NARENDRA_220 | 13:11 | 19:16 | 6:05 | LINE FAULT |
| 300 | 27-Jul-2022 | BAGALKOT | 110 | KUDACHI220-UGAR | UGAR_110 | 11:30 | 14:50 | 3:20 | LINE CLEAR AVAILED |
| 301 | 27-Jul-2022 | BAGALKOT | 110 | ATHANI220-BALIGERI | BALIGERI_110 | 6:15 | 6:25 | 0:10 | LINE FAULT |
| 302 | 27-Jul-2022 | BAGALKOT | 110 | AMBEWADI220-SUPA-2 | STATION NOT AFFECTED AMBEWADI_220 | 14:24 | 15:15 | 0:51 | LINE CLEAR AVAILED |
| 303 | 27-Jul-2022 | BAGALKOT | 110 | 220/110KV , LV2 | STATION NOT AFFECTED KARWAR_220 | 10:07 | 14:40 | 4:33 | LINE CLEAR AVAILED |
| 304 | 27-Jul-2022 | BAGALKOT | 220 | KARWAR-KADRA-2 | STATION NOT AFFECTED KARWAR_220 | 10:15 | 14:30 | 4:15 | LINE CLEAR AVAILED |
| 305 | 27-Jul-2022 | BAGALKOT | 110 | KARWAR220-KARWAR | KARWAR_110 | 10:20 | 14:44 | 4:24 | LINE CLEAR AVAILED |
| 306 | 27-Jul-2022 | BAGALKOT | 220 | BELAGAVI-NARENDRA-1 | STATION NOT AFFECTED BELAGAVI_220 | 11:20 | 11:47 | 0:27 | LINE FAULT |
| 307 | 27-Jul-2022 | BENGALURU | 66 | BANGARPET - MALUR 220 | BANGARPET | 6:55 | 7:00 | 0:05 | LOAD CHANGE OVER |
| 308 | 27-Jul-2022 | BENGALURU | 66 | BANGARPET - KOLAR 220 | BANGARPET | 9:50 | 9:55 | 0:05 | LOAD CHANGE OVER |
| 309 | 27-Jul-2022 | BENGALURU | 66 | DABUSPET 220 - TYAMAGONDLU | TYAMAGONDLU | 16:08 | 16:27 | 0:19 | LINE FAULT |
| 310 | 27-Jul-2022 | BENGALURU | 66 | HV2 | T BEGUR | 16:08 | 19:15 | 3:07 | TRANSFORMER FAULT |
| 311 | 27-Jul-2022 | BENGALURU | 66 | HULLENAHALLI - ANCHEPALYA 220 | KUDUR, HULENAHALLI, SIRIGIRIPURA | 11:30 | 17:52 | 6:22 | LINE CLEAR AVAILED |
| 312 | 27-Jul-2022 | BENGALURU | 220 | NELAMANGALA 400 - NITTUR | NO STATION AFFECTED | 12:14 | 14:05 | 1:51 | LINE FAULT |
| 313 | 27-Jul-2022 | BENGALURU | 66 | KOLAR 220 - VOKKALERI | VOKKALERI | 19:40 | 20:13 | 0:33 | LOAD CURTAILMENT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--------------------------------------|--|---------|-----------|----------|--------------------|
| 314 | 27-Jul-2022 | BENGALURU | 66 | KOLAR 220 - VOKKALERI | VOKKALERI | 21:47 | 22:18 | 0:31 | LOAD CURTAILMENT |
| 315 | 27-Jul-2022 | BENGALURU | 66 | KOLAR 220 - VEMGAL | TALAGUNDA, VEMGAL, KYALNUR | 19:40 | 20:13 | 0:33 | LOAD CURTAILMENT |
| 316 | 27-Jul-2022 | BENGALURU | 66 | KOLAR 220 - THAYLUR | TAMAKA | 19:48 | 20:13 | 0:25 | LOAD CURTAILMENT |
| 317 | 27-Jul-2022 | BENGALURU | 66 | KOLAR 220 - PGCIL AUX | PGCIL AUX, SUGUTUR | 19:48 | 20:13 | 0:25 | LOAD CURTAILMENT |
| 318 | 27-Jul-2022 | BENGALURU | 66 | KOLAR 220 - NANGALI | KEMBODI | 19:48 | 20:13 | 0:25 | LOAD CURTAILMENT |
| 319 | 27-Jul-2022 | BENGALURU | 66 | LAKSHMIPURA - SOMAYAJANAHALLI | SOMAJANAHALLI | 18:00 | 18:10 | 0:10 | LINE FAULT |
| 320 | 27-Jul-2022 | BENGALURU | 66 | SOMAYAJANAHALLI - SOLAR IPP | SOMAYAJANAHALLI | 18:00 | 18:10 | 0:10 | LINE FAULT |
| 321 | 27-Jul-2022 | BENGALURU | 66 | H GOLLAHALLI - T GOLLAHALLI 220 | H GOLLAHALLI, MUDIYANURU | 15:10 | 16:00 | 0:50 | LINE CLEAR AVAILED |
| 322 | 27-Jul-2022 | BENGALURU | 66 | HV2 | H GOLLAHALLI | 11:20 | 12:35 | 1:15 | LINE CLEAR AVAILED |
| 323 | 27-Jul-2022 | BENGALURU | 66 | T GOLLAHALLI 220 - TAYALUR | TAYALUR, NG HULKUR, MALLANAYAKANAHALLI | 18:23 | 18:33 | 0:10 | LINE FAULT |
| 324 | 27-Jul-2022 | BENGALURU | 66 | T GOLLAHALLI 220 - NANGLI | NANGLI, BAIRKURU | 18:23 | 18:33 | 0:10 | LINE FAULT |
| 325 | 27-Jul-2022 | BENGALURU | 66 | VEMGAL - KYALANUR | KYALANUR | 20:10 | 20:20 | 0:10 | LINE FAULT |
| 326 | 27-Jul-2022 | BENGALURU | 66 | HV1 | SANKALGERE | 10:05 | 15:20 | 5:15 | LINE CLEAR AVAILED |
| 327 | 27-Jul-2022 | BENGALURU | 66 | HV2 | SANKALGERE | 10:05 | 15:20 | 5:15 | LINE CLEAR AVAILED |
| 328 | 27-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - GANJIGUNTE 1 & 2 | GANJIGUNTE, PALLICHERLU | 19:44 | 20:08 | 0:23 | LOAD CURTAILMENT |
| 329 | 27-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - LAKSHMIPURA | TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU | 19:44 | 20:07 | 0:22 | LOAD CURTAILMENT |
| 330 | 27-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - NANDIGANAHALLI | NANDIGANAHALLI | 19:44 | 20:07 | 0:22 | LOAD CURTAILMENT |
| 331 | 27-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - SIDLAGHATTA | SIDLAGHATTA, MELUR | 19:44 | 20:00 | 0:15 | LOAD CURTAILMENT |
| 332 | 27-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - TALAGAWARA | TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA | 19:44 | 20:06 | 0:21 | LOAD CURTAILMENT |
| 333 | 27-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - SRINIVASPURA | G KODIHALLI, SRINIVASPURA, YELDUR | 19:44 | 20:02 | 0:17 | LOAD CURTAILMENT |
| 334 | 27-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - YENNIGADALE | BOMMEPALLIC CROSS, YENIGADALE | 19:44 | 20:09 | 0:24 | LOAD CURTAILMENT |
| 335 | 27-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - IRGAMPALLI | IRAGAMPALLI, M GOLLAHALLI, DIBBURAHALLI | 19:44 | 20:10 | 0:25 | LOAD CURTAILMENT |
| 336 | 27-Jul-2022 | BENGALURU | 66 | SARJAPURA 220 - ATTIBELE | ATTIBELE | 19:48 | 20:17 | 0:28 | LOAD CURTAILMENT |
| 337 | 27-Jul-2022 | BENGALURU | 66 | MITTEMARI 220 - BAGEPALLI 1 | VATADOSANAHALLI | 8:24 | 8:28 | 0:03 | LINE CLEAR AVAILED |
| 338 | 27-Jul-2022 | BENGALURU | 66 | MITTEMARI 220 - JULLUPALYA | JULLUPALYA | 8:24 | 8:27 | 0:03 | LINE CLEAR AVAILED |
| 339 | 27-Jul-2022 | BENGALURU | 66 | MALUR 220 - LAKKUR | DEVANGONDHI, LAKKUR | 6:47 | 7:03 | 0:16 | LINE CLEAR AVAILED |
| 340 | 27-Jul-2022 | BENGALURU | 66 | MALUR 220 - LAKKUR | DEVANGONDHI, LAKKUR | 19:44 | 19:50 | 0:06 | LOAD CURTAILMENT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|-----------------------------------|--|---------|-----------|----------|--------------------|
| 341 | 27-Jul-2022 | BENGALURU | 66 | MALUR 220 - MAASTHI | MAASTHI | 19:44 | 19:50 | 0:06 | LOAD CURTAILMENT |
| 342 | 27-Jul-2022 | BENGALURU | 66 | MALUR 220 - KGF 1 | TEKAL, BUDIKOTE, TORLAKKI | 19:44 | 19:50 | 0:06 | LOAD CURTAILMENT |
| 343 | 27-Jul-2022 | BENGALURU | 66 | MALUR 220 - KGF 2 | BANGARPETE | 19:44 | 19:50 | 0:06 | LOAD CURTAILMENT |
| 344 | 27-Jul-2022 | BENGALURU | 66 | MALUR 220 - HOSKOTE 2 | JADIGENAHALLI | 19:44 | 19:50 | 0:06 | LOAD CURTAILMENT |
| 345 | 27-Jul-2022 | BENGALURU | 66 | MALUR 220 - LAKKUR | DEVANGONDHI, LAKKUR | 5:53 | 6:08 | 0:15 | LINE FAULT |
| 346 | 27-Jul-2022 | BENGALURU | 66 | MALUR 220 - LAKKUR | DEVANGONDHI, LAKKUR | 9:38 | 9:39 | 0:01 | LINE CLEAR AVAILED |
| 347 | 27-Jul-2022 | BENGALURU | 66 | HV2 | CHATRA | 13:58 | 14:03 | 0:05 | TRANSFORMER FAULT |
| 348 | 27-Jul-2022 | BENGALURU | 66 | KOTHIPURA 220 - RAMANAGARA | RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA | 10:10 | 15:18 | 5:08 | LINE CLEAR AVAILED |
| 349 | 27-Jul-2022 | BENGALURU | 66 | KANAKAPURA 220 - CHANNAPATNA | ALLIMARDANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE | 17:46 | 18:03 | 0:17 | LINE FAULT |
| 350 | 27-Jul-2022 | BENGALURU | 66 | SUBRAMANYAPURA 220 - SARAKKI 2 | NO STATION AFFECTED | 17:21 | 18:11 | 0:50 | LINE FAULT |
| 351 | 27-Jul-2022 | BENGALURU | 66 | HV1 | TK HALLI 220 | 14:18 | 14:23 | 0:05 | LINE CLEAR AVAILED |
| 352 | 27-Jul-2022 | BENGALURU | 66 | HV2 | TK HALLI 220 | 14:18 | 14:23 | 0:05 | LINE CLEAR AVAILED |
| 353 | 27-Jul-2022 | BENGALURU | 66 | TK HALLI 220 - MANDYA 1 | KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA | 14:38 | 14:50 | 0:12 | LINE CLEAR AVAILED |
| 354 | 27-Jul-2022 | BENGALURU | 66 | TK HALLI 220 - HAROHALLI 2 | VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT) | 14:38 | 14:50 | 0:12 | LINE CLEAR AVAILED |
| 355 | 27-Jul-2022 | BENGALURU | 66 | TK HALLI 220 - IGGALUR | IGGALUR,K HONALGERE, YATHAMBADI | 14:38 | 14:50 | 0:12 | LINE CLEAR AVAILED |
| 356 | 27-Jul-2022 | BENGALURU | 66 | TK HALLI 220 - AKKURMOLE | AKKURMOLE | 14:38 | 14:50 | 0:12 | LINE CLEAR AVAILED |
| 357 | 27-Jul-2022 | BENGALURU | 66 | TK HALLI 220 - SOMANAHALLI 2 | HALAGUR, HONNIGANAHALLI, DODDALAHALLI, SATHNUR (ACHLU) | 14:38 | 14:50 | 0:12 | LINE CLEAR AVAILED |
| 358 | 27-Jul-2022 | BENGALURU | 66 | HV2 | NRS 220 | 22:07 | 22:18 | 0:10 | LOAD CHANGE OVER |
| 359 | 27-Jul-2022 | BENGALURU | 66 | NRS 220 - SRS 2 | NRS 220 | 22:08 | 22:18 | 0:10 | LOAD CHANGE OVER |
| 360 | 27-Jul-2022 | BENGALURU | 66 | HV1 | SOUTH CITY | 10:41 | 17:26 | 6:45 | LINE CLEAR AVAILED |
| 361 | 27-Jul-2022 | BENGALURU | 66 | HV2 | SOUTH CITY | 10:41 | 17:26 | 6:45 | LINE CLEAR AVAILED |
| 362 | 27-Jul-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - HOSUR RAMAPURA | HOSURU RAMAPURA, NITRALLI | 19:47 | 20:07 | 0:20 | LOAD CURTAILMENT |
| 363 | 27-Jul-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - DB PURA 1 | MANCHENAHALLI, GUNDAMGERE | 19:47 | 20:08 | 0:21 | LOAD CURTAILMENT |
| 364 | 27-Jul-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - DB PURA 2 | THONDEBHAVI | 19:47 | 20:16 | 0:29 | LOAD CURTAILMENT |
| 365 | 27-Jul-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - BAGEPALI 2 | VIDHURASHWATHA, GUNDLU KOTTURU | 19:47 | 20:18 | 0:31 | LOAD CURTAILMENT |
| 366 | 27-Jul-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - KODIGENAHALLI | ID HALLI, KODIGENAHALLI | 19:48 | 20:20 | 0:32 | LOAD CURTAILMENT |
| 367 | 27-Jul-2022 | BENGALURU | 66 | HV1 | G KODIHALLI | 10:15 | 10:20 | 0:05 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--|--|-----------------------|--------------------|-------------|--------------------------------|
| 368 | 27-Jul-2022 | BENGALURU | 66 | HV2 | G KODIHALLI | 13:10 | 13:15 | 0:05 | LINE CLEAR AVAILED |
| 369 | 27-Jul-2022 | BENGALURU | 220 | EAST DIVISION COMPOUND 220 - A STATION 220 | NO STATION AFFECTED | 08:38:00(23/07/2022) | | | LINE OPEN, LINE FAULT |
| 370 | 27-Jul-2022 | GULBARGA | 400 | RTPS-MUNIRABAD | MUNIRABAD_400 | 10:04 (14.06.2022) | 22:27 (27.07.2022) | 1044:23 HRS | LINE CHARGED |
| 371 | 27-Jul-2022 | GULBARGA | 400 | BPS-JSWL3 | BPS_400 | 12:09 | 17:05 | 4:56 | LINE CLEAR AVAILED |
| 372 | 27-Jul-2022 | GULBARGA | 220 | SEDAM_SHAHAPUR | SEDAM_220 | 05:48(10/06/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 373 | 27-Jul-2022 | GULBARGA | 220 | HV1 | SHAHAPUR_220 | 13:48 | 14:35 | 0:47 | LINE CLEAR AVAILED |
| 374 | 27-Jul-2022 | GULBARGA | 220 | HV1 | SHAHABAD_220 | 11:40 | 14:15 | 2:35 | LINE CLEAR AVAILED |
| 375 | 27-Jul-2022 | GULBARGA | 220 | LINGASUGUR-SHAHAPUR | SHAHAPUR_220 | 10:52 | 12:55 | 2:03 | LINE CLEAR AVAILED |
| 376 | 27-Jul-2022 | GULBARGA | 220 | LINGASUGUR-SHAHAPUR | LINGASUGUR_220 | 21:47(26.07.2022) | 11:30(27.07.2022) | 13:43HRS | LINE CHARGED |
| 377 | 27-Jul-2022 | GULBARGA | 220 | LINGASUGUR-SHAHAPUR | LINGASUGUR_220 | 12:06 | 12:26 | 0:20 | LINE CLEAR AVAILED |
| 378 | 27-Jul-2022 | GULBARGA | 220 | LINGASUGUR-SINDHANOOR220 | SINDHANOOR_220 | 13:26 | 13:58 | 0:32 | LINE FAULT |
| 379 | 27-Jul-2022 | GULBARGA | 220 | LINGASUGUR-SINDHANOOR220 | SINDHANOOR_220 | 14:35 | 18:19 | 3:44 | LINE FAULT |
| 380 | 27-Jul-2022 | GULBARGA | 220 | MALLAT-RTPS | MALLAT_220 | 23:20(26.07.2022) | 18:58 (27.07.2022) | 19:38 HRS | LINE CHARGED |
| 381 | 27-Jul-2022 | GULBARGA | 220 | KUSTAGI-SULEKAL | SULEKAL_220 | 14:23 | 14:34 | 0:11 | LINE FAULT |
| 382 | 27-Jul-2022 | GULBARGA | 220 | KUSTAGI-ASTRO_IPP | KUSTAGI_220 | 15:37 | 17:37 | 2:00 | LINE FAULT |
| 383 | 27-Jul-2022 | GULBARGA | 220 | KUSTAGI-LINGASUGUR | KUSTAGI_220 | 15:37 | 15:41 | 0:04 | LINE FAULT |
| 384 | 27-Jul-2022 | GULBARGA | 220 | SHAHAPUR-RTPS_2 | SHAHAPUR_220 | 4:40 | 4:49 | 0:09 | LINE FAULT |
| 385 | 27-Jul-2022 | GULBARGA | 220 | LINGAPUR-BTPS | LINGAPUR_220 | 10:21 | 18:03 | 7:42 | LINE CLEAR AVAILED |
| 386 | 27-Jul-2022 | GULBARGA | 220 | SHAHAPUR-LINGASUGUR | SHAHAPUR_220 | 21:47 (26.07.2022) | 11:30 (27.07.2022) | 13:43 HRS | LINE CHARGED |
| 387 | 27-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR1 | JEWARGI_110 | 12:15(15/06/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 388 | 27-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR2 | NALWAR_110 | 15:10(14/06/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 389 | 27-Jul-2022 | GULBARGA | 110 | HUMNABAD-HALLIKHED | HALLIKHED_110 | 9:34(20/07/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 390 | 27-Jul-2022 | GULBARGA | 110 | HUMNABAD-HALBARGA | HALBARGA_110 | 3:54(20/07/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 391 | 27-Jul-2022 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 10:43 | 10:48 | 0:05 | TRANSFORMER FAULT |
| 392 | 27-Jul-2022 | GULBARGA | 110 | HV1 | HALKUNDI_110 | 10:20 | 11:10 | 0:50 | LINE CLEAR AVAILED |
| 393 | 27-Jul-2022 | GULBARGA | 110 | HV2 | DEODURGA_110 | 10:50 | 11:20 | 0:30 | LINE CLEAR AVAILED |
| 394 | 27-Jul-2022 | GULBARGA | 110 | HV2 | SREERAMANAGAR_110 | 5:25 | 5:37 | 0:12 | TRANSFORMER FAULT |
| 395 | 27-Jul-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVIAMARESHWARA_110,MANVI_110 | 23:51(26.07.2022) | 00:04(27.07.2022) | 0:13HRS | LINE CHARGED |
| 396 | 27-Jul-2022 | GULBARGA | 110 | YELBURGA-PRPJSLR_IPP | YELBURGA_110 | 12:11 | 12:18 | 0:07 | LINE CLEAR AVAILED |
| 397 | 27-Jul-2022 | GULBARGA | 110 | YAPALDINNI-VADAVATI | YAPALDINNI_110 | 3:00 | 3:13 | 0:13 | MAIN SUPPLY FAILURE |
| 398 | 27-Jul-2022 | GULBARGA | 110 | YARADONA-MARALIHALLI | YARADONA_110 | 12:30 | 13:05 | 0:35 | MAIN SUPPLY FAILURE |
| 399 | 27-Jul-2022 | GULBARGA | 110 | NANDUR-SHAHABAD | NANDUR_110 | 5:40 | 7:36 | 1:56 | LINE FAULT |
| 400 | 27-Jul-2022 | GULBARGA | 110 | GULBARGA WEST-GULBARGA SOUTH 1GULBARGA SOUTH_110 | | 11:10 | 13:50 | 2:40 | NFBC ISSUED |
| 401 | 27-Jul-2022 | GULBARGA | 110 | JAWALGERA-SINDHANOOR(VALA BELLARY) | JAWALGERA_110 | 20:05 | 20:10 | 0:05 | MAIN SUPPLY FAILURE |
| 402 | 27-Jul-2022 | GULBARGA | 110 | SULEKAL-MARALIHALLI | MUKUNDA_110, YEREDONA_110,BENNUR SOLAR_IPP | 0:21 | 0:41 | 0:20 | LINE FAULT |
| 403 | 27-Jul-2022 | GULBARGA | 110 | SULEKAL-MARALIHALLI | MUKUNDA_110, YEREDONA_110,BENNUR SOLAR_IPP | 4:02 | 4:12 | 0:10 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--------------------------|---|-------------------|-----------|----------|-------------------------------------|
| 404 | 27-Jul-2022 | GULBARGA | 110 | HALBARGA-KOLHAR1 | KOLHAR_110,JANAWADA_110,NSSK SUGAR FACTORY | 22:33 | 22:48 | 0:15 | LINE FAULT |
| 405 | 27-Jul-2022 | GULBARGA | 110 | HALBARGA-KOLHAR2 | KOLHAR_110,JANAWADA_110,NSSK SUGAR FACTORY | 22:33 | 22:48 | 0:15 | LINE FAULT |
| 406 | 27-Jul-2022 | GULBARGA | 110 | SHAHABAD-BAGEWADI1 | MADEWAL_110,MORATAGI_110,GHATARGA_110,DEVANGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110 | 5:39 | 5:46 | 0:07 | LINE FAULT |
| 407 | 27-Jul-2022 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR_110 | 13:10 | 13:34 | 0:24 | LINE CLEAR AVAILED |
| 408 | 27-Jul-2022 | GULBARGA | 110 | RAICHUR-SHAHAPUR2 | GOOGLE_110 | 5:52 | 6:00 | 0:08 | LINE FAULT |
| 409 | 27-Jul-2022 | GULBARGA | 110 | RAICHUR-SINDHANOOR1 | SIRWAR_110 | 21:16 | 21:30 | 0:14 | LINE FAULT |
| 410 | 27-Jul-2022 | GULBARGA | 110 | RAICHUR-SINDHANOOR1 | SIRWAR_110 | 22:24 | 22:40 | 0:16 | LINE FAULT |
| 411 | 27-Jul-2022 | GULBARGA | 110 | RAICHUR-MALIYABAD | MALIYABAD_110,YERAGERA_110,VADAVATTI_110,YAPALDINNI_110 | 23:15 | 23:20 | 0:05 | LINE FAULT |
| 412 | 27-Jul-2022 | GULBARGA | 110 | MALLAT-KAVITAL | KAVITAL_110 | 1:59 | 2:09 | 0:10 | LINE FAULT |
| 413 | 27-Jul-2022 | GULBARGA | 110 | MALLAT-KAVITAL | KAVITAL_110 | 4:34 | 4:52 | 0:18 | LINE FAULT |
| 414 | 27-Jul-2022 | GULBARGA | 110 | MALLAT-BYAGAWATH1 | BYAGAWATH_110,VALKAMDINNI_110 | 2:12 | 2:24 | 0:12 | LINE FAULT |
| 415 | 27-Jul-2022 | GULBARGA | 110 | ALIPUR-MUNIRABAD | TORANGALLU_110,KUDITINI_110,KURUGOD_110,SHATAVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAMLAPUR_IPP,MATR_110,RBNS FACTORY | 2:16 | 2:30 | 0:14 | LINE FAULT |
| 416 | 27-Jul-2022 | GULBARGA | 110 | KUSTAGI-GANDAL | GANDAL_110,NAVALI_110 | 19:43 | 20:54 | 1:11 | LOAD CURTAILMENT |
| 417 | 27-Jul-2022 | GULBARGA | 110 | KUSTAGI-TAWERGERA | TAWERGERA_110 | 19:43 | 20:56 | 1:13 | LOAD CURTAILMENT |
| 418 | 27-Jul-2022 | GULBARGA | 110 | KUSATGI-ILKAL_1&2 | ILKAL_110 | 19:43 | 20:56 | 1:13 | LOAD CURTAILMENT |
| 419 | 27-Jul-2022 | GULBARGA | 110 | KUSTAGI-HANUMASAGAR | HANUMASAGAR_110,HIREGONNAGAR_110,HANUMANAL_110 | 19:43 | 20:58 | 1:15 | LOAD CURTAILMENT |
| 420 | 27-Jul-2022 | GULBARGA | 110 | KUSATGI-BEVOOR | BEVOOR_110,MANGALORE_110 | 19:43 | 21:01 | 1:18 | LOAD CURTAILMENT |
| 421 | 27-Jul-2022 | GULBARGA | 110 | KUSTAGI-VAJRABANDI | VAJRABANDI_110,YELBURGA_110,KUKNOOR_110 | 19:43 | 21:01 | 1:18 | LOAD CURTAILMENT |
| 422 | 27-Jul-2022 | GULBARGA | 110 | SINDHANOOR-SINDHANOOR_2 | SINDHANOOR_110,,VALAKAMADINNI_110, | 2:17 | 2:27 | 0:10 | LINE FAULT |
| 423 | 27-Jul-2022 | GULBARGA | 110 | SINDHANOOR-SUZLON_IPP | SINDHANOOR_220 | 3:20 | 3:30 | 0:10 | LINE FAULT |
| 424 | 27-Jul-2022 | GULBARGA | 110 | SHAHAPUR-SHAHAPUR_1&2 | SHAHAPUR_110,NALWAR_110,JEWARGI_110 | 13:33 | 15:38 | 2:05 | LINE CLEAR AVAILED |
| 425 | 27-Jul-2022 | GULBARGA | 110 | SEDAM-VICAT SAGAR_IPP | SEDAM_220 | 0:32 | 0:37 | 0:05 | LINE FAULT |
| 426 | 27-Jul-2022 | GULBARGA | 110 | SEDAM-CHITTAPUR | CHITTAPUR_110,KORWAR TEMPLE_110 | 21:02 | 21:06 | 0:04 | LINE FAULT |
| 427 | 27-Jul-2022 | GULBARGA | 66 | HV3 | KUDLIGI_66 | 12:10 | 12:40 | 0:30 | LINE CLEAR AVAILED |
| 428 | 27-Jul-2022 | GULBARGA | 66 | HARAPANAHALLI-NEELAGUNDA | HARAPANAHALLI_66 | 6:45 | 7:00 | 0:15 | MAIN SUPPLY FAILURE |
| 429 | 27-Jul-2022 | GULBARGA | 66 | KUDLIGI-SOKKE(KUDLIGI) | KUDLIGI_66,KOGALI_66,BANVEKAL_66,CHORNOOR_66,GUDEKOTE_66,HANSI_66 | 13:25 | 13:40 | 0:15 | LINE CLEAR AVAILED |
| 430 | 27-Jul-2022 | GULBARGA | 66 | ITTAGI-HIREHADAGALI_2 | HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP | 23:17 | 23:28 | 0:11 | LINE FAULT |
| 431 | 27-Jul-2022 | HASSAN | 220 | CRPATNA-HSN400 | CRPATNA_220 | 13:34(15.07.2022) | | | LINE OPEN, LINE FAULT |
| 432 | 27-Jul-2022 | HASSAN | 66 | CHANNAR-MALLALI | CHANNARAYAPATNA_66 | 12:26(22.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 433 | 27-Jul-2022 | HASSAN | 400 | UPCL-HASSAN2 | upcl_gen | 23:39(27.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 434 | 27-Jul-2022 | HASSAN | 220 | MRSSHM-HONNALLI | MRSMSG_2220 | 12:44(27.07.2022) | | | LINE OPEN, LINE FAULT |
| 435 | 27-Jul-2022 | HASSAN | 110 | HV2 | HOSANGADI_110 | 20:43(27.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 436 | 27-Jul-2022 | HASSAN | 220 | GERSOPA-TALGUPA1 | gerusoppa_gen | 11:56 | 13:19 | 1:23 | LINE CLEAR AVAILED |
| 437 | 27-Jul-2022 | HASSAN | 220 | GERSOPA-TALGUPA2 | gerusoppa_gen | 11:57 | 13:20 | 1:23 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|--------------------|---------------------|---------|-----------|----------|---------------------|
| 438 | 27-Jul-2022 | HASSAN | 220 | GOPALAP-HNPUR21 | GOPALPURA_220 | 2:23 | 15:55 | 13:32 | MAIN SUPPLY FAILURE |
| 439 | 27-Jul-2022 | HASSAN | 220 | GOPALAP-HNPUR22 | GOPALPURA_220 | 2:23 | 15:55 | 13:32 | MAIN SUPPLY FAILURE |
| 440 | 27-Jul-2022 | HASSAN | 220 | HV2 | GOPALPURA_220 | 15:50 | 19:50 | 4:00 | MAIN SUPPLY FAILURE |
| 441 | 27-Jul-2022 | HASSAN | 220 | HV1 | HEGGUNJE_220 | 15:27 | 17:20 | 1:53 | LINE CLEAR AVAILED |
| 442 | 27-Jul-2022 | HASSAN | 110 | LV1 | HEGGUNJE_220 | 15:27 | 17:20 | 1:53 | LINE CLEAR AVAILED |
| 443 | 27-Jul-2022 | HASSAN | 220 | HNPR2-GPLPR1 | HOLENARASIPURA_220 | 2:23 | 15:50 | 13:27 | LINE FAULT |
| 444 | 27-Jul-2022 | HASSAN | 220 | HNPR2-GPLPR1 | HOLENARASIPURA_220 | 15:50 | 16:30 | 0:40 | MAIN SUPPLY FAILURE |
| 445 | 27-Jul-2022 | HASSAN | 220 | HNPR2-GPLPR2 | HOLENARASIPURA_220 | 3:20 | 16:30 | 13:10 | LINE FAULT |
| 446 | 27-Jul-2022 | HASSAN | 220 | HV1 | HOLENARASIPURA_220 | 2:23 | 16:33 | 14:10 | MAIN SUPPLY FAILURE |
| 447 | 27-Jul-2022 | HASSAN | 220 | HV2 | HOLENARASIPURA_220 | 2:23 | 16:33 | 14:10 | MAIN SUPPLY FAILURE |
| 448 | 27-Jul-2022 | HASSAN | 66 | HNPR2-CRPTN | HOLENARASIPURA_220 | 2:23 | 5:19 | 2:56 | MAIN SUPPLY FAILURE |
| 449 | 27-Jul-2022 | HASSAN | 66 | HNPR2-HASS1 | HOLENARASIPURA_220 | 2:23 | 5:20 | 2:57 | MAIN SUPPLY FAILURE |
| 450 | 27-Jul-2022 | HASSAN | 66 | HNPR2-HASS2 | HOLENARASIPURA_220 | 2:23 | 17:47 | 15:24 | MAIN SUPPLY FAILURE |
| 451 | 27-Jul-2022 | HASSAN | 66 | HNPR2-HASS3 | HOLENARASIPURA_220 | 2:32 | 17:17 | 14:45 | MAIN SUPPLY FAILURE |
| 452 | 27-Jul-2022 | HASSAN | 66 | HNPR2-HNPR1 | HOLENARASIPURA_220 | 2:32 | 17:20 | 14:48 | MAIN SUPPLY FAILURE |
| 453 | 27-Jul-2022 | HASSAN | 66 | HV1 | HOLENARASIPURA_220 | 4:29 | 5:00 | 0:31 | MAIN SUPPLY FAILURE |
| 454 | 27-Jul-2022 | HASSAN | 66 | HV1 | HOLENARASIPURA_220 | 16:42 | 17:01 | 0:19 | MAIN SUPPLY FAILURE |
| 455 | 27-Jul-2022 | HASSAN | 66 | Lv1 | HOLENARASIPURA_220 | 3:34 | 16:42 | 13:08 | MAIN SUPPLY FAILURE |
| 456 | 27-Jul-2022 | HASSAN | 66 | Lv2 | HOLENARASIPURA_220 | 2:23 | 16:59 | 14:36 | MAIN SUPPLY FAILURE |
| 457 | 27-Jul-2022 | HASSAN | 66 | HNPR2-MYSOR1 | HOLENARASIPURA_220 | 2:32 | 17:17 | 14:45 | MAIN SUPPLY FAILURE |
| 458 | 27-Jul-2022 | HASSAN | 66 | HNPR2-MYSOR2 | HOLENARASIPURA_220 | 2:32 | 5:00 | 2:28 | MAIN SUPPLY FAILURE |
| 459 | 27-Jul-2022 | HASSAN | 66 | HNPR2-RNPR1 | HOLENARASIPURA_220 | 2:32 | 17:54 | 15:22 | MAIN SUPPLY FAILURE |
| 460 | 27-Jul-2022 | HASSAN | 66 | HNPR2-RNPR2 | HOLENARASIPURA_220 | 2:32 | 17:55 | 15:23 | MAIN SUPPLY FAILURE |
| 461 | 27-Jul-2022 | HASSAN | 220 | KEMAR-Kavoor2 | KEMAR_220 | 10:36 | 12:01 | 1:25 | LINE CLEAR AVAILED |
| 462 | 27-Jul-2022 | HASSAN | 110 | KEMAR-Guruvykere1 | KEMAR_220 | 17:23 | 18:22 | 0:59 | LINE CLEAR AVAILED |
| 463 | 27-Jul-2022 | HASSAN | 220 | MRSSHM-STRP1 | MRSMSG_220 | 13:00 | 13:43 | 0:43 | LINE FAULT |
| 464 | 27-Jul-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY3 | MRSMSG_220 | 11:04 | 17:08 | 6:04 | LINE CLEAR AVAILED |
| 465 | 27-Jul-2022 | HASSAN | 110 | MRSSHM-SS1 | MRSMSG_220 | 13:53 | 14:10 | 0:17 | LINE FAULT |
| 466 | 27-Jul-2022 | HASSAN | 220 | MSEZ-KAVOOR2 | MSEZ_220 | 10:36 | 12:01 | 1:25 | NFBC ISSUED |
| 467 | 27-Jul-2022 | HASSAN | 220 | SHRAVTY-SHIMOGA3 | sharavathy_gen | 11:04 | 17:08 | 6:04 | NFBC ISSUED |
| 468 | 27-Jul-2022 | HASSAN | 220 | SHRLKP-SGS | SHIRALKOPPA_220 | 15:49 | 16:44 | 0:55 | LINE CLEAR AVAILED |
| 469 | 27-Jul-2022 | HASSAN | 220 | TALAGU-STRP2 | TALAGUPPA_400 | 13:00 | 13:47 | 0:47 | LINE FAULT |
| 470 | 27-Jul-2022 | HASSAN | 110 | ALKOLA-MRS | ALKOLA_110 | 14:00 | 14:16 | 0:16 | LINE FAULT |
| 471 | 27-Jul-2022 | HASSAN | 110 | HV2 | BARANGI_110 | 15:54 | 16:44 | 0:50 | LINE CLEAR AVAILED |
| 472 | 27-Jul-2022 | HASSAN | 110 | GURUVA-KEMAR1 | GURUVAYANAKERE_110 | 16:34 | 18:40 | 2:06 | LINE FAULT |
| 473 | 27-Jul-2022 | HASSAN | 110 | HV1 | KADUR_220 | 11:03 | 11:18 | 0:15 | TRANSFORMER FAULT |
| 474 | 27-Jul-2022 | HASSAN | 110 | HV2 | KARAYA_110 | 8:26 | 17:43 | 9:17 | LINE CLEAR AVAILED |
| 475 | 27-Jul-2022 | HASSAN | 110 | KAVOOR-KVRKNJE | KAVOOR_220 | 8:03 | 12:16 | 4:13 | LINE CLEAR AVAILED |
| 476 | 27-Jul-2022 | HASSAN | 110 | KAVOOR-AMR | KAVOOR_220 | 12:54 | 19:03 | 6:09 | LINE CLEAR AVAILED |
| 477 | 27-Jul-2022 | HASSAN | 110 | KAVOOR-KLSKR2 | KAVOOR_220 | 12:18 | 18:51 | 6:33 | LINE CLEAR AVAILED |
| 478 | 27-Jul-2022 | HASSAN | 110 | KITTADA-BLGAVE | KITTADAHALALLI_110 | 12:15 | 15:06 | 2:51 | LINE CLEAR AVAILED |
| 479 | 27-Jul-2022 | HASSAN | 110 | HV1 | KITTADAHALALLI_110 | 12:15 | 15:06 | 2:51 | LINE CLEAR AVAILED |
| 480 | 27-Jul-2022 | HASSAN | 110 | HV2 | KITTADAHALALLI_110 | 12:15 | 15:06 | 2:51 | LINE CLEAR AVAILED |
| 481 | 27-Jul-2022 | HASSAN | 110 | HV2 | KONDENALU_110 | 7:33 | 14:38 | 7:05 | TRANSFORMER FAULT |
| 482 | 27-Jul-2022 | HASSAN | 110 | KULASH-KAVOOR 2 | KULASHEKARA_110 | 12:18 | 18:55 | 6:37 | LINE CLEAR AVAILED |
| 483 | 27-Jul-2022 | HASSAN | 110 | HV2 | KUNDAPURA_110 | 11:10 | 11:35 | 0:25 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|------------------------|-----------------------|---------|-----------|----------|---------------------|
| 484 | 27-Jul-2022 | HASSAN | 110 | SAGARA-ALKLA | SAGARA_110 | 13:53 | 14:18 | 0:25 | LINE FAULT |
| 485 | 27-Jul-2022 | HASSAN | 66 | ALDUR-BALEHONNUR | ALDUR_66 | 12:30 | 19:17 | 6:47 | LINE CLEAR AVAILED |
| 486 | 27-Jul-2022 | HASSAN | 66 | HV1 | ARAKALGUD_66 | 12:15 | 13:15 | 1:00 | LINE CLEAR AVAILED |
| 487 | 27-Jul-2022 | HASSAN | 66 | BANDISH-HNPURA | BANDISHETTIHALLY_66 | 2:20 | 4:30 | 2:10 | MAIN SUPPLY FAILURE |
| 488 | 27-Jul-2022 | HASSAN | 66 | BANDISH-HNPURA | BANDISHETTIHALLY_66 | 8:55 | 9:00 | 0:05 | MAIN SUPPLY FAILURE |
| 489 | 27-Jul-2022 | HASSAN | 66 | BANDISH-HNPURA | BANDISHETTIHALLY_66 | 9:05 | 9:20 | 0:15 | MAIN SUPPLY FAILURE |
| 490 | 27-Jul-2022 | HASSAN | 66 | BANDISH-HNPURA | BANDISHETTIHALLY_66 | 9:50 | 10:00 | 0:10 | MAIN SUPPLY FAILURE |
| 491 | 27-Jul-2022 | HASSAN | 66 | BANDISH-HNPURA | BANDISHETTIHALLY_66 | 17:30 | 18:00 | 0:30 | MAIN SUPPLY FAILURE |
| 492 | 27-Jul-2022 | HASSAN | 66 | CHIKABO-KUSHLNAGAR | CHIKKABOMMENAHALLI_66 | 17:45 | 17:50 | 0:05 | MAIN SUPPLY FAILURE |
| 493 | 27-Jul-2022 | HASSAN | 66 | CRPATNA-MATTANAVILE | CRPATNA_220 | 10:09 | 10:20 | 0:11 | LINE FAULT |
| 494 | 27-Jul-2022 | HASSAN | 66 | DODDAKA-HNPURA | DODDAKADANUR_66 | 4:55 | 5:08 | 0:13 | MAIN SUPPLY FAILURE |
| 495 | 27-Jul-2022 | HASSAN | 66 | HV1 | DODDAKADANUR_66 | 3:40 | 4:57 | 1:17 | MAIN SUPPLY FAILURE |
| 496 | 27-Jul-2022 | HASSAN | 66 | HV1 | DODDAKADANUR_66 | 16:46 | 16:59 | 0:13 | MAIN SUPPLY FAILURE |
| 497 | 27-Jul-2022 | HASSAN | 66 | GENDEHA-MUDIGERE | GENDEHALLI_66 | 13:13 | 15:12 | 1:59 | LINE CLEAR AVAILED |
| 498 | 27-Jul-2022 | HASSAN | 66 | HV1 | HNPURA_66 | 2:25 | 4:40 | 2:15 | MAIN SUPPLY FAILURE |
| 499 | 27-Jul-2022 | HASSAN | 66 | HV1 | HNPURA_66 | 4:42 | 5:31 | 0:49 | MAIN SUPPLY FAILURE |
| 500 | 27-Jul-2022 | HASSAN | 66 | HV1 | HNPURA_66 | 17:05 | 17:21 | 0:16 | MAIN SUPPLY FAILURE |
| 501 | 27-Jul-2022 | HASSAN | 66 | HV2 | HNPURA_66 | 2:25 | 4:40 | 2:15 | MAIN SUPPLY FAILURE |
| 502 | 27-Jul-2022 | HASSAN | 66 | HV2 | HNPURA_66 | 4:42 | 5:31 | 0:49 | MAIN SUPPLY FAILURE |
| 503 | 27-Jul-2022 | HASSAN | 66 | HV2 | HNPURA_66 | 17:05 | 17:21 | 0:16 | MAIN SUPPLY FAILURE |
| 504 | 27-Jul-2022 | HASSAN | 66 | HNPURA-RAMNATHPURA | HNPURA_66 | 4:23 | 17:16 | 12:53 | MAIN SUPPLY FAILURE |
| 505 | 27-Jul-2022 | HASSAN | 66 | HNPURA-SOMANAHALLI | HNPURA_66 | 4:38 | 5:46 | 1:08 | MAIN SUPPLY FAILURE |
| 506 | 27-Jul-2022 | HASSAN | 66 | HNPURA-DIDGTHL | MATTANAVILE_66 | 10:10 | 10:25 | 0:15 | MAIN SUPPLY FAILURE |
| 507 | 27-Jul-2022 | HASSAN | 66 | HNPURA-HNPRA | MOSALEHOSAHALLI_66 | 2:50 | 17:17 | 14:27 | MAIN SUPPLY FAILURE |
| 508 | 27-Jul-2022 | HASSAN | 66 | HV1 | MOSALEHOSAHALLI_66 | 2:50 | 4:00 | 1:10 | MAIN SUPPLY FAILURE |
| 509 | 27-Jul-2022 | HASSAN | 66 | HV1 | MOSALEHOSAHALLI_66 | 17:11 | 17:18 | 0:07 | HAND TRIPPED |
| 510 | 27-Jul-2022 | HASSAN | 66 | HV1 | NAGARTHI_66 | 2:20 | 5:20 | 3:00 | MAIN SUPPLY FAILURE |
| 511 | 27-Jul-2022 | HASSAN | 66 | HV1 | NAGARTHI_66 | 9:05 | 10:05 | 1:00 | MAIN SUPPLY FAILURE |
| 512 | 27-Jul-2022 | HASSAN | 66 | HV1 | NAGARTHI_66 | 16:45 | 17:01 | 0:16 | MAIN SUPPLY FAILURE |
| 513 | 27-Jul-2022 | HASSAN | 66 | RAMNAT-BNDSTHL | RAMNATHPURA_66 | 8:57 | 9:07 | 0:10 | LINE FAULT |
| 514 | 27-Jul-2022 | HASSAN | 66 | RAMNAT-BNDSTHL | RAMNATHPURA_66 | 9:10 | 9:20 | 0:10 | LINE FAULT |
| 515 | 27-Jul-2022 | HASSAN | 66 | RAMNAT-BNDSTHL | RAMNATHPURA_66 | 9:55 | 10:02 | 0:07 | LINE FAULT |
| 516 | 27-Jul-2022 | HASSAN | 66 | HV2 | RAMNATHPURA_66 | 2:20 | 4:15 | 1:55 | MAIN SUPPLY FAILURE |
| 517 | 27-Jul-2022 | HASSAN | 66 | HV2 | RAMNATHPURA_66 | 17:31 | 17:58 | 0:27 | HAND TRIPPED |
| 518 | 27-Jul-2022 | HASSAN | 66 | RAMNAT-KUSALNAGARA | RAMNATHPURA_66 | 2:20 | 4:15 | 1:55 | MAIN SUPPLY FAILURE |
| 519 | 27-Jul-2022 | HASSAN | 66 | SHANTHI-RMSWRNGR | SHANTHIGRAMA_66 | 17:46 | 17:56 | 0:10 | HAND TRIPPED |
| 520 | 27-Jul-2022 | HASSAN | 66 | SHANTHI-UDYAPURA | SHANTHIGRAMA_66 | 17:46 | 17:55 | 0:09 | HAND TRIPPED |
| 521 | 27-Jul-2022 | HASSAN | 66 | SIGEBAG-KDLGRE | SIGEBAGE_66 | 15:25 | 15:47 | 0:22 | LINE FAULT |
| 522 | 27-Jul-2022 | HASSAN | 66 | UDAYAP-SHANTIGRAMA | UDAYAPURA_66 | 9:03 | 18:27 | 9:24 | LINE CLEAR AVAILED |
| 523 | 27-Jul-2022 | MYSURU | 66 | CRNAGARA-HONGANUR | HONAGNUR AND YELANDUR | 6:57 | 7:10 | 0:12 | LINE FAULT |
| 524 | 27-Jul-2022 | MYSURU | 66 | CRNAGARA-KOLLEGALA | NO STATIONS EFFECTED | 15:36 | 15:46 | 0:09 | LINE FAULT |
| 525 | 27-Jul-2022 | MYSURU | 66 | DEVNUR(N'GUD)-HV1 | NO STATIONS EFFECTED | 15:50 | 17:11 | 1:20 | LINE CLEAR AVAILED |
| 526 | 27-Jul-2022 | MYSURU | 66 | DK MAIDANA-VAJAMANGALA | JYOTHINAGARA | 19:57 | 21:02 | 1:04 | LINE FAULT |
| 527 | 27-Jul-2022 | MYSURU | 66 | FTS-JYOTHINAGAR | JYOTHINAGARA | 19:40 | 21:46 | 2:06 | LINE FAULT |
| 528 | 27-Jul-2022 | MYSURU | 66 | HANAGODU-HV1 | NO STATIONS EFFECTED | 13:03 | 14:12 | 1:08 | LINE CLEAR AVAILED |
| 529 | 27-Jul-2022 | MYSURU | 66 | JYOTHINAGARA-FTS | NO STATIONS EFFECTED | 1:23 | 1:49 | 0:26 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|--------------------------------|--|----------------------------|-----------|----------|-------------------------------------|
| 530 | 27-Jul-2022 | MYSURU | 66 | JYOTHINAGARA-DKMAIDANA | JYOTHINAGARA | 19:40 | 20:41 | 1:01 | LINE FAULT |
| 531 | 27-Jul-2022 | MYSURU | 66 | JYOTHINAGARA-VAJAMANGALA | JYOTHINAGARA | 19:40 | 21:02 | 1:22 | LINE FAULT |
| 532 | 27-Jul-2022 | MYSURU | 66 | KADAKOLA-MANDKALLI | NO STATIONS EFFECTED | 20:07 | 20:50 | 0:43 | LINE FAULT |
| 533 | 27-Jul-2022 | MYSURU | 66 | KIADBMANDYA-HV1 | NO STATIONS EFFECTED | 14:40 | 14:51 | 0:11 | MAIN SUPPLY FAILURE |
| 534 | 27-Jul-2022 | MYSURU | 66 | KIADBMANDYA-HV2 | NO STATIONS EFFECTED | 14:40 | 14:51 | 0:11 | MAIN SUPPLY FAILURE |
| 535 | 27-Jul-2022 | MYSURU | 66 | KMDODDI-HV1 | NO STATIONS EFFECTED | 14:40 | 14:50 | 0:10 | MAIN SUPPLY FAILURE |
| 536 | 27-Jul-2022 | MYSURU | 66 | KMDODDI-HV2 | NO STATIONS EFFECTED | 14:40 | 14:50 | 0:10 | MAIN SUPPLY FAILURE |
| 537 | 27-Jul-2022 | MYSURU | 66 | KR PETE 220-HV1 | NO STATIONS EFFECTED | 12:37 | 15:37 | 2:59 | LINE CLEAR AVAILED |
| 538 | 27-Jul-2022 | MYSURU | 66 | KR PETE 220-HV2 | NO STATIONS EFFECTED | 11:02 | 12:35 | 1:33 | LINE CLEAR AVAILED |
| 539 | 27-Jul-2022 | MYSURU | 220 | KR PETE 220-HV1 | NO STATIONS EFFECTED | 10:08 | 13:51 | 3:43 | LINE CLEAR AVAILED |
| 540 | 27-Jul-2022 | MYSURU | 220 | KR PETE 220-HV2 | NO STATIONS EFFECTED | 13:58 | 16:46 | 2:48 | LINE CLEAR AVAILED |
| 541 | 27-Jul-2022 | MYSURU | 66 | KUSHALNAGAR220-RAMANTHAPURA1 | ALUR SIDDAPURA & KANAGAL | 17:45 | 17:49 | 0:03 | HAND TRIPPED |
| 542 | 27-Jul-2022 | MYSURU | 66 | MADDUR-HV1 | NO STATIONS EFFECTED | 14:41 | 14:52 | 0:11 | MAIN SUPPLY FAILURE |
| 543 | 27-Jul-2022 | MYSURU | 66 | MADDUR-HV2 | NO STATIONS EFFECTED | 14:41 | 14:51 | 0:10 | MAIN SUPPLY FAILURE |
| 544 | 27-Jul-2022 | MYSURU | 66 | MANDYA-HV2 | NO STATIONS EFFECTED | 14:30 | 14:35 | 0:05 | LINE FAULT |
| 545 | 27-Jul-2022 | MYSURU | 66 | KOPPA-HV1 | NO STATIONS EFFECTED | 11:51 | 12:41 | 0:50 | LINE FAULT |
| 546 | 27-Jul-2022 | MYSURU | 66 | KIADB SOMANAHALLI-HV1 | NO STATIONS EFFECTED | 14:40 | 14:51 | 0:11 | MAIN SUPPLY FAILURE |
| 547 | 27-Jul-2022 | MYSURU | 66 | MANDGERE-HV1 | NO STATIONS EFFECTED | 2:25 | 5:15 | 2:50 | MAIN SUPPLY FAILURE |
| 548 | 27-Jul-2022 | MYSURU | 66 | MANDGERE-HV1 | NO STATIONS EFFECTED | 9:05 | 10:05 | 1:00 | MAIN SUPPLY FAILURE |
| 549 | 27-Jul-2022 | MYSURU | 66 | MANDGERE-HV1 | NO STATIONS EFFECTED | 16:45 | 17:00 | 0:15 | MAIN SUPPLY FAILURE |
| 550 | 27-Jul-2022 | MYSURU | 66 | ADDIHALLI-BG NAGARA | AC GIRI, BG NAGARA & VADERALLI | 16:53 | 16:58 | 0:05 | LINE FAULT |
| 551 | 27-Jul-2022 | MYSURU | 66 | HONNALLI-HV2 | NO STATIONS EFFECTED | 16:50 | 18:35 | 1:45 | LINE CLEAR AVAILED |
| 552 | 27-Jul-2022 | MYSURU | 66 | HARADANAHALLI-HV1 | NO STATIONS EFFECTED | 2:20 | 5:20 | 3:00 | MAIN SUPPLY FAILURE |
| 553 | 27-Jul-2022 | MYSURU | 66 | HARADANAHALLI-HV2 | NO STATIONS EFFECTED | 2:20 | 5:20 | 3:00 | MAIN SUPPLY FAILURE |
| 554 | 27-Jul-2022 | MYSURU | 66 | HARADANAHALLI-HV1 | NO STATIONS EFFECTED | 17:05 | 17:20 | 0:15 | MAIN SUPPLY FAILURE |
| 555 | 27-Jul-2022 | MYSURU | 66 | HARADANAHALLI-HV2 | NO STATIONS EFFECTED | 17:05 | 17:20 | 0:15 | MAIN SUPPLY FAILURE |
| 556 | 27-Jul-2022 | MYSURU | 66 | HV1 | GUNDLUPETE_66 | 17:02:00 (12.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 557 | 27-Jul-2022 | MYSURU | 220 | HV2 | MADHUVANAHALLI_220 | 18:57:18 (31.5.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 558 | 27-Jul-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 6:26:00 PM (22/04/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 559 | 27-Jul-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16:00 (08/12/2021) | | | LINE OPEN , LINE CLEAR AVAILED |
| 560 | 27-Jul-2022 | MYSURU | 220 | HV1 | KADAKOLA_220 | 1:41:14 (21/07/2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 561 | 27-Jul-2022 | TUMKUR | 220 | DAVANGERE SRS- GUTTUR-1 | DAVANGERE_SRS_220 | 08:02(22.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 562 | 27-Jul-2022 | TUMKUR | 220 | TR1 | PAVAGADA_220 | 18:20 | 18:30 | 0:10 | TRANSFORMER FAULT |
| 563 | 27-Jul-2022 | TUMKUR | 220 | TR2 | PAVAGADA_220 | 18:20 | 18:30 | 0:10 | TRANSFORMER FAULT |
| 564 | 27-Jul-2022 | TUMKUR | 220 | ANTHRASANAHALLI 220KV-KBCROSS | ANTHRASANAHALLI_220 | 10:06 | 17:26 | 7:20 | LINE CLEAR AVAILED |
| 565 | 27-Jul-2022 | TUMKUR | 220 | DAVANGERE SRS- SHIMOGA 2 | DAVANGERE_SRS_220 | 14:20(27.07.2022) | | | LINE OPEN, LINE FAULT |
| 566 | 27-Jul-2022 | TUMKUR | 220 | NITTUR 220-NELAMANGALA | NITTUR_220 | 12:03 | 14:02 | 1:59 | LINE FAULT |
| 567 | 27-Jul-2022 | TUMKUR | 66 | NARENDRA LINE-1-GUTTUR | GUTTUR_400 | 00:01(23.07.2022) | | | LOAD CURTAILMENT |
| 568 | 27-Jul-2022 | TUMKUR | 66 | GUTTUR_400DAVANGERE LINE -1 | GUTTUR_400 | 00:08(23.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 569 | 27-Jul-2022 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- BELLAVI | BELLAVI_66,MALLASANDRA_66, HEGGERE_66, DODDASARANGI_66 | 19:26 | 19:42 | 0:16 | LOAD CURTAILMENT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|--|---|---------|-----------|----------|---------------------|
| 570 | 27-Jul-2022 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- MELEKOTE | MELKOTE_66, BADDIHALLI_66 | 19:26 | 19:33 | 0:07 | LOAD CURTAILMENT |
| 571 | 27-Jul-2022 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- CHELUR | CHELURU_66, HOSAKERE_66, HAGAL WADI_66 | 19:26 | 20:15 | 0:49 | LOAD CURTAILMENT |
| 572 | 27-Jul-2022 | TUMKUR | 66 | URDIGERE-ANTHRASANAHALLI | URDIGERE_66 | 19:26 | 20:20 | 0:54 | LOAD CURTAILMENT |
| 573 | 27-Jul-2022 | TUMKUR | 66 | ANCHEPALYA 220- ANCHEPALYA 2 | KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA | 11:30 | 17:53 | 6:23 | LINE CLEAR AVAILED |
| 574 | 27-Jul-2022 | TUMKUR | 66 | ANCHEPALYA 220- BG NAGAR | BG NAGAR | 6:40 | 7:01 | 0:21 | LOAD CURTAILMENT |
| 575 | 27-Jul-2022 | TUMKUR | 66 | ANCHEPALYA 220kV- HULIYURDURGA | HULIYURDURGA_66, CHAWANAKUPPE_66 | 17:36 | 23:37 | 6:01 | LINE FAULT |
| 576 | 27-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- DAVANGERE | DAVANAGERE_66,KADAJJI_66,MELEKATTE_66 | 13:01 | 15:00 | 1:59 | LINE CLEAR AVAILED |
| 577 | 27-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- KUKKAWADA | KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66 | 19:55 | 20:22 | 0:27 | HAND TRIPPED |
| 578 | 27-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- HARIHARA | HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66 | 19:55 | 20:22 | 0:27 | HAND TRIPPED |
| 579 | 27-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- HARIHARA | HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66 | 23:20 | 23:48 | 0:28 | LINE FAULT |
| 580 | 27-Jul-2022 | TUMKUR | 66 | HIRIYUR 220KV- PARSHAMPURA | PARSHAMPURA_66 | 6:30 | 7:18 | 0:48 | LINE FAULT |
| 581 | 27-Jul-2022 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR1 | WELSPUNSOLAR1_IPP_66 | 8:38 | 8:49 | 0:11 | LINE FAULT |
| 582 | 27-Jul-2022 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR2 | WELSPUN SOLAR2 | 8:38 | 8:49 | 0:11 | LINE FAULT |
| 583 | 27-Jul-2022 | TUMKUR | 66 | THALLAK 220kV- SEI VENUS DIAMOND_IPP_66 | SEI VENUS DIAMOND_IPP_66 | 12:16 | 12:30 | 0:14 | HAND TRIPPED |
| 584 | 27-Jul-2022 | TUMKUR | 66 | PAVAGDA_220- SHYLAPURA_66 | SHYLAPURA_66 | 18:20 | 18:35 | 0:15 | LINE FAULT |
| 585 | 27-Jul-2022 | TUMKUR | 66 | BILCHODU66-UCHANGIDURGA66 | BILCHODU_66 | 9:00 | 9:15 | 0:15 | MAIN SUPPLY FAILURE |
| 586 | 27-Jul-2022 | TUMKUR | 66 | BILCHODU66-UCHANGIDURGA66 | BILCHODU_66 | 9:25 | 9:35 | 0:10 | MAIN SUPPLY FAILURE |
| 587 | 27-Jul-2022 | TUMKUR | 66 | BILCHODU66-UCHANGIDURGA66 | BILCHODU_66 | 13:05 | 15:00 | 1:55 | MAIN SUPPLY FAILURE |
| 588 | 27-Jul-2022 | TUMKUR | 66 | TR2 | IDHALLY_66 | 1:35 | 1:40 | 0:05 | TRANSFORMER FAULT |
| 589 | 27-Jul-2022 | TUMKUR | 66 | BADDIHALLI66-MELKOTE66 | BADDIHALLI_66 | 19:35 | 20:15 | 0:40 | HAND TRIPPED |
| 590 | 27-Jul-2022 | TUMKUR | 66 | KORATAGERE66-MADHUGIRI | KORATAGERE_66 | 12:55 | 13:05 | 0:10 | LINE FAULT |
| 591 | 27-Jul-2022 | TUMKUR | 66 | HOLALKERE- RAMGIRI 1 | HOLALKERE_66 | 5:55 | 6:00 | 0:05 | LINE FAULT |
| 592 | 27-Jul-2022 | TUMKUR | 66 | HOLALKERE- RAMGIRI 1 | HOLALKERE_66 | 12:00 | 12:10 | 0:10 | LINE FAULT |
| 593 | 27-Jul-2022 | TUMKUR | 66 | HOLALKERE- RAMGIRI 1 | HOLALKERE_66 | 13:55 | 14:05 | 0:10 | LINE FAULT |
| 594 | 27-Jul-2022 | TUMKUR | 66 | MAYAKONDA-SASALUHALLA | SASALUHALLA_66,CHIKKAJAJUR_66 | 14:20 | 14:25 | 0:05 | LINE FAULT |
| 595 | 27-Jul-2022 | TUMKUR | 66 | NAGALAMADIKE-MADHUGIRI | NAGALMADIKE_66 | 11:00 | 14:30 | 3:30 | NFBC ISSUED |
| 596 | 27-Jul-2022 | TUMKUR | 66 | TR1 | PDKOTE_66 | 8:55 | 9:05 | 0:10 | TRANSFORMER FAULT |
| 597 | 27-Jul-2022 | TUMKUR | 66 | AZURE POWER | PDKOTE_66 | 9:45 | 9:55 | 0:10 | HAND TRIPPED |
| 598 | 27-Jul-2022 | TUMKUR | 66 | HARIYABBE-PD KOTE | PDKOTE_66 | 11:30 | 14:55 | 3:25 | NFBC ISSUED |
| 599 | 27-Jul-2022 | TUMKUR | 66 | TR1 | SAVALANGA_66 | 13:45 | 16:45 | 3:00 | LINE CLEAR AVAILED |
| 600 | 27-Jul-2022 | TUMKUR | 66 | TR1 | THIPPUR_66 | 6:40 | 7:00 | 0:20 | MAIN SUPPLY FAILURE |
| 601 | 27-Jul-2022 | TUMKUR | 66 | TR1 | THIPPUR_66 | 15:30 | 16:40 | 1:10 | TRANSFORMER FAULT |
| 602 | 27-Jul-2022 | TUMKUR | 66 | HONNALLI 220kV- KUNDUR66 | KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66 | 9:40 | 9:55 | 0:15 | MAIN SUPPLY FAILURE |
| 603 | 27-Jul-2022 | TUMKUR | 66 | TR1 | HULIYURDURGA_66 | 15:10 | 17:45 | 2:35 | LINE CLEAR AVAILED |
| 604 | 27-Jul-2022 | TUMKUR | 66 | TR2 | HULIYURDURGA_66 | 16:45 | 17:45 | 1:00 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|----------------------------------|---------------------------------------|-----------------------|-----------|----------|-------------------------------------|
| 605 | 27-Jul-2022 | TUMKUR | 66 | TR1 | LOKIKERE_66 | 9:50 | 10:20 | 0:30 | MAIN SUPPLY FAILURE |
| 606 | 27-Jul-2022 | TUMKUR | 66 | TR1 | LOKIKERE_66 | 6:10 | 6:20 | 0:10 | TRANSFORMER FAULT |
| 607 | 27-Jul-2022 | TUMKUR | 66 | MALEBENNUR66-HONNALLI66 | MALEBENNUR_66 | 9:45 | 9:50 | 0:05 | MAIN SUPPLY FAILURE |
| 608 | 28-Jul-2022 | BAGALKOT | 220 | SIRSI-HUBLI-1 | STATION NOT AFFECTED SIRSI_220 | 19:46 (15.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 609 | 28-Jul-2022 | BAGALKOT | 220 | SIRSI-HUBLI-2 | STATION NOT AFFECTED SIRSI_220 | 19:46 (15.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 610 | 28-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED TODALBAGI_110 | 19:13 (17.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 611 | 28-Jul-2022 | BAGALKOT | 110 | TODALBAGI-SAVALAGI | TODALBAGI_110 | 18:00 (20.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 612 | 28-Jul-2022 | BAGALKOT | 110 | SIRSI-SIRSI1&2(KAVALWAD | STATION NOT AFFECTED SIRSI_110 | 12:55 (22.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 613 | 28-Jul-2022 | BAGALKOT | 110 | UTTUR - F1 JAMB CB(MUDHOL) | STATION NOT AFFECTED UTTUR_110 | 9:51 (24.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 614 | 28-Jul-2022 | BAGALKOT | 220 | SOUDATTI-BIDNAL | STATION NOT AFFECTED SOUNDATTI_220 | 9:28 | 9:37 | 0:09 | HAND TRIPPED |
| 615 | 28-Jul-2022 | BAGALKOT | 220 | BIDNAL-SOUDATTI | STATION NOT AFFECTED BIDNAL_220 | 8:47 | 9:36 | 0:49 | LINE FAULT |
| 616 | 28-Jul-2022 | BAGALKOT | 220 | HUBLI-NAGZARI-3 | STATION NOT AFFECTED HUBLI_220 | 10:07 | 10:29 | 0:22 | HAND TRIPPED |
| 617 | 28-Jul-2022 | BAGALKOT | 220 | HUBLI-NAGZARI-2 | STATION NOT AFFECTED HUBLI_220 | 11:16 | 11:44 | 0:28 | HAND TRIPPED |
| 618 | 28-Jul-2022 | BAGALKOT | 220 | HUBLI-NAGZARI-2 | STATION NOT AFFECTED HUBLI_220 | 15:57 | 17:41 | 1:44 | LINE CLEAR AVAILED |
| 619 | 28-Jul-2022 | BAGALKOT | 220 | HUBLI-NAGZARI-2 | STATION NOT AFFECTED HUBLI_220 | 17:43 | 17:48 | 0:05 | HAND TRIPPED |
| 620 | 28-Jul-2022 | BAGALKOT | 220 | HUBLI-NAGZARI-1 | STATION NOT AFFECTED HUBLI_220 | 12:54 | 15:57 | 3:03 | LINE CLEAR AVAILED |
| 621 | 28-Jul-2022 | BAGALKOT | 220 | HUBLI-SIRSI-2 | STATION NOT AFFECTED HUBLI_220 | 12:06 | 12:07 | 0:01 | LINE FAULT |
| 622 | 28-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-LOKAPUR | LOKAPUR_110 | 7:19 | 7:53 | 0:34 | LINE FAULT |
| 623 | 28-Jul-2022 | BAGALKOT | 110 | RANEENNUR220-BYADAGI (GUTTAL) | STATION NOT AFFECTED RANEENNUR_220 | 11:11 | 18:14 | 7:03 | LINE CLEAR AVAILED |
| 624 | 28-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV-1 & LV1 | STATION NOT AFFECTED KARWAR_220 | 11:19 | 12:52 | 1:33 | LINE CLEAR AVAILED |
| 625 | 28-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV2 (HV-4) | STATION NOT AFFECTED GADAG_220 | 3:40 | 11:41 | 8:01 | TRANSFORMER FAULT |
| 626 | 28-Jul-2022 | BAGALKOT | 110 | 220/110KV, LV2 (LV-4) | STATION NOT AFFECTED GADAG_220 | 3:40 | 11:43 | 8:03 | TRANSFORMER FAULT |
| 627 | 28-Jul-2022 | BAGALKOT | 220 | BIDNAL-HARTI-1 | STATION NOT AFFECTED BIDNAL_220 | 12:21 | 19:15 | 6:54 | LINE FAULT |
| 628 | 28-Jul-2022 | BAGALKOT | 220 | BIDNAL-HARTI-2 | STATION NOT AFFECTED BIDNAL_220 | 11:49 | 19:15 | 7:26 | LINE FAULT |
| 629 | 28-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV3 | BILAGI_110 | 13:18 | 13:27 | 0:09 | HAND TRIPPED |
| 630 | 28-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV3 | BILAGI_110 | 15:04 | 15:21 | 0:17 | HAND TRIPPED |
| 631 | 28-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV3 | BILAGI_110 | 18:22 | 18:48 | 0:26 | HAND TRIPPED |
| 632 | 28-Jul-2022 | BAGALKOT | 110 | DADDI-HONAGA | HONAGA_110 | 11:21 | 14:15 | 2:54 | LINE FAULT |
| 633 | 28-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | DEVAR GENNUR_110 | 8:40 | 8:50 | 0:10 | TRANSFORMER FAULT |
| 634 | 28-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | DEVAR GENNUR_110 | 11:40 | 12:02 | 0:22 | HAND TRIPPED |
| 635 | 28-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | HIEMASALI_110 | 15:47 | 15:50 | 0:03 | TRANSFORMER FAULT |
| 636 | 28-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | HIEMASALI_110 | 17:31 | 17:33 | 0:02 | TRANSFORMER FAULT |
| 637 | 28-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | KAMBAGI_110 | 9:23 | 9:33 | 0:10 | TRANSFORMER FAULT |
| 638 | 28-Jul-2022 | BAGALKOT | 110 | 110/33KV,HV3 | LOKAPUR_110 & BATAKURKI,RSSKN_33 | 7:57 | 8:07 | 0:10 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|------------------------------------|---|-----------------------|-----------|----------|-------------------------------------|
| 639 | 28-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | LOKAPUR_110 | 7:57 | 8:01 | 0:04 | TRANSFORMER FAULT |
| 640 | 28-Jul-2022 | BAGALKOT | 220 | MAHALINGPUR-NARENDRA1 | MAHALINGAPUR_220 | 6:47 | 8:00 | 1:13 | LINE FAULT |
| 641 | 28-Jul-2022 | BAGALKOT | 220 | MAHALINGPUR-NARENDRA2 | MAHALINGAPUR_220 | 6:47 | 8:00 | 1:13 | LINE FAULT |
| 642 | 28-Jul-2022 | BAGALKOT | 220 | 220/110KV,HV3 | MAHALINGAPUR_220 | 7:55 | 10:42 | 2:47 | LINE CLEAR AVAILED |
| 643 | 28-Jul-2022 | BAGALKOT | 110 | 110/33KV,HV3 | MAHALINGAPUR_220 & DEMPO , JAGADAL_33 | 6:20 | 6:27 | 0:07 | TRANSFORMER FAULT |
| 644 | 28-Jul-2022 | BAGALKOT | 110 | MAHALINGPUR-HIDIKAL | HIDIKAL_110 | 7:51 | 10:48 | 2:57 | LINE CLEAR AVAILED |
| 645 | 28-Jul-2022 | BAGALKOT | 110 | MAHALINGAPUR-RABAKAVI | RABAKAVI_110 | 7:48 | 11:30 | 3:42 | LINE CLEAR AVAILED |
| 646 | 28-Jul-2022 | BAGALKOT | 110 | NAVALAGI-JAMAKHANDI | JAMAKHANDI_110 | 3:29 | 3:41 | 0:12 | LINE FAULT |
| 647 | 28-Jul-2022 | BAGALKOT | 110 | 110/33,HV3 (33KV HV1) | ZALKI_110, HORTI_33 | 16:41 | 16:50 | 0:09 | HAND TRIPPED |
| 648 | 28-Jul-2022 | BAGALKOT | 110 | 110/33KV,HV4(33KV HV2) | ZALKI_110, DHULKHED_33,NEVARGI_33,HALSANGI_33 | 22:11 | 23:13 | 1:02 | TRANSFORMER FAULT |
| 649 | 28-Jul-2022 | BAGALKOT | 110 | TODALBAGI-JAMKHANDI(JKD SUGARS) | TODALBAGI_110, JKD SUGARS_IPP | 3:15 | 3:42 | 0:27 | LINE FAULT |
| 650 | 28-Jul-2022 | BAGALKOT | 110 | SATTI-RABAKAVI | STATION NOT AFFECTED SATTI_110 | 8:56 | 9:01 | 0:05 | HAND TRIPPED |
| 651 | 28-Jul-2022 | BAGALKOT | 110 | SATTI-RABAKAVI | STATION NOT AFFECTED SATTI_110 | 11:21 | 11:26 | 0:05 | HAND TRIPPED |
| 652 | 28-Jul-2022 | BAGALKOT | 110 | 110/33KV, HV3 | STATION NOT AFFECTED YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 653 | 28-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV1 | STATION NOT AFFECTED AMBEWADI_220 | 20:00 (09.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 654 | 28-Jul-2022 | BAGALKOT | 220 | GADAG-HARTI-2 | STATION NOT AFFECTED GADAG_220 | 10:55 (19.07.2020) | | | LINE OPEN , LINE CLEAR AVAILED |
| 655 | 28-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV-3 & LV3 | STATION NOT AFFECTED ATHANI_220 | 10:26 (25.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 656 | 28-Jul-2022 | BAGALKOT | 220 | NARENDRA-BELAGAVI-2 | STATION NOT AFFECTED NARENDRA_220 | 11:09 (26.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 657 | 28-Jul-2022 | BAGALKOT | 220 | NARENDRA-BELAGAVI-2 | STATION NOT AFFECTED BELAGAVI_220 | 11:21 (28.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 658 | 28-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-RAMDURG | STATION NOT AFFECTED BAGALKOT_220 | 7:05 | 8:21 | 1:16 | LINE FAULT |
| 659 | 28-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV2 | STATION NOT AFFECTED HUBLI_220 | 15:07 | 18:16 | 3:09 | LINE CLEAR AVAILED |
| 660 | 28-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED HUBLI_220 | 16:14 | 18:00 | 1:46 | LINE CLEAR AVAILED |
| 661 | 28-Jul-2022 | BAGALKOT | 220 | HUBLI-SIRSI-2 | STATION NOT AFFECTED HUBLI_220 | 12:54 | 20:15 | 7:21 | LINE FAULT |
| 662 | 28-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV-2 & LV2 | KARWAR_220 | 12:52 | 13:42 | 0:50 | LINE CLEAR AVAILED |
| 663 | 28-Jul-2022 | BAGALKOT | 110 | 220SODATTI-RAMADURGA-1 | STATION NOT AFFECTED RAMADURGA_110 | 8:50 | 12:35 | 3:45 | LINE FAULT |
| 664 | 28-Jul-2022 | BAGALKOT | 220 | GADAG-BAGALKOT-2 | STATION NOT AFFECTED GADAG_220 | 12:05 | 13:08 | 1:03 | LINE CLEAR AVAILED |
| 665 | 28-Jul-2022 | BENGALURU | 66 | HV1 | BAIRKURU | 13:05 | 13:10 | 0:05 | LINE CLEAR AVAILED |
| 666 | 28-Jul-2022 | BENGALURU | 66 | HV2 | BAIRKURU | 14:08 | 14:10 | 0:02 | LINE CLEAR AVAILED |
| 667 | 28-Jul-2022 | BENGALURU | 66 | BAIRKURU - NANGLI | BAIRKURU | 15:10 | 15:40 | 0:30 | LINE CLEAR AVAILED |
| 668 | 28-Jul-2022 | BENGALURU | 66 | KANAKAPURA 220 - RAMANAGARA | ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE | 15:29 | 15:39 | 0:10 | LINE FAULT |
| 669 | 28-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - SIDLAGHATTA | SIDLAGHATTA, MELUR | 10:06 | 10:14 | 0:08 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--|---|---------|-----------|----------|---------------------|
| 670 | 28-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - YENNIGADALE | YENNIGADALE, CHELUR, CHAKAVELU | 19:37 | 19:55 | 0:18 | LOAD CURTAILMENT |
| 671 | 28-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - IRGAMPALLI | IRAGAMPALLI, M GOLLAHALLI | 19:37 | 19:58 | 0:21 | LOAD CURTAILMENT |
| 672 | 28-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - GANJIGUNTE 1 | GANJIGUNTE, PALLICHERLU | 19:37 | 20:00 | 0:23 | LOAD CURTAILMENT |
| 673 | 28-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - GANJIGUNTE 2 | GANJIGUNTE, PALLICHERLU | 19:37 | 20:00 | 0:23 | LOAD CURTAILMENT |
| 674 | 28-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - SRINIVASPURA | G KODIHALLI, SRINIVASPURA, YELDUR | 19:37 | 19:53 | 0:16 | LOAD CURTAILMENT |
| 675 | 28-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - LAKSHMIPURA | TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU | 19:37 | 19:59 | 0:22 | LOAD CURTAILMENT |
| 676 | 28-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - TALAGAWARA | TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA | 19:37 | 20:00 | 0:23 | LOAD CURTAILMENT |
| 677 | 28-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - NANDIGANAHALLI | NANDIGANAHALLI | 19:37 | 19:57 | 0:20 | LOAD CURTAILMENT |
| 678 | 28-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - SIDLAGHATTA | SIDLAGHATTA, MELUR | 19:37 | 19:53 | 0:16 | LOAD CURTAILMENT |
| 679 | 28-Jul-2022 | BENGALURU | 66 | HV1 | DEVANAHALLI 66 | 12:04 | 12:06 | 0:02 | LINE CLEAR AVAILED |
| 680 | 28-Jul-2022 | BENGALURU | 66 | HV2 | DEVANAHALLI 66 | 13:56 | 13:59 | 0:03 | LINE CLEAR AVAILED |
| 681 | 28-Jul-2022 | BENGALURU | 66 | HV2 | HONNIGANAHALLI | 12:36 | 12:40 | 0:04 | LINE CLEAR AVAILED |
| 682 | 28-Jul-2022 | BENGALURU | 66 | HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR) | GRINDWELL (EHT) | 19:34 | 19:51 | 0:17 | LOAD CURTAILMENT |
| 683 | 28-Jul-2022 | BENGALURU | 66 | HOSKOTE 220 - HOSKOTE 2(DG3) | BELL CERAMICS (EHT), KONDASPURA | 19:34 | 19:51 | 0:17 | LOAD CURTAILMENT |
| 684 | 28-Jul-2022 | BENGALURU | 66 | HOSKOTE 220 - PILLAGUMPA | PILLAGUMPA | 19:35 | 19:49 | 0:14 | LOAD CURTAILMENT |
| 685 | 28-Jul-2022 | BENGALURU | 66 | HOSKOTE 220 - VOLVO | VOLVO, NANDAGUDI | 19:35 | 19:49 | 0:14 | LOAD CURTAILMENT |
| 686 | 28-Jul-2022 | BENGALURU | 66 | KOLAR 220 - VEMGAL | TALAGUNDA, VEMGAL, KYALNUR | 19:40 | 19:54 | 0:14 | LOAD CURTAILMENT |
| 687 | 28-Jul-2022 | BENGALURU | 66 | KOLAR 220 - THAYLUR | TAMAKA | 19:40 | 19:55 | 0:15 | LOAD CURTAILMENT |
| 688 | 28-Jul-2022 | BENGALURU | 66 | KOLAR 220 - PGCIL AUX | PGCIL AUX, SUGUTUR | 16:16 | 16:31 | 0:15 | LINE FAULT |
| 689 | 28-Jul-2022 | BENGALURU | 66 | LAKSHMIPURA - ADDAGAL | ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU | 14:15 | 14:30 | 0:15 | LINE FAULT |
| 690 | 28-Jul-2022 | BENGALURU | 66 | LAKSHMIPURA - TADIGOLU | LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU | 14:15 | 14:25 | 0:10 | LINE FAULT |
| 691 | 28-Jul-2022 | BENGALURU | 66 | MALUR 220 - KGF 2 | BANGARPETE | 14:36 | 14:54 | 0:18 | LINE CLEAR AVAILED |
| 692 | 28-Jul-2022 | BENGALURU | 66 | MALUR 220 - HOSKOTE 2 | JADIGENAHALLI | 19:32 | 19:48 | 0:16 | LINE FAULT |
| 693 | 28-Jul-2022 | BENGALURU | 66 | MANDIKAL - GUDIBANDE | MANDIKAL | 18:09 | 18:29 | 0:20 | LINE FAULT |
| 694 | 28-Jul-2022 | BENGALURU | 66 | VIDYANAGARA - BEGUR 220 | VIDYANAGARA | 11:30 | 11:35 | 0:05 | LOAD CHANGE OVER |
| 695 | 28-Jul-2022 | BENGALURU | 66 | VIDYANAGARA - HOSKOTE 220 | VIDYANAGARA | 14:45 | 15:00 | 0:15 | LOAD CHANGE OVER |
| 696 | 28-Jul-2022 | BENGALURU | 66 | HULLENAHALLI - ANCHEPALYA 220 | HULLENAHALLI | 19:30 | 20:00 | 0:30 | MAIN SUPPLY FAILURE |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--|---------------------------------|-----------------------|-----------|----------|--------------------------------|
| 697 | 28-Jul-2022 | BENGALURU | 66 | AGALAKOTE - ANCHEPALYA 220 | HULLENAHALLI | 19:30 | 20:00 | 0:30 | MAIN SUPPLY FAILURE |
| 698 | 28-Jul-2022 | BENGALURU | 66 | AGALAKOTE - ANCHEPALYA 220 | MATHIKERE | 19:30 | 20:00 | 0:30 | MAIN SUPPLY FAILURE |
| 699 | 28-Jul-2022 | BENGALURU | 66 | TK HALLI 220 - IGGALUR | IGGALUR,K HONALGERE, YATHAMBADI | 8:31 | 8:47 | 0:16 | LINE FAULT |
| 700 | 28-Jul-2022 | BENGALURU | 220 | TK HALLI 220 - KANAKAPURA 220 | NO STATION AFFECTED | 12:03 | 14:02 | 1:59 | LINE FAULT |
| 701 | 28-Jul-2022 | BENGALURU | 66 | HV1 | MAGADI 220 | 8:29 | 9:29 | 1:00 | LINE CLEAR AVAILED |
| 702 | 28-Jul-2022 | BENGALURU | 66 | IRGAMPALLI - M GOLLAHALLI | M GOLLAHALLI | 17:42 | 18:35 | 0:53 | LINE CLEAR AVAILED |
| 703 | 28-Jul-2022 | BENGALURU | 220 | DB PURA 220 - BIAL BEGUR 220 | NO STATION AFFECTED | 12:04 | 13:50 | 1:46 | LINE FAULT |
| 704 | 28-Jul-2022 | BENGALURU | 66 | DB PURA 220 - DG 2 | GUNDAMGERE,DODDABELAVANGALA | 13:51 | 13:59 | 0:08 | LINE FAULT |
| 705 | 28-Jul-2022 | BENGALURU | 66 | DB PURA 220 - DG 2 | DODDABELAVANGALA | 13:59 | 14:15 | 0:16 | LINE FAULT |
| 706 | 28-Jul-2022 | BENGALURU | 66 | DB PURA 220 - DG 2 | DODDABELAVANGALA | 14:15 | 16:33 | 2:18 | LINE FAULT |
| 707 | 28-Jul-2022 | BENGALURU | 66 | HV1 | BIDADI 220 | 17:42 | 17:52 | 0:10 | LINE CLEAR AVAILED |
| 708 | 28-Jul-2022 | BENGALURU | 66 | HV3 | BIDADI 220 | 18:21 | 18:35 | 0:14 | LINE CLEAR AVAILED |
| 709 | 28-Jul-2022 | BENGALURU | 220 | EAST DIVISION COMPOUND 220 - A STATION 220 | NO STATION AFFECTED | 08:38:00(23/07/2022) | | | LINE OPEN, LINE FAULT |
| 710 | 28-Jul-2022 | BENGALURU | 66 | MANDIKAL - PERESANDRA | NO STATION AFFECTED | 18:09(28/07/2022) | | | LINE OPEN, LINE FAULT |
| 711 | 28-Jul-2022 | GULBARGA | 400 | RTPS-BTPS | RTPS_400 | 0:00 | 12:20 | 12:20 | LINE FAULT |
| 712 | 28-Jul-2022 | GULBARGA | 400 | YTPS-BPS_2 | YTPS_400 | 12:51 | 21:02 | 8:11 | LINE CLEAR AVAILED |
| 713 | 28-Jul-2022 | GULBARGA | 220 | SEDAM_SHAHAPUR | SEDAM_220 | 05:48(10/06/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 714 | 28-Jul-2022 | GULBARGA | 220 | HV2 | BADELADUKU_220 (KUDLIGI) | 4:00 | 4:11 | 0:11 | TRANSFORMER FAULT |
| 715 | 28-Jul-2022 | GULBARGA | 220 | HV1 | SEDAM_220 | 13:05 | 14:25 | 1:20 | TRANSFORMER FAULT |
| 716 | 28-Jul-2022 | GULBARGA | 220 | HV1 | SEDAM_220 | 16:10 | 16:20 | 0:10 | LINE CLEAR AVAILED |
| 717 | 28-Jul-2022 | GULBARGA | 220 | SHAHAPUR-SHAHABAD | SHAHABAD_220 | 12:24 | 21:14 | 8:50 | LINE CLEAR AVAILED |
| 718 | 28-Jul-2022 | GULBARGA | 220 | SHAHAPUR-RTPS_2 | SHAHAPUR_220 | 20:21 | 20:30 | 0:09 | LINE FAULT |
| 719 | 28-Jul-2022 | GULBARGA | 220 | SHAHAPUR-LINGASUGUR | SHAHAPUR_220 | 20:21 | 20:27 | 0:06 | LINE FAULT |
| 720 | 28-Jul-2022 | GULBARGA | 220 | SINDHANOOR-SULEKAL | SINDHANOOR_220 | 2:22 | 2:32 | 0:10 | LINE FAULT |
| 721 | 28-Jul-2022 | GULBARGA | 220 | LINGSUGUR-SHAHAPUR | LINGSUGUR_220 | 20:21 | 20:27 | 0:06 | LINE FAULT |
| 722 | 28-Jul-2022 | GULBARGA | 220 | LINGAPUR-BTPS | LINGAPUR_220 | 13:10 | 18:47 | 5:37 | LINE CLEAR AVAILED |
| 723 | 28-Jul-2022 | GULBARGA | 220 | SHAHAPUR-KAPNOOR | KAPNOOR_220 | 20:42 | 20:50 | 0:08 | LINE CLEAR AVAILED |
| 724 | 28-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR1 | JEWARGI_110 | 12:15(15/06/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 725 | 28-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR2 | NALWAR_110 | 15:10(14/06/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 726 | 28-Jul-2022 | GULBARGA | 110 | HUMNABAD-HALLIKHED | HALLIKHED_110 | 9:34(20/07/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 727 | 28-Jul-2022 | GULBARGA | 110 | HUMNABAD-HALBARGA | HALBARGA_110 | 3:54(20/07/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 728 | 28-Jul-2022 | GULBARGA | 110 | MALLAT-BYAGWAT | BYAGWAT_110,VALKAMDINNI_110 | 23:57(28.07.2022) | | | LINE OPEN, LINE FAULT |
| 729 | 28-Jul-2022 | GULBARGA | 110 | YELBURGA-PRPJSR_IPP | YELBURGA_110 | 19:25(28.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 730 | 28-Jul-2022 | GULBARGA | 110 | HV2 | SREERAMANAGAR_110 | 5:50 | 6:01 | 0:11 | TRANSFORMER FAULT |
| 731 | 28-Jul-2022 | GULBARGA | 110 | HV1 | KUSTAGI_220 | 19:14 | 19:30 | 0:16 | TRANSFORMER FAULT |
| 732 | 28-Jul-2022 | GULBARGA | 110 | HV3 | MUNIRABAD_220 | 17:53 | 18:33 | 0:40 | LINE CLEAR AVAILED |
| 733 | 28-Jul-2022 | GULBARGA | 110 | YELBURGA-PRPJSR_IPP | YELBURGA_110 | 9:17 | 9:20 | 0:03 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|---------------------------|--|---------|-----------|----------|---------------------|
| 734 | 28-Jul-2022 | GULBARGA | 110 | YELBURGA-PRPJSR_1PP | YELBURGA_110 | 3:40 | 3:58 | 0:18 | LINE FAULT |
| 735 | 28-Jul-2022 | GULBARGA | 110 | YELBURGA-TALAKUTAI_1PP | YELBURGA_110 | 11:05 | 11:25 | 0:20 | LINE CLEAR AVAILED |
| 736 | 28-Jul-2022 | GULBARGA | 110 | YELBURGA-KUKUNOOR | KUKUNOOR_110 | 13:18 | 13:20 | 0:02 | LINE CLEAR AVAILED |
| 737 | 28-Jul-2022 | GULBARGA | 110 | GURUMITAKAL-KONKAL | KONKAL_110,YADGIR_110 | 8:19 | 8:24 | 0:05 | LINE FAULT |
| 738 | 28-Jul-2022 | GULBARGA | 110 | GURUMITAKAL-KONKAL | KONKAL_110,YADGIR_110 | 19:05 | 19:12 | 0:07 | LINE FAULT |
| 739 | 28-Jul-2022 | GULBARGA | 110 | YAPALDINNI-VADAVATI | YAPALDINNI_110 | 1:30 | 1:40 | 0:10 | MAIN SUPPLY FAILURE |
| 740 | 28-Jul-2022 | GULBARGA | 110 | AURAD-SANTHAPUR | AURAD_110,DONGARGOA_110 | 20:10 | 20:15 | 0:05 | MAIN SUPPLY FAILURE |
| 741 | 28-Jul-2022 | GULBARGA | 110 | NALEAR-CLEAN SOLAR_1PP | NALWAR_110 | 20:25 | 20:35 | 0:10 | LINE FAULT |
| 742 | 28-Jul-2022 | GULBARGA | 110 | CHINCHOLI-RENEW SOLAR_1PP | CHINCHOLI_110 | 19:00 | 22:10 | 3:10 | LINE CLEAR AVAILED |
| 743 | 28-Jul-2022 | GULBARGA | 110 | HUNSAGI-KEMBHAVI | HUNSAGI_110 | 12:10 | 13:00 | 0:50 | MAIN SUPPLY FAILURE |
| 744 | 28-Jul-2022 | GULBARGA | 110 | SEDAM-VICAT SAGAR_1PP | SEDAM_220 | 0:10 | 0:20 | 0:10 | LINE FAULT |
| 745 | 28-Jul-2022 | GULBARGA | 110 | SEDAM-VICAT SAGAR_1PP | SEDAM_220 | 0:40 | 0:50 | 0:10 | LINE FAULT |
| 746 | 28-Jul-2022 | GULBARGA | 110 | SEDAM-VICAT SAGAR_1PP | SEDAM_220 | 3:10 | 15:10 | 12:00 | LINE FAULT |
| 747 | 28-Jul-2022 | GULBARGA | 110 | SEDAM-VICAT SAGAR_1PP | SEDAM_220 | 20:10 | 21:15 | 1:05 | LINE FAULT |
| 748 | 28-Jul-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | SAIDAPUR_110 | 4:50 | 4:55 | 0:05 | LINE FAULT |
| 749 | 28-Jul-2022 | GULBARGA | 110 | MALLAT-ALKOD | ALKOD_110,GALAG_110 | 1:49 | 1:59 | 0:10 | LINE FAULT |
| 750 | 28-Jul-2022 | GULBARGA | 110 | MALLAT-ALKOD | ALKOD_110,GALAG_110 | 2:20 | 2:30 | 0:10 | LINE FAULT |
| 751 | 28-Jul-2022 | GULBARGA | 110 | MALLAT-ALKOD | ALKOD_110,GALAG_110 | 5:15 | 5:45 | 0:30 | LINE FAULT |
| 752 | 28-Jul-2022 | GULBARGA | 110 | MALLAT-ALKOD | ALKOD_110,GALAG_110 | 6:10 | 6:55 | 0:45 | LINE FAULT |
| 753 | 28-Jul-2022 | GULBARGA | 110 | MALLAT-SIRWAR | SIRWAR_110 | 21:58 | 22:08 | 0:10 | LINE FAULT |
| 754 | 28-Jul-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVIAMARESHWARA_110,MANVI_110 | 22:20 | 22:39 | 0:19 | LINE FAULT |
| 755 | 28-Jul-2022 | GULBARGA | 110 | ALIPUR-BELLARY NORTH1 | SOMASAMUNDRA_110,BELLARY NORTH_110,MOKA_110,P.D HALLI_110,BISLHALLI_110,JANAKI_1PP,BASAI STEEL ACC_110 | 4:22 | 4:55 | 0:33 | LINE FAULT |
| 756 | 28-Jul-2022 | GULBARGA | 110 | ALIPUR-RVNL | RVNL_110 | 4:24 | 6:30 | 2:06 | LINE FAULT |
| 757 | 28-Jul-2022 | GULBARGA | 110 | ALIPUR-MINARA | MINARA_1PP | 6:40 | 11:50 | 0:22 | LINE CLEAR AVAILED |
| 758 | 28-Jul-2022 | GULBARGA | 110 | RAICHUR-SINDHANOOR1 | SIRWAR_110 | 4:26 | 4:36 | 0:10 | LINE FAULT |
| 759 | 28-Jul-2022 | GULBARGA | 110 | RAICHUR-SINDHANOOR1 | SIRWAR_110 | 5:36 | 5:55 | 0:19 | LINE FAULT |
| 760 | 28-Jul-2022 | GULBARGA | 110 | RAICHUR-SINDHANOOR1 | SIRWAR_110 | 11:03 | 11:07 | 0:04 | LINE FAULT |
| 761 | 28-Jul-2022 | GULBARGA | 110 | RAICHUR-SINDHANOOR1 | SIRWAR_110 | 23:35 | 23:40 | 0:05 | LINE FAULT |
| 762 | 28-Jul-2022 | GULBARGA | 110 | SHAHABAD-BAGEWADI2 | YADRAMI_110,MORATAGI_110 | 1:12 | 1:15 | 0:35 | LINE FAULT |
| 763 | 28-Jul-2022 | GULBARGA | 110 | HALBARGA-SANTAPUR | SANTAPUR_110,DONGARGOAN_110,DIGGI_110 | 18:50 | 18:56 | 0:06 | LINE FAULT |
| 764 | 28-Jul-2022 | GULBARGA | 110 | SULEKAL-MALLAPUR | MALLAPUR_110 | 13:35 | 13:45 | 0:10 | LINE FAULT |
| 765 | 28-Jul-2022 | GULBARGA | 110 | HUMNABAD-ALAND | ALAND_110,KADAGANCHI_110 | 19:32 | 20:02 | 0:30 | LOAD CURTAILMENT |
| 766 | 28-Jul-2022 | GULBARGA | 110 | HUMNABAD-MANEIKHELLI | MANAIKHELLI_110 | 19:32 | 20:04 | 0:32 | LOAD CURTAILMENT |
| 767 | 28-Jul-2022 | GULBARGA | 110 | HUMNABAD-CHITAGUPPA | CHITAGUPPA_110, NIRNA_110 | 19:32 | 20:02 | 0:30 | LOAD CURTAILMENT |
| 768 | 28-Jul-2022 | GULBARGA | 110 | HUMNABAD-BHALKI | BHALKI_110,LADHA_110,MGSSK_1PP,BSSK_1PP | 19:32 | 20:04 | 0:32 | LOAD CURTAILMENT |
| 769 | 28-Jul-2022 | GULBARGA | 110 | HUMNABAD-HUMNABAD_2 | HUMNABAD_110 | 19:32 | 20:06 | 0:34 | LOAD CURTAILMENT |
| 770 | 28-Jul-2022 | GULBARGA | 110 | HUMNABAD-SASTHAPUR | RAJESHWAR_110,SASTHAPUR_110,MANTHAL_110 | 19:32 | 20:07 | 0:35 | LOAD CURTAILMENT |
| 771 | 28-Jul-2022 | GULBARGA | 66 | HV2 | HALVAGALU_66 | 9:15 | 9:20 | 0:05 | TRANSFORMER FAULT |
| 772 | 28-Jul-2022 | GULBARGA | 66 | HV2 | BENNEHALLI_66 | 4:05 | 4:10 | 0:05 | TRANSFORMER FAULT |
| 773 | 28-Jul-2022 | GULBARGA | 66 | HV1,HV2 | PUNABGATTA_66 | 10:50 | 11:55 | 1:05 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--------------------------|--|-------------------|-----------------------|------------|-----------------------|
| 774 | 28-Jul-2022 | GULBARGA | 66 | ITTAGI-HIREHADAGALI_2 | HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66, SOVENHALLI_66, TUNGA BHADRA_IPP | 5:51 | 6:08 | 0:17 | LINE FAULT |
| 775 | 28-Jul-2022 | GULBARGA | 66 | BENVEKAL-AVADA SOLAR_IPP | BENVEKAL_66 | 1:00 | 1:35 | 0:35 | LINE FAULT |
| 776 | 28-Jul-2022 | GULBARGA | 66 | PUNABGATTA-NEELGUNDA | PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJAINI_66 | 5:20 | 5:30 | 0:10 | LINE FAULT |
| 777 | 28-Jul-2022 | GULBARGA | 66 | BADELADUKU-KOTTUR | KOTTUR_66 | 4:00 | 12:20 | 8:20 | LINE FAULT |
| 778 | 28-Jul-2022 | HASSAN | 220 | CRPATNA-HSN400 | CRPATNA_220 | 13:34(15.07.2022) | | | LINE OPEN, LINE FAULT |
| 779 | 28-Jul-2022 | HASSAN | 220 | MRSSHM-HONNALLI | MRSMSG_2220 | 12:44(27.07.2022) | | | LINE OPEN, LINE FAULT |
| 780 | 28-Jul-2022 | HASSAN | 400 | UPCL-HASSAN2 | upcl_gen | 23:39(27.07.2022) | 6:44(28.07.2022) | 7:04 hrs | LINE CHARGED |
| 781 | 28-Jul-2022 | HASSAN | 110 | HV2 | HOSANGADI_110 | 20:43(27.07.2022) | 0:14(28.07.2022) | 3:30 hrs | TRANSFORMER CHARGED |
| 782 | 28-Jul-2022 | HASSAN | 66 | CHANNAR-MALLALI | CHANNARARAYPATNA_66 | 12:26(22.07.2022) | 19:05 (28.07.2022) | 150:38 hrs | LINE CHARGED |
| 783 | 28-Jul-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY3 | MRSMSG_220 | 11:07 | 14:50 | 3:43 | LINE FAULT |
| 784 | 28-Jul-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY4 | MRSMSG_220 | 15:30 | 15:52 | 0:22 | LINE FAULT |
| 785 | 28-Jul-2022 | HASSAN | 220 | SHRAVTY-SHIMOGA3 | gen_sharavthy | 11:07 | 14:50 | 3:43 | LINE FAULT |
| 786 | 28-Jul-2022 | HASSAN | 220 | SHRAVTY-SHIMOGA4 | gen_sharavthy | 15:30 | 15:52 | 0:22 | LINE FAULT |
| 787 | 28-Jul-2022 | HASSAN | 220 | SHRAVTY-SIRISI 1 | gen_sharavthy | 10:47(27.7.22) | | | LINE OPEN, LINE FAULT |
| 788 | 28-Jul-2022 | HASSAN | 110 | HV1 | ARASIKERE_110 | 12:30 | 13:05 | 0:35 | LINE CLEAR AVAILED |
| 789 | 28-Jul-2022 | HASSAN | 110 | HV1 | GANDASI_110 | 15:48 | 18:17 | 2:29 | LINE CLEAR AVAILED |
| 790 | 28-Jul-2022 | HASSAN | 110 | HV2 | GANDASI_110 | 13:01 | 15:12 | 2:11 | LINE CLEAR AVAILED |
| 791 | 28-Jul-2022 | HASSAN | 110 | KADUR-NERELEKERE | KADUR_220 | 14:27 | 14:59 | 0:32 | LINE FAULT |
| 792 | 28-Jul-2022 | HASSAN | 110 | KADUR-NGNHL | KADUR_220 | 19:39 | 20:05 | 0:26 | HAND TRIPPED |
| 793 | 28-Jul-2022 | HASSAN | 110 | KADUR-YGTI | KADUR_220 | 19:40 | 20:06 | 0:26 | HAND TRIPPED |
| 794 | 28-Jul-2022 | HASSAN | 110 | HV2 | KARAYA_110 | 6:52 | 11:53 | 5:01 | LINE CLEAR AVAILED |
| 795 | 28-Jul-2022 | HASSAN | 110 | HV1 | KEMAR_220 | 0:38 | 0:43 | 0:05 | TRANSFORMER FAULT |
| 796 | 28-Jul-2022 | HASSAN | 110 | KEMAR-NANDHIKUR1 | KEMAR_220 | 11:47 | 13:05 | 1:18 | LINE CLEAR AVAILED |
| 797 | 28-Jul-2022 | HASSAN | 110 | KEMAR-NANDHIKUR2 | KEMAR_220 | 10:03 | 14:32 | 4:29 | NFBC ISSUED |
| 798 | 28-Jul-2022 | HASSAN | 110 | KEMAR-KARKALA | KEMAR_220 | 11:39 | 12:12 | 0:33 | LINE CLEAR AVAILED |
| 799 | 28-Jul-2022 | HASSAN | 110 | HV1 | SHIVAPURA_110 | 18:12 | 18:36 | 0:24 | LINE CLEAR AVAILED |
| 800 | 28-Jul-2022 | HASSAN | 110 | SHRLKP-SHIKARIPURA | SHIRALKOPPA_220 | 12:26 | 13:01 | 0:35 | LINE FAULT |
| 801 | 28-Jul-2022 | HASSAN | 66 | CHANNAR-HIRESAVE | CHANNARARAYPATNA_66 | 18:49 | 19:13 | 0:24 | LINE FAULT |
| 802 | 28-Jul-2022 | HASSAN | 66 | CHANNAR-UDAYAPURA | CHANNARARAYPATNA_66 | 13:33 | 13:51 | 0:18 | LINE FAULT |
| 803 | 28-Jul-2022 | HASSAN | 66 | GENDEHA-MUDIGERE | GENDEHALLI_66 | 13:06 | 14:30 | 1:24 | LINE CLEAR AVAILED |
| 804 | 28-Jul-2022 | HASSAN | 66 | HNPR2-HASS2 | HOLENARASIPURA_220 | 11:44 | 11:59 | 0:15 | LINE FAULT |
| 805 | 28-Jul-2022 | HASSAN | 66 | HNPR2-MYSOR1 | HOLENARASIPURA_220 | 9:05 | 9:07 | 0:02 | HAND TRIPPED |
| 806 | 28-Jul-2022 | HASSAN | 66 | HV1 | MALLAPURA_66 | 10:51 | 12:48 | 1:57 | TRANSFORMER FAULT |
| 807 | 28-Jul-2022 | HASSAN | 66 | UDAYAP-BAGUR | UDAYAPURA_66 | 13:35 | 13:55 | 0:20 | MAIN SUPPLY FAILURE |
| 808 | 28-Jul-2022 | MYSURU | 66 | HV1 | ARKALVADI_66 | 10:33 | 10:57 | 0:24 | LINE CLEAR AVAILED |
| 809 | 28-Jul-2022 | MYSURU | 66 | HV1 | BGPURA_66 | 11:20 | 12:25 | 1:04 | LINE CLEAR AVAILED |
| 810 | 28-Jul-2022 | MYSURU | 66 | HV2 | BILIKERE_66 | 11:03 | 12:45 | 1:41 | LINE CLEAR AVAILED |
| 811 | 28-Jul-2022 | MYSURU | 220 | HV2 | CRNAGAR_220 | 15:26 | 15:44 | 0:17 | TRANSFORMER FAULT |
| 812 | 28-Jul-2022 | MYSURU | 66 | HV1 | CRNAGAR_220 | 15:32 | 15:51 | 0:19 | HAND TRIPPED |
| 813 | 28-Jul-2022 | MYSURU | 66 | CR NAGARA-KOLLEGALA | NO STATIONS EFFECTED | 15:33 | 17:01 | 1:27 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|--------------------------------------|--|--------------------------|-------------------|-----------|-------------------------------------|
| 814 | 28-Jul-2022 | MYSURU | 66 | DEVNUR(MYS)-RAJEEVNAGARA | NO STATIONS EFFECTED | 12:24 | 14:26 | 2:02 | NFBC ISSUED |
| 815 | 28-Jul-2022 | MYSURU | 66 | DEVNUR(MYS)-VAJAMANGALA | NO STATIONS EFFECTED | 15:29 | 17:00 | 1:31 | LINE CLEAR AVAILED |
| 816 | 28-Jul-2022 | MYSURU | 66 | DEVNUR(MYS)-RAJEEVNAGARA | DEVANOORMYS_66 | 16:28 | 16:31 | 0:03 | LINE FAULT |
| 817 | 28-Jul-2022 | MYSURU | 66 | HV1 | DEVANOORMYS_66 | 10:35 | 13:20 | 2:45 | LINE CLEAR AVAILED |
| 818 | 28-Jul-2022 | MYSURU | 66 | HV2 | DEVANOORMYS_66 | 13:21 | 15:35 | 2:14 | LINE CLEAR AVAILED |
| 819 | 28-Jul-2022 | MYSURU | 66 | FTS-JYOTHINAGARA | JYOTHINAGARA_66 | 7:48 | 9:29 | 1:40 | LINE CLEAR AVAILED |
| 820 | 28-Jul-2022 | MYSURU | 66 | HV1 | MADDUR_66 | 11:37 | 13:27 | 1:49 | LINE CLEAR AVAILED |
| 821 | 28-Jul-2022 | MYSURU | 220 | HV1 | NAGAMANGALA_220 | 0:29 | 0:49 | 0:20 | TRANSFORMER FAULT |
| 822 | 28-Jul-2022 | MYSURU | 66 | NAGAMANGALA 220-KOPPA | BESAGARAHALLI_66 DUNDANAHALLI_66 KOPPA_66 | 0:29 | 0:42 | 0:13 | LINE FAULT |
| 823 | 28-Jul-2022 | MYSURU | 66 | NAGAMANGALA 220-KASALGERE | KESLAGERE_66 | 0:29 | 0:42 | 0:13 | LINE FAULT |
| 824 | 28-Jul-2022 | MYSURU | 66 | MADHUVANAHALLI-HEBBANI | NO STATIONS EFFECTED | 13:12 | 13:17 | 0:05 | LINE FAULT |
| 825 | 28-Jul-2022 | MYSURU | 66 | MUGUR-THAYUR | THAYURU_66 | 19:15 | 19:20 | 0:05 | LINE FAULT |
| 826 | 28-Jul-2022 | MYSURU | 66 | SANTHE SARAGURU-BEGUR | NO STATIONS EFFECTED | 5:37 | 6:19 | 0:42 | LINE FAULT |
| 827 | 28-Jul-2022 | MYSURU | 66 | SANTHE SARAGURU-KADAKOLA 1 | ANTHARSANTHE_66 HDKOTE_66 YERALLI HAND POST_66 | 19:00 | 19:10 | 0:10 | LINE FAULT |
| 828 | 28-Jul-2022 | MYSURU | 66 | VAJMANGALA-JYOTHINAGARA | JYOTHINAGARA_66 | 7:31 | 9:21 | 1:50 | LINE CLEAR AVAILED |
| 829 | 28-Jul-2022 | MYSURU | 66 | VAJMANGALA-DEVNUR(MYS) | NO STATIONS EFFECTED | 15:19 | 17:01 | 1:42 | NFBC ISSUED |
| 830 | 28-Jul-2022 | MYSURU | 66 | VAJMANGALA-HEBBANI | NO STATIONS EFFECTED | 19:01 | 19:08 | 0:07 | LINE FAULT |
| 831 | 28-Jul-2022 | MYSURU | 66 | VAJMANGALA-HEBBANI | NO STATIONS EFFECTED | 23:28 | 23:59 | 0:31 | LINE FAULT |
| 832 | 28-Jul-2022 | MYSURU | 66 | HV1 | GUNDLUPETE_66 | 17:02:00 (12.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 833 | 28-Jul-2022 | MYSURU | 220 | HV2 | MADHUVANAHALLI_220 | 18:57:18 (31.5.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 834 | 28-Jul-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 18:26 (22/04/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 835 | 28-Jul-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16:00 (08/12/2021) | | | LINE OPEN , LINE CLEAR AVAILED |
| 836 | 28-Jul-2022 | MYSURU | 220 | HV1 | KADAKOLA_220 | 1:41:14 (21/07/2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 837 | 28-Jul-2022 | TUMKUR | 220 | DAVANGERE SRS- GUTTUR-1 | DAVANGERE_SRS_220 | 08:02(22.07.2022) | 17:22(28.07.2022) | 129:20HRS | LINE CHARGED |
| 838 | 28-Jul-2022 | TUMKUR | 220 | DAVANGERE SRS- SHIMOGA 2 | DAVANGERE_SRS_220 | 14:20(27.07.2022) | | | LINE OPEN, LINE FAULT |
| 839 | 28-Jul-2022 | TUMKUR | 220 | TR1 | THALLAK_220 | 3:42 | 4:21 | 0:39 | TRANSFORMER FAULT |
| 840 | 28-Jul-2022 | TUMKUR | 220 | TR2 | THALLAK_220 | 3:42 | 4:27 | 0:45 | TRANSFORMER FAULT |
| 841 | 28-Jul-2022 | TUMKUR | 220 | TR3 | THALLAK_220 | 3:42 | 4:23 | 0:41 | TRANSFORMER FAULT |
| 842 | 28-Jul-2022 | TUMKUR | 220 | THALLAK_220-HM HOLE_220 | THALLAK_220 | 3:42 | 4:33 | 0:51 | LINE FAULT |
| 843 | 28-Jul-2022 | TUMKUR | 220 | TR3 | KB CROSS | 16:47 | 17:08 | 0:21 | HAND TRIPPED |
| 844 | 28-Jul-2022 | TUMKUR | 220 | TR2(HV) | KIADB | 15:18 | 16:45 | 1:27 | LINE CLEAR AVAILED |
| 845 | 28-Jul-2022 | TUMKUR | 220 | TR2(LV) | KIADB | 15:17 | 16:39 | 1:22 | LINE CLEAR AVAILED |
| 846 | 28-Jul-2022 | TUMKUR | 220 | TR1(HV) | KIADB | 16:50 | 17:03 | 0:13 | HAND TRIPPED |
| 847 | 28-Jul-2022 | TUMKUR | 110 | KB CROSS 220kV-BANDIHALLI(TIPTUR110) | TIPTUR_110,KARADI_66,BANDIHALLI_110,HUNSE GHATTA_110 | 4:08 | 4:30 | 0:22 | LINE FAULT |
| 848 | 28-Jul-2022 | TUMKUR | 110 | KB CROSS 220kV-BANDIHALLI(TIPTUR110) | TIPTUR_110,KARADI_66,BANDIHALLI_110,HUNSE GHATTA_110 | 4:30 | 4:39 | 0:09 | LINE FAULT |
| 849 | 28-Jul-2022 | TUMKUR | 66 | ANTHRASANAHALI 220KV- KORA | KORA_66, BRAKMASANDRA_66,THOVINAKERE_66,ANKASA NDRA_66 | 9:54 | 10:04 | 0:10 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|---|--|---------|-----------|----------|--------------------|
| 850 | 28-Jul-2022 | TUMKUR | 66 | ANTHRASANAHALI 220KV- KOLALA | KOLALA_66, URDIGERE_66 | 14:27 | 16:46 | 2:19 | LINE FAULT |
| 851 | 28-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- CHITRADURGA 1 | DAVANGERE_220 | 1:15 | 1:27 | 0:12 | LINE FAULT |
| 852 | 28-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- CHITRADURGA 1 | DAVANGERE_220 | 1:39 | 1:49 | 0:10 | LINE FAULT |
| 853 | 28-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- CHITRADURGA 1 | DAVANGERE_220 | 1:59 | 2:08 | 0:09 | LINE FAULT |
| 854 | 28-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- CHITRADURGA 1 | DAVANGERE_220 | 2:48 | 3:12 | 0:24 | LINE FAULT |
| 855 | 28-Jul-2022 | TUMKUR | 66 | ANCHEPALYA 220kv- KUNIGAL66 | YEDIYUR_66,THIPPUR,JIDDEGERE_66 | 19:30 | 20:02 | 0:32 | LOAD CURTAILMENT |
| 856 | 28-Jul-2022 | TUMKUR | 66 | ANCHEPALYA 220- ANCHEPALYA 2 | KUDUR_66, HULLENAHALI_66,SRI GIRI PURA | 19:30 | 20:02 | 0:32 | LOAD CURTAILMENT |
| 857 | 28-Jul-2022 | TUMKUR | 66 | ANCHEPALYA 220kv- HULIYURDURGA | HULIYURDURGA_66, CHAWANAKUPPE_66 | 19:30 | 20:02 | 0:32 | LOAD CURTAILMENT |
| 858 | 28-Jul-2022 | TUMKUR | 66 | YEDIYUR- ANCHEPALYA220KV | BGNAGARA_66 | 19:30 | 20:02 | 0:32 | LOAD CURTAILMENT |
| 859 | 28-Jul-2022 | TUMKUR | 66 | ANCHEPALYA 66kv-HEBBUR66 | HEBBUR_66,THIMMASANDRA_66,HONNENAHALLI_66 | 19:30 | 20:02 | 0:32 | LOAD CURTAILMENT |
| 860 | 28-Jul-2022 | TUMKUR | 66 | ANCHEPALYA 220kv- AMRUTHUR | AMRUTHUR_66, SANTEMAVATTUR_66,YEDAVANI_66 | 19:30 | 20:02 | 0:32 | LOAD CURTAILMENT |
| 861 | 28-Jul-2022 | TUMKUR | 66 | ANCHEPALYA 220kv- KEMPANAHALLI | KEMPANAHALLI_66, AGALKOTE_66 | 19:30 | 20:02 | 0:32 | LOAD CURTAILMENT |
| 862 | 28-Jul-2022 | TUMKUR | 66 | THALLAK 220kv-PARSHAMPURA | THALLAK_220 | 2:43 | 2:55 | 0:12 | LINE FAULT |
| 863 | 28-Jul-2022 | TUMKUR | 66 | THALLAK 220kv-PARSHAMPURA | THALLAK_220 | 2:58 | 4:43 | 1:45 | LINE FAULT |
| 864 | 28-Jul-2022 | TUMKUR | 66 | THALLAK 220kv -BGKERE 1 | BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66 | 4:06 | 4:34 | 0:28 | HAND TRIPPED |
| 865 | 28-Jul-2022 | TUMKUR | 66 | THALLAK 220kv -BGKERE 2 | HANAGAL_66, | 4:06 | 4:34 | 0:28 | HAND TRIPPED |
| 866 | 28-Jul-2022 | TUMKUR | 66 | THALLAK 220kv- GOWRASAMUDRA | | 4:06 | 4:40 | 0:34 | HAND TRIPPED |
| 867 | 28-Jul-2022 | TUMKUR | 66 | THALLAK 220kv- SEI DIAMOND SOLAR_IPP_66 | SEI DIAMOND SOLAR_IPP_66 | 4:06 | 4:44 | 0:38 | HAND TRIPPED |
| 868 | 28-Jul-2022 | TUMKUR | 66 | THALLAK 220kv- SEI VENUS DIAMOND_IPP_66 | SEI VENUS DIAMOND_IPP_66 | 4:06 | 4:44 | 0:38 | HAND TRIPPED |
| 869 | 28-Jul-2022 | TUMKUR | 66 | THALLAK 220-THALLAK66 | THALLAK_66 | 4:06 | 4:28 | 0:22 | HAND TRIPPED |
| 870 | 28-Jul-2022 | TUMKUR | 66 | THALLAK 220kv- WELSPUN SOLAR1 | WELSPUNSOLAR1_IPP_66 | 4:06 | 4:41 | 0:35 | HAND TRIPPED |
| 871 | 28-Jul-2022 | TUMKUR | 66 | THALLAK 220kv- WELSPUN SOLAR2 | WELSPUN SOLAR2 | 4:06 | 4:41 | 0:35 | HAND TRIPPED |
| 872 | 28-Jul-2022 | TUMKUR | 66 | THALLAK 220kv- NAYAKANHATTI | NAYAKANHATTI_66, HIREMALLANAHOLE_66 | 4:06 | 4:39 | 0:33 | HAND TRIPPED |
| 873 | 28-Jul-2022 | TUMKUR | 66 | CHITRADURGA 220kv- TURUVANUR | MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66 | 7:42 | 7:54 | 0:12 | LINE FAULT |
| 874 | 28-Jul-2022 | TUMKUR | 66 | MADHUGIRI 220kv- PULAMAGATTA | MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66 | 4:28 | 4:39 | 0:11 | LINE FAULT |
| 875 | 28-Jul-2022 | TUMKUR | 66 | MADHUGIRI 220kv- PULAMAGATTA | MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66 | 5:33 | 7:47 | 2:14 | LINE FAULT |
| 876 | 28-Jul-2022 | TUMKUR | 66 | MADHUGIRI 220kv- PULAMAGATTA | MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66 | 22:39 | 23:05 | 0:26 | LINE FAULT |
| 877 | 28-Jul-2022 | TUMKUR | 66 | TR1 | KIADB | 6:44 | 6:52 | 0:08 | HAND TRIPPED |
| 878 | 28-Jul-2022 | TUMKUR | 66 | TR1 | KIADB | 12:42 | 14:17 | 1:35 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|------------------------------|---|-----------------------|-------------------|-----------|-------------------------------------|
| 879 | 28-Jul-2022 | TUMKUR | 66 | TR1 | KIADB | 15:07 | 15:10 | 0:03 | HAND TRIPPED |
| 880 | 28-Jul-2022 | TUMKUR | 66 | TR2 | KIADB | 16:52 | 17:04 | 0:12 | HAND TRIPPED |
| 881 | 28-Jul-2022 | TUMKUR | 66 | TR1 | KIADB | 17:05 | 17:20 | 0:15 | HAND TRIPPED |
| 882 | 28-Jul-2022 | TUMKUR | 66 | 66KV TMTP | KIADB | 16:50 | 17:07 | 0:17 | HAND TRIPPED |
| 883 | 28-Jul-2022 | TUMKUR | 66 | NARENDRA LINE-1-GUTTUR | GUTTUR_400 | 00:01(23.07.2022) | 09:31(28.07.2022) | 128:30HRS | LINE CHARGED |
| 884 | 28-Jul-2022 | TUMKUR | 66 | GUTTUR_400DAVANGERE LINE -1 | GUTTUR_400 | 00:08(23.07.2022) | 17:22(28.07.2022) | 129:20HRS | LINE CHARGED |
| 885 | 28-Jul-2022 | TUMKUR | 66 | BILCHODU66-PALLAGATTE66 | PALLAGATTE_66,SOKKE_66,JAGALUR_66 | 4:55 | 5:05 | 0:10 | LINE FAULT |
| 886 | 28-Jul-2022 | TUMKUR | 66 | BILCHODU66-UCHANGIDURGA66 | BILCHODU_66 | 5:25 | 5:30 | 0:05 | MAIN SUPPLY FAILURE |
| 887 | 28-Jul-2022 | TUMKUR | 66 | KORA- BRAHMASANDRA | KORA_66, BRAHMASANDRA_66, THOVINAKERE_66 | 9:55 | 10:25 | 0:30 | MAIN SUPPLY FAILURE |
| 888 | 28-Jul-2022 | TUMKUR | 66 | THALLAK 220kV -BGKERE 2 | HANAGAL_66, | 3:43 | 4:34 | 0:51 | MAIN SUPPLY FAILURE |
| 889 | 28-Jul-2022 | TUMKUR | 66 | HARIYABBE-PD KOTE | HARIYABBE_66 | 10:20 | 10:25 | 0:05 | HAND TRIPPED |
| 890 | 28-Jul-2022 | TUMKUR | 66 | HOLALKERE- RAMGIRI 1 | HOLALKERE_66 | 0:50 | 1:00 | 0:10 | LINE FAULT |
| 891 | 28-Jul-2022 | TUMKUR | 66 | TR2 | HOLALKERE_66 | 9:01 | 9:06 | 0:05 | TRANSFORMER FAULT |
| 892 | 28-Jul-2022 | TUMKUR | 66 | TR2 | HOLALKERE_66 | 9:10 | 9:15 | 0:05 | TRANSFORMER FAULT |
| 893 | 28-Jul-2022 | TUMKUR | 66 | MALEBENNUR66-HONNALLI66 | MALEBENNUR_66 | 12:25 | 12:35 | 0:10 | MAIN SUPPLY FAILURE |
| 894 | 28-Jul-2022 | TUMKUR | 66 | TR1 | SASALUHALLA | 17:20 | 17:55 | 0:35 | LINE CLEAR AVAILED |
| 895 | 28-Jul-2022 | TUMKUR | 66 | ANCHEPALYA 220kV- YEDIYUR_66 | YEDIYUR_66,THIPPUR_66,JIDDEGERE_66 | 16:20 | 17:20 | 1:00 | LINE CLEAR AVAILED |
| 896 | 28-Jul-2022 | TUMKUR | 66 | TR1 | THIPPUR_66 | 19:30 | 20:00 | 0:30 | MAIN SUPPLY FAILURE |
| 897 | 28-Jul-2022 | TUMKUR | 66 | TR2 | HULIYURDURGA_66 | 16:10 | 18:10 | 2:00 | LINE CLEAR AVAILED |
| 898 | 28-Jul-2022 | TUMKUR | 66 | HONNALLI 220kV- KUNDUR66 | KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66 | 12:25 | 12:39 | 0:14 | MAIN SUPPLY FAILURE |
| 899 | 28-Jul-2022 | TUMKUR | 66 | HIREHALLI_66-HONNUDIKE_66 | HIREHALLI_66 | 12:05 | 13:00 | 0:55 | LINE CLEAR AVAILED |
| 900 | 28-Jul-2022 | TUMKUR | 66 | TR2 | KUNIGAL_66 | 10:00 | 12:25 | 2:25 | LINE CLEAR AVAILED |
| 901 | 28-Jul-2022 | TUMKUR | 66 | NAGALAMADIKE-PAVAGADA220KV | NAGALMADIKE_66 | 1:30 | 5:50 | 4:20 | LINE FAULT |
| 902 | 29-Jul-2022 | BAGALKOT | 220 | SIRSI-HUBLI-1 | STATION NOT AFFECTED SIRSI_220 | 19:46 (15.07.2022) | | | LOAD CURTAILMENT |
| 903 | 29-Jul-2022 | BAGALKOT | 220 | SIRSI-HUBLI-2 | STATION NOT AFFECTED SIRSI_220 | 19:46 (15.07.2022) | | | LOAD CURTAILMENT |
| 904 | 29-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED TODALBAGI_110 | 19:13 (17.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 905 | 29-Jul-2022 | BAGALKOT | 110 | TODALBAGI-SAVALAGI | TODALBAGI_110 | 18:00 (20.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 906 | 29-Jul-2022 | BAGALKOT | 110 | UTTUR - F1 JAMB CB(MUDHOL) | STATION NOT AFFECTED UTTUR_110 | 9:51 (24.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 907 | 29-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV3 | STATION NOT AFFECTED BILAGI_110 | 7:28 (29.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 908 | 29-Jul-2022 | BAGALKOT | 110 | HUBLI220-SIRSI (KALAGHATAGI) | KALAGHATAGI_110 | 9:53 | 18:03 | 8:10 | LINE CLEAR AVAILED |
| 909 | 29-Jul-2022 | BAGALKOT | 110 | HUBLI220-KADANAKOPPA | KADANAKOPPA_110 | 10:04 | 18:05 | 8:01 | LINE CLEAR AVAILED |
| 910 | 29-Jul-2022 | BAGALKOT | 220 | HUBLI-SIRSI-1 | STATION NOT AFFECTED HUBLI_220 | 15:51 | 20:48 | 4:57 | LINE FAULT |
| 911 | 29-Jul-2022 | BAGALKOT | 220 | HUBLI-NARENDRA-2 | STATION NOT AFFECTED HUBLI_220 | 15:51 | 17:56 | 2:05 | LINE FAULT |
| 912 | 29-Jul-2022 | BAGALKOT | 110 | 220/110KV, LV-1 | KARWAR_220 | 13:53 | 14:18 | 0:25 | MAIN SUPPLY FAILURE |
| 913 | 29-Jul-2022 | BAGALKOT | 110 | KARWAR220-SOLARIS (BINAGA) | BINAGA_110 | 13:53 | 14:01 | 0:08 | MAIN SUPPLY FAILURE |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--------------------------------------|---|-----------------------|-----------|----------|-----------------------|
| 914 | 29-Jul-2022 | BAGALKOT | 110 | KARWAR220-ARGA (KUMTA) | KUMTA_110 | 14:18 | 14:18 | 0:00 | MAIN SUPPLY FAILURE |
| 915 | 29-Jul-2022 | BAGALKOT | 220 | BAGALKOT- GADAG-1 | STATION NIOT AFFECTED BAGALKOT_220 | 21:01 | 23:16 | 2:15 | LINE FAULT |
| 916 | 29-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-KATARKI (NEERBUDIHAL) | NEERABUDIHAL_110 | 21:01 | 23:16 | 2:15 | LINE FAULT |
| 917 | 29-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV-2 | STATION NOT AFFECTED BELAGAVI_220 | 13:22 | 17:51 | 4:31 | LINE CLEAR AVAILED |
| 918 | 29-Jul-2022 | BAGALKOT | 110 | 220/110KV, LV-2 | STATION NOT AFFECTED BELAGAVI_220 | 13:21 | 17:52 | 4:31 | LINE CLEAR AVAILED |
| 919 | 29-Jul-2022 | BAGALKOT | 220 | AMBEWADI-NAGAZARI-2 | STATION NOT AFFECTED AMBEWADI_220 | 11:19 | 12:09 | 0:50 | LINE FAULT |
| 920 | 29-Jul-2022 | BAGALKOT | 220 | AMBEWADI-NAGAZARI-2 | STATION NOT AFFECTED AMBEWADI_220 | 18:16 | 18:53 | 0:37 | LINE FAULT |
| 921 | 29-Jul-2022 | BAGALKOT | 110 | MUGALKHOD220-RAIBAG-1 | STATION NOT AFFECTED MUGALKHOD_220 | 10:17 | 11:53 | 1:36 | LINE CLEAR AVAILED |
| 922 | 29-Jul-2022 | BAGALKOT | 110 | MUGALKHOD220-ITNAL-1 | STATION NOT AFFECTED MUGALKHOD_220 | 10:51 | 12:10 | 1:19 | LINE CLEAR AVAILED |
| 923 | 29-Jul-2022 | BAGALKOT | 110 | ALMEL-KPR SUGAR | ALMEL_110 | 8:35 | 19:08 | 10:33 | MAIN SUPPLY FAILURE |
| 924 | 29-Jul-2022 | BAGALKOT | 110 | ALMEL-JAMKHANDI SUGARS | ALMEL_110 | 8:35 | 19:18 | 10:43 | MAIN SUPPLY FAILURE |
| 925 | 29-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | BAGALKOT_110 | 10:27 | 16:57 | 6:30 | LINE CLEAR AVAILED |
| 926 | 29-Jul-2022 | BAGALKOT | 220 | BAGEWADI-RBRK | BAGEWADI_220 | 15:40 | 16:16 | 0:36 | LINE FAULT |
| 927 | 29-Jul-2022 | BAGALKOT | 110 | BAGEWADI-UKKALI | UKKALI_110 | 1:34 | 1:43 | 0:09 | LINE FAULT |
| 928 | 29-Jul-2022 | BAGALKOT | 110 | BIDNAL-NAVALGUND | NAVALGUND_110 | 17:57 (29.07.2022) | | | LINE OPEN, LINE FAULT |
| 929 | 29-Jul-2022 | BAGALKOT | 220 | BIDNAL-HARTI 1&2 | BIDNAL_220 | 13:49 | 18:54 | 5:05 | LINE CLEAR AVAILED |
| 930 | 29-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1&2 | CHANDKAVATE_110 | 12:00 | 19:02 | 7:02 | LINE CLEAR AVAILED |
| 931 | 29-Jul-2022 | BAGALKOT | 110 | CHANDKAVATE-ALMEL | ALMEL_110 | 8:36 | 19:02 | 10:26 | LINE CLEAR AVAILED |
| 932 | 29-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | DEVARGENNUR_110 | 15:51 | 16:39 | 0:48 | LINE CLEAR AVAILED |
| 933 | 29-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | GADAG_110 | 10:05 | 10:23 | 0:18 | LINE CLEAR AVAILED |
| 934 | 29-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | GUTTAL_110 | 12:31 | 16:46 | 4:15 | LINE CLEAR AVAILED |
| 935 | 29-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | HUDALI_110 | 13:05 | 13:39 | 0:34 | TRANSFORMER FAULT |
| 936 | 29-Jul-2022 | BAGALKOT | 110 | ITANAL-BORUKA | ITANAL_110 | 6:17 | 6:42 | 0:25 | LINE FAULT |
| 937 | 29-Jul-2022 | BAGALKOT | 110 | ITANAL-KABBUR(RAIBAG) | KABBUR_110 | 10:52 | 12:09 | 1:17 | LINE CLEAR AVAILED |
| 938 | 29-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | KADANAKOPPA_110 | 10:01 | 18:18 | 8:17 | LINE CLEAR AVAILED |
| 939 | 29-Jul-2022 | BAGALKOT | 110 | HUBLI-KALAGHATGI | KALGHATGI_110 (STATION NOT AFFECTED) | 9:53 | 18:06 | 8:13 | LINE CLEAR AVAILED |
| 940 | 29-Jul-2022 | BAGALKOT | 110 | CHIKKODI-KADAKALAT | KADAKLAT_110 | 11:11 | 11:59 | 0:48 | LINE CLEAR AVAILED |
| 941 | 29-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | KAMBAGI_110 | 9:11 | 9:19 | 0:08 | TRANSFORMER FAULT |
| 942 | 29-Jul-2022 | BAGALKOT | 110 | UDIKERI-NKR | STATION OT AFFECTED UDIKERI_110 | 22:14 | 22:25 | 0:11 | LINE CLEAR AVAILED |
| 943 | 29-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | STATION OT AFFECTED SIRSI_110 | 17:51 | 17:58 | 0:07 | TRANSFORMER FAULT |
| 944 | 29-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV2(10MVA1) | STATION OT AFFECTED SAVALAGI_110 | 14:31 | 18:09 | 3:38 | LINE CLEAR AVAILED |
| 945 | 29-Jul-2022 | BAGALKOT | 110 | SADALA-BORGAON | BOROGOAN_110 STATION OT AFFECTED SADALAGA_110 | 15:20 | 17:18 | 1:58 | LINE CLEAR AVAILED |
| 946 | 29-Jul-2022 | BAGALKOT | 110 | ITANAL(MUGHLKHOD LINE 1)- RAIBAG | STATION OT AFFECTED RAIBAG_110 | 10:11 | 11:55 | 1:44 | NFBC ISSUED |
| 947 | 29-Jul-2022 | BAGALKOT | 110 | BIDNAL-NAVALK | STATION OT AFFECTED NAVALGUND_110 | 17:57 (29.07.2022) | | | LINE OPEN, LINE FAULT |
| 948 | 29-Jul-2022 | BAGALKOT | 220 | MKHUBA-NARENDRA(KITTUR) | KITTUR_110 | 12:49 | 12:57 | 0:08 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|---|---|-----------------------|-----------------------|-----------|-------------------------------------|
| 949 | 29-Jul-2022 | BAGALKOT | 110 | 110/33KV,HV2(HV3) | KOLAR WS_33, NTPC_33 , KARJOL LIS_33 STATIONN OT AFFECTED MATTIHAL_110 | 15:46 | 16:12 | 0:26 | TRANSFORMER FAULT |
| 950 | 29-Jul-2022 | BAGALKOT | 110 | 110/33KV,HV2(HV3) | KOLAR WS_33, NTPC_33 , KARJOL LIS_33 STATIONN OT AFFECTED MATTIHAL_110 | 16:35 | 16:55 | 0:20 | LINE CLEAR AVAILED |
| 951 | 29-Jul-2022 | BAGALKOT | 110 | 110/33KV, HV3 | STATION NOT AFFECTED YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 952 | 29-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV1 | STATION NOT AFFECTED AMBEWADI_220 | 20:00 (09.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 953 | 29-Jul-2022 | BAGALKOT | 220 | GADAG-HARTI-2 | STATION NOT AFFECTED GADAG_220 | 10:55 (19.07.2020) | 23:59 (29.07.2022) | 253:04HRS | LINE CHARGED |
| 954 | 29-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV-3 & LV3 | STATION NOT AFFECTED ATHANI_220 | 10:26 (25.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 955 | 29-Jul-2022 | BAGALKOT | 220 | NARENDRA-BELAGAVI-2 | STATION NOT AFFECTED NARENDRA_220 | 11:09 (26.07.2022) | 16:21 (29.07.2022) | 77:12HRS | LINE CHARGED |
| 956 | 29-Jul-2022 | BAGALKOT | 220 | NARENDRA-BELAGAVI-2 | STATION NOT AFFECTED BELAGAVI_220 | 11:21 (26.07.2022) | 16:28 (29.07.2022) | 77:07HRS | LINE CHARGED |
| 957 | 29-Jul-2022 | BAGALKOT | 220 | HUBLI-NAGAZARI-2 | STATION NOT AFFECTED HUBLI_220 | 10:41 | 11:10 | 0:29 | HAND TRIPPED |
| 958 | 29-Jul-2022 | BAGALKOT | 220 | HUBLI-NAGAZARI-3 | STATION NOT AFFECTED HUBLI_220 | 11:16 | 13:22 | 2:06 | LINE CLEAR AVAILED |
| 959 | 29-Jul-2022 | BAGALKOT | 220 | HUBLI-NAGAZARI-3 | STATION NOT AFFECTED HUBLI_220 | 13:27 | 13:57 | 0:30 | HAND TRIPPED |
| 960 | 29-Jul-2022 | BAGALKOT | 110 | 220/110KV, LV-2 | KARWAR_220 | 13:53 | 14:17 | 0:24 | MAIN SUPPLY FAILURE |
| 961 | 29-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-RAMDURG | STATION NIOT AFFECTED BAGALKOT_220 | 11:35 | 13:16 | 1:41 | LINE CLEAR AVAILED |
| 962 | 29-Jul-2022 | BAGALKOT | 220 | NARENDRA-HUBLI-2 | STATION NOT AFFECTED NARENDRA_220 | 12:50 | 17:56 | 5:06 | LINE FAULT |
| 963 | 29-Jul-2022 | BAGALKOT | 220 | NARENDRA-BELAGAVI-2 | STATION NOT AFFECTED NARENDRA_220 | 20:17 (29.07.2022) | | | LINE OPEN, LINE FAULT |
| 964 | 29-Jul-2022 | BAGALKOT | 220 | GADAG-BAGALKOT-1 | STATION NOT AFFECTED GADAG_220 | 21:01 | 23:16 | 2:15 | LINE FAULT |
| 965 | 29-Jul-2022 | BAGALKOT | 220 | BELAGAVI-NARENDRA-2 | STATION NOT AFFECTED BELAGAVI_220 | 20:18 (29.07.2022) | | | LINE OPEN, LINE FAULT |
| 966 | 29-Jul-2022 | BAGALKOT | 220 | BELAGAVI-CHIKKODI (AEQU5)-2 | STATION NOT AFFECTED BELAGAVI_220 | 9:33 | 18:32 | 8:59 | LINE CLEAR AVAILED |
| 967 | 29-Jul-2022 | BAGALKOT | 220 | AMBEWADI-NAGAZARI-1 | STATION NOT AFFECTED AMBEWADI_220 | 17:08 | 17:12 | 0:04 | HAND TRIPPED |
| 968 | 29-Jul-2022 | BAGALKOT | 220 | AMBEWADI-NAGAZARI-1 | STATION NOT AFFECTED AMBEWADI_220 | 17:20 | 18:48 | 1:28 | LINE CLEAR AVAILED |
| 969 | 29-Jul-2022 | BAGALKOT | 220 | AMBEWADI-NAGAZARI-1 | STATION NOT AFFECTED AMBEWADI_220 | 19:16 | 19:59 | 0:43 | HAND TRIPPED |
| 970 | 29-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV4 | STATION NOT AFFECTED ANKALI_110 | 11:08 | 12:00 | 0:52 | TRANSFORMER FAULT |
| 971 | 29-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV2 | STATION NOT AFFECTED GUTTAL_110 | 12:30 | 16:35 | 4:05 | LINE CLEAR AVAILED |
| 972 | 29-Jul-2022 | BENGALURU | 66 | KANAKAPURA 220 - RAMANAGARA | ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE | 12:11 | 12:25 | 0:14 | LINE CLEAR AVAILED |
| 973 | 29-Jul-2022 | BENGALURU | 66 | HV1 | ALLIMARADANAHALLI | 23:25 | 23:41 | 0:16 | LINE CLEAR AVAILED |
| 974 | 29-Jul-2022 | BENGALURU | 220 | MYLSANDRA 400 - YARANDANAHALLI 3 220 | NO STATION AFFECTED | 1:42 | 2:25 | 0:43 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--|--|-----------------------|-------------------|----------|--------------------------------|
| 975 | 29-Jul-2022 | BENGALURU | 66 | NIMHANS 220 - JAYANAGAR | JAYANAGAR, NATIONAL COLLEGE | 1:43 | 2:00 | 0:17 | LINE FAULT |
| 976 | 29-Jul-2022 | BENGALURU | 66 | HOODY 220 - BMRL | NO STATION AFFECTED | 6:33 | 6:58 | 0:25 | LINE FAULT |
| 977 | 29-Jul-2022 | BENGALURU | 66 | BUDIKOTE - TEKAL | BUDIKOTE | 16:50 | 17:15 | 0:25 | LINE CLEAR AVOIDED |
| 978 | 29-Jul-2022 | BENGALURU | 66 | YELAHANKA 220 - LINE 7 | KANASWADI | 8:34 | 8:56 | 0:22 | LINE FAULT |
| 979 | 29-Jul-2022 | BENGALURU | 66 | THYALUR - NG HULKUR | NG HULKUR | 11:45 | 12:45 | 1:00 | LINE CLEAR AVOIDED |
| 980 | 29-Jul-2022 | BENGALURU | 66 | THYALUR - T GOLAHALLI | THAYALUR, NG HULKUR, MALLANAYAKANAHALLI | 16:10 | 16:50 | 0:40 | LINE CLEAR AVOIDED |
| 981 | 29-Jul-2022 | BENGALURU | 66 | THAYLUR - MALLANAYAKANAHALLI | MALLANAYAKANAHALLI | 15:20 | 16:50 | 1:30 | LINE CLEAR AVOIDED |
| 982 | 29-Jul-2022 | BENGALURU | 66 | HV1 | THAYLUR | 14:10 | 14:15 | 0:05 | LINE CLEAR AVOIDED |
| 983 | 29-Jul-2022 | BENGALURU | 66 | HV2 | THAYLUR | 12:35 | 12:40 | 0:05 | LINE CLEAR AVOIDED |
| 984 | 29-Jul-2022 | BENGALURU | 66 | HV3 | NELAMANGALA 66 | 22:37 | 22:47 | 0:09 | TRANSFORMER FAULT |
| 985 | 29-Jul-2022 | BENGALURU | 66 | MALUR 220 - MAASTHI | MAASTHI | 1:34 | 1:45 | 0:10 | LINE FAULT |
| 986 | 29-Jul-2022 | BENGALURU | 66 | MALUR 220 - MAASTHI | MAASTHI | 1:45 | 2:09 | 0:24 | LINE FAULT |
| 987 | 29-Jul-2022 | BENGALURU | 66 | MALUR 220 - MAASTHI | MAASTHI | 2:09 | 5:56 | 3:46 | LINE FAULT |
| 988 | 29-Jul-2022 | BENGALURU | 66 | MALUR 220 - MAASTHI | MAASTHI | 5:56 | 7:49 | 1:53 | LINE FAULT |
| 989 | 29-Jul-2022 | BENGALURU | 66 | KOLAR 220 - VEMGAL | TALAGUNDA, VEMGAL, KYALNUR | 13:58 | 14:07 | 0:08 | LINE FAULT |
| 990 | 29-Jul-2022 | BENGALURU | 220 | HV2 | KIADB HARDWARE PARK 220 | 17:05 | 18:22 | 1:17 | TRANSFORMER FAULT |
| 991 | 29-Jul-2022 | BENGALURU | 66 | GOWRIBIDANUR 220 - PERESANDRA | D PALYA, GUDIBANDE, MANDIKAL | 19:18 | 19:45 | 0:27 | LOAD CURTAILMENT |
| 992 | 29-Jul-2022 | BENGALURU | 66 | DALSANUR - SRINIVASPURA | SRINIVASPURA, YELDUR | 10:35 | 11:04 | 0:29 | LINE CLEAR AVOIDED |
| 993 | 29-Jul-2022 | BENGALURU | 220 | EAST DIVISION COMPOUND 220 - A STATION 220 | NO STATION AFFECTED | 08:38:00(23/07/2022) | | | LINE OPEN, LINE FAULT |
| 994 | 29-Jul-2022 | BENGALURU | 66 | MANDIKAL - PERESANDRA | NO STATION AFFECTED | 18:09(28/07/2022) | 14:12(29/07/2022) | 20:12HRS | LINE CHARGED |
| 995 | 29-Jul-2022 | GULBARGA | 400 | BTPS-RTPS | RTPS_400 | 10:45 | 15:39 | 4:54 | LINE CLEAR AVOIDED |
| 996 | 29-Jul-2022 | GULBARGA | 220 | SEDAM_SHAHAPUR | SEDAM_220 | 05:48(10/06/2022) | | | LINE OPEN , LINE CLEAR AVOIDED |
| 997 | 29-Jul-2022 | GULBARGA | 220 | HV2 | BADELADUKU_220 (KUDLIGI) | 15:00 | 15:36 | 0:36 | TRANSFORMER FAULT |
| 998 | 29-Jul-2022 | GULBARGA | 220 | SHAHAPUR-RTPS_2 | SHAHAPUR_220 | 4:32 | 4:49 | 0:17 | LINE FAULT |
| 999 | 29-Jul-2022 | GULBARGA | 220 | LINGAPUR-SULEKAL | LINGAPUR_220 | 10:02 | 17:58 | 7:56 | LINE CLEAR AVOIDED |
| 1000 | 29-Jul-2022 | GULBARGA | 220 | MALLAT-RTPS | MALLAT_220 | 4:08 | 4:35 | 0:27 | LINE FAULT |
| 1001 | 29-Jul-2022 | GULBARGA | 110 | SINDHNOOR-VALABELLARI | MANVI_110,MADLAPUR_110,KURDICROSS_110, ADVIAMRESHWAR_110,JAWALGERA_110 | 23:55 (29.07.2022) | | | LINE OPEN, LINE FAULT |
| 1002 | 29-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR1 | JEWARGI_110 | 12:15(15/06/2022) | | | LINE OPEN , LINE CLEAR AVOIDED |
| 1003 | 29-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR2 | NALWAR_110 | 15:10(14/06/2022) | | | LINE OPEN , LINE CLEAR AVOIDED |
| 1004 | 29-Jul-2022 | GULBARGA | 110 | HUMNABAD-HALLIKHED | HALLIKHED_110 | 9:34(20/07/2022) | | | LINE OPEN , LINE CLEAR AVOIDED |
| 1005 | 29-Jul-2022 | GULBARGA | 110 | HUMNABAD-HALBARGA | HALBARGA_110 | 3:54(20/07/2022) | | | LINE OPEN , LINE CLEAR AVOIDED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|------------------------|---|-------------------|-------------------|----------|--------------------|
| 1006 | 29-Jul-2022 | GULBARGA | 110 | HV2 | CHICKSUGUR_110 | 14:08 | 15:05 | 0:57 | LINE CLEAR AVAILED |
| 1007 | 29-Jul-2022 | GULBARGA | 110 | HV1 | TEKKALKOTE_110 | 16:45 | 17:15 | 0:30 | LINE CLEAR AVAILED |
| 1008 | 29-Jul-2022 | GULBARGA | 110 | HV1 | TEKKALKOTE_110 | 17:28 | 18:18 | 0:50 | LINE CLEAR AVAILED |
| 1009 | 29-Jul-2022 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 14:05 | 14:09 | 0:04 | TRANSFORMER FAULT |
| 1010 | 29-Jul-2022 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 22:23 | 22:28 | 0:05 | TRANSFORMER FAULT |
| 1011 | 29-Jul-2022 | GULBARGA | 110 | HV1 | MATAMARI_110 | 4:15 | 4:26 | 0:11 | TRANSFORMER FAULT |
| 1012 | 29-Jul-2022 | GULBARGA | 110 | HV1 | MATAMARI_110 | 6:25 | 6:30 | 0:05 | TRANSFORMER FAULT |
| 1013 | 29-Jul-2022 | GULBARGA | 110 | HV1 | CHINCHOLI_110 | 15:45 | 16:06 | 0:21 | LINE CLEAR AVAILED |
| 1014 | 29-Jul-2022 | GULBARGA | 110 | HV3 | KEMBHAVI_110 | 17:55 | 18:20 | 0:25 | TRANSFORMER FAULT |
| 1015 | 29-Jul-2022 | GULBARGA | 110 | HV4 (10MVA) | KUSTAGI_220 | 13:50 | 14:00 | 0:10 | TRANSFORMER FAULT |
| 1016 | 29-Jul-2022 | GULBARGA | 110 | LV1 | SHAHABAD_220 | 15:20 | 15:40 | 0:20 | LINE CLEAR AVAILED |
| 1017 | 29-Jul-2022 | GULBARGA | 110 | YELBURGA-PRPJS LR_IPP | YELBURGA_110 | 19:25(28.07.2022) | 3:28(29.07.2022) | 8:03HRS | LINE CHARGED |
| 1018 | 29-Jul-2022 | GULBARGA | 110 | MALLAT-BYAGWAT | BYAGWAT_110,VALKAMDINNI_110 | 23:57(28.07.2022) | 00:05(29.07.2022) | 00:08HRS | LINE CHARGED |
| 1019 | 29-Jul-2022 | GULBARGA | 110 | YELBURGA-PRPJS LR_IPP | YELBURGA_110 | 3:40 | 3:58 | 0:18 | LINE FAULT |
| 1020 | 29-Jul-2022 | GULBARGA | 110 | YELBURGA-PRPJS LR_IPP | YELBURGA_110 | 9:14 | 9:20 | 0:06 | LINE CLEAR AVAILED |
| 1021 | 29-Jul-2022 | GULBARGA | 110 | PDHALLI-ALIPUR | PDHALLI_110 | 23:04 | 23:25 | 0:21 | LINE FAULT |
| 1022 | 29-Jul-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | SAIDAPUR_110 | 3:19 | 3:23 | 0:04 | LINE FAULT |
| 1023 | 29-Jul-2022 | GULBARGA | 110 | SHAHAPUR-KBJNL | KBJNL_110 | 5:23 | 5:28 | 0:05 | LINE FAULT |
| 1024 | 29-Jul-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | SAIDAPUR_110 | 20:10 | 20:14 | 0:04 | LINE FAULT |
| 1025 | 29-Jul-2022 | GULBARGA | 110 | LINGASUGUR-HATTI | HATTI_110,MASKI_110,KAVITHAL_110,SOMANA MARDI_IPP,GAMESHA_IPP | 12:08 | 14:54 | 2:46 | LINE CLEAR AVAILED |
| 1026 | 29-Jul-2022 | GULBARGA | 110 | KUSTAGI-TAWARAGERA | TAWARAGERA_110 | 9:10 | 11:38 | 2:28 | LINE CLEAR AVAILED |
| 1027 | 29-Jul-2022 | GULBARGA | 110 | NALEAR-CLEAN SOLAR_IPP | NALWAR_110 | 19:50 | 20:20 | 0:30 | LINE FAULT |
| 1028 | 29-Jul-2022 | GULBARGA | 110 | NALEAR-CLEAN SOLAR_IPP | NALWAR_110 | 20:57 | 21:45 | 0:48 | LINE FAULT |
| 1029 | 29-Jul-2022 | GULBARGA | 110 | SHAHABAD-BAGEWADI2 | YADRAMI_110,MORATAGI_110, GHATARGA_110 | 5:31 | 5:35 | 0:04 | LINE FAULT |
| 1030 | 29-Jul-2022 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 5:44 | 5:49 | 0:05 | LINE FAULT |
| 1031 | 29-Jul-2022 | GULBARGA | 110 | RAICHUR-SINDHANOOR1 | SIRWAR_110 | 23:58 | 0:03 | 0:05 | LINE FAULT |
| 1032 | 29-Jul-2022 | GULBARGA | 110 | RAICHUR-SINDHNOOR2 | KURDICROSS_110,MADLAPUR_110,MANVI_110 | 5:45 | 6:00 | 0:15 | LINE FAULT |
| 1033 | 29-Jul-2022 | GULBARGA | 110 | HUMNABAD-ALAND | ALAND_110,KADAGANCHI_110 | 0:46 | 0:50 | 0:04 | LINE FAULT |
| 1034 | 29-Jul-2022 | GULBARGA | 110 | HUMNABAD-ALAND | ALAND_110,KADAGANCHI_110 | 4:52 | 4:57 | 0:05 | LINE FAULT |
| 1035 | 29-Jul-2022 | GULBARGA | 110 | ALIPUR-BELLARY NORTH | SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELS | 23:03 | 23:25 | 0:22 | LINE FAULT |
| 1036 | 29-Jul-2022 | GULBARGA | 110 | HALBARGA-CHIDRI 2 | CHIDRI_110 | 19:01 | 19:07 | 0:06 | LINE FAULT |
| 1037 | 29-Jul-2022 | GULBARGA | 110 | HALBARGA-KAMTHANA | KAMTHANA_110,HABSIKOTE_110 | 19:01 | 19:52 | 0:51 | LINE FAULT |
| 1038 | 29-Jul-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 3:01 | 3:11 | 0:10 | LINE FAULT |
| 1039 | 29-Jul-2022 | GULBARGA | 110 | MALLAT-SIRWAR | SIRWAR_110 | 3:05 | 3:15 | 0:10 | LINE FAULT |
| 1040 | 29-Jul-2022 | GULBARGA | 110 | MALLAT-ALKOD | ALKOD_110,GALAG_110 | 18:28 | 18:38 | 0:10 | LINE FAULT |
| 1041 | 29-Jul-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 22:06 | 22:13 | 0:07 | LINE FAULT |
| 1042 | 29-Jul-2022 | GULBARGA | 110 | SULEKAL-KANAKAGIRI | NAVALI_110, CLEAN SOLAR_IPP | 9:40 | 11:48 | 2:08 | NFBC ISSUED |
| 1043 | 29-Jul-2022 | GULBARGA | 66 | HV1 | PUNABGHATA_66 | 11:30 | 11:35 | 0:05 | TRANSFORMER FAULT |
| 1044 | 29-Jul-2022 | GULBARGA | 66 | HV2 | UJJANI_66 | 14:40 | 14:45 | 0:05 | TRANSFORMER FAULT |
| 1045 | 29-Jul-2022 | GULBARGA | 66 | HV2 | TELAGI_66 | 15:00 | 15:10 | 0:10 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|-------------------------|--|-------------------|-------------------|----------|-----------------------|
| 1046 | 29-Jul-2022 | GULBARGA | 66 | BADELADUKU-GUDEKOTE | GUDEKOTE_66,CJ HALLI_66,HOSAHALLI_66,UJJANI_66 | 15:00 | 15:27 | 0:27 | LINE FAULT |
| 1047 | 29-Jul-2022 | GULBARGA | 66 | ITTAGI-HAGRIBOMMANHALLI | HAGRIBOMMANHALLI_66,UPANAYAKANAHALLI_66 | 12:00 | 13:00 | 1:00 | LINE CLEAR AVAILED |
| 1048 | 29-Jul-2022 | GULBARGA | 66 | ITTAGI-HUVINAHADAGALI | HUVINAHADGALI_66,HOLAGUNDI_66 | 18:54 | 19:08 | 0:14 | LINE FAULT |
| 1049 | 29-Jul-2022 | GULBARGA | 66 | ITTAGI-HIREHADAGALI_2 | HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66, SOVENHALLI_66, TUNGA BHADRA_IPP | 19:08 | 19:15 | 0:07 | LINE FAULT |
| 1050 | 29-Jul-2022 | GULBARGA | 66 | KUDLIGI-HANSI | HANSI_66 | 15:00 | 15:30 | 0:30 | LINE FAULT |
| 1051 | 29-Jul-2022 | GULBARGA | 66 | UJJANI-BREIPL IPP | UJJANI_66 | 14:40 | 15:30 | 0:50 | LINE FAULT |
| 1052 | 29-Jul-2022 | HASSAN | 220 | CRPATNA-HSN400 | CRPATNA_220 | 13:34(15.07.2022) | | | LINE OPEN, LINE FAULT |
| 1053 | 29-Jul-2022 | HASSAN | 220 | MRSSHM-HONNALLI | MRSMSG_2220 | 12:44(27.07.2022) | 10:46(29.07.2022) | 46:02HRS | LINE CHARGED |
| 1054 | 29-Jul-2022 | HASSAN | 220 | GERSOPA-MRS | gerusoppa_gen | 13:50 | 14:09 | 0:19 | LINE FAULT |
| 1055 | 29-Jul-2022 | HASSAN | 220 | HV1 | HEGGUNJE_220 | 11:10 | 12:10 | 1:00 | LINE CLEAR AVAILED |
| 1056 | 29-Jul-2022 | HASSAN | 220 | KADUR-DABUSET | KADUR_220 | 15:55 | 18:58 | 3:03 | NFBC ISSUED |
| 1057 | 29-Jul-2022 | HASSAN | 220 | KEMAR-Kavoor2 | KEMAR_220 | 10:17 | 17:40 | 7:23 | LINE CLEAR AVAILED |
| 1058 | 29-Jul-2022 | HASSAN | 220 | MRSSHM-STRP1 | MRSMSG_220 | 13:50 | 14:10 | 0:20 | LINE FAULT |
| 1059 | 29-Jul-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY1 | MRSMSG_220 | 15:34 | 15:51 | 0:17 | LINE CLEAR AVAILED |
| 1060 | 29-Jul-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY1 | MRSMSG_220 | 16:00 | 16:07 | 0:07 | LINE CLEAR AVAILED |
| 1061 | 29-Jul-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY3 | MRSMSG_220 | 11:10 | 13:21 | 2:11 | LINE CLEAR AVAILED |
| 1062 | 29-Jul-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY4 | MRSMSG_220 | 13:29 | 17:09 | 3:40 | LINE FAULT |
| 1063 | 29-Jul-2022 | HASSAN | 220 | MRSSHM-VARAH13 | MRSMSG_220 | 8:46 | 16:11 | 7:25 | LINE CLEAR AVAILED |
| 1064 | 29-Jul-2022 | HASSAN | 110 | MRSSHM-BADRAVATY1 | MRSMSG_220 | 17:25 | 18:05 | 0:40 | LINE CLEAR AVAILED |
| 1065 | 29-Jul-2022 | HASSAN | 110 | MRSSHM-BADRAVATY2 | MRSMSG_220 | 16:01 | 18:05 | 2:04 | LINE FAULT |
| 1066 | 29-Jul-2022 | HASSAN | 110 | HV3 | MRSMSG_220 | 12:14 | 13:30 | 1:16 | LINE CLEAR AVAILED |
| 1067 | 29-Jul-2022 | HASSAN | 220 | MSEZ-KEMAR2 | MSEZ_220 | 10:17 | 17:40 | 7:23 | LINE CLEAR AVAILED |
| 1068 | 29-Jul-2022 | HASSAN | 220 | SHRAVTY-SHIMOGA1 | sharavathy_gen | 15:34 | 15:51 | 0:17 | LINE CLEAR AVAILED |
| 1069 | 29-Jul-2022 | HASSAN | 220 | SHRAVTY-SHIMOGA1 | sharavathy_gen | 16:00 | 16:07 | 0:07 | LINE CLEAR AVAILED |
| 1070 | 29-Jul-2022 | HASSAN | 220 | SHRAVTY-SHIMOGA3 | sharavathy_gen | 11:10 | 13:21 | 2:11 | LINE CLEAR AVAILED |
| 1071 | 29-Jul-2022 | HASSAN | 220 | SHRAVTY-SHIMOGA4 | sharavathy_gen | 13:29 | 17:09 | 3:40 | LINE FAULT |
| 1072 | 29-Jul-2022 | HASSAN | 220 | VARAH1-SHMG3 | varahi_gen | 8:46 | 16:10 | 7:24 | NFBC ISSUED |
| 1073 | 29-Jul-2022 | HASSAN | 110 | ANAVATI-BARNGI | ANAVATTI_110 | 7:45 | 8:50 | 1:05 | LINE CLEAR AVAILED |
| 1074 | 29-Jul-2022 | HASSAN | 110 | ANAVATI-BARNGI | ANAVATTI_110 | 16:12 | 17:08 | 0:56 | HAND TRIPPED |
| 1075 | 29-Jul-2022 | HASSAN | 110 | BARANG-ANVATTI | BARANGI_110 | 7:47 | 8:50 | 1:03 | LINE CLEAR AVAILED |
| 1076 | 29-Jul-2022 | HASSAN | 110 | BARANG-ANVATTI | BARANGI_110 | 16:04 | 17:10 | 1:06 | LINE CLEAR AVAILED |
| 1077 | 29-Jul-2022 | HASSAN | 110 | HV1 | BARANGI_110 | 16:04 | 17:10 | 1:06 | LINE CLEAR AVAILED |
| 1078 | 29-Jul-2022 | HASSAN | 110 | HV2 | BARANGI_110 | 16:04 | 17:10 | 1:06 | LINE CLEAR AVAILED |
| 1079 | 29-Jul-2022 | HASSAN | 110 | HV1 | HEGGUNJE_220 | 11:10 | 12:12 | 1:02 | LINE CLEAR AVAILED |
| 1080 | 29-Jul-2022 | HASSAN | 110 | KADUR-NERELEKERE | KADUR_220 | 11:34 | 12:01 | 0:27 | LINE CLEAR AVAILED |
| 1081 | 29-Jul-2022 | HASSAN | 110 | HV2 | KARAYA_110 | 14:43 | 15:00 | 0:17 | LINE CLEAR AVAILED |
| 1082 | 29-Jul-2022 | HASSAN | 110 | KEMAR-NANDHIKUR2 | KEMAR_220 | 10:45 | 13:16 | 2:31 | LINE CLEAR AVAILED |
| 1083 | 29-Jul-2022 | HASSAN | 110 | HV1 | KONAJE_110 | 8:12 | 8:21 | 0:09 | MAIN SUPPLY FAILURE |
| 1084 | 29-Jul-2022 | HASSAN | 110 | HV2 | KONAJE_110 | 8:12 | 8:21 | 0:09 | MAIN SUPPLY FAILURE |
| 1085 | 29-Jul-2022 | HASSAN | 110 | HV3 | KONAJE_110 | 8:12 | 8:21 | 0:09 | MAIN SUPPLY FAILURE |
| 1086 | 29-Jul-2022 | HASSAN | 110 | KONAJE-MANJESWARG | KONAJE_110 | 8:11 | 13:04 | 4:53 | LINE FAULT |
| 1087 | 29-Jul-2022 | HASSAN | 110 | LPH-LST4 | lph_gen | 12:27 | 14:43 | 2:16 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|-----------------------------|---|---------|-----------|----------|---------------------|
| 1088 | 29-Jul-2022 | HASSAN | 110 | SAGARA-LST4 | SAGARA_110 | 12:27 | 14:42 | 2:15 | LINE CLEAR AVAILED |
| 1089 | 29-Jul-2022 | HASSAN | 66 | HV2 | CHANNARAYAPATNA_220 | 8:26 | 8:45 | 0:19 | LINE CLEAR AVAILED |
| 1090 | 29-Jul-2022 | HASSAN | 66 | HV2 | CHANNARAYAPATNA_220 | 8:50 | 10:21 | 1:31 | LINE CLEAR AVAILED |
| 1091 | 29-Jul-2022 | HASSAN | 66 | HV2 | CHANNARAYAPATNA_220 | 10:20 | 11:20 | 1:00 | LINE CLEAR AVAILED |
| 1092 | 29-Jul-2022 | HASSAN | 66 | CHANNAR-MALLALI | CHANNARAYAPATNA_220 | 9:12 | 20:23 | 11:11 | LINE CLEAR AVAILED |
| 1093 | 29-Jul-2022 | HASSAN | 66 | CHIKABO-SIDPR | CHIKABOMMENAHALLI_66 | 9:08 | 9:20 | 0:12 | LINE FAULT |
| 1094 | 29-Jul-2022 | HASSAN | 66 | CHIKKAK-DUDDA | CHIKKAKONDAGOLA_66 | 18:20 | 20:30 | 2:10 | MAIN SUPPLY FAILURE |
| 1095 | 29-Jul-2022 | HASSAN | 66 | HV1 | GORUR_66 | 10:24 | 15:48 | 5:24 | LINE CLEAR AVAILED |
| 1096 | 29-Jul-2022 | HASSAN | 66 | HASSN22-R R NAGAR | HASSAN_220 | 17:16 | 17:39 | 0:23 | LINE FAULT |
| 1097 | 29-Jul-2022 | HASSAN | 66 | HASSN22-UDDURKOPLU | HASSAN_220 | 6:26 | 7:10 | 0:44 | LINE FAULT |
| 1098 | 29-Jul-2022 | HASSAN | 66 | HNPR2-HASS2 | HOLENARASIPURA_220 | 17:21 | 17:33 | 0:12 | LINE FAULT |
| 1099 | 29-Jul-2022 | HASSAN | 66 | HNPR2-HASS2 | HOLENARASIPURA_220 | 18:03 | 18:51 | 0:48 | LINE FAULT |
| 1100 | 29-Jul-2022 | HASSAN | 66 | UDDURKO-SUZLON | UDDURKOPLU_66 | 6:26 | 7:11 | 0:45 | LINE FAULT |
| 1101 | 29-Jul-2022 | HASSAN | 66 | UDDURKO-CKNDGL | UDDURKOPLU_66 | 18:20 | 21:37 | 3:17 | LINE FAULT |
| 1102 | 29-Jul-2022 | MYSURU | 66 | HV2 | BETTADHAPURA_66 | 19:08 | 19:42 | 0:33 | LINE CLEAR AVAILED |
| 1103 | 29-Jul-2022 | MYSURU | 66 | BG NAGARA-HIRISAVE | KADABALLY_66 | 2:01 | 2:08 | 0:06 | LINE FAULT |
| 1104 | 29-Jul-2022 | MYSURU | 66 | BEGUR220-SARGUR | NO STATIONS EFFECTED | 18:41 | 18:54 | 0:13 | LINE FAULT |
| 1105 | 29-Jul-2022 | MYSURU | 66 | CR NAGARA-KABBALLY | NO STATIONS EFFECTED | 14:33 | 14:48 | 0:15 | LINE FAULT |
| 1106 | 29-Jul-2022 | MYSURU | 66 | CR NAGARA-GUNDLUPETE | TERAKANAMBE_66 | 14:33 | 14:46 | 0:13 | LINE FAULT |
| 1107 | 29-Jul-2022 | MYSURU | 66 | HV1 | DEVANORNGUDU_66 | 14:17 | 17:21 | 3:04 | LINE CLEAR AVAILED |
| 1108 | 29-Jul-2022 | MYSURU | 66 | HV2 | GAMANAHALLY_66 | 11:00 | 11:35 | 0:35 | LINE CLEAR AVAILED |
| 1109 | 29-Jul-2022 | MYSURU | 66 | HV2 | GAMANAHALLY_66 | 16:00 | 19:00 | 3:00 | LINE CLEAR AVAILED |
| 1110 | 29-Jul-2022 | MYSURU | 66 | HV2 | GVGUDI_66 | 17:05 | 17:50 | 0:44 | TRANSFORMER FAULT |
| 1111 | 29-Jul-2022 | MYSURU | 66 | HV1 | HALAGUR_66 | 10:14 | 10:35 | 0:21 | MAIN SUPPLY FAILURE |
| 1112 | 29-Jul-2022 | MYSURU | 66 | HV2 | HALAGUR_66 | 10:14 | 10:35 | 0:21 | MAIN SUPPLY FAILURE |
| 1113 | 29-Jul-2022 | MYSURU | 66 | HV1 | HALAGUR_66 | 17:30 | 17:35 | 0:05 | MAIN SUPPLY FAILURE |
| 1114 | 29-Jul-2022 | MYSURU | 66 | HV2 | HALAGUR_66 | 17:30 | 17:35 | 0:05 | MAIN SUPPLY FAILURE |
| 1115 | 29-Jul-2022 | MYSURU | 66 | HV1 | HANAGODU_66 | 0:55 | 1:04 | 0:09 | TRANSFORMER FAULT |
| 1116 | 29-Jul-2022 | MYSURU | 66 | HV1 | HANAGODU_66 | 6:40 | 7:02 | 0:21 | TRANSFORMER FAULT |
| 1117 | 29-Jul-2022 | MYSURU | 66 | HV1 | HANAGODU_66 | 20:09 | 20:25 | 0:15 | TRANSFORMER FAULT |
| 1118 | 29-Jul-2022 | MYSURU | 220 | KADAKOLA-KOZIKODE | NO STATIONS EFFECTED | 11:14 | 19:51 | 8:37 | LINE CLEAR AVAILED |
| 1119 | 29-Jul-2022 | MYSURU | 66 | HV1 | KHBCOLONY_66 | 13:40 | 13:58 | 0:18 | LINE CLEAR AVAILED |
| 1120 | 29-Jul-2022 | MYSURU | 66 | HV2 | KHBCOLONY_66 | 13:40 | 13:58 | 0:18 | LINE CLEAR AVAILED |
| 1121 | 29-Jul-2022 | MYSURU | 66 | HV2 | KHBCOLONY_66 | 15:28 | 17:31 | 2:03 | LINE CLEAR AVAILED |
| 1122 | 29-Jul-2022 | MYSURU | 66 | MADHUVANAHALLY-KOLLEGALA | KOLLEGALA_66 | 19:02 | 19:11 | 0:09 | LINE FAULT |
| 1123 | 29-Jul-2022 | MYSURU | 66 | MADHUVANAHALLY-LOKKANAHALLI | LOKKANAHALLI_66 PGPALYA_66 | 12:17 | 12:22 | 0:05 | LINE FAULT |
| 1124 | 29-Jul-2022 | MYSURU | 220 | HV1 | NAGAMANGALA_220 | 0:29 | 0:49 | 0:20 | TRANSFORMER FAULT |
| 1125 | 29-Jul-2022 | MYSURU | 66 | NAGAMANGALA 220-KASALGERE | BESAGARAHALLI_66 DUNDANAHALLI_66 KESLAGERE_66 KOPPA_66 | 0:29 | 0:42 | 0:13 | LINE FAULT |
| 1126 | 29-Jul-2022 | MYSURU | 66 | HV2 | MANDYA_66 | 10:28 | 11:25 | 0:57 | LINE CLEAR AVAILED |
| 1127 | 29-Jul-2022 | MYSURU | 66 | HV1 | PANDAVAPURA_66 | 15:33 | 19:16 | 3:42 | LINE CLEAR AVAILED |
| 1128 | 29-Jul-2022 | MYSURU | 66 | PONNAMPETE-VIRAJPETE | VIRAJPET_66 | 11:36 | 12:52 | 1:16 | LINE CLEAR AVAILED |
| 1129 | 29-Jul-2022 | MYSURU | 66 | HV1 | SATHEGALA_66 | 16:05 | 16:27 | 0:22 | LINE CLEAR AVAILED |
| 1130 | 29-Jul-2022 | MYSURU | 66 | HV2 | SATHEGALA_66 | 16:17 | 17:25 | 1:08 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|---|--|--------------------------|-----------|----------|-------------------------------------|
| 1131 | 29-Jul-2022 | MYSURU | 66 | SANTHE SARAGUR-KADAKOLA 1 | NO STATIONS EFFECTED | 1:39 | 1:50 | 0:10 | LINE FAULT |
| 1132 | 29-Jul-2022 | MYSURU | 66 | SB HALLI-ADDIHALLI | ADDIHALLI_66 ADICHUNCHANAGIRI_66 BGNAGARA_66 KADABALLY_66 | 1:33 | 1:43 | 0:10 | LINE FAULT |
| 1133 | 29-Jul-2022 | MYSURU | 66 | SB HALLI-HUYGONAHALLI 1 | NO STATIONS EFFECTED | 1:33 | 1:42 | 0:09 | LINE FAULT |
| 1134 | 29-Jul-2022 | MYSURU | 66 | HV2 | SANTHEBACHALLI_66 | 17:58 | 18:21 | 0:23 | LINE CLEAR AVAILED |
| 1135 | 29-Jul-2022 | MYSURU | 66 | SFC SIVA-HEBBANI 6 | NO STATIONS EFFECTED | 1:32 | 1:47 | 0:14 | LINE FAULT |
| 1136 | 29-Jul-2022 | MYSURU | 66 | SFC SIVA-PGL | NO STATIONS EFFECTED | 1:32 | 1:40 | 0:07 | LINE FAULT |
| 1137 | 29-Jul-2022 | MYSURU | 66 | HV2 | SHEELUNERE_66 | 17:55 | 18:00 | 0:05 | TRANSFORMER FAULT |
| 1138 | 29-Jul-2022 | MYSURU | 66 | TUBINAKERE-MC-4 | NO STATIONS EFFECTED | 5:42 | 5:52 | 0:10 | LINE FAULT |
| 1139 | 29-Jul-2022 | MYSURU | 66 | HV1 | VAJAMANGALA_220 | 5:41 | 6:45 | 1:04 | TRANSFORMER FAULT |
| 1140 | 29-Jul-2022 | MYSURU | 66 | VYASARAJAPURA-THUBLA | GARGESHWARI_66 THUMBLA_66 TNARASIPURA_66 VYASRAJPURA_66 | 18:13 | 18:22 | 0:09 | LINE FAULT |
| 1141 | 29-Jul-2022 | MYSURU | 66 | HV1 | GUNDLUPETE_66 | 17:02:00 (12.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1142 | 29-Jul-2022 | MYSURU | 220 | HV2 | MADHUVANAHALLI_220 | 18:57:18 (31.5.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1143 | 29-Jul-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 18:26 (22/04/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1144 | 29-Jul-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16:00 (08/12/2021) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1145 | 29-Jul-2022 | MYSURU | 220 | HV1 | KADAKOLA_220 | 1:41:14 (21/07/2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1146 | 29-Jul-2022 | TUMKUR | 220 | DAVANGERE SRS- SHIMOGA 2 | DAVANGERE_SRS_220 | 14:20(27.07.2022) | | | LINE OPEN, LINE FAULT |
| 1147 | 29-Jul-2022 | TUMKUR | 220 | ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 1 | ANTHRASANAHALLI_220 | 1:50 | 12:18 | 10:28 | LINE FAULT |
| 1148 | 29-Jul-2022 | TUMKUR | 220 | TR3 | ANTHRASANAHALLI_220 | 1:50 | 2:05 | 0:15 | TRANSFORMER FAULT |
| 1149 | 29-Jul-2022 | TUMKUR | 220 | ANTHRASANAHALLI 220KV- KBCROSS | ANTHRASANAHALLI_220 | 12:23 | 12:38 | 0:15 | LINE FAULT |
| 1150 | 29-Jul-2022 | TUMKUR | 220 | TR3 | HIRIYUR_220 | 0:58 | 1:20 | 0:22 | TRANSFORMER FAULT |
| 1151 | 29-Jul-2022 | TUMKUR | 220 | HONNALLI 220kv-DAVANAGERE SRS | HONNALLI_220 | 12:31 | 12:44 | 0:13 | MAIN SUPPLY FAILURE |
| 1152 | 29-Jul-2022 | TUMKUR | 220 | TR1 | HONNALLI_220 | 12:34 | 12:49 | 0:15 | MAIN SUPPLY FAILURE |
| 1153 | 29-Jul-2022 | TUMKUR | 220 | TR2 | HONNALLI_220 | 12:34 | 12:52 | 0:18 | MAIN SUPPLY FAILURE |
| 1154 | 29-Jul-2022 | TUMKUR | 220 | DAVANGERE SRS- GUTTUR-2 | DAVANGERE_SRS_220 | 16:18(29.7.22) | | | MAIN SUPPLY FAILURE |
| 1155 | 29-Jul-2022 | TUMKUR | 220 | CHITRADURGA 220- GUTTUR 220 | CHITRADURGA_220 | 10:20 | 18:50 | 8:30 | MAIN SUPPLY FAILURE |
| 1156 | 29-Jul-2022 | TUMKUR | 220 | NITTUR 220-NELAMANGALA | NITTUR_220 | 10:16 | 19:16 | 9:00 | LINE CLEAR AVAILED |
| 1157 | 29-Jul-2022 | TUMKUR | 220 | BENKIKER 220-220KV HONNALI LINE-1 | BENKIKERE_220 | 12:31 | 12:45 | 0:14 | MAIN SUPPLY FAILURE |
| 1158 | 29-Jul-2022 | TUMKUR | 220 | BENKIKER 220-220KV HONNALI LINE-2 | BENKIKERE_220 | 12:31 | 12:45 | 0:14 | MAIN SUPPLY FAILURE |
| 1159 | 29-Jul-2022 | TUMKUR | 220 | TR1 | BENKIKERE_220 | 12:31 | 12:45 | 0:14 | MAIN SUPPLY FAILURE |
| 1160 | 29-Jul-2022 | TUMKUR | 220 | TR2 | BENKIKERE_220 | 12:31 | 12:45 | 0:14 | MAIN SUPPLY FAILURE |
| 1161 | 29-Jul-2022 | TUMKUR | 220 | PAVAGADA_220-MADHUGIRI_220 LINE-2 | PAVAGADA_220 | 2:45 | 8:05 | 5:20 | LINE FAULT |
| 1162 | 29-Jul-2022 | TUMKUR | 220 | BENKIKERE_220-HOSADURGA_220 | HOSADURGA_220 | 12:30 | 12:45 | 0:15 | MAIN SUPPLY FAILURE |
| 1163 | 29-Jul-2022 | TUMKUR | 220 | TR1 | HOSADURGA_220 | 12:30 | 12:45 | 0:15 | MAIN SUPPLY FAILURE |
| 1164 | 29-Jul-2022 | TUMKUR | 220 | TR2 | HOSADURGA_220 | 12:30 | 12:45 | 0:15 | MAIN SUPPLY FAILURE |
| 1165 | 29-Jul-2022 | TUMKUR | 110 | KB CROSS 220kv- AMMASANDRA_110 | AMMASANDRA_110,SAMPIGE_110 | 12:24 | 12:30 | 0:06 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|--|--|---------|-----------|----------|---------------------|
| 1166 | 29-Jul-2022 | TUMKUR | 110 | KB CROSS 220kV- MAYASANDRA | MAYASANDRA_110, TALKERE_110,KADEHALLI_110, | 12:24 | 12:30 | 0:06 | LINE CLEAR AVAILED |
| 1167 | 29-Jul-2022 | TUMKUR | 110 | KB CROSS 220kV- AMMASANDRA_110 | AMMASANDRA_110,SAMPIGE_110 | 1:52 | 2:02 | 0:10 | LINE FAULT |
| 1168 | 29-Jul-2022 | TUMKUR | 110 | NITTUR 220-SOMLAPURA110 | NITTUR_220 | 8:55 | 9:15 | 0:20 | LINE FAULT |
| 1169 | 29-Jul-2022 | TUMKUR | 110 | NITTUR 220-SOMLAPURA110 | NITTUR_220 | 11:01 | 11:45 | 0:44 | LINE FAULT |
| 1170 | 29-Jul-2022 | TUMKUR | 110 | NITTUR 220-SOMLAPURA110 | NITTUR_220 | 15:25 | 17:20 | 1:55 | LINE CLEAR AVAILED |
| 1171 | 29-Jul-2022 | TUMKUR | 66 | ANTHRASANAHALLI 220kV- KORATEGERE | KORATEGERE,CHIKKATOTLUKERE_66, BELADARA_66 | 1:30 | 1:46 | 0:16 | LINE FAULT |
| 1172 | 29-Jul-2022 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- KORA | KORA_66, BRAKMASANDRA_66,THOVINAKERE_66,ANKASA NDRA_66 | 1:50 | 2:08 | 0:18 | HAND TRIPPED |
| 1173 | 29-Jul-2022 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- BELLAVI | BELLAVI_66,MALLASANDRA_66, HEGGERE_66, DODDASARANGI_66 | 2:15 | 3:40 | 1:25 | LINE FAULT |
| 1174 | 29-Jul-2022 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- MELEKOTE | MELKOTE_66, BADDIHALLI_66 | 3:18 | 3:41 | 0:23 | LINE FAULT |
| 1175 | 29-Jul-2022 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- MELEKOTE | MELKOTE_66, BADDIHALLI_66 | 3:41 | 9:08 | 5:27 | LINE FAULT |
| 1176 | 29-Jul-2022 | TUMKUR | 66 | TR1 | ANTHRASANAHALLI_220 | 1:50 | 2:08 | 0:18 | HAND TRIPPED |
| 1177 | 29-Jul-2022 | TUMKUR | 66 | TR2 | ANTHRASANAHALLI_220 | 1:50 | 2:08 | 0:18 | HAND TRIPPED |
| 1178 | 29-Jul-2022 | TUMKUR | 66 | TR3 | ANTHRASANAHALLI_220 | 1:50 | 2:08 | 0:18 | HAND TRIPPED |
| 1179 | 29-Jul-2022 | TUMKUR | 66 | THALLAK 220kV- GOWRASAMUDRA | GOWRASAMUDRA_66 | 3:35 | 3:50 | 0:15 | LINE FAULT |
| 1180 | 29-Jul-2022 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR1 | WELSPUNSOLAR1_IPP_66 | 8:22 | 8:38 | 0:16 | LINE FAULT |
| 1181 | 29-Jul-2022 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR2 | WELSPUN SOLAR2 | 8:22 | 8:38 | 0:16 | LINE FAULT |
| 1182 | 29-Jul-2022 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR1 | WELSPUNSOLAR1_IPP_66 | 8:51 | 8:59 | 0:08 | LINE FAULT |
| 1183 | 29-Jul-2022 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR2 | WELSPUN SOLAR2 | 8:51 | 8:59 | 0:08 | LINE FAULT |
| 1184 | 29-Jul-2022 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR1 | WELSPUNSOLAR1_IPP_66 | 10:04 | 11:31 | 1:27 | LINE FAULT |
| 1185 | 29-Jul-2022 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR2 | WELSPUN SOLAR2 | 10:04 | 11:46 | 1:42 | LINE FAULT |
| 1186 | 29-Jul-2022 | TUMKUR | 66 | HONNALLI 220kV-SUZLON-1 | HONNALLI_220 | 12:34 | 12:47 | 0:13 | MAIN SUPPLY FAILURE |
| 1187 | 29-Jul-2022 | TUMKUR | 66 | HONNALLI 220kV-SUZLON-2 | HONNALLI_220 | 12:34 | 12:47 | 0:13 | MAIN SUPPLY FAILURE |
| 1188 | 29-Jul-2022 | TUMKUR | 66 | HONNALI66-HONNALLI220 | HONNALLI_66 | 12:34 | 12:56 | 0:22 | MAIN SUPPLY FAILURE |
| 1189 | 29-Jul-2022 | TUMKUR | 66 | HONNALLI 220KV- NYAMATHI | CHILLUR_66, NYAMATHI_66, SAVALANGA_66 | 12:34 | 12:56 | 0:22 | MAIN SUPPLY FAILURE |
| 1190 | 29-Jul-2022 | TUMKUR | 66 | HONNALLI 220KV- SASUVEHALLI | SASUVEHALLI_66,CHANNAGIRI_66 | 12:34 | 12:54 | 0:20 | MAIN SUPPLY FAILURE |
| 1191 | 29-Jul-2022 | TUMKUR | 66 | HONNALLI 220kV- CHANNAGIRI(NALLUR) | DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66 | 12:34 | 12:55 | 0:21 | MAIN SUPPLY FAILURE |
| 1192 | 29-Jul-2022 | TUMKUR | 66 | HONNALLI 220kV- KUNDUR66 | KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66 | 12:34 | 12:57 | 0:23 | MAIN SUPPLY FAILURE |
| 1193 | 29-Jul-2022 | TUMKUR | 66 | HONNALLI 220kV- BANUVALLI | BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66 | 12:34 | 12:58 | 0:24 | MAIN SUPPLY FAILURE |
| 1194 | 29-Jul-2022 | TUMKUR | 66 | TR1 | HONNALLI_220 | 12:34 | 12:49 | 0:15 | MAIN SUPPLY FAILURE |
| 1195 | 29-Jul-2022 | TUMKUR | 66 | TR2 | HONNALLI_220 | 12:34 | 12:53 | 0:19 | HAND TRIPPED |
| 1196 | 29-Jul-2022 | TUMKUR | 66 | CHITRADURGA 66kV- CHITRADURGA 1 | CHITRADURGA_66 | 9:18 | 9:27 | 0:09 | HAND TRIPPED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|---------------------------------------|---|-----------------------|-----------|----------|-------------------------------------|
| 1197 | 29-Jul-2022 | TUMKUR | 66 | CHITRADURGA 66kV-CHITRADURGA 2 | CHITRADURGA_66 | 9:18 | 9:27 | 0:09 | HAND TRIPPED |
| 1198 | 29-Jul-2022 | TUMKUR | 66 | CHITRADURGA 66kV-CHITRADURGA 1 | CHITRADURGA_66 | 12:23 | 15:29 | 3:06 | LINE CLEAR AVAILED |
| 1199 | 29-Jul-2022 | TUMKUR | 66 | CHITRADURGA 66kV-CHITRADURGA 2 | CHITRADURGA_66 | 12:23 | 15:29 | 3:06 | LINE CLEAR AVAILED |
| 1200 | 29-Jul-2022 | TUMKUR | 66 | CHITRADURGA 66kV-PANDARAHALLI 1 | CHITRADURGA_66 OLD MUSS,PANDARAHALLI_66,CHITRAHALLI_66,HDP URA_66,HOLALKERE_66,RAMGIRI_66 | 11:34 | 13:32 | 1:58 | LINE CLEAR AVAILED |
| 1201 | 29-Jul-2022 | TUMKUR | 66 | CHITRADURGA 66kV-PANDARAHALLI 2 | P1&P2 CLUB | 11:18 | 13:52 | 2:34 | LINE CLEAR AVAILED |
| 1202 | 29-Jul-2022 | TUMKUR | 66 | SIRA_220-66KV TAVAREKERE | SIRA_220 | 15:29 | 0:00 | 8:31 | LINE CLEAR AVAILED |
| 1203 | 29-Jul-2022 | TUMKUR | 66 | SIRA_220-66KV TAVAREKERE | SIRA_220 | 17:25 | 17:26 | 0:01 | HAND TRIPPED |
| 1204 | 29-Jul-2022 | TUMKUR | 66 | BENKIKER 220- BENKIKERE66 | BENKIKERE_220 | 12:31 | 12:45 | 0:14 | MAIN SUPPLY FAILURE |
| 1205 | 29-Jul-2022 | TUMKUR | 66 | BENKIKER 220-MALADIHALLI_66 | BENKIKERE_220 | 12:31 | 12:45 | 0:14 | MAIN SUPPLY FAILURE |
| 1206 | 29-Jul-2022 | TUMKUR | 66 | UCHANGIDURGA-PUNABHAGATTA(neelagunda) | BILCHODU_66 | 13:20 | 13:35 | 0:15 | MAIN SUPPLY FAILURE |
| 1207 | 29-Jul-2022 | TUMKUR | 66 | SASUVEHALLI_66-CHANNAGIRI_66 | CHANNAGIRI_66 | 16:55 | 17:10 | 0:15 | MAIN SUPPLY FAILURE |
| 1208 | 29-Jul-2022 | TUMKUR | 66 | SASUVEHALLI_66-CHANNAGIRI_66 | CHANNAGIRI_66 | 12:30 | 12:55 | 0:25 | MAIN SUPPLY FAILURE |
| 1209 | 29-Jul-2022 | TUMKUR | 66 | TR2 | CHANNAGIRI_66 | 17:35 | 17:45 | 0:10 | TRANSFORMER FAULT |
| 1210 | 29-Jul-2022 | TUMKUR | 66 | HOLALKERE- RAMGIRI 1 | HOLALKERE_66 | 6:35 | 6:40 | 0:05 | LINE FAULT |
| 1211 | 29-Jul-2022 | TUMKUR | 66 | HANGAL66-RAMPURA | RAMPURA_66 | 22:20 | 0:00 | 1:40 | LINE FAULT |
| 1212 | 29-Jul-2022 | TUMKUR | 66 | HIREHALLI - BADDIHALLI | HIREHALLI_66 | 4:29 | 4:39 | 0:10 | HAND TRIPPED |
| 1213 | 29-Jul-2022 | TUMKUR | 66 | TR1 | HONNALI_66 | 18:40 | 18:50 | 0:10 | TRANSFORMER FAULT |
| 1214 | 29-Jul-2022 | TUMKUR | 66 | KORATAGERE66-MADHUGIRI | KORATAGERE_66 | 13:30 | 14:00 | 0:30 | LINE FAULT |
| 1215 | 29-Jul-2022 | TUMKUR | 66 | HOLALKERE- RAMGIRI 2 | SASALUHALLA_66 | 16:10 | 16:25 | 0:15 | MAIN SUPPLY FAILURE |
| 1216 | 29-Jul-2022 | TUMKUR | 66 | HOLALKERE- RAMGIRI 2 | SASALUHALLA_66 | 18:40 | 18:50 | 0:10 | MAIN SUPPLY FAILURE |
| 1217 | 29-Jul-2022 | TUMKUR | 66 | TR1 | NIDSALE_66 | 21:15 | 23:00 | 1:45 | TRANSFORMER FAULT |
| 1218 | 29-Jul-2022 | TUMKUR | 66 | TR2 | PULAMAGATTA_66 | 6:30 | 20:15 | 13:45 | TRANSFORMER FAULT |
| 1219 | 29-Jul-2022 | TUMKUR | 66 | KALAMARANAHALLI- HIRIYUR220KV | KALAMARANAHALLI_66 | 16:40 | 21:05 | 4:25 | MAIN SUPPLY FAILURE |
| 1220 | 29-Jul-2022 | TUMKUR | 66 | KALAMARANAHALLI-BPCLSOLAR_IPP_66 | BPCLSOLAR_IPP_66 | 23:30 | 23:40 | 0:10 | LINE FAULT |
| 1221 | 29-Jul-2022 | TUMKUR | 66 | KALAMARANAHALLI-BPCLSOLAR_IPP_66 | BPCLSOLAR_IPP_66 | 23:45 | 0:00 | 0:15 | LINE FAULT |
| 1222 | 29-Jul-2022 | TUMKUR | 66 | DASUDI66-HIRIYUR220 | DASUDI_66 | 17:35 | 17:45 | 0:10 | MAIN SUPPLY FAILURE |
| 1223 | 29-Jul-2022 | TUMKUR | 66 | TR2 | DASUDI_66 | 12:30 | 13:00 | 0:30 | LINE CLEAR AVAILED |
| 1224 | 30-Jul-2022 | BAGALKOT | 220 | SIRSI-HUBLI-1 | STATION NOT AFFECTED SIRSI_220 | 19:46 (15.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1225 | 30-Jul-2022 | BAGALKOT | 220 | SIRSI-HUBLI-2 | STATION NOT AFFECTED SIRSI_220 | 19:46 (15.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1226 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED TODALBAGI_110 | 19:13 (17.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1227 | 30-Jul-2022 | BAGALKOT | 110 | TODALBAGI-SAVALAGI | STATION NOT AFFECTED TODALBAGI_110 | 18:00 (20.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1228 | 30-Jul-2022 | BAGALKOT | 110 | UTTUR - F1 JAMB CB(MUDHOL) | STATION NOT AFFECTED UTTUR_110 | 9:51 (24.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--|--|----------------------|-----------------------|----------|-------------------------------------|
| 1229 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV3 | STATION NOT AFFECTED BILAGI_110 | 7:28 (29.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1230 | 30-Jul-2022 | BAGALKOT | 110 | BIDNAL-NAVALGUND | NAVALGUND_110 | 17:57 (29.07.2022) | 12:21 (30.07.2022) | 18:24HRS | LINE CHARGED |
| 1231 | 30-Jul-2022 | BAGALKOT | 110 | CHIKKODI220-SADALGA | SADALGA_110 | 6:43 | 8:25 | 1:42 | LINE FAULT |
| 1232 | 30-Jul-2022 | BAGALKOT | 220 | HUBLI-NAGAZARI-3 | STATION NOT AFFECTED HUBLI_220 | 9:04 | 13:48 | 4:44 | NFBC ISSUED |
| 1233 | 30-Jul-2022 | BAGALKOT | 220 | HUBLI-NARENDRA-1 | STATION NOT AFFECTED HUBLI_220 | 12:18 | 15:05 | 2:47 | LINE FAULT |
| 1234 | 30-Jul-2022 | BAGALKOT | 220 | HUBLI-SIRSI-1 | STATION NOT AFFECTED HUBLI_220 | 12:30 | 18:15 | 5:45 | LINE FAULT |
| 1235 | 30-Jul-2022 | BAGALKOT | 220 | HUBLI-SIRSI-2 | STATION NOT AFFECTED HUBLI_220 | 13:38 | 13:39 | 0:01 | LINE FAULT |
| 1236 | 30-Jul-2022 | BAGALKOT | 220 | HAVERI-BIDNAL | STATION NOT AFFECTED HAVERI_220 | 16:15 | 20:25 | 4:10 | LINE FAULT |
| 1237 | 30-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV-3 & LV3 | STATION NOT AFFECTED BELAGAVI_220 | 15:55 | 17:59 | 2:04 | LINE CLEAR AVAILED |
| 1238 | 30-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV-1 | STATION NOT AFFECTED BELAGAVI_220 | 12:27 | 14:25 | 1:58 | LINE CLEAR AVAILED |
| 1239 | 30-Jul-2022 | BAGALKOT | 110 | 220/110KV, LV-1 | STATION NOT AFFECTED BELAGAVI_220 | 12:27 | 14:28 | 2:01 | LINE CLEAR AVAILED |
| 1240 | 30-Jul-2022 | BAGALKOT | 220 | NARENDRA-HUBLI-1 | STATION NOT AFFECTED NARENDRA_220 | 12:19 | 18:09 | 5:50 | LINE FAULT |
| 1241 | 30-Jul-2022 | BAGALKOT | 110 | MUGALKHOD220- RAIBAG-2 | STATION NOT AFFECTED MUGALKHOD_220 | 10:09 | 11:46 | 1:37 | LINE CLEAR AVAILED |
| 1242 | 30-Jul-2022 | BAGALKOT | 110 | MUGALKHOD220- SULTANPUR | STATION NOT AFFECTED MUGALKHOD_220 | 10:42 | 12:02 | 1:20 | LINE CLEAR AVAILED |
| 1243 | 30-Jul-2022 | BAGALKOT | 110 | MUGALKHOD220- ITNAL-2 | STATION NOT AFFECTED MUGALKHOD_220 | 11:14 | 12:40 | 1:26 | LINE CLEAR AVAILED |
| 1244 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV-1 | STATION NOT AFFECTED KUDACHI_220 | 14:33 | 14:36 | 0:03 | TRANSFORMER FAULT |
| 1245 | 30-Jul-2022 | BAGALKOT | 220 | AMBEWADI_NAGZARI-2 | STATION NOT AFFECTED AMBEWADI_220 | 9:33 | 18:24 | 8:51 | LINE CLEAR AVAILED |
| 1246 | 30-Jul-2022 | BAGALKOT | 110 | BELAGAVI20-ANKALAGI | STATION NOT AFFECTED BELAGAVI_220 | 6:05 | 9:41 | 3:36 | LINE FAULT |
| 1247 | 30-Jul-2022 | BAGALKOT | 110 | 110/33KV, HV4 | DULAKHED_33 HALASANGI_33 NIVARGI_33 STATION NOT AFFECTED ZALKI_110 | 1:08 | 2:11 | 1:03 | TRANSFORMER FAULT |
| 1248 | 30-Jul-2022 | BAGALKOT | 110 | AIGALI-SAVALAGI | AIGALI_110 | 6:46 | 13:50 | 7:04 | LINE CLEAR AVAILED |
| 1249 | 30-Jul-2022 | BAGALKOT | 110 | AINAPUR-ATHANI SUGARS | AINAPUR_110 | 7:25 | 7:36 | 0:11 | LINE FAULT |
| 1250 | 30-Jul-2022 | BAGALKOT | 110 | ALMEL-KPR SUGARS &JAMAKHANDU SUGARS | ALMEL_110 | 6:26 | 7:13 | 0:47 | HAND TRIPPED |
| 1251 | 30-Jul-2022 | BAGALKOT | 110 | MAMADAPUR-BABALESHWAR | BABALESHWAR_110 | 21:17 | 21:33 | 0:16 | HAND TRIPPED |
| 1252 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | BABALESHWAR_110 | 21:17 | 21:29 | 0:12 | HAND TRIPPED |
| 1253 | 30-Jul-2022 | BAGALKOT | 220 | BAGEWADI-FORTUNE FIVE 2 | BAGEWADI_220 | 1:41 | 12:44 | 11:03 | LINE CLEAR AVAILED |
| 1254 | 30-Jul-2022 | BAGALKOT | 220 | BIDNAL-HAVERI | BIDNAL_220 | 16:15 | 20:27 | 4:12 | LINE FAULT |
| 1255 | 30-Jul-2022 | BAGALKOT | 110 | BAGEWADI-CHAND KAVATE | CHANDKAVATE_110 | 5:23 | 5:30 | 0:07 | LINE FAULT |
| 1256 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV3 | GHTATAPRABHA_110 | 16:55 | 17:21 | 0:26 | TRANSFORMER FAULT |
| 1257 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV3 | GHTATAPRABHA_110 | 18:09 | 18:12 | 0:03 | TRANSFORMER FAULT |
| 1258 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | GOKAK_110 | 19:41 | 20:07 | 0:26 | TRANSFORMER FAULT |
| 1259 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | HIEMASALI_110 | 9:35 | 9:43 | 0:08 | TRANSFORMER FAULT |
| 1260 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | HIEMASALI_110 | 10:55 | 10:59 | 0:04 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|-----------------------------|--|-----------------------|----------------------|----------|-------------------------------------|
| 1261 | 30-Jul-2022 | BAGALKOT | 110 | HUNGUND-ILKAL | HUNGUND_110 | 15:31 | 18:00 | 2:29 | LINE CLEAR AVAILED |
| 1262 | 30-Jul-2022 | BAGALKOT | 110 | ITANAL-KABBUR | KABBUR_110 | 11:13 | 12:41 | 1:28 | LINE CLEAR AVAILED |
| 1263 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | KAMBAGI_110 | 11:02 | 11:10 | 0:08 | TRANSFORMER FAULT |
| 1264 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | KAMBAGI_110 | 13:30 | 13:37 | 0:07 | TRANSFORMER FAULT |
| 1265 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | KUDACHI_110 | 14:33 | 14:36 | 0:03 | TRANSFORMER FAULT |
| 1266 | 30-Jul-2022 | BAGALKOT | 110 | KULAGERI-MRN | KULAGERI CROSS_110 | 6:10 | 6:13 | 0:03 | LINE FAULT |
| 1267 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | LOKAPUR_110 | 1:01 | 2:01 | 1:00 | TRANSFORMER FAULT |
| 1268 | 30-Jul-2022 | BAGALKOT | 110 | LOKAPUR-DALMIA CEMENTS | LOKAPUR_110 | 22:12 | 22:32 | 0:20 | LINE FAULT |
| 1269 | 30-Jul-2022 | BAGALKOT | 110 | BAGEWADI-MAMADAPUR1 | MAMADAPUR_110 | 6:09 | 6:16 | 0:07 | LINE FAULT |
| 1270 | 30-Jul-2022 | BAGALKOT | 110 | MANTUR-NIRANI | MANTUR_110 | 7:59 | 14:59 | 7:00 | LINE FAULT |
| 1271 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | MUDDEBIHAL_110 | 8:43 | 8:56 | 0:13 | TRANSFORMER FAULT |
| 1272 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | MUDDEBIHAL_110 | 15:50 | 17:05 | 1:15 | TRANSFORMER FAULT |
| 1273 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV2 | NANADI_110 | 12:51 | 13:23 | 0:32 | LINE CLEAR AVAILED |
| 1274 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | NANADI_110 | 14:10 | 17:42 | 3:32 | LINE CLEAR AVAILED |
| 1275 | 30-Jul-2022 | BAGALKOT | 110 | SAVALGI-AIGALI | SAVALAGI_110 | 2:58 | 6:59 | 4:01 | LOAD CHANGE OVER |
| 1276 | 30-Jul-2022 | BAGALKOT | 110 | SAVALGI-AIGALI | SAVALAGI_110 | 2:58 | 6:59 | 4:01 | LINE CLEAR AVAILED |
| 1277 | 30-Jul-2022 | BAGALKOT | 110 | TAKKALAKI-THORVI | THORVI_110 | 20:44 | 22:24 | 1:40 | LINE CLEAR AVAILED |
| 1278 | 30-Jul-2022 | BAGALKOT | 110 | YALLAMANAWADI-AIGALI | YALLAMNAVADI_110 | 0:23 | 0:31 | 0:08 | LINE FAULT |
| 1279 | 30-Jul-2022 | BAGALKOT | 110 | YALLAMANAWADI-AIGALI | YALLAMNAVADI_110 | 0:58 | 3:31 | 2:33 | LINE FAULT |
| 1280 | 30-Jul-2022 | BAGALKOT | 110 | YALLAMANAWADI-AIGALI | YALLAMNAVADI_110 | 7:39 | 13:41 | 6:02 | LINE CLEAR AVAILED |
| 1281 | 30-Jul-2022 | BAGALKOT | 110 | YALLAMANAWADI-SAVALAGI | YALLAMNAVADI_110 | 13:41 | 18:00 | 4:19 | LINE CLEAR AVAILED |
| 1282 | 30-Jul-2022 | BAGALKOT | 110 | 110/33KV, HV3 | STATION NOT AFFECTED YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1283 | 30-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV1 | STATION NOT AFFECTED AMBEWADI_220 | 20:00 (09.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1284 | 30-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV-3 & LV3 | STATION NOT AFFECTED ATHANI_220 | 10:26 (25.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1285 | 30-Jul-2022 | BAGALKOT | 220 | NARENDRA-BELAGAVI-2 | STATION NOT AFFECTED NARENDRA_220 | 20:17 (29.07.2022) | 8:39 (30.07.2022) | 12:22HRS | LINE CHARGED |
| 1286 | 30-Jul-2022 | BAGALKOT | 220 | BELAGAVI-NARENDRA-2 | STATION NOT AFFECTED BELAGAVI_220 | 20:18 (29.07.2022) | 9:18 (30.07.2022) | 13:00HRS | LINE CHARGED |
| 1287 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED GIRISAGAR_110 | 8:40 | 8:45 | 0:05 | TRANSFORMER FAULT |
| 1288 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV2 | STATION NOT AFFECTED BILAGI_110 | 16:45 | 17:20 | 0:35 | LINE CLEAR AVAILED |
| 1289 | 30-Jul-2022 | BAGALKOT | 110 | SADALAGA-CHKODI (BORAGAON) | BORGAON_110 | 6:45 | 7:50 | 1:05 | LINE FAULT |
| 1290 | 30-Jul-2022 | BAGALKOT | 110 | SADALAGA-CHKODI (BORAGAON) | BORGAON_110 | 7:50 | 8:20 | 0:30 | LINE CLEAR AVAILED |
| 1291 | 30-Jul-2022 | BAGALKOT | 110 | INDI220-DEVARHIPARGID | DEVARHIPARGID_110 HIREMASALI_110 ATHARGA_110 | 6:15 | 6:30 | 0:15 | LINE FAULT |
| 1292 | 30-Jul-2022 | BAGALKOT | 110 | INDI220-LACHYAN | LACHYAN_110 HIREBVANUR_110 RODAGI_110 | 6:15 | 6:33 | 0:18 | LINE FAULT |
| 1293 | 30-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-RAMDURG | STATION NOT AFFECTED BAGALKOT_220 | 6:10 | 6:25 | 0:15 | LINE FAULT |
| 1294 | 30-Jul-2022 | BAGALKOT | 220 | BELAGAVI-NARENDRA-2 | STATION NOT AFFECTED BELAGAVI_220 | 10:50 | 19:24 | 8:34 | LINE CLEAR AVAILED |
| 1295 | 30-Jul-2022 | BAGALKOT | 220 | BELAGAVI-AEQUS (CHIKKODI)-1 | STATION NOT AFFECTED BELAGAVI_220 | 10:40 | 19:32 | 8:52 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|---|--|---------|-----------|----------|---------------------|
| 1296 | 30-Jul-2022 | BAGALKOT | 220 | BELAGAVI-AEQUS (CHIKKODI)-2 | STATION NOT AFFECTED BELAGAVI_220 | 9:33 | 18:32 | 8:59 | LINE CLEAR AVAILED |
| 1297 | 30-Jul-2022 | BAGALKOT | 220 | NARENDRA-BELAGAVI-2 | STATION NOT AFFECTED NARENDRA_220 | 10:50 | 17:23 | 6:33 | LINE CLEAR AVAILED |
| 1298 | 30-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV4 | STATION NOT AFFECTED HANAGAL_110 | 13:20 | 13:50 | 0:30 | LINE CLEAR AVAILED |
| 1299 | 30-Jul-2022 | BAGALKOT | 110 | ATHANI220-AIGALI | AIGALI_110 | 6:06 | 6:18 | 0:12 | LINE FAULT |
| 1300 | 30-Jul-2022 | BAGALKOT | 110 | ATHANI220-BALIGERI | BALIGERI_110 | 7:29 | 7:42 | 0:13 | LINE FAULT |
| 1301 | 30-Jul-2022 | BAGALKOT | 220 | ATHANI220-RAVI URJA 1 | ATHANI_220 | 15:28 | 17:55 | 2:27 | LINE CLEAR AVAILED |
| 1302 | 30-Jul-2022 | BAGALKOT | 220 | ATHANI220-RAVI URJA 2 | ATHANI_220 | 15:28 | 17:56 | 2:28 | LINE CLEAR AVAILED |
| 1303 | 30-Jul-2022 | BENGALURU | 66 | AREHALLI - SUBRAMANYAPURA 220 | AREHALLI | 21:49 | 22:08 | 0:19 | MAIN SUPPLY FAILURE |
| 1304 | 30-Jul-2022 | BENGALURU | 220 | A STATION 220 - NRS 220 | A STATION 220 | 13:12 | 13:54 | 0:42 | MAIN SUPPLY FAILURE |
| 1305 | 30-Jul-2022 | BENGALURU | 66 | A STATION 220 - KANTEERAVA STADIUM | KANTEERAVA STADIUM | 13:10 | 13:54 | 0:44 | MAIN SUPPLY FAILURE |
| 1306 | 30-Jul-2022 | BENGALURU | 66 | A STATION 220 - A STATION 2 | A STATION 2 66 | 13:10 | 13:54 | 0:44 | MAIN SUPPLY FAILURE |
| 1307 | 30-Jul-2022 | BENGALURU | 66 | HV1 | CHANDRA LAYOUT | 10:17 | 10:20 | 0:03 | LINE CLEAR AVAILED |
| 1308 | 30-Jul-2022 | BENGALURU | 66 | HV2 | CHANDRA LAYOUT | 12:48 | 12:52 | 0:04 | LINE CLEAR AVAILED |
| 1309 | 30-Jul-2022 | BENGALURU | 66 | HV1 | CHATRA | 13:09 | 13:31 | 0:22 | LINE CLEAR AVAILED |
| 1310 | 30-Jul-2022 | BENGALURU | 66 | ELECTRONIC CITY - ELECTRONIC CITY P2 S1 | ELECTRONIC CITY, HULIMANGALA, INFOSYS(EHT) | 9:55 | 10:00 | 0:05 | LOAD CHANGE OVER |
| 1311 | 30-Jul-2022 | BENGALURU | 66 | ELECTRONIC CITY - ELECTRONIC CITY P2 S1 | ELECTRONIC CITY, HULIMANGALA, INFOSYS(EHT) | 18:20 | 18:24 | 0:04 | LOAD CHANGE OVER |
| 1312 | 30-Jul-2022 | BENGALURU | 66 | HV1 | ELECTRONIC CITY PH-2 SEC-2 | 17:50 | 18:18 | 0:28 | TRANSFORMER FAULT |
| 1313 | 30-Jul-2022 | BENGALURU | 220 | EPIP 220 - HSR LAYOUT 220 | NO STATION AFFECTED | 11:41 | 14:09 | 2:28 | LINE FAULT |
| 1314 | 30-Jul-2022 | BENGALURU | 220 | EPIP 220 - HSR LAYOUT 220 | NO STATION AFFECTED | 15:50 | 19:00 | 3:10 | LINE FAULT |
| 1315 | 30-Jul-2022 | BENGALURU | 66 | EXORA - CESSNA | EXORA | 22:09 | 22:28 | 0:19 | MAIN SUPPLY FAILURE |
| 1316 | 30-Jul-2022 | BENGALURU | 66 | GLOBAL TECH PARK - HSR ALYOUT 220 | GLOBAL TECH PARK | 22:53 | 23:00 | 0:07 | MAIN SUPPLY FAILURE |
| 1317 | 30-Jul-2022 | BENGALURU | 66 | HAL 220 - HOODY 2 | BAGMANE TECH PARK, GTRE (EHT) | 12:00 | 17:32 | 5:32 | LINE CLEAR AVAILED |
| 1318 | 30-Jul-2022 | BENGALURU | 66 | HANUMANTHNAGARA - SOMANAHALLI 220 | HANUMANTHNAGARA | 21:11 | 21:35 | 0:24 | MAIN SUPPLY FAILURE |
| 1319 | 30-Jul-2022 | BENGALURU | 66 | HV1 | HENNUR CROSS | 11:07 | 11:10 | 0:03 | LINE CLEAR AVAILED |
| 1320 | 30-Jul-2022 | BENGALURU | 66 | HV2 | HENNUR CROSS | 12:50 | 12:55 | 0:05 | LINE CLEAR AVAILED |
| 1321 | 30-Jul-2022 | BENGALURU | 66 | HENNUR CROSS - HBR LAYOUT 220 | HENNUR CROSS, PURVANKARA PALM BEACH | 13:51 | 14:00 | 0:09 | LINE CLEAR AVAILED |
| 1322 | 30-Jul-2022 | BENGALURU | 66 | HOODY 220 - HP (EHT) | HP (EHT) | 9:55 | 10:20 | 0:25 | LINE CLEAR AVAILED |
| 1323 | 30-Jul-2022 | BENGALURU | 66 | HOODY 220 - BRIGADE METROPOLIS | BRIGADE METROPOLIS | 9:56 | 10:20 | 0:24 | LINE CLEAR AVAILED |
| 1324 | 30-Jul-2022 | BENGALURU | 66 | HV2 | HOODY 220 | 10:49 | 16:55 | 6:06 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--|---|---------|-----------|----------|---------------------|
| 1325 | 30-Jul-2022 | BENGALURU | 66 | HSR LAYOUT 220 - DEVARABISANAHALLI | DEVARABISANAHALLI | 22:54 | 23:00 | 0:06 | LINE CLEAR AVAILED |
| 1326 | 30-Jul-2022 | BENGALURU | 66 | HV3 | HSR LAYOUT 220 | 7:50 | 8:10 | 0:20 | TRANSFORMER FAULT |
| 1327 | 30-Jul-2022 | BENGALURU | 66 | HV3 | HSR LAYOUT 220 | 19:53 | 20:26 | 0:33 | TRANSFORMER FAULT |
| 1328 | 30-Jul-2022 | BENGALURU | 66 | HV1 | IISc | 15:22 | 15:26 | 0:04 | LINE CLEAR AVAILED |
| 1329 | 30-Jul-2022 | BENGALURU | 66 | HV2 | IISc | 10:42 | 10:45 | 0:03 | LINE CLEAR AVAILED |
| 1330 | 30-Jul-2022 | BENGALURU | 220 | HV2 | NAGANATHPURA 220 | 21:28 | 21:48 | 0:20 | TRANSFORMER FAULT |
| 1331 | 30-Jul-2022 | BENGALURU | 66 | HV1 | NAGANATHPURA 220 | 21:28 | 21:49 | 0:21 | MAIN SUPPLY FAILURE |
| 1332 | 30-Jul-2022 | BENGALURU | 66 | HV2 | NAGANATHPURA 220 | 21:28 | 21:49 | 0:21 | MAIN SUPPLY FAILURE |
| 1333 | 30-Jul-2022 | BENGALURU | 66 | NAGANATHPURA 220 - ELECTRONIC CITY P2 S2 | ELECTRONIC CITY P2 S2 | 21:28 | 21:49 | 0:21 | MAIN SUPPLY FAILURE |
| 1334 | 30-Jul-2022 | BENGALURU | 220 | NRS 220 - A STATION 220 | A STATION 220 | 13:12 | 13:53 | 0:41 | LINE FAULT |
| 1335 | 30-Jul-2022 | BENGALURU | 66 | RMZ - VIKAS TECH PARK 220 | RMZ | 22:07 | 23:12 | 1:05 | MAIN SUPPLY FAILURE |
| 1336 | 30-Jul-2022 | BENGALURU | 66 | RMZ - VIKAS TECH PARK 220 | RMZ | 23:28 | 23:45 | 0:17 | MAIN SUPPLY FAILURE |
| 1337 | 30-Jul-2022 | BENGALURU | 66 | SOMANAHALLI 220 - KANAKAPURA 1 | HANUMANTHNAGAR | 21:11 | 21:35 | 0:24 | LINE FAULT |
| 1338 | 30-Jul-2022 | BENGALURU | 220 | HV1 | SRS PEENYA 220 | 6:00 | 7:15 | 1:15 | LINE CLEAR AVAILED |
| 1339 | 30-Jul-2022 | BENGALURU | 66 | SRS PEENYA 220 - MEI LAYOUT | MEI LAYOUT, WIDIA, WIDIA (EHT) | 6:15 | 7:08 | 0:53 | LINE CLEAR AVAILED |
| 1340 | 30-Jul-2022 | BENGALURU | 66 | SUBRAMANYAPURA 220 - REMCO 1 | AREHALLI | 21:49 | 22:08 | 0:19 | LINE FAULT |
| 1341 | 30-Jul-2022 | BENGALURU | 66 | VICTORIA - A STATION 220 | VICTORIA | 13:12 | 13:43 | 0:31 | MAIN SUPPLY FAILURE |
| 1342 | 30-Jul-2022 | BENGALURU | 220 | VIKAS TECH PARK 220 - MALUR 220 | VIKAS TECH PARK 220 | 22:08 | 23:13 | 1:05 | MAIN SUPPLY FAILURE |
| 1343 | 30-Jul-2022 | BENGALURU | 66 | VIKAS TECH PARK 220 - PRIMAL PROJECT | PRIMAL PROJECT | 22:08 | 23:13 | 1:05 | MAIN SUPPLY FAILURE |
| 1344 | 30-Jul-2022 | BENGALURU | 66 | VIKAS TECH PARK 220 - GLOBAL TECH PARK | GLOBAL TECH PARK | 22:08 | 23:13 | 1:05 | MAIN SUPPLY FAILURE |
| 1345 | 30-Jul-2022 | BENGALURU | 66 | VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE | EMBASSY TECH VILLAGE | 22:08 | 23:13 | 1:05 | MAIN SUPPLY FAILURE |
| 1346 | 30-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ANEKAL 1 | SURYANAGAR | 8:52 | 9:27 | 0:35 | LINE FAULT |
| 1347 | 30-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ANEKAL 2 | ANEKAL, SAMANDURU | 8:52 | 9:26 | 0:34 | LINE FAULT |
| 1348 | 30-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ELECTRONIC CITY 1 | ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA | 9:46 | 10:01 | 0:15 | LINE CLEAR AVAILED |
| 1349 | 30-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ANEKAL 1 | SURYANAGAR | 13:51 | 14:10 | 0:19 | LINE CLEAR AVAILED |
| 1350 | 30-Jul-2022 | BENGALURU | 220 | HV3 | YARANDANAHALLI 220 | 21:28 | 22:00 | 0:32 | TRANSFORMER FAULT |
| 1351 | 30-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ANEKAL 1 | SURYANAGAR | 21:28 | 22:48 | 1:20 | LINE FAULT |
| 1352 | 30-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ANEKAL 2 | ANEKAL, SAMANDURU | 21:28 | 22:48 | 1:20 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--|-------------------------------|---------|-----------|----------|---------------------|
| 1353 | 30-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ELECTRONIC CITY 2 | BIOCON (EHT), BOMMASANDRA I/A | 21:28 | 22:48 | 1:20 | LINE FAULT |
| 1354 | 30-Jul-2022 | BENGALURU | 66 | HV1 | YARANDANAHALLI 220 | 21:28 | 22:48 | 1:20 | TRANSFORMER FAULT |
| 1355 | 30-Jul-2022 | BENGALURU | 66 | HV2 | YARANDANAHALLI 220 | 21:28 | 22:48 | 1:20 | TRANSFORMER FAULT |
| 1356 | 30-Jul-2022 | BENGALURU | 66 | HV3 | YARANDANAHALLI 220 | 21:28 | 22:48 | 1:20 | TRANSFORMER FAULT |
| 1357 | 30-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - CHANDAPURA | NO STATION AFFECTED | 22:30 | 23:20 | 0:50 | LINE FAULT |
| 1358 | 30-Jul-2022 | BENGALURU | 66 | HV1 | ADUGODI | 9:35 | 9:37 | 0:02 | LINE CLEAR AVAILED |
| 1359 | 30-Jul-2022 | BENGALURU | 66 | HV2 | ADUGODI | 12:12 | 12:14 | 0:02 | LINE CLEAR AVAILED |
| 1360 | 30-Jul-2022 | BENGALURU | 220 | KOLAR 220 - PGCIL 1 | KOLAR 220 | 22:08 | 0:00 | 1:52 | LINE FAULT |
| 1361 | 30-Jul-2022 | BENGALURU | 220 | KOLAR 220 - PGCIL 2 | KOLAR 220 | 22:08 | 23:02 | 0:54 | MAIN SUPPLY FAILURE |
| 1362 | 30-Jul-2022 | BENGALURU | 66 | HV1 | KOLAR 220 | 22:08 | 23:02 | 0:54 | MAIN SUPPLY FAILURE |
| 1363 | 30-Jul-2022 | BENGALURU | 66 | HV2 | KOLAR 220 | 22:08 | 23:02 | 0:54 | MAIN SUPPLY FAILURE |
| 1364 | 30-Jul-2022 | BENGALURU | 66 | KOLAR 220 - NANGALI | KEMBODI | 22:08 | 23:14 | 1:06 | MAIN SUPPLY FAILURE |
| 1365 | 30-Jul-2022 | BENGALURU | 66 | KOLAR 220 - THAYLUR | TAMAKA | 22:08 | 23:14 | 1:06 | MAIN SUPPLY FAILURE |
| 1366 | 30-Jul-2022 | BENGALURU | 66 | KOLAR 220 - PGCIL AUX | PGCIL AUX, SUGUTUR | 22:08 | 23:14 | 1:06 | MAIN SUPPLY FAILURE |
| 1367 | 30-Jul-2022 | BENGALURU | 66 | KOLAR 220 - VEMGAL | TALAGUNDA, VEMGAL, KYALNUR | 22:08 | 23:30 | 1:22 | MAIN SUPPLY FAILURE |
| 1368 | 30-Jul-2022 | BENGALURU | 66 | KOLAR 220 - VOKKALERI | VOKKALERI | 22:08 | 23:14 | 1:06 | MAIN SUPPLY FAILURE |
| 1369 | 30-Jul-2022 | BENGALURU | 66 | KOLAR 220 - SRINIVASPURA | DRRO (EHT), MALLASANDRA | 22:08 | 23:02 | 0:54 | MAIN SUPPLY FAILURE |
| 1370 | 30-Jul-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 1 | NARASAPURA | 22:08 | 23:14 | 1:06 | MAIN SUPPLY FAILURE |
| 1371 | 30-Jul-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 2 | NARASAPURA | 11:30 | 11:35 | 0:05 | LINE FAULT |
| 1372 | 30-Jul-2022 | BENGALURU | 66 | KOLAR 220 - VEMGAL | TALAGUNDA, VEMGAL, KYALNUR | 12:50 | 13:10 | 0:20 | LINE FAULT |
| 1373 | 30-Jul-2022 | BENGALURU | 66 | KOLAR 220 - VEMGAL | TALAGUNDA, VEMGAL, KYALNUR | 15:00 | 15:30 | 0:30 | LINE CLEAR AVAILED |
| 1374 | 30-Jul-2022 | BENGALURU | 66 | SM MANGALA - CHINTAMANI 220 | SM MANGALA | 22:30 | 23:15 | 0:45 | LOAD CHANGE OVER |
| 1375 | 30-Jul-2022 | BENGALURU | 66 | SADLI - MITTEMARI 220 | SADLI, DIBBURAHALLI | 22:50 | 23:20 | 0:29 | LINE FAULT |
| 1376 | 30-Jul-2022 | BENGALURU | 66 | SADLI - MITTEMARI 220 | SADLI, DIBBURAHALLI | 23:20 | 23:41 | 0:21 | LINE FAULT |
| 1377 | 30-Jul-2022 | BENGALURU | 66 | SARJAPURA 220 - CHANDAPURA | CHANDAPURA | 22:08 | 23:29 | 1:21 | MAIN SUPPLY FAILURE |
| 1378 | 30-Jul-2022 | BENGALURU | 66 | SARJAPURA 220 - DOMMASANDRA | DOMMASANDRA | 22:08 | 23:20 | 1:12 | MAIN SUPPLY FAILURE |
| 1379 | 30-Jul-2022 | BENGALURU | 66 | DB PURA 220 - DG 1 | AIR(EHT) | 9:28 | 9:37 | 0:09 | LINE FAULT |
| 1380 | 30-Jul-2022 | BENGALURU | 66 | DB PURA 220 - VIJAYAPURA | VIJAYAPURA, JANGAMAKOTE | 22:38 | 22:45 | 0:07 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--------------------------------|--|------------------|-----------|----------|--------------------------------|
| 1381 | 30-Jul-2022 | BENGALURU | 66 | DB PURA 220 - DG 2 | DODDABELAVANGALA, GUNDAMGERE | 23:28 | 23:32 | 0:04 | LINE FAULT |
| 1382 | 30-Jul-2022 | BENGALURU | 220 | MALUR 220 - KOLAR 1 | MALUR 220 | 22:08 | 23:15 | 1:07 | MAIN SUPPLY FAILURE |
| 1383 | 30-Jul-2022 | BENGALURU | 220 | MALUR 220 - KOLAR 3 | SARJAPURA 220, VIKAS TECH PARK 220 | 22:08 | 23:13 | 1:05 | MAIN SUPPLY FAILURE |
| 1384 | 30-Jul-2022 | BENGALURU | 220 | MALUR 220 - SOMANHALLI 1 O/G | SARJAPURA 220, VIKAS TECH PARK 220 | 22:08 | 23:15 | 1:07 | MAIN SUPPLY FAILURE |
| 1385 | 30-Jul-2022 | BENGALURU | 66 | MALUR 220 - MAASTHI | MAASTHI | 22:08 | 23:19 | 1:11 | MAIN SUPPLY FAILURE |
| 1386 | 30-Jul-2022 | BENGALURU | 66 | MALUR 220 - KGF 1 | TEKAL, BUDIKOTE, TORLAKKI | 22:08 | 23:10 | 1:02 | MAIN SUPPLY FAILURE |
| 1387 | 30-Jul-2022 | BENGALURU | 66 | MALUR 220 - KGF 2 | BANGARPETE | 22:08 | 23:20 | 1:12 | MAIN SUPPLY FAILURE |
| 1388 | 30-Jul-2022 | BENGALURU | 66 | MALUR 220 - HOSKOTE 2 | JADIGENAHALLI | 22:08 | 22:40 | 0:32 | MAIN SUPPLY FAILURE |
| 1389 | 30-Jul-2022 | BENGALURU | 66 | MALUR 220 - HOSKOTE 1 | NO STATION AFFECTED | 22:08 | 23:20 | 1:12 | MAIN SUPPLY FAILURE |
| 1390 | 30-Jul-2022 | BENGALURU | 66 | MALUR 220 - MALUR I/A | MALUR I/A, ADL (EHT), BEST STEEL (EHT) | 22:08 | 23:19 | 1:11 | MAIN SUPPLY FAILURE |
| 1391 | 30-Jul-2022 | BENGALURU | 66 | MALUR 220 - MALUR 66 | MALUR 66 | 22:08 | 23:17 | 1:09 | MAIN SUPPLY FAILURE |
| 1392 | 30-Jul-2022 | BENGALURU | 66 | MALUR 220 - LAKKUR | DEVANGONDHI, LAKKUR | 22:08 | 23:19 | 1:11 | MAIN SUPPLY FAILURE |
| 1393 | 30-Jul-2022 | BENGALURU | 66 | MALUR 220 - LAKKUR | DEVANGONDHI, LAKKUR | 20:46 | 21:15 | 0:29 | LINE FAULT |
| 1394 | 30-Jul-2022 | BENGALURU | 220 | CHINTAMANI 220 - PCGIL 2 | NO STATION AFFECTED | 13:16 | 16:44 | 3:28 | LINE FAULT |
| 1395 | 30-Jul-2022 | BENGALURU | 66 | HV3 | CHIKKABALLAPURA I/A | 22:49 | 23:25 | 0:35 | TRANSFORMER FAULT |
| 1396 | 30-Jul-2022 | BENGALURU | 66 | HV2 | KGF | 8:00 | 8:05 | 0:05 | LINE CLEAR AVAILED |
| 1397 | 30-Jul-2022 | BENGALURU | 66 | SATHANUR - HONNIGANAHALLI | HONNIGANAHALLI, HALGUR | 20:30 | 21:35 | 1:05 | LINE FAULT |
| 1398 | 30-Jul-2022 | BENGALURU | 66 | SATHANUR - HONNIGANAHALLI | HONNIGANAHALLI, HALGUR | 22:00 | 22:15 | 0:15 | LINE FAULT |
| 1399 | 30-Jul-2022 | BENGALURU | 66 | SARJAPURA 220 - ATTIBELE | ATTIBELE | 22:08 | 23:00 | 0:52 | MAIN SUPPLY FAILURE |
| 1400 | 30-Jul-2022 | BENGALURU | 66 | SURYANAGAR - ANEKAL | ANEKAL | 8:54 | 9:38 | 0:44 | LINE FAULT |
| 1401 | 30-Jul-2022 | BENGALURU | 66 | HV1 | JIGANI 220 | 23:03 | 23:23 | 0:20 | TRANSFORMER FAULT |
| 1402 | 30-Jul-2022 | BENGALURU | 66 | SURYANAGAR - ANEKAL | SURYANAGAR | 15:02 | 15:10 | 0:08 | LOAD CHANGE OVER |
| 1403 | 30-Jul-2022 | BENGALURU | 220 | GOWRIBIDANUR 220 - MITTEMARI 2 | MITTEMARI 220 | 23:53(30-7-2022) | | | LINE OPEN, LINE FAULT |
| 1404 | 30-Jul-2022 | BENGALURU | 66 | MITTEMARI 220 - JULLUPALYA | JULLUPALYA | 23:53(30-7-2022) | | | MAIN SUPPLY FAILURE |
| 1405 | 30-Jul-2022 | BENGALURU | 66 | MITTEMARI 220 - BAGEPALLI 1 | VATADOSANAHALLI | 23:53(30-7-2022) | | | MAIN SUPPLY FAILURE |
| 1406 | 30-Jul-2022 | BENGALURU | 220 | HV2 | MITTEMARI 220 | 23:53(30-7-2022) | | | MAIN SUPPLY FAILURE |
| 1407 | 30-Jul-2022 | BENGALURU | 66 | HV1 | MITTEMARI 220 | 23:53(30-7-2022) | | | MAIN SUPPLY FAILURE |
| 1408 | 30-Jul-2022 | BENGALURU | 220 | MALUR 220 - HOODY I/C | NO STATION AFFECTED | 11:04(30-7-2021) | | | LINE OPEN , LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--|--|-----------------------|--------------------|-----------|-------------------------------------|
| 1409 | 30-Jul-2022 | BENGALURU | 66 | HV1 | SUGUTUR | 23:20(30-7-2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1410 | 30-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - CHANDAPURA | NO STATION AFFECTED | 23:20(30/07/2022) | | | LINE OPEN, LINE FAULT |
| 1411 | 30-Jul-2022 | BENGALURU | 220 | HV2 | YARANDANAHALLI 220 | 21:28:00(30/07/2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1412 | 30-Jul-2022 | BENGALURU | 220 | EAST DIVISION COMPOUND 220 - A STATION 220 | NO STATION AFFECTED | 08:38:00(23/07/2022) | | | LINE OPEN, LINE FAULT |
| 1413 | 30-Jul-2022 | GULBARGA | 220 | SEDAM_SHAHAPUR | SEDAM_220 | 05:48(10/06/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1414 | 30-Jul-2022 | GULBARGA | 220 | SEDAM_SHAHAPUR | SEDAM_220 | 05:48(10/06/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1415 | 30-Jul-2022 | GULBARGA | 220 | HUMNABAD-KAPNOOR1 | HUMNABAD_220 | 1:40 | 6:52 | 5:12 | LINE CLEAR AVAILED |
| 1416 | 30-Jul-2022 | GULBARGA | 220 | SHAHABAD-SHAHAPUR | SHAHABAD_220 | 5:42 | 5:55 | 0:13 | LINE FAULT |
| 1417 | 30-Jul-2022 | GULBARGA | 220 | SEDAM-HUMNABAD1 | SEDAM_220 | 11:14 | 11:19 | 0:05 | LINE CLEAR AVAILED |
| 1418 | 30-Jul-2022 | GULBARGA | 220 | RAICHUR-JURALA 1&2 _IPP | RAICHUR_220 | 9:30 | 17:00 | 7:30 | NFBC ISSUED |
| 1419 | 30-Jul-2022 | GULBARGA | 220 | KAPNOOR-SHAHAPUR | SHAHAPUR_220 | 5:42 | 6:04 | 0:22 | LINE FAULT |
| 1420 | 30-Jul-2022 | GULBARGA | 220 | SHAHAPUR-LINGASUGUR | SHAHAPUR_220 | 6:15 | 12:28 | 6:13 | LINE FAULT |
| 1421 | 30-Jul-2022 | GULBARGA | 110 | HUMNABAD-HALLIKHED | HALLIKHED_110 | 9:34(20/07/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1422 | 30-Jul-2022 | GULBARGA | 110 | HUMNABAD-HALBARGA | HALBARGA_110 | 3:54(20/07/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1423 | 30-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR1 | JEWARGI_110 | 12:15(15/06/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1424 | 30-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR2 | NALWAR_110 | 15:10(14/06/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1425 | 30-Jul-2022 | GULBARGA | 110 | HALBARGA-BHALKI | BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP | 06:55 (26/07/2022) | | | LINE OPEN, LINE FAULT |
| 1426 | 30-Jul-2022 | GULBARGA | 110 | HV3 | KOPPAL_110 | 7:30 | 8:10 | 0:40 | TRANSFORMER FAULT |
| 1427 | 30-Jul-2022 | GULBARGA | 110 | HV2 | SHAHAPUR_110 | 15:00 | 15:21 | 0:21 | LINE CLEAR AVAILED |
| 1428 | 30-Jul-2022 | GULBARGA | 110 | HV1 | ALLIPUR_220 | 1:12 | 1:32 | 0:20 | TRANSFORMER FAULT |
| 1429 | 30-Jul-2022 | GULBARGA | 110 | LV1 | SEDAM_220 | 11:14 | 11:35 | 0:21 | TRANSFORMER FAULT |
| 1430 | 30-Jul-2022 | GULBARGA | 110 | HV1 | HUNASAGI_110 | 10:05 | 11:50 | 1:45 | LINE CLEAR AVAILED |
| 1431 | 30-Jul-2022 | GULBARGA | 110 | SINDHNOOR-VALABELLARI | MANVI_110,MADLAPUR_110,KURDICROSS_110, ADVIAMRESHWAR_110,JAWALGERA_110 | 23:55 (29.07.2022) | 00:10 (30.07.2022) | 00:15 HRS | LINE CHARGED |
| 1432 | 30-Jul-2022 | GULBARGA | 110 | NALWAR-CLEAN SOLAR | NALWAR_110 | 0:08 | 0:46 | 0:38 | LINE FAULT |
| 1433 | 30-Jul-2022 | GULBARGA | 110 | NALWAR-CLEAN SOLAR | NALWAR_110 | 5:17 | 6:12 | 0:55 | LINE FAULT |
| 1434 | 30-Jul-2022 | GULBARGA | 110 | NALWAR-CLEAN SOLAR | NALWAR_110 | 6:33 | 7:07 | 0:34 | LINE FAULT |
| 1435 | 30-Jul-2022 | GULBARGA | 110 | NALWAR-CLEAN SOLAR | NALWAR_110 | 22:05 | 22:25 | 0:20 | LINE FAULT |
| 1436 | 30-Jul-2022 | GULBARGA | 110 | MUDDAPURA-MASKI | MASKI_110,HATTI_110 | 19:07 | 19:14 | 0:07 | LINE FAULT |
| 1437 | 30-Jul-2022 | GULBARGA | 110 | KEMBHAVI-HUNSAGI | HUNSAGI_110 | 3:05 | 3:20 | 0:15 | LINE FAULT |
| 1438 | 30-Jul-2022 | GULBARGA | 110 | KEMBHAVI-HUNSAGI | HUNSAGI_110 | 5:35 | 6:00 | 0:25 | LINE FAULT |
| 1439 | 30-Jul-2022 | GULBARGA | 110 | SHAHAPUR-KEMBHAVI | KEMBHAVI_110,HUNSAGI_110,ASKI_110,UGAR SUGAR_IPP | 9:35 | 9:45 | 0:10 | LINE FAULT |
| 1440 | 30-Jul-2022 | GULBARGA | 110 | MASKI-SINDHANOOR | MASKI_110,HATTI_110 | 0:03 | 0:06 | 0:03 | LINE FAULT |
| 1441 | 30-Jul-2022 | GULBARGA | 110 | HUMNABAD-ALAND | ALAND_110,KADAGANCHI_110 | 23:22 | 23:37 | 0:15 | LINE FAULT |
| 1442 | 30-Jul-2022 | GULBARGA | 110 | KAPNOOR-MADIYAL | MADIYAL_110,CHOWDAPURA_110,NSL SUGARS FACTORY | 6:31 | 6:36 | 0:05 | LINE FAULT |
| 1443 | 30-Jul-2022 | GULBARGA | 110 | HUMNABAD-HUMNABAD2 | ALAND_110,KADAGANCHI_110 | 23:21 | 23:32 | 0:11 | LINE FAULT |
| 1444 | 30-Jul-2022 | GULBARGA | 110 | SINDHANOOR-THURVIHAL | THURVIHAL_110,GANDHINAGAR_110 | 4:02 | 4:22 | 0:20 | LINE FAULT |
| 1445 | 30-Jul-2022 | GULBARGA | 110 | SINDHNOOR-VALABELLARI | MANVI_110,MADLAPUR_110,KURDICROSS_110, ADVIAMRESHWAR_110,JAWALGERA_110 | 4:35 | 4:45 | 0:10 | LINE FAULT |
| 1446 | 30-Jul-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | YADGIR_110,SAIDAPUR_110 | 0:27 | 0:32 | 0:05 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|-----------------------|--|-------------------|-----------|----------|-----------------------|
| 1447 | 30-Jul-2022 | GULBARGA | 110 | SHAHAPUR-KBJNL | KBJNL_110 | 1:16 | 19:41 | 18:25 | LINE FAULT |
| 1448 | 30-Jul-2022 | GULBARGA | 110 | SHAHAPUR-SHAHAPUR_1 | SHAHAPUR_110,NALWAR_110,JEWARGI_110 | 20:52 | 21:21 | 0:29 | LINE FAULT |
| 1449 | 30-Jul-2022 | GULBARGA | 110 | SEDAM-VICAT SAGAR_IPP | SEDAM_220 | 10:40 | 20:50 | 10:10 | LINE CLEAR AVAILED |
| 1450 | 30-Jul-2022 | GULBARGA | 110 | SHAHABAD-BAGEWADI2 | YADRAMI_110,MORATAGI_110, GHATARGA_110 | 6:15 | 6:20 | 0:05 | LINE FAULT |
| 1451 | 30-Jul-2022 | GULBARGA | 110 | RAICHUR-SINDHNOOR2 | KURDICROSS_110,MADLAPUR_110,MANVI_110 | 6:46 | 6:56 | 0:10 | LINE FAULT |
| 1452 | 30-Jul-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 2:32 | 2:39 | 0:07 | LINE FAULT |
| 1453 | 30-Jul-2022 | GULBARGA | 110 | HUNASAGI-KEMBHAVI | HUNASAGI_110 | 3:05 | 3:20 | 0:15 | LINE FAULT |
| 1454 | 30-Jul-2022 | GULBARGA | 110 | HUNASAGI-KEMBHAVI | HUNASAGI_110 | 5:50 | 5:55 | 0:05 | MAIN SUPPLY FAILURE |
| 1455 | 30-Jul-2022 | GULBARGA | 110 | HUNASAGI-KEMBHAVI | HUNASAGI_110 | 6:00 | 6:05 | 0:05 | MAIN SUPPLY FAILURE |
| 1456 | 30-Jul-2022 | GULBARGA | 110 | GABBUR-RAICHUR | GABBUR_110 | 11:40 | 11:45 | 0:05 | MAIN SUPPLY FAILURE |
| 1457 | 30-Jul-2022 | GULBARGA | 110 | GABBUR-RAICHUR | GABBUR_110 | 12:35 | 12:40 | 0:05 | MAIN SUPPLY FAILURE |
| 1458 | 30-Jul-2022 | GULBARGA | 110 | BYGWAT-MALLAT | BYGWAT_110 | 5:50 | 6:00 | 0:10 | MAIN SUPPLY FAILURE |
| 1459 | 30-Jul-2022 | GULBARGA | 66 | HV1 | CHORNOOR_66 | 15:40 | 15:50 | 0:10 | TRANSFORMER FAULT |
| 1460 | 30-Jul-2022 | GULBARGA | 66 | HV1 | HANASI_66 | 21:05 | 21:15 | 0:10 | TRANSFORMER FAULT |
| 1461 | 30-Jul-2022 | GULBARGA | 66 | MUNIRABAD-MSD | HANSI_66 | 14:43 | 16:58 | 2:15 | LINE CLEAR AVAILED |
| 1462 | 30-Jul-2022 | GULBARGA | 66 | PUNABGHATA-NEELAGUNDA | PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJAINI_66 | 6:40 | 6:45 | 0:05 | LINE FAULT |
| 1463 | 30-Jul-2022 | GULBARGA | 66 | TELAGE-KURUBARAHALLI | KURUBARAHALLI_110 | 15:15 | 18:20 | 3:05 | LINE FAULT |
| 1464 | 30-Jul-2022 | GULBARGA | 66 | ITTAGI-HUVINAHADGALI | HUVINAHADGALI_66,HOLAGUNDI_66 | 1:30 | 1:45 | 0:15 | LINE FAULT |
| 1465 | 30-Jul-2022 | GULBARGA | 66 | ITTAGI-HIREHADAGALI_2 | HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66, SOVENHALLI_66, TUNGA BHADRA_IPP | 2:15 | 20:20 | 18:05 | LINE FAULT |
| 1466 | 30-Jul-2022 | GULBARGA | 66 | ITTAGI-HIREHADAGALI_2 | HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66, SOVENHALLI_66, TUNGA BHADRA_IPP | 5:40 | 6:10 | 0:30 | LINE FAULT |
| 1467 | 30-Jul-2022 | GULBARGA | 66 | NEELGUNDA-TELIGE | TELAGE_66,KURBHAHALLI_66,YEREGUNTA_66 | 15:18 | 15:25 | 0:07 | LINE FAULT |
| 1468 | 30-Jul-2022 | HASSAN | 220 | CRPATNA-HSN400 | CRPATNA_220 | 13:34(15.07.2022) | | | LINE OPEN, LINE FAULT |
| 1469 | 30-Jul-2022 | HASSAN | 220 | GERSOPA-TALGUPA1 | gen_gersoppa | 6:13 | 6:30 | 0:17 | LINE FAULT |
| 1470 | 30-Jul-2022 | HASSAN | 220 | GERSOPA-TALGUPA2 | gen_gersoppa | 6:13 | 6:30 | 0:17 | LINE FAULT |
| 1471 | 30-Jul-2022 | HASSAN | 220 | KAVOOR-KVRKNJE | KAVOOR_220 | 5:52 | 6:17 | 0:25 | LINE FAULT |
| 1472 | 30-Jul-2022 | HASSAN | 220 | KAVOOR-KVR AMR | KAVOOR_220 | 5:12 | 5:19 | 0:07 | LINE FAULT |
| 1473 | 30-Jul-2022 | HASSAN | 220 | KAVOOR-KVR AMR | KAVOOR_220 | 5:46 | 6:15 | 0:29 | LINE FAULT |
| 1474 | 30-Jul-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY3 | MRSMSG_220 | 12:49 | 14:06 | 1:17 | LINE FAULT |
| 1475 | 30-Jul-2022 | HASSAN | 220 | SHRAVITY-SHIMOGA3 | gen_sharavathy | 12:49 | 14:06 | 1:17 | LINE FAULT |
| 1476 | 30-Jul-2022 | HASSAN | 220 | SHRAVITY-SHIRALKOPPA | gen_sharavathy | 12:34 | 14:20 | 1:46 | LINE FAULT |
| 1477 | 30-Jul-2022 | HASSAN | 220 | SHRLKP-SGS | SHIRALKOPPA_220 | 12:34 | 14:20 | 1:46 | LINE FAULT |
| 1478 | 30-Jul-2022 | HASSAN | 110 | SHRLKP-BARANG | SHIRALKOPPA_220 | 8:10 | 18:06 | 9:56 | LINE CLEAR AVAILED |
| 1479 | 30-Jul-2022 | HASSAN | 110 | SHRLKP-KITTADAHALLI | SHIRALKOPPA_220 | 3:22 | 5:38 | 2:16 | LINE FAULT |
| 1480 | 30-Jul-2022 | HASSAN | 110 | SHRLKP-KITTADAHALLI | SHIRALKOPPA_220 | 12:43 | 12:49 | 0:06 | MAIN SUPPLY FAILURE |
| 1481 | 30-Jul-2022 | HASSAN | 110 | SHRLKP-SHIKARIPURA | SHIRALKOPPA_220 | 12:43 | 12:50 | 0:07 | MAIN SUPPLY FAILURE |
| 1482 | 30-Jul-2022 | HASSAN | 110 | SHRLKP-SORAB | SHIRALKOPPA_220 | 12:44 | 12:52 | 0:08 | MAIN SUPPLY FAILURE |
| 1483 | 30-Jul-2022 | HASSAN | 110 | SHRLKP-SHIRALKOPPA | SHIRALKOPPA_220 | 12:44 | 12:50 | 0:06 | MAIN SUPPLY FAILURE |
| 1484 | 30-Jul-2022 | HASSAN | 110 | HV1 | BARANGI_110 | 10:13 | 12:43 | 2:30 | TRANSFORMER FAULT |
| 1485 | 30-Jul-2022 | HASSAN | 110 | HV1 | BARANGI_110 | 13:16 | 14:15 | 0:59 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|--------------------------------|---------------------------------------|----------------------|-------------------|----------|-------------------------------------|
| 1486 | 30-Jul-2022 | HASSAN | 110 | HV2 | KARAYA_110 | 14:33 | 19:07 | 4:34 | LINE CLEAR AVAILED |
| 1487 | 30-Jul-2022 | HASSAN | 110 | KARAYA-PUTTUR | KARAYA_110 | 10:08 | 14:18 | 4:10 | LINE CLEAR AVAILED |
| 1488 | 30-Jul-2022 | HASSAN | 110 | KEMAR-NANDHIKUR1 | KARAYA_110 | 11:00 | 13:04 | 2:04 | LINE CLEAR AVAILED |
| 1489 | 30-Jul-2022 | HASSAN | 110 | HV2 | KONAJE_110 | 5:53 | 6:10 | 0:17 | MAIN SUPPLY FAILURE |
| 1490 | 30-Jul-2022 | HASSAN | 110 | PUTTUR-PUTUR 1 | PUTTUR_220 | 10:39 | 14:17 | 3:38 | LINE CLEAR AVAILED |
| 1491 | 30-Jul-2022 | HASSAN | 66 | HV1 | BYACHANAHALLI_66 | 16:35 | 18:00 | 1:25 | LINE CLEAR AVAILED |
| 1492 | 30-Jul-2022 | HASSAN | 66 | CHIKKAK-DUDDA | CHIKKAKONDAGOLA_66 | 13:21 | 16:31 | 3:10 | LINE FAULT |
| 1493 | 30-Jul-2022 | HASSAN | 66 | HV1 | GORUR_66 | 11:47 | 12:57 | 1:10 | LINE CLEAR AVAILED |
| 1494 | 30-Jul-2022 | HASSAN | 66 | HV1 | MALLAPURA-66 | 11:06 | 17:35 | 6:29 | TRANSFORMER FAULT |
| 1495 | 30-Jul-2022 | HASSAN | 66 | SALAGAM-HIREMANGLUR | SALAGAME_66 | 11:57 | 12:33 | 0:36 | LINE CLEAR AVAILED |
| 1496 | 30-Jul-2022 | HASSAN | 66 | HV1 | SALAGAME_66 | 11:56 | 12:34 | 0:38 | LINE CLEAR AVAILED |
| 1497 | 30-Jul-2022 | HASSAN | 66 | HV2 | SALAGAME_66 | 11:58 | 12:34 | 0:36 | LINE CLEAR AVAILED |
| 1498 | 30-Jul-2022 | HASSAN | 66 | SALAGAM-UDURKOPPLU | SALAGAME_66 | 11:57 | 12:33 | 0:36 | LINE CLEAR AVAILED |
| 1499 | 30-Jul-2022 | HASSAN | 66 | HV1 | SIGEBAGE_66 | 14:06 | 15:12 | 1:06 | LINE CLEAR AVAILED |
| 1500 | 30-Jul-2022 | HASSAN | 66 | UDDURKO-UDDUR | UDDURKOPPLU_66 | 13:29 | 13:39 | 0:10 | HAND TRIPPED |
| 1501 | 30-Jul-2022 | MYSURU | 66 | HV2 | BETTADAPURA_66 | 14:41 | 16:35 | 1:54 | LINE CLEAR AVAILED |
| 1502 | 30-Jul-2022 | MYSURU | 66 | CHUNCHANAKATTE-RAVANDUR | BETTADHAPURA_66 KITTUR_66 RAVANDUR_66 | 21:33 | 21:43 | 0:09 | LINE FAULT |
| 1503 | 30-Jul-2022 | MYSURU | 66 | HV1 | HANAGODU_66 | 10:59 | 13:01 | 2:02 | LINE CLEAR AVAILED |
| 1504 | 30-Jul-2022 | MYSURU | 66 | HV2 | HONNALLY_MYS_66 | 12:40 | 15:46 | 3:05 | LINE CLEAR AVAILED |
| 1505 | 30-Jul-2022 | MYSURU | 66 | KHB STATION-BILIKERE | DMG_HALLI_66 | 14:58 | 18:20 | 3:21 | NFBC ISSUED |
| 1506 | 30-Jul-2022 | MYSURU | 66 | KHB STATION-HOOTAGALLI | NO STATIONS EFFECTED | 14:52 | 14:57 | 0:04 | HAND TRIPPED |
| 1507 | 30-Jul-2022 | MYSURU | 66 | KHB STATION-HOOTAGALLI | NO STATIONS EFFECTED | 18:20 | 18:24 | 0:03 | HAND TRIPPED |
| 1508 | 30-Jul-2022 | MYSURU | 66 | KALAMANDIR-MYSORE SOUTH | NO STATIONS EFFECTED | 9:56 | 13:43 | 3:47 | LINE CLEAR AVAILED |
| 1509 | 30-Jul-2022 | MYSURU | 66 | MADHUVANAHALLI-MAMBALLI | MAMBALLI_66 | 2:35 | 2:40 | 0:05 | LINE FAULT |
| 1510 | 30-Jul-2022 | MYSURU | 66 | MADHUVANAHALLI-LOKKANAHALLI | LOKKANAHALLI_66 PGPALYA_66 | 9:24 | 9:32 | 0:08 | LINE FAULT |
| 1511 | 30-Jul-2022 | MYSURU | 66 | MADHUVANAHALLI-LOKKANAHALLI | LOKKANAHALLI_66 PGPALYA_66 | 12:38 | 12:42 | 0:04 | LINE FAULT |
| 1512 | 30-Jul-2022 | MYSURU | 66 | HV1 | MYSURU SOUTH_66 | 12:39 | 13:33 | 0:53 | LINE CLEAR AVAILED |
| 1513 | 30-Jul-2022 | MYSURU | 66 | HV2 | MYSURU SOUTH_66 | 13:36 | 16:34 | 2:57 | LINE CLEAR AVAILED |
| 1514 | 30-Jul-2022 | MYSURU | 66 | HV1 | PANDAVAPURA_66 | 15:50 | 17:48 | 1:57 | LINE CLEAR AVAILED |
| 1515 | 30-Jul-2022 | MYSURU | 66 | RK NAGARA-MANTAKALLI | NO STATIONS EFFECTED | 9:32 | 13:53 | 4:20 | LINE CLEAR AVAILED |
| 1516 | 30-Jul-2022 | MYSURU | 66 | SFC SIVA-10MW | NO STATIONS EFFECTED | 20:43 | 21:13 | 0:30 | LINE FAULT |
| 1517 | 30-Jul-2022 | MYSURU | 66 | VAJMANGALA-KADAKOLA 2 | NO STATIONS EFFECTED | 5:54 | 6:00 | 0:06 | LINE FAULT |
| 1518 | 30-Jul-2022 | MYSURU | 66 | HOOTAGALLI-KAGGERE (HAMPAPURA) | NO STATIONS EFFECTED | 14:38 | 18:08 | 3:30 | LINE CLEAR AVAILED |
| 1519 | 30-Jul-2022 | MYSURU | 66 | HV1 | GUNDLUPETE_66 | 17:02(12.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1520 | 30-Jul-2022 | MYSURU | 220 | HV2 | MADHUVANAHALLI_220 | 18:57:18 (31.5.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1521 | 30-Jul-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 18:26 (22/04/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1522 | 30-Jul-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHALLI | NO STATIONS EFFECTED | 15:16(08/12/2021) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1523 | 30-Jul-2022 | MYSURU | 220 | HV1 | KADAKOLA_220 | 1:41:14 (21/07/2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1524 | 30-Jul-2022 | TUMKUR | 220 | DAVANGERE SRS- SHIMOGA 2 | DAVANGERE_SRS_220 | 14:20(27.07.2022) | | | LINE OPEN, LINE FAULT |
| 1525 | 30-Jul-2022 | TUMKUR | 220 | DAVANGERE SRS- GUTTUR-2 | DAVANGERE_SRS_220 | 4:18:00 (29.07.2022) | 18:55(30.07.2022) | 38:15HRS | LINE CHARGED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--------------------------------------|---|-----------------------|-----------|----------|-------------------------------------|
| 1526 | 30-Jul-2022 | TUMKUR | 220 | CHITRADURGA 220- GUTTUR 220 | GUTTUR 220 | 9:43 | 18:51 | 9:08 | NFBC ISSUED |
| 1527 | 30-Jul-2022 | TUMKUR | 220 | GUTTUR 400- CHITRADURGA 220 | CHITRADURGA_220 | 9:42 | 18:50 | 9:07 | LINE CLEAR AVAILED |
| 1528 | 30-Jul-2022 | TUMKUR | 220 | CHITRADURGA 220kv- CHITRADURGA 4 | CHITRADURGA_220 | 13:00 | 16:00 | 3:00 | LINE CLEAR AVAILED |
| 1529 | 30-Jul-2022 | TUMKUR | 110 | NITTUR 220kv- SOMALAPURA | SOMALAPURA_66 | 21:05 | 21:20 | 0:14 | HAND TRIPPED |
| 1530 | 30-Jul-2022 | TUMKUR | 66 | TR-1 | AMRUTHUR_66 | 22:27 | 22:29 | 0:02 | TRANSFORMER FAULT |
| 1531 | 30-Jul-2022 | TUMKUR | 66 | BILCHODU-PALLAGATTE | PALLAGATTE_66 | 6:50 | 6:55 | 0:05 | MAIN SUPPLY FAILURE |
| 1532 | 30-Jul-2022 | TUMKUR | 66 | TR-1 | CHALLAKERE_66 | 15:32 | 16:38 | 1:06 | LINE CLEAR AVAILED |
| 1533 | 30-Jul-2022 | TUMKUR | 66 | CHITRADURGA 220kv- PANDARAHALLI 1 | HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66 | 13:37 | 15:17 | 1:39 | LINE CLEAR AVAILED |
| 1534 | 30-Jul-2022 | TUMKUR | 66 | CHITRADURGA 220kv- PANDARAHALLI 2 | PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66 | 14:06 | 14:20 | 0:14 | LINE CLEAR AVAILED |
| 1535 | 30-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- AVAREGERE66(CTA-1) | AVAREGERE_66,MELLEKATTE_66,KADAJJI_66 | 1:38 | 1:48 | 0:10 | LINE FAULT |
| 1536 | 30-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- AVAREGERE66(CTA-1) | AVAREGERE_66,MELLEKATTE_66,KADAJJI_66 | 9:47 | 9:58 | 0:11 | LINE FAULT |
| 1537 | 30-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- AVAREGERE66(CTA-1) | AVAREGERE_66,MELLEKATTE_66,KADAJJI_66 | 10:18 | 10:45 | 0:27 | LINE FAULT |
| 1538 | 30-Jul-2022 | TUMKUR | 66 | HANAGAL- RAMPURA | RAMAPURA_66 | 11:05 | 12:10 | 1:05 | LINE CLEAR AVAILED |
| 1539 | 30-Jul-2022 | TUMKUR | 66 | HONNALLI - KUNDUR | HONNALLI_66 | 7:39 | 7:50 | 0:10 | LINE FAULT |
| 1540 | 30-Jul-2022 | TUMKUR | 66 | JAVAGONDANAHALLI- INFOSYS-1 | JAVAGONDANAHALLI_66 | 10:52 | 10:56 | 0:04 | HAND TRIPPED |
| 1541 | 30-Jul-2022 | TUMKUR | 66 | JAVAGONDANAHALLI- SIRA | JAVAGONDANAHALLI_66 | 14:12 | 14:30 | 0:17 | HAND TRIPPED |
| 1542 | 30-Jul-2022 | TUMKUR | 66 | KUNDUR- HONNALI | KUNDUR_66,MALEBENNUR_66 | 3:37 | 3:40 | 0:03 | LINE FAULT |
| 1543 | 30-Jul-2022 | TUMKUR | 66 | KUNDUR- HONNALI | KUNDUR_66,MALEBENNUR_66 | 7:39 | 8:30 | 0:50 | MAIN SUPPLY FAILURE |
| 1544 | 30-Jul-2022 | TUMKUR | 66 | TR-1 | KUNDUR_66 | 3:36 | 3:45 | 0:09 | TRANSFORMER FAULT |
| 1545 | 30-Jul-2022 | TUMKUR | 66 | TR-1 | KUNDUR_66 | 5:14 | 5:31 | 0:16 | TRANSFORMER FAULT |
| 1546 | 30-Jul-2022 | TUMKUR | 66 | TR-1 | LOKIKERE_66(SHAGLE) | 1:50 | 1:57 | 0:06 | MAIN SUPPLY FAILURE |
| 1547 | 30-Jul-2022 | TUMKUR | 66 | MAYAKONDA- DAVANAGERE SRS 220KV | MAYAKONDA_66 | 10:20 | 11:00 | 0:40 | MAIN SUPPLY FAILURE |
| 1548 | 30-Jul-2022 | TUMKUR | 66 | SIRA220-TAVAREKERE | TAVAREKERE_66 | 14:16 | 14:20 | 0:03 | HAND TRIPPED |
| 1549 | 30-Jul-2022 | TUMKUR | 66 | THALLAK 220kv- GOWRASAMUDRA | CHALLAKERE_66, SANIKERE_66 | 4:22 | 4:29 | 0:07 | LINE FAULT |
| 1550 | 30-Jul-2022 | TUMKUR | 66 | THALLAK 220kv- WELSPUN SOLAR1 & 2 | WELSPUNSOLAR1 & 2_IPP_66 | 9:27 | 9:38 | 0:10 | LINE FAULT |
| 1551 | 30-Jul-2022 | TUMKUR | 66 | THALLAK 220kv- WELSPUN SOLAR1 & 2 | WELSPUNSOLAR1 & 2_IPP_66 | 15:50 | 15:59 | 0:08 | LINE FAULT |
| 1552 | 30-Jul-2022 | TUMKUR | 66 | TR-1 | YADIYUR_66 | 19:48 | 19:51 | 0:02 | LINE CLEAR AVAILED |
| 1553 | 31-Jul-2022 | BAGALKOT | 220 | SIRSI-HUBLI-1 | STATION NOT AFFECTED SIRSI_220 | 19:46 (15.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1554 | 31-Jul-2022 | BAGALKOT | 220 | SIRSI-HUBLI-2 | STATION NOT AFFECTED SIRSI_220 | 19:46 (15.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1555 | 31-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED TODALBAGI_110 | 19:13 (17.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1556 | 31-Jul-2022 | BAGALKOT | 110 | TODALBAGI-SAVALAGI | STATION NOT AFFECTED TODALBAGI_110 | 18:00 (20.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1557 | 31-Jul-2022 | BAGALKOT | 110 | UTTUR - F1 JAMB CB(MUDHOL) | STATION NOT AFFECTED UTTUR_110 | 9:51 (24.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1558 | 31-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV3 | STATION NOT AFFECTED BILAGI_110 | 7:28 (29.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1559 | 31-Jul-2022 | BAGALKOT | 220 | HUBLI-SIRSI-2 | STATION NOT AFFECTED HUBLI_220 | 14:21 | 18:11 | 3:50 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|---------------------------------|--------------------------------------|---------|-----------|----------|--------------------|
| 1560 | 31-Jul-2022 | BAGALKOT | 220 | AMBEWADI_NAGZARI-2 | STATION NOT AFFECTED AMBEWADI_220 | 13:37 | 13:55 | 0:18 | LINE FAULT |
| 1561 | 31-Jul-2022 | BAGALKOT | 220 | AMBEWADI_PONDA-2 | STATION NOT AFFECTED AMBEWADI_220 | 16:56 | 18:48 | 1:52 | LINE FAULT |
| 1562 | 31-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-BAGALKOT-2 | BAGALKOT_110 | 8:11 | 11:50 | 3:39 | LINE CLEAR AVAILED |
| 1563 | 31-Jul-2022 | BAGALKOT | 110 | CHIKKODI220-CHIKKODI | STATION NOT AFFECTED CHIKKODI_220 | 15:15 | 18:28 | 3:13 | LINE CLEAR AVAILED |
| 1564 | 31-Jul-2022 | BAGALKOT | 220 | HAVERI-BIDNAL | STATION NOT AFFECTED HAVERI_220 | 11:07 | 17:29 | 6:22 | LINE FAULT |
| 1565 | 31-Jul-2022 | BAGALKOT | 220 | SIRSI-SHARAVATY-2 | STATION NOT AFFECTED SIRSI_220 | 11:58 | 15:15 | 3:17 | LINE FAULT |
| 1566 | 31-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV-2 & LV2 | STATION NOT AFFECTED BELAGAVI_220 | 13:16 | 17:59 | 4:43 | LINE CLEAR AVAILED |
| 1567 | 31-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV-1 | STATION NOT AFFECTED BELAGAVI_220 | 13:10 | 17:56 | 4:46 | LINE CLEAR AVAILED |
| 1568 | 31-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV-3 | STATION NOT AFFECTED BELAGAVI_220 | 13:19 | 14:37 | 1:18 | LINE CLEAR AVAILED |
| 1569 | 31-Jul-2022 | BAGALKOT | 110 | BELAGAVI20-KANABARGI | STATION NOT AFFECTED BELAGAVI_220 | 10:43 | 14:59 | 4:16 | LINE CLEAR AVAILED |
| 1570 | 31-Jul-2022 | BAGALKOT | 110 | BELAGAVI20-BELGAVI(NEHARUNAGAR) | STATION NOT AFFECTED BELAGAVI_220 | 12:31 | 15:19 | 2:48 | LINE CLEAR AVAILED |
| 1571 | 31-Jul-2022 | BAGALKOT | 110 | BELAGAVI20-VADAGAON | STATION NOT AFFECTED BELAGAVI_220 | 13:05 | 16:35 | 3:30 | LINE CLEAR AVAILED |
| 1572 | 31-Jul-2022 | BAGALKOT | 110 | BELAGAVI20-KANABARGI | STATION NOT AFFECTED BELAGAVI_220 | 17:02 | 17:38 | 0:36 | HAND TRIPPED |
| 1573 | 31-Jul-2022 | BAGALKOT | 110 | BELAGAVI20-ANKALAGI | STATION NOT AFFECTED BELAGAVI_220 | 13:14 | 18:25 | 5:11 | LINE CLEAR AVAILED |
| 1574 | 31-Jul-2022 | BAGALKOT | 220 | NARENDRA-KNBRG1 (BELAGAVI-1) | STATION NOT AFFECTED NARENDRA_220 | 11:59 | 18:09 | 6:10 | NFBC ISSUED |
| 1575 | 31-Jul-2022 | BAGALKOT | 110 | BAGEWADI-MAMADAPUR1 | MAMADAPUR_110 | 5:33 | 5:52 | 0:19 | LINE FAULT |
| 1576 | 31-Jul-2022 | BAGALKOT | 220 | BIDNAL-HAVERI | BIDNAL_220 | 11:07 | 17:29 | 6:22 | LINE FAULT |
| 1577 | 31-Jul-2022 | BAGALKOT | 110 | BIDNAL-ANNIGERI | ANNIGERI_110 | 2:12 | 2:30 | 0:18 | HAND TRIPPED |
| 1578 | 31-Jul-2022 | BAGALKOT | 110 | BIDNAL-GADAG | GADAG_110 | 2:12 | 2:27 | 0:15 | HAND TRIPPED |
| 1579 | 31-Jul-2022 | BAGALKOT | 110 | BIDNAL-NAVALGUND | NAVALGUND_110 | 2:12 | 2:29 | 0:17 | HAND TRIPPED |
| 1580 | 31-Jul-2022 | BAGALKOT | 110 | BIDNAL-PH COMPOUND | PH COMPUND_110 | 2:12 | 8:51 | 6:39 | LINE CLEAR AVAILED |
| 1581 | 31-Jul-2022 | BAGALKOT | 110 | KIADB BIJAPUR-BHUTANAL | BHUTANAL_110 | 20:26 | 20:41 | 0:15 | LINE FAULT |
| 1582 | 31-Jul-2022 | BAGALKOT | 110 | THORVI-TAKKALAKI | TAKKALAKI_110 | 20:33 | 20:44 | 0:11 | HAND TRIPPED |
| 1583 | 31-Jul-2022 | BAGALKOT | 110 | BELGAUM-MACHE | BELGAUM_110 | 12:34 | 15:38 | 3:04 | LINE CLEAR AVAILED |
| 1584 | 31-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1&2 | BELGAUM_110 | 12:37 | 15:39 | 3:02 | LINE CLEAR AVAILED |
| 1585 | 31-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV4 | BELGAUM_110 | 15:57 | 16:07 | 0:10 | LINE CLEAR AVAILED |
| 1586 | 31-Jul-2022 | BAGALKOT | 110 | BENAKATTI-F2(YARAGATTI) | BENEKATTI_110 | 5:13 | 6:17 | 1:04 | LINE FAULT |
| 1587 | 31-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | CHIKKODI_110 | 10:35 | 18:35 | 8:00 | LINE CLEAR AVAILED |
| 1588 | 31-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | CHIKKODI_110 | 10:42 | 18:35 | 7:53 | LINE CLEAR AVAILED |
| 1589 | 31-Jul-2022 | BAGALKOT | 110 | CHANDKAVATE-ALMEL | ALMEL_110 | 6:31 | 7:10 | 0:39 | LINE FAULT |
| 1590 | 31-Jul-2022 | BAGALKOT | 110 | GADAG ROAD-GOPANAKOPPA | GADAG ROAD_110 | 1:14 | 2:27 | 1:13 | LOAD CHANGE OVER |
| 1591 | 31-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | GADAG_110 | 15:44 | 17:27 | 1:43 | LINE CLEAR AVAILED |
| 1592 | 31-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | MORATAGI_110 | 11:10 | 11:53 | 0:43 | LINE CLEAR AVAILED |
| 1593 | 31-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | MUDEDEBIHAL_110 | 11:18 | 11:53 | 0:35 | LINE CLEAR AVAILED |
| 1594 | 31-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | MUDEDEBIHAL_110 | 13:10 | 13:26 | 0:16 | LINE CLEAR AVAILED |
| 1595 | 31-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | NANADI_110 | 12:18 | 13:24 | 1:06 | LINE CLEAR AVAILED |
| 1596 | 31-Jul-2022 | BAGALKOT | 110 | BIDNAL-NAVALGUND | NAVALGUND_110 | 0:55 | 9:10 | 8:15 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--|--|-----------------------|-----------|----------|-------------------------------------|
| 1597 | 31-Jul-2022 | BAGALKOT | 110 | TAKKALAKI-TIKOTA | TIKOTA_110 | 20:35 | 20:45 | 0:10 | HAND TRIPPED |
| 1598 | 31-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | TIKOTA_110 | 19:11 | 19:42 | 0:31 | HAND TRIPPED |
| 1599 | 31-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | TIKOTA_110 | 22:26 | 22:42 | 0:16 | HAND TRIPPED |
| 1600 | 31-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV4 | TIKOTA_110 | 22:26 | 23:04 | 0:38 | HAND TRIPPED |
| 1601 | 31-Jul-2022 | BAGALKOT | 110 | RANEENNUR-TUMMINAKATTE | TUMMINAKATTE_110 | 12:31 | 19:04 | 6:33 | LINE CLEAR AVAILED |
| 1602 | 31-Jul-2022 | BAGALKOT | 110 | YALLAMANAWADI-SAVALAGI | YALLAMNAVADI_110 | 10:05 | 10:42 | 0:37 | LINE CLEAR AVAILED |
| 1603 | 31-Jul-2022 | BAGALKOT | 110 | 110/33KV, HV3 | STATION NOT AFFECTED YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1604 | 31-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV1 | STATION NOT AFFECTED AMBEWADI_220 | 20:00 (09.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1605 | 31-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV-3 & LV3 | STATION NOT AFFECTED ATHANI_220 | 10:26 (25.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1606 | 31-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-BAGALKOT-1 | BAGALKOT_110 | 8:11 | 11:50 | 3:39 | LINE CLEAR AVAILED |
| 1607 | 31-Jul-2022 | BAGALKOT | 110 | RANEENNUR220-RATTIHALLI (TUMMINAKATTI) | STATION NOT AFFECTED RANEENNUR_220 | 12:13 | 19:07 | 6:54 | LINE FAULT |
| 1608 | 31-Jul-2022 | BAGALKOT | 110 | MK HUBLI220- HIREBAGEWADI | HIREBAGEWADI_110 | 6:07 | 6:42 | 0:35 | LINE FAULT |
| 1609 | 31-Jul-2022 | BENGALURU | 66 | HV2 | APPAREL PARK | 3:50 | 3:54 | 0:04 | TRANSFORMER FAULT |
| 1610 | 31-Jul-2022 | BENGALURU | 66 | AREHALLI - BANASHANKARI | AREHALLI | 0:42 | 0:45 | 0:03 | LOAD CHANGE OVER |
| 1611 | 31-Jul-2022 | BENGALURU | 66 | NELAKADRENAHALLI - BRINDAVANA 220 | NELAKADRENAHALLI | 11:05 | 13:50 | 2:45 | LINE CLEAR AVAILED |
| 1612 | 31-Jul-2022 | BENGALURU | 66 | GOKULA - BEL(EHT) | BEL(EHT) | 12:21 | 14:37 | 2:16 | LINE CLEAR AVAILED |
| 1613 | 31-Jul-2022 | BENGALURU | 66 | GOKULA - MATHIKERE | MATHIKERE | 8:17 | 8:35 | 0:18 | LINE FAULT |
| 1614 | 31-Jul-2022 | BENGALURU | 66 | HV2 | HEBBALA 220 | 1:22 | 3:29 | 2:07 | LINE CLEAR AVAILED |
| 1615 | 31-Jul-2022 | BENGALURU | 66 | HV3 | HEBBALA 220 | 0:26 | 3:43 | 3:17 | TRANSFORMER FAULT |
| 1616 | 31-Jul-2022 | BENGALURU | 66 | KODIGEHALLI - BYADRAHALLI | KODIGEHALLI | 12:30 | 12:37 | 0:07 | MAIN SUPPLY FAILURE |
| 1617 | 31-Jul-2022 | BENGALURU | 66 | KODIGEHALLI - MAGADI 220 | KODIGEHALLI | 13:40 | 13:46 | 0:06 | LOAD CHANGE OVER |
| 1618 | 31-Jul-2022 | BENGALURU | 66 | MAHALAKSHMI LAYOUT - SRS PEENYA 220 | MAHALAKSHMI LAYOUT | 9:10 | 9:18 | 0:08 | LOAD CHANGE OVER |
| 1619 | 31-Jul-2022 | BENGALURU | 66 | MAHALAKSHMI LAYOUT - NRS PEENYA 220 | MAHALAKSHMI LAYOUT | 17:24 | 17:29 | 0:05 | LOAD CHANGE OVER |
| 1620 | 31-Jul-2022 | BENGALURU | 66 | HV2 | MELLAHALLI | 7:50 | 8:00 | 0:10 | TRANSFORMER FAULT |
| 1621 | 31-Jul-2022 | BENGALURU | 66 | NANDINI LAYOUT - SRS PEENYA 220 | NANDINI LAYOUT | 7:02 | 7:13 | 0:11 | LOAD CHANGE OVER |
| 1622 | 31-Jul-2022 | BENGALURU | 66 | NANDINI LAYOUT - NRS 220 | NANDINI LAYOUT | 17:26 | 17:32 | 0:06 | LOAD CHANGE OVER |
| 1623 | 31-Jul-2022 | BENGALURU | 66 | HV2 | NRS 220 | 18:08 | 18:13 | 0:05 | LOAD CHANGE OVER |
| 1624 | 31-Jul-2022 | BENGALURU | 66 | HV3 | NRS 220 | 10:53 | 11:36 | 0:43 | LINE CLEAR AVAILED |
| 1625 | 31-Jul-2022 | BENGALURU | 66 | RMV - GOKULA | RMV, TATA INSTITUTE (EHT) | 8:52 | 8:56 | 0:04 | LOAD CHANGE OVER |
| 1626 | 31-Jul-2022 | BENGALURU | 66 | RMZ - VIKAS TECH PARK 220 | RMZ | 15:26 | 15:47 | 0:21 | MAIN SUPPLY FAILURE |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|------------------------------|--------------------------------|---------|-----------|----------|--------------------|
| 1627 | 31-Jul-2022 | BENGALURU | 66 | SRS PEENYA 220 - MEI LAYOUT | MEI LAYOUT, WIDIA, WIDIA (EHT) | 7:56 | 7:59 | 0:03 | LINE CLEAR AVAILED |
| 1628 | 31-Jul-2022 | BENGALURU | 66 | SRS PEENYA 220 - BYADRAHALLI | BYADRAHALLI, SRIGANDA KAVALU | 12:30 | 13:25 | 0:55 | LINE CLEAR AVAILED |
| 1629 | 31-Jul-2022 | BENGALURU | 66 | SRS PEENYA 220 - MEI LAYOUT | MEI LAYOUT, WIDIA, WIDIA (EHT) | 17:05 | 17:07 | 0:02 | LINE CLEAR AVAILED |
| 1630 | 31-Jul-2022 | BENGALURU | 66 | T GOLLAHALLI 220 - AVANI | AVANI, MULBAGAL | 21:17 | 22:27 | 1:10 | LINE FAULT |
| 1631 | 31-Jul-2022 | BENGALURU | 66 | VICTORIA - NATIONAL COLLEGE | VICTORIA | 9:45 | 9:47 | 0:02 | LOAD CHANGE OVER |
| 1632 | 31-Jul-2022 | BENGALURU | 66 | HV2 | VIJAYANAGARA | 6:22 | 6:31 | 0:09 | LOAD CHANGE OVER |
| 1633 | 31-Jul-2022 | BENGALURU | 66 | HV1 | VIJAYANAGARA | 6:24 | 6:31 | 0:07 | LOAD CHANGE OVER |
| 1634 | 31-Jul-2022 | BENGALURU | 66 | HV1 | VIJAYANAGARA | 22:04 | 22:15 | 0:11 | LOAD CHANGE OVER |
| 1635 | 31-Jul-2022 | BENGALURU | 66 | HV2 | VIJAYANAGARA | 22:04 | 22:16 | 0:12 | LOAD CHANGE OVER |
| 1636 | 31-Jul-2022 | BENGALURU | 66 | HV1 | SOMANAHALLI 220 | 0:56 | 1:25 | 0:29 | TRANSFORMER FAULT |
| 1637 | 31-Jul-2022 | BENGALURU | 66 | HV2 | MANYATHA TECH PARK 66 | 10:24 | 10:28 | 0:04 | LINE CLEAR AVAILED |
| 1638 | 31-Jul-2022 | BENGALURU | 220 | KOLAR 220 - PGCIL 1 | KOLAR 220 | 10:01 | 13:01 | 3:00 | LINE CLEAR AVAILED |
| 1639 | 31-Jul-2022 | BENGALURU | 220 | KOLAR 220 - PGCIL 2 | KOLAR 220 | 10:01 | 13:01 | 3:00 | LINE CLEAR AVAILED |
| 1640 | 31-Jul-2022 | BENGALURU | 66 | HV1 | KOLAR 220 | 9:49 | 10:36 | 0:47 | LINE CLEAR AVAILED |
| 1641 | 31-Jul-2022 | BENGALURU | 66 | HV2 | KOLAR 220 | 9:49 | 10:36 | 0:47 | LINE CLEAR AVAILED |
| 1642 | 31-Jul-2022 | BENGALURU | 66 | HV1 | KOLAR 220 | 12:20 | 13:04 | 0:44 | LINE CLEAR AVAILED |
| 1643 | 31-Jul-2022 | BENGALURU | 66 | HV2 | KOLAR 220 | 12:20 | 13:04 | 0:44 | LINE CLEAR AVAILED |
| 1644 | 31-Jul-2022 | BENGALURU | 220 | HV2 | KOLAR 220 | 9:52 | 10:35 | 0:43 | LINE CLEAR AVAILED |
| 1645 | 31-Jul-2022 | BENGALURU | 220 | HV2 | KOLAR 220 | 12:30 | 13:02 | 0:32 | LINE CLEAR AVAILED |
| 1646 | 31-Jul-2022 | BENGALURU | 66 | KOLAR 220 - NANGALI | KEMBODI | 9:48 | 13:08 | 3:20 | LINE CLEAR AVAILED |
| 1647 | 31-Jul-2022 | BENGALURU | 66 | KOLAR 220 - THAYLUR | TAMAKA | 9:48 | 15:42 | 5:54 | LINE CLEAR AVAILED |
| 1648 | 31-Jul-2022 | BENGALURU | 66 | KOLAR 220 - PGCIL AUX | PGCIL AUX, SUGUTUR | 9:48 | 13:08 | 3:20 | LINE CLEAR AVAILED |
| 1649 | 31-Jul-2022 | BENGALURU | 66 | KOLAR 220 - VEMGAL | TALAGUNDA, VEMGAL, KYALNUR | 9:47 | 11:08 | 1:21 | LINE CLEAR AVAILED |
| 1650 | 31-Jul-2022 | BENGALURU | 66 | KOLAR 220 - VEMGAL | TALAGUNDA, VEMGAL, KYALNUR | 12:26 | 13:10 | 0:44 | LINE CLEAR AVAILED |
| 1651 | 31-Jul-2022 | BENGALURU | 66 | KOLAR 220 - VOKKALERI | VOKKALERI | 9:49 | 11:10 | 1:21 | LINE CLEAR AVAILED |
| 1652 | 31-Jul-2022 | BENGALURU | 66 | KOLAR 220 - VOKKALERI | VOKKALERI | 12:26 | 13:21 | 0:55 | LINE CLEAR AVAILED |
| 1653 | 31-Jul-2022 | BENGALURU | 66 | KOLAR 220 - SRINIVASPURA | DRRO (EHT), MALLASANDRA | 9:48 | 15:44 | 5:56 | LINE CLEAR AVAILED |
| 1654 | 31-Jul-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 1 | NARASAPURA | 9:49 | 10:36 | 0:47 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|-------------------------------------|--|---------|-----------|----------|---------------------|
| 1655 | 31-Jul-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 1 | NARASAPURA | 12:26 | 13:06 | 0:40 | LINE CLEAR AVAILED |
| 1656 | 31-Jul-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 2 | NARASAPURA | 20:48 | 20:55 | 0:07 | LINE FAULT |
| 1657 | 31-Jul-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 2 | NARASAPURA | 20:55 | 23:08 | 2:13 | LINE FAULT |
| 1658 | 31-Jul-2022 | BENGALURU | 66 | SM MANGALA - KOLAR 220 | SM MANGALA | 9:47 | 10:18 | 0:31 | LOAD CHANGE OVER |
| 1659 | 31-Jul-2022 | BENGALURU | 66 | DALASNUR - KOLAR 220 | DALASNUR | 8:00 | 8:10 | 0:10 | LOAD CHANGE OVER |
| 1660 | 31-Jul-2022 | BENGALURU | 66 | DALASNUR - SRINIVASPURA | DALASNUR | 15:55 | 16:05 | 0:10 | LOAD CHANGE OVER |
| 1661 | 31-Jul-2022 | BENGALURU | 66 | KOLAR 220 - VEMGAL | TALAGUNDA, VEMGAL, KYALNUR | 9:47 | 11:08 | 1:21 | LINE CLEAR AVAILED |
| 1662 | 31-Jul-2022 | BENGALURU | 66 | KOLAR 220 - VEMGAL | TALAGUNDA, VEMGAL, KYALNUR | 12:26 | 13:10 | 0:44 | LINE CLEAR AVAILED |
| 1663 | 31-Jul-2022 | BENGALURU | 66 | MANDIKAL - PERESANDRA | MANDIKAL, GUDIBANDE, D PALYA | 2:38 | 2:55 | 0:16 | LINE FAULT |
| 1664 | 31-Jul-2022 | BENGALURU | 66 | PATHPALYA - THIMMAPALLI | THIMMAPALLI | 0:21 | 0:32 | 0:11 | LINE FAULT |
| 1665 | 31-Jul-2022 | BENGALURU | 66 | DB PURA 220 - DG 1 | AIR(EHT) | 1:33 | 2:02 | 0:29 | MAIN SUPPLY FAILURE |
| 1666 | 31-Jul-2022 | BENGALURU | 66 | DB PURA 220 - DG 2 | DODDABELAVANGALA, GUNDAMGERE | 1:33 | 2:02 | 0:29 | MAIN SUPPLY FAILURE |
| 1667 | 31-Jul-2022 | BENGALURU | 66 | DB PURA 220 - DEVANAHALLI 1 | KUNDANA | 1:33 | 2:02 | 0:29 | MAIN SUPPLY FAILURE |
| 1668 | 31-Jul-2022 | BENGALURU | 66 | DB PURA 220 - DEVANAHALLI 2 | DEVANAHALLI | 1:33 | 2:02 | 0:29 | MAIN SUPPLY FAILURE |
| 1669 | 31-Jul-2022 | BENGALURU | 66 | DB PURA 220 - D CROSS | D CROSS | 1:33 | 2:02 | 0:29 | MAIN SUPPLY FAILURE |
| 1670 | 31-Jul-2022 | BENGALURU | 66 | DB PURA 220 - CHIKKABALLAPURA I/A 2 | CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI | 14:22 | 14:35 | 0:13 | LINE FAULT |
| 1671 | 31-Jul-2022 | BENGALURU | 66 | DB PURA 220 - DEVANAHALLI 1 | KUNDANA | 16:56 | 17:06 | 0:10 | LINE CLEAR AVAILED |
| 1672 | 31-Jul-2022 | BENGALURU | 66 | DB PURA 220 - DEVANAHALLI 2 | DEVANAHALLI | 16:56 | 17:06 | 0:10 | LINE CLEAR AVAILED |
| 1673 | 31-Jul-2022 | BENGALURU | 66 | DB PURA 220 - DG 1 | AIR(EHT) | 16:57 | 17:07 | 0:10 | LINE CLEAR AVAILED |
| 1674 | 31-Jul-2022 | BENGALURU | 66 | DB PURA 220 - DG 2 | DODDABELAVANGALA, GUNDAMGERE | 16:57 | 17:07 | 0:10 | LINE CLEAR AVAILED |
| 1675 | 31-Jul-2022 | BENGALURU | 66 | DB PURA 220 - D CROSS | D CROSS | 16:57 | 17:07 | 0:10 | LINE CLEAR AVAILED |
| 1676 | 31-Jul-2022 | BENGALURU | 220 | LV1 | DB PURA 220 | 1:33 | 1:44 | 0:11 | TRANSFORMER FAULT |
| 1677 | 31-Jul-2022 | BENGALURU | 220 | LV1 | DB PURA 220 | 1:44 | 2:01 | 0:17 | TRANSFORMER FAULT |
| 1678 | 31-Jul-2022 | BENGALURU | 66 | BANGARPETE - KGF | BANGARPETE | 14:20 | 14:35 | 0:15 | LOAD CHANGE OVER |
| 1679 | 31-Jul-2022 | BENGALURU | 66 | JADIGENAHALLI - HOSKOTE 220 | JADIGENAHALLI | 16:00 | 16:05 | 0:05 | LOAD CHANGE OVER |
| 1680 | 31-Jul-2022 | BENGALURU | 66 | MALUR 220 - MALUR I/A | MALUR I/A, ADL (EHT), BEST STEEL (EHT) | 13:03 | 13:35 | 0:32 | LINE CLEAR AVAILED |
| 1681 | 31-Jul-2022 | BENGALURU | 220 | MALUR 220 - KOLAR 3 | NO STATION AFFECTED | 14:51 | 14:57 | 0:06 | LINE FAULT |
| 1682 | 31-Jul-2022 | BENGALURU | 220 | HV2 | KIADB DB PURA 220 | 4:08 | 5:39 | 1:31 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--|---|-----------------------|-------------------|----------|--------------------------------|
| 1683 | 31-Jul-2022 | BENGALURU | 66 | ALUR - SRS PEENYA 220 | ALUR, BIEC | 6:40 | 6:45 | 0:05 | LOAD CHANGE OVER |
| 1684 | 31-Jul-2022 | BENGALURU | 66 | ALUR - NELAMANGALA 66 | ALUR, BIEC | 17:00 | 17:13 | 0:13 | LOAD CHANGE OVER |
| 1685 | 31-Jul-2022 | BENGALURU | 66 | ATTIBELE - ANEKAL | ATTIBELE | 11:05 | 11:10 | 0:05 | LOAD CHANGE OVER |
| 1686 | 31-Jul-2022 | BENGALURU | 66 | KACHAMARANAHALLI - DIVYASHREE TECH PARK | KACHAMARANAHALLI | 11:05 | 11:08 | 0:03 | LOAD CHANGE OVER |
| 1687 | 31-Jul-2022 | BENGALURU | 66 | HV2 | APPRAREL PARK | 3:45 | 3:50 | 0:05 | TRANSFORMER FAULT |
| 1688 | 31-Jul-2022 | BENGALURU | 66 | HV1 | SOMANTHPURA | 2:05 | 3:05 | 1:00 | TRANSFORMER FAULT |
| 1689 | 31-Jul-2022 | BENGALURU | 66 | MITTEMARI 220 - BAGEPALLI 1 | VATADOSANAHALLI | 0:54 | 1:01 | 0:07 | LINE FAULT |
| 1690 | 31-Jul-2022 | BENGALURU | 66 | MITTEMARI 220 - BAGEPALLI 1 | VATADOSANAHALLI | 1:01 | 1:07 | 0:06 | LINE FAULT |
| 1691 | 31-Jul-2022 | BENGALURU | 66 | KACHAMARANAHALLI - DOMMASANDRA | KACHAMARANAHALLI | 18:00 | 18:03 | 0:03 | LOAD CHANGE OVER |
| 1692 | 31-Jul-2022 | BENGALURU | 220 | MALUR 220 - HOODY I/C | NO STATION AFFECTED | 11:04(30-7-2021) | 9:27(31-7-2022) | 22:22 | LINE CHARGED |
| 1693 | 31-Jul-2022 | BENGALURU | 220 | HV2 | MITTEMARI 220 | 23:53(30-7-2022) | 1:10(31-7-2022) | 1:16 | MAIN SUPPLY FAILURE |
| 1694 | 31-Jul-2022 | BENGALURU | 66 | HV1 | MITTEMARI 220 | 23:53(30-7-2022) | 0:03(31-7-2022) | 0:09 | MAIN SUPPLY FAILURE |
| 1695 | 31-Jul-2022 | BENGALURU | 66 | MITTEMARI 220 - JULLUPALYA | JULLUPALYA | 23:53(30-7-2022) | 0:09(31-7-2022) | 0:15 | MAIN SUPPLY FAILURE |
| 1696 | 31-Jul-2022 | BENGALURU | 66 | MITTEMARI 220 - BAGEPALLI 1 | VATADOSANAHALLI | 23:53(30-7-2022) | 0:06(31-7-2022) | 0:12 | MAIN SUPPLY FAILURE |
| 1697 | 31-Jul-2022 | BENGALURU | 220 | GOWRIBIDANUR 220 - MITTEMARI 2 | MITTEMARI 220 | 23:53(30-7-2022) | 0:23(31-7-2022) | 0:30 | LINE FAULT |
| 1698 | 31-Jul-2022 | BENGALURU | 66 | HV1 | SUGUTUR | 23:20(30-7-2022) | 0:30(31-7-2022) | 1:10 | TRANSFORMER FAULT |
| 1699 | 31-Jul-2022 | BENGALURU | 220 | HV2 | YARANDANAHALLI 220 | 21:28:00(30/07/2022) | 8:23(31/07/2022) | 10:55HRS | TRANSFORMER CHARGED |
| 1700 | 31-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - CHANDAPURA | NO STATION AFFECTED | 23:20(30/07/2022) | 11:10(31/07/2022) | 11:50HRS | LINE CHARGED |
| 1701 | 31-Jul-2022 | BENGALURU | 220 | EAST DIVISION COMPOUND 220 - A STATION 220 | NO STATION AFFECTED | 08:38:00(23/07/2022) | | | LINE OPEN, LINE FAULT |
| 1702 | 31-Jul-2022 | GULBARGA | 220 | SEDAM_SHAHAPUR | SEDAM_220 | 05:48(10/06/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1703 | 31-Jul-2022 | GULBARGA | 220 | HV1 | KUSTAGI_220 | 3:45 | 4:24 | 0:39 | TRANSFORMER FAULT |
| 1704 | 31-Jul-2022 | GULBARGA | 220 | HV2 | KUSTAGI_220 | 3:45 | 4:24 | 0:39 | TRANSFORMER FAULT |
| 1705 | 31-Jul-2022 | GULBARGA | 220 | LINGASUGUR-RTPS | LINGASUGUR_220 | 1:48 | 2:12 | 0:24 | LINE FAULT |
| 1706 | 31-Jul-2022 | GULBARGA | 220 | LINGASUGUR-RTPS | LINGASUGUR_220 | 23:02 | 23:38 | 0:36 | LINE FAULT |
| 1707 | 31-Jul-2022 | GULBARGA | 110 | HUMNABAD-HALLIKHED | HALLIKHED_110 | 9:34(20/07/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1708 | 31-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR1 | JEWARGI_110 | 12:15(15/06/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1709 | 31-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR2 | NALWAR_110 | 15:10(14/06/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1710 | 31-Jul-2022 | GULBARGA | 110 | HUMNABAD-HALBARGA | HALBARGA_110 | 3:54(20/07/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1711 | 31-Jul-2022 | GULBARGA | 110 | HALBARGA-BHALKI | BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP | 06:55 (26/07/2022) | | | LINE OPEN, LINE FAULT |
| 1712 | 31-Jul-2022 | GULBARGA | 110 | NALWAR-SHAHAPUR110 | NALWAR_110 | 21:53(31.07.2022) | | | LINE OPEN, LINE FAULT |
| 1713 | 31-Jul-2022 | GULBARGA | 110 | LV1 | SHAHAPUR_220 | 20:30 | 20:50 | 0:20 | TRANSFORMER FAULT |
| 1714 | 31-Jul-2022 | GULBARGA | 110 | NALWAR-CLEAN SOLAR | NALWAR_110 | 5:15 | 5:24 | 0:09 | LINE FAULT |
| 1715 | 31-Jul-2022 | GULBARGA | 110 | YELBURGA-PRPJ_SLR | YELBURGA_110 | 4:40 | 5:14 | 0:34 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|---------------------------|---|-------------------|-----------|----------|-----------------------|
| 1716 | 31-Jul-2022 | GULBARGA | 110 | MUDDAPURA-MASKI | MASKI_110, HATTI_110 | 21:04 | 21:10 | 0:06 | LINE FAULT |
| 1717 | 31-Jul-2022 | GULBARGA | 110 | KEMBHAVI-HUNSAGI | HUNSAGI_110 | 20:05 | 20:20 | 0:15 | LINE FAULT |
| 1718 | 31-Jul-2022 | GULBARGA | 110 | SHAHAPUR-KEMBHAVI | KEMBHAVI_110,HUNSAGI_110,ASKI_110,UGAR SUGAR_IPP | 20:30 | 20:50 | 0:20 | MAIN SUPPLY FAILURE |
| 1719 | 31-Jul-2022 | GULBARGA | 110 | ALIPUR-MUNIRABAD | TORANGALLU_110,KUDITINI_110,KURUGOD_110,SHATAVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAMLAPUR_IPP,MATR_110,RBNS FACTORY | 2:04 | 2:15 | 0:11 | LINE FAULT |
| 1720 | 31-Jul-2022 | GULBARGA | 110 | HUMNABAD-CHITAGUPPA | CHITAGUPPA_110,NIRNA_110 | 5:50 | 6:10 | 0:20 | LINE FAULT |
| 1721 | 31-Jul-2022 | GULBARGA | 110 | KAPNOOR-MADIYAL | MADIYAL_110,CHOWDAPURA_110,NSL SUGARS FACTORY | 5:02 | 5:37 | 0:35 | LINE FAULT |
| 1722 | 31-Jul-2022 | GULBARGA | 110 | SINDHNOOR-VALABELLARI | MANVI_110,MADLAPUR_110,KURDICROSS_110,ADVIAMRESHWAR_110,JAWALGERA_110 | 1:55 | 2:05 | 0:10 | LINE FAULT |
| 1723 | 31-Jul-2022 | GULBARGA | 110 | SHAHAPUR-SHAHAPUR_1 | SHAHAPUR_110,NALWAR_110,JEWARGI_110 | 11:45 | 12:05 | 0:20 | LINE FAULT |
| 1724 | 31-Jul-2022 | GULBARGA | 110 | SHAHAPUR-SHAHAPUR_1 | SHAHAPUR_110,NALWAR_110,JEWARGI_110 | 13:13 | 13:15 | 0:02 | LINE CLEAR AVAILED |
| 1725 | 31-Jul-2022 | GULBARGA | 110 | SHAHAPUR-KBJNL | KBJNL_110 | 20:30 | 22:12 | 1:42 | LINE FAULT |
| 1726 | 31-Jul-2022 | GULBARGA | 110 | SHAHAPUR-SHAHAPUR_1 | SHAHAPUR_110,NALWAR_110,JEWARGI_110 | 21:54 | 22:10 | 0:16 | LINE FAULT |
| 1727 | 31-Jul-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | YADGIR_110,SAIDAPUR_110 | 23:54 | 23:58 | 0:04 | LINE FAULT |
| 1728 | 31-Jul-2022 | GULBARGA | 110 | KUSTAGI-VAJRABANDI | VAJRABANDI_110,YELBURGA_110,KUKNOOR_110 | 3:45 | 4:34 | 0:49 | LINE FAULT |
| 1729 | 31-Jul-2022 | GULBARGA | 110 | KUSTAGI-HANUMASAGAR | HANUMASAGAR_110,HIREGONNAGAR_110,HANUMANAL_110 | 12:04 | 16:25 | 4:21 | NFBC ISSUED |
| 1730 | 31-Jul-2022 | GULBARGA | 110 | RAICHUR-SHAHAPUR1 | GABBUR_110 | 11:37 | 12:44 | 1:07 | LINE CLEAR AVAILED |
| 1731 | 31-Jul-2022 | GULBARGA | 110 | RAICHUR-MALIYABAD | MALIYABAD_110,YERAGERA_110,VADAVATTI_110,YAPALDINNI_110 | 20:37 | 20:44 | 0:07 | LINE FAULT |
| 1732 | 31-Jul-2022 | GULBARGA | 110 | HALBARGA-HALLIKHED | HALLIKHED_110 | 6:24 | 6:28 | 0:04 | LINE FAULT |
| 1733 | 31-Jul-2022 | GULBARGA | 110 | HALBARGA-SANTAPUR | SANTAPUR_110,DONGARGOAN_110,DIGGI_110 | 6:32 | 6:39 | 0:07 | LINE FAULT |
| 1734 | 31-Jul-2022 | GULBARGA | 110 | HALBARGA-KAMTHANA | KAMTHANA_110,HABSIKOTE_110 | 9:27 | 18:43 | 9:16 | LINE CLEAR AVAILED |
| 1735 | 31-Jul-2022 | GULBARGA | 110 | HALBARGA-CHIDRI 2 | CHIDRI_110 | 9:58 | 18:51 | 8:53 | LINE CLEAR AVAILED |
| 1736 | 31-Jul-2022 | GULBARGA | 110 | MALLAT-ALKOD | ALKOD_110,GALAG_110 | 2:05 | 2:10 | 0:05 | LINE FAULT |
| 1737 | 31-Jul-2022 | GULBARGA | 110 | MALLAT-BYAGWAT | BYAGWAT_110,VALKAMDINNI_110 | 21:08 | 21:14 | 0:06 | LINE FAULT |
| 1738 | 31-Jul-2022 | GULBARGA | 66 | HV2 | CHORNOOR_66 | 16:50 | 17:10 | 0:20 | LINE CLEAR AVAILED |
| 1739 | 31-Jul-2022 | GULBARGA | 66 | UCHCHANGIDURGA-PUNABGHATA | UCHCHANGIDURGA_66 | 13:00 | 13:10 | 0:10 | LINE FAULT |
| 1740 | 31-Jul-2022 | GULBARGA | 66 | TELAGI-YARAGUNTA | YARAGUNTA_66 | 17:20 | 17:30 | 0:10 | LINE FAULT |
| 1741 | 31-Jul-2022 | GULBARGA | 66 | PUNABGHATA-NEELAGUNDA | PUNABGATTA_66,UCHCHANGIDURGA_66,BILCHOD_66,UJJAINI_66 | 12:55 | 13:00 | 0:05 | LINE FAULT |
| 1742 | 31-Jul-2022 | GULBARGA | 66 | ITTAGI-HIREHADAGALI_2 | HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66,SOVENHALLI_66,TUNGA BHADRA_IPP | 6:20 | 6:34 | 0:14 | LINE FAULT |
| 1743 | 31-Jul-2022 | GULBARGA | 66 | ITTAGI-HAGRIBOMMANHALLI | UPANAYAKANHALLI_66,HAGRIBOMMANHALLI_66 | 9:33 | 9:38 | 0:05 | LINE CLEAR AVAILED |
| 1744 | 31-Jul-2022 | GULBARGA | 66 | ITTAGI-HAGRIBOMMANHALLI | UPANAYAKANHALLI_66,HAGRIBOMMANHALLI_66 | 15:18 | 15:25 | 0:07 | LINE CLEAR AVAILED |
| 1745 | 31-Jul-2022 | GULBARGA | 66 | MUNIRABAD-MSD | HANSI_66 | 14:43 | 16:58 | 2:15 | LINE CLEAR AVAILED |
| 1746 | 31-Jul-2022 | HASSAN | 220 | CRPATNA-HSN400 | CRPATNA_220 | 13:34(15.07.2022) | | | LINE OPEN, LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|--------------------------|--|----------------------|-----------|----------|-------------------------------------|
| 1747 | 31-Jul-2022 | HASSAN | 110 | HV2 | KARAYA_110 | 6:55(31.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1748 | 31-Jul-2022 | HASSAN | 110 | HV1 | SINGATGERER_110 | 1:33(31.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1749 | 31-Jul-2022 | HASSAN | 220 | MRSSHM-VARAH13 | MRSMSG_220 | 9:31 | 18:45 | 9:14 | LINE CLEAR AVAILED |
| 1750 | 31-Jul-2022 | HASSAN | 110 | MRSSHM-GAJNUR | MRSMSG_220 | 9:56 | 19:06 | 9:10 | LINE CLEAR AVAILED |
| 1751 | 31-Jul-2022 | HASSAN | 220 | SHRAVITY-SHIRALKOPPA | gen_sharavathy | 12:15 | 13:50 | 1:35 | LINE FAULT |
| 1752 | 31-Jul-2022 | HASSAN | 220 | SHRLKP-SGS | SHIRALKOPPA_220 | 12:15 | 13:50 | 1:35 | LINE FAULT |
| 1753 | 31-Jul-2022 | HASSAN | 110 | SHRLKP-BARANG | SHIRALKOPPA_220 | 9:30 | 17:48 | 8:18 | LINE CLEAR AVAILED |
| 1754 | 31-Jul-2022 | HASSAN | 110 | SHRLKP-KITTADAHALLI | SHIRALKOPPA_220 | 12:08 | 12:19 | 0:11 | MAIN SUPPLY FAILURE |
| 1755 | 31-Jul-2022 | HASSAN | 110 | SHRLKP-SHIKARIPURA | SHIRALKOPPA_220 | 12:08 | 12:18 | 0:10 | MAIN SUPPLY FAILURE |
| 1756 | 31-Jul-2022 | HASSAN | 110 | SHRLKP-SHIRALKOPPA | SHIRALKOPPA_220 | 12:08 | 12:19 | 0:11 | MAIN SUPPLY FAILURE |
| 1757 | 31-Jul-2022 | HASSAN | 110 | SHRLKP-SORAB | SHIRALKOPPA_220 | 12:08 | 12:20 | 0:12 | MAIN SUPPLY FAILURE |
| 1758 | 31-Jul-2022 | HASSAN | 220 | VARAHI-SHMG3 | gen_varahi | 9:30 | 18:45 | 9:15 | NFBC ISSUED |
| 1759 | 31-Jul-2022 | HASSAN | 110 | ANAVATI-BARNGI | ANAVATTI_110 | 17:45 | 18:06 | 0:21 | HAND TRIPPED |
| 1760 | 31-Jul-2022 | HASSAN | 110 | HV1 | ARSIKERE_220 | 10:30 | 11:10 | 0:40 | LINE CLEAR AVAILED |
| 1761 | 31-Jul-2022 | HASSAN | 110 | BARANG-ANVATTI | BARANGI_110 | 17:45 | 18:06 | 0:21 | HAND TRIPPED |
| 1762 | 31-Jul-2022 | HASSAN | 110 | GAJNUR-SHIMOGA IC LINE | GAJNUR_110 | 9:07 | 19:10 | 10:03 | NFBC ISSUED |
| 1763 | 31-Jul-2022 | HASSAN | 110 | KONAJE-MANJESWARG | KONAJE_110 | 10:25 | 12:34 | 2:09 | NFBC ISSUED |
| 1764 | 31-Jul-2022 | HASSAN | 66 | CHIKKAK-DUDDA | CHIKKAKONDAGOLA_66 | 9:50 | 10:16 | 0:26 | MAIN SUPPLY FAILURE |
| 1765 | 31-Jul-2022 | HASSAN | 66 | HASSN22-UDDURKOPLU | HASSAN_220 | 9:49 | 10:13 | 0:24 | LINE FAULT |
| 1766 | 31-Jul-2022 | HASSAN | 66 | SAKALE-IPCL2 | SAKALESHPURA_66 | 16:16 | 16:37 | 0:21 | LINE FAULT |
| 1767 | 31-Jul-2022 | HASSAN | 66 | SAKALE-IPCL2 | SAKALESHPURA_66 | 17:20 | 17:48 | 0:28 | LINE FAULT |
| 1768 | 31-Jul-2022 | HASSAN | 66 | UDDURKO-SUZLON | UDDURKOPPLU_66 | 10:08 | 10:20 | 0:12 | HAND TRIPPED |
| 1769 | 31-Jul-2022 | HASSAN | 66 | UDDURKO-UDDUR | UDDURKOPPLU_66 | 9:49 | 10:17 | 0:28 | LINE FAULT |
| 1770 | 31-Jul-2022 | HASSAN | 66 | UDDURKO-NITTUR1 | UDDURKOPPLU_66 | 10:16 | 10:33 | 0:17 | HAND TRIPPED |
| 1771 | 31-Jul-2022 | HASSAN | 66 | UDDURKO-NITTUR2 | UDDURKOPPLU_66 | 9:49 | 12:24 | 2:35 | LINE FAULT |
| 1772 | 31-Jul-2022 | MYSURU | 66 | HV1 | BG PURA_66 | 7:29 | 8:15 | 0:46 | TRANSFORMER FAULT |
| 1773 | 31-Jul-2022 | MYSURU | 66 | CHANDRAVADI-KADAKOLA 2 | DOORA_66 HURA_66 HULLAHALLI_66 | 7:48 | 8:06 | 0:18 | LINE FAULT |
| 1774 | 31-Jul-2022 | MYSURU | 66 | DOORA-CHANDRAVADI | DOORA_66 HURA_66 HULLAHALLI_66 | 7:55 | 8:15 | 0:20 | LINE FAULT |
| 1775 | 31-Jul-2022 | MYSURU | 66 | G UKKADA-S R PATNA | NO STATIONS EFFECTED | 14:30 | 18:12 | 3:42 | LINE CLEAR AVAILED |
| 1776 | 31-Jul-2022 | MYSURU | 66 | HANNUR-AMPS SOLAR | NO STATIONS EFFECTED | 6:10 | 6:18 | 0:08 | LINE FAULT |
| 1777 | 31-Jul-2022 | MYSURU | 66 | HOOTAGALLI-BARC 1 | NO STATIONS EFFECTED | 15:44 | 15:53 | 0:09 | LINE FAULT |
| 1778 | 31-Jul-2022 | MYSURU | 66 | KOPPA-BESAGARAHALLI | BESAGARAHALLI_66 DUNDANAHALLI_66 | 2:45 | 2:52 | 0:07 | LINE FAULT |
| 1779 | 31-Jul-2022 | MYSURU | 66 | HV1 | KOPPA_66 | 12:56 | 13:01 | 0:05 | TRANSFORMER FAULT |
| 1780 | 31-Jul-2022 | MYSURU | 66 | SANTHESARAGUR-KADAKOLA 1 | ANTHARSANTHE_66 HDKOTE_66 YERALLI HAND POST_66 | 0:38 | 0:52 | 0:14 | LINE FAULT |
| 1781 | 31-Jul-2022 | MYSURU | 66 | SANTHESARAGUR-KADAKOLA 2 | NO STATIONS EFFECTED | 0:38 | 0:52 | 0:14 | LINE FAULT |
| 1782 | 31-Jul-2022 | MYSURU | 66 | SFC SIVA-HEBBANI 6 | NO STATIONS EFFECTED | 18:46 | 19:11 | 0:24 | LINE FAULT |
| 1783 | 31-Jul-2022 | MYSURU | 66 | SFC SIVA-HEBBANI 7 | NO STATIONS EFFECTED | 18:46 | 19:11 | 0:25 | LINE FAULT |
| 1784 | 31-Jul-2022 | MYSURU | 66 | SFC SIVA-PGL | NO STATIONS EFFECTED | 18:47 | 18:58 | 0:10 | LINE FAULT |
| 1785 | 31-Jul-2022 | MYSURU | 66 | HV1 | GUNDLUPETE_66 | 17:02(12.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1786 | 31-Jul-2022 | MYSURU | 220 | HV2 | MADHUVANAHALLI_220 | 18:57:18 (31.5.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1787 | 31-Jul-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 18:26 (22/04/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1788 | 31-Jul-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16(08/12/2021) | | | LINE OPEN , LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--|---|-----------------------|-----------|----------|-------------------------------------|
| 1789 | 31-Jul-2022 | MYSURU | 220 | HV1 | KADAKOLA_220 | 1:41:14 (21/07/2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1790 | 31-Jul-2022 | TUMKUR | 220 | DAVANGERE SRS- SHIMOGA 2 | DAVANGERE_SRS_220 | 14:20(27.07.2022) | | | LINE OPEN, LINE FAULT |
| 1791 | 31-Jul-2022 | TUMKUR | 220 | KB CROSS 220kV- NELAMANGALA(ANTHARASANAHA LLI) | KBCROSS_220 | 2:00 | 6:09 | 4:09 | LINE FAULT |
| 1792 | 31-Jul-2022 | TUMKUR | 110 | KB CROSS 220kV- MAYASANDRA | MAYASANDRA_110,KADEHALLI_110 | 2:00 | 2:35 | 0:35 | LINE FAULT |
| 1793 | 31-Jul-2022 | TUMKUR | 110 | KATRIKEHAL-THIMMANAHALLI | KATRIKEHAL_110 | 2:00 | 2:30 | 0:30 | MAIN SUPPLY FAILURE |
| 1794 | 31-Jul-2022 | TUMKUR | 110 | KATRIKEHAL-THIMMANAHALLI | KATRIKEHAL_110 | 7:05 | 7:50 | 0:45 | MAIN SUPPLY FAILURE |
| 1795 | 31-Jul-2022 | TUMKUR | 66 | TR-1 | CHALLAKERE_66 | 1:35 | 1:45 | 0:10 | TRANSFORMER FAULT |
| 1796 | 31-Jul-2022 | TUMKUR | 66 | CHITRADURGA 220kV- PANDARAHALLI 2 | PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66 | 11:01 | 11:08 | 0:06 | LINE FAULT |
| 1797 | 31-Jul-2022 | TUMKUR | 66 | CHITRADURGA 220kV- PANDARAHALLI 1 | HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66 | 11:02 | 11:09 | 0:07 | LINE FAULT |
| 1798 | 31-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- KUKKAWADA | KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66 | 11:40 | 18:32 | 6:52 | LINE CLEAR AVAILED |
| 1799 | 31-Jul-2022 | TUMKUR | 66 | GUTUR 66-DAVANGERE SRS-1 | GUTUR_66 | 15:42 | 16:55 | 1:13 | LINE CLEAR AVAILED |
| 1800 | 31-Jul-2022 | TUMKUR | 66 | TR-1 & 2 | GUTUR_66 | 15:42 | 16:55 | 1:13 | LINE CLEAR AVAILED |
| 1801 | 31-Jul-2022 | TUMKUR | 66 | GUTTUR220-HALASABALU | HALASABALU_66 | 13:32 | 15:11 | 1:39 | LINE FAULT |
| 1802 | 31-Jul-2022 | TUMKUR | 66 | GUTTUR220-HALASABALU | HALASABALU_66 | 15:11 | 16:42 | 1:31 | NFBC ISSUED |
| 1803 | 31-Jul-2022 | TUMKUR | 66 | HANAGAL-GUDEKOTE(THALLAK) | HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66 | 5:32 | 5:44 | 0:11 | LINE FAULT |
| 1804 | 31-Jul-2022 | TUMKUR | 66 | HONNALLI-HONNALLI | HONNALLI_66, KATTIGE_66 | 9:35 | 9:48 | 0:13 | LINE FAULT |
| 1805 | 31-Jul-2022 | TUMKUR | 66 | KUKKAWADA -HONNALLI | KUKKAWADA_66 | 10:20 | 18:39 | 8:18 | LINE CLEAR AVAILED |
| 1806 | 31-Jul-2022 | TUMKUR | 66 | KUKKAWADA- SRS DAVANGERE | KUKKAWADA_66 | 10:51 | 18:39 | 7:47 | LINE CLEAR AVAILED |
| 1807 | 31-Jul-2022 | TUMKUR | 66 | LINGADHALLI-CHANNAGIRI (NALLUR) | LINGADAHALLI_66 | 10:20 | 10:50 | 0:30 | HAND TRIPPED |
| 1808 | 31-Jul-2022 | TUMKUR | 66 | TR-1 | LOKIKERE_66 | 10:20 | 10:40 | 0:20 | MAIN SUPPLY FAILURE |
| 1809 | 31-Jul-2022 | TUMKUR | 66 | TR-1 | LOKIKERE_66 | 11:00 | 11:50 | 0:50 | MAIN SUPPLY FAILURE |
| 1810 | 31-Jul-2022 | TUMKUR | 66 | TR-2 | MALEBENNUR_66 | 11:16 | 11:28 | 0:12 | TRANSFORMER FAULT |
| 1811 | 31-Jul-2022 | TUMKUR | 66 | MAYAKONDA- DAVANAGERE SRS 220KV | MAYAKONDA_66 | 11:00 | 11:10 | 0:10 | MAIN SUPPLY FAILURE |
| 1812 | 31-Jul-2022 | TUMKUR | 66 | NIDASALE 66 - DUNDANAHALLI 66 | DUNDANAHALLI_66 | 9:19 | 12:53 | 3:34 | LINE CLEAR AVAILED |
| 1813 | 31-Jul-2022 | TUMKUR | 66 | PDKOTE-CLEAR SOLAR | CLEAR SOLAR | 15:15 | 15:20 | 0:04 | HAND TRIPPED |
| 1814 | 31-Jul-2022 | TUMKUR | 66 | TR-2 | RENGANATHAPURA_66 | 17:25 | 17:42 | 0:16 | HAND TRIPPED |
| 1815 | 31-Jul-2022 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR1 & 2 | WELSPUNSOLAR1 & 2_IPP_66 | 8:40 | 8:54 | 0:14 | LINE FAULT |
| 1816 | 31-Jul-2022 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR1 & 2 | WELSPUNSOLAR1 & 2_IPP_66 | 16:03 | 16:14 | 0:11 | LINE FAULT |
| 1817 | 31-Jul-2022 | TUMKUR | 66 | THALLAK 220kV - BGKERE 1 | BGKERE_66 | 5:30 | 5:35 | 0:05 | LINE FAULT |
| 1818 | 31-Jul-2022 | TUMKUR | 66 | THALLAK 220kV - BGKERE 2 | BGKERE_66 | 5:30 | 5:41 | 0:11 | LINE FAULT |
| 1819 | 1-Aug-2022 | BAGALKOT | 220 | SIRSI-HUBLI-1 | STATION NOT AFFECTED SIRSI_220 | 19:46 (15.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1820 | 1-Aug-2022 | BAGALKOT | 220 | SIRSI-HUBLI-2 | STATION NOT AFFECTED SIRSI_220 | 19:46 (15.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1821 | 1-Aug-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED TODALBAGI_110 | 19:13 (17.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1822 | 1-Aug-2022 | BAGALKOT | 110 | TODALBAGI-SAVALAGI | STATION NOT AFFECTED TODALBAGI_110 | 18:00 (20.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|----------|---------|----------------------------------|--|-----------------------|-----------|----------|-------------------------------------|
| 1823 | 1-Aug-2022 | BAGALKOT | 110 | UTTUR - F1 JAMB CB(MUDHOL) | STATION NOT AFFECTED UTTUR_110 | 9:51 (24.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1824 | 1-Aug-2022 | BAGALKOT | 110 | 110/11KV, HV3 | STATION NOT AFFECTED BILAGI_110 | 7:28 (29.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1825 | 1-Aug-2022 | BAGALKOT | 110 | BELLATTI-ENERCON2& AB SOLAR | BELLATTI_110 | 4:42 | 5:08 | 0:26 | HAND TRIPPED |
| 1826 | 1-Aug-2022 | BAGALKOT | 110 | BELLATTI-ENERCON2 | BELLATTI_110 | 14:51 | 15:28 | 0:37 | LINE CLEAR AVAILED |
| 1827 | 1-Aug-2022 | BAGALKOT | 110 | LAXMESHWAR-BELLATTI_110 | BELLATTI_110 | 21:42 | 22:01 | 0:19 | LINE FAULT |
| 1828 | 1-Aug-2022 | BAGALKOT | 110 | BELLATTI-ENERCON2& AB SOLAR | BELLATTI_110 | 21:45 | 22:11 | 0:26 | HAND TRIPPED |
| 1829 | 1-Aug-2022 | BAGALKOT | 110 | BIDNAL-ANNIGERI | ANNIGER_110 | 6:27 | 11:50 | 5:23 | LINE FAULT |
| 1830 | 1-Aug-2022 | BAGALKOT | 110 | GHATAPRABHA220-GHATAPRABHA | GHATAPRABHA_110 | 15:33 | 16:40 | 1:07 | LINE CLEAR AVAILED |
| 1831 | 1-Aug-2022 | BAGALKOT | 110 | 110/11KV,HV1 | HIEMASALI_110 | 8:11 | 8:17 | 0:06 | TRANSFORMER FAULT |
| 1832 | 1-Aug-2022 | BAGALKOT | 110 | HUNGUND -KUDALSANGAM | KUDALSANGAM_110 | 6:37 | 6:45 | 0:08 | LINE FAULT |
| 1833 | 1-Aug-2022 | BAGALKOT | 110 | KALAGHATGI-AB SOLAR | KALAGHATGI_110 | 17:06 | 17:07 | 0:01 | HAND TRIPPED |
| 1834 | 1-Aug-2022 | BAGALKOT | 110 | KULAGERI CROSS-KERUR | KULAGER CROSS_110 | 11:43 | 14:24 | 2:41 | LINE CLEAR AVAILED |
| 1835 | 1-Aug-2022 | BAGALKOT | 110 | LAXMESHWAR-BELLATTI_110 | BELLATTI_110 | 4:37 | 5:00 | 0:23 | LINE FAULT |
| 1836 | 1-Aug-2022 | BAGALKOT | 110 | LAXMESHWAR-BELLATTI_110 | BELLATTI_110 | 21:43 | 21:59 | 0:16 | LINE FAULT |
| 1837 | 1-Aug-2022 | BAGALKOT | 220 | AMBEWADI-NAGZARI-2 | STATION NOT AFFECTED AMBEWADI_220 | 14:50 | 19:47 | 4:57 | LINE FAULT |
| 1838 | 1-Aug-2022 | BAGALKOT | 110 | 110 KV BORGAON | 110 KV SADALAGA | 12:00 | 14:00 | 2:00 | LINE CLEAR AVAILED |
| 1839 | 1-Aug-2022 | BAGALKOT | 220 | 220/110KV, HV-3 | STATION NOT AFFECTED BAGALKOT_220 | 12:16 | 13:49 | 1:33 | LINE CLEAR AVAILED |
| 1840 | 1-Aug-2022 | BAGALKOT | 110 | 220/110KV, LV-3 | STATION NOT AFFECTED BAGALKOT_220 | 12:15 | 13:50 | 1:35 | LINE CLEAR AVAILED |
| 1841 | 1-Aug-2022 | BAGALKOT | 110 | GADAG220-DAMBAL1 (SAMBAPUR) | SAMBAPUR_110 | 10:02 | 12:53 | 2:51 | LINE CLEAR AVAILED |
| 1842 | 1-Aug-2022 | BAGALKOT | 110 | GHATAPRABHA220-GHATAPRABHA-1 | GHATAPRABHA_110 | 12:22 | 15:27 | 3:05 | LINE CLEAR AVAILED |
| 1843 | 1-Aug-2022 | BAGALKOT | 110 | 110/33KV,HV2 | HUBLI_220 | 16:39 | 17:41 | 1:02 | LINE CLEAR AVAILED |
| 1844 | 1-Aug-2022 | BAGALKOT | 220 | NARENDRA220-KNBRG1 (BELAGAVI 1) | NARENDRA_220 | 11:27 (01.08.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1845 | 1-Aug-2022 | BAGALKOT | 220 | HUBLI-NAGAZARI-3 | STATION NOT AFFECTED HUBLI_220 | 9:23 | 16:18 | 6:55 | LINE CLEAR AVAILED |
| 1846 | 1-Aug-2022 | BAGALKOT | 220 | HUBLI-NAGAZARI-1 | STATION NOT AFFECTED HUBLI_220 | 12:03 | 12:23 | 0:20 | LINE CLEAR AVAILED |
| 1847 | 1-Aug-2022 | BAGALKOT | 220 | HUBLI-NAGAZARI-2 | STATION NOT AFFECTED HUBLI_220 | 12:04 | 12:23 | 0:19 | LINE CLEAR AVAILED |
| 1848 | 1-Aug-2022 | BAGALKOT | 110 | RANEENNUR220-HIREKERUR | HIREKERUR_110 | 2:15 | 2:20 | 0:05 | LINE FAULT |
| 1849 | 1-Aug-2022 | BAGALKOT | 110 | HAVERI220-TILAVALLI (HANAGAL) | HANAGAL_110 | 6:08 | 6:26 | 0:18 | LINE FAULT |
| 1850 | 1-Aug-2022 | BAGALKOT | 110 | HAVERI220-TILAVALLI (HANAGAL) | HANAGAL_110 | 12:38 | 13:02 | 0:24 | LINE CLEAR AVAILED |
| 1851 | 1-Aug-2022 | BAGALKOT | 110 | 110/33KV, HV3 | STATION NOT AFFECTED YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1852 | 1-Aug-2022 | BAGALKOT | 220 | 220/110KV, HV1 | STATION NOT AFFECTED AMBEWADI_220 | 20:00 (09.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1853 | 1-Aug-2022 | BAGALKOT | 220 | 220/110KV, HV-3 & LV3 | STATION NOT AFFECTED ATHANI_220 | 10:26 (25.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1854 | 1-Aug-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED AEQUS_220 | 21:09 (30.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1855 | 1-Aug-2022 | BAGALKOT | 220 | AMBEWADI-NAGZARI-1 | STATION NOT AFFECTED AMBEWADI_220 | 14:50 | 19:29 | 4:39 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|-----------|---------|---|---|---------|-----------|----------|---------------------|
| 1856 | 1-Aug-2022 | BAGALKOT | 110 | 110/11KV, HV1 & HV2 | SINGATALUR_110 | 12:20 | 13:00 | 0:40 | MAIN SUPPLY FAILURE |
| 1857 | 1-Aug-2022 | BAGALKOT | 110 | MUNDARGI-BIDANL LIS | BIDNAL LIS_110 STATION NOT AFFECTED MUNDARGI_110 | 12:25 | 13:30 | 1:05 | LINE CLEAR AVAILED |
| 1858 | 1-Aug-2022 | BAGALKOT | 110 | MUNDARAGI-SINGATALUR | SINGATALUR_110 | 12:20 | 13:00 | 0:40 | LINE CLEAR AVAILED |
| 1859 | 1-Aug-2022 | BAGALKOT | 110 | INDI220-DEVARHIPARGI | DEVARAHIPPARGI_110 | 8:30 | 8:35 | 0:05 | LINE FAULT |
| 1860 | 1-Aug-2022 | BAGALKOT | 110 | INDI220-LACHYAN | LACHYAN_110 HIREBEVNUR_110 ROODAGI_110 DULKHED_110 | 8:30 | 8:35 | 0:05 | LINE FAULT |
| 1861 | 1-Aug-2022 | BAGALKOT | 110 | INDI220-LACHYAN | LACHYAN_110 HIREBEVNUR_110 ROODAGI_110 DULKHED_110 | 15:01 | 15:06 | 0:05 | LINE FAULT |
| 1862 | 1-Aug-2022 | BENGALURU | 66 | HV1 | ALLIMARADANAHALLI | 7:50 | 8:22 | 0:32 | LINE CLEAR AVAILED |
| 1863 | 1-Aug-2022 | BENGALURU | 66 | EXORA - CESSNA | EXORA | 7:08 | 7:18 | 0:10 | MAIN SUPPLY FAILURE |
| 1864 | 1-Aug-2022 | BENGALURU | 66 | HANUMANTHNAGARA - KANAKAPURA 220 | HANUMANTHNAGARA | 13:45 | 13:50 | 0:05 | LOAD CHANGE OVER |
| 1865 | 1-Aug-2022 | BENGALURU | 66 | HENNUR CROSS - HBR LAYOUT 220 | HENNUR CROSS | 21:47 | 22:05 | 0:18 | MAIN SUPPLY FAILURE |
| 1866 | 1-Aug-2022 | BENGALURU | 66 | HENNUR CROSS - VIDYANAGARA | HENNUR CROSS | 23:36 | 23:39 | 0:03 | LOAD CHANGE OVER |
| 1867 | 1-Aug-2022 | BENGALURU | 66 | HOODY 220 - GRAPHITE INDIA (EHT) | GRAPHITE INDIA (EHT) | 9:33 | 15:28 | 5:55 | LINE CLEAR AVAILED |
| 1868 | 1-Aug-2022 | BENGALURU | 220 | HOODY 220 - HBR LAYOUT 220 | HBR LAYOUT 220, MANYATHA TECH PARK 220 | 21:47 | 22:10 | 0:23 | LINE FAULT |
| 1869 | 1-Aug-2022 | BENGALURU | 66 | HBR LAYOUT 220 - HBR LAYOUT 66 | HBR LAYOUT 66 | 21:47 | 22:14 | 0:27 | MAIN SUPPLY FAILURE |
| 1870 | 1-Aug-2022 | BENGALURU | 66 | HV3 | MANYATHA TECH PARK 220 | 21:47 | 22:07 | 0:20 | MAIN SUPPLY FAILURE |
| 1871 | 1-Aug-2022 | BENGALURU | 66 | MANYATHA TECH PARK 220 - SHOBHA CITY | SHOBHA CITY | 21:47 | 22:07 | 0:20 | MAIN SUPPLY FAILURE |
| 1872 | 1-Aug-2022 | BENGALURU | 66 | KODIGEHALLI - SRS PEENYA 220 | KODIGEHALLI | 9:16 | 9:22 | 0:06 | LOAD CHANGE OVER |
| 1873 | 1-Aug-2022 | BENGALURU | 66 | MATHIKERE - HEBBALA 220 | MATHIKERE | 0:05 | 4:30 | 4:25 | LINE CLEAR AVAILED |
| 1874 | 1-Aug-2022 | BENGALURU | 66 | NANDINI LAYOUT - SRS PEENYA 220 | NANDINI LAYOUT | 2:24 | 3:07 | 0:43 | LINE FAULT |
| 1875 | 1-Aug-2022 | BENGALURU | 66 | NANDINI LAYOUT - NRS 220 | NANDINI LAYOUT | 15:25 | 15:31 | 0:06 | LOAD CHANGE OVER |
| 1876 | 1-Aug-2022 | BENGALURU | 66 | HV1 | NIMHANS 220 | 10:33 | 10:36 | 0:03 | LINE CLEAR AVAILED |
| 1877 | 1-Aug-2022 | BENGALURU | 66 | RMV - HEBBALA 220 | RMV, TATA INSTITUTE (EHT) | 8:37 | 8:41 | 0:04 | LOAD CHANGE OVER |
| 1878 | 1-Aug-2022 | BENGALURU | 220 | HV3 | SRS PEENYA 220 | 16:21 | 17:38 | 1:17 | TRANSFORMER FAULT |
| 1879 | 1-Aug-2022 | BENGALURU | 66 | T GOLLAHALI 220 - AVANI | AVANI, MULBAGAL | 6:16 | 6:38 | 0:22 | LINE FAULT |
| 1880 | 1-Aug-2022 | BENGALURU | 66 | T GOLLAHALI 220 - AVANI | AVANI, MULBAGAL | 15:10 | 15:52 | 0:42 | LINE CLEAR AVAILED |
| 1881 | 1-Aug-2022 | BENGALURU | 66 | T GOLLAHALI 220 - NANGLI | NANGLI, BAIRKURU | 22:16 | 22:29 | 0:13 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|-----------|---------|-------------------------------|---|---------|-----------|----------|---------------------|
| 1882 | 1-Aug-2022 | BENGALURU | 66 | LR BANDE - HBR LAYOUT 220 | LR BANDE | 21:47 | 22:08 | 0:21 | MAIN SUPPLY FAILURE |
| 1883 | 1-Aug-2022 | BENGALURU | 66 | HV2 | MELLAHALLI | 1:33 | 1:57 | 0:24 | TRANSFORMER FAULT |
| 1884 | 1-Aug-2022 | BENGALURU | 66 | HV1 | VIJAYANAGARA | 6:41 | 6:51 | 0:10 | LOAD CHANGE OVER |
| 1885 | 1-Aug-2022 | BENGALURU | 66 | HV2 | VIJAYANAGARA | 6:41 | 6:51 | 0:10 | LOAD CHANGE OVER |
| 1886 | 1-Aug-2022 | BENGALURU | 66 | ATTIBELE - ANEKAL | ATTIBELE | 9:25 | 9:30 | 0:05 | LOAD CHANGE OVER |
| 1887 | 1-Aug-2022 | BENGALURU | 66 | HV1 | BAGEPALLI | 19:00 | 19:10 | 0:10 | TRANSFORMER FAULT |
| 1888 | 1-Aug-2022 | BENGALURU | 66 | CHELUR - SOMANATHPURA | CHELUR | 23:10 | 23:50 | 0:40 | LINE FAULT |
| 1889 | 1-Aug-2022 | BENGALURU | 66 | CHELUR - SOMANATHPURA | CHELUR | 23:55 | 23:59 | 0:04 | LINE FAULT |
| 1890 | 1-Aug-2022 | BENGALURU | 66 | CHINTAMANI 220 - GANJIGUNTE 1 | GANJIGUNTE, PALLICHERLU | 5:26 | 5:38 | 0:12 | LINE FAULT |
| 1891 | 1-Aug-2022 | BENGALURU | 66 | CHINTAMANI 220 - GANJIGUNTE 2 | GANJIGUNTE, PALLICHERLU | 5:26 | 5:38 | 0:12 | LINE FAULT |
| 1892 | 1-Aug-2022 | BENGALURU | 66 | CHINTAMANI 220 - GANJIGUNTE 1 | GANJIGUNTE, PALLICHERLU | 21:38 | 21:51 | 0:13 | LINE FAULT |
| 1893 | 1-Aug-2022 | BENGALURU | 66 | CHINTAMANI 220 - GANJIGUNTE 2 | GANJIGUNTE, PALLICHERLU | 21:38 | 21:51 | 0:13 | LINE FAULT |
| 1894 | 1-Aug-2022 | BENGALURU | 66 | CHINTAMANI 220 - IRGAMPALLI | IRAGAMPALLI, M GOLLAHALLI, BURUDAGUNTE | 22:10 | 22:23 | 0:13 | LINE FAULT |
| 1895 | 1-Aug-2022 | BENGALURU | 66 | CHINTAMANI 220 - LAKSHMIPURA | TADIGOLU CROSS, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU | 21:09 | 21:25 | 0:16 | LINE FAULT |
| 1896 | 1-Aug-2022 | BENGALURU | 66 | CHINTAMANI 220 - TALAGAWARA | TALAGAWARA, Y HUNSENHALLI, CHEEMANGALA | 21:14 | 21:27 | 0:13 | LINE FAULT |
| 1897 | 1-Aug-2022 | BENGALURU | 66 | DABUSPET 220 - NELAMANGALA 66 | NELAMANGALA 66 | 22:15 | 22:42 | 0:27 | LINE FAULT |
| 1898 | 1-Aug-2022 | BENGALURU | 66 | DABUSPET 220 - TYAMAGONDALU | TYAMAGONDALU, T BEGUR | 22:15 | 22:42 | 0:27 | LINE FAULT |
| 1899 | 1-Aug-2022 | BENGALURU | 66 | DABUSPET 220 - TYAMAGONDALU | TYAMAGONDALU, T BEGUR | 22:32 | 23:59 | 1:27 | LINE FAULT |
| 1900 | 1-Aug-2022 | BENGALURU | 66 | HV1 | GUNDAMGERE | 17:15 | 17:25 | 0:10 | TRANSFORMER FAULT |
| 1901 | 1-Aug-2022 | BENGALURU | 66 | GUNDAMGERE - GOWRIBIDANUR 220 | GUNDAMGERE | 17:15 | 17:25 | 0:10 | LINE FAULT |
| 1902 | 1-Aug-2022 | BENGALURU | 66 | HV2 | IRAGAMPALLI | 21:30 | 21:45 | 0:15 | TRANSFORMER FAULT |
| 1903 | 1-Aug-2022 | BENGALURU | 66 | HV1 | KOLAR 220 | 23:27 | 23:45 | 0:18 | LINE CLEAR AVAILED |
| 1904 | 1-Aug-2022 | BENGALURU | 66 | HV1 | KOLAR 220 | 23:49 | 23:59 | 0:10 | TRANSFORMER FAULT |
| 1905 | 1-Aug-2022 | BENGALURU | 66 | HOSKOTE 220 - HOSKOTE 2(DG3) | KONDASPURA | 5:23 | 5:48 | 0:25 | LINE FAULT |
| 1906 | 1-Aug-2022 | BENGALURU | 66 | HOSKOTE 220 - HOSKOTE 2(DG3) | KONDASPURA | 20:55 | 21:21 | 0:26 | LINE FAULT |
| 1907 | 1-Aug-2022 | BENGALURU | 66 | HOSKOTE 220 - HOSKOTE 2(DG3) | NO STATION AFFECTED | 22:05 | 23:59 | 1:54 | LINE FAULT |
| 1908 | 1-Aug-2022 | BENGALURU | 66 | HV1 | KEMBODI | 13:51 | 14:13 | 0:22 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|-----------|---------|--|---|-----------------------|-----------|----------|-------------------------------------|
| 1909 | 1-Aug-2022 | BENGALURU | 66 | KONDASPURA - EPIP 220 | KONDASPURA | 7:18 | 7:21 | 0:03 | LOAD CHANGE OVER |
| 1910 | 1-Aug-2022 | BENGALURU | 66 | MITTEMARI 220 - SOMANATHPURA | SOMANATHPURA, CHAKAVELU, CHELUR | 7:53 | 8:03 | 0:10 | LINE FAULT |
| 1911 | 1-Aug-2022 | BENGALURU | 66 | MITTEMARI 220 - SOMANATHPURA | SOMANATHPURA, CHAKAVELU, CHELUR | 23:54 | 23:59 | 0:05 | LINE FAULT |
| 1912 | 1-Aug-2022 | BENGALURU | 66 | NELAMANGALA 66 - DABUSPETE 220 | NELAMANGALA 66 | 22:15 | 22:40 | 0:25 | LINE FAULT |
| 1913 | 1-Aug-2022 | BENGALURU | 66 | HV2 | SARJAPURA 220 | 18:18 | 18:40 | 0:22 | TRANSFORMER FAULT |
| 1914 | 1-Aug-2022 | BENGALURU | 66 | HV1 | S M MANGALA | 21:01 | 22:22 | 1:21 | TRANSFORMER FAULT |
| 1915 | 1-Aug-2022 | BENGALURU | 66 | HV2 | VOLVO | 12:24 | 12:26 | 0:02 | TRANSFORMER FAULT |
| 1916 | 1-Aug-2022 | BENGALURU | 66 | HV1 | SOMANAHALLI 220 | 23:53 | 23:59 | 0:06 | TRANSFORMER FAULT |
| 1917 | 1-Aug-2022 | BENGALURU | 66 | MAGADI 66kV | MAGADI 220kV | 6:31 | 6:47 | 0:16 | LINE FAULT |
| 1918 | 1-Aug-2022 | BENGALURU | 66 | HV1 | MAGADI 220kV | 13:45 | 14:35 | 0:50 | LINE CLEAR AVAILED |
| 1919 | 1-Aug-2022 | BENGALURU | 66 | HV1 | GANJIGUNTE | 1:20 | 1:25 | 0:05 | TRANSFORMER FAULT |
| 1920 | 1-Aug-2022 | BENGALURU | 66 | HV2 | KODIHALLI HAROBELE | 14:02 | 14:58 | 0:56 | LINE CLEAR AVAILED |
| 1921 | 1-Aug-2022 | BENGALURU | 66 | CHELUR - SOMANATHPURA | CHELUR | 23:55:00(01/08/2022) | | | LINE OPEN, LINE FAULT |
| 1922 | 1-Aug-2022 | BENGALURU | 66 | DABUSPET 220 - TYAMAGONDALU | TYAMAGONDALU, T BEGUR | 22:32(01/08/2022) | | | LINE OPEN, LINE FAULT |
| 1923 | 1-Aug-2022 | BENGALURU | 66 | HV1 | KOLAR 220 | 23:49:00(01/08/2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1924 | 1-Aug-2022 | BENGALURU | 66 | MITTEMARI 220 - SOMANATHPURA | SOMANATHPURA, CHAKAVELU, CHELUR | 23:54:00(01/08/2022) | | | LINE OPEN, LINE FAULT |
| 1925 | 1-Aug-2022 | BENGALURU | 66 | HV1 | SOMANAHALLI 220 | 23:53(01/08/2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1926 | 1-Aug-2022 | BENGALURU | 66 | HOSKOTE 220 - HOSKOTE 2(DG3) | NO STATION AFFECTED | 22:05(01/08/2022) | | | LINE OPEN, LINE FAULT |
| 1927 | 1-Aug-2022 | BENGALURU | 220 | EAST DIVISION COMPOUND 220 - A STATION 220 | NO STATION AFFECTED | 08:38:00(23/07/2022) | | | LINE OPEN, LINE FAULT |
| 1928 | 1-Aug-2022 | GULBARGA | 110 | LINGASUGUR-CHAYADEVI_IPP | LINGASUGUR_220 | 9:32 | 9:44 | 0:12 | LINE FAULT |
| 1929 | 1-Aug-2022 | GULBARGA | 110 | SHAHAPUR-KHANAPUR | KHANAPUR_110,WADAGERA_110,SANNATHI_IPP | 0:58 | 1:05 | 0:07 | LINE FAULT |
| 1930 | 1-Aug-2022 | GULBARGA | 110 | SHAHAPUR-KHANAPUR | KHANAPUR_110,WADAGERA_110,SANNATHI_IPP | 14:06 | 18:57 | 4:51 | LINE CLEAR AVAILED |
| 1931 | 1-Aug-2022 | GULBARGA | 110 | SHAHAPUR-SHAHAPUR1 | SHAHAPUR_110 | 17:10 | 18:39 | 1:29 | LINE CLEAR AVAILED |
| 1932 | 1-Aug-2022 | GULBARGA | 110 | SHAHABAD-CHITTAPUR | CHITTAPUR_110,KORAWAR TEMPLE_110 | 10:45 | 15:49 | 5:04 | LINE CLEAR AVAILED |
| 1933 | 1-Aug-2022 | GULBARGA | 110 | SHAHABAD- GULBARGA UNIVERCITY1&2 | GULBARGA SOUTH_110,FARATHABAD_110,NANDUR_110,G ULBARGA UNIVERCITY_110 | 12:45 | 12:58 | 0:13 | LINE FAULT |
| 1934 | 1-Aug-2022 | GULBARGA | 110 | SHAHABAD-BAGEWADI2 | YADRAMI_110,MORATAGI_110 | 16:10 | 16:58 | 0:48 | LINE CLEAR AVAILED |
| 1935 | 1-Aug-2022 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 16:10 | 16:35 | 0:25 | LINE CLEAR AVAILED |
| 1936 | 1-Aug-2022 | GULBARGA | 110 | SHAHABAD-FARTHABAD | FARTHABAD_110,GULBARGA SOUTH_110 | 16:10 | 16:58 | 0:48 | LINE CLEAR AVAILED |
| 1937 | 1-Aug-2022 | GULBARGA | 110 | SHAHABAD-WADI | WADI_110 | 16:10 | 16:58 | 0:48 | LINE CLEAR AVAILED |
| 1938 | 1-Aug-2022 | GULBARGA | 110 | HALBARGA-SANTAPUR | SANTAPUR_110,DONGARGOAN_110,DIGGI_110 | 1:05 | 1:14 | 0:09 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|----------|---------|------------------------|--|-------------------|--------------------|----------|-------------------------------------|
| 1939 | 1-Aug-2022 | GULBARGA | 110 | HALBARGA-ACMESOLAR_IPP | HALBARGA_220 | 18:50 | 20:03 | 1:13 | LINE CLEAR AVAILED |
| 1940 | 1-Aug-2022 | GULBARGA | 110 | RAICHUR-SHAHAPUR1 | GABBUR_110 | 20:46 | 20:50 | 0:04 | LINE FAULT |
| 1941 | 1-Aug-2022 | GULBARGA | 110 | RAICHUR-SHAHAPUR2 | GOOGLE_110 | 21:50 | 21:58 | 0:08 | LINE FAULT |
| 1942 | 1-Aug-2022 | GULBARGA | 66 | HV1,HV2 | HARAPANAHALLI_66 | 11:30 | 11:45 | 0:15 | TRANSFORMER FAULT |
| 1943 | 1-Aug-2022 | GULBARGA | 66 | HV1 | HARAPANAHALLI_66 | 11:55 | 15:50 | 3:55 | LINE CLEAR AVAILED |
| 1944 | 1-Aug-2022 | GULBARGA | 66 | HV2 | HARAPANAHALLI_66 | 16:45 | 16:55 | 0:10 | TRANSFORMER FAULT |
| 1945 | 1-Aug-2022 | GULBARGA | 66 | HV1 | CHORNOOR_66 | 15:00 | 16:10 | 1:10 | LINE CLEAR AVAILED |
| 1946 | 1-Aug-2022 | GULBARGA | 66 | HV2 | PUNABGATTA_66 | 13:10 | 16:30 | 3:20 | LINE CLEAR AVAILED |
| 1947 | 1-Aug-2022 | GULBARGA | 66 | PUNABGHATA-NEELAGUNDA | PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJAINI_66 | 11:25 | 11:30 | 0:05 | LINE FAULT |
| 1948 | 1-Aug-2022 | GULBARGA | 66 | TELAGI-YARAGUNTA | YARAGUNTA_66 | 16:00 | 16:10 | 0:10 | LINE FAULT |
| 1949 | 1-Aug-2022 | GULBARGA | 66 | ITTAGI-HIREHADAGALI_2 | HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66, SOVENHALLI_66, TUNGA BHADRA_IPP | 6:44 | 6:54 | 0:10 | LINE FAULT |
| 1950 | 1-Aug-2022 | GULBARGA | 66 | ITTAGI-HIREHADAGALI_2 | HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66, SOVENHALLI_66, TUNGA BHADRA_IPP | 19:24 | 19:39 | 0:15 | LINE FAULT |
| 1951 | 1-Aug-2022 | GULBARGA | 66 | MUNIRABAD-MHD | VENKATAPURA_66,RRRSTEELS_IPP, UPHALLI_66, HPHALLI_66 | 6:04 | 6:13 | 0:09 | LINE FAULT |
| 1952 | 1-Aug-2022 | HASSAN | 220 | CRPATNA-HSN400 | CRPATNA_220 | 13:34(15.07.2022) | | | LINE OPEN, LINE FAULT |
| 1953 | 1-Aug-2022 | HASSAN | 400 | UPCL-HASSAN2 | gen_upcl | 2:00 (31.07.2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 1954 | 1-Aug-2022 | HASSAN | 110 | HV1 | SINGATGERER_110 | 1:33(31.07.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 1955 | 1-Aug-2022 | HASSAN | 110 | HV2 | KARAYA_110 | 6:55(31.07.2022) | 17:54(001.08.2022) | 34:59HRS | TRANSFORMER CHARGED |
| 1956 | 1-Aug-2022 | HASSAN | 220 | HGUNJE-VARAHI | HEGGUNJE_220 | 10:54 | 14:30 | 3:36 | LINE CLEAR AVAILED |
| 1957 | 1-Aug-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY1 | MRSMSG_220 | 10:50 | 17:24 | 6:34 | LINE CLEAR AVAILED |
| 1958 | 1-Aug-2022 | HASSAN | 110 | MRSSHM-MPM | MRSMSG_220 | 13:27 | 16:14 | 2:47 | LINE FAULT |
| 1959 | 1-Aug-2022 | HASSAN | 220 | HV2 | MSEZ_220 | 10:14 | 16:55 | 6:41 | LINE CLEAR AVAILED |
| 1960 | 1-Aug-2022 | HASSAN | 110 | LV1 | MSEZ_220 | 10:14 | 16:55 | 6:41 | LINE CLEAR AVAILED |
| 1961 | 1-Aug-2022 | HASSAN | 220 | SHRAVTY-SHIMOGA1 | sharavathy_gen | 10:50 | 17:24 | 6:34 | LINE CLEAR AVAILED |
| 1962 | 1-Aug-2022 | HASSAN | 220 | VARAHI-KEMAR3 | varahi_gen | 10:54 | 14:30 | 3:36 | NFBC ISSUED |
| 1963 | 1-Aug-2022 | HASSAN | 110 | HV2 | ANAVATTI_110 | 16:08 | 16:53 | 0:45 | TRANSFORMER FAULT |
| 1964 | 1-Aug-2022 | HASSAN | 110 | HV2 | ANAVATTI_110 | 18:00 | 18:32 | 0:32 | TRANSFORMER FAULT |
| 1965 | 1-Aug-2022 | HASSAN | 110 | HGUNJE-VARAHI | HGGUNJE_220 | 10:54 | 14:30 | 3:36 | LINE CLEAR AVAILED |
| 1966 | 1-Aug-2022 | HASSAN | 66 | BALLUPE-KANDLI | BALLUPETE_66 | 12:50 | 18:13 | 5:23 | LINE CLEAR AVAILED |
| 1967 | 1-Aug-2022 | HASSAN | 66 | CHIKKAK-DUDDA | CHIKKAKONDAGOLA_66 | 10:45 | 11:06 | 0:21 | LINE CLEAR AVAILED |
| 1968 | 1-Aug-2022 | HASSAN | 66 | HNPR2-HASS3 | HOLENARASIPURA_220 | 11:05 | 15:57 | 4:52 | LINE CLEAR AVAILED |
| 1969 | 1-Aug-2022 | HASSAN | 66 | KANDLI-SAKLIESHPUR | KANDLI_66 | 16:50 | 18:22 | 1:32 | MAIN SUPPLY FAILURE |
| 1970 | 1-Aug-2022 | HASSAN | 66 | MOSALEH-HNPRA | MOSALEHOSAHALLI_66 | 11:12 | 16:00 | 4:48 | MAIN SUPPLY FAILURE |
| 1971 | 1-Aug-2022 | HASSAN | 66 | HV1 | MOSALEHOSAHALLI_66 | 11:11 | 12:38 | 1:27 | MAIN SUPPLY FAILURE |
| 1972 | 1-Aug-2022 | HASSAN | 66 | HV1 | MOSALEHOSAHALLI_66 | 15:48 | 16:01 | 0:13 | HAND TRIPPED |
| 1973 | 1-Aug-2022 | HASSAN | 66 | SAKALE-HANBAL | SAKLESHPURA_66 | 16:32 | 18:22 | 1:50 | LINE CLEAR AVAILED |
| 1974 | 1-Aug-2022 | HASSAN | 66 | SAKALE-HASSAN1 | SAKLESHPURA_66 | 16:32 | 18:25 | 1:53 | LINE FAULT |
| 1975 | 1-Aug-2022 | HASSAN | 66 | HV1 | SAKLESHPURA_66 | 16:32 | 18:19 | 1:47 | LINE CLEAR AVAILED |
| 1976 | 1-Aug-2022 | HASSAN | 66 | HV2 | SAKLESHPURA_66 | 16:32 | 18:17 | 1:45 | LINE CLEAR AVAILED |
| 1977 | 1-Aug-2022 | HASSAN | 66 | SAKALE-IPCL1 | SAKLESHPURA_66 | 16:31 | 18:32 | 2:01 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|---------|---------|----------------------------------|--|---------|-----------|----------|---------------------|
| 1978 | 1-Aug-2022 | HASSAN | 66 | SAKALE-IPCL2 | SAKLESH PURA_66 | 15:10 | 15:20 | 0:10 | HAND TRIPPED |
| 1979 | 1-Aug-2022 | HASSAN | 66 | SAKALE-IPCL2 | SAKLESH PURA_66 | 16:33 | 18:22 | 1:49 | LINE CLEAR AVAILED |
| 1980 | 1-Aug-2022 | MYSURU | 66 | BG PURA-HEBBANI | BGPURA_66, CHANDALLI_66, PARINAMIPURA_66 , THALAKADU_66 | 7:37 | 8:05 | 0:28 | LINE FAULT |
| 1981 | 1-Aug-2022 | MYSURU | 66 | BG PURA-HEBBANI | BGPURA_66, CHANDALLI_66, PARINAMIPURA_66 , THALAKADU_66 | 8:15 | 8:20 | 0:05 | HAND TRIPPED |
| 1982 | 1-Aug-2022 | MYSURU | 66 | HV1 | BOOKANAKERE_66 | 14:51 | 15:31 | 0:40 | LINE CLEAR AVAILED |
| 1983 | 1-Aug-2022 | MYSURU | 66 | HV1 | HANAGODU_66 | 23:20 | 23:34 | 0:13 | MAIN SUPPLY FAILURE |
| 1984 | 1-Aug-2022 | MYSURU | 66 | HARADANAHALLI(JAK)-LAXJEET | NO STATIONS EFFECTED | 22:02 | 22:10 | 0:08 | LINE FAULT |
| 1985 | 1-Aug-2022 | MYSURU | 66 | HEBBANI-MEGHALAPURA | CHIDRAVALI_66 GARGESHWARI_66 THUMBLA_66 MEGALAPURA_66 NARASIPURA_66 VYASRAJPURA_66 | 7:36 | 8:36 | 1:00 | LINE FAULT |
| 1986 | 1-Aug-2022 | MYSURU | 66 | HEBBANI-MEGHALAPURA | BGPURA_66, CHANDALLI_66, PARINAMIPURA_66 , THALAKADU_66 | 8:56 | 8:58 | 0:02 | HAND TRIPPED |
| 1987 | 1-Aug-2022 | MYSURU | 66 | HUNSUR-ELAWALA | GAVADAGERE_66 | 7:24 | 7:42 | 0:17 | LINE FAULT |
| 1988 | 1-Aug-2022 | MYSURU | 220 | HV1 | HOOTAGALLY_220 | 20:34 | 21:24 | 0:50 | TRANSFORMER FAULT |
| 1989 | 1-Aug-2022 | MYSURU | 220 | HV2 | HOOTAGALLY_220 | 20:34 | 21:41 | 1:07 | TRANSFORMER FAULT |
| 1990 | 1-Aug-2022 | MYSURU | 66 | HOOTAGALLY -HUNSUR | NO STATIONS EFFECTED | 20:01 | 22:08 | 2:07 | LINE FAULT |
| 1991 | 1-Aug-2022 | MYSURU | 66 | HOOTAGALLY -BARC 2 | NO STATIONS EFFECTED | 20:01 | 22:13 | 2:12 | LINE FAULT |
| 1992 | 1-Aug-2022 | MYSURU | 66 | HOOTAGALLY -BARC1 | NO STATIONS EFFECTED | 20:34 | 22:05 | 1:31 | MAIN SUPPLY FAILURE |
| 1993 | 1-Aug-2022 | MYSURU | 66 | HOOTAGALLY -RBI | NO STATIONS EFFECTED | 20:34 | 21:53 | 1:19 | MAIN SUPPLY FAILURE |
| 1994 | 1-Aug-2022 | MYSURU | 66 | HOOTAGALLY -VIKRANTH | HEBBAL_66 METAGALLY_66 | 20:34 | 21:48 | 1:14 | MAIN SUPPLY FAILURE |
| 1995 | 1-Aug-2022 | MYSURU | 66 | HOOTAGALLY -VIJAYNAGARA | VIJAYANAGRAMYS_66 | 20:34 | 21:49 | 1:15 | MAIN SUPPLY FAILURE |
| 1996 | 1-Aug-2022 | MYSURU | 66 | HOOTAGALLY -BANNIMANTAP | BANNIMANTAP_66 | 20:34 | 22:07 | 1:33 | LINE CLEAR AVAILED |
| 1997 | 1-Aug-2022 | MYSURU | 66 | HOOTAGALLY -DATTAGALLI | DATTAGALLY_66 RKNAGARA_66 MANDAKALLI_66 | 20:34 | 21:47 | 1:13 | LINE CLEAR AVAILED |
| 1998 | 1-Aug-2022 | MYSURU | 66 | HOOTAGALLY -BOGADHI | BOGADHI_66 KALAMANDIRA_66 | 20:34 | 21:59 | 1:25 | LINE CLEAR AVAILED |
| 1999 | 1-Aug-2022 | MYSURU | 66 | HV1 | HOOTAGALLY_220 | 20:34 | 21:02 | 0:28 | HAND TRIPPED |
| 2000 | 1-Aug-2022 | MYSURU | 66 | HV2 | HOOTAGALLY_220 | 20:34 | 21:06 | 0:32 | HAND TRIPPED |
| 2001 | 1-Aug-2022 | MYSURU | 220 | KADAKOLA-KOZIKODE | NO STATIONS EFFECTED | 14:50 | 16:38 | 1:47 | LINE FAULT |
| 2002 | 1-Aug-2022 | MYSURU | 66 | KADAKOLA-SARAGUR 2 | NO STATIONS EFFECTED | 6:44 | 6:55 | 0:11 | LINE FAULT |
| 2003 | 1-Aug-2022 | MYSURU | 66 | KADAKOLA-VAJAMANGALA 2 | NO STATIONS EFFECTED | 6:08 | 6:20 | 0:12 | LINE FAULT |
| 2004 | 1-Aug-2022 | MYSURU | 66 | KIADB MANDYA-MADDUR | MADDUR_66, SOMANAHALLI_66 | 22:39 | 22:48 | 0:09 | LINE FAULT |
| 2005 | 1-Aug-2022 | MYSURU | 66 | KIRUGAVALLU-MALIYUR | BANNUR_66 MALIYURU_66 | 20:05 | 20:17 | 0:12 | LINE FAULT |
| 2006 | 1-Aug-2022 | MYSURU | 220 | KUSHALANAGARA 220-BASTIPURA 2 | NO STATIONS EFFECTED | 5:31 | 7:45 | 2:14 | LINE FAULT |
| 2007 | 1-Aug-2022 | MYSURU | 66 | KUSHALANAGARA 220-RAMANATHPURA 1 | ALUR SIDDAPURA_66 KANAGAL_66 | 4:32 | 4:39 | 0:07 | LINE FAULT |
| 2008 | 1-Aug-2022 | MYSURU | 66 | LOKKANHALLY-PG PALYA | PGPALYA_66 | 17:10 | 17:15 | 0:05 | LINE FAULT |
| 2009 | 1-Aug-2022 | MYSURU | 66 | HV1 | LOKKANAHALLI_66 | 12:20 | 12:45 | 0:25 | LINE CLEAR AVAILED |
| 2010 | 1-Aug-2022 | MYSURU | 66 | MADHUVANAHALLI-HEBBANI | NO STATIONS EFFECTED | 6:57 | 7:02 | 0:05 | LINE FAULT |
| 2011 | 1-Aug-2022 | MYSURU | 66 | MEGHALAPURA-HEBBANI | NO STATIONS EFFECTED | 8:07 | 9:15 | 1:07 | LINE CLEAR AVAILED |
| 2012 | 1-Aug-2022 | MYSURU | 66 | P PURA-ATRIA 2 | NO STATIONS EFFECTED | 20:45 | 21:29 | 0:44 | MAIN SUPPLY FAILURE |
| 2013 | 1-Aug-2022 | MYSURU | 66 | P PURA-TUBINAKERE | BANANGADI_66 PANDAVAPURA_66 | 21:01 | 22:04 | 1:02 | LINE CLEAR AVAILED |
| 2014 | 1-Aug-2022 | MYSURU | 66 | HV2 | SANTHEMARAHALLI_66 | 19:25 | 19:47 | 0:22 | TRANSFORMER FAULT |
| 2015 | 1-Aug-2022 | MYSURU | 66 | HV1 | SANIVARASANTHE_66 | 16:16 | 16:24 | 0:07 | TRANSFORMER FAULT |
| 2016 | 1-Aug-2022 | MYSURU | 66 | SFC SIVA-HEBBANI 6 | NO STATIONS EFFECTED | 7:36 | 7:46 | 0:10 | LINE FAULT |
| 2017 | 1-Aug-2022 | MYSURU | 220 | HV1 | TUBINAKERE_220 | 10:20 | 10:21 | 0:01 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|---------|---------|--------------------------------------|---|----------------------|-----------|----------|-------------------------------------|
| 2018 | 1-Aug-2022 | MYSURU | 220 | HV1 | TUBINAKERE_220 | 18:57 | 19:50 | 0:52 | TRANSFORMER FAULT |
| 2019 | 1-Aug-2022 | MYSURU | 66 | TUBINAKERE-MC-4 | NO STATIONS EFFECTED | 21:47 | 21:53 | 0:06 | LINE FAULT |
| 2020 | 1-Aug-2022 | MYSURU | 66 | TUBINAKERE-PANDAVAPURA | BANANGADI_66 DODDABYADARAHALLI_66 PANDAVAPURA_66 | 20:43 | 22:04 | 1:21 | LINE FAULT |
| 2021 | 1-Aug-2022 | MYSURU | 66 | YERALLI HAND POST-HD KOTE | ANTHARSANTHE_66 HDKOTE_66 | 12:15 | 12:25 | 0:10 | LINE FAULT |
| 2022 | 1-Aug-2022 | MYSURU | 66 | HOOTAGALLY -BEML | HEBBAL-INDUSTRIAL_66 | 20:34(1.8.22) | | | LINE OPEN, LINE FAULT |
| 2023 | 1-Aug-2022 | MYSURU | 220 | KADAKOLA-KOZIKODE | NO STATIONS EFFECTED | 19:35(1.8.22) | | | LINE OPEN, LINE FAULT |
| 2024 | 1-Aug-2022 | MYSURU | 66 | P PURA-ATRIA 1 | NO STATIONS EFFECTED | 20:45(1.8.22) | | | MAIN SUPPLY FAILURE |
| 2025 | 1-Aug-2022 | MYSURU | 66 | HV1 | GUNDLUPETE_66 | 17:02 (12.07.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 2026 | 1-Aug-2022 | MYSURU | 220 | HV2 | MADHUVANAHALLI_220 | 18:57:18 (31.5.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 2027 | 1-Aug-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 18:26 (22/04/2022) | | | LINE OPEN , LINE CLEAR AVAILED |
| 2028 | 1-Aug-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16(08/12/2021) | | | LINE OPEN , LINE CLEAR AVAILED |
| 2029 | 1-Aug-2022 | MYSURU | 220 | HV1 | KADAKOLA_220 | 1:41:14 (21/07/2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 2030 | 1-Aug-2022 | TUMKUR | 220 | DAVANGERE SRS- SHIMOGA 2 | DAVANGERE_SRS_220 | 14:20(27.07.2022) | | | LINE OPEN, LINE FAULT |
| 2031 | 1-Aug-2022 | TUMKUR | 220 | GUTTUR 400KV- HAVERI 1 | HAVERI_220 | 17:23 | 17:26 | 0:02 | LINE FAULT |
| 2032 | 1-Aug-2022 | TUMKUR | 220 | TR-2 | MADHUGIRI_220 | 7:39 | 8:18 | 0:39 | TRANSFORMER FAULT |
| 2033 | 1-Aug-2022 | TUMKUR | 220 | TR-2 | MADHUGIRI_220 | 10:24 | 10:39 | 0:14 | TRANSFORMER FAULT |
| 2034 | 1-Aug-2022 | TUMKUR | 220 | TR-1 | PAVAGADA_220 | 0:30 | 1:14 | 0:44 | TRANSFORMER FAULT |
| 2035 | 1-Aug-2022 | TUMKUR | 220 | TR-1 | PAVAGADA_220 | 3:05 | 7:24 | 4:19 | TRANSFORMER FAULT |
| 2036 | 1-Aug-2022 | TUMKUR | 220 | TR-2 | PAVAGADA_220 | 3:05 | 7:32 | 4:26 | TRANSFORMER FAULT |
| 2037 | 1-Aug-2022 | TUMKUR | 220 | PAVAGADA 220kv- MADHUGIRI 1 | PAVAGADA_220 | 0:30 | 8:27 | 7:56 | LINE FAULT |
| 2038 | 1-Aug-2022 | TUMKUR | 220 | PAVAGADA 220kv- MADHUGIRI 2 | PAVAGADA_220 | 3:05 | 7:22 | 4:16 | LINE FAULT |
| 2039 | 1-Aug-2022 | TUMKUR | 66 | ANCHEPALYA 220- HEBBUR | HEBBUR_66 | 3:40 | 3:50 | 0:10 | LINE FAULT |
| 2040 | 1-Aug-2022 | TUMKUR | 66 | TR-2 | BEVINAHALLI_66 | 14:07 | 15:23 | 1:16 | LINE CLEAR AVAILED |
| 2041 | 1-Aug-2022 | TUMKUR | 66 | TR-2 | BHARAMAGIRI_66 | 6:15 | 6:25 | 0:10 | TRANSFORMER FAULT |
| 2042 | 1-Aug-2022 | TUMKUR | 66 | BILCHODU-PUNABHAGHATTA | BILCHODU_66 | 11:25 | 11:30 | 0:05 | MAIN SUPPLY FAILURE |
| 2043 | 1-Aug-2022 | TUMKUR | 66 | HOLALKERE- RAMGIRI 1 | HOLALKERE_66 | 6:26 | 6:31 | 0:05 | LINE FAULT |
| 2044 | 1-Aug-2022 | TUMKUR | 66 | TR-2 | HONNUDIKE_66 | 12:50 | 12:53 | 0:03 | TRANSFORMER FAULT |
| 2045 | 1-Aug-2022 | TUMKUR | 66 | KALAMARANAHALLI- BPCLSOLAR_IPP_66 | BPCLSOLAR_IPP_66 | 19:13 | 19:17 | 0:03 | HAND TRIPPED |
| 2046 | 1-Aug-2022 | TUMKUR | 66 | TR-1 | KORATAGERE_66 | 1:50 | 2:10 | 0:20 | TRANSFORMER FAULT |
| 2047 | 1-Aug-2022 | TUMKUR | 66 | KUKKAWADA -HONNALLI | KUKKAWADA_66 | 10:05 | 16:47 | 6:41 | LINE CLEAR AVAILED |
| 2048 | 1-Aug-2022 | TUMKUR | 66 | TR-2(LV-2) | MADHUGIRI_220 | 7:39 | 8:19 | 0:39 | HAND TRIPPED |
| 2049 | 1-Aug-2022 | TUMKUR | 66 | TR-2(LV-2) | MADHUGIRI_220 | 10:24 | 10:40 | 0:15 | HAND TRIPPED |
| 2050 | 1-Aug-2022 | TUMKUR | 66 | MADHUGIRI 220kv- MADHUGIRI | MADHUGIRI_66, BADAVANAHALLI_66 | 7:44 | 8:21 | 0:36 | HAND TRIPPED |
| 2051 | 1-Aug-2022 | TUMKUR | 66 | MADHUGIRI 220kv- MADHUGIRI | MADHUGIRI_66, BADAVANAHALLI_66 | 10:32 | 10:41 | 0:08 | HAND TRIPPED |
| 2052 | 1-Aug-2022 | TUMKUR | 66 | MADHUGIRI 220kv- MEDIGESHI | MEDIGESHI_66 | 7:39 | 10:24 | 2:45 | LINE FAULT |
| 2053 | 1-Aug-2022 | TUMKUR | 66 | MADHUGIRI 220kv- MEDIGESHI | MEDIGESHI_66 | 10:24 | 17:59 | 7:35 | LINE FAULT |
| 2054 | 1-Aug-2022 | TUMKUR | 66 | MADHUGIRI 220kv- NITRAHALLI | NITRAHALLI_66 | 7:45 | 9:50 | 2:05 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|---------|---------|---|------------------------|---------|-----------|----------|--------------------|
| 2055 | 1-Aug-2022 | TUMKUR | 66 | MADHUGIRI 220kV- NITRAHALLI | NITRAHALLI_66 | 10:32 | 10:40 | 0:08 | HAND TRIPPED |
| 2056 | 1-Aug-2022 | TUMKUR | 66 | MADHUGIRI 220kV- PULLAMAGATTA | PULLAMGATTA_66 | 7:47 | 8:24 | 0:37 | HAND TRIPPED |
| 2057 | 1-Aug-2022 | TUMKUR | 66 | MADHUGIRI 220kV- PULLAMAGATTA | PULLAMGATTA_66 | 10:34 | 10:42 | 0:08 | HAND TRIPPED |
| 2058 | 1-Aug-2022 | TUMKUR | 66 | NAGALAMADIKE- RNS INFRA SOLAR IPP_66 | RNS INFRA SOLAR_IPP_66 | 4:09 | 6:33 | 2:23 | LINE FAULT |
| 2059 | 1-Aug-2022 | TUMKUR | 66 | NAGALAMADIKE- ATRIA_IPP_66 | RAISE_IPP_66 | 3:05 | 3:35 | 0:30 | LINE FAULT |
| 2060 | 1-Aug-2022 | TUMKUR | 66 | TR-2 | PAVAGADA_66 | 7:34 | 15:07 | 7:32 | LINE CLEAR AVAILED |
| 2061 | 1-Aug-2022 | TUMKUR | 66 | TR-1(LV-1) | PAVAGADA_220 | 3:43 | 7:24 | 3:41 | TRANSFORMER FAULT |
| 2062 | 1-Aug-2022 | TUMKUR | 66 | TR-2(LV-2) | PAVAGADA_220 | 3:43 | 7:32 | 3:48 | TRANSFORMER FAULT |
| 2063 | 1-Aug-2022 | TUMKUR | 66 | PAVAGADA220-MIDIGESHI | MIDIGESHI_66 | 3:52 | 4:06 | 0:14 | LINE FAULT |
| 2064 | 1-Aug-2022 | TUMKUR | 66 | PAVAGADA 220kV- SHYLAPURA | SHYLAPURA_66 | 0:30 | 1:12 | 0:41 | LINE FAULT |
| 2065 | 1-Aug-2022 | TUMKUR | 66 | TR-1 | SASALUHALLA_66 | 11:23 | 13:57 | 2:33 | LINE CLEAR AVAILED |