

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM:04.02.2020 TO 10.02.2020**

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	4-Feb-2020	BAGALKOT	110	110/11KV,HV 1	BILAGI_110	15:34	16:23	0:49	LINE CLEAR AVAILED
2	4-Feb-2020	BAGALKOT	110	GADAG ROAD-GOPANAKOPPA	GOPANAKOPPA_110	11:46	15:27	3:41	NFBC ISSUED
3	4-Feb-2020	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	9:37	9:52	0:15	TRANSFORMER FAULT
4	4-Feb-2020	BAGALKOT	220	SHIROLKOPPA(BELLIGAVI)- RANEBENNUR	RANEBENNUR_220	13:48	23:59	10:11	LINE CLEAR AVAILED
5	4-Feb-2020	BAGALKOT	110	110/11KV, HV2	NIDAGUNDI_110	11:33	11:57	0:24	TRANSFORMER FAULT
6	4-Feb-2020	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	18:49	19:04	0:15	LOAD CURTAILMENT
7	4-Feb-2020	BAGALKOT	110	MRUTHYUNJAY NAGAR- GOPPANAKOPPA	GOPPANAKOPPA_110	15:44	15:47	0:03	HAND TRIPPED
8	4-Feb-2020	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	0:00	12:50	12:50	LINE CLEAR AVAILED
9	4-Feb-2020	BAGALKOT	110	HAVERI220- HANGAL (TILUVALLI)	TILUVALLI_110	9:11	9:20	0:09	HAND TRIPPED
10	4-Feb-2020	BAGALKOT	220	AMBEWADI-NARENDRA1&2	AMBEWADI_220	10:09	18:51	8:42	LINE CLEAR AVAILED
11	4-Feb-2020	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	19:22	23:59	4:37	LINE FAULT
12	4-Feb-2020	BAGALKOT	110	110/11KV,HV 1	BILAGI_110	15:34	16:23	0:49	LINE CLEAR AVAILED
13	4-Feb-2020	BAGALKOT	110	GADAG ROAD-GOPANAKOPPA	GOPANAKOPPA_110	11:46	15:27	3:41	NFBC ISSUED
14	4-Feb-2020	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	9:37	9:52	0:15	TRANSFORMER FAULT
15	4-Feb-2020	BAGALKOT	220	SHIROLKOPPA(BELLIGAVI)- RANEBENNUR	RANEBENNUR_220	13:48	23:59	10:11	LINE CLEAR AVAILED
16	4-Feb-2020	BAGALKOT	110	110/11KV, HV2	NIDAGUNDI_110	11:33	11:57	0:24	TRANSFORMER FAULT
17	4-Feb-2020	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	18:49	19:04	0:15	LOAD CURTAILMENT
18	4-Feb-2020	BAGALKOT	110	MRUTHYUNJAY NAGAR- GOPPANAKOPPA	GOPPANAKOPPA_110	15:44	15:47	0:03	HAND TRIPPED
19	4-Feb-2020	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	0:00	12:50	12:50	LINE CLEAR AVAILED
20	4-Feb-2020	BAGALKOT	110	HAVERI220- HANGAL (TILUVALLI)	TILUVALLI_110	9:11	9:20	0:09	HAND TRIPPED
21	4-Feb-2020	BAGALKOT	220	AMBEWADI-NARENDRA1&2	AMBEWADI_220	10:09	18:51	8:42	LINE CLEAR AVAILED
22	4-Feb-2020	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	19:22	23:59	4:37	LINE FAULT
23	4-Feb-2020	BENGALURU	66	HV1	VOLVO	14:38	14:45	0:07	LINE CLEAR AVAILED
24	4-Feb-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO(EHT), DALASANUR	15:25	15:30	0:05	LINE FAULT
25	4-Feb-2020	BENGALURU	66	HV1	BAGEPALLI	10:10	10:15	0:04	LINE CLEAR AVAILED
26	4-Feb-2020	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	6:44	6:50	0:06	LOAD CHANGE OVER
27	4-Feb-2020	BENGALURU	66	HV2	SOMANAHALLI 220	13:08	14:40	1:32	LINE CLEAR AVAILED
28	4-Feb-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	13:16	13:28	0:12	LINE CLEAR AVAILED
29	4-Feb-2020	BENGALURU	66	HV1	SOMANAHALLI 220	13:35	13:38	0:03	LINE CLEAR AVAILED
30	4-Feb-2020	BENGALURU	66	HV1	SOMANAHALLI 220	14:20	23:59	9:39	TRANSFORMER FAULT
31	4-Feb-2020	BENGALURU	66	HV1	SOMANAHALLI 220	0:00	11:40	11:40	TRANSFORMER FAULT
32	4-Feb-2020	BENGALURU	66	HV1	THAYALUR	11:37	12:01	0:24	LINE CLEAR AVAILED
33	4-Feb-2020	BENGALURU	66	ST.JOHN WOOD - HSR 220	ST.JOHN WOOD	11:36	13:20	1:44	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
34	4-Feb-2020	BENGALURU	66	ANJANAPURA - KHODAYS 220	ANJANAPURA	12:03	13:22	1:19	LINE CLEAR AVAILED
35	4-Feb-2020	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-2	13:20	14:19	0:59	LINE CLEAR AVAILED
36	4-Feb-2020	BENGALURU	66	HV1	MEI LAYOUT	9:17	9:19	0:02	LINE CLEAR AVAILED
37	4-Feb-2020	BENGALURU	66	HV2	MEI LAYOUT	10:28	10:30	0:02	LINE CLEAR AVAILED
38	4-Feb-2020	BENGALURU	66	HV1	VIJAYANAGARA	10:03	10:08	0:05	LOAD CHANGEOVER
39	4-Feb-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110,SAIDAPUR_110	6:05	6:12	0:07	LINE FAULT
40	4-Feb-2020	GULBARGA	110	HV2	HANUMASAGAR_110	7:20	7:40	0:20	LOAD CURTAILMENT
41	4-Feb-2020	GULBARGA	110	HV2	HATTI_110	7:16	7:23	0:07	LOAD CURTAILMENT
42	4-Feb-2020	GULBARGA	110	HV2	ALAND_110	7:15	7:45	0:30	LOAD CURTAILMENT
43	4-Feb-2020	GULBARGA	110	HV2	ALAND_110	14:30	14:35	0:05	TRANSFORMER FAULT
44	4-Feb-2020	GULBARGA	110	HV1	KURKUNTA_110	7:15	7:20	0:05	LOAD CURTAILMENT
45	4-Feb-2020	GULBARGA	110	HV2	CHINCHOLI_110	7:20	7:35	0:15	LOAD CURTAILMENT
46	4-Feb-2020	GULBARGA	110	HV4	YELBURGA	7:15	7:30	0:15	LOAD CURTAILMENT
47	4-Feb-2020	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	16:12	18:20	2:08	LINE FAULT
48	4-Feb-2020	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	16:25	18:20	1:55	LINE CLEAR AVAILED
49	4-Feb-2020	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	22:48	23:55	1:07	LINE FAULT
50	4-Feb-2020	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	23:55	23:59	0:04	LINE CLEAR AVAILED
51	4-Feb-2020	GULBARGA	110	HV1	PDHALLI_110	18:49	18:55	0:06	LOAD CURTAILMENT
52	4-Feb-2020	GULBARGA	110	HV1	MAHAGOAN_110	18:49	19:50	1:01	LOAD CURTAILMENT
53	4-Feb-2020	GULBARGA	110	HV1	MAHAGOAN_110	7:15	7:45	0:30	LOAD CURTAILMENT
54	4-Feb-2020	GULBARGA	110	HV3	KAMPLI_GLB_110	18:49	19:05	0:16	LOAD CURTAILMENT
55	4-Feb-2020	GULBARGA	110	HV1	KURKUNTA_110	7:15	7:20	0:05	LOAD CURTAILMENT
56	4-Feb-2020	GULBARGA	110	HV1	KURKUNTA_110	18:49	19:01	0:12	LOAD CURTAILMENT
57	4-Feb-2020	GULBARGA	110	HV1	SIRWAR_110	18:49	18:55	0:06	LOAD CURTAILMENT
58	4-Feb-2020	GULBARGA	66	HV1	TAMBRAHALLI_66	8:35	8:40	0:05	LINE CLEAR AVAILED
59	4-Feb-2020	GULBARGA	110	HV3	YELBURGA_110	18:50	19:09	0:19	LOAD CURTAILMENT
60	4-Feb-2020	GULBARGA	110	HV2	JEWARGI_110	18:50	19:00	0:10	LOAD CURTAILMENT
61	4-Feb-2020	GULBARGA	110	HV2	CHINCHOLI_110	18:50	19:15	0:25	LOAD CURTAILMENT
62	4-Feb-2020	GULBARGA	110	CHINCHOLI-RENEW WIND IPP	CHINCHOLI_110	19:39	23:42	4:03	LINE CLEAR AVAILED
63	4-Feb-2020	GULBARGA	110	GABUR-BPSLR_IPP	GABUR_110	23:45	23:49	0:04	LINE FAULT
64	4-Feb-2020	GULBARGA	110	GABUR-BPSLR_IPP	GABUR_110	22:24	22:27	0:03	LINE FAULT
65	4-Feb-2020	GULBARGA	110	GABUR-BPSLR_IPP	GABUR_110	19:35	19:39	0:04	LINE FAULT
66	4-Feb-2020	GULBARGA	110	GABUR-BPSLR_IPP	GABUR_110	21:35	21:39	0:04	LINE FAULT
67	4-Feb-2020	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	0:00	13:42	13:42	NFBC ISSUED
68	4-Feb-2020	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	13:46	23:59	10:13	LINE FAULT
69	4-Feb-2020	HASSAN	220	HV3	KEMAR_220	11:11	12:51	1:40	LINE CLEAR AVAILED
70	4-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	0:00	13:42	13:42	LINE CLEAR AVAILED
71	4-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	13:45	23:59	10:14	LINE FAULT
72	4-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	0:00	14:52	14:52	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
73	4-Feb-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	9:12	20:51	11:39	NFBC ISSUED
74	4-Feb-2020	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	18:17	21:49	3:32	LINE FAULT
75	4-Feb-2020	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	0:00	9:45	9:45	LINE CLEAR AVAILED
76	4-Feb-2020	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	5:36	13:45	8:09	LINE FAULT
77	4-Feb-2020	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	5:36	13:45	8:09	LINE FAULT
78	4-Feb-2020	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	9:12	20:53	11:41	LINE CLEAR AVAILED
79	4-Feb-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	18:17	21:49	3:32	LINE FAULT
80	4-Feb-2020	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	5:35	5:54	0:19	HAND TRIPPED
81	4-Feb-2020	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	5:37	5:50	0:13	HAND TRIPPED
82	4-Feb-2020	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	5:36	5:49	0:13	HAND TRIPPED
83	4-Feb-2020	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	5:36	5:41	0:05	HAND TRIPPED
84	4-Feb-2020	HASSAN	110	HV1	BRAHMAVARA_110	7:15	7:30	0:15	LOAD CURTAILMENT
85	4-Feb-2020	HASSAN	110	HV1	BRAHMAVARA_110	18:49	19:04	0:15	LOAD CURTAILMENT
86	4-Feb-2020	HASSAN	110	HV2	GERUMARA_110	7:15	7:48	0:33	LOAD CURTAILMENT
87	4-Feb-2020	HASSAN	110	HV1	GURUVAYANAKERE_110	10:05	10:12	0:07	TRANSFORMER FAULT
88	4-Feb-2020	HASSAN	110	LV3	KEMAR_220	11:11	12:51	1:40	LINE CLEAR AVAILED
89	4-Feb-2020	HASSAN	110	HV2	MANIPAL_110	10:14	12:43	2:29	LINE CLEAR AVAILED
90	4-Feb-2020	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	11:08	12:57	1:49	MAIN SUPPLY FAILURE
91	4-Feb-2020	HASSAN	110	HV1	SHIVPURA_110	7:05	8:42	1:37	LINE CLEAR AVAILED
92	4-Feb-2020	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	9:53	22:37	12:44	MAIN SUPPLY FAILURE
93	4-Feb-2020	HASSAN	66	HV1	BAGUR_66	12:00	12:40	0:40	MAIN SUPPLY FAILURE
94	4-Feb-2020	HASSAN	66	HV2	BAGUR_66	11:59	12:44	0:45	MAIN SUPPLY FAILURE
95	4-Feb-2020	HASSAN	66	BAGUR-UDAYAPUR	BAGUR_66	11:59	12:39	0:40	MAIN SUPPLY FAILURE
96	4-Feb-2020	HASSAN	66	HV2	BASAVAGT	7:15	7:27	0:12	LOAD CURTAILMENT
97	4-Feb-2020	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	5:57	18:30	12:33	NFBC ISSUED
98	4-Feb-2020	HASSAN	66	HV1	HALLIMYSORE_66	7:15	7:19	0:04	LOAD CURTAILMENT
99	4-Feb-2020	HASSAN	66	HV1	HANGARANAHALLY_66	7:15	7:35	0:20	LOAD CURTAILMENT
100	4-Feb-2020	HASSAN	66	HASSN220-ARAKALGUD1	HASSAN_220	9:08	22:33	13:25	LINE CLEAR AVAILED
101	4-Feb-2020	HASSAN	66	HASSN220-ARAKALGUD2	HASSAN_220	9:08	22:33	13:25	LINE CLEAR AVAILED
102	4-Feb-2020	HASSAN	66	LV1	HASSAN_220	10:30	11:20	0:50	LINE CLEAR AVAILED
103	4-Feb-2020	HASSAN	66	HASSN220-CRP1	HASSAN_220	10:30	11:20	0:50	LINE CLEAR AVAILED
104	4-Feb-2020	HASSAN	66	HASSN220-HNPURA	HASSAN_220	10:30	11:20	0:50	LINE CLEAR AVAILED
105	4-Feb-2020	HASSAN	66	HASSN220-SKPURA1	HASSAN_220	10:30	11:20	0:50	LINE CLEAR AVAILED
106	4-Feb-2020	HASSAN	66	HASSN220-SKPURA2	HASSAN_220	10:30	11:20	0:50	LINE CLEAR AVAILED
107	4-Feb-2020	HASSAN	66	HASSN220-CRP2	HASSAN_220	10:30	11:20	0:50	LINE CLEAR AVAILED
108	4-Feb-2020	HASSAN	66	KIADB HA-RAMESWARNAGAR	KIADB_66	10:14	11:39	1:25	LINE CLEAR AVAILED
109	4-Feb-2020	HASSAN	66	HV2	RAMESHWARNAGAR_66	7:14	7:23	0:09	LOAD CURTAILMENT
110	4-Feb-2020	MYSORE	66	HV2	ADDIHALLI_66	7:15	7:20	0:05	LOAD CURTAILMENT
111	4-Feb-2020	MYSORE	66	HV1	ARAKERE_66,	15:42	16:00	0:18	LINE CLEAR AVAILED
112	4-Feb-2020	MYSORE	66	HV1	BGPURA_66	7:14	7:30	0:15	LOAD CURTAILMENT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
113	4-Feb-2020	MYSORE	66	HV1	BILIKERE_66	7:15	7:30	0:14	LOAD CURTAILMENT
114	4-Feb-2020	MYSORE	66	HV1	DODDINADUVADI_66	7:15	7:28	0:12	LOAD CURTAILMENT
115	4-Feb-2020	MYSORE	66	HV2	DODDARAYAPET_66	7:15	7:50	0:34	LOAD CURTAILMENT
116	4-Feb-2020	MYSORE	66	HV2	HDKOTE_66	7:15	7:30	0:14	LOAD CURTAILMENT
117	4-Feb-2020	MYSORE	66	HV1	HUNSUR_66	8:56	21:43	12:47	LINE CLEAR AVAILED
118	4-Feb-2020	MYSORE	66	HV2	HUNSUR_66	8:56	17:44	8:48	LINE CLEAR AVAILED
119	4-Feb-2020	MYSORE	66	HV2	JAIPUR_66	7:15	7:26	0:11	LOAD CURTAILMENT
120	4-Feb-2020	MYSORE	66	HV1	JAKKANAHALLY_66	7:15	7:50	0:34	LOAD CURTAILMENT
121	4-Feb-2020	MYSORE	66	HV2	KMDODDI_66	7:16	7:47	0:31	LOAD CURTAILMENT
122	4-Feb-2020	MYSORE	66	HV2	KOLLEGALA_66	7:16	7:22	0:06	LOAD CURTAILMENT
123	4-Feb-2020	MYSORE	66	HV1	KUSHALANAGARA_66	7:15	7:30	0:14	LOAD CURTAILMENT
124	4-Feb-2020	MYSORE	66	KUSHALNAGARA 220-BYLUKUPPE	BYLUKUPPE_66, HANAGODU_66, PERIYAPATNA_66, PONNAMPET_66, VIRAJPET_66	9:09	11:52	2:43	LINE FAULT
125	4-Feb-2020	MYSORE	66	KUSHALNAGARA 220-BYLUKUPPE	BYLUKUPPE_66	13:15	15:09	1:54	LINE CLEAR AVAILED
126	4-Feb-2020	MYSORE	66	KUSHALNAGARA 220-PERIYAPATNA-1	HANAGODU_66, PERIYAPATNA_66, PONNAMPET_66, VIRAJPET_66	13:15	15:09	1:54	LINE CLEAR AVAILED
127	4-Feb-2020	MYSORE	66	HV1	MEGALAPURA_66	7:14	7:30	0:15	LOAD CURTAILMENT
128	4-Feb-2020	MYSORE	66	HV1	NAGAMANGALA_66	7:16	7:30	0:13	LOAD CURTAILMENT
129	4-Feb-2020	MYSORE	66	HV1	PANDAVAPURA_66	7:14	7:46	0:32	LOAD CURTAILMENT
130	4-Feb-2020	MYSORE	66	HV1	PONNAMPET_66	12:02	12:16	0:13	HAND TRIPPED
131	4-Feb-2020	MYSORE	66	HV2	PONNAMPET_66	7:14	7:26	0:11	LOAD CURTAILMENT
132	4-Feb-2020	MYSORE	66	HV2	PONNAMPET_66	12:02	12:16	0:13	HAND TRIPPED
133	4-Feb-2020	MYSORE	66	HV2	SANTHESARAGUR_66	7:16	7:30	0:13	LOAD CURTAILMENT
134	4-Feb-2020	MYSORE	66	HV2	SANTHEMARAHALLI_66	7:16	7:24	0:07	LOAD CURTAILMENT
135	4-Feb-2020	MYSORE	66	SHANIVARSANTHE-MALIPTNA	SANIVARASANTHE_66	10:02	17:20	7:17	LINE CLEAR AVAILED
136	4-Feb-2020	MYSORE	66	HV1	SUNTIKOPPA_66	12:06	17:23	5:17	LINE CLEAR AVAILED
137	4-Feb-2020	MYSORE	66	HV1	SUNTIKOPPA_66	17:32	18:07	0:35	LINE CLEAR AVAILED
138	4-Feb-2020	MYSORE	66	SUNTIKOPPA-KUSHALNAGARA	SUNTIKOPPA_66	12:22	17:23	5:01	LINE CLEAR AVAILED
139	4-Feb-2020	MYSORE	66	VAJMANGALA-JYOTHINAGARA	DKMAIDANA_66, JYOTHINAGARA_66	10:22	10:45	0:22	HAND TRIPPED
140	4-Feb-2020	MYSORE	66	VAJMANGALA-DEVNUR(MYS)	DEVANOORMYS_66, RAJEEVNAGARA_66	10:26	10:44	0:17	HAND TRIPPED
141	4-Feb-2020	MYSORE	66	HV1	VAJAMANGALA_220	11:44	18:10	6:25	LINE CLEAR AVAILED
142	4-Feb-2020	MYSORE	220	HV2	VAJAMANGALA_220	10:28	18:38	8:10	LINE CLEAR AVAILED
143	4-Feb-2020	TUMKUR	110	TR-1& TR-2	KBCROSS_220	11:15	12:55	1:40	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
144	4-Feb-2020	TUMKUR	110	TR-1	KBCROSS_220	17:03	18:37	1:33	LINE CLEAR AVAILED
145	4-Feb-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	13:31	13:34	0:03	HAND TRIPPED
146	4-Feb-2020	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	7:22	8:05	0:42	LOAD CURTAILMENT
147	4-Feb-2020	TUMKUR	110	TR-1	TIMMANAHALLI_110	13:30	14:07	0:37	LINE CLEAR AVAILED
148	4-Feb-2020	TUMKUR	66	TR-1	BANUVALLI_66	10:06	10:11	0:05	HAND TRIPPED
149	4-Feb-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	7:33	8:00	0:26	LINE FAULT
150	4-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	21:23	21:35	0:11	LINE FAULT
151	4-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	6:46	6:51	0:05	LINE FAULT
152	4-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	8:21	8:26	0:05	LINE FAULT
153	4-Feb-2020	TUMKUR	66	TR-1	HANAGAL_66	8:33	12:59	4:26	LINE CLEAR AVAILED
154	4-Feb-2020	TUMKUR	66	TR-2	HANAGAL_66	18:56	19:01	0:05	HAND TRIPPED
155	4-Feb-2020	TUMKUR	66	TR-2	HARAPPANAHALLI_66	12:06	15:30	3:23	LINE CLEAR AVAILED
156	4-Feb-2020	TUMKUR	66	TR-1	HIRIYUR_66	18:15	18:23	0:08	LINE CLEAR AVAILED
157	4-Feb-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	11:30	17:46	6:15	LINE FAULT
158	4-Feb-2020	TUMKUR	66	TR-2	HULIYURDURGA_66	12:50	14:10	1:19	LINE CLEAR AVAILED
159	4-Feb-2020	TUMKUR	66	TR-1	LINGADAHALLY_66	12:28	12:31	0:02	HAND TRIPPED
160	4-Feb-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	4:21	4:29	0:07	TRANSFORMER FAULT
161	4-Feb-2020	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	NAYAKANAHATTI_66	1:09	6:55	5:45	LINE FAULT
162	4-Feb-2020	TUMKUR	66	TR-2	SHYLAPURA_66	10:50	10:53	0:03	TRANSFORMER FAULT
163	4-Feb-2020	TUMKUR	66	TR-1	SHYLAPURA_66	13:05	13:08	0:02	TRANSFORMER FAULT
164	4-Feb-2020	TUMKUR	66	TR-1	TUMKUR_66	8:24	8:52	0:28	TRANSFORMER FAULT
165	5-Feb-2020	BAGALKOT	110	110/11KV,HV 1	ACHANUR_110	15:25	16:15	0:50	LINE CLEAR AVAILED
166	5-Feb-2020	BAGALKOT	110	110/11KV,HV 1	HANAGALL_110	9:16	9:20	0:04	HAND TRIPPED
167	5-Feb-2020	BAGALKOT	110	110/11KV,HV 2	HATTARAGI_110	12:06	12:33	0:27	HAND TRIPPED
168	5-Feb-2020	BAGALKOT	110	110/33KV,HV 3	HIDIKAL_110KV & 33KV KOLIGUDD&MYTRA SOLAR	19:34	20:13	0:39	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
169	5-Feb-2020	BAGALKOT	110	110/11KV,HV 2	HIDIKAL DAM_110	13:56	14:39	0:43	HAND TRIPPED
170	5-Feb-2020	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	10:25	18:26	8:01	LINE CLEAR AVAILED
171	5-Feb-2020	BAGALKOT	110	KADANKOPPA-KAVALWADA	KAVALWADA_110	10:15	10:28	0:13	HAND TRIPPED
172	5-Feb-2020	BAGALKOT	110	LAXMESHVAR-BELLATTI	BELLATTI_110	4:48	5:25	0:37	LINE FAULT
173	5-Feb-2020	BAGALKOT	110	LAXMESHVAR-BELLATTI	BELLATTI_110	5:33	5:54	0:21	HAND TRIPPED
174	5-Feb-2020	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	9:55	10:35	0:40	LINE CLEAR AVAILED
175	5-Feb-2020	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	19:18	23:59	4:41	LINE CLEAR AVAILED
176	5-Feb-2020	BAGALKOT	110	SIRSI1-KUMTA	KUMTA_110	18:58	23:59	5:01	LINE CLEAR AVAILED
177	5-Feb-2020	BAGALKOT	110	110/33KV, HV1	TIKOTA_110, BIJJARGI_33	8:21	8:31	0:10	TRANSFORMER FAULT
178	5-Feb-2020	BAGALKOT	220	SHARAVATHY2-SIRSI	SIRSI_220	9:45	23:59	14:14	LINE CLEAR AVAILED
179	5-Feb-2020	BAGALKOT	220	220/110KV, HV1&LV1	SIRSI_220	10:26	13:18	2:52	LINE CLEAR AVAILED
180	5-Feb-2020	BAGALKOT	110	ESALE(SIRSI220)-SIRSI1&2	SIRSI_110	10:44	18:52	8:08	LINE CLEAR AVAILED
181	5-Feb-2020	BAGALKOT	110	110/11KV, HV1	SIRSI_220	13:13	14:45	1:32	LINE CLEAR AVAILED
182	5-Feb-2020	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	10:37	19:12	8:35	LINE CLEAR AVAILED
183	5-Feb-2020	BAGALKOT	110	VAJRAMATTI220-KATARKI	KATARKI_110	6:26	6:31	0:05	LINE FAULT
184	5-Feb-2020	BAGALKOT	110	110/11KV, HV2	VAJRAMATTI_110	7:05	7:10	0:05	TRANSFORMER FAULT
185	5-Feb-2020	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	22:35	22:40	0:05	TRANSFORMER FAULT
186	5-Feb-2020	BENGALURU	66	HV1	SOMANAHALLI 220	0:00	11:40	11:40	TRANSFORMER FAULT
187	5-Feb-2020	BENGALURU	66	SOMANAHALLI 220 - SUBRAMAYAPURA 1	SUBRAMAYAPURA 66, ISKON	10:52	11:00	0:08	LOAD CHANGE OVER
188	5-Feb-2020	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMAYAPURA 66, ISKON	15:29	15:37	0:07	LOAD CHANGE OVER
189	5-Feb-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	SOUTH CITY	13:45	14:03	0:18	LINE CLEAR AVAILED
190	5-Feb-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	13:55	14:04	0:09	LOAD CHANGE OVER
191	5-Feb-2020	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	16:34	16:40	0:06	LOAD CHANGE OVER
192	5-Feb-2020	BENGALURU	66	ELITA PROMENEDE - RBI	ELITA PROMENEDE	16:32	16:38	0:06	LOAD CHANGE OVER
193	5-Feb-2020	BENGALURU	66	VICTORIA - NRS 220	VICTORIA	23:17	23:20	0:03	LOAD CHANGE OVER
194	5-Feb-2020	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	12:56	13:44	0:47	LINE CLEAR AVAILED
195	5-Feb-2020	BENGALURU	66	REMCO - NRS	VIJAYANAGARA	21:52	21:58	0:05	LOAD CHANGE OVER
196	5-Feb-2020	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	12:33	12:39	0:05	LOAD CHANGE OVER
197	5-Feb-2020	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	23:22	23:31	0:09	LOAD CHANGE OVER

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
198	5-Feb-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	16:52	17:02	0:10	LINE FAULT
199	5-Feb-2020	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	15:44	15:55	0:11	MAIN SUPPLY FAILURE
200	5-Feb-2020	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI	15:44	15:55	0:11	MAIN SUPPLY FAILURE
201	5-Feb-2020	BENGALURU	66	HAL 220 - B STATION	B STATION	15:44	15:54	0:10	MAIN SUPPLY FAILURE
202	5-Feb-2020	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	15:44	15:56	0:12	MAIN SUPPLY FAILURE
203	5-Feb-2020	BENGALURU	66	HAL 220 - HOODY 1	HAL 220, EDC 220	15:44	15:57	0:13	MAIN SUPPLY FAILURE
204	5-Feb-2020	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	12:32	12:37	0:05	LOAD CHANGEOVER
205	5-Feb-2020	BENGALURU	220	HOODY 400 - HAL 1	HAL 220, EDC 220	15:44	15:50	0:06	LINE CLEAR AVAILED
206	5-Feb-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	6:56	7:01	0:05	LINE FAULT
207	5-Feb-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	12:16	13:16	0:59	LINE FAULT
208	5-Feb-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	10:10	10:30	0:20	LINE FAULT
209	5-Feb-2020	BENGALURU	66	MANCHENAHALLI - GOWRIBIDANUR 220	MANCHENAHALLI	11:22	11:59	0:37	LINE CLEAR AVAILED
210	5-Feb-2020	BENGALURU	220	HV2	HAL 220	15:44	15:52	0:07	MAIN SUPPLY FAILURE
211	5-Feb-2020	BENGALURU	66	HV2	TELECOM LAYOUT	17:55	18:02	0:07	TRANSFORMER FAULT
212	5-Feb-2020	BENGALURU	66	HV1	RR NAGAR	23:08	23:11	0:03	LOAD CHANGEOVER
213	5-Feb-2020	BENGALURU	66	HV2	RR NAGAR	23:08	23:11	0:03	LOAD CHANGEOVER
214	5-Feb-2020	BENGALURU	66	HV1	KHODAYS 220	10:25	10:30	0:04	LINE CLEAR AVAILED
215	5-Feb-2020	BENGALURU	66	HV1	HAL 220	15:44	15:52	0:08	MAIN SUPPLY FAILURE
216	5-Feb-2020	BENGALURU	66	HV2	HAL 220	15:44	15:52	0:08	MAIN SUPPLY FAILURE
217	5-Feb-2020	BENGALURU	66	HV1	A STATION 66	2:29	5:01	2:31	TRANSFORMER FAULT
218	5-Feb-2020	BENGALURU	66	HV1	A STATION 66	3:24	5:01	1:36	LINE CLEAR AVAILED
219	5-Feb-2020	BENGALURU	66	HV1	ADUGODI	12:10	12:13	0:03	LINE CLEAR AVAILED
220	5-Feb-2020	BENGALURU	220	HV1	HAL 220	15:44	15:52	0:08	MAIN SUPPLY FAILURE
221	5-Feb-2020	BENGALURU	66	HV1	ATTIBELE	13:09	13:47	0:37	LINE CLEAR AVAILED
222	5-Feb-2020	BENGALURU	66	HV2	BANGARPET	10:31	13:32	3:00	TRANSFORMER FAULT
223	5-Feb-2020	BENGALURU	66	HV1	BANGARPET	9:50	10:00	0:10	LINE CLEAR AVAILED
224	5-Feb-2020	BENGALURU	66	HV1	NANDIGANAHALLI	11:20	11:25	0:04	LINE CLEAR AVAILED
225	5-Feb-2020	BENGALURU	66	AVANI - KOLAR 220	AVANI, MULBAGALU	20:48	21:04	0:16	LINE CLEAR AVAILED
226	5-Feb-2020	BENGALURU	66	AVANI - MULBAGALU	MULBAGALU	20:48	21:09	0:20	LINE CLEAR AVAILED
227	5-Feb-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	12:50	12:55	0:05	LINE FAULT
228	5-Feb-2020	GULBARGA	66	GUDEKOTE-KUDLIGI	GUDEKOTE_66	7:45	7:55	0:10	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
229	5-Feb-2020	GULBARGA	110	KEMBHAVI-UGARSUGAR	KEMBHAVI_110	3:10	3:15	0:05	LINE FAULT
230	5-Feb-2020	GULBARGA	110	KEMBHAVI_ACMESLR_IPP	KEMBHAVI_110	5:15	5:25	0:10	LINE FAULT
231	5-Feb-2020	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	0:00	11:00	11:00	LINE CLEAR AVAILED
232	5-Feb-2020	GULBARGA	220	SEDAM-RTPS2	RTPS_220	11:40	13:32	1:52	LINE CLEAR AVAILED
233	5-Feb-2020	GULBARGA	220	SEDAM-HUMNABAD2	SEDAM_220	13:44	15:38	1:54	LINE CLEAR AVAILED
234	5-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGUR_IPP	3:02	3:08	0:06	LINE FAULT
235	5-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_110	5:14	5:19	0:05	LINE FAULT
236	5-Feb-2020	GULBARGA	220	HV1	ITTAGI_220	10:05	10:15	0:10	TRANSFORMER FAULT
237	5-Feb-2020	GULBARGA	110	LV1	ITTAGI_220	10:05	10:20	0:15	TRANSFORMER FAULT
238	5-Feb-2020	GULBARGA	220	HV1,LV1	ITTAGI_220	10:20	11:30	1:10	TRANSFORMER FAULT
239	5-Feb-2020	GULBARGA	220	HV1	ITTAGI_220	11:30	12:45	1:15	LINE CLEAR AVAILED
240	5-Feb-2020	GULBARGA	110	LV1	ITTAGI_220	11:30	12:50	1:20	LINE CLEAR AVAILED
241	5-Feb-2020	GULBARGA	110	GABUR-BPSLR_IPP	GABUR_110	0:21	0:30	0:09	LINE FAULT
242	5-Feb-2020	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	19:29	19:34	0:05	LINE FAULT
243	5-Feb-2020	GULBARGA	110	HV2	JEWARGI_110	10:49	13:49	3:00	LINE CLEAR AVAILED
244	5-Feb-2020	GULBARGA	110	HV1	JEWARGI_110	14:39	16:45	2:06	LINE CLEAR AVAILED
245	5-Feb-2020	GULBARGA	66	HBHALLI-ITTAGGI	HAGARIBOMMANAHALLI_66	10:45	10:50	0:05	MAIN SUPPLY FAILURE
246	5-Feb-2020	GULBARGA	110	SIDHANOOR220-TURVIHAL	TURVIHAL_110	22:02	22:13	0:11	LINE FAULT
247	5-Feb-2020	GULBARGA	220	ALIPUR-RAGALPADU	NEELGUNDA_220,GUTTI_220	9:43	19:21	9:38	LINE CLEAR AVAILED
248	5-Feb-2020	GULBARGA	220	HV1	SHAHABAD_220	19:40	23:59	4:19	TRANSFORMER FAULT
249	5-Feb-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:29	15:16	3:47	LINE CLEAR AVAILED
250	5-Feb-2020	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	0:00	12:24	12:24	LINE FAULT
251	5-Feb-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	12:45	16:15	3:30	LINE CLEAR AVAILED
252	5-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	0:00	12:23	12:23	LINE FAULT
253	5-Feb-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	3:20	12:20	9:00	LINE FAULT
254	5-Feb-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	12:43	15:09	2:26	LINE CLEAR AVAILED
255	5-Feb-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	15:57	19:18	3:21	LINE FAULT
256	5-Feb-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	3:20	15:10	11:50	LINE FAULT
257	5-Feb-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	15:57	19:18	3:21	LINE FAULT
258	5-Feb-2020	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	9:45	23:59	14:14	NFBC ISSUED
259	5-Feb-2020	HASSAN	110	HV1	BAIKAMPADI_110	8:08	17:23	9:15	LINE CLEAR AVAILED
260	5-Feb-2020	HASSAN	110	HV2	BAIKAMPADI_110	8:08	17:23	9:15	LINE CLEAR AVAILED
261	5-Feb-2020	HASSAN	110	HV4	BAIKAMPADI_110	8:10	17:23	9:13	LINE CLEAR AVAILED
262	5-Feb-2020	HASSAN	110	HV1	JAVAGAL_110	11:06	18:33	7:27	LINE CLEAR AVAILED
263	5-Feb-2020	HASSAN	110	HV2	JOG_110	9:22	10:29	1:07	LINE CLEAR AVAILED
264	5-Feb-2020	HASSAN	110	HV2	JOG_110	13:56	14:02	0:06	HAND TRIPPED
265	5-Feb-2020	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	7:27	18:02	10:35	LINE CLEAR AVAILED
266	5-Feb-2020	HASSAN	110	HV2	MANIPAL_110	9:45	10:10	0:25	LINE CLEAR AVAILED
267	5-Feb-2020	HASSAN	110	HV	PUTTUR_220	16:06	16:46	0:40	LINE CLEAR AVAILED



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
268	5-Feb-2020	HASSAN	110	HV1	MRSMSG_220	12:39	12:47	0:08	HAND TRIPPED
269	5-Feb-2020	HASSAN	110	HV2	MRSMSG_220	12:36	12:39	0:03	HAND TRIPPED
270	5-Feb-2020	HASSAN	110	HV3	MRSMSG_220	12:07	12:35	0:28	HAND TRIPPED
271	5-Feb-2020	HASSAN	110	HV4	MRSMSG_220	11:47	11:49	0:02	HAND TRIPPED
272	5-Feb-2020	HASSAN	110	HV4	MRSMSG_220	11:57	12:06	0:09	HAND TRIPPED
273	5-Feb-2020	HASSAN	66	LV1	MRSMSG_220	12:39	12:47	0:08	HAND TRIPPED
274	5-Feb-2020	HASSAN	66	LV2	MRSMSG_220	12:36	12:39	0:03	HAND TRIPPED
275	5-Feb-2020	HASSAN	66	LV3	MRSMSG_220	12:07	12:35	0:28	HAND TRIPPED
276	5-Feb-2020	HASSAN	66	LV4	MRSMSG_220	11:47	11:49	0:02	HAND TRIPPED
277	5-Feb-2020	HASSAN	66	LV4	MRSMSG_220	11:57	12:06	0:09	HAND TRIPPED
278	5-Feb-2020	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:25	12:48	2:23	MAIN SUPPLY FAILURE
279	5-Feb-2020	HASSAN	66	HV1	ALDUR_66	10:09	12:47	2:38	MAIN SUPPLY FAILURE
280	5-Feb-2020	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	20:02	20:21	0:19	LINE FAULT
281	5-Feb-2020	HASSAN	66	HV1	K_BYRAPURA_66	4:00	4:05	0:05	TRANSFORMER FAULT
282	5-Feb-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	8:38	8:48	0:10	LINE FAULT
283	5-Feb-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	8:49	12:44	3:55	LINE FAULT
284	5-Feb-2020	HASSAN	66	HASSN220-ARAKALGUD2	HASSAN_220	16:17	16:47	0:30	LINE FAULT
285	5-Feb-2020	HASSAN	66	HASSN220-CRP2	HASSAN_220	8:20	8:30	0:10	LINE FAULT
286	5-Feb-2020	HASSAN	66	HASSN220-UDDURKOPLU	HASSAN_220	4:16	4:36	0:20	LINE FAULT
287	5-Feb-2020	HASSAN	66	HASSN220-SUZLON	HASSAN_220	4:16	4:36	0:20	LINE FAULT
288	5-Feb-2020	HASSAN	66	HASSN220-SUZLON	HASSAN_220	8:37	9:27	0:50	LINE FAULT
289	5-Feb-2020	HASSAN	66	HV1	HASSAN_66	7:42	8:30	0:48	TRANSFORMER FAULT
290	5-Feb-2020	HASSAN	66	HV2	UDAYAPURA_66	9:22	9:28	0:06	TRANSFORMER FAULT
291	5-Feb-2020	HASSAN	66	UDDURKO-SUZLON	UDDURKOPLU_66	4:18	4:36	0:18	MAIN SUPPLY FAILURE
292	5-Feb-2020	HASSAN	66	UDDURKO-SUZLON	UDDURKOPLU_66	7:59	9:27	1:28	LINE FAULT
293	5-Feb-2020	HASSAN	66	UDDURKO-UDDUR	UDDURKOPLU_66	4:16	4:36	0:20	LINE FAULT
294	5-Feb-2020	MYSORE	66	KADAKOLA-NANJANGUDU 1	BEGUR_66 NANJANGUDU_66 SINDHUVALI_66	9:52	9:59	0:06	LINE FAULT
295	5-Feb-2020	MYSORE	66	KADAKOLA-NANJANGUDU 1	BEGUR_66 NANJANGUDU_66 SINDHUVALI_66	9:59	14:08	4:09	LINE FAULT
296	5-Feb-2020	MYSORE	66	KADAKOLA-NANJANGUDU 2	THANDYA_66	9:52	9:57	0:04	LINE FAULT
297	5-Feb-2020	MYSORE	66	KADAKOLA-NANJANGUDU 2	THANDYA_66	9:59	10:10	0:10	LINE FAULT
298	5-Feb-2020	MYSORE	66	HV3	KRPET_66	14:29	14:59	0:29	LINE CLEAR AVAILED
299	5-Feb-2020	MYSORE	66	HV2	SATHEGALA_66	15:46	18:16	2:29	LINE CLEAR AVAILED
300	5-Feb-2020	MYSORE	66	THANDYA-NANJANGUDU	THANDYA_66	10:00	14:11	4:11	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
301	5-Feb-2020	MYSORE	66	TUBINKERE-MC-2	BASARALU_66, BESAGARAHALLI_66, CHIKKA_MANDYA_66, HADLI_66, HAMPAPURA_66, KADKOTHANAHALLI_66, KOPPA_66, MALAVALLI_66, MANDYA_66	16:14	16:44	0:29	LINE FAULT
302	5-Feb-2020	TUMKUR	220	TR-1(HV SIDE)	CHITRADURGA_220	8:06	10:20	2:13	TRANSFORMER FAULT
303	5-Feb-2020	TUMKUR	220	TR-1(HV SIDE)	KBCROSS_220	13:39	19:04	5:24	LINE CLEAR AVAILED
304	5-Feb-2020	TUMKUR	110	TR-1	BIDARE_110	12:06	13:03	0:56	LINE CLEAR AVAILED
305	5-Feb-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	12:06	13:13	1:06	LINE CLEAR AVAILED
306	5-Feb-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	4:36	4:46	0:09	LINE FAULT
307	5-Feb-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	10:36	10:38	0:02	LINE FAULT
308	5-Feb-2020	TUMKUR	110	TR-1(LV SIDE )	KBCROSS_220	12:43	19:06	6:22	LINE CLEAR AVAILED
309	5-Feb-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	4:37	4:50	0:13	LINE FAULT
310	5-Feb-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	10:36	10:48	0:11	LINE FAULT
311	5-Feb-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	19:20	19:28	0:08	LINE FAULT
312	5-Feb-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	21:33	21:34	0:01	TRANSFORMER FAULT
313	5-Feb-2020	TUMKUR	66	TR-1	CHITRADURGA_220	8:06	10:21	2:14	TRANSFORMER FAULT
314	5-Feb-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	10:17	10:28	0:10	HAND TRIPPED
315	5-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	8:22	8:26	0:04	LINE FAULT
316	6-Feb-2020	BAGALKOT	110	110/11KV,HV 4	GAJENDRAGAD_110	7:15	7:27	0:12	LOAD CURTAILMENT
317	6-Feb-2020	BAGALKOT	110	110/11KV,HV 2	HIDIKAL_110	9:30	10:25	0:55	TRANSFORMER FAULT
318	6-Feb-2020	BAGALKOT	110	INDI-LACHYAL TO HIREBEVANUR	HIREBEVANUR_110	21:58	22:06	0:08	HAND TRIPPED
319	6-Feb-2020	BAGALKOT	110	110/11KV,HV 1	HIREKERUR_110	16:19	16:44	0:25	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
320	6-Feb-2020	BAGALKOT	110	110/11KV, HV2	UGARKHUD_110	9:14	9:16	0:02	TRANSFORMER FAULT
321	6-Feb-2020	BAGALKOT	220	SHARAVATHY2-SIRSI	SIRSI_220	0:00	18:47	18:47	LINE CLEAR AVAILED
322	6-Feb-2020	BAGALKOT	220	SHARAVATHY1-SIRSI	SIRSI_220	10:04	23:59	13:55	LINE CLEAR AVAILED
323	6-Feb-2020	BAGALKOT	220	220/110KV, HV1&LV1	SIRSI_220	10:02	19:05	9:03	LINE CLEAR AVAILED
324	6-Feb-2020	BAGALKOT	220	SIRSI-HUBLI1&2	SIRSI_220	10:08	18:49	8:41	LINE CLEAR AVAILED
325	6-Feb-2020	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	7:15	7:23	0:08	LOAD CURTAILMENT
326	6-Feb-2020	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)- RANEENNUR	RANEENNUR_220	0:00	6:39	6:39	LINE CLEAR AVAILED
327	6-Feb-2020	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	6:39	9:22	2:43	LINE CLEAR AVAILED
328	6-Feb-2020	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)- RANEENNUR	RANEENNUR_220	9:22	23:59	14:37	LINE CLEAR AVAILED
329	6-Feb-2020	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	14:22	14:25	0:03	TRANSFORMER FAULT
330	6-Feb-2020	BAGALKOT	110	110/33KV, HV2	MURDESHWAR_110	14:05	14:19	0:14	LINE CLEAR AVAILED
331	6-Feb-2020	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	0:00	19:45	19:45	LINE CLEAR AVAILED
332	6-Feb-2020	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	9:54	19:41	9:47	LINE CLEAR AVAILED
333	6-Feb-2020	BAGALKOT	220	BIJAPUR220-BAGEWADI1	BIJAPUR_220	21:02	22:39	1:37	LINE FAULT
334	6-Feb-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	12:00	14:46	2:46	LINE CLEAR AVAILED
335	6-Feb-2020	BAGALKOT	220	KUDUCHI-MAHALINNGAPUR2	KUDUCHI_220	14:10	18:55	4:45	LINE CLEAR AVAILED
336	6-Feb-2020	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	0:00	9:54	9:54	LINE CLEAR AVAILED
337	6-Feb-2020	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	19:11	23:59	4:48	LINE CLEAR AVAILED
338	6-Feb-2020	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(G)_110	10:45	13:55	3:10	TRANSFORMER FAULT
339	6-Feb-2020	BAGALKOT	110	110/11KV,HV1	MAMADAPUR(G)_110	10:45	11:35	0:50	HAND TRIPPED
340	6-Feb-2020	BAGALKOT	110	GOKAK-MAMADAPUR(G)	MAMADAPUR(G)_110	10:45	11:25	0:40	HAND TRIPPED
341	6-Feb-2020	BAGALKOT	110	SOUBHAGYALAKSHMI-MAMADAPUR(G)	MAMADAPUR(G)_110	10:45	11:35	0:50	HAND TRIPPED
342	6-Feb-2020	BAGALKOT	400	GUTTUR-DHONI	DHONI_400	12:32	16:02	3:30	NFBC ISSUED
343	6-Feb-2020	BAGALKOT	400	GUDDADAHALLI-DHONI	DHONI_400	12:32	16:06	3:34	NFBC ISSUED
344	6-Feb-2020	BENGALURU	66	HOODY 220 - HAL 2	BAGMANE WORLD TECH PARK	6:27	8:26	1:58	LINE FAULT
345	6-Feb-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	20:10	20:18	0:07	LINE FAULT
346	6-Feb-2020	BENGALURU	66	BAGHMANE WORLD TECH PARK - HOODY 2	BAGHMANE WORLD TECH PARK	6:26	8:38	2:11	LINE FAULT
347	6-Feb-2020	BENGALURU	66	BAGHMANE WORLD TECH PARK - HOODY 1	BAGHMANE WORLD TECH PARK	6:26	7:20	0:53	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
348	6-Feb-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	8:26	9:34	1:07	LINE CLEAR AVAILED
349	6-Feb-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	17:21	18:31	1:09	LINE CLEAR AVAILED
350	6-Feb-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	12:53	12:58	0:05	LINE CLEAR AVAILED
351	6-Feb-2020	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	12:53	12:58	0:04	LINE CLEAR AVAILED
352	6-Feb-2020	BENGALURU	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	10:26	16:39	6:12	LINE CLEAR AVAILED
353	6-Feb-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	10:55	12:30	1:35	MAIN SUPPLY FAILURE
354	6-Feb-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	13:13	13:20	0:06	LINE CLEAR AVAILED
355	6-Feb-2020	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	10:55	12:10	1:15	MAIN SUPPLY FAILURE
356	6-Feb-2020	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	13:13	13:19	0:05	LINE CLEAR AVAILED
357	6-Feb-2020	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	7:36	7:55	0:19	MAIN SUPPLY FAILURE
358	6-Feb-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	7:51	7:55	0:03	LOAD CHANGEOVER
359	6-Feb-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	9:51	9:55	0:04	LOAD CHANGEOVER
360	6-Feb-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	10:25	10:32	0:07	LOAD CHANGEOVER
361	6-Feb-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	11:41	11:44	0:02	LOAD CHANGEOVER
362	6-Feb-2020	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, BIEC	7:36	10:33	2:57	LINE FAULT
363	6-Feb-2020	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR	11:21	11:28	0:07	LOAD CHANGEOVER
364	6-Feb-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:55	12:35	1:40	MAIN SUPPLY FAILURE
365	6-Feb-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	12:15	13:30	1:15	LINE CLEAR AVAILED
366	6-Feb-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	20:11	20:18	0:07	LINE FAULT
367	6-Feb-2020	BENGALURU	66	HV2	RR NAGAR	13:32	13:33	0:01	LINE CLEAR AVAILED
368	6-Feb-2020	BENGALURU	66	HV1	CHAKAVELU	18:08	18:10	0:01	LINE CLEAR AVAILED
369	6-Feb-2020	BENGALURU	66	HV2	RR NAGAR	13:32	13:33	0:01	LINE CLEAR AVAILED
370	6-Feb-2020	BENGALURU	220	LV3	KOLAR 220	10:55	11:16	0:21	TRANSFORMER FAULT
371	6-Feb-2020	BENGALURU	220	LV3	KOLAR 220	11:16	12:55	1:39	TRANSFORMER FAULT
372	6-Feb-2020	BENGALURU	66	HV1	MUDIYANUR	21:04	21:20	0:15	TRANSFORMER FAULT
373	6-Feb-2020	BENGALURU	66	HV1	NANDIGANAHALLI	15:52	18:05	2:12	LINE CLEAR AVAILED
374	6-Feb-2020	BENGALURU	66	HV1	SURYANAGAR	9:20	9:38	0:18	LINE CLEAR AVAILED
375	6-Feb-2020	BENGALURU	66	HV2	TEKAL	14:01	16:32	2:31	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
376	6-Feb-2020	GULBARGA	110	ALIPUR-BELLARYNORTH	BELLARYNORTH_110,SOMASAM UDRA_110,MOKA_110,PDHALLI_110,BISHALLI_110,JANAKI_IPP,BA SAISTEELAACC_IPP	13:18	15:53	2:35	LINE CLEAR AVAILED
377	6-Feb-2020	GULBARGA	110	HV1	BETAGERA_110	11:20	14:30	3:10	LINE CLEAR AVAILED
378	6-Feb-2020	GULBARGA	66	HV1	CJHALLI_66	8:35	8:55	0:20	LINE CLEAR AVAILED
379	6-Feb-2020	GULBARGA	66	HV2	CJHALLI_66	8:35	17:59	9:24	LINE CLEAR AVAILED
380	6-Feb-2020	GULBARGA	220	HV1	ITTAGI_220	10:00	10:06	0:06	TRANSFORMER FAULT
381	6-Feb-2020	GULBARGA	220	HV1	ITTAGI_220	1:20	1:30	0:10	TRANSFORMER FAULT
382	6-Feb-2020	GULBARGA	220	KAPNOOR-SHAHABAD	SHAHABAD_220	10:40	16:58	6:18	NFBC ISSUED
383	6-Feb-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	2:35	2:42	0:07	LINE FAULT
384	6-Feb-2020	GULBARGA	220	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	11:50	12:46	0:56	NFBC ISSUED
385	6-Feb-2020	GULBARGA	110	HV1	TEKKALKOTE_110	11:12	11:18	0:06	TRANSFORMER FAULT
386	6-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGUR_IPP	18:24	18:31	0:07	LINE FAULT
387	6-Feb-2020	GULBARGA	110	HV2	YELBURGA_110	12:40	12:48	0:08	TRANSFORMER FAULT
388	6-Feb-2020	GULBARGA	110	HV2	YELBURGA_110	14:10	14:15	0:05	TRANSFORMER FAULT
389	6-Feb-2020	GULBARGA	110	PDHALLI-ALIPUR	PDHALLI_110	13:18	16:15	2:57	MAIN SUPPLY FAILURE
390	6-Feb-2020	GULBARGA	110	PDHALLI-ALIPUR	PDHALLI_110	18:20	18:25	0:05	MAIN SUPPLY FAILURE
391	6-Feb-2020	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	11:21	11:37	0:16	MAIN SUPPLY FAILURE
392	6-Feb-2020	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	9:39	12:37	2:58	LINE CLEAR AVAILED
393	6-Feb-2020	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	11:21	12:57	1:36	LINE FAULT
394	6-Feb-2020	HASSAN	220	KAVOOR-KADUR	MRSMSG_220	14:27	14:45	0:18	LINE FAULT
395	6-Feb-2020	HASSAN	220	KAVOOR-SHARAVATHY2	MRSMSG_220	22:47	23:59	1:12	LINE FAULT
396	6-Feb-2020	HASSAN	220	HV1	MSEZ_220	11:20	11:43	0:23	TRANSFORMER FAULT
397	6-Feb-2020	HASSAN	220	HV2	MSEZ_220	11:20	11:43	0:23	TRANSFORMER FAULT
398	6-Feb-2020	HASSAN	220	KAVOOR-KAVOOR1	MSEZ_220	9:39	12:37	2:58	NFBC ISSUED
399	6-Feb-2020	HASSAN	220	KAVOOR-KAVOOR2	MSEZ_220	11:20	12:57	1:37	LINE FAULT
400	6-Feb-2020	HASSAN	220	KAVOOR-KEMAR1	MSEZ_220	11:20	12:01	0:41	LINE FAULT
401	6-Feb-2020	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	11:47	11:56	0:09	HAND TRIPPED
402	6-Feb-2020	HASSAN	110	KAVOOR-AMR	KAVOOR_220	11:46	11:51	0:05	HAND TRIPPED
403	6-Feb-2020	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	11:20	11:54	0:34	LINE FAULT
404	6-Feb-2020	HASSAN	110	LV1	MSEZ_220	11:20	11:43	0:23	TRANSFORMER FAULT
405	6-Feb-2020	HASSAN	110	LV2	MSEZ_220	11:20	14:21	3:01	TRANSFORMER FAULT
406	6-Feb-2020	HASSAN	220	KAVOOR-SHIMOGA1	sharavathy_gen	22:47	23:59	1:12	LINE FAULT
407	6-Feb-2020	HASSAN	220	KAVOOR-SIRISI 1	sharavathy_gen	10:04	23:59	13:55	NFBC ISSUED
408	6-Feb-2020	HASSAN	220	KAVOOR-SIRISI 2	sharavathy_gen	0:00	18:47	18:47	NFBC ISSUED
409	6-Feb-2020	HASSAN	110	HV2	BAIKAMPADI_110	11:29	12:03	0:34	MAIN SUPPLY FAILURE
410	6-Feb-2020	HASSAN	110	HV3	BAIKAMPADI_110	11:29	12:03	0:34	MAIN SUPPLY FAILURE
411	6-Feb-2020	HASSAN	110	HV1	BRAHMAVA	7:15	7:30	0:15	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
412	6-Feb-2020	HASSAN	110	KADUR-YGTI	KADUR_220	13:08	14:07	0:59	LINE FAULT
413	6-Feb-2020	HASSAN	110	HV1	KEMAR_220	6:58	7:40	0:42	LINE CLEAR AVAILED
414	6-Feb-2020	HASSAN	110	HV2	KONAJE_110	11:20	11:37	0:17	MAIN SUPPLY FAILURE
415	6-Feb-2020	HASSAN	110	HV2	KONAJE_110	11:47	11:58	0:11	MAIN SUPPLY FAILURE
416	6-Feb-2020	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	10:01	13:13	3:12	NFBC ISSUED
417	6-Feb-2020	HASSAN	110	HV2	MANIPAL_110	9:10	10:04	0:54	LINE CLEAR AVAILED
418	6-Feb-2020	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	14:57	15:42	0:45	LINE FAULT
419	6-Feb-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	0:10	0:22	0:12	TRANSFORMER FAULT
420	6-Feb-2020	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	18:33	18:41	0:08	LINE FAULT
421	6-Feb-2020	HASSAN	66	HV1	HNPURA_66	13:21	13:55	0:34	LINE CLEAR AVAILED
422	6-Feb-2020	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	13:26	13:42	0:16	HAND TRIPPED
423	6-Feb-2020	HASSAN	66	HV1	SINGAPURA_66	10:59	11:03	0:04	HAND TRIPPED
424	6-Feb-2020	HASSAN	66	HV2	UDAYAPURA_66	8:28	8:32	0:04	TRANSFORMER FAULT
425	6-Feb-2020	MYSORE	66	HV1	BESAGARAHALLI_66	7:14	7:45	0:30	LOAD CURTAILMENT
426	6-Feb-2020	MYSORE	66	HV1	BOMMALAPURA_66	8:11	12:19	4:08	LINE CLEAR AVAILED
427	6-Feb-2020	MYSORE	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	16:09	17:14	1:05	LINE FAULT
428	6-Feb-2020	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HDKOTE_66 HAMPAPURA(K)_66 ANTHARSANTHE_66	15:17	15:24	0:07	LINE FAULT
429	6-Feb-2020	MYSORE	66	HV1	KOLLEGALA_66	10:32	16:22	5:49	LINE CLEAR AVAILED
430	6-Feb-2020	MYSORE	66	HV1	SATHEGALA_66	7:14	7:17	0:02	LOAD CURTAILMENT
431	6-Feb-2020	MYSORE	66	HV2	SATHEGALA_66	11:37	12:39	1:01	LINE CLEAR AVAILED
432	6-Feb-2020	MYSORE	66	HV5	SFCSHIVA_66	12:15	23:59	11:43	LINE CLEAR AVAILED
433	6-Feb-2020	MYSORE	66	HV1	SUNTIKOPPA_66	11:29	17:04	5:34	LINE CLEAR AVAILED
434	6-Feb-2020	MYSORE	66	SUNTIKOPPA-KUSHALNAGARA	SUNTIKOPPA_66	13:14	17:00	3:45	LINE CLEAR AVAILED
435	6-Feb-2020	MYSORE	66	HV1	YELANDUR_66	7:14	7:25	0:10	LOAD CURTAILMENT
436	6-Feb-2020	TUMKUR	220	TR-1	MADHUGIRI_220	12:33	13:01	0:27	LINE CLEAR AVAILED
437	6-Feb-2020	TUMKUR	220	TR-2	MADHUGIRI_220	13:03	13:43	0:39	LINE CLEAR AVAILED
438	6-Feb-2020	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110,	2:10	2:25	0:15	LINE FAULT
439	6-Feb-2020	TUMKUR	110	TR-1	GUNGURMALE_110	12:46	14:03	1:17	LINE CLEAR AVAILED
440	6-Feb-2020	TUMKUR	110	NITTUR 220kV- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	6:55	7:26	0:30	LOAD CURTAILMENT
441	6-Feb-2020	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	7:27	7:57	0:30	LOAD CURTAILMENT
442	6-Feb-2020	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	5:56	6:54	0:57	LOAD CURTAILMENT
443	6-Feb-2020	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	5:56	6:53	0:57	LOAD CURTAILMENT
444	6-Feb-2020	TUMKUR	66	ANCHEPALYA 66kV-ANCHEPALYA 1	ANCHEPALYA_66,BHAKTHARAHALLI_66,THIMMASANDRA_66	14:04	14:11	0:06	LOAD CURTAILMENT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
445	6-Feb-2020	TUMKUR	66	BANUVALLI- NANDUGUDI	NANDIGUDI_66	16:35	17:14	0:39	LINE CLEAR AVAILED
446	6-Feb-2020	TUMKUR	66	BANUVALLI- NANDUGUDI	NANDIGUDI_66	22:29	22:56	0:27	MAIN SUPPLY FAILURE
447	6-Feb-2020	TUMKUR	66	BASAVAPATNA- SRS DAVANAGERE	BASAVAPATNA_66	11:52	13:43	1:50	LINE CLEAR AVAILED
448	6-Feb-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	13:28	14:03	0:34	LINE CLEAR AVAILED
449	6-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:33	9:38	0:04	LINE FAULT
450	6-Feb-2020	TUMKUR	66	TR-1	DAVANGERE_SRS_220	10:32	10:43	0:10	TRANSFORMER FAULT
451	6-Feb-2020	TUMKUR	66	TR-1	HIRIYUR_66	6:52	6:58	0:06	TRANSFORMER FAULT
452	6-Feb-2020	TUMKUR	66	TR-1	HIRIYUR_66	7:05	7:10	0:05	TRANSFORMER FAULT
453	6-Feb-2020	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	22:24	22:54	0:30	LINE FAULT
454	6-Feb-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-2	INFOSYS-2	13:04	13:32	0:27	HAND TRIPPED
455	6-Feb-2020	TUMKUR	66	TR-2	KUKKAWADA_66	10:03	10:07	0:04	TRANSFORMER FAULT
456	6-Feb-2020	TUMKUR	66	TR-1	MADHUGIRI_220	12:33	13:01	0:27	LINE CLEAR AVAILED
457	6-Feb-2020	TUMKUR	66	TR-2	MADHUGIRI_220	13:03	13:43	0:40	LINE CLEAR AVAILED
458	6-Feb-2020	TUMKUR	66	NITRAHALLI 66 -CLEAN SOLAR	CLEANMAXSOLAR_IPP_66	18:25	18:34	0:08	HAND TRIPPED
459	6-Feb-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	7:12	7:28	0:15	LINE FAULT
460	6-Feb-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	8:21	8:37	0:16	LINE FAULT
461	6-Feb-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	9:10	9:28	0:17	LINE FAULT
462	6-Feb-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	16:18	16:33	0:15	LINE FAULT
463	7-Feb-2020	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	RANNABELAGALI_110	12:48	17:50	5:02	LINE CLEAR AVAILED
464	7-Feb-2020	BAGALKOT	110	110/11KV,HV-2	SHIROL_110	12:05	13:38	1:33	LINE CLEAR AVAILED
465	7-Feb-2020	BAGALKOT	110	110/11KV,HV-2	SHIROL_110	17:00	17:30	0:30	LINE CLEAR AVAILED
466	7-Feb-2020	BAGALKOT	110	110/11KV,HV-2	SHIROL_110	8:30	8:40	0:10	TRANSFORMER FAULT
467	7-Feb-2020	BAGALKOT	220	SHIRALKOPPA(BALLIGAVI)- RANEENNUR	RANEENNUR_220	0:00	6:31	6:31	LINE CLEAR AVAILED
468	7-Feb-2020	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	6:31	8:35	2:04	LINE CLEAR AVAILED
469	7-Feb-2020	BAGALKOT	220	SHIRALKOPPA(BALLIGAVI)- RANEENNUR	RANEENNUR_220	8:35	23:59	15:24	LINE CLEAR AVAILED
470	7-Feb-2020	BAGALKOT	220	ATHANI-MAHALINGAPUR	ATHANI_220	9:30	13:17	3:47	LINE CLEAR AVAILED
471	7-Feb-2020	BENGALURU	66	HV1	CHAKKAVELU	13:50	13:53	0:03	LINE CLEAR AVAILED
472	7-Feb-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	6:38	6:42	0:04	LINE CLEAR AVAILED
473	7-Feb-2020	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	17:17	17:36	0:19	LOAD CHANGEOVER
474	7-Feb-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	15:15	16:12	0:57	LINE CLEAR AVAILED
475	7-Feb-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	10:48	13:45	2:57	LINE CLEAR AVAILED
476	7-Feb-2020	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	10:10	16:30	6:20	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
477	7-Feb-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	17:50	18:00	0:10	LOAD CURTAILMENT
478	7-Feb-2020	BENGALURU	66	HV1	SURYANAGARA	9:20	9:38	0:18	LINE CLEAR AVAILED
479	7-Feb-2020	BENGALURU	66	IISC - HEBBAL 220	IISC	7:27	7:33	0:06	LOAD CHANGEOVER
480	7-Feb-2020	BENGALURU	66	IISC - NRS 220	IISC	17:44	17:50	0:06	LOAD CHANGEOVER
481	7-Feb-2020	BENGALURU	66	HOODY 220 - SHANTHINIKETHAN	SHANTHINIKETHAN	13:30	15:43	2:13	LINE FAULT
482	7-Feb-2020	BENGALURU	66	HV1	HANUMANTHNAGAR	9:05	9:19	0:13	TRANSFORMER FAULT
483	7-Feb-2020	BENGALURU	66	HV2	NRS 220	22:16	22:25	0:08	LINE CLEAR AVAILED
484	7-Feb-2020	BENGALURU	66	HOODY 220 - SHANTHINIKETHAN	SHANTHINIKETHAN	15:43	16:28	0:45	LINE FAULT
485	7-Feb-2020	GULBARGA	220	KAPNOOR-SHAHABAD	SHAHABAD_220	15:05	16:45	1:40	NFBC ISSUED
486	7-Feb-2020	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	7:40	14:05	6:25	NFBC ISSUED
487	7-Feb-2020	GULBARGA	220	HV1	LINGASUGUR_220	11:18	14:20	3:02	LINE CLEAR AVAILED
488	7-Feb-2020	GULBARGA	220	HV1	KUSTIGI_220	15:26	17:17	1:51	LINE CLEAR AVAILED
489	7-Feb-2020	GULBARGA	110	HV1	CHINCHOLI_110	7:16	7:32	0:16	TRANSFORMER FAULT
490	7-Feb-2020	GULBARGA	110	HV2	DEODURGA_110	10:05	10:10	0:05	TRANSFORMER FAULT
491	7-Feb-2020	GULBARGA	110	HV2	HATTI_110	7:50	7:59	0:09	TRANSFORMER FAULT
492	7-Feb-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	4:20	4:30	0:10	LINE FAULT
493	7-Feb-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	6:07	6:13	0:06	LINE FAULT
494	7-Feb-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110,SAIDAPUR_110	6:17	6:26	0:09	LINE FAULT
495	7-Feb-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	3:39	3:58	0:19	LINE FAULT
496	7-Feb-2020	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110, VADAVATTI_110	6:16	6:36	0:20	LINE FAULT
497	7-Feb-2020	GULBARGA	110	HV1	RAICHUR_220	14:36	14:44	0:08	TRANSFORMER FAULT
498	7-Feb-2020	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110, MANVI_110	15:35	15:40	0:05	LINE FAULT
499	7-Feb-2020	GULBARGA	110	HV2	ALLIPUR_220	10:55	12:59	2:04	LINE CLEAR AVAILED
500	7-Feb-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110,SAIDAPUR_110	23:15	23:53	0:38	LINE FAULT
501	7-Feb-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	6:30	9:42	3:12	LINE CLEAR AVAILED
502	7-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMG_220	0:00	10:08	10:08	LINE FAULT
503	7-Feb-2020	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	0:00	10:08	10:08	LINE FAULT
504	7-Feb-2020	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	0:00	18:00	18:00	NFBC ISSUED
505	7-Feb-2020	HASSAN	110	HV1	HALADY_110	7:17	7:37	0:20	LOAD CURTAILMENT
506	7-Feb-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	9:03	9:13	0:10	LINE FAULT
507	7-Feb-2020	HASSAN	110	HV1	ARASIKERE_110	15:16	16:52	1:36	LINE CLEAR AVAILED
508	7-Feb-2020	HASSAN	110	HV2	GERUMARA_110	7:17	7:44	0:27	LOAD CURTAILMENT
509	7-Feb-2020	HASSAN	110	HV1	BRAHMAVARA_110	7:17	7:31	0:14	LOAD CURTAILMENT
510	7-Feb-2020	HASSAN	66	HV1	HALLIMYSORE_66	7:17	7:26	0:09	LOAD CURTAILMENT
511	7-Feb-2020	HASSAN	66	HV1	HANGARANAHALLY_66	7:17	7:32	0:15	LOAD CURTAILMENT
512	7-Feb-2020	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	19:53	19:58	0:05	LINE FAULT
513	7-Feb-2020	HASSAN	66	HV2	UDAYAPURA_66	8:31	8:35	0:04	TRANSFORMER FAULT



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
514	7-Feb-2020	HASSAN	66	HV2	BASAVAGHATTA_66	7:16	7:26	0:10	LOAD CURTAILMENT
515	7-Feb-2020	MYSORE	66	HV2	ADDIHALLI_66	7:16	7:26	0:09	LOAD CURTAILMENT
516	7-Feb-2020	MYSORE	66	HV1	DODDINADUVADI_66	7:16	7:22	0:06	LOAD CURTAILMENT
517	7-Feb-2020	MYSORE	66	DUNDANAHALLY-HULIYURDURGA	DUNDANAHALLI_66	17:10	18:56	1:46	LINE CLEAR AVAILED
518	7-Feb-2020	MYSORE	66	HV1	HEBBAL_66	9:16	9:20	0:03	TRANSFORMER FAULT
519	7-Feb-2020	MYSORE	66	HV1	HEBBAL_66	13:37	13:43	0:06	TRANSFORMER FAULT
520	7-Feb-2020	MYSORE	66	HV2	JAIPUR_66	7:16	7:34	0:17	LOAD CURTAILMENT
521	7-Feb-2020	MYSORE	66	KADAKOLA-SARAGURU 2	B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66, CHANDRAVADI_66	8:26	8:30	0:03	LINE FAULT
522	7-Feb-2020	MYSORE	66	KADAKOLA-SARAGURU 1	JAIPUR_66 HDKOTE_66 HAMPAPURA(K)_66 ANTHARSANTHE_66	8:26	8:30	0:03	LINE FAULT
523	7-Feb-2020	MYSORE	66	KADAKOLA-SARAGURU 1	JAIPUR_66 HDKOTE_66 HAMPAPURA(K)_66 ANTHARSANTHE_66	8:34	8:37	0:02	LINE FAULT
524	7-Feb-2020	MYSORE	66	HV2	KMDODDI_66	7:16	7:45	0:28	LOAD CURTAILMENT
525	7-Feb-2020	MYSORE	66	HV2	KOLLEGALA_66	7:16	7:36	0:19	LOAD CURTAILMENT
526	7-Feb-2020	MYSORE	66	HV1	KUSHALANAGARA_66	7:16	7:32	0:15	LOAD CURTAILMENT
527	7-Feb-2020	MYSORE	66	KUSHALANAGARA 220-MYSORE-1	MIRLE_66	16:08	16:19	0:11	LINE FAULT
528	7-Feb-2020	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	8:43	8:48	0:05	LINE FAULT
529	7-Feb-2020	MYSORE	66	HV3	SFCSHIVA_66	15:07	16:00	0:52	HAND TRIPPED
530	7-Feb-2020	MYSORE	66	HV4	SFCSHIVA_66	15:06	16:00	0:53	HAND TRIPPED
531	7-Feb-2020	TUMKUR	220	TR-1( HV SIDE)	HIRIYUR_220	8:36	17:50	9:14	LINE CLEAR AVAILED
532	7-Feb-2020	TUMKUR	110	TR-1	BIDARE_110	17:32	18:24	0:51	LINE CLEAR AVAILED
533	7-Feb-2020	TUMKUR	110	TR-2	KADEHALLI_110	22:07	22:15	0:08	TRANSFORMER FAULT
534	7-Feb-2020	TUMKUR	110	TR-1	KBCROSS_220	11:02	13:27	2:24	LINE CLEAR AVAILED
535	7-Feb-2020	TUMKUR	110	TR-2	KBCROSS_220	11:02	13:27	2:24	LINE CLEAR AVAILED
536	7-Feb-2020	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	7:14	7:43	0:28	LOAD CURTAILMENT
537	7-Feb-2020	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	7:14	7:42	0:27	LOAD CURTAILMENT
538	7-Feb-2020	TUMKUR	66	TR-2	AVAREGERE_66	16:56	17:19	0:22	TRANSFORMER FAULT
539	7-Feb-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	1:09	1:11	0:01	TRANSFORMER FAULT
540	7-Feb-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	6:58	7:01	0:03	TRANSFORMER FAULT
541	7-Feb-2020	TUMKUR	66	TR-1	CHIKKABANAGERE_66	13:34	13:39	0:04	TRANSFORMER FAULT
542	7-Feb-2020	TUMKUR	66	TR-1	CHIKKABANAGERE_66	15:04	15:07	0:03	HAND TRIPPED
543	7-Feb-2020	TUMKUR	66	TR-2	DAVANAGERE_66	12:47	13:19	0:32	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
544	7-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	7:33	9:45	2:12	LINE FAULT
545	7-Feb-2020	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:14	7:17	0:02	LINE FAULT
546	7-Feb-2020	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	14:05	14:19	0:14	LINE CLEAR AVAILED
547	7-Feb-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	14:01	14:09	0:08	TRANSFORMER FAULT
548	7-Feb-2020	TUMKUR	66	NAGASAMUDRA- IPP_SOLAR	IPP_SOLAR	19:38	19:45	0:07	LINE CLEAR AVAILED
549	7-Feb-2020	TUMKUR	66	NAGASAMUDRA- IPP_SOLAR	IPP_SOLAR	20:02	20:04	0:01	LINE CLEAR AVAILED
550	7-Feb-2020	TUMKUR	66	NAGASAMUDRA- RAMPUR	NAGASAMUDRA_66, RAMPURA_66	16:50	19:03	2:12	LINE CLEAR AVAILED
551	7-Feb-2020	TUMKUR	66	NEELAGUNDA-HARPANAHALLI-1	HARAPPANAHALLI_66	6:06	6:43	0:37	LINE FAULT
552	7-Feb-2020	TUMKUR	66	TR-1	PAVAGADA_220	9:02	9:11	0:09	TRANSFORMER FAULT
553	7-Feb-2020	TUMKUR	66	TR-1	PAVAGADA_220	11:10	11:14	0:04	TRANSFORMER FAULT
554	7-Feb-2020	TUMKUR	66	RAMPURA66-ABLETEC(SSHTY)_IPP_66	ABLETEC(SSHTY)_IPP_66	16:45	19:11	2:25	LINE CLEAR AVAILED
555	7-Feb-2020	TUMKUR	66	RAMPURA66-CLEAN SOLAR_IPP_66	CLEAN SOLAR_IPP_66	16:47	19:30	2:43	LINE CLEAR AVAILED
556	7-Feb-2020	TUMKUR	66	TR-1	SHYLAPURA_66	21:23	21:59	0:35	HAND TRIPPED
557	7-Feb-2020	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	0:54	1:55	1:01	LINE FAULT
558	7-Feb-2020	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	8:52	9:29	0:37	LINE CLEAR AVAILED
559	8-Feb-2020	BAGALKOT	220	SHIRALKOPPA(BALLIGAVI)- RANEENNUR	RANEENNUR_220	0:00	6:42	6:42	LINE CLEAR AVAILED
560	8-Feb-2020	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	6:42	9:10	2:28	LINE CLEAR AVAILED
561	8-Feb-2020	BAGALKOT	220	SHIRALKOPPA(BALLIGAVI)- RANEENNUR	RANEENNUR_220	9:10	23:59	14:49	LINE CLEAR AVAILED
562	8-Feb-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	7:58	8:06	0:08	LINE FAULT
563	8-Feb-2020	BENGALURU	66	HV2	T K HALLI 220	17:14	17:22	0:08	TRANSFORMER FAULT
564	8-Feb-2020	BENGALURU	220	HV2	CHINTAMANI	16:06	22:41	6:35	TRANSFORMER FAULT
565	8-Feb-2020	BENGALURU	220	HV2	CHINTAMANI	22:41	22:48	0:07	TRANSFORMER FAULT
566	8-Feb-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	16:06	17:26	1:20	LINE FAULT
567	8-Feb-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	11:00	11:17	0:17	LINE CLEAR AVAILED
568	8-Feb-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	11:00	11:17	0:17	LINE CLEAR AVAILED
569	8-Feb-2020	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	11:00	11:17	0:17	LINE CLEAR AVAILED
570	8-Feb-2020	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	11:00	11:17	0:17	LINE CLEAR AVAILED
571	8-Feb-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:00	11:15	0:15	LINE CLEAR AVAILED
572	8-Feb-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	11:00	11:15	0:15	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
573	8-Feb-2020	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	11:00	11:15	0:15	LINE CLEAR AVAILED
574	8-Feb-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	13:11	13:18	0:07	LINE CLEAR AVAILED
575	8-Feb-2020	BENGALURU	220	HV1	D B PURA	11:05	11:09	0:04	LINE CLEAR AVAILED
576	8-Feb-2020	BENGALURU	220	HV2	D B PURA	11:05	11:11	0:06	LINE CLEAR AVAILED
577	8-Feb-2020	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	10:00	16:55	6:55	LINE CLEAR AVAILED
578	8-Feb-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	6:36	6:51	0:15	LINE FAULT
579	8-Feb-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	11:15	13:07	1:52	LINE CLEAR AVAILED
580	8-Feb-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	16:41	16:46	0:05	LINE CLEAR AVAILED
581	8-Feb-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	20:05	20:12	0:07	LINE CLEAR AVAILED
582	8-Feb-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	9:10	9:35	0:25	LOAD CURTAILMENT
583	8-Feb-2020	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR	9:15	9:30	0:15	LOAD CURTAILMENT
584	8-Feb-2020	BENGALURU	220	HV3	KOLAR 220	10:20	10:40	0:20	TRANSFORMER FAULT
585	8-Feb-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	10:20	10:41	0:21	LINE CLEAR AVAILED
586	8-Feb-2020	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	10:20	10:41	0:21	LINE CLEAR AVAILED
587	8-Feb-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:20	10:41	0:21	LINE CLEAR AVAILED
588	8-Feb-2020	BENGALURU	66	HV1	SULIBELE	16:35	17:05	0:30	LINE CLEAR AVAILED
589	8-Feb-2020	BENGALURU	66	HV1	VOLVO	17:17	17:28	0:11	LINE CLEAR AVAILED
590	8-Feb-2020	BENGALURU	66	YELAHANKA 220 - LINE 3	ATTUR,ESCORTS (EHT)	16:18	16:58	0:40	LINE FAULT
591	8-Feb-2020	BENGALURU	66	YELAHANKA 220 - LINE 6	SOLADEVANAHALLI	10:30	11:19	0:49	LINE FAULT
592	8-Feb-2020	BENGALURU	220	YELAHANKA 220 - MANYATHA TECH PARK 220	MANYATHA TECH PARK,HEBBAL	10:30	11:12	0:42	LINE FAULT
593	8-Feb-2020	BENGALURU	66	MANYATHA 220 - LINE 2	SAHAKARINAGAR	6:24	9:24	3:00	LINE FAULT
594	8-Feb-2020	BENGALURU	66	HV1	MANYATHA 220	10:35	11:12	0:37	LINE CLEAR AVAILED
595	8-Feb-2020	BENGALURU	66	MANYATHA 220 - HOSKOTE 1	MANYATHA 66	10:35	11:12	0:37	LINE CLEAR AVAILED
596	8-Feb-2020	BENGALURU	66	HV1	MANYATHA 220	13:34	13:44	0:10	LINE CLEAR AVAILED
597	8-Feb-2020	BENGALURU	66	MANYATHA 220 - HOSKOTE 1	MANYATHA 66	13:34	13:44	0:10	LINE CLEAR AVAILED
598	8-Feb-2020	BENGALURU	66	IISC - HEBBAL 220	IISC	7:30	7:55	0:25	LOAD CHANGEOVER
599	8-Feb-2020	BENGALURU	66	IISC - NRS 220	IISC	11:41	11:44	0:03	LOAD CHANGEOVER
600	8-Feb-2020	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	17:23	19:58	2:35	LINE FAULT
601	8-Feb-2020	BENGALURU	66	SRS PEENYA 220 - BMRCL (EHT)	BMRCL (EHT)	17:23	18:26	1:03	MAIN SUPPLY FAILURE
602	8-Feb-2020	BENGALURU	66	SRS PEENYA 220 - NRS 1	NANDINI LAYOUT	17:23	18:08	0:45	MAIN SUPPLY FAILURE
603	8-Feb-2020	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	17:23	17:49	0:26	MAIN SUPPLY FAILURE
604	8-Feb-2020	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	17:23	18:20	0:57	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
605	8-Feb-2020	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, BIEC, NELAMANGALA 66	17:23	18:35	1:12	MAIN SUPPLY FAILURE
606	8-Feb-2020	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	17:23	18:32	1:09	MAIN SUPPLY FAILURE
607	8-Feb-2020	BENGALURU	66	SRS PEENYA 220 - PLATINUM CITY	PLATIMUM CITY	17:23	18:21	0:58	MAIN SUPPLY FAILURE
608	8-Feb-2020	BENGALURU	66	SRS PEENYA 220 - BRINDAVANA	BRINDAVANA	17:23	19:19	1:56	MAIN SUPPLY FAILURE
609	8-Feb-2020	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	21:50	23:59	2:09	LINE FAULT
610	8-Feb-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	11:30	11:35	0:05	LOAD CHANGEOVER
611	8-Feb-2020	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	10:06	11:10	1:04	MAIN SUPPLY FAILURE
612	8-Feb-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	19:48	20:15	0:27	LOAD CHANGEOVER
613	8-Feb-2020	BENGALURU	66	HV2	BMTC	16:41	19:00	2:18	LINE CLEAR AVAILED
614	8-Feb-2020	BENGALURU	66	HV2	NRS 220	10:49	10:56	0:06	LINE CLEAR AVAILED
615	8-Feb-2020	BENGALURU	66	HV2	NRS 220	17:32	17:36	0:04	LINE CLEAR AVAILED
616	8-Feb-2020	BENGALURU	220	HV2	SRS PEENYA 220	17:23	19:14	1:51	TRANSFORMER FAULT
617	8-Feb-2020	BENGALURU	220	HV3	SRS PEENYA 220	17:23	17:58	0:35	TRANSFORMER FAULT
618	8-Feb-2020	BENGALURU	220	HV4	SRS PEENYA 220	17:23	18:17	0:54	TRANSFORMER FAULT
619	8-Feb-2020	BENGALURU	220	HV5	SRS PEENYA 220	17:23	19:10	1:47	MAIN SUPPLY FAILURE
620	8-Feb-2020	BENGALURU	66	C STATION - HEBBAL 220	C STATION	10:05	16:40	6:35	LINE CLEAR AVAILED
621	8-Feb-2020	BENGALURU	66	ELITE PROMENEDE - RBI	ELITE PROMENEDE	11:10	11:20	0:10	LOAD CHANGEOVER
622	8-Feb-2020	BENGALURU	220	HEBBAL 220 - MANYATHA 220	HEBBAL 220	10:35	11:12	0:37	LINE CLEAR AVAILED
623	8-Feb-2020	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	10:35	11:12	0:37	MAIN SUPPLY FAILURE
624	8-Feb-2020	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	10:35	11:12	0:37	MAIN SUPPLY FAILURE
625	8-Feb-2020	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	11:12	11:24	0:12	LOAD CHANGEOVER
626	8-Feb-2020	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	11:20	11:30	0:10	LOAD CHANGEOVER
627	8-Feb-2020	BENGALURU	66	HV1	DALASANUR	9:16	10:02	0:46	LINE CLEAR AVAILED
628	8-Feb-2020	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	17:23	18:45	1:22	MAIN SUPPLY FAILURE
629	8-Feb-2020	BENGALURU	66	RMV - TATA INSTITUTE (EHT)	TATA INSTITUTE (EHT)	18:02	18:50	0:48	MAIN SUPPLY FAILURE
630	8-Feb-2020	BENGALURU	66	BRINDAVANA - NELAKADRINAHALLI	NELAKADRINAHALLI	4:55	5:55	1:00	LINE FAULT
631	8-Feb-2020	BENGALURU	66	BRINDAVANA - SRS PEENYA 220	BRINDAVANA	4:55	5:15	0:20	LOAD CHANGEOVER
632	8-Feb-2020	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	17:15	17:23	0:07	LOAD CHANGEOVER
633	8-Feb-2020	BENGALURU	66	KHB - YELAHANKA 220	KHB	9:22	17:35	8:13	LINE CLEAR AVAILED
634	8-Feb-2020	BENGALURU	66	SRS PEENYA 220 - NELAKADRINAHALLI	NELAKADRINAHALLI	17:23	19:55	2:32	LINE FAULT
635	8-Feb-2020	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	7:03	7:30	0:27	MAIN SUPPLY FAILURE
636	8-Feb-2020	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	18:24	18:26	0:02	LOAD CHANGEOVER
637	8-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGUR_IPP,ASKI_110	4:47	4:52	0:05	LINE FAULT
638	8-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGUR_IPP,ASKI_110	4:55	5:07	0:12	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
639	8-Feb-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110,SAIDAPUR_110	5:21	5:28	0:07	LINE FAULT
640	8-Feb-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110,SAIDAPUR_110	23:34	23:42	0:08	LINE FAULT
641	8-Feb-2020	GULBARGA	110	ALLIPUR-MUNIRBAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,SHATHAVANA_IPP,AGRAWAL_IPP,SUZLON_IPP,KAMALAPUR_IPP,MATR,RBNS_FACTORY	1:14	1:24	0:10	HAND TRIPPED
642	8-Feb-2020	GULBARGA	110	SEDAM-SHAHABAD	CHITAPUR_110,RAJEASHREE CEMENTS_IPP,KORAWAR TEMPLE_110	19:39	20:35	0:56	LINE FAULT
643	8-Feb-2020	GULBARGA	110	HALBARGA-BHALIKI	BHALKI_110,LADHA_110,MGSSK_IPP,BHALKISUGAR_IPP	5:07	5:20	0:13	LINE FAULT
644	8-Feb-2020	GULBARGA	110	HV2	SHORAPUR_110	0:06	0:12	0:06	TRANSFORMER FAULT
645	8-Feb-2020	GULBARGA	110	LV1	HALBURGA_220	17:26	17:29	0:03	TRANSFORMER FAULT
646	8-Feb-2020	GULBARGA	66	HV1	HAMPASAGAR_66	9:00	9:05	0:05	TRANSFORMER FAULT
647	8-Feb-2020	GULBARGA	66	HV1	KOGALI_66	17:15	17:50	0:35	TRANSFORMER FAULT
648	8-Feb-2020	GULBARGA	66	KOGALI-ASTROSOLAR_IPP	KOGALI_66	11:05	11:10	0:05	LINE CLEAR AVAILED
649	8-Feb-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	19:09	22:17	3:08	LINE CLEAR AVAILED
650	8-Feb-2020	HASSAN	220	ARSK2-HSN	ARASIKERE_220	12:23	14:26	2:03	NFBC ISSUED
651	8-Feb-2020	HASSAN	220	KADUR-DABUSET	KADUR_220	6:05	14:41	8:36	LINE FAULT
652	8-Feb-2020	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	10:14	12:15	2:01	LINE CLEAR AVAILED
653	8-Feb-2020	HASSAN	110	JOG110-LPH	JOG_110	8:55	16:42	7:47	LINE CLEAR AVAILED
654	8-Feb-2020	HASSAN	110	HV1	MOODABIDRE_110	7:25	7:32	0:07	TRANSFORMER FAULT
655	8-Feb-2020	HASSAN	110	HV1	MOODABIDRE_110	9:24	9:32	0:08	TRANSFORMER FAULT
656	8-Feb-2020	HASSAN	110	HV1	MOODABIDRE_110	10:36	10:50	0:14	TRANSFORMER FAULT
657	8-Feb-2020	HASSAN	110	HV2	SAGARA_110	10:28	13:41	3:13	LINE CLEAR AVAILED
658	8-Feb-2020	HASSAN	66	HV1	HASSAN_66	3:36	3:58	0:22	TRANSFORMER FAULT
659	8-Feb-2020	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	6:44	6:50	0:06	LINE FAULT
660	8-Feb-2020	MYSORE	66	BOGADHI-KALAMANDIR	KALAMANDIRA_66	7:09	8:07	0:57	LINE FAULT
661	8-Feb-2020	MYSORE	66	HV1	JAKKANAHALLY_66	12:34	12:36	0:01	HAND TRIPPED
662	8-Feb-2020	MYSORE	66	HV2	JAKKANAHALLY_66	12:34	12:36	0:01	HAND TRIPPED
663	8-Feb-2020	MYSORE	66	KUSHALNAGARA 220-RAMANTHAPURA 1	ALUR SIDDAPUR_66 KANAGAL_66	11:15	12:09	0:53	LINE CLEAR AVAILED
664	8-Feb-2020	MYSORE	66	MADDUR-SOMNAHALI	MADDUR_66 SOMANAHALLI_66	7:58	9:04	1:05	LINE FAULT
665	8-Feb-2020	MYSORE	66	TN PURA-THAYUR	TNARASIPURA_66	9:10	17:50	8:40	LINE CLEAR AVAILED
666	8-Feb-2020	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	12:23	14:26	2:02	LINE CLEAR AVAILED
667	8-Feb-2020	TUMKUR	66	TR-2	AVAREGERE_66	10:38	10:49	0:10	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
668	8-Feb-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	8:52	8:58	0:06	TRANSFORMER FAULT
669	8-Feb-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	15:13	15:20	0:06	TRANSFORMER FAULT
670	8-Feb-2020	TUMKUR	66	TR-1	HANGLA_66	11:03	12:12	1:08	LINE CLEAR AVAILED
671	8-Feb-2020	TUMKUR	66	TR-1	HIRIYUR_66	11:46	11:57	0:10	TRANSFORMER FAULT
672	8-Feb-2020	TUMKUR	66	TR-2	HULIYURDURGA_66	6:41	6:54	0:12	TRANSFORMER FAULT
673	8-Feb-2020	TUMKUR	66	MADHUGIRI 220kV- SIRA 1	GULIGENAHALLI_66,SIRA_66	10:07	11:16	1:08	LINE CLEAR AVAILED
674	8-Feb-2020	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	10:07	11:11	1:04	LINE CLEAR AVAILED
675	8-Feb-2020	TUMKUR	66	TR-1	MATHOD_66	10:13	10:18	0:05	TRANSFORMER FAULT
676	8-Feb-2020	TUMKUR	66	TR-2	MATHOD_66	23:40	23:45	0:05	TRANSFORMER FAULT
677	8-Feb-2020	TUMKUR	66	NEELAGUNDA 220kV-HARAPPANAHALLI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	6:39	6:52	0:12	LINE FAULT
678	8-Feb-2020	TUMKUR	66	TR-1	NEELAGUNDA_220	2:48	2:59	0:11	TRANSFORMER FAULT
679	8-Feb-2020	TUMKUR	66	TR-1	NEELAGUNDA_220	7:25	10:03	2:38	TRANSFORMER FAULT
680	8-Feb-2020	TUMKUR	66	TR-1	RANGANATHAPURA_66	9:47	10:59	1:12	LINE CLEAR AVAILED
681	8-Feb-2020	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	9:07	9:17	0:09	MAIN SUPPLY FAILURE
682	8-Feb-2020	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	10:19	11:23	1:04	LINE CLEAR AVAILED
683	8-Feb-2020	TUMKUR	66	SIRA- MADHUGIRI 1	BUKKAPATNA_66, KALLAMBELLA_66	10:19	11:22	1:03	LINE CLEAR AVAILED
684	8-Feb-2020	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	11:17	11:23	0:05	LINE CLEAR AVAILED
685	8-Feb-2020	TUMKUR	66	TR-2	THOVINAKERE_66	22:15	23:16	1:00	LINE CLEAR AVAILED
686	8-Feb-2020	TUMKUR	66	TR-1	TUMKUR_66	10:57	12:15	1:17	LINE CLEAR AVAILED
687	9-Feb-2020	BAGALKOT	220	SHIRALKOPPA(BALLIGAVI)- RANEBENNUR	RANEBENNUR_220	0:00	7:47	7:47	LINE CLEAR AVAILED
688	9-Feb-2020	BAGALKOT	220	GUTTUR-RANEBENNUR	RANEBENNUR_220	7:47	9:10	1:23	LINE CLEAR AVAILED
689	9-Feb-2020	BENGALURU	66	HV1	T K HALLI 220	7:20	7:23	0:03	TRANSFORMER FAULT
690	9-Feb-2020	BENGALURU	66	VRISHBHAVATHI 220 - REMCO	REMCO	7:19	7:55	0:36	LINE FAULT
691	9-Feb-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	6:31	6:36	0:05	LINE FAULT
692	9-Feb-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	4:41	4:48	0:07	LINE FAULT
693	9-Feb-2020	BENGALURU	66	HV1	DOMMASANDRA	12:17	12:39	0:22	TRANSFORMER FAULT
694	9-Feb-2020	BENGALURU	66	JIGANI - SOMANAHALLI 220	JIGANI,JIGANI LINK ROAD,B G ROAD	12:15	12:20	0:05	LOAD CHANGEOVER
695	9-Feb-2020	BENGALURU	66	JIGANI - JIGANI 220	JIGANI,JIGANI LINK ROAD,B G ROAD	16:40	16:45	0:05	LOAD CHANGEOVER

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
696	9-Feb-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:13	9:20	0:07	LINE FAULT
697	9-Feb-2020	BENGALURU	66	SOLADEVANAHALLI - YELAHANKA 220	SOLADEVANAHALLI	13:40	13:43	0:03	LOAD CHANGEOVER
698	9-Feb-2020	BENGALURU	66	SOLDEVANAHALLI - SRS PEENYA 220	SOLDEVANAHALLI	16:00	16:08	0:08	LOAD CHANGEOVER
699	9-Feb-2020	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	0:00	0:05	0:05	LINE FAULT
700	9-Feb-2020	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	15:32	19:02	3:30	LINE CLEAR AVAILED
701	9-Feb-2020	BENGALURU	66	HV2	REMCO	7:17	11:43	4:26	TRANSFORMER FAULT
702	9-Feb-2020	BENGALURU	66	HV1	NELEMANGALA 66	10:07	16:21	6:13	LINE CLEAR AVAILED
703	9-Feb-2020	BENGALURU	66	SRS PEENYA 220 - NRS 1	NANDINI LAYOUT	18:23	18:26	0:03	LINE CLEAR AVAILED
704	9-Feb-2020	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	18:23	18:26	0:03	LINE CLEAR AVAILED
705	9-Feb-2020	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	17:08	17:20	0:12	LOAD CHANGEOVER
706	9-Feb-2020	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	17:36	17:46	0:10	LOAD CHANGEOVER
707	9-Feb-2020	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	10:02	10:24	0:22	LINE FAULT
708	9-Feb-2020	BENGALURU	66	HV1	D CROSS	11:01	11:07	0:05	LINE CLEAR AVAILED
709	9-Feb-2020	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	10:58	11:20	0:22	LINE CLEAR AVAILED
710	9-Feb-2020	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	16:15	16:30	0:15	LINE CLEAR AVAILED
711	9-Feb-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	10:58	11:15	0:17	LINE CLEAR AVAILED
712	9-Feb-2020	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	10:58	11:16	0:18	LINE CLEAR AVAILED
713	9-Feb-2020	BENGALURU	66	SUBRAMANYAPURA 220 - SOMANAHALLI 220		16:14	16:40	0:26	LINE CLEAR AVAILED
714	9-Feb-2020	BENGALURU	66	HV1	SOMANAHALLI 220	10:58	11:20	0:22	LINE CLEAR AVAILED
715	9-Feb-2020	BENGALURU	66	BG ROAD - SOMANAHALLI 220	BG ROAD	12:20	12:38	0:18	LOAD CHANGEOVER
716	9-Feb-2020	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	BG ROAD	16:40	16:45	0:05	LOAD CHANGEOVER
717	9-Feb-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	10:40	13:17	2:37	LINE CLEAR AVAILED
718	9-Feb-2020	BENGALURU	66	HV1	SOMANAHALLI 220	12:32	12:48	0:16	LINE CLEAR AVAILED
719	9-Feb-2020	BENGALURU	66	HV1	SOMANAHALLI 220	16:10	16:28	0:18	LINE CLEAR AVAILED
720	9-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGUR_IPP,ASKI_110	21:35	21:42	0:07	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
721	9-Feb-2020	GULBARGA	110	ALLIPIR-MUNIRBAD	TORANGALLU_110,KUDITINI_110 ,KURUGOD_110,SHATHAVANA_IP P,AGRAWAL_IPP,SUZLON_IPP,KAMALAPUR_IPP,MATR,RBNS_FACTORY	8:39	8:53	0:14	LINE FAULT
722	9-Feb-2020	GULBARGA	110	ALLIPIR-MUNIRBAD	TORANGALLU_110,KUDITINI_110 ,KURUGOD_110,SHATHAVANA_IP P,AGRAWAL_IPP,SUZLON_IPP,KAMALAPUR_IPP,MATR,RBNS_FACTORY	10:32	10:39	0:07	HAND TRIPPED
723	9-Feb-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,MALLAPUR_110,YEREDONA_110,SRE RAMNAGAR_110	12:10	12:20	0:10	LINE FAULT
724	9-Feb-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	15:52	16:10	0:18	LINE FAULT
725	9-Feb-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	22:58	23:08	0:10	LINE FAULT
726	9-Feb-2020	GULBARGA	66	HV1	HAGARIBOMMANAHALLI_66	12:10	12:15	0:05	TRANSFORMER FAULT
727	9-Feb-2020	GULBARGA	66	ITAAGI-HIREHADAGALI1	HIREHADAGALI_66	14:25	14:40	0:15	LINE FAULT
728	9-Feb-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	7:19	8:22	1:03	LINE CLEAR AVAILED
729	9-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	4:58	10:48	5:50	LINE FAULT
730	9-Feb-2020	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	4:58	10:48	5:50	LINE FAULT
731	9-Feb-2020	HASSAN	110	HV2	ARASIKERE_110	16:23	18:57	2:34	LINE CLEAR AVAILED
732	9-Feb-2020	HASSAN	110	HV2	HOSANGADI_110	10:51	18:04	7:13	LINE CLEAR AVAILED
733	9-Feb-2020	HASSAN	66	HASSN22-ARAKALGUD2	HASSAN_220	6:29	6:59	0:30	LINE FAULT
734	9-Feb-2020	HASSAN	66	HV2	HNPURA_66	12:08	13:59	1:51	LINE CLEAR AVAILED
735	9-Feb-2020	HASSAN	66	HV2	UDAYAPURA_66	9:06	9:08	0:02	TRANSFORMER FAULT
736	9-Feb-2020	MYSORE	66	HV1	JAKKANAHALLY_66	14:11	14:33	0:22	TRANSFORMER FAULT
737	9-Feb-2020	MYSORE	66	KIRUGAVALU-SFC	KIRUGAVALU_66 VADKEPURA_66	13:12	13:29	0:17	LINE FAULT
738	9-Feb-2020	MYSORE	66	HV2	KOLLEGALA-	11:09	12:20	1:10	LINE CLEAR AVAILED
739	9-Feb-2020	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	13:04	13:10	0:05	LINE FAULT
740	9-Feb-2020	MYSORE	66	HV2	SANTHEMARAHALLI_66	10:15	11:52	1:36	LINE CLEAR AVAILED
741	9-Feb-2020	TUMKUR	110	TR-2	SAMPIGE_110	10:19	10:37	0:18	TRANSFORMER FAULT
742	9-Feb-2020	TUMKUR	110	TR-1	SHETYKERE_110	8:05	8:43	0:38	LINE CLEAR AVAILED
743	9-Feb-2020	TUMKUR	66	AVAREGERE 66kV-DAVANGERE SRS	AVAREGERE_66	21:45	21:52	0:06	LINE FAULT
744	9-Feb-2020	TUMKUR	66	TR-2	AVAREGERE_66	21:45	21:52	0:06	TRANSFORMER FAULT
745	9-Feb-2020	TUMKUR	66	TR-3	AVAREGERE_66	21:45	23:15	1:29	TRANSFORMER FAULT
746	9-Feb-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	8:06	8:13	0:06	TRANSFORMER FAULT
747	9-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	7:18	7:34	0:16	LINE FAULT



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
748	9-Feb-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	15:03	15:26	0:23	TRANSFORMER FAULT
749	9-Feb-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	21:21	22:12	0:50	TRANSFORMER FAULT
750	10-Feb-2020	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	11:02	12:56	1:54	LINE FAULT
751	10-Feb-2020	BAGALKOT	220	PONDA 1-AMBEWADI	AMBEWADI_220	14:54	18:44	3:50	LINE FAULT
752	10-Feb-2020	BAGALKOT	110	110/11KV,HV1&HV2	ANKALI_110	10:55	17:01	6:06	LINE CLEAR AVAILED
753	10-Feb-2020	BAGALKOT	110	110/33KV,HV3&HV4	ANKALI_110,KOTWAGI_33,NANDI KURLI_33	10:55	17:02	6:07	LINE CLEAR AVAILED
754	10-Feb-2020	BAGALKOT	110	ANKOLA-KUMTA	KUMTA_110	10:32	17:32	7:00	LINE CLEAR AVAILED
755	10-Feb-2020	BAGALKOT	110	ATHANI220-TAUSHI	TAUSHI_110	4:49	5:17	0:28	LINE FAULT
756	10-Feb-2020	BAGALKOT	220	HARTI 1-BIDNAL	BIDNAL_220	13:42	18:48	5:06	LINE FAULT
757	10-Feb-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	19:51	23:59	4:08	LINE FAULT
758	10-Feb-2020	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	11:22	16:42	5:20	LINE CLEAR AVAILED
759	10-Feb-2020	BAGALKOT	110	110/11KV,HV1	HANGAL_110	14:36	14:39	0:03	HAND TRIPPED
760	10-Feb-2020	BAGALKOT	110	VAJRAMATTI220-BILAGI	BILAGI_110	16:56	17:24	0:28	LINE FAULT
761	10-Feb-2020	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	16:25	23:59	7:34	LINE CLEAR AVAILED
762	10-Feb-2020	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	RANNABELAGALI_110	16:15	23:59	7:44	LINE CLEAR AVAILED
763	10-Feb-2020	BAGALKOT	220	220/110KV,HV2,LV2	MK HUBLI_220	15:38	17:08	1:30	LINE CLEAR AVAILED
764	10-Feb-2020	BAGALKOT	110	MK HUBLI220-MK HUBLI2	MK HUBLI_110	16:08	18:07	1:59	LINE CLEAR AVAILED
765	10-Feb-2020	BAGALKOT	220	MAHALINGAPUR-NARENDRA1	MAHALINGAPUR_220	10:39	17:43	7:04	LINE CLEAR AVAILED
766	10-Feb-2020	BAGALKOT	220	MAHALINGAPUR-NARENDRA2	MAHALINGAPUR_220	17:50	21:33	3:43	LINE CLEAR AVAILED
767	10-Feb-2020	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220	16:13	19:27	3:14	LINE CLEAR AVAILED
768	10-Feb-2020	BAGALKOT	110	SIRSI1-KUMTA	KUMTA_110	0:00	10:28	10:28	LINE CLEAR AVAILED
769	10-Feb-2020	BAGALKOT	110	SIRSI1-KUMTA	KUMTA_110	19:03	23:59	4:56	LINE CLEAR AVAILED
770	10-Feb-2020	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	12:02	23:59	11:57	LINE CLEAR AVAILED
771	10-Feb-2020	BAGALKOT	110	110/11KV,HV2	JAMKHANDI_110	7:36	14:46	7:10	LINE CLEAR AVAILED
772	10-Feb-2020	BAGALKOT	110	110/11KV,HV3	JAMKHANDI_110	7:37	7:44	0:07	HAND TRIPPED
773	10-Feb-2020	BAGALKOT	110	110/11KV,HV1	KHANAPUR_110	19:52	22:04	2:12	LINE CLEAR AVAILED
774	10-Feb-2020	BAGALKOT	110	110/11KV,HV 2	BAGALKOT_110	11:20	15:25	4:05	LINE CLEAR AVAILED
775	10-Feb-2020	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TEC PARK 220	15:34	16:17	0:42	LINE CLEAR AVAILED
776	10-Feb-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	15:34	16:17	0:42	MAIN SUPPLY FAILURE
777	10-Feb-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	15:34	16:17	0:42	MAIN SUPPLY FAILURE
778	10-Feb-2020	BENGALURU	66	HV1	BAIRAKURU	15:04	15:08	0:04	LINE CLEAR AVAILED
779	10-Feb-2020	BENGALURU	66	HV2	BAIRAKURU	15:04	15:09	0:04	LINE CLEAR AVAILED
780	10-Feb-2020	BENGALURU	66	HV1	HOSUR RAMAPURA	11:47	13:08	1:20	LINE CLEAR AVAILED
781	10-Feb-2020	BENGALURU	66	MANCHENALLY - GOWRIBIDANUR 220	MANCHENALLY	13:57	14:44	0:46	LINE CLEAR AVAILED
782	10-Feb-2020	BENGALURU	66	HV2	MANCHENALLY	10:59	11:37	0:37	LINE CLEAR AVAILED
783	10-Feb-2020	BENGALURU	66	HV2	SOMAYAJANAHALLY	14:48	15:19	0:30	TRANSFORMER FAULT
784	10-Feb-2020	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	15:55	16:10	0:14	LINE CLEAR AVAILED
785	10-Feb-2020	BENGALURU	66	HV1	D CROSS	14:48	15:12	0:23	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
786	10-Feb-2020	BENGALURU	220	HV1	NAGANATHPURA 220	13:20	13:35	0:15	LOAD CHANGEOVER
787	10-Feb-2020	BENGALURU	66	HV1	NAGANATHPURA 220	13:20	13:35	0:15	LOAD CHANGEOVER
788	10-Feb-2020	BENGALURU	66	HV2	NAGANATHPURA 220	13:20	13:35	0:15	LOAD CHANGEOVER
789	10-Feb-2020	BENGALURU	66	HV1	BRIGADE METROPOLIS	10:23	11:10	0:47	TRANSFORMER FAULT
790	10-Feb-2020	BENGALURU	220	HV5	SRS PEENYA 220	9:10	10:05	0:55	TRANSFORMER FAULT
791	10-Feb-2020	BENGALURU	66	SRS PEENYA 220 - BRINDAVANA	BRINDAVANA, NELAKADRINAHALLI	9:10	10:07	0:57	MAIN SUPPLY FAILURE
792	10-Feb-2020	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	13:20	13:35	0:15	MAIN SUPPLY FAILURE
793	10-Feb-2020	BENGALURU	66	HV3	ELECTRONIC CITY P2 S1	11:15	13:10	1:55	LINE CLEAR AVAILED
794	10-Feb-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	4:27	5:02	0:35	MAIN SUPPLY FAILURE
795	10-Feb-2020	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 220	ELECTRONIC CITY	12:15	13:20	1:05	LINE CLEAR AVAILED
796	10-Feb-2020	BENGALURU	220	HV1	YARANDANAHALLI 220	4:27	4:57	0:30	TRANSFORMER FAULT
797	10-Feb-2020	BENGALURU	66	HV2	YARANDANAHALLI 220	4:27	4:57	0:30	MAIN SUPPLY FAILURE
798	10-Feb-2020	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	11:02	11:15	0:13	LINE CLEAR AVAILED
799	10-Feb-2020	GULBARGA	400	BTPSG-RTPS	BTPSG_400	4:20	10:15	5:55	LINE FAULT
800	10-Feb-2020	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	14:45	14:56	0:11	LINE FAULT
801	10-Feb-2020	GULBARGA	220	SEDAM-ORIENTCEMENTS	ORIENT CEMENTS_IPP	15:25	15:42	0:17	LINE FAULT
802	10-Feb-2020	GULBARGA	110	HV2	HATTI_110	7:11	7:15	0:04	TRANSFORMER FAULT
803	10-Feb-2020	GULBARGA	110	HV2	HATTI_110	10:17	10:22	0:05	TRANSFORMER FAULT
804	10-Feb-2020	GULBARGA	110	HV1	TEKKALKOTE_110	11:51	11:56	0:05	TRANSFORMER FAULT
805	10-Feb-2020	GULBARGA	110	HV1	TEKKALKOTE_110	15:26	15:35	0:09	TRANSFORMER FAULT
806	10-Feb-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	22:20	22:29	0:09	MAIN SUPPLY FAILURE
807	10-Feb-2020	GULBARGA	110	HV2	SHORAPUR_110	22:20	22:36	0:16	TRANSFORMER FAULT
808	10-Feb-2020	GULBARGA	66	ITAAGI-KUDLIGI 2	CJHALLI_66,GUDEKOTE_66,HOSA HALLI_66, BANVEKAL_66,CHORNOOR_66	10:35	10:45	0:10	LINE FAULT
809	10-Feb-2020	GULBARGA	66	BANAVEKAL-SLRYS	BANAVEKAL_66	10:35	10:56	0:21	MAIN SUPPLY FAILURE
810	10-Feb-2020	GULBARGA	66	ITAAGI-KUDLIGI 1	KOGALI_66,KUDLIGI_66,HANASI_66	10:35	10:45	0:10	LINE FAULT
811	10-Feb-2020	GULBARGA	66	ITAAGI-KUDLIGI 2	CJHALLI_66,GUDEKOTE_66,HOSA HALLI_66, BANVEKAL_66,CHORNOOR_66	10:35	10:45	0:10	LINE FAULT
812	10-Feb-2020	GULBARGA	66	HV1	HAGRIBOMMANAHALL_66	11:45	11:55	0:10	TRANSFORMER FAULT
813	10-Feb-2020	HASSAN	220	HV1	HASSAN_220	8:25	8:46	0:21	TRANSFORMER FAULT
814	10-Feb-2020	HASSAN	110	HV2	ANANDAPURA_110	0:00	22:53	22:53	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
815	10-Feb-2020	HASSAN	110	JOG-JST1	JOG_110	9:51	10:40	0:49	LINE FAULT
816	10-Feb-2020	HASSAN	110	HV1	MRSMSG_220	9:05	13:45	4:40	LINE CLEAR AVAILED
817	10-Feb-2020	HASSAN	110	HV2	MRSMSG_220	13:01	13:06	0:05	TRANSFORMER FAULT
818	10-Feb-2020	HASSAN	110	HV3	MRSMSG_220	13:01	13:06	0:05	TRANSFORMER FAULT
819	10-Feb-2020	HASSAN	110	HV4	MRSMSG_220	13:01	13:06	0:05	TRANSFORMER FAULT
820	10-Feb-2020	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	8:29	8:47	0:18	HAND TRIPPED
821	10-Feb-2020	HASSAN	66	HASSN22-BELUR	HASSAN_220	10:29	13:48	3:19	LINE CLEAR AVAILED
822	10-Feb-2020	HASSAN	66	HASSN22-SKPURA2	HASSAN_220	8:29	8:46	0:17	HAND TRIPPED
823	10-Feb-2020	HASSAN	66	HASSN22-ARKD2	HASSAN_220	8:29	8:46	0:17	HAND TRIPPED
824	10-Feb-2020	HASSAN	66	HASSN22-ARKD1	HASSAN_220	8:29	8:47	0:18	HAND TRIPPED
825	10-Feb-2020	HASSAN	66	HASSN22-HNPURA	HASSAN_220	8:29	8:47	0:18	HAND TRIPPED
826	10-Feb-2020	HASSAN	66	LV1	HASSAN_220	8:25	8:46	0:21	TRANSFORMER FAULT
827	10-Feb-2020	HASSAN	66	HASSN22-CRP1	HASSAN_220	8:34	8:47	0:13	HAND TRIPPED
828	10-Feb-2020	HASSAN	66	HASSN22-CRP2	HASSAN_220	8:29	8:47	0:18	HAND TRIPPED
829	10-Feb-2020	HASSAN	66	HASSN22-SKPURA1	HASSAN_220	8:29	8:48	0:19	HAND TRIPPED
830	10-Feb-2020	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	11:29	12:18	0:49	LINE CLEAR AVAILED
831	10-Feb-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	13:03	13:12	0:09	HAND TRIPPED
832	10-Feb-2020	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	13:03	13:12	0:09	HAND TRIPPED
833	10-Feb-2020	HASSAN	66	MRSSHM-DVG1	MRSMSG_220	13:01	13:07	0:06	HAND TRIPPED
834	10-Feb-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	13:01	13:08	0:07	HAND TRIPPED
835	10-Feb-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	13:19	13:45	0:26	HAND TRIPPED
836	10-Feb-2020	HASSAN	66	LV1	MRSMSG_220	9:05	13:45	4:40	TRANSFORMER FAULT
837	10-Feb-2020	HASSAN	66	LV2	MRSMSG_220	13:01	13:08	0:07	TRANSFORMER FAULT
838	10-Feb-2020	HASSAN	66	LV3	MRSMSG_220	13:01	13:07	0:06	TRANSFORMER FAULT
839	10-Feb-2020	HASSAN	66	LV4	MRSMSG_220	13:01	13:07	0:06	TRANSFORMER FAULT
840	10-Feb-2020	HASSAN	66	HV1	BAGUR_66	11:37	11:47	0:10	LINE CLEAR AVAILED
841	10-Feb-2020	HASSAN	66	HV1	BAGUR_66	13:06	13:30	0:24	LINE CLEAR AVAILED
842	10-Feb-2020	HASSAN	66	HV2	BAGUR_66	11:37	11:48	0:11	LINE CLEAR AVAILED
843	10-Feb-2020	HASSAN	66	HV2	BAGUR_66	13:07	13:30	0:23	LINE CLEAR AVAILED
844	10-Feb-2020	HASSAN	66	BAGUR-UDAYAPUR	BAGUR_66	11:37	11:47	0:10	LINE CLEAR AVAILED
845	10-Feb-2020	HASSAN	66	BAGUR-UDAYAPUR	BAGUR_66	13:08	13:29	0:21	LINE CLEAR AVAILED
846	10-Feb-2020	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	5:23	5:30	0:07	LINE FAULT
847	10-Feb-2020	HASSAN	66	HV1	KUDLIGERE_66	17:53	18:10	0:17	TRANSFORMER FAULT
848	10-Feb-2020	HASSAN	66	HV2	UDAYAPURA_66	12:18	12:23	0:05	TRANSFORMER FAULT
849	10-Feb-2020	HASSAN	66	HV2	UDAYAPURA_66	17:52	17:55	0:03	TRANSFORMER FAULT
850	10-Feb-2020	HASSAN	66	UDDURKO-SUZLON	UDDURKOPLU_66	11:29	12:21	0:52	MAIN SUPPLY FAILURE
851	10-Feb-2020	MYSORE	66	HV1	DODDARAYAPET_66	7:13	9:13	2:00	TRANSFORMER FAULT
852	10-Feb-2020	MYSORE	66	HV2	FTS_66	9:37	11:12	1:34	LINE CLEAR AVAILED
853	10-Feb-2020	MYSORE	66	HOOTAGALLI-FTS1	FTS_66	7:54	8:03	0:09	LINE FAULT
854	10-Feb-2020	MYSORE	66	HOOTAGALLI-FTS1	FTS_66	8:04	10:34	2:30	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
855	10-Feb-2020	MYSORE	66	HV2	PANDAVAPURA_66	13:23	13:25	0:01	HAND TRIPPED
856	10-Feb-2020	MYSORE	66	HV1	SRIRANGAPATNA_66	9:32	9:45	0:13	TRANSFORMER FAULT
857	10-Feb-2020	TUMKUR	66	TR-2	AVAREGERE_66	16:13	16:25	0:12	TRANSFORMER FAULT
858	10-Feb-2020	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	12:00	13:06	1:05	MAIN SUPPLY FAILURE
859	10-Feb-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	12:40	12:44	0:04	TRANSFORMER FAULT
860	10-Feb-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:08	6:24	0:15	LINE FAULT
861	10-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:05	13:04	0:59	LINE CLEAR AVAILED
862	10-Feb-2020	TUMKUR	66	HARIHARA-DAVANGERE SRS	HARIHAR_66	12:05	13:05	1:00	LINE CLEAR AVAILED
863	10-Feb-2020	TUMKUR	66	TR-1	HARIHAR_66	12:05	13:06	1:00	LINE CLEAR AVAILED
864	10-Feb-2020	TUMKUR	66	TR-2	HARIHAR_66	12:05	13:06	1:00	LINE CLEAR AVAILED
865	10-Feb-2020	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	11:12	13:03	1:50	LINE CLEAR AVAILED
866	10-Feb-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	16:16	16:20	0:04	LINE FAULT