

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 29.01.2019 to 04.02.2019**

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	29-Jan-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR1	MAMADAPUR_110	11:40	17:58	6:18	LINE CLEAR AVAILED
2	29-Jan-19	BAGALKOT	220	220/110KV,HV1,LV1	KARWAR_220	0:00	17:20	17:20	LINE CLEAR AVAILED
3	29-Jan-19	BAGALKOT	110	110/33KV,HV4	GOPANAKOPPA_110,KMC_33	12:31	13:50	1:19	LINE CLEAR AVAILED
4	29-Jan-19	BAGALKOT	110	CHIKKODI220-NANADI	NANADI_110	15:31	17:30	1:59	HAND TRIPPED
5	29-Jan-19	BANGALORE	66	HV2	ADDAGAL	11:32	12:40	1:07	LINE CLEAR AVAILED
6	29-Jan-19	BANGALORE	66	HBR LAYOUT - VIDYANAGAR	HBR LAYOUT	11:10	11:20	0:10	LOAD CHANGEOVER
7	29-Jan-19	BANGALORE	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	14:30	14:40	0:10	LOAD CHANGEOVER
8	29-Jan-19	BANGALORE	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	11:15	12:20	1:05	LINE CLEAR AVAILED
9	29-Jan-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	7:42	9:00	1:18	LINE FAULT
10	29-Jan-19	BANGALORE	66	HV2	SUGUTUR	16:36	16:45	0:08	TRANSFORMER FAULT
11	29-Jan-19	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	8:22	8:25	0:03	LINE FAULT
12	29-Jan-19	BANGALORE	66	TAMAKA - THAYALUR	THAYALUR, NG HULKUR, MALLANAYAKANAHALLI	8:25	10:10	1:45	LINE CLEAR AVAILED
13	29-Jan-19	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	9:15	10:10	0:55	LINE CLEAR AVAILED
14	29-Jan-19	BANGALORE	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD, ITC (EHT)	6:30	7:01	0:31	LINE FAULT
15	29-Jan-19	BANGALORE	66	KHB - YELAHANKA 220	KHB	11:42	11:48	0:06	LOAD CHANGEOVER
16	29-Jan-19	BANGALORE	66	KHB - SRS PEENYA 220	KHB	14:22	14:25	0:03	LOAD CHANGEOVER
17	29-Jan-19	BANGALORE	66	RAJANKUNTE - YELAHANKA 220	RAJANKUNTE	11:30	11:35	0:05	LOAD CHANGEOVER
18	29-Jan-19	BANGALORE	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	14:20	14:30	0:10	LOAD CHANGEOVER
19	29-Jan-19	BANGALORE	66	HV2	REMCO	12:08	12:38	0:29	LINE CLEAR AVAILED
20	29-Jan-19	BANGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR	8:22	15:40	7:18	LINE CLEAR AVAILED
21	29-Jan-19	BANGALORE	66	HV1	ELECTRONIC CITY PH 2 SEC 1	15:39	15:43	0:03	TRANSFORMER FAULT
22	29-Jan-19	GULBARGA	400	BTPS-RTPS	BTPSG_220	5:02	18:22	13:20	LINE FAULT
23	29-Jan-19	GULBARGA	220	HV2	ALIPUR_220	2:39	3:06	0:27	TRANSFORMER FAULT
24	29-Jan-19	GULBARGA	220	ALIPUR-GOOTY(RAGALPADU)	GOOTY_220	2:39	3:43	1:04	LINE FAULT
25	29-Jan-19	GULBARGA	220	HV2	ALIPUR_220	5:02	5:30	0:28	TRANSFORMER FAULT
26	29-Jan-19	GULBARGA	220	HV1	ALIPUR_220	5:22	5:29	0:07	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
27	29-Jan-19	GULBARGA	220	HV2	ALIPUR_220	2:39	3:06	0:27	TRANSFORMER FAULT
28	29-Jan-19	GULBARGA	220	HV2	ALIPUR_220	5:02	6:20	1:18	TRANSFORMER FAULT
29	29-Jan-19	GULBARGA	220	HV1	ALIPUR_220	5:02	5:29	0:27	TRANSFORMER FAULT
30	29-Jan-19	GULBARGA	220	ALIPUR-GOOTY	GOOTY_220	2:39	3:43	1:04	LINE FAULT
31	29-Jan-19	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220	6:24	15:38	9:14	LINE FAULT
32	29-Jan-19	GULBARGA	220	HV1	RAICHUR_220	11:37	12:49	1:12	LINE CLEAR AVAILED
33	29-Jan-19	GULBARGA	220	ALIPUR-GOOTY	GOOTY_220	4:15	17:27	13:12	LINE FAULT
34	29-Jan-19	GULBARGA	220	LINGAPUR-JVSL-1	JSVL_220	13:06	18:45	5:39	LINE FAULT
35	29-Jan-19	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	4:58	23:59	19:01	LINE FAULT
36	29-Jan-19	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	3:36	21:20	17:44	LINE FAULT
37	29-Jan-19	GULBARGA	110	LV2	ALIPUR_220	2:39	3:06	0:27	TRANSFORMER FAULT
38	29-Jan-19	GULBARGA	110	ALIPUE-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELS_IPP	5:24	5:31	0:07	LINE CLEAR AVAILED
39	29-Jan-19	GULBARGA	110	ALIPUE-BELLARY SOUTH	BELLARY SOUTH_110,HALKUNDI_110	5:24	5:31	0:07	LINE CLEAR AVAILED
40	29-Jan-19	GULBARGA	110	ALIPUR-MUNIRABAD	TORANAGALLU_110,KUDITINI_110 ,KURUGOD_110,SHATAVAHANA_I PP,AGARWAL_IPP,SUZLON_IPP,KAMALAPUR_110,MATRI_110,RBNS FACTORY	5:59	9:20	3:21	LINE FAULT
41	29-Jan-19	GULBARGA	110	ALIPUR-BELLARY-NORTH	BELLARYNORTH_110,MOKA_110,P D_HALLI_110,BISIHALLI_110,SOM ASAMUDRA_110	5:43	11:30	5:47	LINE FAULT
42	29-Jan-19	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KAMALAPUR_110,KUDITINI_110,KURUGOD_110, METRI_110	5:59	6:08	0:09	LINE FAULT
43	29-Jan-19	GULBARGA	110	HV1	BYAGAWAT_110	2:00	2:10	0:10	TRANSFORMER FAULT
44	29-Jan-19	GULBARGA	110	HALBURGA-ACMVSLR	HALBURGA_220	11:53	12:02	0:09	LINE FAULT
45	29-Jan-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	12:06	12:31	0:25	LINE FAULT
46	29-Jan-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	11:39	11:43	0:04	LINE FAULT
47	29-Jan-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	11:48	11:52	0:04	LINE FAULT
48	29-Jan-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	11:20	11:23	0:03	LINE FAULT
49	29-Jan-19	GULBARGA	110	HV3	LADHA_110	15:07	15:35	0:28	LINE CLEAR AVAILED
50	29-Jan-19	GULBARGA	110	SINDHANOOR-RAICHUR1	VALKAMDINNI_110,BYAGAWAT_110	3:35	12:28	8:53	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
51	29-Jan-19	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADALAPURA_110	11:24	12:28	1:04	LINE CLEAR AVAILED
52	29-Jan-19	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARTAGI_110GANGAVATHI_110,S RERAMANAGAR_110,VENKATAGIR I_110	6:06	7:02	0:56	LINE FAULT
53	29-Jan-19	GULBARGA	110	RAICHUR-SHAHABAD1	GABUR_110,DEODURGA_110	3:23	3:31	0:08	LINE FAULT
54	29-Jan-19	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHICKSUGUR_110,SHA KTINAGAR_110	12:12	14:27	2:15	LINE CLEAR AVAILED
55	29-Jan-19	GULBARGA	110	RAICHUR-SINDHANOOR1	BYAGAWAT_110,VALKAMDINNI_1 10	3:33	16:11	12:38	LINE FAULT
56	29-Jan-19	GULBARGA	66	HV2	TAMBRAHALLI_66	5:30	5:40	0:10	TRANSFORMER FAULT
57	29-Jan-19	GULBARGA	66	ITTAGGI-CLNMAX1	ITTAGI_220	12:27	12:35	0:08	LINE FAULT
58	29-Jan-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	10:31	12:32	2:01	NFBC ISSUED
59	29-Jan-19	HASSAN	220	HV1	PUTTUR_220	0:41	2:01	1:20	LINE CLEAR AVAILED
60	29-Jan-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	0:23	1:01	0:38	LINE CLEAR AVAILED
61	29-Jan-19	HASSAN	110	LV1	PUTTUR_220	0:41	2:01	1:20	LINE CLEAR AVAILED
62	29-Jan-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	13:40	15:25	1:45	LINE CLEAR AVAILED
63	29-Jan-19	HASSAN	110	HV2	ANAVATTI_110	13:40	15:25	1:45	LINE CLEAR AVAILED
64	29-Jan-19	HASSAN	110	HV1	SHIVPURA_110	7:23	9:01	1:38	LINE CLEAR AVAILED
65	29-Jan-19	HASSAN	110	HV1	MRSMSG_220	12:22	12:46	0:24	LINE CLEAR AVAILED
66	29-Jan-19	HASSAN	110	HV2	MRSMSG_220	12:47	13:09	0:22	LINE CLEAR AVAILED
67	29-Jan-19	HASSAN	110	HV3	MRSMSG_220	13:10	13:27	0:17	LINE CLEAR AVAILED
68	29-Jan-19	HASSAN	110	HV4	MRSMSG_220	13:28	13:46	0:18	LINE CLEAR AVAILED
69	29-Jan-19	HASSAN	66	LV1	MRSMSG_220	12:22	12:46	0:24	LINE CLEAR AVAILED
70	29-Jan-19	HASSAN	66	LV2	MRSMSG_220	12:47	13:09	0:22	LINE CLEAR AVAILED
71	29-Jan-19	HASSAN	66	LV3	MRSMSG_220	13:10	13:28	0:18	LINE CLEAR AVAILED
72	29-Jan-19	HASSAN	66	LV4	MRSMSG_220	13:28	13:46	0:18	LINE CLEAR AVAILED
73	29-Jan-19	HASSAN	66	HV1	DODDAKADANUR_66	9:13	9:17	0:04	TRANSFORMER FAULT
74	29-Jan-19	MYSORE	66	G UKKADA-METAGALLY	SRIRANGAPATNA_66	10:00	16:59	6:59	LINE CLEAR AVAILED
75	29-Jan-19	MYSORE	66	HV1	K_HONNALGERE_66	8:20	8:23	0:03	HAND TRIPPED
76	29-Jan-19	MYSORE	66	HV2	K_HONNALGERE_66	8:20	8:24	0:04	HAND TRIPPED
77	29-Jan-19	MYSORE	66	KIADB MANDYA-MADDUR	KIADBMANDYA_66 MADDUR_66	8:17	8:24	0:07	HAND TRIPPED
78	29-Jan-19	MYSORE	66	KIADB MANDYA-MADDUR	KIADBMANDYA_66	15:25	15:51	0:26	LOAD CHANGEOVER
79	29-Jan-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66	8:25	15:42	7:17	LINE CLEAR AVAILED
80	29-Jan-19	MYSORE	66	HV2	KRPET_66	16:22	16:24	0:02	HAND TRIPPED
81	29-Jan-19	MYSORE	66	MANDYA-M2	MALAVALLI_66 HADLI_66	8:17	16:01	7:44	LINE CLEAR AVAILED
82	29-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	20:08	23:59	3:50	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
83	29-Jan-19	MYSORE	66	HV1	SRIRANGAPATNA_66	17:48	18:31	0:42	LINE CLEAR AVAILED
84	29-Jan-19	MYSORE	66	HV2	SRIRANGAPATNA_66	10:15	18:34	8:19	LINE CLEAR AVAILED
85	29-Jan-19	MYSORE	66	HV1	VAJAMANGALA_220	17:33	17:40	0:07	LOAD CHANGEOVER
86	29-Jan-19	MYSORE	66	VAJAMANGALA-KADAKOL A 1	MARADIHUNDI_66 AYRALLI_66	17:47	18:08	0:20	LOAD CHANGEOVER
87	29-Jan-19	TUMKUR	220	TR-1 (HV SIDE )	NEELAGUNDA_220	11:40	13:25	1:44	LINE CLEAR AVAILED
88	29-Jan-19	TUMKUR	110	HONNAVALLI 110-TIPTUR	HALKURKE_110,KEREKODI_110,HU NSEGHATTA_110	13:41	14:21	0:39	LINE CLEAR AVAILED
89	29-Jan-19	TUMKUR	110	HONNAVALLI 110-TIPTUR	HALKURKE_110,KEREKODI_110,HU NSEGHATTA_110	18:53	18:58	0:05	LINE CLEAR AVAILED
90	29-Jan-19	TUMKUR	66	TR-1	CHANNAGIRI_66	13:35	13:45	0:09	LINE CLEAR AVAILED
91	29-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	11:37	17:38	6:01	HAND TRIPPED
92	29-Jan-19	TUMKUR	66	GUTUR 66-DAVANGERE SRS2	GUTUR_66	12:31	14:40	2:08	HAND TRIPPED
93	29-Jan-19	TUMKUR	66	TR-2	GUTTUR_66	14:02	14:05	0:02	HAND TRIPPED
94	29-Jan-19	TUMKUR	66	TR-1(LV SIDE)	NEELAGUNDA_220	11:40	13:25	1:44	LINE CLEAR AVAILED
95	29-Jan-19	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,HARAPPAN AHALLI_66,HALUVAGALU_66,TELA GI_66,	11:40	11:48	0:07	HAND TRIPPED
96	29-Jan-19	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,HARAPPAN AHALLI_66,HALUVAGALU_66,TELA GI_66,	13:23	13:31	0:07	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
97	29-Jan-19	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,HARAPPAN AHALLI_66,HALUVAGALU_66,TELAGI_66,	13:32	14:01	0:28	LINE FAULT
98	29-Jan-19	TUMKUR	66	TR-1	SASALUHALLA_66	7:02	7:03	0:01	TRANSFORMER FAULT
136	30-Jan-19	BAGALKOT	110	110/11KV,HV2	AKSHAY COLONY_110	15:20	15:53	0:33	LINE CLEAR AVAILED
137	30-Jan-19	BAGALKOT	110	110/33KV,HV2	ANKALAGI_110	12:31	13:10	0:39	LINE CLEAR AVAILED
138	30-Jan-19	BAGALKOT	110	ANKOLA-ARGA	ARGA_110	16:25	20:00	3:35	LINE FAULT
139	30-Jan-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR1	MAMADAPUR_110	13:58	20:03	6:05	LINE CLEAR AVAILED
140	30-Jan-19	BAGALKOT	110	BELGAUM220-KANABARGI	KANABARGI_110	1:02	1:09	0:07	LINE FAULT
141	30-Jan-19	BAGALKOT	110	110/33KV,HV1	HANAGAL_110,BELAGALPET_33,BOMMANAHALLI_33,LAXMIPUR_33 ,BASAPUR_33,PALA_33	17:50	18:04	0:14	LINE CLEAR AVAILED
142	30-Jan-19	BAGALKOT	110	110/11KV,HV2	HATTARGI_110	8:24	8:40	0:16	LINE CLEAR AVAILED
143	30-Jan-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110, KOLIGUDDA_33	14:31	18:12	3:41	LINE CLEAR AVAILED
144	30-Jan-19	BAGALKOT	110	110/33KV,HV4	HIDIKAL_110,ALAGAWADI_33	14:31	18:11	3:40	LINE CLEAR AVAILED
145	30-Jan-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	18:04	18:09	0:05	LINE CLEAR AVAILED
146	30-Jan-19	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	16:27	16:53	0:26	LINE FAULT
147	30-Jan-19	BAGALKOT	110	110/33KV,HV-3	SANKESHWAR_ &33KV HEBBAL&KANAGAL	12:37	12:52	0:15	HAND TRIPPED
148	30-Jan-19	BAGALKOT	110	110/11KV,HV-1	SALAHALLI_110	14:28	15:02	0:34	TRANSFORMER FAULT
149	30-Jan-19	BAGALKOT	110	DODDANAVAR SOLAR-NANADI	NANADI_110	0:00	11:30	11:30	LINE CLEAR AVAILED
150	30-Jan-19	BAGALKOT	110	110/11KV,HV1	MURDESHWARA_110	15:51	15:53	0:02	HAND TRIPPED
127	30-Jan-19	BANGALORE	66	HV3	ELECTRONIC CITY	15:37	15:53	0:16	TRANSFORMER FAULT
128	30-Jan-19	BANGALORE	66	HV2	VICTORIA HOSPITAL	12:09	12:13	0:03	LINE CLEAR AVAILED
129	30-Jan-19	BANGALORE	66	HV2	CHAKAVELU	16:06	16:10	0:03	LINE CLEAR AVAILED
130	30-Jan-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	20:41	20:46	0:05	LINE FAULT
131	30-Jan-19	BANGALORE	66	HV2	DEVANGONDHI	14:42	14:54	0:12	TRANSFORMER FAULT
132	30-Jan-19	BANGALORE	66	HV1	SIDDLAGHATTA	7:02	9:00	1:57	LINE CLEAR AVAILED
133	30-Jan-19	BANGALORE	66	HV2	Y HUNSENAHALLI	14:45	15:03	0:18	LINE CLEAR AVAILED
134	30-Jan-19	BANGALORE	66	HV1	Y HUNSENAHALLI	14:35	15:05	0:30	LINE CLEAR AVAILED
135	30-Jan-19	BANGALORE	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE, MATHIKERE	9:10	9:35	0:25	MAIN SUPPLY FAILURE
120	30-Jan-19	GULBARGA	400	JSWVL400-GUTTUR	GUTTUR_400	0:00	17:47	17:47	LINE FAULT
121	30-Jan-19	GULBARGA	220	KUSHTAGI-LINGASUGUR	KUSTAGI_220	13:35	13:40	0:05	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
122	30-Jan-19	GULBARGA	220	LINGAPUR-JVSL-1	JINDAL_220	16:35	16:46	0:11	LOAD CHANGEOVER
123	30-Jan-19	GULBARGA	110	HV1	BEVOOR_110	8:10	8:30	0:20	LINE CLEAR AVAILED
124	30-Jan-19	GULBARGA	110	DHADESUGUR-SIRIGUPPA	DHADESUGUR_110,TEKKALAKOTE_110	14:46	15:05	0:19	LINE FAULT
125	30-Jan-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	11:10	11:20	0:10	LINE FAULT
126	30-Jan-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KAMPLI_110	19:54	20:14	0:20	LINE FAULT
99	30-Jan-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	10:40	13:51	3:11	LINE CLEAR AVAILED
100	30-Jan-19	HASSAN	220	GERSOPA-TALGUPA2	GERUSOPPA_GEN	10:40	13:51	3:11	NFBC ISSUED
101	30-Jan-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	10:34	15:14	4:40	LINE CLEAR AVAILED
102	30-Jan-19	HASSAN	220	MRSSTM-DAVANGERE	MRSMSG_220	9:23	13:58	4:35	LINE CLEAR AVAILED
103	30-Jan-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	10:34	15:14	4:40	LINE CLEAR AVAILED
104	30-Jan-19	HASSAN	110	HV2	MRSMSG_220	9:52	12:28	2:36	LINE CLEAR AVAILED
105	30-Jan-19	HASSAN	110	HV1	GURUPURA_110	10:56	11:36	0:40	LINE CLEAR AVAILED
106	30-Jan-19	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	10:35	15:16	4:41	LINE CLEAR AVAILED
107	30-Jan-19	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:35	15:16	4:41	LINE CLEAR AVAILED
108	30-Jan-19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	10:46	13:53	3:07	LINE CLEAR AVAILED
109	30-Jan-19	HASSAN	110	HV1	SHIVAPURA_110	7:51	9:05	1:14	LINE CLEAR AVAILED
110	30-Jan-19	HASSAN	66	LV2	MRSMSG_220	9:52	12:29	2:37	LINE CLEAR AVAILED
151	30-Jan-19	MYSORE	66	HV1	DODDARAYAPET_66	8:29	8:43	0:13	LINE CLEAR AVAILED
152	30-Jan-19	MYSORE	66	HV1	DODDARAYAPET_66	12:00	12:49	0:48	LINE CLEAR AVAILED
153	30-Jan-19	MYSORE	66	HV2	HONNALLY_MYS_66	11:10	11:45	0:35	HAND TRIPPED
154	30-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	13:15	20:57	7:42	HAND TRIPPED
111	30-Jan-19	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	9:35	13:51	4:15	LINE CLEAR AVAILED
112	30-Jan-19	TUMKUR	220	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:45	14:38	3:53	LINE CLEAR AVAILED
113	30-Jan-19	TUMKUR	66	ANCHEPALYA 220KV- YEDIYUR(BG NAGAR)	YEDIYUR_66	15:27	19:21	3:53	LINE FAULT
114	30-Jan-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	15:22	15:43	0:20	HAND TRIPPED
115	30-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:10	18:03	9:53	HAND TRIPPED
116	30-Jan-19	TUMKUR	66	GUTUR 66-DAVANGERE SRS2	GUTUR_66	16:51	16:54	0:02	HAND TRIPPED
117	30-Jan-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66	1:03	1:16	0:12	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
118	30-Jan-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	7:45	7:53	0:08	LINE FAULT
119	30-Jan-19	TUMKUR	66	KEMPANAHALLI - AGALAKOTE	AGALKOTE_66	9:31	9:37	0:06	HAND TRIPPED
214	31-Jan-19	BAGALKOT	110	110/11KV, HV4	BAILHONGAL_110	15:10	15:21	0:11	LINE CLEAR AVAILED
215	31-Jan-19	BAGALKOT	110	MKHUBLI110-BAILHONGAL	BAILHONGAL_110	15:27	15:34	0:07	LINE CLEAR AVAILED
216	31-Jan-19	BAGALKOT	110	110/11KV, HV2	BANAHATTI_110	0:00	18:28	18:28	LINE CLEAR AVAILED
217	31-Jan-19	BAGALKOT	110	BAGEWADI-MAMDAPUR2	MAMDAPUR_110	10:04	19:23	9:19	LINE CLEAR AVAILED
218	31-Jan-19	BAGALKOT	110	ENERCON-BIJAPUR220	BIJAPUR_220	23:58	23:59	0:01	LINE FAULT
219	31-Jan-19	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	MUDHOL_110	1:49	23:59	22:10	LINE FAULT
220	31-Jan-19	BAGALKOT	110	JAMBAGI-MUDHOL(HALAKI)	HALAKI_110	2:09	3:02	0:53	HAND TRIPPED
221	31-Jan-19	BAGALKOT	110	110/11KV, HV1	JAMBAGI_110	2:09	2:54	0:45	TRANSFORMER FAULT
222	31-Jan-19	BAGALKOT	110	SIRSI1-KUMTA	KUMTA_110	9:23	23:59	14:36	HAND TRIPPED
223	31-Jan-19	BAGALKOT	110	SHIRGUPPI-BILAGI	BILAGI_110	19:38	19:40	0:02	LINE FAULT
224	31-Jan-19	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	10:36	10:40	0:04	TRANSFORMER FAULT
225	31-Jan-19	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	10:31	14:50	4:19	LINE CLEAR AVAILED
226	31-Jan-19	BAGALKOT	110	BAGEWADI220-MUDDEBIHAL	MUDDEBIHAL_110	13:41	13:53	0:12	LINE CLEAR AVAILED
227	31-Jan-19	BAGALKOT	110	110/11KV,HV3	MUDDEBIHAL_110	11:02	13:53	2:51	LINE CLEAR AVAILED
228	31-Jan-19	BAGALKOT	110	MK HUBLI220-HIREBAGEWADI	HIREBAGEWADI_110	18:00	18:15	0:15	LINE CLEAR AVAILED
229	31-Jan-19	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	11:00	11:26	0:26	LINE CLEAR AVAILED
230	31-Jan-19	BANGALORE	66	AUSTIN TOWN - KORAMANGALA	KORAMANGALA	13:00	14:59	1:58	LINE CLEAR AVAILED
231	31-Jan-19	BANGALORE	66	HV2	BMTC	12:03	13:38	1:34	LINE CLEAR AVAILED
232	31-Jan-19	BANGALORE	66	HV2	BMTC	15:03	15:07	0:04	TRANSFORMER FAULT
233	31-Jan-19	BANGALORE	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	7:20	7:30	0:10	LOAD CHANGEOVER
234	31-Jan-19	BANGALORE	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	9:58	10:08	0:10	LOAD CHANGEOVER
235	31-Jan-19	BANGALORE	66	HV1	GOKULA	10:15	10:38	0:23	LINE CLEAR AVAILED
236	31-Jan-19	BANGALORE	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	2:45	2:59	0:14	LOAD CHANGEOVER
237	31-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	2:45	2:59	0:14	MAIN SUPPLY FAILURE
238	31-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	2:45	2:59	0:14	MAIN SUPPLY FAILURE
239	31-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK, GLOBAL TECH PARK (EHT)	2:45	2:48	0:03	MAIN SUPPLY FAILURE
240	31-Jan-19	BANGALORE	66	GLOBAL TECH PARK - VIKAS TECH PARK 220	GLOBAL TECH PARK, GLOBAL TECH PARK (EHT)	12:08	12:10	0:02	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
241	31-Jan-19	BANGALORE	66	GLOBAL TECH PARK - DEVARABISANAHALLI	GLOBAL TECH PARK, GLOBAL TECH PARK (EHT)	9:30	9:50	0:20	LOAD CHANGEOVER
242	31-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	VIKAS TECH PARK 220	9:30	9:50	0:20	LOAD CHANGEOVER
243	31-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	9:30	9:50	0:20	MAIN SUPPLY FAILURE
244	31-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	9:30	9:50	0:20	MAIN SUPPLY FAILURE
245	31-Jan-19	BANGALORE	66	ATTIBELE - SARJAPURA	ATTIBELE	4:10	4:30	0:20	MAIN SUPPLY FAILURE
246	31-Jan-19	BANGALORE	66	ATTIBELE - ANEKAL	ATTIBELE	9:35	9:40	0:05	LOAD CHANGEOVER
247	31-Jan-19	BANGALORE	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	4:20	4:46	0:26	MAIN SUPPLY FAILURE
248	31-Jan-19	BANGALORE	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	9:25	11:15	1:50	LINE CLEAR AVAILED
249	31-Jan-19	BANGALORE	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	10:58	11:15	0:17	LOAD CHANGEOVER
250	31-Jan-19	BANGALORE	66	YERANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	7:07	7:26	0:19	LOAD CHANGEOVER
251	31-Jan-19	BANGALORE	66	HV1	SARJAPURA 220	9:24	9:34	0:10	LOAD CHANGEOVER
252	31-Jan-19	BANGALORE	66	CHANDAPURA - SARJAPURA 220	SARJAPURA 220	7:07	7:26	0:19	MAIN SUPPLY FAILURE
253	31-Jan-19	BANGALORE	66	HV1	SARJAPURA 220	4:12	5:50	1:38	MAIN SUPPLY FAILURE
254	31-Jan-19	BANGALORE	66	HV2	TEMAGONDALU	16:05	16:15	0:10	LINE CLEAR AVAILED
255	31-Jan-19	BANGALORE	66	HV2	TEMAGONDALU	12:59	13:10	0:10	LINE CLEAR AVAILED
256	31-Jan-19	BANGALORE	66	HV1	T BEGUR	10:04	10:10	0:05	LINE CLEAR AVAILED
257	31-Jan-19	BANGALORE	66	RAMANAGARA - KEMPANAHALLI	RAMANAGARA	10:01	11:20	1:18	LINE CLEAR AVAILED
258	31-Jan-19	BANGALORE	66	HV1	MELUR	13:32	14:09	0:36	TRANSFORMER FAULT
259	31-Jan-19	BANGALORE	220	MALUR 220 - KOLAR 1	MALUR 220	4:20	4:55	0:35	MAIN SUPPLY FAILURE
260	31-Jan-19	BANGALORE	220	MALUR 220 - KOLAR 3	SARJAPURA 220	4:20	4:56	0:36	MAIN SUPPLY FAILURE
261	31-Jan-19	BANGALORE	220	MALUR 220 - HOODY 220	MALUR 220	8:19	8:47	0:27	LOAD CHANGEOVER
262	31-Jan-19	BANGALORE	220	KOLAR 220 - PGCIL 1	KOLAR 220	4:15	7:50	3:35	LINE CLEAR AVAILED
263	31-Jan-19	BANGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	4:20	5:48	1:28	MAIN SUPPLY FAILURE
264	31-Jan-19	BANGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	1:18	1:33	0:15	MAIN SUPPLY FAILURE
265	31-Jan-19	BANGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	8:17	9:38	1:21	MAIN SUPPLY FAILURE
266	31-Jan-19	BANGALORE	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	4:20	5:48	1:28	MAIN SUPPLY FAILURE



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
267	31-Jan-19	BANGALORE	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	8:17	9:38	1:20	MAIN SUPPLY FAILURE
268	31-Jan-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT)	4:20	5:48	1:28	MAIN SUPPLY FAILURE
269	31-Jan-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT)	8:17	9:38	1:20	MAIN SUPPLY FAILURE
270	31-Jan-19	BANGALORE	66	MALUR 220 - MALUR 66	MALUR 66	4:20	5:48	1:28	MAIN SUPPLY FAILURE
271	31-Jan-19	BANGALORE	220	KOLAR 220 - PGCIL 1	KOLAR 220	1:05	8:10	7:05	MAIN SUPPLY FAILURE
272	31-Jan-19	BANGALORE	66	KOLAR 220 - BANGARPET 1	BANGARPET	4:13	9:03	4:50	MAIN SUPPLY FAILURE
273	31-Jan-19	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	4:10	9:03	4:52	MAIN SUPPLY FAILURE
274	31-Jan-19	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI, NARASAPURA	4:10	9:03	4:52	MAIN SUPPLY FAILURE
275	31-Jan-19	BANGALORE	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	4:10	9:03	4:52	MAIN SUPPLY FAILURE
276	31-Jan-19	BANGALORE	66	KOLAR 220 - DALASNUR	MALLASANDRA, DRDO (EHT), DAALSNUR	4:10	9:03	4:52	MAIN SUPPLY FAILURE
277	31-Jan-19	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	4:10	9:03	4:53	MAIN SUPPLY FAILURE
278	31-Jan-19	BANGALORE	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	4:10	9:03	4:53	MAIN SUPPLY FAILURE
279	31-Jan-19	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	1:08	3:10	2:01	MAIN SUPPLY FAILURE
280	31-Jan-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	1:09	3:09	1:59	MAIN SUPPLY FAILURE
281	31-Jan-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	4:10	9:03	4:53	MAIN SUPPLY FAILURE
282	31-Jan-19	BANGALORE	66	HV2	DODDABELAVANGALA	8:49	9:00	0:11	TRANSFORMER FAULT
283	31-Jan-19	BANGALORE	66	HV2	DODDABELAVANGALA	20:57	21:05	0:08	TRANSFORMER FAULT
284	31-Jan-19	BANGALORE	66	HV2	DODDABELAVANGALA	21:08	21:15	0:06	TRANSFORMER FAULT
285	31-Jan-19	BANGALORE	66	HV2	DODDABELAVANGALA	21:16	21:25	0:08	TRANSFORMER FAULT
286	31-Jan-19	BANGALORE	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	4:20	5:00	0:40	LOAD CHANGEOVER
287	31-Jan-19	BANGALORE	66	DOMMASANDRA - KACHMARANAHALLI	DOMMASANDRA	9:40	9:50	0:10	LOAD CHANGEOVER
195	31-Jan-19	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	5:14	5:18	0:04	LINE FAULT
196	31-Jan-19	GULBARGA	220	KUSTAGI-LINGAPUR	LINGAPUR_220	8:55	9:36	0:41	LINE FAULT
197	31-Jan-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	8:55	9:38	0:43	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
198	31-Jan-19	GULBARGA	220	KUSTAGI-LINGAPUR,LINGASUGUR	LINGAPUR_220,LINGASUGUR_220	12:25	12:30	0:05	HAND TRIPPED
199	31-Jan-19	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110,KAMALANAGAR_110,DONGRAGOA_110	0:38	0:45	0:07	LINE FAULT
200	31-Jan-19	GULBARGA	110	HALBURGA-KOLHAR2	KOLHAR_110,JANAWADA_110	0:37	0:44	0:07	LINE FAULT
201	31-Jan-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	4:47	5:14	0:27	LINE FAULT
202	31-Jan-19	GULBARGA	110	HV2	KAMPLI_GLB_110	9:02	9:12	0:10	TRANSFORMER FAULT
203	31-Jan-19	GULBARGA	110	HV1	KUDITINI_110	7:58	8:27	0:29	TRANSFORMER FAULT
204	31-Jan-19	GULBARGA	110	HV1	MANTHAL_110	15:08	16:40	1:32	LINE CLEAR AVAILED
205	31-Jan-19	GULBARGA	110	RAJESHWAR-WARDA	RAJESHWAR_110	9:11	13:41	4:30	LINE CLEAR AVAILED
206	31-Jan-19	GULBARGA	110	KOLHAR-NSSK	JANAWADA_110	0:37	0:45	0:08	LINE FAULT
207	31-Jan-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	12:00	12:10	0:10	LINE FAULT
208	31-Jan-19	GULBARGA	110	KOLHAR-HALBURGA1	KOLHAR_110	13:45	13:50	0:05	LINE FAULT
209	31-Jan-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	13:44	13:49	0:05	LINE FAULT
210	31-Jan-19	GULBARGA	110	HV1	RAJESHWAR_110	17:36	17:40	0:04	LINE CLEAR AVAILED
211	31-Jan-19	GULBARGA	110	HV1	SRERAMANAGAR_110	6:52	7:15	0:23	TRANSFORMER FAULT
212	31-Jan-19	GULBARGA	66	CHORNOOR-KUDLIGI	CHORNOOR_66	8:49	10:38	1:49	LINE CLEAR AVAILED
213	31-Jan-19	GULBARGA	66	HV1	KOTTUR_66	13:42	13:47	0:05	TRANSFORMER FAULT
155	31-Jan-19	HASSAN	220	SHRAVATHY-SHIRALKOPPA	sharavathy_gen	14:22	14:39	0:17	LINE FAULT
156	31-Jan-19	HASSAN	220	ARSK2-HSN	ARASIKERE_220	14:46	19:12	4:26	LINE CLEAR AVAILED
157	31-Jan-19	HASSAN	220	HV2	ARASIKERE_220	10:56	23:59	13:03	LINE CLEAR AVAILED
158	31-Jan-19	HASSAN	110	LV2	ARASIKERE_220	10:56	23:59	13:03	LINE CLEAR AVAILED
159	31-Jan-19	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	10:55	11:13	0:18	HAND TRIPPED
160	31-Jan-19	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	12:22	12:33	0:11	HAND TRIPPED
161	31-Jan-19	HASSAN	110	ARSK2-BANAVARA	ARASIKERE_220	10:54	11:16	0:22	HAND TRIPPED
162	31-Jan-19	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	11:07	11:17	0:10	LINE FAULT
163	31-Jan-19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	13:37	16:06	2:29	LINE CLEAR AVAILED
164	31-Jan-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	11:08	13:02	1:54	LINE CLEAR AVAILED
165	31-Jan-19	HASSAN	110	HV1	SHIVPURA_110	6:54	8:51	1:57	LINE CLEAR AVAILED
166	31-Jan-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:23	19:21	11:58	LINE CLEAR AVAILED
167	31-Jan-19	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	22:00	22:10	0:10	LINE FAULT
168	31-Jan-19	HASSAN	66	BYRAPU-BAGUR	K_BYRAPURA_66	18:35	20:20	1:45	MAIN SUPPLY FAILURE
169	31-Jan-19	HASSAN	66	HASSN220-HN PURA	HASSAN_220	10:30	15:10	4:40	NFBC ISSUED
170	31-Jan-19	HASSAN	66	HV2	HASSAN_66	18:54	19:24	0:30	TRANSFORMER FAULT
171	31-Jan-19	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	9:53	15:30	5:37	LINE CLEAR AVAILED
288	31-Jan-19	MYSORE	66	HV1	DODDARAYAPET_66	8:05	8:19	0:14	LINE CLEAR AVAILED
289	31-Jan-19	MYSORE	66	HV1	DODDARAYAPET_66	11:51	12:37	0:45	LINE CLEAR AVAILED
290	31-Jan-19	MYSORE	66	HV2	SATHEGALA_66	10:57	13:00	2:02	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
291	31-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	5:50	12:02	6:11	HAND TRIPPED
292	31-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	16:23	23:59	7:35	HAND TRIPPED
293	31-Jan-19	MYSORE	66	HUNSUR-HOOTAGALLI	BANNIKUPPE_66 HOSURGATE_66	6:31	6:42	0:11	LINE FAULT
172	31-Jan-19	TUMKUR	220	NITTUR 220kV-HASSAN	NITTUR_220	14:49	19:01	4:12	LINE CLEAR AVAILED
173	31-Jan-19	TUMKUR	220	NEELAGUNDA- GUTTUR	NEELAGUNDA_220	2:19	8:10	5:51	LINE FAULT
174	31-Jan-19	TUMKUR	110	TR-1	MAYASANDRA_110	10:38	11:25	0:46	TRANSFORMER FAULT
175	31-Jan-19	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	9:38	10:19	0:40	MAIN SUPPLY FAILURE
176	31-Jan-19	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	9:37	10:33	0:56	MAIN SUPPLY FAILURE
177	31-Jan-19	TUMKUR	66	TR-1	CHANNAGIRI_66	12:30	12:34	0:04	TRANSFORMER FAULT
178	31-Jan-19	TUMKUR	66	TR-2	CHANNAGIRI_66	2:45	11:57	9:11	TRANSFORMER FAULT
179	31-Jan-19	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	0:09	0:25	0:16	LINE FAULT
180	31-Jan-19	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	9:36	10:14	0:38	HAND TRIPPED
181	31-Jan-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	12:10	12:31	0:21	HAND TRIPPED
182	31-Jan-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	12:11	12:33	0:22	HAND TRIPPED
183	31-Jan-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:11	12:36	0:25	HAND TRIPPED
184	31-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	9:09	17:47	8:38	HAND TRIPPED
185	31-Jan-19	TUMKUR	66	HANAGAL- AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	9:49	10:47	0:57	LINE CLEAR AVAILED
186	31-Jan-19	TUMKUR	66	TR-1	HIEMALLANAHOLE_66	18:19	18:24	0:04	TRANSFORMER FAULT
187	31-Jan-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	12:11	12:15	0:04	HAND TRIPPED
188	31-Jan-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	12:28	15:30	3:01	HAND TRIPPED
189	31-Jan-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:38	12:51	0:12	MAIN SUPPLY FAILURE
190	31-Jan-19	TUMKUR	66	TR-2	KUNIGAL_66	2:03	2:11	0:07	TRANSFORMER FAULT
191	31-Jan-19	TUMKUR	66	TR-1	MAYAKONDA_66	21:59	22:06	0:07	TRANSFORMER FAULT
192	31-Jan-19	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	9:49	10:27	0:37	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
193	31-Jan-19	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,SOKK E_66	23:35	23:43	0:08	LINE FAULT
194	31-Jan-19	TUMKUR	66	TR-2	YNHOSKOTE_66	11:13	11:54	0:41	LINE CLEAR AVAILED
326	1-Feb-19	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	15:23	15:25	0:02	HAND TRIPPED
327	1-Feb-19	BAGALKOT	220	RAVI URJA1-ATHANI	ATHANI_220	8:31	14:29	5:58	LINE FAULT
328	1-Feb-19	BAGALKOT	110	BAGEWADI-MAMDAPUR2	MAMDAPUR_110	11:10	13:16	2:06	HAND TRIPPED
329	1-Feb-19	BAGALKOT	110	ENERCON-BIJAPUR220	BIJAPUR_220	0:00	0:23	0:23	LINE CLEAR AVAILED
330	1-Feb-19	BAGALKOT	110	220/110KV,LV1(LV2)	GADAG_220	10:49	23:59	13:10	HAND TRIPPED
331	1-Feb-19	BAGALKOT	110	GADAG220-SAMBAPUR ROAD	SAMBAPUR ROAD_110(STATION NOT INTERRUPTED)	17:03	23:59	6:56	HAND TRIPPED
332	1-Feb-19	BAGALKOT	110	110/33KV,HV2	HUBLI_220	15:33	17:24	1:51	LINE CLEAR AVAILED
333	1-Feb-19	BAGALKOT	110	110/33KV,HV2	SADALAGA_110,BHOJ_33	14:05	15:17	1:12	TRANSFORMER FAULT
334	1-Feb-19	BAGALKOT	110	110/33KV,HV2	SADALAGA_110,BHOJ_33	15:42	23:59	8:17	TRANSFORMER FAULT
335	1-Feb-19	BAGALKOT	110	220/110KV,LV3	MAHALINGAPUR_220	11:33	11:44	0:11	TRANSFORMER FAULT
336	1-Feb-19	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	HIDIKAL_110	11:43	11:47	0:04	HAND TRIPPED
337	1-Feb-19	BANGALORE	66	HV2	DEVANGONDHI	12:41	13:15	0:33	LINE CLEAR AVAILED
338	1-Feb-19	BANGALORE	66	HV1	HAROBEL	9:52	10:01	0:08	TRANSFORMER FAULT
339	1-Feb-19	BANGALORE	66	HV1	DODDABELAVANGALA	1:01	1:08	0:07	TRANSFORMER FAULT
340	1-Feb-19	BANGALORE	66	HV1	DODDABELAVANGALA	1:20	1:29	0:08	TRANSFORMER FAULT
341	1-Feb-19	BANGALORE	66	HV2	DODDABELAVANGALA	8:47	8:51	0:04	TRANSFORMER FAULT
342	1-Feb-19	BANGALORE	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	14:01	14:22	0:21	LINE FAULT
343	1-Feb-19	BANGALORE	220	HV1	SARJAPURA 220	14:01	14:24	0:23	MAIN SUPPLY FAILURE
344	1-Feb-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	14:01	14:24	0:23	MAIN SUPPLY FAILURE
345	1-Feb-19	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:01	14:24	0:23	MAIN SUPPLY FAILURE
346	1-Feb-19	BANGALORE	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	14:01	15:14	1:13	MAIN SUPPLY FAILURE
347	1-Feb-19	BANGALORE	66	HV1	SARJAPURA 220	14:01	14:28	0:27	MAIN SUPPLY FAILURE
348	1-Feb-19	BANGALORE	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	17:36	17:40	0:04	LOAD CHANGEOVER
349	1-Feb-19	BANGALORE	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	15:08	15:12	0:04	LOAD CHANGEOVER
350	1-Feb-19	BANGALORE	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	16:41	16:48	0:07	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
351	1-Feb-19	BANGALORE	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE	6:58	7:12	0:14	LINE FAULT
352	1-Feb-19	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	14:01	14:22	0:21	MAIN SUPPLY FAILURE
353	1-Feb-19	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	14:01	14:22	0:21	MAIN SUPPLY FAILURE
322	1-Feb-19	GULBARGA	220	ALIPUR-GOOTY	GOOTY_220,RAGALPADU_220	9:41	10:57	1:16	LINE CLEAR AVAILED
323	1-Feb-19	GULBARGA	110	HV2	RAJESHWAR_110	12:21	15:31	3:10	LINE CLEAR AVAILED
324	1-Feb-19	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADALAPURA_110	1:05	1:30	0:25	LINE FAULT
325	1-Feb-19	GULBARGA	66	ITTAGI-HBHALLI	HAGARIBOMMANAHALLI_66	17:56	18:00	0:04	LINE FAULT
294	1-Feb-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:39	13:50	2:11	NFBC ISSUED
295	1-Feb-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:41	20:34	3:53	LINE FAULT
296	1-Feb-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	13:57	17:16	3:19	LINE CLEAR AVAILED
297	1-Feb-19	HASSAN	220	MRSSHM-VARAH12	MRSMG_220	6:46	13:28	6:42	LINE FAULT
298	1-Feb-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	13:56	17:15	3:19	LINE CLEAR AVAILED
299	1-Feb-19	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	6:46	13:28	6:42	LINE FAULT
300	1-Feb-19	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	17:42	18:03	0:21	HAND TRIPPED
301	1-Feb-19	HASSAN	110	LV1	KEMAR_220	17:57	18:00	0:03	TRANSFORMER FAULT
302	1-Feb-19	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	17:43	18:07	0:24	MAIN SUPPLY FAILURE
303	1-Feb-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	17:44	18:06	0:22	MAIN SUPPLY FAILURE
304	1-Feb-19	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	18:34	18:40	0:06	MAIN SUPPLY FAILURE
305	1-Feb-19	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	18:34	18:40	0:06	MAIN SUPPLY FAILURE
306	1-Feb-19	HASSAN	110	HV1	SHIVPURA_110	7:09	8:58	1:49	LINE CLEAR AVAILED
307	1-Feb-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	7:54	8:39	0:45	MAIN SUPPLY FAILURE
308	1-Feb-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	7:48	8:39	0:51	LINE CLEAR AVAILED
309	1-Feb-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	10:09	10:58	0:49	LINE FAULT
354	1-Feb-19	MYSORE	66	HV1	DODDARAYAPET_66	8:00	8:16	0:16	LINE CLEAR AVAILED
355	1-Feb-19	MYSORE	66	HV1	DODDARAYAPET_66	12:00	12:24	0:24	LINE CLEAR AVAILED
356	1-Feb-19	MYSORE	66	HV1	FTS_66	16:54	17:06	0:12	HAND TRIPPED
357	1-Feb-19	MYSORE	66	HV1	FTS_66	16:54	17:06	0:12	HAND TRIPPED
358	1-Feb-19	MYSORE	66	HV1	PERIYAPATNA_66	14:00	14:20	0:20	HAND TRIPPED
359	1-Feb-19	MYSORE	66	HV5	SFCSHIVA_66	12:18	23:59	11:40	HAND TRIPPED
360	1-Feb-19	MYSORE	66	VAJAMANGALA-JYOTHINAGARA	JYOTHINAGARA_66	5:19	13:21	8:02	LINE FAULT
361	1-Feb-19	MYSORE	66	JYOTHINAGARA-FTS	JYOTHINAGARA_66 DKMAIDANA_66 FTS_66 BANNIMANTAP_66	4:28	4:44	0:16	LINE FAULT
362	1-Feb-19	MYSORE	66	PERIAPATNA-KUSHALANAGARA 1	PERIYAPATNA_66	13:55	14:20	0:25	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
363	1-Feb-19	MYSORE	66	PERIAPATNA-KUSHALANAGARA 2	PERIYAPATNA_66	13:55	15:30	1:35	HAND TRIPPED
364	1-Feb-19	MYSORE	66	PERIAPATNA-HANAGODU	PERIYAPATNA_66	13:55	15:30	1:35	HAND TRIPPED
365	1-Feb-19	MYSORE	66	PERIAPATNA-HUNSUR	PERIYAPATNA_66	14:00	15:30	1:30	HAND TRIPPED
310	1-Feb-19	TUMKUR	110	TR-1	GUBBI_110	18:42	18:46	0:03	TRANSFORMER FAULT
311	1-Feb-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	12:55	13:05	0:09	LINE FAULT
312	1-Feb-19	TUMKUR	66	TR-2	CHANNAGIRI_66	21:38	21:40	0:02	TRANSFORMER FAULT
313	1-Feb-19	TUMKUR	66	CHIKKABANAGERE- GLOBAL TECKPARK	GLOBAL TECKPARK_IPP_66	12:49	14:20	1:31	LINE CLEAR AVAILED
314	1-Feb-19	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	12:49	14:20	1:31	LINE CLEAR AVAILED
315	1-Feb-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:21	17:46	9:25	HAND TRIPPED
316	1-Feb-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	16:01	16:23	0:22	LINE FAULT
317	1-Feb-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	20:19	20:34	0:14	LINE FAULT
318	1-Feb-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	21:10	21:31	0:20	LINE FAULT
319	1-Feb-19	TUMKUR	66	TR-2	KORA_66	12:36	14:53	2:17	LINE CLEAR AVAILED
320	1-Feb-19	TUMKUR	66	TR-2	RAMPURA_66	8:30	8:37	0:06	TRANSFORMER FAULT
321	1-Feb-19	TUMKUR	66	TURUVANUR66-JAGALU	JAGALUR_66,BIDARKERE_66,SOKKE_66	2:33	2:38	0:05	LINE FAULT
366	2-Feb-19	BAGALKOT	110	110/11KV,HV1	MKHUBLI_220	10:41	12:21	1:40	LINE CLEAR AVAILED
367	2-Feb-19	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	8:08	19:48	11:40	LINE CLEAR AVAILED
368	2-Feb-19	BAGALKOT	110	KONNUR-KERUR	KONNUR_110	0:00	15:22	15:22	LINE CLEAR AVAILED
369	2-Feb-19	BAGALKOT	110	110/33KV,HV-3	ANAKLI_110	8:29	9:05	0:36	TRANSFORMER FAULT
370	2-Feb-19	BAGALKOT	110	110/11KV,HV-1	BABALESHWAR_110	7:45	8:11	0:26	HAND TRIPPED
371	2-Feb-19	BAGALKOT	110	110/11KV,HV-1	ATHARGA_110	11:12	11:17	0:05	HAND TRIPPED
372	2-Feb-19	BAGALKOT	110	110/11KV,HV-3	BAILHONGAL_110	13:04	15:38	2:34	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
373	2-Feb-19	BAGALKOT	110	MK HUBLI-BAILHONGAL	BAILHONGAL_110	15:29	15:36	0:07	HAND TRIPPED
374	2-Feb-19	BAGALKOT	110	220/110KV,LV-1(LV-2)	GADAG_220	0:00	15:24	15:24	HAND TRIPPED
375	2-Feb-19	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	16:37	17:29	0:52	HAND TRIPPED
376	2-Feb-19	BANGALORE	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	11:52	12:24	0:31	LINE FAULT
377	2-Feb-19	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:52	12:24	0:31	MAIN SUPPLY FAILURE
378	2-Feb-19	BANGALORE	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	11:52	12:24	0:31	MAIN SUPPLY FAILURE
379	2-Feb-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:52	12:24	0:31	MAIN SUPPLY FAILURE
380	2-Feb-19	BANGALORE	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	8:30	8:38	0:08	LOAD CHANGEOVER
381	2-Feb-19	BANGALORE	66	HV1	HANUMANTHNAGARA	12:15	12:20	0:05	LINE CLEAR AVAILED
382	2-Feb-19	BANGALORE	66	HV2	NRS 220	9:40	15:27	5:47	LINE CLEAR AVAILED
383	2-Feb-19	BANGALORE	66	HV5	NRS 220	12:30	15:18	2:48	LINE CLEAR AVAILED
384	2-Feb-19	BANGALORE	66	HV1	RR NAGAR	14:16	14:22	0:05	LINE CLEAR AVAILED
385	2-Feb-19	BANGALORE	66	HV2	SIR MV LAYOUT	10:40	10:45	0:05	LINE CLEAR AVAILED
386	2-Feb-19	BANGALORE	66	HV3	YARANDANAHALLI 220	3:02	4:53	1:51	TRANSFORMER FAULT
387	2-Feb-19	BANGALORE	66	HV1	YARANDANAHALLI 220	3:30	3:36	0:06	LOAD CHANGEOVER
388	2-Feb-19	BANGALORE	66	HV3	YARANDANAHALLI 220	17:37	18:40	1:03	LINE CLEAR AVAILED
389	2-Feb-19	BANGALORE	66	HV2	YARANDANAHALLI 220	18:45	18:50	0:05	LOAD CHANGEOVER
390	2-Feb-19	BANGALORE	66	HV2	YARANDANAHALLI 220	12:10	12:19	0:09	LOAD CHANGEOVER
391	2-Feb-19	BANGALORE	66	HV1	YARANDANAHALLI 220	18:46	18:55	0:09	LOAD CHANGEOVER
392	2-Feb-19	BANGALORE	66	HV1	LR BANDE	10:38	10:48	0:09	LINE CLEAR AVAILED
393	2-Feb-19	BANGALORE	66	HV2	RMV	15:01	15:04	0:02	LINE CLEAR AVAILED
394	2-Feb-19	GULBARGA	220	KAPNOOR-SHAHAPUR1	KAPNOOR_220	5:01	5:25	0:24	LINE FAULT
395	2-Feb-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	12:40	12:47	0:07	LINE FAULT
396	2-Feb-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	15:23	15:24	0:01	LINE FAULT
397	2-Feb-19	GULBARGA	110	STARMETALLIC_IPP-MUNIRABAD	MUNIRABAD_220	23:03	23:41	0:38	LINE FAULT
398	2-Feb-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110	11:51	19:43	7:52	LINE CLEAR AVAILED
399	2-Feb-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110	2:43	20:31	17:48	LINE FAULT
400	2-Feb-19	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	21:26	21:45	0:19	LINE FAULT
401	2-Feb-19	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	0:25	0:50	0:25	LINE FAULT
402	2-Feb-19	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	4:10	4:30	0:20	LINE FAULT
403	2-Feb-19	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	20:13	20:30	0:17	LINE FAULT
404	2-Feb-19	HASSAN	110	HV1	PUTTUR_110	10:23	10:30	0:07	TRANSFORMER FAULT
405	2-Feb-19	HASSAN	110	HV2	BHADRAVATHI_110	23:00	23:59	0:59	TRANSFORMER FAULT
406	2-Feb-19	HASSAN	110	HV1	HOSANGADI_110	19:53	21:04	1:11	TRANSFORMER FAULT
407	2-Feb-19	HASSAN	110	LV1	KADUR_220	8:05	8:18	0:13	HAND TRIPPED
408	2-Feb-19	HASSAN	66	HASSN22-ARKALGUD2	HASSAN_220	17:31	17:51	0:20	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
409	2-Feb-19	HASSAN	66	HV1	BELUR_6666	18:19	21:07	2:48	LINE CLEAR AVAILED
410	2-Feb-19	HASSAN	66	SAKALE-HASSAN	SAKLESHAPURA_66	14:38	14:53	0:15	LINE FAULT
411	2-Feb-19	HASSAN	66	HV2	S.BELAGOLA_66	11:02	11:06	0:04	TRANSFORMER FAULT
412	2-Feb-19	MYSORE	66	PONNAMPETE-VIRAJPET	VIRAJPET_66	10:41	11:35	0:53	LINE CLEAR AVAILED
413	2-Feb-19	MYSORE	66	HV1	BETTADHAPURA_66	12:40	14:10	1:30	LINE CLEAR AVAILED
414	2-Feb-19	MYSORE	66	HV2	BETTADHAPURA_66	11:57	14:10	2:13	LINE CLEAR AVAILED
415	2-Feb-19	MYSORE	66	HV1	MADIKERI_66	14:37	16:06	1:28	LINE CLEAR AVAILED
416	2-Feb-19	MYSORE	66	HV2	SANTHESARAGUR_66	11:00	12:40	1:40	LINE CLEAR AVAILED
417	2-Feb-19	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	MADESWARAPURA_66 JAKKANAHALLY_66 G MALLIGERE_66, GUDDENAHALLI_6 6 BOGADHI_66 NAGAMANGALA_66	9:05	9:21	0:16	LINE FAULT
418	2-Feb-19	MYSORE	66	MANDYA-M2	MALAVALLI_66 HADLI_66	8:43	8:54	0:10	LINE FAULT
419	2-Feb-19	MYSORE	220	HOOTAGALLI-BASTIPURA 1	BANNIKUPPE_66, HOSURGATE_66 HUNSUR_66 ELAVALA_66 GAVADAGERE_66 METAGALLY_66 HEBBAL_66 VIJAYANAGRAMYS_66, KHBCOLONY_66 DMG_HALLI_66 BELAGOLA_66 HEBBAL- INDUSTRIAL_66 DATTAGALLY_66 RKNAGARA_66 BOGADHI_66 KALAMANDIRA_66 FTS_66BANNIMANTAP_66	20:25	21:21	0:56	MAIN SUPPLY FAILURE
420	2-Feb-19	MYSORE	220	HOOTAGALLI-BASTIPURA 2	BANNIKUPPE_66, HOSURGATE_66 HUNSUR_66 ELAVALA_66 GAVADAGERE_66 METAGALLY_66 HEBBAL_66 VIJAYANAGRAMYS_66 KHBCOLONY_66 DMG_HALLI_66 BELAGOLA_66 HEBBAL- INDUSTRIAL_66 DATTAGALLY_66 RKNAGARA_66 BOGADHI_66 KALAMANDIRA_66 FTS_66BANNIMANTAP_66	20:25	21:22	0:57	MAIN SUPPLY FAILURE



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
421	2-Feb-19	MYSORE	66	HV1	BYLUKUPPE_66	14:00	15:20	1:20	TRANSFORMER FAULT
422	2-Feb-19	TUMKUR	110	TR-2	KADEHALLI_110	15:37	15:43	0:06	LINE CLEAR AVAILED
423	2-Feb-19	TUMKUR	66	TR-2	CHANNAGIRI_66	8:40	8:45	0:04	TRANSFORMER FAULT
424	2-Feb-19	TUMKUR	66	TR-2	DYAVARANAHALLI_66	9:12	10:24	1:11	LINE CLEAR AVAILED
425	2-Feb-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	9:12	17:38	8:26	HAND TRIPPED
426	2-Feb-19	TUMKUR	66	TR-1	CHANNAGIRI_66	17:15	17:22	0:07	LINE CLEAR AVAILED
427	2-Feb-19	TUMKUR	66	TR-1	HALUVAGALU_66	17:15	17:22	0:07	LINE CLEAR AVAILED
428	2-Feb-19	TUMKUR	66	HARAPPANAHALLI-ITTAGI	HARAPPANAHALLI_66	12:39	13:24	0:44	LINE CLEAR AVAILED
429	2-Feb-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	17:44	17:53	0:08	LINE FAULT
430	2-Feb-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	18:16	18:36	0:19	LINE FAULT
431	2-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	21:06	21:12	0:05	LINE FAULT
432	2-Feb-19	TUMKUR	66	NAGASAMUDRA- HANAGAL	NAGASAMUDRA_66	12:06	14:56	2:49	LINE CLEAR AVAILED
433	2-Feb-19	TUMKUR	66	NAGASAMUDRA- RAMPUR	NAGASAMUDRA_66, RAMPURA_66	12:06	14:59	2:52	LINE CLEAR AVAILED
434	2-Feb-19	TUMKUR	66	RAMPURA66-CLEAN SOLAR_IPP_66	CLEAN SOLAR_IPP_66	15:09	15:46	0:36	HAND TRIPPED
435	2-Feb-19	TUMKUR	66	RAMPURA66-ABLETEC(SSHTY)_IPP_66	ABLETEC(SSHTY)_IPP_66	15:09	15:46	0:37	HAND TRIPPED
436	2-Feb-19	TUMKUR	66	RAMPURA66-WELSPUN SOLAR	WELSPUN SOLAR_IPP_66	15:09	15:46	0:37	HAND TRIPPED
437	3-Feb-19	BAGALKOT	110	110/33KV, HV2	SADALAGA_110, BHOJ_33	0:00	18:15	18:15	LINE CLEAR AVAILED
438	3-Feb-19	BAGALKOT	110	110/11KV,HV2	NAVALGUND_110	20:33	21:03	0:30	TRANSFORMER FAULT
439	3-Feb-19	BAGALKOT	220	220/110KV, HV1&LV1	MKHUBLI_220	11:43	17:17	5:34	LINE CLEAR AVAILED
440	3-Feb-19	BAGALKOT	110	110/11KV,HV1	MKHUBLI_220	11:04	15:54	4:50	LINE CLEAR AVAILED
441	3-Feb-19	BAGALKOT	110	MKHUBLI220-KITTUR	KITTUR_110	10:15	17:45	7:30	LINE CLEAR AVAILED
442	3-Feb-19	BAGALKOT	110	110/11KV,HV2	KHANAPUR_110	8:44	9:36	0:52	TRANSFORMER FAULT
443	3-Feb-19	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	5:41	5:58	0:17	LINE FAULT
444	3-Feb-19	BAGALKOT	220	GHATAPRABHA-KUDACHI	GHATAPRABHA_220	20:51	22:20	1:29	HAND TRIPPED
445	3-Feb-19	BAGALKOT	220	GHATAPRABHA-CHIKKODI	GHATAPRABHA_220	21:02	22:16	1:14	HAND TRIPPED
446	3-Feb-19	BAGALKOT	220	CHIKKODI-BELGAUM(BELGAUM2)	CHIKKODI_220	20:53	23:59	3:06	HAND TRIPPED
447	3-Feb-19	BANGALORE	220	MALUR 220 - KOLAR 1	MALUR 220	10:57	11:27	0:30	LOAD CHANGEOVER
448	3-Feb-19	BANGALORE	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	11:05	11:35	0:30	LOAD CHANGEOVER
449	3-Feb-19	BANGALORE	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	11:05	11:35	0:30	LINE CLEAR AVAILED
450	3-Feb-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:05	11:35	0:30	LINE CLEAR AVAILED
451	3-Feb-19	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:05	11:35	0:30	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
452	3-Feb-19	BANGALORE	220	MALUR 220 - KOLAR 3	MALUR 220	19:45	20:07	0:22	LOAD CHANGEOVER
453	3-Feb-19	BANGALORE	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	19:45	20:15	0:30	LOAD CHANGEOVER
454	3-Feb-19	BANGALORE	66	ATTIBELE - ANEKAL	ATTIBELE	20:30	20:35	0:05	LOAD CHANGEOVER
455	3-Feb-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	19:45	20:15	0:30	LINE CLEAR AVAILED
456	3-Feb-19	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	19:45	20:15	0:30	LINE CLEAR AVAILED
457	3-Feb-19	BANGALORE	66	HV1	HAROBELE	15:08	15:14	0:06	TRANSFORMER FAULT
458	3-Feb-19	BANGALORE	66	GLOBAL TECH PARK - DEVARABISANAHALLI	GLOBAL TECH PARK, GLOBAL TECH PARK (EHT)	20:37	20:38	0:01	LOAD CHANGEOVER
459	3-Feb-19	GULBARGA	110	MALLAT-BYAGWAT-1	BYAGAWAT_110	2:39	2:56	0:17	LINE FAULT
460	3-Feb-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:40	12:45	1:05	NFBC ISSUED
461	3-Feb-19	HASSAN	220	KADUR-DABUSET	KADUR_220	9:52	15:54	6:02	HAND TRIPPED
462	3-Feb-19	HASSAN	110	HV2	BHADRAVATHI_110	0:00	14:51	14:51	TRANSFORMER FAULT
463	3-Feb-19	HASSAN	110	HV2	BHADRAVATHI_110	15:02	15:05	0:03	HAND TRIPPED
464	3-Feb-19	HASSAN	110	HV1	BHADRAVATHI_110	11:51	12:49	0:58	LINE CLEAR AVAILED
465	3-Feb-19	HASSAN	110	HV2	MSEZ_220	11:47	13:06	1:19	LINE CLEAR AVAILED
466	3-Feb-19	HASSAN	110	HV1	SHIVPURA_110	7:12	9:08	1:56	LINE CLEAR AVAILED
467	3-Feb-19	HASSAN	66	HV1	ARAKALGUD_66	21:30	23:59	2:29	TRANSFORMER FAULT
468	3-Feb-19	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	19:26	21:08	1:42	LINE CLEAR AVAILED
469	3-Feb-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	14:47	14:56	0:09	LINE FAULT
470	3-Feb-19	MYSORE	220	HOOTAGALLI-BASTIPURA 1	BANNIKUPPE_66, HOSURGATE_66 HUNSUR_66 ELAVALA_66 GAVADAGERE_66 METAGALLY_66 HEBBAL_66 VIJAYANAGRAMYS_66, KHBCOLONY_66 DMG_HALLI_66 BELAGOLA_66 HEBBAL- INDUSTRIAL_66 DATTAGALLY_66 RKNAGARA_66 BOGADHI_66 KALAMANDIRA_66 FTS_66BANNIMANTAP_66	20:25	21:21	0:56	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
471	3-Feb-19	MYSORE	220	HOOTAGALLI-BASTIPURA 2	BANNIKUPPE_66, HOSURGATE_66 HUNSUR_66 ELAVALA_66 GAVADAGERE_66 METAGALLY_66 HEBBAL_66 VIJAYANAGRAMYS_66 KHBCOLONY_66 DMG_HALLI_66 BELAGOLA_66 HEBBAL- INDUSTRIAL_66 DATTAGALLY_66 RKNAGARA_66 BOGADHI_66 KALAMANDIRA_66 FTS_66BANNIMANTAP_66	20:25	21:22	0:57	MAIN SUPPLY FAILURE
472	3-Feb-19	MYSORE	66	HV1	BYLUKUPPE_66	14:00	15:20	1:20	TRANSFORMER FAULT
473	3-Feb-19	TUMKUR	66	HONNALLI 220KV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	15:10	17:00	1:49	LINE CLEAR AVAILED
474	4-Feb-19	BAGALKOT	220	CHIKKODI-BELGAUM(BELGAUM 2)	CHIKKODI_220	0:00	7:42	7:42	HAND TRIPPED
475	4-Feb-19	BAGALKOT	110	110/11KV,HV-1	BILAGI_110	16:19	16:33	0:14	TRANSFORMER FAULT
476	4-Feb-19	BAGALKOT	110	110/11KV,HV-1	BILAGI_110	16:49	17:00	0:11	TRANSFORMER FAULT
477	4-Feb-19	BAGALKOT	110	110/11KV,HV-2	MALAGHAN(B)	9:37	9:39	0:02	TRANSFORMER FAULT
478	4-Feb-19	BAGALKOT	110	110/11KV,HV-2	MALAGHAN(B)	9:55	10:24	0:29	TRANSFORMER FAULT
479	4-Feb-19	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	13:39	14:36	0:57	LINE CLEAR AVAILED
480	4-Feb-19	BAGALKOT	110	110/33KV, HV2	SADALAGA_110, BHOJ_33	10:30	15:08	4:38	TRANSFORMER FAULT
481	4-Feb-19	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	14:01	14:18	0:17	LINE CLEAR AVAILED
482	4-Feb-19	BANGALORE	66	KOLAR 220 - SRINIVASPURA	DALASNUR, MALLASANDRA, YELDUR	11:00	17:05	6:05	LINE CLEAR AVAILED
483	4-Feb-19	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	11:00	16:48	5:48	LINE CLEAR AVAILED
484	4-Feb-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	16:37	16:42	0:04	LINE FAULT
485	4-Feb-19	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	10:57	16:51	5:53	LINE CLEAR AVAILED
486	4-Feb-19	BANGALORE	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	15:12	15:31	0:18	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
487	4-Feb-19	BANGALORE	66	HV1	CHAKAVELU	15:12	15:31	0:19	TRANSFORMER FAULT
488	4-Feb-19	BANGALORE	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	10:56	16:50	5:53	LINE CLEAR AVAILED
489	4-Feb-19	BANGALORE	66	HV1	SIDDALAGATTA	10:59	11:13	0:13	LINE CLEAR AVAILED
490	4-Feb-19	BANGALORE	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	6:10	6:19	0:08	LOAD CHANGEOVER
491	4-Feb-19	BANGALORE	66	HV1	CHANDAPURA	14:26	14:30	0:03	LINE CLEAR AVAILED
492	4-Feb-19	BANGALORE	66	HV2	CHANDAPURA	15:40	15:45	0:05	LINE CLEAR AVAILED
493	4-Feb-19	BANGALORE	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	13:07	13:13	0:06	LINE CLEAR AVAILED
494	4-Feb-19	GULBARGA	220	KAPNOOR-SHAHAPUR1	SHAHPOOR_220	4:48	5:05	0:17	LINE FAULT
495	4-Feb-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	2:25	2:40	0:15	LINE FAULT
496	4-Feb-19	GULBARGA	110	ALIPUR-BELARYSOUTH2	BELLARYSOUTH_110,	2:25	2:40	0:15	LINE FAULT
497	4-Feb-19	HASSAN	220	HV2	ARASIKERE_110	0:00	13:46	13:46	LINE CLEAR AVAILED
498	4-Feb-19	HASSAN	220	ARSK2-SHMG	ARASIKERE_110	10:05	16:31	6:26	LINE FAULT
499	4-Feb-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	11:37	11:44	0:07	LINE FAULT
500	4-Feb-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	15:23	20:25	5:02	LINE FAULT
501	4-Feb-19	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	16:31	23:59	7:28	LINE FAULT
502	4-Feb-19	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	2:28	7:19	4:51	LINE FAULT
503	4-Feb-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	15:23	20:27	5:04	LINE FAULT
504	4-Feb-19	HASSAN	220	HV1	SHIRALKOPPA_220	18:11	18:25	0:14	HAND TRIPPED
505	4-Feb-19	HASSAN	110	HV2	MRSMSG_220	15:11	23:59	8:48	LINE CLEAR AVAILED
506	4-Feb-19	HASSAN	110	ARSK2-ARSKR	ARASIKERE_110	13:30	13:52	0:22	HAND TRIPPED
507	4-Feb-19	HASSAN	110	ARSK2-BANAVARA	ARASIKERE_110	13:36	13:52	0:16	HAND TRIPPED
508	4-Feb-19	HASSAN	110	LV2	ARASIKERE_110	0:00	13:51	13:51	LINE CLEAR AVAILED
509	4-Feb-19	HASSAN	110	LV1	SHIRALKOPPA_220	18:11	18:28	0:17	HAND TRIPPED
510	4-Feb-19	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	6:33	12:54	6:21	LINE FAULT
511	4-Feb-19	HASSAN	66	LV2	MRSMSG_220	15:11	23:59	8:48	LINE CLEAR AVAILED
512	4-Feb-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:19	19:53	12:34	LINE CLEAR AVAILED
513	4-Feb-19	HASSAN	66	HV1	ARKD_66	0:00	9:10	9:10	TRANSFORMER FAULT
514	4-Feb-19	HASSAN	66	HV1	ARKD_66	9:50	11:05	1:15	LINE CLEAR AVAILED
515	4-Feb-19	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	15:14	18:08	2:54	LINE CLEAR AVAILED
516	4-Feb-19	MYSORE	66	HV1	BYLUKUPPE_66	11:14	11:30	0:15	LINE CLEAR AVAILED
517	4-Feb-19	MYSORE	66	HV2	MYSORESOUTH_66	10:49	23:59	13:09	LINE CLEAR AVAILED
518	4-Feb-19	MYSORE	66	HV1	PANDAVAPURA_66	11:43	13:33	1:50	LINE CLEAR AVAILED
519	4-Feb-19	MYSORE	66	HV2	PANDAVAPURA_66	12:33	14:18	1:44	LINE CLEAR AVAILED
520	4-Feb-19	MYSORE	66	PARINAMIPURA-TALAKADU	THALAKADU_66 BGPURA_66	21:41	21:48	0:07	LINE FAULT
521	4-Feb-19	MYSORE	66	PARINAMIPURA-TALAKADU	THALAKADU_66 BGPURA_66	21:52	22:02	0:10	LINE FAULT
522	4-Feb-19	MYSORE	66	PARINAMIPURA-TALAKADU	THALAKADU_66 BGPURA_66	22:16	22:44	0:28	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
523	4-Feb-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66 KIRUGAVALU_66 MALIYURU_66	9:12	9:18	0:05	LOAD CHANGEOVER
524	4-Feb-19	TUMKUR	220	KB CROSS 220kV- SHIMOGA	MRSMSG_220	2:28	7:22	4:53	LINE FAULT
525	4-Feb-19	TUMKUR	110	HONNAVALI 110-TIPTUR	HALKURKE_110,KEREKODI_110,HU NSEGHATTA_110	16:20	16:57	0:36	LINE CLEAR AVAILED
526	4-Feb-19	TUMKUR	110	HONNAVALI 110-TIPTUR	HALKURKE_110,KEREKODI_110,HU NSEGHATTA_110	17:01	17:10	0:08	LINE CLEAR AVAILED
527	4-Feb-19	TUMKUR	110	TR-3	GUBBI_110	16:09	17:36	1:26	LINE CLEAR AVAILED
528	4-Feb-19	TUMKUR	110	TR-1	KALLUR_110	10:43	11:15	0:31	TRANSFORMER FAULT
529	4-Feb-19	TUMKUR	110	TR-2	NITTUR_220	17:41	18:32	0:51	LINE CLEAR AVAILED
530	4-Feb-19	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	14:34	14:41	0:07	LINE FAULT
531	4-Feb-19	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	15:14	15:24	0:09	LINE FAULT
532	4-Feb-19	TUMKUR	66	ANTHRASANAHALI 220kV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	6:55	7:14	0:19	LINE FAULT
533	4-Feb-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	14:07	17:27	3:20	LINE CLEAR AVAILED
534	4-Feb-19	TUMKUR	66	TR-2	CHIKKABANAGERE_66	11:23	13:57	2:33	LINE CLEAR AVAILED
535	4-Feb-19	TUMKUR	66	DYAVARANAHALI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	7:40	17:42	10:02	HAND TRIPPED
536	4-Feb-19	TUMKUR	66	HANAGAL- AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	16:49	19:45	2:55	LINE CLEAR AVAILED
537	4-Feb-19	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	9:00	9:04	0:04	HAND TRIPPED
538	4-Feb-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:49	11:53	2:04	LINE FAULT
539	4-Feb-19	TUMKUR	66	TR-1	SIRA_66	12:35	13:09	0:33	LINE CLEAR AVAILED
540	4-Feb-19	TUMKUR	66	TR-2	SIRA_66	13:14	13:32	0:17	LINE CLEAR AVAILED