

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 24.09.2019 TO 30.09.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	24-Sep-19	BAGALKOT	110	110/33KV,HV3	BELUR_110	9:48	21:47	11:59	LINE CLEAR AVAILED
2	24-Sep-19	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	17:00	23:59	6:59	LINE FAULT
3	24-Sep-19	BAGALKOT	220	BAGALKOT-GADAG 1	BAGALKOT_220	22:19	23:59	1:40	LINE CLEAR AVAILED
4	24-Sep-19	BAGALKOT	220	ADPH 2 -BAGEWADI	BAGEWADI_220	19:18	20:40	1:22	LINE FAULT
5	24-Sep-19	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMDAPUR_110	19:20	20:03	0:43	LINE FAULT
6	24-Sep-19	BAGALKOT	220	BELGUM-CHIKKODI2	BELGAUM_220	6:35	11:15	4:40	LINE CLEAR AVAILED
7	24-Sep-19	BAGALKOT	220	BELGUM-NARENDRA1	BELGAUM_220	5:01	9:49	4:48	LINE FAULT
8	24-Sep-19	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	10:00	17:42	7:42	LINE CLEAR AVAILED
9	24-Sep-19	BAGALKOT	220	CHIKKODI-BELGAUM1	CHIKKODI_220	11:01	18:38	7:37	LINE CLEAR AVAILED
10	24-Sep-19	BAGALKOT	220	220/110KV,HV1,LV1&HV2,LV2	CHIKKODI_220,ANKALI_110,CHIKKODI_110,SHANKESHWAR_110,NIPPANI_110,SADALAGA_110,DKSSK_110,BHOJ_110,RAIBAG1&2_110.NA NADI_110	10:10	18:38	8:28	LINE CLEAR AVAILED
11	24-Sep-19	BAGALKOT	220	CHIKKODI-GHATAPRABHA	CHIKKODI_220	11:12	18:38	7:26	LINE CLEAR AVAILED
12	24-Sep-19	BAGALKOT	220	CHIKKODI-KUDUCHI	CHIKKODI_220	11:10	19:07	7:57	LINE CLEAR AVAILED
13	24-Sep-19	BAGALKOT	220	CHIKKODI-MUDASHINGI	CHIKKODI_220	11:05	23:59	12:54	LINE CLEAR AVAILED
14	24-Sep-19	BAGALKOT	220	CHIKKODI-TALANDGE	CHIKKODI_220	11:05	23:59	12:54	LINE CLEAR AVAILED
15	24-Sep-19	BAGALKOT	110	110/11KV,HV1	CHIKKODI_220	10:00	17:47	7:47	LINE CLEAR AVAILED
16	24-Sep-19	BAGALKOT	110	110/11KV,HV1	CHIKKODI_220	18:50	19:00	0:10	TRANSFORMER FAULT
17	24-Sep-19	BAGALKOT	110	110/11KV,HV1	CHIKKODI_220	21:00	21:05	0:05	TRANSFORMER FAULT
18	24-Sep-19	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	2:30	3:00	0:30	LINE FAULT
19	24-Sep-19	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA2	GHATAPRABHA_110	3:30	3:40	0:10	LINE FAULT
20	24-Sep-19	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	3:30	3:40	0:10	LINE FAULT
21	24-Sep-19	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA1	GHATAPRABHA_110	8:55	9:40	0:45	LINE FAULT
22	24-Sep-19	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA2	GHATAPRABHA_110	3:45	9:45	6:00	LINE CLEAR AVAILED
23	24-Sep-19	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	4:10	9:45	5:35	LINE CLEAR AVAILED
24	24-Sep-19	BAGALKOT	110	110/33KV,HV3,HV4	GOPPANAKOPPA_110,KMC_33KV, KUSUGAL_33KV	4:57	5:15	0:18	TRANSFORMER FAULT
25	24-Sep-19	BAGALKOT	110	110/33KV,HV4	GOPPANAKOPPA_110,KMC_33KV, KUSUGAL_33KV	5:28	5:37	0:09	TRANSFORMER FAULT
26	24-Sep-19	BAGALKOT	110	110/33KV,HV4	GOPPANAKOPPA_110,KMC_33KV, KUSUGAL_33KV	12:20	13:05	0:45	LINE CLEAR AVAILED
27	24-Sep-19	BAGALKOT	110	HUKKERI-HATTARGI	HATTARGI_110	10:06	23:59	13:53	LINE CLEAR AVAILED
28	24-Sep-19	BAGALKOT	110	110/33KV,HV2	UTTUR_110,YADAWAD_33,VANTA GOD_33	0:01	0:29	0:28	HAND TRIPPED
29	24-Sep-19	BAGALKOT	110	110/33KV,HV2	UTTUR_110,YADAWAD_33,VANTA GOD_33	11:15	12:02	0:47	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
30	24-Sep-19	BAGALKOT	110	110/33KV,HV2	UTTUR_110,YADAWAD_33,VANTA GOD_33	13:22	13:36	0:14	LINE CLEAR AVAILED
31	24-Sep-19	BAGALKOT	110	SIRSI-UMMACHAGI	UMMACHAGI_110	18:15	18:55	0:40	LINE CLEAR AVAILED
32	24-Sep-19	BAGALKOT	110	110/11KV,HV1	UCHAGOAN_110	15:24	16:05	0:41	LINE CLEAR AVAILED
33	24-Sep-19	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	7:50	14:46	6:56	LINE FAULT
34	24-Sep-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	11:00	14:47	3:47	LINE CLEAR AVAILED
35	24-Sep-19	BAGALKOT	110	HUBLI220-KADANAKOPPA	KADANAKOPPA_110	11:28	15:20	3:52	LINE CLEAR AVAILED
36	24-Sep-19	BAGALKOT	110	SOUDATTI220-NARAGUND	NARAGUND_110	16:31	17:01	0:30	LINE FAULT
37	24-Sep-19	BAGALKOT	110	SOUDATTI220-RAMDURGA 1&2	RAMDURGA_110	16:31	17:12	0:41	LINE FAULT
38	24-Sep-19	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	0:00	16:00	16:00	LINE CLEAR AVAILED
39	24-Sep-19	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	16:49	23:59	7:10	LINE FAULT
40	24-Sep-19	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	10:23	18:43	8:20	LINE CLEAR AVAILED
41	24-Sep-19	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	10:00	10:29	0:29	LINE CLEAR AVAILED
42	24-Sep-19	BAGALKOT	110	110/11KV,HV1	RAIBAG_110	3:03	3:11	0:08	TRANSFORMER FAULT
43	24-Sep-19	BAGALKOT	110	CHIKKODI220-NANADI	NANADI_110	10:09	17:49	7:40	LINE CLEAR AVAILED
44	24-Sep-19	BAGALKOT	110	110/11KV, HV1&HV2	NANADI_110	10:09	17:53	7:44	LINE CLEAR AVAILED
45	24-Sep-19	BAGALKOT	110	DODDANAVAR-NANADI	NANADI_110	10:30	17:55	7:25	LINE CLEAR AVAILED
46	24-Sep-19	BAGALKOT	110	VIJAYNAGAR SUGARS-MUNDARGI	MUNDARGI_110	12:19	13:05	0:46	LINE CLEAR AVAILED
47	24-Sep-19	BAGALKOT	220	220/110KV, HV1	SIRSI_220	10:56	11:45	0:49	LINE CLEAR AVAILED
48	24-Sep-19	BAGALKOT	220	220/110KV,HV3&LV3	MAHALINGAPUR_220	11:41	17:52	6:11	LINE CLEAR AVAILED
49	24-Sep-19	BAGALKOT	110	110/33KV,HV3	LOKAPUR_110, RSSKN_33, BATKURKI_33	4:35	4:42	0:07	TRANSFORMER FAULT
50	24-Sep-19	BAGALKOT	110	110/11KV,HV1	KUD DHARWAD_110	0:00	0:11	0:11	LINE CLEAR AVAILED
51	24-Sep-19	BAGALKOT	110	110/11KV,HV1	KADANAKOPPA_110	10:15	18:03	7:48	LINE CLEAR AVAILED
52	24-Sep-19	BAGALKOT	110	ITANAL-HIDIKAL	HIDIKAL_110	10:39	19:00	8:21	LINE CLEAR AVAILED
53	24-Sep-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	10:18	18:58	8:40	LINE CLEAR AVAILED
54	24-Sep-19	BENGALURU	220	HOODY 400 - ITPL 220	ITPL (EHT), EPIP 220	15:58	16:10	0:12	LINE CLEAR AVAILED
55	24-Sep-19	BENGALURU	66	EPIP 220 - CHANDAPURA	SHAMRAJ TECH PARK, KACHMARANAHALLI	15:58	16:13	0:15	MAIN SUPPLY FAILURE
56	24-Sep-19	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	15:58	16:13	0:15	MAIN SUPPLY FAILURE
57	24-Sep-19	BENGALURU	220	HV1	EPIP 220	15:58	16:10	0:12	MAIN SUPPLY FAILURE
58	24-Sep-19	BENGALURU	220	HV2	EPIP 220	15:58	16:10	0:12	MAIN SUPPLY FAILURE
59	24-Sep-19	BENGALURU	66	BAGMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	0:00	8:15	8:15	LINE FAULT
60	24-Sep-19	BENGALURU	66	BAGMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	8:31	12:22	3:50	LINE CLEAR AVAILED
61	24-Sep-19	BENGALURU	66	BOODIGERE - HOSKOTE 220	BOODIGERE	10:08	10:22	0:14	LOAD CHANGEVER
62	24-Sep-19	BENGALURU	66	BEGUR 220 - VIDYANAGARA	VIDYANAGARA	16:42	17:44	1:02	LINE FAULT
63	24-Sep-19	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	16:42	17:20	0:38	MAIN SUPPLY FAILURE
64	24-Sep-19	BENGALURU	66	CHELUR - ESUN SOLAR (IPP)	CHELUR	14:44	14:57	0:12	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
65	24-Sep-19	BENGALURU	66	CHINTAMANI 220 - YENIGADLE	CHELUR, CHAKAVELU, YENIGADLE	14:44	14:49	0:05	LINE FAULT
66	24-Sep-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1 & 2	DEVANAHALLI, KUNDANA	17:28	17:37	0:09	LINE CLEAR AVAILED
67	24-Sep-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	5:55	6:19	0:24	LINE FAULT
68	24-Sep-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	16:37	17:13	0:36	LINE FAULT
69	24-Sep-19	BENGALURU	66	HV2	JANGAMAKOTE	6:00	6:22	0:21	TRANSFORMER FAULT
70	24-Sep-19	BENGALURU	66	HV1	MAGADI 66	10:48	12:16	1:28	LINE CLEAR AVAILED
71	24-Sep-19	BENGALURU	66	SIDLAGHATTA - CHINTAMANI 220	SIDLAGHATTA	12:03	12:13	0:10	LINE FAULT
72	24-Sep-19	BENGALURU	66	SIDLAGHATTA - MELUR	MELUR	12:03	12:17	0:14	LINE CLEAR AVAILED
73	24-Sep-19	BENGALURU	66	HV1	SULIBELE	8:55	9:15	0:20	TRANSFORMER FAULT
74	24-Sep-19	BENGALURU	400	HV1	SULIBELE	12:10	12:17	0:07	LINE CLEAR AVAILED
75	24-Sep-19	BENGALURU	66	HV2	SULIBELE	15:03	15:29	0:25	LINE CLEAR AVAILED
76	24-Sep-19	GULBARGA	220	SHAHAPUR-SHAHBAD	SHAHABAD_220	0:00	10:34	10:34	LINE CLEAR AVAILED
77	24-Sep-19	GULBARGA	220	SEDAM-HUMNABAD2	SEDAM_220	13:56	14:11	0:15	LINE FAULT
78	24-Sep-19	GULBARGA	220	HV1	KUSTAGI_220	6:24	6:37	0:13	TRANSFORMER FAULT
79	24-Sep-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	16:56	17:42	0:46	NFBC ISSUED
80	24-Sep-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	18:00	23:59	5:59	LINE FAULT
81	24-Sep-19	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHAD_220	17:13	17:36	0:23	LINE FAULT
82	24-Sep-19	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	1:35	1:40	0:05	LINE FAULT
83	24-Sep-19	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	4:15	4:20	0:05	LINE FAULT
84	24-Sep-19	GULBARGA	110	HALBURGA-KOLHAR1,2	KOLHAR_110,JANAWADA_110,NSS K_SUGARFACTORY	6:04	6:12	0:08	LINE FAULT
85	24-Sep-19	GULBARGA	110	HALBURGA-CHIDRI1	KAMTHANA_110, HABSIKOTE_110	4:44	4:54	0:10	LINE FAULT
86	24-Sep-19	GULBARGA	110	HV1	HANUMANAL_110	12:37	13:00	0:23	LINE CLEAR AVAILED
87	24-Sep-19	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110, HIREGONNAGAR_110, HANUMANAL_110	6:44	6:45	0:01	LINE FAULT
88	24-Sep-19	GULBARGA	110	KUSTAGI-INRSOLAR_IPP	KUSTAGI_220	10:11	10:27	0:16	LINE FAULT
89	24-Sep-19	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	5:19	5:25	0:06	LINE FAULT
90	24-Sep-19	GULBARGA	110	KUSTAGI-KUSTAGI SLR_IPP	KUSTAGI_220	19:30	21:00	1:30	LINE FAULT
91	24-Sep-19	GULBARGA	110	RAICHUR-SAHHPUR2	GOOGLE_110	5:13	5:32	0:19	LINE FAULT
92	24-Sep-19	GULBARGA	110	HV2	RAICHUR_220	9:18	9:28	0:10	TRANSFORMER FAULT
93	24-Sep-19	GULBARGA	110	HV2	RAICHUR_220	16:45	17:06	0:21	TRANSFORMER FAULT
94	24-Sep-19	GULBARGA	110	HV1	RAICHUR_220	8:40	17:27	8:47	LINE CLEAR AVAILED
95	24-Sep-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	21:42	21:50	0:08	LINE FAULT
96	24-Sep-19	GULBARGA	110	SRERAMNAGAR-MUNIRABAD	SRERAMNAGAR_110	20:00	20:10	0:10	LINE FAULT
97	24-Sep-19	GULBARGA	110	HV1	SRERAMNAGAR_110	11:05	11:40	0:35	LINE CLEAR AVAILED
98	24-Sep-19	GULBARGA	110	HV2	SRERAMNAGAR_110	20:00	20:10	0:10	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
99	24-Sep-19	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	19:00	19:12	0:12	LINE FAULT
100	24-Sep-19	GULBARGA	110	HV1	SHAHPUR_220	17:45	18:15	0:30	TRANSFORMER FAULT
101	24-Sep-19	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	19:05	19:10	0:05	LINE FAULT
102	24-Sep-19	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	5:10	5:15	0:05	LINE FAULT
103	24-Sep-19	GULBARGA	110	MALLAT-MANVI	MANVI_110	21:40	21:58	0:18	LINE FAULT
104	24-Sep-19	GULBARGA	66	BANAVEKAL-SLRYS_IPP	BANAVEKAL_66	14:40	14:51	0:11	LINE CLEAR AVAILED
105	24-Sep-19	GULBARGA	66	KOGALI-ATRIASOLAR_IPP	KOGALI_66	14:29	14:37	0:08	LINE FAULT
106	24-Sep-19	GULBARGA	66	KOGALI-KUDLIGI	KUDLIGI_66	14:10	14:35	0:25	LINE FAULT
107	24-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	12:31	12:31	LINE FAULT
108	24-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:05	23:59	1:54	LINE CLEAR AVAILED
109	24-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	8:03	8:03	LINE CLEAR AVAILED
110	24-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:10	23:59	0:49	HAND TRIPPED
111	24-Sep-19	HASSAN	220	GER SOPA-STRP1	gerusoppa_gen	12:17	23:59	11:42	LINE FAULT
112	24-Sep-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	12:17	17:58	5:41	LINE FAULT
113	24-Sep-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	17:58	23:59	6:01	LINE FAULT
114	24-Sep-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	14:27	14:32	0:05	HAND TRIPPED
115	24-Sep-19	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	12:06	15:44	3:38	LINE FAULT
116	24-Sep-19	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	16:00	18:44	2:44	LINE FAULT
117	24-Sep-19	HASSAN	220	HV2	PUTTUR_220	10:17	13:04	2:47	LINE CLEAR AVAILED
118	24-Sep-19	HASSAN	110	LV2	PUTTUR_220	10:16	13:28	3:12	LINE CLEAR AVAILED
119	24-Sep-19	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	14:27	14:32	0:05	HAND TRIPPED
120	24-Sep-19	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	0:00	12:10	12:10	LINE CLEAR AVAILED
121	24-Sep-19	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	12:18	15:59	3:41	LINE FAULT
122	24-Sep-19	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	15:59	18:44	2:45	LINE FAULT
123	24-Sep-19	HASSAN	110	ANANDA-LPH(LST-4)	ANANDAPURA_110	9:59	17:57	7:58	LINE CLEAR AVAILED
124	24-Sep-19	HASSAN	110	HV1	BHADRAVATHI_110	18:00	23:59	5:59	TRANSFORMER FAULT
125	24-Sep-19	HASSAN	110	HULICA-KVR	HULICAL_110	11:01	14:56	3:55	LINE CLEAR AVAILED
126	24-Sep-19	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	10:19	13:23	3:04	LINE CLEAR AVAILED
127	24-Sep-19	HASSAN	110	HV1	KUNDAPURA_110	10:40	19:05	8:25	LINE CLEAR AVAILED
128	24-Sep-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	12:17	12:34	0:17	LINE FAULT
129	24-Sep-19	HASSAN	66	HV1	BELUR_66	13:55	16:35	2:40	LINE CLEAR AVAILED
130	24-Sep-19	HASSAN	66	HV2	BELUR_66	10:40	18:45	8:05	LINE CLEAR AVAILED
131	24-Sep-19	HASSAN	66	HV1	HARIHARAPURA_66	22:45	22:58	0:13	TRANSFORMER FAULT
132	24-Sep-19	HASSAN	66	HV2	SALAGAME_66	10:26	13:28	3:02	LINE CLEAR AVAILED
133	24-Sep-19	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	9:35	14:33	4:58	LINE CLEAR AVAILED
134	24-Sep-19	HASSAN	66	HV1	SINGAPURA_66	9:35	14:33	4:58	LINE CLEAR AVAILED
135	24-Sep-19	HASSAN	66	HV2	SINGAPURA_66	9:35	14:33	4:58	LINE CLEAR AVAILED
136	24-Sep-19	HASSAN	66	SOMNHL-HARADANAHALLI	SOMANAHALLI_66	10:43	14:38	3:55	LINE CLEAR AVAILED
137	24-Sep-19	MYSORE	66	BANNUR-MALIYURU	MALIYURU_66	10:45	17:22	6:37	NFBC ISSUED
138	24-Sep-19	MYSORE	66	HV1	BOOKANAKERE_66	9:36	15:45	6:08	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
139	24-Sep-19	MYSORE	66	HV2	BOOKANAKERE_66	9:36	15:46	6:10	LINE CLEAR AVAILED
140	24-Sep-19	MYSORE	66	HV1	DODDARAYAPET_66	6:05	6:15	0:10	TRANSFORMER FAULT
141	24-Sep-19	MYSORE	66	HV1	DODDARAYAPET_66	6:38	20:09	13:31	TRANSFORMER FAULT
142	24-Sep-19	MYSORE	66	HUNSUR-HANGODU	HANAGODU_66	10:07	23:59	13:52	NFBC ISSUED
143	24-Sep-19	MYSORE	66	JAKKANAHALLY-NAGAMANGLA	BOGADHI MANDYA_66, G MALLIGERE_66 ,GUDDENAHALLI_66 ,NAGAMANGALA_66	9:06	9:13	0:07	LINE FAULT
144	24-Sep-19	MYSORE	66	HV1	KADAKOLA_220	10:31	13:36	3:05	LINE CLEAR AVAILED
145	24-Sep-19	MYSORE	66	KIRUGAVALU-MALIYURU	MALIYURU_66	11:09	17:05	5:56	NFBC ISSUED
146	24-Sep-19	MYSORE	66	HV4	SFCSHIVA_66	11:13	11:56	0:42	HAND TRIPPED
147	24-Sep-19	TUMKUR	220	TR-3(HV SIDE)	CHITRADURGA_220	5:02	7:05	2:03	TRANSFORMER FAULT
148	24-Sep-19	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR_IPP_66	AZURE POWER SOLAR_IPP_66	13:58	14:01	0:03	HAND TRIPPED
149	24-Sep-19	TUMKUR	220	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	13:58	14:08	0:10	HAND TRIPPED
150	24-Sep-19	TUMKUR	220	TR-3	HIRIYUR_220	11:01	13:58	2:57	LINE CLEAR AVAILED
151	24-Sep-19	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110	10:18	10:24	0:06	HAND TRIPPED
152	24-Sep-19	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	13:45	14:00	0:14	HAND TRIPPED
153	24-Sep-19	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	5:02	7:18	2:16	TRANSFORMER FAULT
154	24-Sep-19	TUMKUR	66	TR-2	DAVANAGERE_66	6:26	8:02	1:36	TRANSFORMER FAULT
155	24-Sep-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	12:57	13:10	0:13	LINE FAULT
156	24-Sep-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:08	10:17	0:08	HAND TRIPPED
157	24-Sep-19	TUMKUR	66	HARAPPANAHALLI-SUZLON 1	SUZLON_IPP_66	0:01	1:06	1:05	LINE FAULT
158	24-Sep-19	TUMKUR	66	HARAPPANAHALLI-SUZLON 2	SUZLON_IPP_66	0:01	1:06	1:05	LINE FAULT
159	24-Sep-19	TUMKUR	66	KORA- BRAHMASANDRA	BRAHMASANDRA_66	2:36	6:30	3:53	LINE FAULT
160	24-Sep-19	TUMKUR	66	KUNDUR- HONNALI	HONNALI_66	3:53	5:23	1:29	LINE FAULT
161	24-Sep-19	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	0:01	2:11	2:09	LINE FAULT
162	24-Sep-19	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	3:41	4:26	0:45	LINE FAULT
163	24-Sep-19	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	5:10	10:14	5:04	LINE FAULT
164	24-Sep-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	4:22	6:05	1:43	LINE FAULT
165	24-Sep-19	TUMKUR	66	TR-2	NAGALMADIKE_66	10:56	11:16	0:20	LINE CLEAR AVAILED
166	24-Sep-19	TUMKUR	66	TR-1	PAVAGADA_66	11:34	12:02	0:27	LINE CLEAR AVAILED
167	24-Sep-19	TUMKUR	66	TR-1	SAVALANGA_66	10:06	11:47	1:40	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
168	24-Sep-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	2:10	4:13	2:02	LINE CLEAR AVAILED
169	24-Sep-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:43	11:03	0:20	HAND TRIPPED
170	24-Sep-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	12:30	14:00	1:30	LINE CLEAR AVAILED
171	24-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	4:01	4:13	0:11	HAND TRIPPED
172	24-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	10:42	11:02	0:20	HAND TRIPPED
173	24-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	12:52	12:56	0:03	HAND TRIPPED
174	24-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	13:58	14:04	0:06	HAND TRIPPED
175	24-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	4:01	4:13	0:11	HAND TRIPPED
176	24-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	10:42	11:02	0:19	HAND TRIPPED
177	24-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	12:30	13:58	1:27	LINE CLEAR AVAILED
178	24-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	4:01	4:13	0:11	HAND TRIPPED
179	24-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	10:42	11:02	0:19	HAND TRIPPED
180	24-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	12:30	13:57	1:27	LINE CLEAR AVAILED
181	24-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	2:10	4:13	2:03	LINE CLEAR AVAILED
182	24-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	10:41	11:01	0:19	HAND TRIPPED
183	25-Sep-19	BAGALKOT	220	AMBEWADI-PONDA1	AMBEWADI_220	0:00	13:33	13:33	LINE CLEAR AVAILED
184	25-Sep-19	BAGALKOT	220	AMBEWADI-PONDA1	AMBEWADI_220	17:18	23:59	6:41	LINE FAULT
185	25-Sep-19	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,ANKOLA_33	11:40	13:32	1:52	LINE CLEAR AVAILED
186	25-Sep-19	BAGALKOT	110	ANNIGERI-GADAG	GADAG_110	10:28	19:35	9:07	NFBC ISSUED
187	25-Sep-19	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	15:28	16:58	1:30	LINE CLEAR AVAILED
188	25-Sep-19	BAGALKOT	110	GADAG-BETAGERI	BETAGERI_110	10:42	18:03	7:21	NFBC ISSUED
189	25-Sep-19	BAGALKOT	110	110/33KV,HV3	BELUR_110	11:30	18:40	7:10	LINE CLEAR AVAILED
190	25-Sep-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR1	MAMADAPUR_110	7:50	8:05	0:15	LINE FAULT
191	25-Sep-19	BAGALKOT	110	110/11KV,HV1	BIDNAL_220	10:50	15:06	4:16	LINE CLEAR AVAILED
192	25-Sep-19	BAGALKOT	110	110/11KV,HV2	BIDNAL_220	15:10	17:30	2:20	LINE CLEAR AVAILED
193	25-Sep-19	BAGALKOT	110	110/11KV,HV1	BIJAPUR CITY_110	11:01	11:19	0:18	LINE CLEAR AVAILED
194	25-Sep-19	BAGALKOT	110	GADAG220-GADAG	GADAG_110	10:31	18:08	7:37	NFBC ISSUED
195	25-Sep-19	BAGALKOT	110	GADAG 220-GADAG 1	GADAG_110	10:31	18:08	7:37	LINE CLEAR AVAILED
196	25-Sep-19	BAGALKOT	110	110/11KV,HV1	HATTRAGI_110	11:06	15:20	4:14	LINE CLEAR AVAILED
197	25-Sep-19	BAGALKOT	110	110/11KV.HV2	HATTRAGI_110	10:10	15:20	5:10	LINE CLEAR AVAILED
198	25-Sep-19	BAGALKOT	110	JAMKHANDI SUGARS-TODALBAGI	TODALBAGI_110	0:42	0:46	0:04	LINE FAULT
199	25-Sep-19	BAGALKOT	110	110/33KV,HV3	TODALBAGI_110,BIDARI_33KV,HIR EPADASALAGI_33KV	8:27	9:25	0:58	LINE CLEAR AVAILED
200	25-Sep-19	BAGALKOT	110	110/33KV,HV3	TODALBAGI_110,BIDARI_33KV,HIR EPADASALAGI_33KV	10:07	10:09	0:02	HAND TRIPPED
201	25-Sep-19	BAGALKOT	110	UGAR SUGARS-UGAR KHUD	UGAR KHUD_110	10:04	19:59	9:55	LINE CLEAR AVAILED
202	25-Sep-19	BAGALKOT	110	110/11KV,HV2,HV1	UGAR KHUD_110	10:43	19:52	9:09	LINE CLEAR AVAILED
203	25-Sep-19	BAGALKOT	110	110/33KV,HV4	UGAR KHUD_110, MANGSULI,SHEDBAL_33KV	10:00	19:45	9:45	LINE CLEAR AVAILED
204	25-Sep-19	BAGALKOT	220	220/110KV.HV3,LV3,	HUBLI_220	10:49	17:13	6:24	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
205	25-Sep-19	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	12:56	16:07	3:11	LINE FAULT
206	25-Sep-19	BAGALKOT	220	220/110KV,HV2,LV2,	SOUDATTI_220	15:49	16:24	0:35	LINE CLEAR AVAILED
207	25-Sep-19	BAGALKOT	220	220/110KV,HV1	SIRSI_220	10:40	12:11	1:31	LINE CLEAR AVAILED
208	25-Sep-19	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	0:00	16:16	16:16	LINE CLEAR AVAILED
209	25-Sep-19	BAGALKOT	110	SIRSI-KUMTA2	KUMTA_110	9:05	15:50	6:45	NFBC ISSUED
210	25-Sep-19	BAGALKOT	110	SADALAGA-BORGAON	BORGAON_110	21:08	22:00	0:52	LINE FAULT
211	25-Sep-19	BAGALKOT	110	110/11KV,HV1	RATTIHAL_110	14:47	18:08	3:21	LINE CLEAR AVAILED
212	25-Sep-19	BAGALKOT	110	110/11KV,HV1	RATTIHAL_110	8:50	9:15	0:25	TRANSFORMER FAULT
213	25-Sep-19	BAGALKOT	110	110/11KV,HV1	PH COMPOUND_110	10:08	16:14	6:06	LINE CLEAR AVAILED
214	25-Sep-19	BAGALKOT	110	110/11KV,HV2	PH COMPOUND_110	10:54	16:14	5:20	LINE CLEAR AVAILED
215	25-Sep-19	BAGALKOT	110	HUBI-PH COMPOUND	PH COMPOUND_110	16:29	23:59	7:30	LINE CLEAR AVAILED
216	25-Sep-19	BAGALKOT	110	110/11KV,HV1	PG HUNSHYAL_110	10:08	19:29	9:21	LINE CLEAR AVAILED
217	25-Sep-19	BAGALKOT	110	110/11KV,HV1,HV2	NAVANAGAR(H)_110	10:02	16:13	6:11	LINE CLEAR AVAILED
218	25-Sep-19	BAGALKOT	110	110/33KV,HV2,HV3	MURDESHWAR_110,BATKAL_33KV ,KASARKOD_33KV	10:17	14:03	3:46	LINE CLEAR AVAILED
219	25-Sep-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	0:32	6:46	6:14	LINE CLEAR AVAILED
220	25-Sep-19	BAGALKOT	110	110/11KV,HV1	LAXMESHVAR_110	15:40	16:28	0:48	LINE CLEAR AVAILED
221	25-Sep-19	BAGALKOT	220	220/110KV,HV1,LV1,HV2&LV2	KUDACHI_220	11:57	19:38	7:41	LINE CLEAR AVAILED
222	25-Sep-19	BAGALKOT	110	KUDACHI220-MORAB	MORAB_110	10:20	19:43	9:23	LINE CLEAR AVAILED
223	25-Sep-19	BAGALKOT	110	KUDACHI220-UGARKHUD	UGARKHUD_110	11:55	19:41	7:46	LINE CLEAR AVAILED
224	25-Sep-19	BAGALKOT	110	KUDACHI220-AINAPUR	AINAPUR_110	11:55	19:41	7:46	LINE CLEAR AVAILED
225	25-Sep-19	BAGALKOT	110	110/11KV,HV4	KERUR_110	11:49	12:49	1:00	LINE CLEAR AVAILED
226	25-Sep-19	BAGALKOT	110	KUDACHI220-KAGAWAD	KAGAWAD_110	11:55	20:00	8:05	LINE CLEAR AVAILED
227	25-Sep-19	BAGALKOT	110	SHIRGUPPI SUGARS-KAGAWAD	KAGAWAD_110	20:07	20:14	0:07	LINE CLEAR AVAILED
228	25-Sep-19	BAGALKOT	110	110/11KV,HV2	HIDIKAL DAM_110	12:03	13:44	1:41	LINE CLEAR AVAILED
229	25-Sep-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	11:19	14:21	3:02	LINE CLEAR AVAILED
230	25-Sep-19	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	18:36	19:58	1:22	LINE FAULT
231	25-Sep-19	BENGALURU	66	HENNUR CROSS - MANYATA TECH PARK 220	HENNUR CROSS	2:30	2:35	0:05	LOAD CHANGEOVER
232	25-Sep-19	BENGALURU	66	HV2	MALLASANDRA	11:55	13:02	1:07	LINE CLEAR AVAILED
233	25-Sep-19	BENGALURU	66	HV2	KYALANUR	15:24	15:30	0:05	TRANSFORMER FAULT
234	25-Sep-19	BENGALURU	66	HV2	KYALANUR	18:00	18:12	0:12	LOAD CHANGEOVER
235	25-Sep-19	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	17:44	17:57	0:12	LINE FAULT
236	25-Sep-19	BENGALURU	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	21:56	22:11	0:14	LINE FAULT
237	25-Sep-19	BENGALURU	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	22:11	22:37	0:26	LINE FAULT
238	25-Sep-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	19:02	20:10	1:07	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
239	25-Sep-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/ A	19:02	20:19	1:16	LINE FAULT
240	25-Sep-19	BENGALURU	220	HV2	YERANDANAHALLI 2200	19:02	20:04	1:01	TRANSFORMER FAULT
241	25-Sep-19	BENGALURU	66	HV1	AMARJYOTHI	18:30	18:36	0:05	LOAD CHANGEOVER
242	25-Sep-19	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT), AMARJYOTHI	11:36	11:41	0:05	LOAD CHANGEOVER
243	25-Sep-19	BENGALURU	66	KORMANGALA 220 - HAL 1	AMARJYOTHI	17:15	17:50	0:34	LINE FAULT
244	25-Sep-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	19:02	20:57	1:54	LINE FAULT
245	25-Sep-19	GULBARGA	400	JSWVL400-GUTTUR	GUTTUR_400	9:33	14:53	5:20	LINE CLEAR AVAILED
246	25-Sep-19	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	1:30	9:33	8:03	LINE CLEAR AVAILED
247	25-Sep-19	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	11:48	12:28	0:40	LINE CLEAR AVAILED
248	25-Sep-19	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	12:54	13:55	1:01	LINE CLEAR AVAILED
249	25-Sep-19	GULBARGA	220	LINGASUGUR-SINDHANOOR	SIDHANOOR_220	15:17	15:45	0:28	LINE CLEAR AVAILED
250	25-Sep-19	GULBARGA	220	LINGASUGUR-MALLAT	MALLAT_220	15:17	16:14	0:57	LINE CLEAR AVAILED
251	25-Sep-19	GULBARGA	220	HV1,HV2	SIDHANOOR_220	1:41	4:52	3:11	TRANSFORMER FAULT
252	25-Sep-19	GULBARGA	220	HV1,HV2	SIDHANOOR_220	4:14	4:27	0:13	TRANSFORMER FAULT
253	25-Sep-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	0:00	12:29	12:29	LINE FAULT
254	25-Sep-19	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	15:45	16:15	0:30	LINE CLEAR AVAILED
255	25-Sep-19	GULBARGA	220	HV1,LV1	SIDHANOOR_220	23:45	23:55	0:10	TRANSFORMER FAULT
256	25-Sep-19	GULBARGA	110	BHALKI-BHALKISUGAR_IPP	BHALKI_110	6:18	6:28	0:10	LINE FAULT
257	25-Sep-19	GULBARGA	110	GURUMITAKAL-KONKAL	KONKAL_110	7:36	9:27	1:51	MAIN SUPPLY FAILURE
258	25-Sep-19	GULBARGA	110	HUMNABAD220-BHALKI1	BHALKI_110, LADHA_110, MGSSK_SUGAR	5:50	11:31	5:41	LINE FAULT
259	25-Sep-19	GULBARGA	110	HUMNABAD220-MANEKHALLI	MANEKHALLI_110	6:55	7:05	0:10	LINE FAULT
260	25-Sep-19	GULBARGA	110	HUMNABAD220-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	12:30	12:36	0:06	LINE FAULT
261	25-Sep-19	GULBARGA	110	HUMNABAD220-HUMNABAD	HUMNABAD_110	12:36	12:41	0:05	LINE CLEAR AVAILED
262	25-Sep-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	1:53	3:55	2:02	LINE FAULT
263	25-Sep-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	4:12	4:19	0:07	LINE FAULT
264	25-Sep-19	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	8:50	9:10	0:20	LINE FAULT
265	25-Sep-19	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110	9:38	9:53	0:15	LINE CLEAR AVAILED
266	25-Sep-19	GULBARGA	110	SHAHPUR220-YADGIR	YADGIR_110	1:11	1:23	0:12	LINE FAULT
267	25-Sep-19	GULBARGA	110	SHAHPUR220-YADGIR	YADGIR_110	2:50	2:56	0:06	LINE FAULT
268	25-Sep-19	GULBARGA	110	SHAHPUR220-YADGIR	YADGIR_110	3:04	7:17	4:13	LINE FAULT
269	25-Sep-19	GULBARGA	110	SHAHPUR220-KEMBHAVI1	KEMBHAVI_110,UGAR SUGAR_IPP	3:20	3:26	0:06	LINE FAULT
270	25-Sep-19	GULBARGA	110	SHAHPUR220-KEMBHAVI1	KEMBHAVI_110,UGAR SUGAR_IPP	5:32	5:38	0:06	LINE FAULT
271	25-Sep-19	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITKAL_110	0:09	0:34	0:25	LINE FAULT
272	25-Sep-19	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITKAL_110	6:25	6:40	0:15	LINE FAULT
273	25-Sep-19	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITKAL_110	6:43	7:12	0:29	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
274	25-Sep-19	GULBARGA	110	SEDAM-VICATSAGAR	VICATSAGAR_CEMENTS_IPP	2:01	2:13	0:12	LINE FAULT
275	25-Sep-19	GULBARGA	110	SEDAM-ULTRATECH_CEMENTS	ULTRATECH_CEMENTS_IPP	7:15	8:40	1:25	LINE FAULT
276	25-Sep-19	GULBARGA	110	SINDHANOOR-PGLR_WIND_IPP	SIDHANOOR_220	1:41	1:50	0:09	LINE FAULT
277	25-Sep-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_GLB_110, BTPS WATERWORKS	1:41	1:50	0:09	LINE FAULT
278	25-Sep-19	GULBARGA	110	SINDHANOOR-SINDHANOOR1	MASKI_110,MUDDAPUR_110	1:41	1:50	0:09	LINE FAULT
279	25-Sep-19	GULBARGA	110	SINDHANOOR-RAICHUR1	SINDHANOOR_110	1:41	1:55	0:14	LINE FAULT
280	25-Sep-19	GULBARGA	110	SINDHANOOR-SIRUGUPPA	DHADESUGUR_110, SIRIGUPPA_110, TEKKALAKOTE_110,NSLSUGARS_IP P	1:41	2:53	1:12	LINE FAULT
281	25-Sep-19	GULBARGA	110	SINDHANOOR-TURUVIHAL	TURVIHAL_110	3:04	3:22	0:18	LINE FAULT
282	25-Sep-19	GULBARGA	110	SINDHANOOR-TURUVIHAL	TURVIHAL_110	4:14	5:40	1:26	LINE FAULT
283	25-Sep-19	GULBARGA	110	LV1	SIDHANOOR_220	3:50	3:59	0:09	TRANSFORMER FAULT
284	25-Sep-19	GULBARGA	110	RAICHUR-SINDHANOOR2	MANVI_110,MADALPUR_110	20:16	20:21	0:05	LINE FAULT
285	25-Sep-19	GULBARGA	110	RAICHUR-SINDHANOOR2	MANVI_110,MADALPUR_110	23:25	23:31	0:06	LINE FAULT
286	25-Sep-19	GULBARGA	110	HV2	BEVOOR_110	8:15	8:40	0:25	LINE CLEAR AVAILED
287	25-Sep-19	GULBARGA	110	HV3	BEVOOR_110	22:46	23:09	0:23	TRANSFORMER FAULT
288	25-Sep-19	GULBARGA	110	HATTI-GMSH_IPP	HATTI_110	22:04	22:16	0:12	LINE CLEAR AVAILED
289	25-Sep-19	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	20:50	21:10	0:20	LINE FAULT
290	25-Sep-19	GULBARGA	110	KUSTAGI-ILKAL1	ILKAL_110	11:33	11:41	0:08	LINE FAULT
291	25-Sep-19	GULBARGA	110	KUSTAGI-ILKAL2	ILKAL_110	0:00	11:42	11:42	LINE CLEAR AVAILED
292	25-Sep-19	GULBARGA	110	KUSTAGI-ILKAL1,2	ILKAL_110	14:30	15:30	1:00	LINE CLEAR AVAILED
293	25-Sep-19	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONNA GAR_110,HANUMANAL_110	22:22	23:59	1:37	LINE FAULT
294	25-Sep-19	GULBARGA	110	SINDHNOOR-LINGASUGUR	SIDHANOOR_220	15:15	15:45	0:30	LINE CLEAR AVAILED
295	25-Sep-19	GULBARGA	110	SINDHNOOR-SINDHANOOR1	MASKI_110,MUDDAPUR_110	20:50	22:05	1:15	LINE FAULT
296	25-Sep-19	GULBARGA	110	SINDHNOOR-RAICHUR1	VALKAMDINNI_110,ALKOD_110,SI RWAR_110	21:01	22:00	0:59	LINE FAULT
297	25-Sep-19	GULBARGA	110	SINDHNOOR-TURVIHAL	TURVIHAL_110	23:45	23:59	0:14	LINE FAULT
298	25-Sep-19	GULBARGA	66	HV2	KOTTUR_66	12:17	13:13	0:56	LINE CLEAR AVAILED
299	25-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	6:40	6:40	LINE CLEAR AVAILED
300	25-Sep-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	15:12	16:32	1:20	LINE CLEAR AVAILED
301	25-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	7:17	7:17	LINE CLEAR AVAILED
302	25-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:37	23:59	2:22	LINE CLEAR AVAILED
303	25-Sep-19	HASSAN	220	GERSOPA-STRP1	gerusoppa_gen	0:00	17:23	17:23	LINE FAULT
304	25-Sep-19	HASSAN	220	GERSOPA-STRP2	gerusoppa_gen	15:12	16:32	1:20	LINE CLEAR AVAILED
305	25-Sep-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	0:00	17:23	17:23	LINE FAULT
306	25-Sep-19	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	9:26	16:33	7:07	LINE CLEAR AVAILED
307	25-Sep-19	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	9:27	16:33	7:06	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
308	25-Sep-19	HASSAN	110	HV1	BHADRAVATHI_110	0:00	17:24	17:24	TRANSFORMER FAULT
309	25-Sep-19	HASSAN	110	HV1	BIRUR_110	16:50	17:00	0:10	HAND TRIPPED
310	25-Sep-19	HASSAN	110	HV2	BIRUR_110	16:50	17:15	0:25	HAND TRIPPED
311	25-Sep-19	HASSAN	110	HV2	HOSANGADI_110	11:00	13:39	2:39	LINE CLEAR AVAILED
312	25-Sep-19	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	10:27	12:52	2:25	LINE CLEAR AVAILED
313	25-Sep-19	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	10:12	12:55	2:43	LINE CLEAR AVAILED
314	25-Sep-19	HASSAN	110	KAVOOR-Kulashkhara1	KAVOOR_220	10:25	12:54	2:29	LINE CLEAR AVAILED
315	25-Sep-19	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	10:08	13:04	2:56	LINE CLEAR AVAILED
316	25-Sep-19	HASSAN	110	KULASH-KERKNJ	KULASHEKARA_110	10:06	13:07	3:01	LINE CLEAR AVAILED
317	25-Sep-19	HASSAN	110	MRSSHM-MPM	MRSMSG_220	10:28	11:10	0:42	LINE FAULT
318	25-Sep-19	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	12:23	15:15	2:52	LINE CLEAR AVAILED
319	25-Sep-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	23:02	23:07	0:05	LINE FAULT
320	25-Sep-19	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	6:37	6:46	0:09	LINE FAULT
321	25-Sep-19	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	15:50	16:09	0:19	LINE FAULT
322	25-Sep-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	11:23	15:14	3:51	LINE CLEAR AVAILED
323	25-Sep-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	20:51	20:54	0:03	HAND TRIPPED
324	25-Sep-19	MYSORE	66	HV1	ADICHUNCHANAGIRI_66	9:45	9:58	0:12	HAND TRIPPED
325	25-Sep-19	MYSORE	66	HV1	ADICHUNCHANAGIRI_66	17:56	18:00	0:03	HAND TRIPPED
326	25-Sep-19	MYSORE	66	HV1	BASARALU_66	10:00	18:15	8:15	LINE CLEAR AVAILED
327	25-Sep-19	MYSORE	66	HV2	BASARALU_66	10:24	18:15	7:51	LINE CLEAR AVAILED
328	25-Sep-19	MYSORE	66	HV2	DEVANOORNGUDU_66	10:02	16:54	6:51	LINE CLEAR AVAILED
329	25-Sep-19	MYSORE	66	HV2	FTS_66	13:44	15:34	1:50	LINE CLEAR AVAILED
330	25-Sep-19	MYSORE	66	HAMPAPURA-HV1	HAMPAPURA_66	9:43	9:52	0:09	HAND TRIPPED
331	25-Sep-19	MYSORE	66	HV2	HAMPAPURA_66	9:43	9:52	0:09	HAND TRIPPED
332	25-Sep-19	MYSORE	66	HANNUR-MADHUVANAHALLI 2	BANDALLI_66, COWDALLI_66, DODDINADUVADI_66, HANNUR_66, KOTTANUR_66, BANDALLI, MARTAHALLI_66, RAMAPURA_MYS_66	10:35	10:40	0:05	LINE FAULT
333	25-Sep-19	MYSORE	66	HOOTAGALLI-BOGADHI	BOGADHI_66, KALAMANDIRA_66	12:12	14:55	2:43	LINE CLEAR AVAILED
334	25-Sep-19	MYSORE	66	HOOTAGALLI-DATAGALLI	DATTAGALLY_66, RKNAGARA_66	12:15	14:45	2:29	LINE CLEAR AVAILED
335	25-Sep-19	MYSORE	66	HOOTAGALLI-VIJAYANAGARA	VIJAYANAGRAMYS_66	12:10	14:40	2:30	LINE CLEAR AVAILED
336	25-Sep-19	MYSORE	66	HV1	HOOTAGALLY_220	12:21	12:24	0:02	HAND TRIPPED
337	25-Sep-19	MYSORE	66	HV2	HOOTAGALLY_220	12:20	13:14	0:53	HAND TRIPPED
338	25-Sep-19	MYSORE	220	HV1	HOOTAGALLY_220	12:10	12:25	0:15	TRANSFORMER FAULT
339	25-Sep-19	MYSORE	220	HV2	HOOTAGALLY_220	12:12	13:38	1:26	TRANSFORMER FAULT
340	25-Sep-19	MYSORE	220	HV3	HOOTAGALLY_220	10:32	17:03	6:31	LINE CLEAR AVAILED
341	25-Sep-19	MYSORE	66	HV1	HULLAHALLI_66	10:00	15:50	5:50	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
342	25-Sep-19	MYSORE	66	HV2	HULLAHALLI_66	10:00	15:50	5:50	LINE CLEAR AVAILED
343	25-Sep-19	MYSORE	66	HV1	JAKKANAHALLY_66	10:08	17:00	6:51	LINE CLEAR AVAILED
344	25-Sep-19	MYSORE	66	HV2	JAKKANAHALLY_66	10:08	17:00	6:51	LINE CLEAR AVAILED
345	25-Sep-19	MYSORE	66	HV1	K_HONNALGERE_66	9:57	15:14	5:16	LINE CLEAR AVAILED
346	25-Sep-19	MYSORE	66	HV2	K_HONNALGERE_66	9:57	15:13	5:16	LINE CLEAR AVAILED
347	25-Sep-19	MYSORE	66	KIADB MANDYA-MADDUR	KIADBMANDYA_66, MADDUR_66, TUMBEKERE_66	14:10	14:34	0:24	LINE FAULT
348	25-Sep-19	MYSORE	66	HV1	KOPPA_66	9:45	9:49	0:04	HAND TRIPPED
349	25-Sep-19	MYSORE	66	HV2	KOPPA_66	9:45	9:49	0:04	HAND TRIPPED
350	25-Sep-19	MYSORE	66	HV1	KOPPA_66	17:51	18:12	0:21	HAND TRIPPED
351	25-Sep-19	MYSORE	66	HV2	KOPPA_66	17:51	18:12	0:20	HAND TRIPPED
352	25-Sep-19	MYSORE	66	HV1	KMDODDI_66	8:25	14:15	5:50	LINE CLEAR AVAILED
353	25-Sep-19	MYSORE	66	HV2	KMDODDI_66	8:25	14:15	5:50	LINE CLEAR AVAILED
354	25-Sep-19	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	JAKKANAHALLY_66,MADESWARAPURA_66,BOGADHI MANDYA_66, G MALLIGERE_66 ,GUDDENAHALLI_66 ,NAGAMANGALA_66	15:10	15:22	0:12	LINE FAULT
355	25-Sep-19	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	JAKKANAHALLY_66,MADESWARAPURA_66,BOGADHI MANDYA_66, G MALLIGERE_66 ,GUDDENAHALLI_66 ,NAGAMANGALA_66	16:02	16:25	0:23	LINE FAULT
356	25-Sep-19	MYSORE	66	MADDUR-SOMANAHALLI	SOMANAHALLI_66	10:13	15:28	5:14	LINE CLEAR AVAILED
357	25-Sep-19	MYSORE	66	MADDUR-SOMANAHALLI	SOMANAHALLI_66	19:46	20:21	0:34	LINE CLEAR AVAILED
358	25-Sep-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	13:36	14:41	1:05	LINE CLEAR AVAILED
359	25-Sep-19	MYSORE	66	MANDYA-KK HALLI	KADKOTHANAHALLI_66,MALAVALLI_66, HADLI_66	10:20	10:24	0:04	HAND TRIPPED
360	25-Sep-19	MYSORE	66	RAMAPURA-COWDALLY	RAMAPURA_MYS_66	16:48	17:30	0:41	HAND TRIPPED
361	25-Sep-19	MYSORE	66	HV1	RAMAPURA_MYS_66	10:24	17:30	7:05	LINE CLEAR AVAILED
362	25-Sep-19	MYSORE	66	HV2	RAMAPURA_MYS_66	15:05	17:30	2:24	LINE CLEAR AVAILED
363	25-Sep-19	MYSORE	66	HV2	THALAKADU_66	17:57	18:03	0:05	TRANSFORMER FAULT
364	25-Sep-19	MYSORE	220	HV1	TUBINAKERE_220	10:17	17:56	7:39	LINE CLEAR AVAILED
365	25-Sep-19	MYSORE	220	HV2	TUBINAKERE_220	10:20	17:42	7:22	LINE CLEAR AVAILED
366	25-Sep-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 KESLAGERE_66	9:36	17:48	8:12	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
367	25-Sep-19	MYSORE	66	HV1	TUBINAKERE_220	17:51	17:59	0:08	HAND TRIPPED
368	25-Sep-19	MYSORE	66	HV2	TUBINAKERE_220	17:49	18:07	0:18	HAND TRIPPED
369	25-Sep-19	TUMKUR	220	TR-1(HV-1)	ANTHRASANAHALLI_220	10:06	18:02	7:56	LINE CLEAR AVAILED
370	25-Sep-19	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	12:54	17:04	4:10	LINE FAULT
371	25-Sep-19	TUMKUR	220	TR-1(HV-1)	DAVANGERE_SRS_220	13:36	13:40	0:04	LINE CLEAR AVAILED
372	25-Sep-19	TUMKUR	220	TR-2(HV-2)	DAVANGERE_SRS_220	13:42	19:03	5:20	LINE CLEAR AVAILED
373	25-Sep-19	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	15:18	15:45	0:27	LINE FAULT
374	25-Sep-19	TUMKUR	220	PAVAGADA 220kV- MADHUGIRI 1	MADHUGIRI_220	0:13	7:26	7:13	LINE CLEAR AVAILED
375	25-Sep-19	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	1:29	8:27	6:58	LINE CLEAR AVAILED
376	25-Sep-19	TUMKUR	66	TR-1	AMRUTHUR_66	14:37	15:00	0:22	HAND TRIPPED
377	25-Sep-19	TUMKUR	66	BELLAVI-ANTHRASANAHALLI	BELLAVI_66	16:08	17:47	1:39	LINE CLEAR AVAILED
378	25-Sep-19	TUMKUR	66	TR-2	BELLAVI_66	14:24	18:05	3:41	LINE CLEAR AVAILED
379	25-Sep-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:33	6:39	0:05	LINE FAULT
380	25-Sep-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	9:19	9:29	0:10	LINE FAULT
381	25-Sep-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	12:14	12:28	0:14	HAND TRIPPED
382	25-Sep-19	TUMKUR	66	KORA- BRAHMASANDRA	BRAHMASANDRA_66	14:46	15:09	0:22	LINE CLEAR AVAILED
383	25-Sep-19	TUMKUR	66	TR-1	KUNIGAL_66	17:55	18:07	0:11	TRANSFORMER FAULT
384	25-Sep-19	TUMKUR	66	TR-2	KUNIGAL_66	15:20	15:30	0:10	LINE CLEAR AVAILED
385	25-Sep-19	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	6:20	6:30	0:10	LINE FAULT
386	25-Sep-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:32	10:35	0:03	HAND TRIPPED
387	26-Sep-19	BAGALKOT	110	ARGA-ANKOLA	ANKOLA_110	9:27	14:38	5:11	LINE CLEAR AVAILED
388	26-Sep-19	BAGALKOT	220	AMBEWADI-PONDA1	AMBEWADI_220	0:00	16:20	16:20	LINE CLEAR AVAILED
389	26-Sep-19	BAGALKOT	110	MAMADAPUR-BABLESHWARA	BABLESHWARA_110	6:12	8:07	1:55	LINE CLEAR AVAILED
390	26-Sep-19	BAGALKOT	110	110/33KV,HV3	BELUR_110	12:45	17:46	5:01	LINE CLEAR AVAILED
391	26-Sep-19	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	7:21	7:41	0:20	LINE FAULT
392	26-Sep-19	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	2:17	7:43	5:26	LINE FAULT
393	26-Sep-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR2	MAMADAPUR_110	6:07	7:19	1:12	LINE CLEAR AVAILED
394	26-Sep-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR2	MAMADAPUR_110	17:59	19:55	1:56	LINE CLEAR AVAILED
395	26-Sep-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR1	MAMADAPUR_110	6:07	19:55	13:48	LINE CLEAR AVAILED
396	26-Sep-19	BAGALKOT	220	BAGALKOT-GADAG1	BAGALKOT_220	0:00	11:24	11:24	LINE CLEAR AVAILED
397	26-Sep-19	BAGALKOT	220	GADAG-BAGALKOT2	GADAG_220	11:22	23:59	12:37	LINE FAULT
398	26-Sep-19	BAGALKOT	110	GADAG220-SHIRAHATTI	SHIRAHATTI_110	10:19	17:51	7:32	LINE CLEAR AVAILED
399	26-Sep-19	BAGALKOT	220	220/110KV,HV1&LV1	BIDNAL_220	12:04	18:22	6:18	LINE CLEAR AVAILED
400	26-Sep-19	BAGALKOT	110	110/11KV,HV1	BILAGI_110	0:06	0:37	0:31	TRANSFORMER FAULT
401	26-Sep-19	BAGALKOT	110	110/11KV,HV1	BILAGI_110	17:00	17:27	0:27	LINE CLEAR AVAILED
402	26-Sep-19	BAGALKOT	110	110/11KV,HV2	BILAGI_110	11:20	11:35	0:15	LINE CLEAR AVAILED
403	26-Sep-19	BAGALKOT	110	110/11KV,HV2	BILAGI_110	16:45	17:30	0:45	LINE CLEAR AVAILED
404	26-Sep-19	BAGALKOT	110	110/11KV,HV1	BIJAPUR_220	12:07	12:16	0:09	TRANSFORMER FAULT
405	26-Sep-19	BAGALKOT	110	110/11KV,HV1	BIJAPUR_220	13:10	13:17	0:07	TRANSFORMER FAULT
406	26-Sep-19	BAGALKOT	110	BIDNAL220-GADAG ROAD	GADAG ROAD_110	9:40	18:45	9:05	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
407	26-Sep-19	BAGALKOT	220	CHIKKODI-GHATAPRABHA	CHIKKODI_220	16:37	23:59	7:22	LINE CLEAR AVAILED
408	26-Sep-19	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	10:00	18:15	8:15	LINE CLEAR AVAILED
409	26-Sep-19	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD_110	7:20	16:36	9:16	LINE FAULT
410	26-Sep-19	BAGALKOT	110	GAJENDRAGAD-RON1	RON_110	7:20	7:41	0:21	LINE CLEAR AVAILED
411	26-Sep-19	BAGALKOT	110	GAJENDRAGAD-RON2	RON_110	7:20	23:59	16:39	LINE CLEAR AVAILED
412	26-Sep-19	BAGALKOT	110	GAJENDRAGAD-RON1	RON_110	16:38	18:30	1:52	LINE CLEAR AVAILED
413	26-Sep-19	BAGALKOT	110	BAGEWADI-MATTIHAL	MATTIHAL_110	16:01	16:11	0:10	HAND TRIPPED
414	26-Sep-19	BAGALKOT	110	110/11KV,HV2	TARIHAL_110	12:16	12:17	0:01	HAND TRIPPED
415	26-Sep-19	BAGALKOT	110	110/11KV,HV1	TARIHAL_110	13:14	14:30	1:16	LINE CLEAR AVAILED
416	26-Sep-19	BAGALKOT	220	220/110KV,HV1,LV1	HUBLI_220	9:10	16:29	7:19	LINE CLEAR AVAILED
417	26-Sep-19	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	12:14	17:10	4:56	LINE FAULT
418	26-Sep-19	BAGALKOT	110	HUBLI-PH COMPOUND	HUBLI_220	9:45	9:50	0:05	HAND TRIPPED
419	26-Sep-19	BAGALKOT	110	HUBLI-BIDNAL2	HUBLI_220	11:54	12:02	0:08	HAND TRIPPED
420	26-Sep-19	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	0:15	13:51	13:36	LINE FAULT
421	26-Sep-19	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	11:23	13:12	1:49	LINE CLEAR AVAILED
422	26-Sep-19	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	0:00	11:29	11:29	LINE CLEAR AVAILED
423	26-Sep-19	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	12:14	23:59	11:45	LINE FAULT
424	26-Sep-19	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	12:14	13:06	0:52	LINE FAULT
425	26-Sep-19	BAGALKOT	110	BPCL 1&2-SHIRAHATTI	SHIRAHATTI_110	10:09	18:28	8:19	LINE CLEAR AVAILED
426	26-Sep-19	BAGALKOT	110	HUBLI-P H COMPOUND	P H COMPOUND_110	0:00	9:53	9:53	LINE CLEAR AVAILED
427	26-Sep-19	BAGALKOT	110	BIDNAL-PH COMPOUND	P H COMPOUND_110	9:53	23:59	14:06	LINE CLEAR AVAILED
428	26-Sep-19	BAGALKOT	110	110/11KV,HV3	RATTIHAL_110	14:28	17:16	2:48	LINE CLEAR AVAILED
429	26-Sep-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	10:07	18:49	8:42	LINE CLEAR AVAILED
430	26-Sep-19	BAGALKOT	110	NARAGAL-RON	RON_110	7:20	7:42	0:22	LINE FAULT
431	26-Sep-19	BAGALKOT	110	NARAGAL-RON	RON_110	12:41	20:23	7:42	LINE CLEAR AVAILED
432	26-Sep-19	BAGALKOT	110	SHIRAHATTI-LAXMESHWAR	LAXMESHWAR_110	10:34	17:50	7:16	LINE CLEAR AVAILED
433	26-Sep-19	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	9:16	14:21	5:05	LINE CLEAR AVAILED
434	26-Sep-19	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	19:50	23:59	4:09	LINE CLEAR AVAILED
435	26-Sep-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	14:23	23:59	9:36	LINE CLEAR AVAILED
436	26-Sep-19	BAGALKOT	110	110/11KV,HV5	INDI_110	13:19	14:28	1:09	LINE CLEAR AVAILED
437	26-Sep-19	BAGALKOT	110	110/33KV,HV 4	HIDIKAL_110	14:19	15:28	1:09	LINE CLEAR AVAILED
438	26-Sep-19	BENGALURU	66	VIDURASHWATHA - BAGEPALLI	BAGEPALLI, GUNDLU KOTTUR	16:45	16:55	0:10	LINE FAULT
439	26-Sep-19	BENGALURU	66	BAGMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	13:44	15:24	1:40	LINE CLEAR AVAILED
440	26-Sep-19	BENGALURU	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMAPALLI, M GOLLAHALLI	16:31	16:36	0:04	LOAD CHANGEOVER
441	26-Sep-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	1:21	1:30	0:09	LINE FAULT
442	26-Sep-19	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	7:33	7:46	0:13	LINE FAULT
443	26-Sep-19	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	16:54	17:12	0:18	LINE CLEAR AVAILED
444	26-Sep-19	BENGALURU	66	HV2	KODIHALLI	16:21	18:08	1:46	LINE CLEAR AVAILED
445	26-Sep-19	BENGALURU	66	HV1	KODIHALLI	6:50	7:25	0:35	LINE CLEAR AVAILED
446	26-Sep-19	BENGALURU	66	HV1	SULIBELE	13:51	13:53	0:01	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
447	26-Sep-19	BENGALURU	66	HV1	SULIBELE	14:50	15:01	0:11	LINE CLEAR AVAILED
448	26-Sep-19	BENGALURU	66	HV2	SULIBELE	17:20	17:22	0:01	LINE CLEAR AVAILED
449	26-Sep-19	BENGALURU	66	HV2	SULIBELE	17:40	17:44	0:04	LINE CLEAR AVAILED
450	26-Sep-19	BENGALURU	66	SURYANAGAR - ANEKAL	SURYANAGAR	11:27	11:42	0:15	LOAD CHANGEOVER
451	26-Sep-19	BENGALURU	66	YELAHANKA 220 - LINE 7	KANASWADI	8:59	9:19	0:20	LINE FAULT
452	26-Sep-19	BENGALURU	66	YELAHANKA 220 - LINE 4	RAILWAYS (EHT)	14:51	16:13	1:22	LINE FAULT
453	26-Sep-19	BENGALURU	66	SAHAKARINAGARA - DG 4	SAHAKARINAGARA	14:51	15:15	0:24	MAIN SUPPLY FAILURE
454	26-Sep-19	BENGALURU	66	SAHAKARINAGARA - MANYATA TECH PARK 220	SAHAKARINAGARA	17:40	17:50	0:10	LOAD CHANGEOVER
455	26-Sep-19	BENGALURU	66	HV2	SAHAKARINAGARA	15:18	15:50	0:32	TRANSFORMER FAULT
456	26-Sep-19	BENGALURU	66	ITI - HEBBAL	BANASWADI	13:56	15:31	1:35	LINE CLEAR AVAILED
457	26-Sep-19	BENGALURU	66	HV5	NRS 220	13:46	15:17	1:31	LINE CLEAR AVAILED
458	26-Sep-19	BENGALURU	66	HV2	AREHALLI	11:31	11:35	0:03	LOAD CHANGEOVER
459	26-Sep-19	BENGALURU	66	HV1	MATHIKERE	9:29	9:35	0:05	LOAD CHANGEOVER
460	26-Sep-19	BENGALURU	66	HV2	MATHIKERE	11:41	12:38	0:56	LOAD CHANGEOVER
461	26-Sep-19	BENGALURU	66	HV1	NANDINI LAYOUT	10:32	10:34	0:01	LOAD CHANGEOVER
462	26-Sep-19	BENGALURU	66	HV1	NANDINI LAYOUT	12:30	12:33	0:03	LOAD CHANGEOVER
463	26-Sep-19	GULBARGA	400	JSWVL400-GUTTUR	GUTTUR_400	16:08	22:34	6:26	LINE FAULT
464	26-Sep-19	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	1:23	2:07	0:44	LINE FAULT
465	26-Sep-19	GULBARGA	220	KUSTAGI-SUZLON1_IPP	KUSTAGI_220	1:53	2:42	0:49	LINE CLEAR AVAILED
466	26-Sep-19	GULBARGA	220	SHAHPUR-LINGASUGUR	SHAHPUR_220	1:24	8:57	7:33	LINE FAULT
467	26-Sep-19	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	0:00	5:40	5:40	LINE CLEAR AVAILED
468	26-Sep-19	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONNAGAR_110,HANUMANAL_110	0:00	6:34	6:34	LINE FAULT
469	26-Sep-19	GULBARGA	110	SINDHNOOR-TURVIHAL	TURVIHAL_110	0:00	0:30	0:30	LINE FAULT
470	26-Sep-19	GULBARGA	110	SINDHNOOR-PGLR_SLR	SIDHANOOR_220	4:35	4:45	0:10	LINE FAULT
471	26-Sep-19	GULBARGA	110	SINDHNOOR-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KAMPLI_110	6:20	6:30	0:10	LINE FAULT
472	26-Sep-19	GULBARGA	110	SINDHNOOR-TURVIHAL	TURVIHAL_110	7:30	8:30	1:00	LINE CLEAR AVAILED
473	26-Sep-19	GULBARGA	110	SINDHNOOR-SINDHANOOR1	MASKI_110,MUDDAPUR_110	10:10	10:20	0:10	LINE FAULT
474	26-Sep-19	GULBARGA	110	GURUGUNTA-LJVL_IPP	GURGUNTA_110	1:25	1:30	0:05	LINE FAULT
475	26-Sep-19	GULBARGA	110	HATTI-SOMANMARADI_IPP	HATTI_110	10:40	10:49	0:09	LINE FAULT
476	26-Sep-19	GULBARGA	110	HV2	HATTI_110	1:40	2:05	0:25	TRANSFORMER FAULT
477	26-Sep-19	GULBARGA	110	PDHALLI-ALIPUR	PDHALLI_110	5:04	5:12	0:08	MAIN SUPPLY FAILURE
478	26-Sep-19	GULBARGA	110	STAMETALLIC_IPP-MUNUIRABAD	STARMETALLIC_IPP	2:02	5:35	3:33	LINE FAULT
479	26-Sep-19	GULBARGA	110	KAPNOOR220-HUMNABAD1	MAHAGOAN_110, MARGUTTI_110	12:24	12:29	0:05	LINE FAULT
480	26-Sep-19	GULBARGA	110	KAPNOOR220-GULBARGANORTH2	GULBARGANORTH_110,GULBARGASOUTH_110,GULUNI_110	10:22	11:36	1:14	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
481	26-Sep-19	GULBARGA	110	KAPNOOR220-GULBARGANORTH1	GULBARGANORTH_110,GULBARGA SOUTH_110,GULUNI_110	10:22	11:36	1:14	LINE CLEAR AVAILED
482	26-Sep-19	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONNA GAR_110,HANUMANAL_110	0:00	6:34	6:34	LINE FAULT
483	26-Sep-19	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	4:27	4:34	0:07	LINE FAULT
484	26-Sep-19	GULBARGA	110	SEDAM-VICATSAGAR_IPP	VICATSAGAR_IPP	1:07	1:27	0:20	LINE FAULT
485	26-Sep-19	GULBARGA	110	SEDAM-VICATSAGAR_IPP	VICATSAGAR_IPP	5:52	5:58	0:06	LINE FAULT
486	26-Sep-19	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	5:44	5:49	0:05	LINE FAULT
487	26-Sep-19	GULBARGA	110	SINDHNOOR-TURVIHAL	TURVIHAL_110	11:30	12:32	1:02	LINE CLEAR AVAILED
488	26-Sep-19	GULBARGA	110	BANVEKAL-SLRYS_IPP	BANVEKAL_110	13:45	19:01	5:16	LINE CLEAR AVAILED
489	26-Sep-19	GULBARGA	110	HANUMASAGAR-KUSTAGI	HANUMASAGAR_110,HIREGONNA GAR_110,HANUMANAL_110	13:45	15:25	1:40	NFBC ISSUED
490	26-Sep-19	GULBARGA	110	HANUMASAGAR-GAGENDRAGAD	HANUMASAGAR_110,HIREGONNA GAR_110,HANUMANAL_110	13:00	14:40	1:40	NFBC ISSUED
491	26-Sep-19	GULBARGA	110	HV2	HANUMANAL_110	14:41	15:40	0:59	TRANSFORMER FAULT
492	26-Sep-19	GULBARGA	110	SHAHPUR-KEMBHAVI	KEMBHAVI_110	17:40	17:55	0:15	LINE FAULT
493	26-Sep-19	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	21:10	21:20	0:10	LINE FAULT
494	26-Sep-19	GULBARGA	110	RAICHUR-SINDHANOOR2	MANVI_110,MADALAPUR_110	18:57	19:01	0:04	LINE FAULT
495	26-Sep-19	GULBARGA	110	SINDHNOOR-TURVIHAL	TURVIHAL_110	11:30	12:30	1:00	LINE CLEAR AVAILED
496	26-Sep-19	GULBARGA	66	ITTAGI-CLEANMAX1_IPP	ITTAGI_220	12:33	12:39	0:06	LINE CLEAR AVAILED
497	26-Sep-19	GULBARGA	66	ITTAGI-RENEWSOLAR1_IPP	ITTAGI_220	12:37	12:41	0:04	LINE CLEAR AVAILED
498	26-Sep-19	GULBARGA	66	ITTAGI-KUDILIGI1,2	KUDILIGI_66,KOGALI_66,CJHALLI_66,GUDEKOTE_66,HANASI_66,HOSA HALLI_66,BANVEKAL_66,CHORNO OR_66	14:10	18:38	4:28	LINE CLEAR AVAILED
499	26-Sep-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:47	23:59	2:12	LINE CLEAR AVAILED
500	26-Sep-19	HASSAN	220	HV1	HASSAN_220	16:25	16:53	0:28	TRANSFORMER FAULT
501	26-Sep-19	HASSAN	220	HASSN22-NITTUR	HASSAN_220	16:25	16:53	0:28	LINE FAULT
502	26-Sep-19	HASSAN	220	HASSN22-Shomoga	HASSAN_220	16:25	17:22	0:57	LINE FAULT
503	26-Sep-19	HASSAN	220	HV2	HASSAN_220	16:25	16:53	0:28	TRANSFORMER FAULT
504	26-Sep-19	HASSAN	220	HV1	KEMAR_220	12:06	13:14	1:08	LINE CLEAR AVAILED
505	26-Sep-19	HASSAN	110	HV2	AJJAMPURA_110	11:19	11:41	0:22	LINE CLEAR AVAILED
506	26-Sep-19	HASSAN	110	HV1	ARASIKERE_220	14:30	15:10	0:40	MAIN SUPPLY FAILURE
507	26-Sep-19	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	13:35	14:01	0:26	LINE FAULT
508	26-Sep-19	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	14:09	14:30	0:21	LINE FAULT
509	26-Sep-19	HASSAN	110	HV1	BAIKAMPADI_110	13:00	14:25	1:25	LINE CLEAR AVAILED
510	26-Sep-19	HASSAN	110	HV2	BAIKAMPADI_110	13:00	14:26	1:26	LINE CLEAR AVAILED
511	26-Sep-19	HASSAN	110	HV3	BAIKAMPADI_110	14:26	19:49	5:23	LINE CLEAR AVAILED
512	26-Sep-19	HASSAN	110	BANTWA-SALATTUR	BANTWALA_110	9:44	12:47	3:03	NFBC ISSUED
513	26-Sep-19	HASSAN	110	HV1	DMKURKE_110	10:46	16:21	5:35	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
514	26-Sep-19	HASSAN	110	HV1	JOG_110	9:14	17:56	8:42	LINE CLEAR AVAILED
515	26-Sep-19	HASSAN	110	KADUR-NERELEKERE	KADUR_220	16:20	18:27	2:07	LINE FAULT
516	26-Sep-19	HASSAN	110	KADUR-NERELEKERE	KADUR_220	23:37	23:59	0:22	LINE FAULT
517	26-Sep-19	HASSAN	110	KITTADA-BLGAVE	KITTADAHALLI_110	16:59	19:08	2:09	NFBC ISSUED
518	26-Sep-19	HASSAN	110	HV2	KONDENALU_110	10:44	16:08	5:24	LINE CLEAR AVAILED
519	26-Sep-19	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	23:20	23:59	0:39	NFBC ISSUED
520	26-Sep-19	HASSAN	110	SAGARA-IDLE	SAGARA_110	13:47	17:44	3:57	LINE CLEAR AVAILED
521	26-Sep-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	14:15	18:00	3:45	LINE CLEAR AVAILED
522	26-Sep-19	HASSAN	110	HV2	SORABA_110	10:25	18:20	7:55	LINE CLEAR AVAILED
523	26-Sep-19	HASSAN	66	HASSN22-SKP1	HASSAN_220	16:40	16:53	0:13	HAND TRIPPED
524	26-Sep-19	HASSAN	66	HASSN22-SKP2	HASSAN_220	16:40	16:53	0:13	HAND TRIPPED
525	26-Sep-19	HASSAN	66	HASSN22-ARK2	HASSAN_220	16:40	16:53	0:13	HAND TRIPPED
526	26-Sep-19	HASSAN	66	HASSN22-ARK1	HASSAN_220	16:40	16:53	0:13	HAND TRIPPED
527	26-Sep-19	HASSAN	66	HASSN22-HNPURA2	HASSAN_220	16:40	16:53	0:13	HAND TRIPPED
528	26-Sep-19	HASSAN	66	HASSN22-HNPURA1	HASSAN_220	16:40	16:53	0:13	HAND TRIPPED
529	26-Sep-19	HASSAN	66	HASSN22-SUZLON	HASSAN_220	16:40	16:58	0:18	HAND TRIPPED
530	26-Sep-19	HASSAN	66	HASSN22-BELUR	HASSAN_220	16:40	16:58	0:18	HAND TRIPPED
531	26-Sep-19	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	16:40	16:58	0:18	HAND TRIPPED
532	26-Sep-19	HASSAN	66	HV1	BAGUR_110	12:26	14:26	2:00	LINE CLEAR AVAILED
533	26-Sep-19	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	16:24	16:36	0:12	LINE CLEAR AVAILED
534	26-Sep-19	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	18:23	18:42	0:19	LINE CLEAR AVAILED
535	26-Sep-19	HASSAN	66	HV1	DODDAKADANUR_66	11:59	14:33	2:34	LINE CLEAR AVAILED
536	26-Sep-19	HASSAN	66	HV1	HARIHARAPURA_66	13:40	13:45	0:05	TRANSFORMER FAULT
537	26-Sep-19	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	6:23	6:32	0:09	MAIN SUPPLY FAILURE
538	26-Sep-19	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	11:57	12:10	0:13	HAND TRIPPED
539	26-Sep-19	HASSAN	66	HV2	SHRAVANABELAGOLA_66	11:19	17:12	5:53	LINE CLEAR AVAILED
540	26-Sep-19	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	14:49	15:44	0:55	MAIN SUPPLY FAILURE
541	26-Sep-19	HASSAN	66	HV1	SINGAPURA_66	14:49	15:46	0:57	MAIN SUPPLY FAILURE
542	26-Sep-19	HASSAN	66	HV2	SINGAPURA_66	14:49	15:46	0:57	MAIN SUPPLY FAILURE
543	26-Sep-19	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	6:15	6:29	0:14	LINE FAULT
544	26-Sep-19	MYSORE	66	HV1	BANANGADI_66	9:54	17:46	7:52	LINE CLEAR AVAILED
545	26-Sep-19	MYSORE	66	HV2	BANANGADI_66	10:00	17:35	7:35	LINE CLEAR AVAILED
546	26-Sep-19	MYSORE	66	HV1	COWDALLI_66	4:21	4:39	0:18	HAND TRIPPED
547	26-Sep-19	MYSORE	66	CR NAGARA-KABBALLI	HARVEY_66	5:10	5:23	0:13	LINE FAULT
548	26-Sep-19	MYSORE	66	HV1	DEVANOORMYS_66	10:14	15:20	5:06	LINE CLEAR AVAILED
549	26-Sep-19	MYSORE	66	HV2	DEVANOORMYS_66	10:14	17:23	7:09	LINE CLEAR AVAILED
550	26-Sep-19	MYSORE	66	HV1	DODDINADUVADI_66	15:00	15:30	0:30	LINE CLEAR AVAILED
551	26-Sep-19	MYSORE	66	HV2	DODDINADUVADI_66	15:00	15:30	0:30	LINE CLEAR AVAILED
552	26-Sep-19	MYSORE	66	DODDINADUVADI-KOTTANURU	KOTTANUR_66	17:50	17:55	0:05	LINE FAULT
553	26-Sep-19	MYSORE	66	HV1	HAMPAPURA(K)_66	16:18	17:14	0:56	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
554	26-Sep-19	MYSORE	66	HV2	HAMPAPURA(K)_66	11:05	17:15	6:10	LINE CLEAR AVAILED
555	26-Sep-19	MYSORE	66	HV1	JAIPUR_66	10:05	18:56	8:51	LINE CLEAR AVAILED
556	26-Sep-19	MYSORE	66	HV2	JAIPUR_66	10:05	18:50	8:45	LINE CLEAR AVAILED
557	26-Sep-19	MYSORE	66	MADHUVANAHALLI-HANNUR 2	BANDALLI_66, COWDALLI_66, HANNUR_66, MARTAHALLI_66, RAMAPURA_MYS_66	17:48	17:52	0:04	LINE FAULT
558	26-Sep-19	MYSORE	66	HV1	PANDAVAPURA_66	12:11	13:22	1:10	LINE CLEAR AVAILED
559	26-Sep-19	MYSORE	66	HV1	THANDYA_66	15:34	15:48	0:13	TRANSFORMER FAULT
560	26-Sep-19	MYSORE	66	HV1	THANDYA_66	16:39	16:51	0:11	TRANSFORMER FAULT
561	26-Sep-19	MYSORE	66	HV2	THANDYA_66	13:46	16:50	3:04	LINE CLEAR AVAILED
562	26-Sep-19	MYSORE	66	VAJAMANGALA-DEVNUR(MYS)	DEVANOORMYS_66	10:06	15:10	5:03	NFBC ISSUED
563	26-Sep-19	MYSORE	220	HV1	VAJAMANGALA_220	10:41	15:14	4:32	LINE CLEAR AVAILED
564	26-Sep-19	MYSORE	66	HV1	VAJAMANGALA_220	10:50	10:53	0:03	HAND TRIPPED
565	26-Sep-19	TUMKUR	400	TR-1(HV SIDE)	GUTUR_400	16:08	20:29	4:21	TRANSFORMER FAULT
566	26-Sep-19	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	18:16	20:49	2:32	LINE FAULT
567	26-Sep-19	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	20:49	22:53	2:03	LINE FAULT
568	26-Sep-19	TUMKUR	220	TR-3	ANTHRASANAHALLI_220	15:09	16:53	1:44	LINE CLEAR AVAILED
569	26-Sep-19	TUMKUR	220	TR-1(HV SIDE)	CHITRADURGA_220	11:02	13:13	2:10	LINE CLEAR AVAILED
570	26-Sep-19	TUMKUR	220	TR-3(HV SIDE)	CHITRADURGA_220	11:11	12:35	1:23	LINE CLEAR AVAILED
571	26-Sep-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	3:09	8:28	5:18	TRANSFORMER FAULT
572	26-Sep-19	TUMKUR	220	TR-3 (HV SIDE)	HIRIYUR_220	17:03	17:10	0:06	TRANSFORMER FAULT
573	26-Sep-19	TUMKUR	220	HONNALLI 220KV- SUZLON1	SUZLON_IPP_66	4:59	7:29	2:29	LINE FAULT
574	26-Sep-19	TUMKUR	220	HONNALLI 220KV- SUZLON2	SUZLON_IPP_66	4:59	6:08	1:09	LINE FAULT
575	26-Sep-19	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	15:18	16:50	1:32	LINE CLEAR AVAILED
576	26-Sep-19	TUMKUR	110	TR-1	KGTEMPLE_110	12:49	18:48	5:59	LINE CLEAR AVAILED
577	26-Sep-19	TUMKUR	66	ANCHEPALYA 220KV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	22:08	22:20	0:11	LINE FAULT
578	26-Sep-19	TUMKUR	66	TR-2	BELLAVI_66	9:39	14:55	5:16	LINE CLEAR AVAILED
579	26-Sep-19	TUMKUR	66	TR-2	BELLAVI_66	16:32	17:47	1:15	LINE CLEAR AVAILED
580	26-Sep-19	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	11:39	13:04	1:24	LINE CLEAR AVAILED
581	26-Sep-19	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	11:10	12:37	1:27	LINE CLEAR AVAILED
582	26-Sep-19	TUMKUR	66	TR-2	DAVANAGERE_66	16:10	16:11	0:01	TRANSFORMER FAULT
583	26-Sep-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:03	11:27	0:24	HAND TRIPPED
584	26-Sep-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	11:03	11:26	0:22	HAND TRIPPED
585	26-Sep-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:03	11:27	0:24	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
586	26-Sep-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:03	11:31	0:27	HAND TRIPPED
587	26-Sep-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	3:11	3:31	0:19	HAND TRIPPED
588	26-Sep-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	8:19	8:37	0:17	HAND TRIPPED
589	26-Sep-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	17:06	17:12	0:06	HAND TRIPPED
590	26-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	3:13	3:31	0:18	HAND TRIPPED
591	26-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	8:18	8:50	0:31	HAND TRIPPED
592	26-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	3:11	3:32	0:21	HAND TRIPPED
593	26-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	8:18	8:37	0:18	HAND TRIPPED
594	26-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	17:06	17:11	0:04	HAND TRIPPED
595	26-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	3:11	3:32	0:21	HAND TRIPPED
596	26-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	8:18	8:37	0:18	HAND TRIPPED
597	26-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	17:06	17:11	0:04	HAND TRIPPED
598	26-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	3:10	3:31	0:21	HAND TRIPPED
599	26-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	8:18	8:28	0:10	HAND TRIPPED
600	26-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	10:40	10:44	0:03	HAND TRIPPED
601	26-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	17:04	17:11	0:07	HAND TRIPPED
602	26-Sep-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	0:18	0:28	0:09	LINE FAULT
603	26-Sep-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	12:19	13:36	1:17	LINE CLEAR AVAILED
604	26-Sep-19	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	2:29	2:40	0:10	LINE FAULT
605	26-Sep-19	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	3:04	3:14	0:09	LINE FAULT
606	26-Sep-19	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS1_EHT_66	12:00	12:03	0:02	LINE FAULT
607	26-Sep-19	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR_IPP_66	TATA SOLAR_IPP_66	11:09	11:15	0:05	HAND TRIPPED
608	26-Sep-19	TUMKUR	66	KATTIGE- BEDRUGADDE	KATTIGE_66	17:41	18:34	0:53	LINE CLEAR AVAILED
609	26-Sep-19	TUMKUR	66	TR-1	KATTIGE_66	10:15	18:35	8:19	LINE CLEAR AVAILED
610	26-Sep-19	TUMKUR	66	KATTIGE- RENEW WIND IPP	RENEW WIND ENERGY_IPP_66	17:41	18:36	0:55	LINE CLEAR AVAILED
611	26-Sep-19	TUMKUR	66	TR-1	KORA_66	10:29	12:27	1:58	TRANSFORMER FAULT
612	26-Sep-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	4:20	4:35	0:15	LINE FAULT
613	26-Sep-19	TUMKUR	66	TR-1	RAMPURA_66	14:01	14:15	0:13	LINE CLEAR AVAILED
614	26-Sep-19	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	18:43	21:20	2:36	LINE FAULT
615	26-Sep-19	TUMKUR	66	TR-2	THIMMASANDRA_66	16:41	17:35	0:54	LINE CLEAR AVAILED
616	27-Sep-19	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	20:50	21:03	0:13	LINE FAULT
617	27-Sep-19	BAGALKOT	110	BELGAUM220-ANKALAGI	ANKALAGI_110	9:24	17:38	8:14	LINE CLEAR AVAILED
618	27-Sep-19	BAGALKOT	110	110/11KV,HV4	BAILAHONGAL_110	11:50	16:21	4:31	LINE CLEAR AVAILED
619	27-Sep-19	BAGALKOT	110	110/11KV,HV4	BAILAHONGAL_110	16:28	17:35	1:07	LINE CLEAR AVAILED
620	27-Sep-19	BAGALKOT	220	GADAG-BAGALKOT2	GADAG_220	0:00	15:06	15:06	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
621	27-Sep-19	BAGALKOT	220	BAGALKOT-GADAG1	BAGALKOT_220	10:01	15:05	5:04	LINE CLEAR AVAILED
622	27-Sep-19	BAGALKOT	110	BELGAUM220-BELGAUM	BELGAUM_110	8:32	12:13	3:41	LINE FAULT
623	27-Sep-19	BAGALKOT	110	GAJENDRAGAD-RON1	RON_110	8:39	9:27	0:48	HAND TRIPPED
624	27-Sep-19	BAGALKOT	220	GADAG-BAGALKOT1	GADAG_220	21:04	23:59	2:55	LINE CLEAR AVAILED
625	27-Sep-19	BAGALKOT	110	INDI220-HIREBEVANUR	HIREBEVANUR_110	10:00	19:05	9:05	LINE CLEAR AVAILED
626	27-Sep-19	BAGALKOT	110	DSS SUGARS-HIREBEVANUR	HIREBEVANUR_110	10:00	18:47	8:47	LINE CLEAR AVAILED
627	27-Sep-19	BAGALKOT	66	66/33KV,HV4	HARIHAR-HOSPET_66, RAMCO_33	16:10	16:19	0:09	HAND TRIPPED
628	27-Sep-19	BAGALKOT	110	JAMKHANDI SUGARS-TODALBAGI	TODALBAGI_110	10:10	16:54	6:44	LINE CLEAR AVAILED
629	27-Sep-19	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	10:42	11:49	1:07	LINE CLEAR AVAILED
630	27-Sep-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	11:01	12:58	1:57	LINE CLEAR AVAILED
631	27-Sep-19	BAGALKOT	110	BPCL-SHIRAHATTI	SHIRAHATTI_110	17:50	18:04	0:14	LINE FAULT
632	27-Sep-19	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220	0:30	23:59	23:29	TRANSFORMER FAULT
633	27-Sep-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	6:15	6:26	0:11	LINE FAULT
634	27-Sep-19	BAGALKOT	110	110/33KV,HV2	KIRUVATTI_110,YELLAPUR_33	12:46	13:57	1:11	LINE CLEAR AVAILED
635	27-Sep-19	BENGALURU	66	HV2	CHANDAPURA	7:31	7:37	0:06	TRANSFORMER FAULT
636	27-Sep-19	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	18:51	19:21	0:29	LOAD CURTAILMENT
637	27-Sep-19	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66, SM MANGALA	12:10	13:27	1:17	LINE CLEAR AVAILED
638	27-Sep-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	13:45	13:51	0:06	LINE FAULT
639	27-Sep-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1 & 2	DEVANAHALLI, KUNDANA	10:29	10:35	0:06	LINE CLEAR AVAILED
640	27-Sep-19	BENGALURU	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	17:40	17:42	0:02	LINE CLEAR AVAILED
641	27-Sep-19	BENGALURU	66	HV1	HOSUR RAMAPURA	7:50	10:30	2:40	TRANSFORMER FAULT
642	27-Sep-19	BENGALURU	66	HV1	HOSUR RAMAPURA	16:14	16:25	0:10	LINE CLEAR AVAILED
643	27-Sep-19	BENGALURU	66	HV1	KODIHALLI	6:50	6:52	0:02	LINE CLEAR AVAILED
644	27-Sep-19	BENGALURU	66	HV1	KODIHALLI	7:25	7:30	0:05	LINE CLEAR AVAILED
645	27-Sep-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	18:50	19:41	0:50	LOAD CURTAILMENT
646	27-Sep-19	BENGALURU	66	KEMBODI - KOLAR 220	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI, KEMBODI	12:20	14:30	2:10	LINE CLEAR AVAILED
647	27-Sep-19	BENGALURU	66	HV1	SURYANAGAR	11:06	11:37	0:30	LINE CLEAR AVAILED
648	27-Sep-19	BENGALURU	220	HOODY 220 - RAILWAYS 2 (EHT)	RAILWAYS 2 (EHT)	4:53	12:44	7:50	LINE FAULT
649	27-Sep-19	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	15:33	15:49	0:15	LINE FAULT
650	27-Sep-19	BENGALURU	66	HV1	KENGERI SATELLITE	12:42	12:48	0:05	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
651	27-Sep-19	BENGALURU	66	HV2	KENGERI SATELLITE	14:11	14:18	0:06	LINE CLEAR AVAILED
652	27-Sep-19	GULBARGA	220	SHAHPUR-SEDAM	SEDAM_220	12:28	12:41	0:13	LINE CLEAR AVAILED
653	27-Sep-19	GULBARGA	220	HV1	RAICHURSA_220	9:53	16:27	6:34	LINE CLEAR AVAILED
654	27-Sep-19	GULBARGA	220	SINDHANOOR220-LINGASUGUR	SIDHANOOR_220	11:30	11:40	0:10	LINE CLEAR AVAILED
655	27-Sep-19	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	17:21	23:59	6:38	LINE FAULT
656	27-Sep-19	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	5:10	6:40	1:30	LINE FAULT
657	27-Sep-19	GULBARGA	110	HV2	KAVITAL_110	10:28	11:02	0:34	LINE CLEAR AVAILED
658	27-Sep-19	GULBARGA	110	BHALKI-LADHA	LADHA_110	6:17	6:47	0:30	LINE FAULT
659	27-Sep-19	GULBARGA	110	BHALKI-HALBARGA	BHALKI_110,BKLISUGAR_IPP	6:08	6:11	0:03	LINE FAULT
660	27-Sep-19	GULBARGA	110	HV1	RAJESHWAR_110	12:06	12:40	0:34	LINE CLEAR AVAILED
661	27-Sep-19	GULBARGA	110	KAPNOOR-MADIYAL	KAPNOOR_220, CHOWDAPUR_110	13:17	13:26	0:09	LINE FAULT
662	27-Sep-19	GULBARGA	110	HALBURGA-CHIDRI1	KAMTHANA_110, HABSIKOTE_110	5:31	6:05	0:34	LINE FAULT
663	27-Sep-19	GULBARGA	110	HALBURGA-ACMESOLAR_IPP	HALBURGA_220	12:28	12:35	0:07	LINE CLEAR AVAILED
664	27-Sep-19	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	19:18	19:25	0:07	LINE CLEAR AVAILED
665	27-Sep-19	GULBARGA	66	KOTTUR-KUDLIGI	UJJANI_66	12:45	14:25	1:40	LINE CLEAR AVAILED
666	27-Sep-19	GULBARGA	66	KOTTUR-ITTAGI	KOTTUR_66, UJJAINI_66	14:00	14:20	0:20	MAIN SUPPLY FAILURE
667	27-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	1:38	16:30	14:52	LINE FAULT
668	27-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	20:54	23:59	3:05	MAIN SUPPLY FAILURE
669	27-Sep-19	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	10:24	13:53	3:29	LINE CLEAR AVAILED
670	27-Sep-19	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	0:03	1:27	1:24	LINE CLEAR AVAILED
671	27-Sep-19	HASSAN	220	HV3	KEMAR_220	12:32	13:34	1:02	LINE CLEAR AVAILED
672	27-Sep-19	HASSAN	110	LV3	KEMAR_220	12:31	13:35	1:04	LINE CLEAR AVAILED
673	27-Sep-19	HASSAN	110	HV1	SHIVPURA_110	14:30	15:17	0:47	LINE CLEAR AVAILED
674	27-Sep-19	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	10:40	11:40	1:00	LINE CLEAR AVAILED
675	27-Sep-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	8:57	9:07	0:10	LINE FAULT
676	27-Sep-19	HASSAN	66	HV1	KALASAPURA_66	10:00	14:30	4:30	LINE CLEAR AVAILED
677	27-Sep-19	HASSAN	66	HV2	KALASAPURA_66	10:00	14:30	4:30	LINE CLEAR AVAILED
678	27-Sep-19	HASSAN	66	HV1	KANDLI_66	11:25	12:07	0:42	LINE CLEAR AVAILED
679	27-Sep-19	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	10:44	11:40	0:56	NFBC ISSUED
680	27-Sep-19	HASSAN	110	ANANDA-LPH(LST-4)	ANANDAPURA_110	10:12	15:16	5:04	NFBC ISSUED
681	27-Sep-19	HASSAN	110	KADUR-NERELEKERE	KADUR_220	0:00	1:22	1:22	LINE FAULT
682	27-Sep-19	HASSAN	110	KADUR-NGNHL	KADUR_220	8:24	9:06	0:42	LINE FAULT
683	27-Sep-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	13:14	13:28	0:14	LINE FAULT
684	27-Sep-19	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	0:00	1:28	1:28	NFBC ISSUED
685	27-Sep-19	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	18:37	23:59	5:22	LINE FAULT
686	27-Sep-19	MYSORE	66	HV1	DODDARAYAPET_66	15:40	16:12	0:32	TRANSFORMER FAULT
687	27-Sep-19	MYSORE	66	HV1	FTS_66	9:36	9:57	0:20	HAND TRIPPED
688	27-Sep-19	MYSORE	66	HV2	FTS_66	9:33	9:56	0:22	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
689	27-Sep-19	MYSORE	66	HV1	FTS_66	14:46	14:53	0:06	HAND TRIPPED
690	27-Sep-19	MYSORE	66	HV2	FTS_66	14:46	14:51	0:05	HAND TRIPPED
691	27-Sep-19	MYSORE	66	HV1	MADIKERI_66	10:44	16:57	6:12	LINE CLEAR AVAILED
692	27-Sep-19	MYSORE	66	MUGUR-MADHUVANAHALLI	JANNUR_66, MUGUR_66, THAYURU_66, TNARASIPURA_66	3:00	3:18	0:17	LINE FAULT
693	27-Sep-19	MYSORE	66	HV1	SANTHESARAGUR_66	10:18	17:27	7:08	LINE CLEAR AVAILED
694	27-Sep-19	MYSORE	66	HV2	SANTHESARAGUR_66	10:19	17:27	7:08	LINE CLEAR AVAILED
695	27-Sep-19	MYSORE	66	HV1	VAJAMANGALA_220	10:44	16:27	5:42	LINE CLEAR AVAILED
696	27-Sep-19	MYSORE	66	HV2	VAJAMANGALA_220	10:44	16:27	5:42	LINE CLEAR AVAILED
697	27-Sep-19	TUMKUR	400	TR-2(HV SIDE)	GUTUR_400	17:52	18:06	0:14	LINE CLEAR AVAILED
698	27-Sep-19	TUMKUR	220	TR-1(HV SIDE)	ANTHRASANAHALLI_220	9:35	9:41	0:05	TRANSFORMER FAULT
699	27-Sep-19	TUMKUR	220	TR-1	ANTHRASANAHALLI_220	11:25	18:49	7:23	LINE CLEAR AVAILED
700	27-Sep-19	TUMKUR	220	MADHUGIRI 220kV-GOWRIBIDANUR220	MADHUGIRI_220	9:41	11:57	2:16	LINE CLEAR AVAILED
701	27-Sep-19	TUMKUR	110	TR-1	AMMASANDRA_110	12:37	13:54	1:16	TRANSFORMER FAULT
702	27-Sep-19	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	15:13	16:10	0:57	MAIN SUPPLY FAILURE
703	27-Sep-19	TUMKUR	110	TR-1 & TR-2	CHIKKANAYAKANAHALLI_110	15:13	16:05	0:52	MAIN SUPPLY FAILURE
704	27-Sep-19	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETTYKERE_110	15:13	16:04	0:51	MAIN SUPPLY FAILURE
705	27-Sep-19	TUMKUR	110	TR-1	GUBBI_110	16:17	16:42	0:25	LINE CLEAR AVAILED
706	27-Sep-19	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	14:20	15:02	0:41	LINE CLEAR AVAILED
707	27-Sep-19	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	11:25	18:59	7:34	LINE CLEAR AVAILED
708	27-Sep-19	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66	10:37	13:35	2:57	LINE CLEAR AVAILED
709	27-Sep-19	TUMKUR	66	TR-3	HARIYABBE_66	18:19	18:30	0:11	HAND TRIPPED
710	27-Sep-19	TUMKUR	66	TR-1	HIREGUNTANUR_66	12:21	12:57	0:35	LINE CLEAR AVAILED
711	27-Sep-19	TUMKUR	66	TR-2	HIREGUNTANUR_66	12:38	12:57	0:18	LINE CLEAR AVAILED
712	27-Sep-19	TUMKUR	66	TR-2	HOLAVINAHALLY_66	12:22	12:43	0:21	HAND TRIPPED
713	27-Sep-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	17:42	17:55	0:13	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
714	27-Sep-19	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	14:24	14:32	0:08	LINE FAULT
715	27-Sep-19	TUMKUR	66	TR-2	RAMPURA_66	22:19	22:26	0:06	TRANSFORMER FAULT
716	27-Sep-19	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,SOKK E_66	5:15	5:21	0:06	LINE FAULT
717	27-Sep-19	TUMKUR	66	TR-2	BELLAVI_66	10:39	15:43	5:04	LINE CLEAR AVAILED
718	28-Sep-19	BAGALKOT	110	ANKOLA-KUMTA	KUMTA_110	9:47	15:23	5:36	LINE CLEAR AVAILED
719	28-Sep-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR1&2	MAMADAPUR_110	12:24	15:45	3:21	LINE CLEAR AVAILED
720	28-Sep-19	BAGALKOT	220	CHIKKODI-GHATAPRABHA	CHIKKODI_220	0:00	11:00	11:00	LINE CLEAR AVAILED
721	28-Sep-19	BAGALKOT	110	MAHALINGAPUR220-JAMAKHANDI	JAMAKHANDI_110	17:44	17:52	0:08	HAND TRIPPED
722	28-Sep-19	BAGALKOT	110	KADANAKOPPA-KAVALAWADA	KAVALAWADA_110	23:23	23:59	0:36	LINE FAULT
723	28-Sep-19	BAGALKOT	110	TODALBAGI-MAMADAPUR	MAMADAPUR_110	15:39	23:59	8:20	LINE CLEAR AVAILED
724	28-Sep-19	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110	5:41	5:45	0:04	LINE FAULT
725	28-Sep-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	12:20	13:26	1:06	LINE CLEAR AVAILED
726	28-Sep-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	21:06	23:59	2:53	LINE CLEAR AVAILED
727	28-Sep-19	BAGALKOT	110	110/33KV, HV3	MAMADAPUR(B)_110,DEVAR GENNUR_33	12:48	12:58	0:10	TRANSFORMER FAULT
728	28-Sep-19	BAGALKOT	110	110/11KV, HV2	KAGAWAD_110	17:25	17:45	0:20	TRANSFORMER FAULT
729	28-Sep-19	BAGALKOT	110	110/33KV, HV3	SANKESHWAR_110,HEBBAL_33,KA NAGAL_33KV	12:25	12:48	0:23	LINE CLEAR AVAILED
730	28-Sep-19	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	22:22	23:13	0:51	LINE CLEAR AVAILED
731	28-Sep-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	18:36	19:04	0:28	LINE FAULT
732	28-Sep-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	22:22	23:13	0:51	LINE CLEAR AVAILED
733	28-Sep-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	19:18	19:44	0:26	LINE CLEAR AVAILED
734	28-Sep-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	20:12	20:19	0:06	LINE CLEAR AVAILED
735	28-Sep-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	21:02	23:39	2:36	LINE CLEAR AVAILED
736	28-Sep-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	10:03	10:08	0:04	LINE CLEAR AVAILED
737	28-Sep-19	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	9:02	10:03	1:01	LINE FAULT
738	28-Sep-19	BENGALURU	66	HV2	NIMHANS 220	0:38	2:06	1:28	TRANSFORMER FAULT
739	28-Sep-19	BENGALURU	66	HV3	NAGNATHPURA 220	9:25	10:10	0:45	TRANSFORMER FAULT
740	28-Sep-19	GULBARGA	220	HV2	ALIPUR_220	13:15	13:26	0:11	HAND TRIPPED
741	28-Sep-19	GULBARGA	220	ALIPUR-BTPSG	ALIPUR_220	13:08	13:25	0:17	LINE FAULT
742	28-Sep-19	GULBARGA	220	LINGASUGUR-KUSTAGI	LINGASUGUR_220	13:16	17:44	4:28	LINE FAULT
743	28-Sep-19	GULBARGA	110	KAPNOOR-MADIYAL	KAPNOOR_220, CHOWDAPUR_110	23:54	23:58	0:04	LINE FAULT
744	28-Sep-19	GULBARGA	110	LINGASUGUR-GAMESHA_IPP	LINGASUGUR_220	10:55	13:56	3:01	LINE CLEAR AVAILED
745	28-Sep-19	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	19:33	19:40	0:07	LINE FAULT
746	28-Sep-19	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	20:18	20:20	0:02	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
747	28-Sep-19	GULBARGA	110	SINDHANOOR220-SIRAGUPPA	SIRAGUPPA_110,TEKKALKOTE_110 ,DHADESUGUR_110,NSL SUGAR_IPP	6:48	6:58	0:10	LINE FAULT
748	28-Sep-19	GULBARGA	110	SINDHANOOR220-TURVIHAL	TURVIHAL_110	9:35	9:45	0:10	LINE FAULT
749	28-Sep-19	GULBARGA	110	RAICHUR-SIDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAW AT_110	21:22	21:36	0:14	HAND TRIPPED
750	28-Sep-19	GULBARGA	110	RAICHUR-SIDHANOOR2	KURDICROSS_110,MANVI_110,MA DALAPUR_110	23:12	23:17	0:05	LINE FAULT
751	28-Sep-19	GULBARGA	110	SINDHANOOR220-TURVIHAL	TURVIHAL_110	20:50	21:10	0:20	LINE FAULT
752	28-Sep-19	GULBARGA	110	HV1	HANUMSAGAR_110	4:50	5:10	0:20	TRANSFORMER FAULT
753	28-Sep-19	GULBARGA	66	KOGALI-ATRSOLAR	KOGALI_66	10:56	11:10	0:14	HAND TRIPPED
754	28-Sep-19	GULBARGA	66	KOTTUR-SUZLON1	KOTTUR_66	12:20	13:35	1:15	LINE CLEAR AVAILED
755	28-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	9:19	9:19	MAIN SUPPLY FAILURE
756	28-Sep-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	9:57	12:12	2:15	LINE CLEAR AVAILED
757	28-Sep-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	19:38	22:15	2:37	LINE CLEAR AVAILED
758	28-Sep-19	HASSAN	220	LV1	GOPAL	17:40	18:30	0:50	HAND TRIPPED
759	28-Sep-19	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	9:57	12:12	2:15	LINE CLEAR AVAILED
760	28-Sep-19	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	17:10	17:50	0:40	LINE FAULT
761	28-Sep-19	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	17:10	17:50	0:40	LINE FAULT
762	28-Sep-19	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	18:00	21:50	3:50	LINE CLEAR AVAILED
763	28-Sep-19	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	0:00	9:05	9:05	LINE FAULT
764	28-Sep-19	HASSAN	220	VARAH1-SHMG3	varahi_gen	19:40	22:15	2:35	LINE CLEAR AVAILED
765	28-Sep-19	HASSAN	110	HV2	NITTUR_110	9:42	10:42	1:00	LINE CLEAR AVAILED
766	28-Sep-19	MYSORE	66	HV1	JAIPUR_66	10:15	10:25	0:10	LINE CLEAR AVAILED
767	28-Sep-19	MYSORE	66	HV1	JAIPUR_66	11:44	13:44	1:59	LINE CLEAR AVAILED
768	28-Sep-19	MYSORE	66	PARINAMIPURA-TALAKADU	BGPURA_66, CHANDALLI_66, THALAKADU_66	4:37	4:42	0:05	LINE FAULT
769	28-Sep-19	MYSORE	66	PARINAMIPURA-TALAKADU	BGPURA_66, CHANDALLI_66, THALAKADU_66	5:38	5:43	0:05	LINE FAULT
770	28-Sep-19	TUMKUR	220	TR-3	HIRIYUR_220	1:04	8:58	7:54	TRANSFORMER FAULT
771	28-Sep-19	TUMKUR	110	TR-1	KBCROSS_220	14:00	15:33	1:32	TRANSFORMER FAULT
772	28-Sep-19	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	13:55	14:59	1:04	LINE CLEAR AVAILED
773	28-Sep-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	2:38	9:00	6:22	LINE CLEAR AVAILED
774	28-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	2:39	8:59	6:20	LINE CLEAR AVAILED
775	28-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	2:39	8:59	6:19	LINE CLEAR AVAILED
776	28-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	2:38	8:58	6:19	LINE CLEAR AVAILED
777	29-Sep-19	BAGALKOT	110	110/11KV,HV2	ANKALAGI_110	10:19	12:35	2:16	LINE CLEAR AVAILED
778	29-Sep-19	BAGALKOT	220	PONDA1-AMBEWADI	AMBEWADI_220	13:48	15:08	1:20	LINE FAULT
779	29-Sep-19	BAGALKOT	110	NARENDRA220-BELUR1&2	BELUR_110	15:58	18:25	2:27	LINE CLEAR AVAILED
780	29-Sep-19	BAGALKOT	220	BIDNAL-HUBLI 1	BIDNAL_220	11:54	16:34	4:40	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
781	29-Sep-19	BAGALKOT	110	ENERCON-BIJAPUR	BIJAPUR_220	18:50	18:59	0:09	LINE FAULT
782	29-Sep-19	BAGALKOT	220	CHIKKODI-TALANDGE	CHIKKODI_220	0:00	23:12	23:12	LINE CLEAR AVAILED
783	29-Sep-19	BAGALKOT	220	GADAG-BAGALKOT1	GADAG_220	0:00	13:51	13:51	LINE CLEAR AVAILED
784	29-Sep-19	BAGALKOT	110	KADANAKOPPA-KAVALAWADA	KAVALAWADA_110	0:00	12:11	12:11	LINE CLEAR AVAILED
785	29-Sep-19	BAGALKOT	110	KADANAKOPPA-KAVALAWADA	KAVALAWADA_110	13:35	13:55	0:20	HAND TRIPPED
786	29-Sep-19	BAGALKOT	110	110/33KV,HV3	TODALBAGI_110,BIDARI_33KV,HIR EPADASALAGI_33KV	8:07	8:26	0:19	HAND TRIPPED
787	29-Sep-19	BAGALKOT	110	110/33KV,HV3	TODALBAGI_110,BIDARI_33KV,HIR EPADASALAGI_33KV	11:29	11:34	0:05	HAND TRIPPED
788	29-Sep-19	BAGALKOT	220	HUBLI-BIDNAL1	HUBLI_220	12:18	16:35	4:17	LINE FAULT
789	29-Sep-19	BAGALKOT	220	NAGJHARI1-HUBLI	HUBLI_220	12:31	23:59	11:28	LINE FAULT
790	29-Sep-19	BAGALKOT	220	220/110,HV2,LV2	NARENDRA_220,SHEDBAL_110	11:03	11:22	0:19	TRANSFORMER FAULT
791	29-Sep-19	BAGALKOT	110	NARENDRA-SHIRBUR	SHEDBAL_110	11:07	18:24	7:17	LINE FAULT
792	29-Sep-19	BAGALKOT	110	NARENDRA-BELUR 1&2	BELUR_110	16:21	18:25	2:04	LINE CLEAR AVAILED
793	29-Sep-19	BAGALKOT	110	110/11KV,HV2	MATTIHAL_110,KOLAR WATER SUPPLY_33KV,KARJOL_33KN,NTPC _33KV	18:07	23:59	5:52	TRANSFORMER FAULT
794	29-Sep-19	BAGALKOT	220	220/110KV,HV3	MAHALINGAPUR_220	0:30	0:59	0:29	TRANSFORMER FAULT
795	29-Sep-19	BAGALKOT	110	MAHALINGAPUR-RABKAVI	RABKAVI_110	0:30	10:11	9:41	LINE CLEAR AVAILED
796	29-Sep-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	0:00	7:31	7:31	LINE CLEAR AVAILED
797	29-Sep-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	7:31	23:59	16:28	LINE FAULT
798	29-Sep-19	BENGALURU	66	ANEKAL - YARANDANAHALLI 1 & 2	ANEKAL	9:50	10:10	0:20	LOAD CHANGEOVER
799	29-Sep-19	BENGALURU	66	ANEKAL - ATTIBELE	ANEKAL	19:40	19:50	0:10	LOAD CHANGEOVER
800	29-Sep-19	BENGALURU	66	SURANAGAR - YARANDANAHALLI 220	SURANAGAR	9:35	19:52	10:17	LINE CLEAR AVAILED
801	29-Sep-19	BENGALURU	220	CHINTAMANI 220 - PGCIL 1	CHINTAMANI 220	21:02	21:31	0:29	MAIN SUPPLY FAILURE
802	29-Sep-19	BENGALURU	220	CHINTAMANI 220 - PGCIL 2	CHINTAMANI 220	21:02	21:32	0:30	MAIN SUPPLY FAILURE
803	29-Sep-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	21:02	21:33	0:31	MAIN SUPPLY FAILURE
804	29-Sep-19	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	21:02	21:33	0:31	MAIN SUPPLY FAILURE
805	29-Sep-19	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66, SM MANGALA	21:02	21:33	0:31	MAIN SUPPLY FAILURE
806	29-Sep-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	21:02	21:33	0:31	MAIN SUPPLY FAILURE
807	29-Sep-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	21:02	21:33	0:31	MAIN SUPPLY FAILURE
808	29-Sep-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	21:02	21:33	0:31	MAIN SUPPLY FAILURE
809	29-Sep-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA, Y HUNDENAHALLI	21:02	21:33	0:31	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
810	29-Sep-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASAPURA	SRINIVASAPURA, G KODIHALLI	21:02	21:33	0:31	MAIN SUPPLY FAILURE
811	29-Sep-19	BENGALURU	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	21:02	21:33	0:31	MAIN SUPPLY FAILURE
812	29-Sep-19	BENGALURU	220	KOLAR 220 - PGCIL 1 & 2	KOLAR 220	21:02	21:30	0:28	MAIN SUPPLY FAILURE
813	29-Sep-19	BENGALURU	220	KOLAR 220 - RAILWAYS 1 & 2	RAILWAYS (EHT)	21:02	21:30	0:28	MAIN SUPPLY FAILURE
814	29-Sep-19	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	DRDO (EHT), MALLASANDRA, DALASANUR, YELDUR	21:02	21:32	0:30	MAIN SUPPLY FAILURE
815	29-Sep-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	21:02	21:35	0:33	MAIN SUPPLY FAILURE
816	29-Sep-19	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	21:02	21:45	0:43	MAIN SUPPLY FAILURE
817	29-Sep-19	BENGALURU	66	KOLAR 220 - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI, KEMBODI	21:02	21:32	0:30	MAIN SUPPLY FAILURE
818	29-Sep-19	BENGALURU	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	21:02	21:32	0:30	MAIN SUPPLY FAILURE
819	29-Sep-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	21:02	21:35	0:33	MAIN SUPPLY FAILURE
820	29-Sep-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	21:02	21:35	0:33	MAIN SUPPLY FAILURE
821	29-Sep-19	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	21:02	21:32	0:30	MAIN SUPPLY FAILURE
822	29-Sep-19	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	21:02	21:30	0:28	MAIN SUPPLY FAILURE
823	29-Sep-19	BENGALURU	220	KOLAR 220 - MALUR 1 & 3	MALUR 220	21:02	21:30	0:28	MAIN SUPPLY FAILURE
824	29-Sep-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	21:02	21:38	0:36	MAIN SUPPLY FAILURE
825	29-Sep-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	21:02	21:34	0:32	MAIN SUPPLY FAILURE
826	29-Sep-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, LAKKUR, DEVANAGONDHI	21:02	21:38	0:36	MAIN SUPPLY FAILURE
827	29-Sep-19	BENGALURU	66	MALUR 220 -MALUR 66	MALUR 66	21:02	21:33	0:31	MAIN SUPPLY FAILURE
828	29-Sep-19	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, BUDIKOTE, TEKAL, KAMASAMUDRA, KYASAMBALLI, DODDAKARI, ANDERSONPET, BEML (EHT)	21:02	21:37	0:35	MAIN SUPPLY FAILURE
829	29-Sep-19	BENGALURU	220	MALUR 220 - SARJAPURA 220	VIKAS TECH PARK 220, SARJAPURA 220	21:02	21:39	0:37	MAIN SUPPLY FAILURE
830	29-Sep-19	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	21:02	21:45	0:43	MAIN SUPPLY FAILURE
831	29-Sep-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	21:02	21:44	0:42	MAIN SUPPLY FAILURE
832	29-Sep-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	21:02	21:43	0:41	MAIN SUPPLY FAILURE
833	29-Sep-19	BENGALURU	66	KADUBIDANAHALLI - CESSNO TECH PARK	KADUBIDANAHALLI	10:25	10:30	0:05	LOAD CHANGEOVER
834	29-Sep-19	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	7:18	7:58	0:40	LINE FAULT
835	29-Sep-19	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	21:02	21:41	0:39	MAIN SUPPLY FAILURE
836	29-Sep-19	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	21:02	21:41	0:39	MAIN SUPPLY FAILURE
837	29-Sep-19	BENGALURU	66	HOODY 220 - ITI	ITI	21:02	21:18	0:16	LINE FAULT
838	29-Sep-19	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	21:02	21:16	0:14	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
839	29-Sep-19	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	8:51	8:55	0:03	LOAD CHANGEOVER
840	29-Sep-19	BENGALURU	66	HV1	BYADRAHALLI	8:37	8:50	0:12	LINE CLEAR AVAILED
841	29-Sep-19	BENGALURU	220	HV1	VIKAS TECH PARK 220	21:02	21:41	0:39	MAIN SUPPLY FAILURE
842	29-Sep-19	BENGALURU	220	HV2	VIKAS TECH PARK 220	21:02	21:41	0:39	MAIN SUPPLY FAILURE
843	29-Sep-19	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	5:50	6:21	0:31	LINE FAULT
844	29-Sep-19	GULBARGA	220	HV2	RAICHUR_220	14:40	14:51	0:11	TRANSFORMER FAULT
845	29-Sep-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	13:15	17:45	4:30	LINE FAULT
846	29-Sep-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	19:28	20:23	0:55	LINE CLEAR AVAILED
847	29-Sep-19	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110	19:18	19:25	0:07	LINE FAULT
848	29-Sep-19	GULBARGA	110	SINDHANOOR220-SIDHANOOR1	MASKI_110,MUDDAPUR_110	20:30	20:40	0:10	LINE FAULT
849	29-Sep-19	GULBARGA	110	RAICHUR-SIDHANOOR2	KURDICROSS_110,MANVI_110,MA DALAPUR_110	14:28	14:33	0:05	LINE FAULT
850	29-Sep-19	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	22:17	22:21	0:04	LINE FAULT
851	29-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	3:03	9:53	6:50	LINE FAULT
852	29-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	9:53	23:59	14:06	LINE CLEAR AVAILED
853	29-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	11:43	11:43	LINE CLEAR AVAILED
854	29-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:50	23:59	2:09	LINE CLEAR AVAILED
855	29-Sep-19	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	11:40	12:17	0:37	LOAD CURTAILMENT
856	29-Sep-19	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	11:40	12:52	1:12	LOAD CURTAILMENT
857	29-Sep-19	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	11:40	12:37	0:57	LOAD CURTAILMENT
858	29-Sep-19	HASSAN	110	HV6	KAVOOR_220	11:30	12:18	0:48	LOAD CURTAILMENT
859	29-Sep-19	HASSAN	110	HV5	KAVOOR_220	11:30	12:18	0:48	LOAD CURTAILMENT
860	29-Sep-19	HASSAN	110	HV7	KAVOOR_220	11:30	12:18	0:48	LOAD CURTAILMENT
861	29-Sep-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	11:30	12:23	0:53	LOAD CURTAILMENT
862	29-Sep-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	11:43	12:27	0:44	LOAD CURTAILMENT
863	29-Sep-19	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	11:46	12:18	0:32	LOAD CURTAILMENT
864	29-Sep-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	11:46	12:37	0:51	LOAD CURTAILMENT
865	29-Sep-19	HASSAN	220	KEMAR-UPCL1	KEMAR_220	11:30	12:13	0:43	LOAD CURTAILMENT
866	29-Sep-19	HASSAN	220	KEMAR-UPCL2	KEMAR_220	11:30	16:40	5:10	LOAD CURTAILMENT
867	29-Sep-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	11:30	12:15	0:45	LINE FAULT
868	29-Sep-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	11:30	22:09	10:39	LINE FAULT
869	29-Sep-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	11:30	12:52	1:22	LOAD CURTAILMENT
870	29-Sep-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	11:30	13:17	1:47	LOAD CURTAILMENT
871	29-Sep-19	HASSAN	110	KEAMR-Guruvykere2	KEMAR_220	11:30	12:58	1:28	LOAD CURTAILMENT
872	29-Sep-19	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	11:30	12:55	1:25	LOAD CURTAILMENT
873	29-Sep-19	HASSAN	110	HV1	KEMAR_220	11:30	13:06	1:36	LOAD CURTAILMENT
874	29-Sep-19	HASSAN	110	HV2	KEMAR_220	11:30	13:03	1:33	LOAD CURTAILMENT
875	29-Sep-19	HASSAN	110	KEMAR-Manipal1	KEMAR_220	11:30	12:39	1:09	LOAD CURTAILMENT
876	29-Sep-19	HASSAN	110	KEMAR-Manipal2	KEMAR_220	11:30	12:40	1:10	LOAD CURTAILMENT
877	29-Sep-19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	11:30	17:39	6:09	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
878	29-Sep-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	11:30	13:00	1:30	LOAD CURTAILMENT
879	29-Sep-19	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	11:30	12:36	1:06	LOAD CURTAILMENT
880	29-Sep-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	11:30	12:37	1:07	LOAD CURTAILMENT
881	29-Sep-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	11:30	12:24	0:54	LOAD CURTAILMENT
882	29-Sep-19	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	11:30	12:26	0:56	LOAD CURTAILMENT
883	29-Sep-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	11:40	12:37	0:57	LOAD CURTAILMENT
884	29-Sep-19	HASSAN	110	HV	PUTTUR_220	11:30	12:22	0:52	LOAD CURTAILMENT
885	29-Sep-19	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	11:32	12:23	0:51	LOAD CURTAILMENT
886	29-Sep-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	11:30	13:21	1:51	LOAD CURTAILMENT
887	29-Sep-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	13:21	13:35	0:14	LOAD CURTAILMENT
888	29-Sep-19	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	11:37	12:37	1:00	LOAD CURTAILMENT
889	29-Sep-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	11:30	12:13	0:43	LINE FAULT
890	29-Sep-19	HASSAN	220	UPCL-KEMAR2	upcl_gen	11:30	16:41	5:11	LINE FAULT
891	29-Sep-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	11:39	12:16	0:37	LINE FAULT
892	29-Sep-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	11:30	22:09	10:39	LINE FAULT
893	29-Sep-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	11:30	12:52	1:22	LINE FAULT
894	29-Sep-19	HASSAN	110	HV1	BAIKAMPADI_110	11:32	12:20	0:48	LOAD CURTAILMENT
895	29-Sep-19	HASSAN	110	HV2	BAIKAMPADI_110	11:32	12:20	0:48	LOAD CURTAILMENT
896	29-Sep-19	HASSAN	110	HV3	BAIKAMPADI_110	11:32	12:20	0:48	LOAD CURTAILMENT
897	29-Sep-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	11:32	13:00	1:28	LOAD CURTAILMENT
898	29-Sep-19	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	11:32	12:56	1:24	LOAD CURTAILMENT
899	29-Sep-19	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	11:32	12:55	1:23	LINE FAULT
900	29-Sep-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	11:32	12:56	1:24	LOAD CURTAILMENT
901	29-Sep-19	HASSAN	110	HV2	KONAJE_110	11:31	12:41	1:10	LOAD CURTAILMENT
902	29-Sep-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	11:31	12:41	1:10	LOAD CURTAILMENT
903	29-Sep-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	11:31	12:45	1:14	LOAD CURTAILMENT
904	29-Sep-19	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	11:31	12:46	1:15	LOAD CURTAILMENT
905	29-Sep-19	HASSAN	110	MANIPPAL-KEMAR1	MANIPAL_110	11:31	12:39	1:08	LOAD CURTAILMENT
906	29-Sep-19	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	11:30	13:05	1:35	LOAD CURTAILMENT
907	29-Sep-19	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	11:30	13:05	1:35	LOAD CURTAILMENT
908	29-Sep-19	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	11:30	13:02	1:32	LOAD CURTAILMENT
909	29-Sep-19	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	13:15	17:29	4:14	NFBC ISSUED
910	29-Sep-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	10:37	10:43	0:06	LINE FAULT
911	29-Sep-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	14:25	14:29	0:04	LINE FAULT
912	29-Sep-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:37	9:42	0:05	LINE FAULT
913	29-Sep-19	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	11:36	23:59	12:23	LINE CLEAR AVAILED
914	29-Sep-19	MYSORE	66	AC GIRI-TUBINAKERE	ADICHUNCHANAGIRI_66, VADERALLI_66	3:50	4:19	0:29	LINE FAULT
915	29-Sep-19	MYSORE	66	BG NAGARA-ANCHEPALYA	ADICHUNCHANAGIRI_66, VADERALLI_66	3:50	4:14	0:23	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
916	29-Sep-19	MYSORE	66	BILIKERE-GV GUDI	GVGUDI_66	5:52	5:59	0:06	LINE FAULT
917	29-Sep-19	MYSORE	66	HV1	DATTAGALLY_66	6:27	7:02	0:35	TRANSFORMER FAULT
918	29-Sep-19	MYSORE	66	HANNUR-KOTHANURU	KOTTANUR_66	0:12	0:19	0:06	LINE FAULT
919	29-Sep-19	MYSORE	66	HANNUR-MADHUVANAHALLI 1	BANDALLI_66, COWDALLI_66, HANNUR_66, MARTAHALLI_66, RAMAPURA_MYS_66	17:07	17:22	0:15	LINE FAULT
920	29-Sep-19	MYSORE	66	HANNUR-KOTHANURU	KOTTANUR_66	17:05	17:20	0:15	LINE FAULT
921	29-Sep-19	MYSORE	66	HV2	HULLAHALLI_66	17:17	17:53	0:35	LINE CLEAR AVAILED
922	29-Sep-19	MYSORE	66	MADHUVANAHALLI-HANNUR 2	BANDALLI_66, COWDALLI_66, HANNUR_66, MARTAHALLI_66, RAMAPURA_MYS_66	17:07	17:20	0:12	LINE FAULT
923	29-Sep-19	MYSORE	66	VAJAMANGALA-MEGHALAPURA	CHIDRAVALLI_66, MEGALAPURA_66, THUMBLA_66	7:19	7:51	0:31	LINE FAULT
924	29-Sep-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66, KIRUGAVALU_66, MALIYURU_66	14:01	14:22	0:21	LINE FAULT
925	29-Sep-19	TUMKUR	220	TR-3	HIRIYUR_220	2:12	8:45	6:32	TRANSFORMER FAULT
926	29-Sep-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	9:13	9:22	0:09	LINE FAULT
927	29-Sep-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	11:39	14:29	2:50	LINE FAULT
928	29-Sep-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	7:17	7:29	0:12	LINE FAULT
929	29-Sep-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	6:59	7:09	0:10	LINE FAULT
930	29-Sep-19	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	11:10	14:19	3:08	LINE CLEAR AVAILED
931	29-Sep-19	TUMKUR	66	NAGALAMADIKE-SUNDARRAJSOLAR_IPP_66	SUNDARRAJSOLAR_IPP_66	10:51	10:55	0:04	HAND TRIPPED
932	29-Sep-19	TUMKUR	66	NAGALAMADIKE-SUNDARRAJSOLAR_IPP_66	SUNDARRAJSOLAR_IPP_66	11:10	11:15	0:05	HAND TRIPPED
933	30-Sep-19	BAGALKOT	110	110/11KV,HV 2	BHUTANAL_110	10:14	10:25	0:11	HAND TRIPPED
934	30-Sep-19	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	13:23	19:55	6:32	LINE FAULT
935	30-Sep-19	BAGALKOT	110	BIDNAL-PH COMPOUND	PH COMPOUND_110	15:41	23:59	8:18	LINE FAULT
936	30-Sep-19	BAGALKOT	110	GAJENDRAGAD-RON 1	GAJENDRAGAD_110	2:24	3:04	0:40	HAND TRIPPED
937	30-Sep-19	BAGALKOT	110	GAJENDRAGAD-KUSHTAGI	GAJENDRAGAD_110	3:01	11:25	8:24	MAIN SUPPLY FAILURE
938	30-Sep-19	BAGALKOT	220	HAVERI-GUTTUR2	HAVERI_220	10:00	15:57	5:57	LINE CLEAR AVAILED
939	30-Sep-19	BAGALKOT	110	110/33KV,HV 3	GOKAK_110 & RIDDI-SIDDI,KOLAVI SUGARAS_33	12:46	13:04	0:18	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
940	30-Sep-19	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	6:54	7:04	0:10	LINE FAULT
941	30-Sep-19	BAGALKOT	110	110/11KV,HV 1	KHANAPUR_110	16:15	17:59	1:44	LINE CLEAR AVAILED
942	30-Sep-19	BAGALKOT	66	66/33KV,HV 4	HARIHAR_66 &CHICKEN FACTORY_33	18:53	19:01	0:08	LOAD CURTAILMENT
943	30-Sep-19	BAGALKOT	110	110/33KV, HV1	YARAGATTI_110, SHIVPUR_33, CHUNCHNOOR_33	17:00	17:13	0:13	LINE CLEAR AVAILED
944	30-Sep-19	BAGALKOT	110	110/11KV, HV2	UTTUR_110	16:31	16:37	0:06	TRANSFORMER FAULT
945	30-Sep-19	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	15:23	18:40	3:17	LINE CLEAR AVAILED
946	30-Sep-19	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	18:54	18:59	0:05	LOAD CURTAILMENT
947	30-Sep-19	BAGALKOT	110	110/11KV, HV2	SHIROL_110	20:27	20:34	0:07	TRANSFORMER FAULT
948	30-Sep-19	BAGALKOT	110	HIRA SUGAR2-SANKESHWAR	SANKESHWAR_110	11:05	11:09	0:04	LINE CLEAR AVAILED
949	30-Sep-19	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	7:05	11:37	4:32	LINE CLEAR AVAILED
950	30-Sep-19	BAGALKOT	220	HUBLI-NAGJHARI2	HUBLI_220	13:08	17:06	3:58	LINE FAULT
951	30-Sep-19	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	14:03	20:48	6:45	LINE FAULT
952	30-Sep-19	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	0:00	9:49	9:49	LINE CLEAR AVAILED
953	30-Sep-19	BAGALKOT	110	110/33KV, HV2	MATTIHAL_110, KOLAR WATER SUPPLY_33, KARJOL_33, NTPC_33	0:00	14:09	14:09	LINE CLEAR AVAILED
954	30-Sep-19	BAGALKOT	110	110/11KV, HV1	MAMDAPUR(B)_110	14:43	16:01	1:18	LINE CLEAR AVAILED
955	30-Sep-19	BAGALKOT	110	GAMESHA-KULIGOD	KULIGOD_110	9:51	17:34	7:43	LINE CLEAR AVAILED
956	30-Sep-19	BAGALKOT	110	PG HUNSHYAL-NAGNUR (MUDALGI)	NAGNUR_110, MUDALGI_110, KULIGOD_110	19:01	19:15	0:14	LINE FAULT
957	30-Sep-19	BAGALKOT	110	SATTI SUGARS-PG HUNSHYAL	PG HUNSHYAL_110	19:01	19:19	0:18	LINE FAULT
958	30-Sep-19	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHAPURA	2:04	2:08	0:04	LINE FAULT
959	30-Sep-19	BENGALURU	66	HV1	MITTEMARI 220	19:40	23:59	4:19	TRANSFORMER FAULT
960	30-Sep-19	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	18:10	19:04	0:54	LINE FAULT
961	30-Sep-19	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	11:33	11:39	0:05	LINE CLEAR AVAILED
962	30-Sep-19	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	11:23	13:04	1:41	LINE CLEAR AVAILED
963	30-Sep-19	BENGALURU	66	APPAREL PARK - KIADB DB PURA 220	APPAREL PARK	11:05	11:40	0:35	LINE CLEAR AVAILED
964	30-Sep-19	GULBARGA	220	HV1	KUSTAGI_220	2:00	4:06	2:06	TRANSFORMER FAULT
965	30-Sep-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	10:10	11:25	1:15	LINE FAULT
966	30-Sep-19	GULBARGA	220	HV1	KUSTAGI_220	10:10	11:30	1:20	TRANSFORMER FAULT
967	30-Sep-19	GULBARGA	220	KUSTAGI-LINGAPUR	LINGAPUR_220	11:05	11:20	0:15	LINE CLEAR AVAILED
968	30-Sep-19	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	0:00	19:56	19:56	LINE FAULT
969	30-Sep-19	GULBARGA	110	HV1	HANUMANAL_110	12:20	12:25	0:05	TRANSFORMER FAULT
970	30-Sep-19	GULBARGA	110	HV1,HV2,HV3	LINGASUGUR_220	18:54	19:04	0:10	LOAD CURTAILMENT
971	30-Sep-19	GULBARGA	110	HV1	DHADESUGUR_110	18:58	19:10	0:12	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
972	30-Sep-19	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	20:39	20:49	0:10	LINE FAULT
973	30-Sep-19	GULBARGA	110	HV1	SHAHPUR_220	14:41	15:00	0:19	TRANSFORMER FAULT
974	30-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	9:10	9:10	LINE CLEAR AVAILED
975	30-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	17:20	23:59	6:39	LINE CLEAR AVAILED
976	30-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	7:55	7:55	LINE CLEAR AVAILED
977	30-Sep-19	HASSAN	220	HV2	KADUR_220	11:01	12:41	1:40	LINE CLEAR AVAILED
978	30-Sep-19	HASSAN	220	MRSSHM-VARAHI1	MRSMSG_220	21:41	23:59	2:18	LINE FAULT
979	30-Sep-19	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	21:41	23:59	2:18	LINE FAULT
980	30-Sep-19	HASSAN	110	LV2	KADUR_220	11:01	12:41	1:40	LINE CLEAR AVAILED
981	30-Sep-19	HASSAN	110	HV1	BAIKAMPADI_110	23:04	23:59	0:55	TRANSFORMER FAULT
982	30-Sep-19	HASSAN	110	HV1	GURUVAYANAKERE_110	11:24	12:32	1:08	LINE CLEAR AVAILED
983	30-Sep-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	18:32	19:13	0:41	LOAD CURTAILMENT
984	30-Sep-19	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	18:32	19:01	0:29	LINE FAULT
985	30-Sep-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	18:29	19:10	0:41	LINE FAULT
986	30-Sep-19	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	18:29	18:57	0:28	LINE FAULT
987	30-Sep-19	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:18	13:43	3:25	NFBC ISSUED
988	30-Sep-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	11:07	15:22	4:15	LINE CLEAR AVAILED
989	30-Sep-19	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	0:00	19:31	19:31	LINE CLEAR AVAILED
990	30-Sep-19	HASSAN	66	HV2	HOLEHONNUR_66	10:26	12:04	1:38	LINE CLEAR AVAILED
991	30-Sep-19	HASSAN	66	HV1	SALAGAME_66	11:45	12:05	0:20	LOAD CURTAILMENT
992	30-Sep-19	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	11:43	12:00	0:17	HAND TRIPPED
993	30-Sep-19	MYSORE	66	HV1	DODDINADUVADI_66	15:14	15:36	0:22	LINE CLEAR AVAILED
994	30-Sep-19	MYSORE	66	HV2	DODDINADUVADI_66	11:00	14:25	3:25	LINE CLEAR AVAILED
995	30-Sep-19	MYSORE	66	HOOTAGALLY-DATTAGALLI	DATTAGALLY_66, RKNAGARA_66	5:56	6:05	0:09	LINE FAULT
996	30-Sep-19	MYSORE	66	JAKKANALLI-NAGAMANGLA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, NAGAMANGALA_66	21:05	21:13	0:08	LINE FAULT
997	30-Sep-19	MYSORE	220	KADAKOLA-HOOTAGALLY	N00 STATIONS	10:06	17:26	7:20	LINE CLEAR AVAILED
998	30-Sep-19	MYSORE	66	HV2	KIRUGAVALU_66	15:35	16:03	0:28	LINE CLEAR AVAILED
999	30-Sep-19	MYSORE	66	HV2	NAGAMANGALA_66	13:07	13:57	0:49	LINE CLEAR AVAILED
1000	30-Sep-19	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	8:17	9:39	1:21	LINE FAULT
1001	30-Sep-19	TUMKUR	66	TR-2	BELLAVI_66	11:25	16:11	4:45	LINE CLEAR AVAILED
1002	30-Sep-19	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	10:09	18:25	8:15	LINE CLEAR AVAILED
1003	30-Sep-19	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	17:16	20:04	2:48	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1004	30-Sep-19	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	1:35	1:51	0:16	LINE FAULT
1005	30-Sep-19	TUMKUR	66	HANAGAL- AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	12:15	12:21	0:05	LINE FAULT
1006	30-Sep-19	TUMKUR	66	TR-1	HANAGAL_66	12:26	19:01	6:35	LINE CLEAR AVAILED
1007	30-Sep-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	2:27	2:34	0:06	LINE FAULT
1008	30-Sep-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:06	8:18	0:12	LINE FAULT
1009	30-Sep-19	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,SOKK E_66	1:34	1:57	0:23	LINE FAULT