

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM: 18.05.21 TO 24.05.2021**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	18-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
2	18-May-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED ZALKI_110	17:30	18:40	1:10	LINE CLEAR AVOIDED
3	18-May-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YARGATTI_110	21:22	21:31	0:09	TRANSFORMER FAULT
4	18-May-2021	BAGALKOT	110	110/11KV,HV1	ARGA_110	10:22	11:10	0:48	LINE CLEAR AVOIDED
5	18-May-2021	BAGALKOT	110	110/11KV,HV1	MUDEBIHAL_110	11:16	11:41	0:25	LINE CLEAR AVOIDED
6	18-May-2021	BAGALKOT	110	110/11KV,HV2	THORVI_110	13:41	13:46	0:05	TRANSFORMER FAULT
7	18-May-2021	BAGALKOT	110	110/11KV,HV2	SATTI_110	22:53	23:18	0:25	LINE CLEAR AVOIDED
8	18-May-2021	BAGALKOT	110	110/33KV, HV3	HORTI_33KV STATION NOT AFFECTED ZALKI_110	12:32	13:09	0:37	HAND TRIPPED
9	18-May-2021	BAGALKOT	110	220/110KV,LV2	STATION NOT AFFECTED MK HUBLI_220	7:16 (16.05.2021)			LOAD CURTAILMENT
10	18-May-2021	BAGALKOT	110	ANKOLA-KUMTA2	STATION NOT AFFECTED ANKOLA_110	15:17	16:01	0:44	LINE FAULT
11	18-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVOIDED
12	18-May-2021	BAGALKOT	110	BAGEWADI- MAMADAPUR1	MAMADAPUR_110	6:27	6:47	0:20	LINE FAULT
13	18-May-2021	BAGALKOT	110	BAGEWADI- MAMADAPUR2	MAMADAPUR_110	6:27	6:47	0:20	LINE FAULT
14	18-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39(06.04.2021)			LINE OPEN, LINE CLEAR AVOIDED
15	18-May-2021	BAGALKOT	110	CHIKKODI- KADAKLAT(NIPPANI)	KADAKLAT_110	0:59	1:12	0:13	LINE FAULT
16	18-May-2021	BAGALKOT	110	HAVERI220-BYADAGI	STATION NOT AFFECTED HAVERI_220	12:59 (17.05.2021)	13:31 (18.05.2021)	24:32 hrs	LINE CHARGED
17	18-May-2021	BAGALKOT	110	HIREHAL-RON	RON_110	16:53	17:03	0:10	LINE FAULT
18	18-May-2021	BAGALKOT	110	HUBLI220-KADANAKOPPA	KADANAKOPPA_110	10:54	16:05	5:11	NFBC ISSUED
19	18-May-2021	BAGALKOT	110	KADANKOPPA- KAVALWADA	KADANKOPPA_110	6:39 (17.05.2021)			LINE OPEN,LINE FAULT
20	18-May-2021	BAGALKOT	110	KALAGATAGI- ASPL(KAVALWADA)	STATION NOT AFFECTED KALAGATAGI_110	19:31	21:50	2:19	LINE CLEAR AVOIDED
21	18-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
22	18-May-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
23	18-May-2021	BAGALKOT	110	RON-GAMESH	RON_110	17:08	17:34	0:26	HAND TRIPPED
24	18-May-2021	BAGALKOT	110	UTTUR-MUDHOL(ML PURA)	MUDHOL_110	11:51	11:59	0:08	LINE FAULT
25	18-May-2021	BAGALKOT	220	400/220KV,ICT2(LV)	DHONI_400	11:16	16:06	4:50	LINE CLEAR AVOIDED
26	18-May-2021	BAGALKOT	220	AMBEEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	20:24 (15.05.2021)	16:02 (18.05.2021)	67:38 hrs	LINE CHARGED
27	18-May-2021	BAGALKOT	220	AMBEEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	18:07 (18.05.2021)			LINE OPEN,LINE FAULT
28	18-May-2021	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM_220	18:06 (18.05.2021)			LOAD CURTAILMENT
29	18-May-2021	BAGALKOT	220	CHIKKODI- MUGALKOD1(BELGAUM1)	STATION NOT AFFECTED CHIKKODI_220	19:15 (17.05.2021)			LINE OPEN, LINE CLEAR AVOIDED
30	18-May-2021	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	20:47 (18.05.2021)			LINE OPEN, LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
31	18-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
32	18-May-2021	BAGALKOT	220	MUGALKHOD-CHIKKODI1	STATION NOT AFFECTED MUGALKHOD_220	19:16 (17.05.2021)	16:0 (18.05.2021)	20:44 hrs	LINE CHARGED
33	18-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
34	18-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN, LINE CLEAR AVAILED
35	18-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN, LINE CLEAR AVAILED
36	18-May-2021	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	20:47 (18.05.2021)			LINE OPEN,LINE FAULT
37	18-May-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17(23.02.2021)			LINE OPEN,LINE FAULT
38	18-May-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07(24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
39	18-May-2021	BAGALKOT	400	400/220KV,ICT2(HV)	DHONI_400	11:15	15:56	4:41	LINE CLEAR AVAILED
40	18-May-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	16:03	16:08	0:05	LINE FAULT
41	18-May-2021	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	16:00	16:07	0:07	LINE FAULT
42	18-May-2021	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	15:04	15:13	0:09	LINE FAULT
43	18-May-2021	BENGALURU	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	20:10	20:15	0:05	LINE FAULT
44	18-May-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:26	10:48	0:22	LINE FAULT
45	18-May-2021	BENGALURU	66	WELCAST STEEL - DG 3	WELCAST STEEL	17:42	17:47	0:05	LOAD CHANGE OVER
46	18-May-2021	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	15:05	15:09	0:04	LOAD CHANGE OVER
47	18-May-2021	GULBARGA	66	HV1	KUDLIGI_66	9:45	16:20	6:35	LINE CLEAR AVAILED
48	18-May-2021	GULBARGA	66	HV1	KUDLIGI_66	1:35	4:40	3:05	TRANSFORMER FAULT
49	18-May-2021	GULBARGA	66	HV2	KUDLIGI_66	11:05	16:50	5:45	LINE CLEAR AVAILED
50	18-May-2021	GULBARGA	66	HV3	KUDLIGI_66	12:50	13:10	0:20	LINE CLEAR AVAILED
51	18-May-2021	GULBARGA	66	HV3	KUDLIGI_66	14:15	14:20	0:05	TRANSFORMER FAULT
52	18-May-2021	GULBARGA	110	HV1	KOTTUR_66	18:00	18:05	0:05	TRANSFORMER FAULT
53	18-May-2021	GULBARGA	110	HV1	NIRNA_110	17:29	17:40	0:11	LINE CLEAR AVAILED
54	18-May-2021	GULBARGA	110	HV1 & HV2	YELBURGA_110	13:10	17:13	4:03	LINE CLEAR AVAILED
55	18-May-2021	GULBARGA	110	HV2	SHAHAPUR_220	19:13	19:27	0:14	TRANSFORMER FAULT
56	18-May-2021	GULBARGA	110	HV2	SHAHAPUR_220	20:16	20:24	0:08	TRANSFORMER FAULT
57	18-May-2021	GULBARGA	110	HV2	HANUMASAGAR_110	9:30	10:50	1:20	LINE CLEAR AVAILED
58	18-May-2021	GULBARGA	110	KAPNOOR-GULBARGANORTH1	GULBARGANORTH_110,GULBARGASOUTH_110,GULBARGAUNIVERSITY_110	20:28	23:15	2:47	LINE FAULT
59	18-May-2021	GULBARGA	110	KAPNOOR-GULBARGANORTH2	GULBARGANORTH_110,GULBARGASOUTH_110,GULBARGAUNIVERSITY_110	20:28	21:09	0:41	LINE FAULT
60	18-May-2021	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	2:00	2:20	0:20	MAIN SUPPLY FAILURE
61	18-May-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	4:11	4:17	0:06	LINE FAULT
62	18-May-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	5:22	5:30	0:08	LINE FAULT
63	18-May-2021	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110,DHADESUGAR_110,TEKKALKOTE_110,NSLSUGAR_IPP	23:57(17.05.2021)	00:07(18.05.2021)	0:10	LINE FAULT
64	18-May-2021	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110,DHADESUGAR_110,TEKKALKOTE_110,NSLSUGAR_IPP	0:07	0:27	0:20	LINE FAULT
65	18-May-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400(STATION NOT AFFECTED)	22:04(15.05.2021)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
66	18-May-2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400(STATION NOT AFFECTED)	2:55(16.05.2021)			LINE OPEN,LINE FAULT
67	18-May-2021	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	11:04	11:29	0:25	LINE FAULT
68	18-May-2021	HASSAN	66	HV1	CHIKMAGALUR_66	20:24(18.5.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
69	18-May-2021	HASSAN	66	HV1	CHIKMAGALUR_66	15:13	20:20	5:07	LINE CLEAR AVAILED
70	18-May-2021	HASSAN	66	HV1	DODDAMAGGE_66	6:49	7:29	0:40	TRANSFORMER FAULT
71	18-May-2021	HASSAN	66	HV1	DUDDA_66	9:32	9:43	0:11	TRANSFORMER FAULT
72	18-May-2021	HASSAN	66	HV1	HALLIMYSORE_66	9:15	9:28	0:13	HAND TRIPPED
73	18-May-2021	HASSAN	66	HV1	MOSALEHOSAHALLI_66	16:13	16:42	0:29	TRANSFORMER FAULT
74	18-May-2021	HASSAN	66	HV1	SHRAVANABELAGOLA_66	15:58	16:23	0:25	TRANSFORMER FAULT
75	18-May-2021	HASSAN	66	HV2	HALLIMYSORE_66	9:15	9:29	0:14	HAND TRIPPED
76	18-May-2021	HASSAN	66	HV2	SALAGAME_66	11:28	12:08	0:40	TRANSFORMER FAULT
77	18-May-2021	HASSAN	66	HV2	RAMNATHPURA_66	14:17	16:39	2:22	TRANSFORMER FAULT
78	18-May-2021	HASSAN	66	HV2	RAMNATHPURA_66	17:03	18:27	1:24	LINE CLEAR AVAILED
79	18-May-2021	HASSAN	110	HOSNGD-HULIKAL	HOSANGADI_110	13:39	14:13	0:34	LINE FAULT
80	18-May-2021	HASSAN	110	HV1	ARASIKERE_220	10:33	10:55	0:22	TRANSFORMER FAULT
81	18-May-2021	HASSAN	110	HV1	GURUPURA_110	12:47	13:49	1:02	LINE CLEAR AVAILED
82	18-May-2021	HASSAN	110	HV2	NANDIKUR_110	13:40	13:45	0:05	TRANSFORMER FAULT
83	18-May-2021	HASSAN	110	HV2	NANDIKUR_110	13:45	15:30	1:45	LINE CLEAR AVAILED
84	18-May-2021	HASSAN	110	KEMAR-Manipal1	KEMAR_220	16:41	18:09	1:28	NFBC ISSUED
85	18-May-2021	HASSAN	110	KEMAR-UPCL1	KEMAR_220	11:02	14:15	3:13	LINE CLEAR AVAILED
86	18-May-2021	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	16:41	18:09	1:28	NFBC ISSUED
87	18-May-2021	HASSAN	220	HGUNJE-VM3	HEGGUNJE_220	13:39	14:20	0:41	LINE FAULT
88	18-May-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	13:11	14:31	1:20	LINE FAULT
89	18-May-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	14:31	18:03	3:32	LINE FAULT
90	18-May-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	13:37	18:29	4:52	LINE FAULT
91	18-May-2021	HASSAN	220	MRSSTM-VARAH1	MRSMSG_220	13:36	18:20	4:44	LINE FAULT
92	18-May-2021	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	15:28	16:15	0:47	LINE CLEAR AVAILED
93	18-May-2021	HASSAN	220	TALAGU-SGS1	TALAGUPP_400	15:28	16:15	0:47	LINE CLEAR AVAILED
94	18-May-2021	HASSAN	220	UPCL-KEMAR1	upcl_gen	11:03	14:16	3:13	NFBC ISSUED
95	18-May-2021	HASSAN	220	VARAH1-KEMAR1	varahi_gen	13:11	18:04	4:53	LINE FAULT
96	18-May-2021	HASSAN	220	VARAH1-KEMAR2	varahi_gen	13:11	13:26	0:15	LINE FAULT
97	18-May-2021	HASSAN	220	VARAH1-KEMAR2	varahi_gen	13:36	18:29	4:53	LINE FAULT
98	18-May-2021	HASSAN	220	VARAH1-KEMAR3	varahi_gen	13:39	14:20	0:41	LINE FAULT
99	18-May-2021	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	13:36	18:20	4:44	LINE FAULT
100	18-May-2021	MYSURU	66	BYLUKUPPE-KUSHALANAGARA	BYLUKUPPE_66	14:53	15:30	0:36	LINE FAULT
101	18-May-2021	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	12:20	12:27	0:06	LINE FAULT
102	18-May-2021	MYSURU	66	HV1	SHIVALLY_66	9:00	9:23	0:22	LINE CLEAR AVAILED
103	18-May-2021	MYSURU	66	HV2	RKNAGARA_66	16:03	19:44	3:41	LINE CLEAR AVAILED
104	18-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN, LINE CLEAR AVAILED
105	18-May-2021	MYSURU	66	SFC SHIVA-10 MW	NO STATIONS EFFECTED	12:25	12:30	0:05	LINE FAULT
106	18-May-2021	MYSURU	66	SFC SHIVA-5 MW	NO STATIONS EFFECTED	12:25	12:30	0:05	LINE FAULT
107	18-May-2021	MYSURU	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	17:16	17:26	0:10	LINE FAULT
108	18-May-2021	MYSURU	66	TUBINAKERE-G UKKADA	GARUDANAUKADDA_66 SRIRANGAPATNA_66	17:16	17:26	0:09	HAND TRIPPED
109	18-May-2021	MYSURU	66	TUBINAKERE-MC2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66	5:44	5:52	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
110	18-May-2021	MYSURU	66	TUBINAKERE-MC4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66	5:44	5:52	0:08	LINE FAULT
111	18-May-2021	MYSURU	66	TUBINAKERE- NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	17:16	17:26	0:09	HAND TRIPPED
112	18-May-2021	MYSURU	66	TUBINAKERE- NAGAMANGALA 2	SHIVALLY_66	17:16	17:26	0:09	HAND TRIPPED
113	18-May-2021	MYSURU	66	TUBINAKERE- PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	17:16	17:26	0:09	HAND TRIPPED
114	18-May-2021	MYSURU	220	CR NAGARA- MADHUVANALLY 2	NO STATIONS EFFECTED	13:04	13:30	0:26	LINE FAULT
115	18-May-2021	MYSURU	220	CR NAGARA- MADHUVANALLY 2	NO STATIONS EFFECTED	13:31	14:55	1:24	LINE FAULT
116	18-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN, LINE CLEAR AVAILED
117	18-May-2021	TUMKUR	66	BASAVAPATNA-VESTAS- WIND IPP_66	VESTAS-WIND_IPP_66	14:27	15:10	0:42	LINE FAULT
118	18-May-2021	TUMKUR	66	CHITRADURGA 220KV- CHALLAKERE	CHALLAKERE_66, SANIKERE_66,BALENAHALLI_66	18:46	19:26	0:39	HAND TRIPPED
119	18-May-2021	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66,KADAJJI_66,MELEKA TTE_66	14:16	19:21	5:04	LINE FAULT
120	18-May-2021	TUMKUR	66	HONNALLI 220KV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	11:48	11:55	0:07	LINE FAULT
121	18-May-2021	TUMKUR	66	HONNALLI 220KV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	14:27	14:42	0:14	LINE FAULT
122	18-May-2021	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	8:57	9:07	0:10	LINE FAULT
123	18-May-2021	TUMKUR	66	TR-1	CHALLAKERE_66	17:30	17:40	0:10	TRANSFORMER FAULT
124	18-May-2021	TUMKUR	66	TR-1	CHANNAGIRI_66	8:34	8:38	0:03	TRANSFORMER FAULT
125	18-May-2021	TUMKUR	66	TR-1	CHIKKABANAGERE_66	13:31	14:11	0:39	TRANSFORMER FAULT
126	18-May-2021	TUMKUR	66	TR-1	DYAVARANAHALLI_66	5:16	5:31	0:14	TRANSFORMER FAULT
127	18-May-2021	TUMKUR	66	TR-1	THIMMASANDRA_66	11:19	11:39	0:20	LINE CLEAR AVAILED
128	18-May-2021	TUMKUR	66	TR-2	GUTTUR_66	16:23	18:49	2:26	TRANSFORMER FAULT
129	18-May-2021	TUMKUR	66	TR-2	THIMMASANDRA_66	10:52	11:39	0:46	LINE CLEAR AVAILED
130	18-May-2021	TUMKUR	66	TR-2	URDIGERE_66	15:56	16:45	0:49	MAIN SUPPLY FAILURE
131	18-May-2021	TUMKUR	66	TR-3	HARIYABBE_66	17:40	17:47	0:06	TRANSFORMER FAULT
132	18-May-2021	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	17:06	17:18	0:11	TRANSFORMER FAULT
133	18-May-2021	TUMKUR	66	UCHANGIDURGA- I/C220SRSDAVANG(NEELA GUNDA)	UCHCHANGIDURGA_66	3:05	3:15	0:10	LINE FAULT
134	18-May-2021	TUMKUR	66	URDIGERE- ANTHRASANAHALLI	URDIGERE_66	15:53	16:44	0:50	MAIN SUPPLY FAILURE
135	18-May-2021	TUMKUR	66	URDIGERE- ANTHRASANAHALLI	URDIGERE_66	17:06	20:59	3:53	LINE CLEAR AVAILED
136	18-May-2021	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	15:53	16:48	0:54	MAIN SUPPLY FAILURE
137	18-May-2021	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	17:20	17:34	0:14	HAND TRIPPED
138	18-May-2021	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	20:50	21:01	0:10	LINE CLEAR AVAILED
139	18-May-2021	TUMKUR	110	HONNAVALLI 110- KADUR110(ARASIKERE)	HONNAVALLI_110	12:29	12:41	0:12	HAND TRIPPED
140	18-May-2021	TUMKUR	220	TR-3(HV SIDE)	CHITRADURGA_220	17:06	17:16	0:09	TRANSFORMER FAULT
141	19-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
142	19-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_ 66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVOID
143	19-May-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
144	19-May-2021	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_ 220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOID
145	19-May-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_ 220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOID
146	19-May-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_ 220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
147	19-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_ 220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
148	19-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_ 110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVOID
149	19-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_ 110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVOID
150	19-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_ 220	15:17 (15.05.2021)			LINE OPEN, LINE CLEAR AVOID
151	19-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_ 220	15:17 (15.05.2021)			LINE OPEN, LINE CLEAR AVOID
152	19-May-2021	BAGALKOT	110	220/110KV,LV2	STATION NOT AFFECTED MK HUBLI_ 220	7:16 (16.05.2021)	19:05 (19.05.2021)	83:49HRS	TRANSFORMER CHARGED
153	19-May-2021	BAGALKOT	220	CHIKKODI- MUGALKOD1(BELGAUM1)	STATION NOT AFFECTED CHIKKODI_220	19:15 (17.05.2021)	16:08 (19.05.2021)	44:53HRS	LINE CHARGED
154	19-May-2021	BAGALKOT	110	KADANKOPPA- KAVALWADA	KADANKOPPA_110	6:39 (17.05.2021)			LINE OPEN,LINE FAULT
155	19-May-2021	BAGALKOT	220	AMBEEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_ 220	18:07 (18.05.2021)			LINE OPEN,LINE FAULT
156	19-May-2021	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM_ 220	18:06 (18.05.2021)	0:21 (19.05.2021)	6:15HRS	LINE CHARGED
157	19-May-2021	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_ 220	20:47 (18.05.2021)	15:55 (19.05.2021)	19:08HRS	LINE CHARGED
158	19-May-2021	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_ 220	20:47 (18.05.2021)	15:55 (19.05.2021)	19:08HRS	LINE CHARGED
159	19-May-2021	BAGALKOT	110	110/11KV,HV1	ANAND NAGAR_110	12:43	13:55	1:12	LINE CLEAR AVOID
160	19-May-2021	BAGALKOT	110	110/11KV,HV2	AREMALLAPUR_110	13:40	15:04	1:24	LINE CLEAR AVOID
161	19-May-2021	BAGALKOT	220	BIDNAL-HUBLI1	STATION NOT AFFECTED BIDNAL_ 220	10:07	14:10	4:03	NFBC ISSUED
162	19-May-2021	BAGALKOT	110	HIREHAL-RON	RON_110	17:01	17:08	0:07	LINE FAULT
163	19-May-2021	BAGALKOT	110	KULIGOD-GAMESH	KULIGOD_110	7:05	7:12	0:07	HAND TRIPPED
164	19-May-2021	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110,ALNAVAR_33	19:15	19:19	0:04	TRANSFORMER FAULT
165	19-May-2021	BAGALKOT	110	110/11KV,HV1	MANTRUR(G)_110	15:58	17:35	1:37	LINE CLEAR AVOID
166	19-May-2021	BAGALKOT	110	110/11KV,HV2	MANTRUR(G)_110	16:00	17:36	1:36	LINE CLEAR AVOID
167	19-May-2021	BAGALKOT	110	110/11KV,HV2(HV1)	MUDEBIHAL_110	8:23	8:27	0:04	TRANSFORMER FAULT
168	19-May-2021	BAGALKOT	110	110/11KV,HV2(HV1)	MUDEBIHAL_110	9:36	9:42	0:06	TRANSFORMER FAULT
169	19-May-2021	BAGALKOT	110	110/11KV,HV1(HV2)	MUDEBIHAL_110	11:44	12:09	0:25	LINE CLEAR AVOID
170	19-May-2021	BAGALKOT	110	MUDEBIHAL-KNM SOLAR	STATION NOT AFFECTED MUDEBIHAL_ 110	15:47	16:54	1:07	LINE FAULT
171	19-May-2021	BAGALKOT	110	P G HUNSHYAL- (MUDALAGI)NAGANUR	NAGANUR_110	6:45	7:01	0:16	LINE FAULT
172	19-May-2021	BAGALKOT	110	110/11KV,HV2	SATTI_110	10:41	11:19	0:38	LINE CLEAR AVOID
173	19-May-2021	BAGALKOT	220	220/110KV,HV1,LV1	NARENDRA_ 220	11:31	16:43	5:12	LINE CLEAR AVOID
174	19-May-2021	BAGALKOT	110	BAGEWADI- MAMADAPUR1&2	MAMADAPUR_110	6:35	6:46	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
175	19-May-2021	BAGALKOT	110	RON-GAJENDRAGAD1&2	STATION NOT AFFECTED RON_110	17:17	18:19	1:02	LINE CLEAR AVAILED
176	19-May-2021	BAGALKOT	110	RON-GAJENDRAGAD1&2	STATION NOT AFFECTED RON_110	19:02	19:17	0:15	HAND TRIPPED
177	19-May-2021	BAGALKOT	110	RON-GAMESH	STATION NOT AFFECTED RON_110	17:17	17:19	0:02	HAND TRIPPED
178	19-May-2021	BAGALKOT	110	RON-GAMESH	STATION NOT AFFECTED RON_110	19:02	19:04	0:02	HAND TRIPPED
179	19-May-2021	BAGALKOT	110	110/33KV, HV4	DULKHED_33, NEVARGI_33, HALASANGI_33 STATION NOT AFFECTED ZALKI_110	9:45	9:48	0:03	TRANSFORMER FAULT
180	19-May-2021	BAGALKOT	110	VAJJRAMATTI220-KATARKI	KATARKI_110	4:16	4:25	0:09	LINE FAULT
181	19-May-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TADASINAKOPPA_110	20:02	21:07	1:05	LINE CLEAR AVAILED
182	19-May-2021	BAGALKOT	220	HUBLI-BIDNAL1	STATION NOT AFFECTED HUBLI_220	10:44	14:10	3:26	LINE CLEAR AVAILED
183	19-May-2021	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	11:26	15:53	4:27	LINE CLEAR AVAILED
184	19-May-2021	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	11:25	15:53	4:28	LINE CLEAR AVAILED
185	19-May-2021	BAGALKOT	220	220/110KV, HV	STATION NOT AFFECTED SIRSI_220	11:25	16:01	4:36	LINE CLEAR AVAILED
186	19-May-2021	BAGALKOT	220	110/11KV, HV1	STATION NOT AFFECTED SIRSI_220	12:58	14:53	1:55	LINE CLEAR AVAILED
187	19-May-2021	BAGALKOT	110	SIRSI-JOG2	STATION NOT AFFECTED SIRSI_110	15:05	20:01	4:56	LINE CLEAR AVAILED
188	19-May-2021	BAGALKOT	110	SIRSI- SIDDAPUR (JOG1)	STATION NOT AFFECTED SIRSI_110	15:19	15:22	0:03	HAND TRIPPED
189	19-May-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SIRSI_110	16:39	16:43	0:04	TRANSFORMER FAULT
190	19-May-2021	BAGALKOT	110	110/33KV, HV3	KALKERI_33, GOLGERI_33, MYTRA SOLAR_33 STATION NOT AFFECTED SINDAGI_110	13:17	15:09	1:52	LINE CLEAR AVAILED
191	19-May-2021	BAGALKOT	400	DHONI-GUTTUR	STATION NOT AFFECTED DHONI_400	10:35	17:35	7:00	LINE CLEAR AVAILED
192	19-May-2021	BENGALURU	220	LV2	ITI 220	10:10	10:14	0:04	TRANSFORMER FAULT
193	19-May-2021	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	9:21	10:10	0:49	LINE FAULT
194	19-May-2021	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	10:10	14:50	4:40	LINE FAULT
195	19-May-2021	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	10:10	10:36	0:26	MAIN SUPPLY FAILURE
196	19-May-2021	BENGALURU	66	ITI 220 - ITI 66	ITI 66	10:10	10:35	0:25	MAIN SUPPLY FAILURE
197	19-May-2021	BENGALURU	66	ITI 220 - BAGHMANE WORLD TECH PARK	BAGHMANE WORLD TECH PARK	10:10	10:38	0:28	MAIN SUPPLY FAILURE
198	19-May-2021	BENGALURU	66	ITI 220 - NGEF	NGEF,NGEF(EHT)	10:10	10:38	0:28	MAIN SUPPLY FAILURE
199	19-May-2021	BENGALURU	66	HV2	BANASAWADI	10:10	10:35	0:25	MAIN SUPPLY FAILURE
200	19-May-2021	BENGALURU	66	SRS PEENYA 220 - DG1	NO STATION AFFECTED	17:53	20:19	2:26	LINE FAULT
201	19-May-2021	BENGALURU	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	6:56	11:30	4:34	LINE FAULT
202	19-May-2021	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	18:34	18:58	0:24	LINE FAULT
203	19-May-2021	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	11:42	11:48	0:06	LOAD CHANGE OVER
204	19-May-2021	BENGALURU	66	HV2	REMC0	21:11	21:15	0:04	LOAD CHANGE OVER
205	19-May-2021	BENGALURU	66	HV3	HEBBALA 220	15:59	16:36	0:37	LINE CLEAR AVAILED
206	19-May-2021	BENGALURU	66	HV2	HEBBALA 220	16:45	17:28	0:43	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
207	19-May-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	21:06	21:12	0:06	LOAD CHANGE OVER
208	19-May-2021	BENGALURU	66	T K HALLI 220 - SIMSHA	T K HALLI 220	15:35	15:55	0:20	LINE FAULT
209	19-May-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	20:13	20:16	0:03	LINE CLEAR AVAILED
210	19-May-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	20:13	20:16	0:03	LINE CLEAR AVAILED
211	19-May-2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	20:13	20:16	0:03	LINE CLEAR AVAILED
212	19-May-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	7:10	7:24	0:14	LINE FAULT
213	19-May-2021	BENGALURU	66	SOMENAHALLI - PERESANDRA	PERESANDRA	11:00	12:04	1:04	LINE CLEAR AVAILED
214	19-May-2021	BENGALURU	66	HV1	SOMENAHALLI	12:10	13:00	0:50	LINE CLEAR AVAILED
215	19-May-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	15:21	15:41	0:20	LINE FAULT
216	19-May-2021	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	13:15	15:13	1:58	LINE CLEAR AVAILED
217	19-May-2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI	11:47	11:53	0:06	LINE FAULT
218	19-May-2021	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	18:31	18:37	0:06	LINE FAULT
219	19-May-2021	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	23:40	23:45	0:05	LINE FAULT
220	19-May-2021	BENGALURU	66	HV2	MANCHENAHALLI	19:14	19:30	0:16	TRANSFORMER FAULT
221	19-May-2021	BENGALURU	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR, SIRIGEREPURA	22:42	23:15	0:33	LINE FAULT
222	19-May-2021	BENGALURU	66	HULLENAHALLI - KUDUR	KUDUR, SIRIGEREPURA	22:42	23:38	0:56	LINE FAULT
223	19-May-2021	BENGALURU	66	HV1	HULLENAHALLI	22:42	23:15	0:33	TRANSFORMER FAULT
224	19-May-2021	BENGALURU	66	HV2	HULLENAHALLI	22:42 (19 MAY 2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
225	19-May-2021	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	17:37 (19-05-2021)			LINE OPEN, LINE FAULT
226	19-May-2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400	2:55(16.05.2021)			LINE OPEN, LINE FAULT
227	19-May-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:04(15.05.2021)			LINE OPEN, LINE FAULT
228	19-May-2021	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	12:58	14:40	1:42	NFBC ISSUED
229	19-May-2021	GULBARGA	220	BTPS-LINGAPUR	BTPS_220	11:24	14:21	2:57	LINE CLEAR AVAILED
230	19-May-2021	GULBARGA	220	LINGAPUR-KUSHTAGI	LINGAPUR_220	9:05	13:09	4:04	LINE CLEAR AVAILED
231	19-May-2021	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	20:18(19.05.2021)			LINE OPEN, LINE CLEAR AVAILED
232	19-May-2021	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	19:16	19:32	0:16	LINE FAULT
233	19-May-2021	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGAON_110, MARAGUTTI_110	6:56	7:04	0:08	LINE FAULT
234	19-May-2021	GULBARGA	110	SINDHNOOR-RAICHUR2	KURDICROSS_110, MADALAPUR_110, MANVI_110	3:58	4:14	0:16	LINE FAULT
235	19-May-2021	GULBARGA	110	SINDHNOOR-SINDHNOOR1	SINDHANOOR_110	4:23	4:33	0:10	LINE FAULT
236	19-May-2021	GULBARGA	110	SINDHNOOR-RAICHUR2	KURDICROSS_110, MADALAPUR_110, MANVI_110	5:06	5:20	0:14	LINE FAULT
237	19-May-2021	GULBARGA	110	HV2	SHAHAPUR_220	10:56	11:37	0:41	TRANSFORMER FAULT
238	19-May-2021	GULBARGA	110	HV2	SHAHAPUR_220	12:05	12:11	0:06	TRANSFORMER FAULT
239	19-May-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110, UGARSUGAR_IPP	19:02	19:19	0:17	LINE FAULT
240	19-May-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	19:02	19:27	0:25	LINE FAULT
241	19-May-2021	GULBARGA	110	KAPNOOR-MARGUTTI	MAHAGAON_110, MARAGUTTI_110	6:55	7:05	0:10	LINE FAULT
242	19-May-2021	GULBARGA	110	HUMNABAD-MARGUTTI	MAHAGAON_110, MARAGUTTI_110	6:55	12:21	5:26	LINE FAULT
243	19-May-2021	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110	18:55	19:05	0:10	LINE FAULT
244	19-May-2021	GULBARGA	110	HV2	MANVI_110	10:55	12:15	1:20	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
245	19-May-2021	GULBARGA	110	GUTTHALA1-MYLAR	MYLAR_110	12:05	12:15	0:10	LINE CLEAR AVAILED
246	19-May-2021	GULBARGA	110	SINDHNOOR-BENNUR	BENNUR_110	5:00	5:05	0:05	MAIN SUPPLY FAILURE
247	19-May-2021	GULBARGA	110	HV1	BENNUR_110	18:50	19:05	0:15	TRANSFORMER FAULT
248	19-May-2021	GULBARGA	110	HV1	KAMPLI_110	11:00	11:55	0:55	LINE CLEAR AVAILED
249	19-May-2021	GULBARGA	110	HV1	KADAGANCHI_110	10:30	10:35	0:05	TRANSFORMER FAULT
250	19-May-2021	GULBARGA	110	HV2	SHAHTINAGAR_110	10:21	11:52	1:31	LINE CLEAR AVAILED
251	19-May-2021	GULBARGA	66	ITTAGI-HANASI	HANASI_66	17:00	17:15	0:15	LINE FAULT
252	19-May-2021	GULBARGA	66	HV1	KUDLIGI_66	11:40	12:00	0:20	LINE CLEAR AVAILED
253	19-May-2021	HASSAN	110	HV2	PUTTUR_110	9:34(15.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
254	19-May-2021	HASSAN	66	HV1	CHIKMAGALUR_66	20:24(18.5.2021)	18:24(19.5.2021)	21:59 hrs	TRANSFORMER CHARGED
255	19-May-2021	HASSAN	220	UPCL-KEMAR1	upcl_gen	10:39	14:51	4:12	NFBC ISSUED
256	19-May-2021	HASSAN	110	HV1	NITTUR_110	11:05	11:31	0:26	TRANSFORMER FAULT
257	19-May-2021	HASSAN	110	HV1	NITTUR_110	12:28	13:55	1:27	TRANSFORMER FAULT
258	19-May-2021	HASSAN	110	HV1	NITTUR_110	14:08	16:10	2:02	TRANSFORMER FAULT
259	19-May-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	13:01	13:47	0:46	LINE FAULT
260	19-May-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	13:01	13:39	0:38	LINE FAULT
261	19-May-2021	HASSAN	220	KEMAR-UPCL1	KEMAR_220	10:39	14:51	4:12	LINE CLEAR AVAILED
262	19-May-2021	HASSAN	110	JOG-JLT3	mghejog_gen	15:19	15:27	0:08	LINE FAULT
263	19-May-2021	HASSAN	110	JOG-JLT4	mghejog_gen	15:19	15:26	0:07	LINE FAULT
264	19-May-2021	HASSAN	110	JOG-JST1	mghejog_gen	15:19	15:23	0:04	LINE FAULT
265	19-May-2021	HASSAN	110	JOG-JST2	mghejog_gen	15:19	15:28	0:09	LINE FAULT
266	19-May-2021	HASSAN	110	HV3	KAVOOR_220	12:01	13:37	1:36	LINE CLEAR AVAILED
267	19-May-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	13:02	13:46	0:44	LINE FAULT
268	19-May-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	13:02	13:39	0:37	LINE FAULT
269	19-May-2021	HASSAN	110	HV1	MANIPAL_110	10:46	11:11	0:25	LINE CLEAR AVAILED
270	19-May-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	14:15	14:50	0:35	LINE FAULT
271	19-May-2021	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	12:17	14:42	2:25	NFBC ISSUED
272	19-May-2021	HASSAN	66	HV1	DUDDA_66	8:38	8:50	0:12	TRANSFORMER FAULT
273	19-May-2021	HASSAN	66	HV2	HALLIMYSORE_66	7:28	7:42	0:14	MAIN SUPPLY FAILURE
274	19-May-2021	HASSAN	66	HALLYM-MYSOR1	HOLENARASIPURA_220	7:28	7:38	0:10	LINE FAULT
275	19-May-2021	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	11:25	12:15	0:50	LINE CLEAR AVAILED
276	19-May-2021	HASSAN	66	HV1	MAGGE_66	11:25	12:18	0:53	MAIN SUPPLY FAILURE
277	19-May-2021	HASSAN	66	HV2	MAGGE_66	11:25	12:18	0:53	MAIN SUPPLY FAILURE
278	19-May-2021	HASSAN	66	HV2	RAMNATHPURA_66	9:39	13:49	4:10	LINE CLEAR AVAILED
279	19-May-2021	HASSAN	66	HV2	RAMNATHPURA_66	14:00	14:27	0:27	LINE CLEAR AVAILED
280	19-May-2021	HASSAN	66	SAKALE-HASSAN1	SAKLESHPURA_66	11:25	12:16	0:51	NFBC ISSUED
281	19-May-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	11:21	16:19	4:58	LINE CLEAR AVAILED
282	19-May-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	11:21	16:19	4:58	LINE CLEAR AVAILED
283	19-May-2021	HASSAN	66	HV1	SINGAPURA_66	13:34	15:31	1:57	LINE CLEAR AVAILED
284	19-May-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	17:36	17:53	0:17	LINE FAULT
285	19-May-2021	MYSURU	66	HV2	ELAVALA_66	14:30	15:04	0:34	TRANSFORMER FAULT
286	19-May-2021	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	12:48	12:53	0:04	LINE FAULT
287	19-May-2021	MYSURU	66	MADHUVANAHALLI-KOLLEGALA 1	KOLLEGALA_66 PARINAMIPURA_66 SATHEGALA_66 THALAKADU_66 CHANDALLI_66	14:54	15:07	0:12	LINE FAULT
288	19-May-2021	MYSURU	66	PERIYAPATNA-HANGODU	PONNAMPET_66 VIRAJPET_66	9:21	15:06	5:45	LINE CLEAR AVAILED
289	19-May-2021	MYSURU	66	THANDYA-NANJUNGUD	NO STATIONS INTERRUPTED.	10:48	10:50	0:02	HAND TRIPPED
290	19-May-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 2	SHIVALLY_66	6:14	6:19	0:05	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
291	19-May-2021	MYSURU	66	HEBBANI-MEGALAPURA	THUMBLA_66 GARGESHWARI_66 VYASRAJPURA_66 CHIDRAVALI_66 BGPURA_66	15:13	15:29	0:16	LINE FAULT
292	19-May-2021	MYSURU	66	HEBBANI-MEGALAPURA	THUMBLA_66 GARGESHWARI_66 VYASRAJPURA_66 CHIDRAVALI_66 BGPURA_66	15:55	16:09	0:14	LINE FAULT
293	19-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN, LINE CLEAR AVAILED
294	19-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN, LINE CLEAR AVAILED
295	19-May-2021	TUMKUR	220	ANCHEPALYA 220KV- NELMANGALA -1	ANCHEPALYA_220	12:41	14:20	1:38	LINE FAULT
296	19-May-2021	TUMKUR	220	TR-3(HV SIDE)	CHITRADURGA_220	16:21	16:37	0:15	TRANSFORMER FAULT
297	19-May-2021	TUMKUR	220	TR-3(HV SIDE)	THALLAKK_220	5:56	6:10	0:14	TRANSFORMER FAULT
298	19-May-2021	TUMKUR	110	TR-1	BANDIHALLI_110	16:26	18:26	2:00	TRANSFORMER FAULT
299	19-May-2021	TUMKUR	66	TR-2	BENNEHALLI_66	1:30	3:03	1:33	TRANSFORMER FAULT
300	19-May-2021	TUMKUR	66	BEVINAHALLI- AFTL SOLAR_IPP_66	AFTL SOLAR_IPP_66	17:24	17:28	0:03	LINE FAULT
301	19-May-2021	TUMKUR	66	TR-1	BRAHMASANDRA_66	18:54	19:16	0:21	LINE CLEAR AVAILED
302	19-May-2021	TUMKUR	66	CHITRADURGA 220KV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	16:36	16:46	0:09	HAND TRIPPED
303	19-May-2021	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	16:21	16:40	0:18	TRANSFORMER FAULT
304	19-May-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	15:29	15:37	0:07	LINE FAULT
305	19-May-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	15:29	15:37	0:07	LINE FAULT
306	19-May-2021	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	17:05	17:16	0:11	LINE FAULT
307	19-May-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	15:34	16:02	0:28	HAND TRIPPED
308	19-May-2021	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	14:19	14:32	0:13	LINE FAULT
309	19-May-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUND A_66	1:42	2:13	0:30	LINE FAULT
310	19-May-2021	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	17:09	17:20	0:10	LINE FAULT
311	19-May-2021	TUMKUR	66	TR-1	KORATAGERE_66	9:50	10:01	0:11	TRANSFORMER FAULT
312	19-May-2021	TUMKUR	66	PALLAGATTE66- (DVGSOKKE)NEELAGUNDA	PALLAGATTE_66	11:01	13:27	2:25	LINE CLEAR AVAILED
313	19-May-2021	TUMKUR	66	TR-1	PAVAGADA_66	14:02	14:24	0:22	TRANSFORMER FAULT
314	19-May-2021	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	5:55	6:17	0:21	LINE FAULT
315	19-May-2021	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	6:03	6:16	0:13	HAND TRIPPED
316	19-May-2021	TUMKUR	66	TR-3(LV 3)	THALLAKK_220	5:56	6:12	0:16	TRANSFORMER FAULT
317	19-May-2021	TUMKUR	66	TR-1	SHYLA PURA_66	20:42	20:50	0:07	TRANSFORMER FAULT
318	19-May-2021	TUMKUR	66	TR-1	PAVAGADA_220	11:09	11:15	0:06	TRANSFORMER FAULT
319	19-May-2021	TUMKUR	66	TR-1	PAVAGADA_220	11:52	11:57	0:05	TRANSFORMER FAULT
320	20-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
321	20-May-2021	BAGALKOT	110	(HUBLI)RAMANAKOPPA- MUNDAGOD	STATION NOT AFFECTED MUNDGOD_110	23:56 (20.05.2021)			LINE OPEN, LINE CLEAR AVAILED
322	20-May-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NIDAGUNDI_110	7:35	8:50	1:15	TRANSFORMER FAULT
323	20-May-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NIDAGUNDI_110	11:47	13:07	1:20	TRANSFORMER FAULT
324	20-May-2021	BAGALKOT	110	110/11KV,HV2	ITNAL_110	10:22	11:07	0:45	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
325	20-May-2021	BAGALKOT	110	110/33KV, HV4	DULKHED_33, NEVARGI_33, HALASANGI_33 STATION NOT AFFECTED ZALKI_110	0:10	0:21	0:11	TRANSFORMER FAULT
326	20-May-2021	BAGALKOT	110	110/33KV,(HV4)	KAKTATI_33,SUZLON_33 STATION NOT AFFECTED KANABARGI LAYOUT_110	12:08	13:00	0:52	LINE CLEAR AVOIDED
327	20-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVOIDED
328	20-May-2021	BAGALKOT	110	BAGEWADI- MAMADAPUR1&2	MAMADAPUR_110	6:20	6:35	0:15	LINE FAULT
329	20-May-2021	BAGALKOT	110	BAGEWADI- MAMADAPUR1&2	MAMADAPUR_110	14:03	14:13	0:10	LINE FAULT
330	20-May-2021	BAGALKOT	110	BAGEWADI- MAMADAPUR1&2	MAMADAPUR_110	6:20	6:35	0:15	LINE FAULT
331	20-May-2021	BAGALKOT	110	BAGEWADI- MAMADAPUR1&2	MAMADAPUR_110	14:03	14:13	0:10	LINE FAULT
332	20-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVOIDED
333	20-May-2021	BAGALKOT	110	HUBLI220- KALGHATAGI(SIRSI)	STATION NOT AFFECTED HUBLI_220	16:28	20:19	3:51	LINE FAULT
334	20-May-2021	BAGALKOT	110	HUBLI-KADANKOPPA	STATION NOT AFFECTED KADANKOPPA_110	17:59	20:23	2:24	NFBC ISSUED
335	20-May-2021	BAGALKOT	110	HUBLI-KALAGATAGI	STATION NOT AFFECTED KALAGATAGI_110	16:28	20:21	3:53	NFBC ISSUED
336	20-May-2021	BAGALKOT	110	KADANKOPPA- KAVALWADA	KADANKOPPA_110	6:39 (17.05.2021)	17:58 (20.05.2021)	35:19 hrs	LINE CHARGED
337	20-May-2021	BAGALKOT	110	KADANKOPPA- KAVALWADA	STATION NOT AFFECTED KADANKOPPA_110	22:52 (20.05.2021)			LINE OPEN, LINE CLEAR AVOIDED
338	20-May-2021	BAGALKOT	110	KALAGATAGI-ASPL	KALAGATAGI_110	14:40	15:48	1:08	LINE FAULT
339	20-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
340	20-May-2021	BAGALKOT	110	MALGHAN-MANALI SUGARS	MALGHAN(S)_110	5:29	5:50	0:21	LINE FAULT
341	20-May-2021	BAGALKOT	110	NARENDRA220-BELUR2	STATION NOT AFFECTED NARENDRA_220	11:39	14:24	2:45	LINE CLEAR AVOIDED
342	20-May-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
343	20-May-2021	BAGALKOT	110	TAKKALAKI-KN SOLAR	KN SOLAR_110,TAKKALAKI_110, STATIONS NOT AFFECTED	7:09 (20.05.2021)			LINE OPEN,LINE FAULT
344	20-May-2021	BAGALKOT	110	TUMMINAKATTI- RANEBENNUR220(F1CBREA KER)	STATION NOT AFFECTED TUMMINAKATTI_110	15:03	17:55	2:52	LINE CLEAR AVOIDED
345	20-May-2021	BAGALKOT	220	AMBEEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	18:07 (18.05.2021)			LINE OPEN,LINE FAULT
346	20-May-2021	BAGALKOT	220	BELGAUM-KANABARGI1	STATION NOT AFFECTED BELGAUM_220	11:18	13:43	2:25	LINE CLEAR AVOIDED
347	20-May-2021	BAGALKOT	220	BELGAUM-KANABARGI2	STATION NOT AFFECTED BELGAUM_220	13:45 (20.05.2021)			LINE OPEN, LINE CLEAR AVOIDED
348	20-May-2021	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
349	20-May-2021	BAGALKOT	220	MUGALKHOD-CHIKKODI2	STATION NOT AFFECTED MUGALKHOD_220	10:47	12:56	2:09	NFBC ISSUED
350	20-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
351	20-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN, LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
352	20-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN, LINE CLEAR AVAILED
353	20-May-2021	BAGALKOT	220	VAJJARMATTI- KUDAGI2(KUDAGI1)	STATION NOT AFFECTED VAJJARAMATTI_220	12:05	12:52	0:47	HAND TRIPPED
354	20-May-2021	BAGALKOT	220	VAJJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
355	20-May-2021	BAGALKOT	220	VAJJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
356	20-May-2021	BAGALKOT	400	DHONI-GUDADAHALLI	STATION NOT AFFECTED DHONI_400	10:39	17:06	6:27	LINE CLEAR AVAILED
357	20-May-2021	BENGALURU	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	16:59	17:24	0:25	MAIN SUPPLY FAILURE
358	20-May-2021	BENGALURU	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	17:48	17:56	0:08	LOAD CHANGE OVER
359	20-May-2021	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	5:35	5:40	0:05	LINE FAULT
360	20-May-2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI	17:03	17:37	0:33	LINE CLEAR AVAILED
361	20-May-2021	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	17:04	17:37	0:33	LINE CLEAR AVAILED
362	20-May-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	22:34	22:47	0:13	LINE FAULT
363	20-May-2021	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	7:39	7:43	0:04	LOAD CHANGE OVER
364	20-May-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	7:05	7:10	0:04	LINE FAULT
365	20-May-2021	BENGALURU	66	HV1	KHODAYS 220	16:59	17:18	0:19	LINE CLEAR AVAILED
366	20-May-2021	BENGALURU	66	HV1	KHODAYS 220	21:52	21:56	0:04	LOAD CHANGE OVER
367	20-May-2021	BENGALURU	66	HV1	BANGARPET	13:49	13:57	0:07	TRANSFORMER FAULT
368	20-May-2021	BENGALURU	66	HV1	MAASTHI	9:21	9:35	0:13	LINE CLEAR AVAILED
369	20-May-2021	BENGALURU	66	HV1	MANCHENAHALLI	7:20	7:35	0:15	TRANSFORMER FAULT
370	20-May-2021	BENGALURU	66	HV1	MALLANAYAKANA HALLI	16:57	19:21	2:23	TRANSFORMER FAULT
371	20-May-2021	BENGALURU	66	HV1	MALLANAYAKANA HALLI	20:53 (20-05-2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
372	20-May-2021	BENGALURU	66	HV2	KHODAYS 220	16:59	17:18	0:19	LINE CLEAR AVAILED
373	20-May-2021	BENGALURU	66	HV2	KHODAYS 220	21:52	21:56	0:04	LOAD CHANGE OVER
374	20-May-2021	BENGALURU	66	HV2	IRGAMPALLI	21:03	21:09	0:06	TRANSFORMER FAULT
375	20-May-2021	BENGALURU	66	HV2	MANCHENAHALLI	10:17	11:15	0:57	LINE CLEAR AVAILED
376	20-May-2021	BENGALURU	66	HV2	HULLENAHALLI	22:42 (19-5-2021)	0:50	2:07	TRANSFORMER FAULT
377	20-May-2021	BENGALURU	66	HV3	KGF	17:24	17:39	0:15	TRANSFORMER FAULT
378	20-May-2021	BENGALURU	66	IRGAMPALLI - DIBBURAHALLI	DIBBURAHALLI	20:56	21:09	0:12	LINE FAULT
379	20-May-2021	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	16:50	17:33	0:43	LINE CLEAR AVAILED
380	20-May-2021	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	16:59	17:19	0:20	LINE CLEAR AVAILED
381	20-May-2021	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	21:52	21:56	0:04	LOAD CHANGE OVER
382	20-May-2021	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	10:18	10:22	0:03	LINE FAULT
383	20-May-2021	BENGALURU	66	L R BANDE HBR LAYOUT	L R BANDE	13:45	13:48	0:03	LOAD CHANGE OVER
384	20-May-2021	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	12:41	12:45	0:04	LOAD CHANGE OVER
385	20-May-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	13:44	13:49	0:05	LINE FAULT
386	20-May-2021	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	19:00	19:34	0:34	LINE FAULT
387	20-May-2021	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	16:59	17:15	0:16	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
388	20-May-2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	16:59	17:15	0:16	LINE CLEAR AVAILED
389	20-May-2021	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	16:59	17:15	0:16	LINE CLEAR AVAILED
390	20-May-2021	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	16:59	17:25	0:26	LINE CLEAR AVAILED
391	20-May-2021	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	17:37 (19-05-2021)	10:57	17:19	LINE FAULT
392	20-May-2021	BENGALURU	220	HV1	KHODAYS 220	16:59	17:18	0:19	LINE CLEAR AVAILED
393	20-May-2021	BENGALURU	220	HV2	KHODAYS 220	16:59	17:18	0:19	LINE CLEAR AVAILED
394	20-May-2021	BENGALURU	220	KHODAYS 220 - SOMANAHALLI 220	KHODAYS 220	16:59	17:18	0:19	LINE FAULT
395	20-May-2021	BENGALURU	220	SOMANAHALLI 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	16:59	21:26	4:27	LINE FAULT
396	20-May-2021	BENGALURU	220	SUBRAMANYAPURA 220 - KHODAYS 220	SUBRAMANYAPURA 220	16:59	17:11	0:12	LINE FAULT
397	20-May-2021	GULBARGA	66	HV1	ITTAGI_220	9:45	9:50	0:05	TRANSFORMER FAULT
398	20-May-2021	GULBARGA	110	CHITGUPPA-ACMESOLAR IPP	CHITAGUPPA_110	19:20	20:35	1:15	LINE CLEAR AVAILED
399	20-May-2021	GULBARGA	110	HUMNABAD-RAJESHWAR	RAJESHWAR_110,SASTHAPUR_110,MA NTHAL_110	16:05	18:53	2:48	LINE CLEAR AVAILED
400	20-May-2021	GULBARGA	110	HV1	KUDLIGI_66	21:15	21:20	0:05	TRANSFORMER FAULT
401	20-May-2021	GULBARGA	110	HV1	MASKI_110	17:08	17:50	0:42	LINE CLEAR AVAILED
402	20-May-2021	GULBARGA	110	HV2	KAVITAL_110	9:20	12:10	2:50	LINE CLEAR AVAILED
403	20-May-2021	GULBARGA	110	HV3	KEREHALLI_110	11:20	11:45	0:25	TRANSFORMER FAULT
404	20-May-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	12:31	12:46	0:15	LINE CLEAR AVAILED
405	20-May-2021	GULBARGA	110	MALLAT-BYAGWATH2	BYAGWAT_110,VALKAMDINNI_110	21:39	21:50	0:11	LINE FAULT
406	20-May-2021	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHICKSUGUR_110,SHAKTIN AGAR_110,SURANA IPP	19:15	19:27	0:12	LINE FAULT
407	20-May-2021	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHICKSUGUR_110,SHAKTIN AGAR_110,SURANA IPP	19:27	19:39	0:12	LINE FAULT
408	20-May-2021	GULBARGA	110	RAICHUR-APMC1&2	APMC_110,CHICKSUGUR_110,SHAKTIN AGAR_110,SURANA IPP	10:50	10:55	0:05	LINE CLEAR AVAILED
409	20-May-2021	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHICKSUGUR_110,SHAKTIN AGAR_110,SURANA IPP	19:15	19:37	0:22	LINE FAULT
410	20-May-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:40	6:03	0:23	LINE FAULT
411	20-May-2021	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	20:18(19.05.2021)	00:01(20.05.2021)	3:43HRS	LINE CHARGED
412	20-May-2021	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	13:33	16:18	2:45	LINE CLEAR AVAILED
413	20-May-2021	GULBARGA	110	SEDAM-ULTRATECH_IPP	SEDAM_220	4:20	4:34	0:14	LINE FAULT
414	20-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVA NGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	5:33	5:38	0:05	LINE CLEAR AVAILED
415	20-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVA NGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	14:10	14:20	0:10	LINE CLEAR AVAILED
416	20-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVA NGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	21:33	21:38	0:05	LINE FAULT
417	20-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YEDRAMI_110,MORATAGI_110	5:30	5:39	0:09	LINE FAULT
418	20-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	6:10	11:34	5:24	LINE FAULT
419	20-May-2021	GULBARGA	110	SINDHNOOR-RAICHUR2	KURDICROSS_110,MADALAPUR_110,M ANVI_110	18:40	18:50	0:10	LINE FAULT
420	20-May-2021	GULBARGA	220	MALLAT-RTPS	MALLAT_220	4:37	4:54	0:17	LINE FAULT
421	20-May-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400(STATION NOT AFFECTED)	22:04(15.05.2021)			LINE OPEN,LINE FAULT
422	20-May-2021	GULBARGA	400	GDHALLI-DHONI	DHONI_400	10:40	16:52	6:12	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
423	20-May-2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400(STATION NOT AFFECTED)	2:55(16.05.2021)			LINE OPEN,LINE FAULT
424	20-May-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	18:32	19:31	0:59	LINE CLEAR AVOIDED
425	20-May-2021	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:32	13:32	3:00	NFBC ISSUED
426	20-May-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHAPURA_66	11:02	16:55	5:53	LINE CLEAR AVOIDED
427	20-May-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHAPURA_66	11:02	16:55	5:53	LINE CLEAR AVOIDED
428	20-May-2021	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	5:10	5:45	0:35	HAND TRIPPED
429	20-May-2021	HASSAN	110	HV1	ARASIKERE_220	5:10	5:45	0:35	TRANSFORMER FAULT
430	20-May-2021	HASSAN	110	HV1	NANDIKUR_110	11:19	11:48	0:29	LINE CLEAR AVOIDED
431	20-May-2021	HASSAN	110	HV1	SAGARA_110	17:19	19:40	2:21	TRANSFORMER FAULT
432	20-May-2021	HASSAN	110	HV2	PUTTUR_110(NO LOAD AFFECTED)	9:34(15.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVOIDED
433	20-May-2021	HASSAN	110	LV1	ARASIKERE_220	5:10	5:45	0:35	TRANSFORMER FAULT
434	20-May-2021	HASSAN	110	YGTI	KADUR_220	3:09	3:17	0:08	LINE FAULT
435	20-May-2021	MYSURU	66	HAMPAPURA-BASARALU	BESAGARAHALLI_66, KOPPA_66	16:12	16:20	0:07	LINE FAULT
436	20-May-2021	MYSURU	66	HV1	BETTADHAPURA_66	12:00	13:06	1:06	LINE CLEAR AVOIDED
437	20-May-2021	MYSURU	66	HV2	NAGAMANGALA_66	16:12	16:22	0:10	LINE CLEAR AVOIDED
438	20-May-2021	MYSURU	66	HV2	RKNAGARA_66	10:39	12:20	1:41	LINE CLEAR AVOIDED
439	20-May-2021	MYSURU	66	HV2	SATHEGALA_66	10:52	11:06	0:13	HAND TRIPPED
440	20-May-2021	MYSURU	66	KABHALLY-CLEAN SOLAR	NO STATIONS EFFECTED	18:34	19:30	0:55	LINE CLEAR AVOIDED
441	20-May-2021	MYSURU	66	KR PETE 220-KR PETE 1	AKKIEBBAL_66 KIKKERI_66 KRPET_66	5:44	5:52	0:08	LINE FAULT
442	20-May-2021	MYSURU	66	KR PETE-HUYGONAHALLY 1	AKKIEBBAL_66 KIKKERI_66 KRPET_66	5:45	5:50	0:05	LINE FAULT
443	20-May-2021	MYSURU	66	KR PETE-HUYGONAHALLY 2	AKKIEBBAL_66 KIKKERI_66 KRPET_66	5:43	5:50	0:06	LINE FAULT
444	20-May-2021	MYSURU	66	KUSHALANAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	20:26	20:46	0:19	LINE FAULT
445	20-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN, LINE CLEAR AVOIDED
446	20-May-2021	MYSURU	66	VAJAMANGALA-JYOTHINAGARA	DKMAIDANA_66, FTS_66, JYOTHINAGARA_66	17:34	17:42	0:08	LINE FAULT
447	20-May-2021	MYSURU	220	HV2	KUSHALNAGARA_220	10:40	11:41	1:01	LINE CLEAR AVOIDED
448	20-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN, LINE CLEAR AVOIDED
449	20-May-2021	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	12:42	12:46	0:03	LINE FAULT
450	20-May-2021	TUMKUR	66	JAVAGONDANAHALLI-BEVINAHALLI	JAVAGONDANAHALLI_66	12:30	12:45	0:15	MAIN SUPPLY FAILURE
451	20-May-2021	TUMKUR	66	LINGADAHALLI-SHIMOGA(NALLUR)	NALLUR_66,DEVARAHALLI_66, BENKIKERE_66,GOPPENAHALLI_66	6:16	6:31	0:14	LINE FAULT
452	20-May-2021	TUMKUR	66	TR-1	HULIYURDURGA_66	10:58	11:22	0:23	TRANSFORMER FAULT
453	20-May-2021	TUMKUR	110	HONNAVALLI 110-DMKURKE	DMKURKE_110	5:10	7:02	1:51	LINE FAULT
454	20-May-2021	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	4:06	5:38	1:31	LINE CLEAR AVOIDED
455	21-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
456	21-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
457	21-May-2021	BAGALKOT	110	RANEENNUR220-HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
458	21-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
459	21-May-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
460	21-May-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
461	21-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
462	21-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVAILED
463	21-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVAILED
464	21-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN, LINE CLEAR AVAILED
465	21-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN, LINE CLEAR AVAILED
466	21-May-2021	BAGALKOT	220	AMBEEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	18:07 (18.05.2021)			LINE OPEN,LINE FAULT
467	21-May-2021	BAGALKOT	220	BELGAUM-KANABARGI2	STATION NOT AFFECTED BELGAUM_220	13:45 (20.05.2021)	01:55 (21.05.2021)	12:10HRS	LINE CHARGED
468	21-May-2021	BAGALKOT	110	KADANKOPPA-KAVALWADA	STATION NOT AFFECTED KADANKOPPA_110	22:52 (20.05.2021)	10:50 (21.05.2021)	11:58hrs	LINE CHARGED
469	21-May-2021	BAGALKOT	110	(HUBLI)RAMANAKOPPA-MUNDAGOD	STATION NOT AFFECTED MUNDGOD_110	23:56 (20.05.2021)	1:26 (21.05.2021)	1:30hrs	LINE CHARGED
470	21-May-2021	BAGALKOT	110	TAKKALAKI-KN SOLAR	KN SOLAR_110 STATION NOT AFFECTED TAKKALAKI_110	7:09 (20.05.2021)	2:57 (21.05.2021)	19:48hrs	LINE CHARGED
471	21-May-2021	BAGALKOT	110	ATHARGA-KN SOLAR	ATHARGA_110	19:06	19:29	0:23	LINE FAULT
472	21-May-2021	BAGALKOT	110	HATTARAGI-DADDI	HATTARAGI_110	10:26	10:42	0:16	LINE FAULT
473	21-May-2021	BAGALKOT	110	SIRSI110- KUMTA2	STATION NOT AFFECTED SIRSI_110	12:34	18:39	6:05	LINE FAULT
474	21-May-2021	BAGALKOT	110	110/11KV, HV1	MKHUBLI_220	10:53	12:31	1:38	LINE CLEAR AVAILED
475	21-May-2021	BAGALKOT	110	110/11KV, HV1	HOSAHONNATTI_110	3:55	4:07	0:12	TRANSFORMER FAULT
476	21-May-2021	BENGALURU	66	HV1	ATTIBELE	13:00	13:05	0:05	LINE CLEAR AVAILED
477	21-May-2021	BENGALURU	66	IRGAMPALLI - DIBBURAHALLI	NO STATION AFFECTED	6:55	7:00	0:05	LINE FAULT
478	21-May-2021	BENGALURU	66	MAASTHI - ADANI SOLAR (IPP)	NO STATIONS AFFECTED	6:50	7:30	0:40	LINE CLEAR AVAILED
479	21-May-2021	BENGALURU	66	HV1	MAASTHI	8:35	9:00	0:25	LINE CLEAR AVAILED
480	21-May-2021	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	13:56	14:16	0:20	LINE FAULT
481	21-May-2021	BENGALURU	66	HV1	KHW PARK	11:34	11:42	0:08	TRANSFORMER FAULT
482	21-May-2021	BENGALURU	66	HV1	MITTEMARI 220	22:32	22:40	0:08	TRANSFORMER FAULT
483	21-May-2021	BENGALURU	66	HV1	VOLVO	12:20	12:40	0:20	TRANSFORMER FAULT
484	21-May-2021	BENGALURU	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSURU RAMAPURA, NITRALLI	17:32	18:15	0:43	LINE FAULT
485	21-May-2021	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	17:22	17:52	0:29	MAIN SUPPLY FAILURE
486	21-May-2021	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA	17:22	17:51	0:28	MAIN SUPPLY FAILURE
487	21-May-2021	BENGALURU	220	NAGNATHPURA 220 - SOMANAHALLI 220	NAGNATHPURA 220	17:22	17:47	0:24	LINE FAULT
488	21-May-2021	BENGALURU	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	18:20	18:38	0:18	LINE FAULT
489	21-May-2021	BENGALURU	66	HOODY 220 - HP (EHT)	HP (EHT)	13:00	15:55	2:55	LINE CLEAR AVAILED
490	21-May-2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400	2:55(16.05.2021)			LINE OPEN,LINE FAULT
491	21-May-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:04(15.05.2021)			LINE OPEN,LINE FAULT
492	21-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVA NGAON_110,RENUKA_IPP,AFZALPUR_1 10,KARAJAGI_110	9:50(21.05.2021)			LINE OPEN, LINE CLEAR AVAILED
493	21-May-2021	GULBARGA	110	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110	1:00	1:10	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
494	21-May-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:14	6:03	0:49	LINE FAULT
495	21-May-2021	GULBARGA	110	MALLAT-BYAGWATH2	MADLAPUR_110,MANVI_110	3:10	3:31	0:21	LINE FAULT
496	21-May-2021	GULBARGA	110	SINDHNOOR-RAICHUR2	KURDICROSS_110,MADALAPUR_110,M ANVI_110	0:22	0:32	0:10	LINE FAULT
497	21-May-2021	GULBARGA	110	SINDHNOOR-RAICHUR2	KURDICROSS_110,MADALAPUR_110,M ANVI_110	2:20	2:30	0:10	LINE FAULT
498	21-May-2021	GULBARGA	110	SINDHNOOR-RAICHUR2	KURDICROSS_110,MADALAPUR_110,M ANVI_110	3:30	6:40	3:10	LINE FAULT
499	21-May-2021	GULBARGA	110	HV1	SANKLAPUR_110	13:40	13:45	0:05	TRANSFORMER FAULT
500	21-May-2021	GULBARGA	110	HV1	SIRWAR_110	11:55	12:20	0:25	LINE CLEAR AVAIED
501	21-May-2021	GULBARGA	110	HV1	SHORAPUR_110	15:20	15:50	0:30	LINE CLEAR AVAIED
502	21-May-2021	GULBARGA	110	HV1	SAIDAPUR_110	22:45	22:55	0:10	TRANSFORMER FAULT
503	21-May-2021	GULBARGA	110	HV2	DEODURGA_110	15:40	15:50	0:10	TRANSFORMER FAULT
504	21-May-2021	GULBARGA	110	HV2	DEODURGA_110	20:30	21:25	0:55	TRANSFORMER FAULT
505	21-May-2021	GULBARGA	110	HV1	SIRWAR_110	11:55	12:20	0:25	LINE CLEAR AVAIED
506	21-May-2021	GULBARGA	110	HV2	MANVI_110	18:53	18:59	0:06	TRANSFORMER FAULT
507	21-May-2021	GULBARGA	110	SINDHNOOR-TEKKALKOTE	TEKKALKOTE_110	1:00	1:10	0:10	MAIN SUPPLY FAILURE
508	21-May-2021	GULBARGA	110	HV1	SANKLAPUR_110	13:40	13:45	0:05	TRANSFORMER FAULT
509	21-May-2021	GULBARGA	66	HV1	TAMBRAHALLI_66	10:50	11:25	0:35	LINE CLEAR AVAIED
510	21-May-2021	GULBARGA	66	HV1	HOSAHALLI_66	13:55	14:00	0:05	TRANSFORMER FAULT
511	21-May-2021	HASSAN	110	HV2	PUTTUR_110	9:34(15.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAIED
512	21-May-2021	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	23:40(21.05.2021)			LINE OPEN,LINE FAULT
513	21-May-2021	HASSAN	220	MRSSHM-HSN4001	MRS MG_220	11:27	12:25	0:58	LINE FAULT
514	21-May-2021	HASSAN	220	MRSSHM-SHARAVATHY4	MRS MG_220	11:53	13:40	1:47	LINE FAULT
515	21-May-2021	HASSAN	220	MRSSHM-VARAH1	MRS MG_220	9:53	13:46	3:53	LINE CLEAR AVAIED
516	21-May-2021	HASSAN	220	MRSSHM-VARAH1	MRS MG_220	16:02	20:01	3:59	LINE FAULT
517	21-May-2021	HASSAN	220	MRSSHM-VARAH2	MRS MG_220	16:02	20:02	4:00	LINE FAULT
518	21-May-2021	HASSAN	220	SHRAV TY-SHIMO GA4	sharavathy_gen	11:53	13:40	1:47	LINE FAULT
519	21-May-2021	HASSAN	220	VARAH1-SHIMO GA1	varahi_gen	9:53	13:46	3:53	LINE CLEAR AVAIED
520	21-May-2021	HASSAN	220	VARAH1-SHIMO GA1	varahi_gen	16:02	20:01	3:59	LINE FAULT
521	21-May-2021	HASSAN	220	VARAH1-SHIMO GA2	varahi_gen	16:02	20:01	3:59	LINE FAULT
522	21-May-2021	HASSAN	110	HV1	BARANGI_110	11:43	14:38	2:55	LINE CLEAR AVAIED
523	21-May-2021	HASSAN	110	HV1	KONAJE_110	11:23	11:30	0:07	HAND TRIPPED
524	21-May-2021	HASSAN	110	HV2	KONAJE_110	11:23	11:30	0:07	HAND TRIPPED
525	21-May-2021	HASSAN	110	HV3	KONAJE_110	11:23	11:30	0:07	HAND TRIPPED
526	21-May-2021	HASSAN	110	HV1	MANIPAL_110	20:25	21:59	1:34	TRANSFORMER FAULT
527	21-May-2021	HASSAN	110	SALATHUR-KONAJE	SALATHUR_110	11:36	13:53	2:17	NFBC ISSUED
528	21-May-2021	HASSAN	110	HV1	SALATHUR_110	11:26	12:18	0:52	LINE CLEAR AVAIED
529	21-May-2021	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:16	14:11	3:55	NFBC ISSUED
530	21-May-2021	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	10:52	16:05	5:13	LINE CLEAR AVAIED
531	21-May-2021	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	10:52	16:05	5:13	LINE CLEAR AVAIED
532	21-May-2021	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	16:05	17:15	1:10	LINE FAULT
533	21-May-2021	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	16:32	17:15	0:43	HAND TRIPPED
534	21-May-2021	HASSAN	66	HV2	SALAGAME_66	20:05	20:40	0:35	TRANSFORMER FAULT
535	21-May-2021	HASSAN	66	HV1	SATHENAHALLY_66	13:17	14:56	1:39	TRANSFORMER FAULT
536	21-May-2021	MYSURU	66	HV1	GUDDENAHALLI_66	7:20	7:36	0:16	LINE CLEAR AVAIED
537	21-May-2021	MYSURU	66	HD KOTE-TARAKA	NO STATIONS EFFECTED	9:50	13:05	3:15	NFBC ISSUED
538	21-May-2021	MYSURU	66	HV1	KIRUGAVALU_66	18:45	18:56	0:11	HAND TRIPPED
539	21-May-2021	MYSURU	66	YELANDUR-MAMBALLI	NO STATIONS EFFECTED	19:45	19:52	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
540	21-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN, LINE CLEAR AVAILED
541	21-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN, LINE CLEAR AVAILED
542	21-May-2021	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	11:02	12:42	1:40	LINE CLEAR AVAILED
543	21-May-2021	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	11:36	13:19	1:43	LINE CLEAR AVAILED
544	21-May-2021	TUMKUR	110	TR-3	GUBBI_110	14:26	16:43	2:16	LINE CLEAR AVAILED
545	21-May-2021	TUMKUR	66	TR-1	CHIKKABANAGERE_66	7:15	8:26	1:11	LINE CLEAR AVAILED
546	21-May-2021	TUMKUR	66	DAVANGERE SRS-KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:27	15:39	0:11	LINE FAULT
547	21-May-2021	TUMKUR	66	DAVANGERE SRS-HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:39	12:45	0:05	LINE FAULT
548	21-May-2021	TUMKUR	66	DAVANGERE SRS-HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	15:22	15:32	0:09	LINE FAULT
549	21-May-2021	TUMKUR	66	TR-3	HARIYABBE_66	18:09	18:13	0:04	TRANSFORMER FAULT
550	21-May-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	2:29	2:36	0:06	LINE FAULT
551	21-May-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	4:43	4:50	0:06	LINE FAULT
552	21-May-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	15:35	15:48	0:12	LINE FAULT
553	21-May-2021	TUMKUR	66	HONNALLI 220KV-KUNDUR	KUNDUR_66,MALEBENNUR_66	16:51	17:02	0:11	LINE FAULT
554	21-May-2021	TUMKUR	66	MADHUGIRI 220kv-PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	5:26	6:07	0:41	LINE FAULT
555	21-May-2021	TUMKUR	66	JAVAGONDANAHALLI-BEVINAHALLI	JAVAGONDANAHALLI_66	11:39	11:56	0:16	HAND TRIPPED
556	22-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
557	22-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
558	22-May-2021	BAGALKOT	110	RANEBENNUR220-HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
559	22-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
560	22-May-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
561	22-May-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
562	22-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
563	22-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVAILED
564	22-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVAILED
565	22-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN, LINE CLEAR AVAILED
566	22-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN, LINE CLEAR AVAILED
567	22-May-2021	BAGALKOT	220	AMBEEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	18:07 (18.05.2021)			LINE OPEN,LINE FAULT
568	22-May-2021	BAGALKOT	220	GHATAPRABHA-NARENDRA 1	GHATAPRABHA_220	6:01	7:28	1:27	LINE FAULT
569	22-May-2021	BAGALKOT	110	110/33KV,HV4	GOPANAKOPPA_110 &KMC &KUSUGAL_33	9:03	9:28	0:25	LINE CLEAR AVAILED
570	22-May-2021	BAGALKOT	110	HATTARAGI-DADDI	HATTARAGI_110	1:25	1:40	0:15	LINE FAULT
571	22-May-2021	BAGALKOT	110	VAJRAMATTI220-KATARKI	KATARKI_110	5:21	5:39	0:18	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
572	22-May-2021	BAGALKOT	110	SUVARNASOUDA- MACHE	MACHE_110	15:22	16:31	1:09	LINE FAULT
573	22-May-2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	13:11	18:53	5:42	LINE FAULT
574	22-May-2021	BAGALKOT	110	SOUDATTI220- RAMDURGA1	RAMDURGA_110	9:18	9:35	0:17	LINE FAULT
575	22-May-2021	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MKHUBLI_220	15:09 (22.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
576	22-May-2021	BAGALKOT	110	HUKKERI- HATTARGI	HUKKERI_110	6:15	6:49	0:34	HAND TRIPPED
577	22-May-2021	BAGALKOT	110	HUKKERI- VISHWANATH SUGARS	HUKKERI_110	6:15	6:27	0:12	HAND TRIPPED
578	22-May-2021	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	6:03	6:10	0:07	LINE FAULT
579	22-May-2021	BAGALKOT	110	110/11KV, HV4	HUKKERI_110	16:39	16:46	0:07	TRANSFORMER FAULT
580	22-May-2021	BAGALKOT	110	110/11KV, HV1	HOSAHONNATTI_110	7:38	7:45	0:07	TRANSFORMER FAULT
581	22-May-2021	BENGALURU	66	CHIKKABALLAPURA I/A - DB PURA 1	CHIKKABALLAPURA I/A	11:05	11:15	0:10	LINE CLEAR AVAILED
582	22-May-2021	BENGALURU	66	CHIKKABALLAPURA I/A - DB PURA 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	11:05	11:15	0:10	LINE CLEAR AVAILED
583	22-May-2021	BENGALURU	66	HV1	GOWRIBIDANUR 220	11:15	11:33	0:18	TRANSFORMER FAULT
584	22-May-2021	BENGALURU	66	HV2	GUNDAMGERE	12:10	13:05	0:55	TRANSFORMER FAULT
585	22-May-2021	BENGALURU	66	PATHPALYA - BAGEPALLI	PATHPALYA	18:20	18:30	0:10	LINE CLEAR AVAILED
586	22-May-2021	BENGALURU	66	HV1	SIDLAGHATTA	13:30	14:00	0:30	LINE CLEAR AVAILED
587	22-May-2021	BENGALURU	66	KORMANGALA 220 - AUSTIN TOWN 2	NO STATION AFFECTED	17:57	19:05	1:08	LINE FAULT
588	22-May-2021	BENGALURU	66	ITI 220 - HOODY 2	DRDO(EHT)	11:01	13:18	2:17	LINE CLEAR AVAILED
589	22-May-2021	BENGALURU	66	ITI 220 - HOODY 2	DRDO(EHT)	10:22	19:02	8:40	LINE CLEAR AVAILED
590	22-May-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	8:21	8:38	0:17	LINE FAULT
591	22-May-2021	BENGALURU	220	HV1	NRS 220	14:43	14:53	0:10	TRANSFORMER FAULT
592	22-May-2021	BENGALURU	66	REMCO - NRS 220	VIJAYNAGAR HV1	9:26	11:10	1:43	LINE FAULT
593	22-May-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	22:50	23:04	0:13	LINE FAULT
594	22-May-2021	BENGALURU	66	HV2	HEBBAL 220	21:27	22:26	0:59	TRANSFORMER FAULT
595	22-May-2021	BENGALURU	220	HEBBAL 220 - MANYATHA 220	HEBBAL 220	21:27	21:40	0:13	LINE FAULT
596	22-May-2021	BENGALURU	66	HEBBAL 220 - ITI 1	BANASWADI	21:27	21:41	0:14	MAIN SUPPLY FAILURE
597	22-May-2021	BENGALURU	66	HEBBAL 220 - ITI 2	LR BANDE	21:27	21:34	0:07	MAIN SUPPLY FAILURE
598	22-May-2021	BENGALURU	66	HEBBAL 220 - C STATION 1	C STATION	21:27	21:43	0:16	MAIN SUPPLY FAILURE
599	22-May-2021	BENGALURU	66	HEBBAL 220 - IISC	IISC	21:27	21:44	0:17	MAIN SUPPLY FAILURE
600	22-May-2021	BENGALURU	66	BANASWADI - ITI GIS 220	BANASWADI	21:53	21:59	0:06	LOAD CHANGE OVER
601	22-May-2021	BENGALURU	66	LR BANDE - HBR LAYOUT	LR BANDE	21:57	22:00	0:03	LOAD CHANGE OVER
602	22-May-2021	BENGALURU	66	HV1	CHATRA	19:48(22-5-2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
603	22-May-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	NO STATION AFFECTED	8:21(22-5-2021)			LINE OPEN,LINE FAULT
604	22-May-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	23:04:06(22-5-2021)			LINE OPEN,LINE FAULT
605	22-May-2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400	2:55(16.05.2021)			LINE OPEN,LINE FAULT
606	22-May-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:04(15.05.2021)			LINE OPEN,LINE FAULT
607	22-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVA NGAON_110,RENUKA_IPP,AZALPUR_1 10,KARAJAGI_110	9:50(21.05.2021)	21:48(22.05.2021)	39:58HRS	LINE CHARGED
608	22-May-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	21:57	22:14	0:17	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
609	22-May-2021	GULBARGA	110	MALLAT-BYAGWATH2	MADLAPUR_110,MANVI_110	2:04	2:14	0:10	LINE FAULT
610	22-May-2021	GULBARGA	110	MALLAT-BYAGWATH2	MADLAPUR_110,MANVI_110	3:05	3:15	0:10	LINE FAULT
611	22-May-2021	GULBARGA	110	MALLAT-BYAGWATH2	MADLAPUR_110,MANVI_110	5:30	5:42	0:12	LINE FAULT
612	22-May-2021	GULBARGA	110	MALLAT-BYAGWATH2	MADLAPUR_110,MANVI_110	19:35	19:45	0:10	LINE FAULT
613	22-May-2021	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	5:24	5:36	0:12	LINE FAULT
614	22-May-2021	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP	6:55	7:07	0:12	LINE FAULT
615	22-May-2021	GULBARGA	110	HV1	BENNUR_110	13:00	13:08	0:08	TRANSFORMER FAULT
616	22-May-2021	GULBARGA	110	HV1	BEVOOR_110	12:30	13:05	0:35	LINE CLEAR AVAILED
617	22-May-2021	GULBARGA	110	HV1	HATTI_110	1:50	1:53	0:03	TRANSFORMER FAULT
618	22-May-2021	GULBARGA	110	NALWAR-CLEANSOLAR_IPP	NALWAR_110	11:10	11:20	0:10	LINE FAULT
619	22-May-2021	GULBARGA	110	HV2	MANVI_110	11:05	11:23	0:18	LINE CLEAR AVAILED
620	22-May-2021	GULBARGA	110	HV1	MANVI_110	2:27	2:33	0:06	TRANSFORMER FAULT
621	22-May-2021	GULBARGA	110	HV1	SANKLAPUR_110	23:35	23:40	0:05	TRANSFORMER FAULT
622	22-May-2021	HASSAN	110	HV2	PUTTUR_110	9:34(15.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
623	22-May-2021	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	23:40(21.05.2021)	12:15 (22.05.2021)	12:34 hrs	LINE CHARGED
624	22-May-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	2:04	7:31	5:27	LINE CLEAR AVAILED
625	22-May-2021	HASSAN	220	HASSN22-Shomoga	HASSAN_220	14:00	17:03	3:03	LINE FAULT
626	22-May-2021	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	14:24	18:27	4:03	LINE CLEAR AVAILED
627	22-May-2021	HASSAN	220	MRSSHM-VARAH1	MRS MG_220	10:05	14:50	4:45	LINE CLEAR AVAILED
628	22-May-2021	HASSAN	220	MRSSHM-VARAH3	MRS MG_220	13:55	15:26	1:31	LINE FAULT
629	22-May-2021	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	14:24	18:27	4:03	NFBC ISSUED
630	22-May-2021	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	10:05	14:50	4:45	LINE CLEAR AVAILED
631	22-May-2021	HASSAN	220	VARAH1-SHMG3	varahi_gen	13:55	15:26	1:31	LINE FAULT
632	22-May-2021	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	13:55	14:00	0:05	LINE FAULT
633	22-May-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	15:17	21:39	6:22	LINE FAULT
634	22-May-2021	HASSAN	66	HV1	KANDLI_66	12:44	13:05	0:21	LINE CLEAR AVAILED
635	22-May-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	6:13	6:20	0:07	HAND TRIPPED
636	22-May-2021	HASSAN	66	HV1	MOSALEHOSAHALLI_66	11:15	11:55	0:40	TRANSFORMER FAULT
637	22-May-2021	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	12:49	13:02	0:13	HAND TRIPPED
638	22-May-2021	MYSURU	66	HV2	DEVANOORNGUDU_66	13:43	13:55	0:11	TRANSFORMER FAULT
639	22-May-2021	MYSURU	66	HV1	GUDDENAHALLI_66	14:09	14:46	0:36	LINE CLEAR AVAILED
640	22-May-2021	MYSURU	66	GUNDLUPETE-KABHALLI	NO STATIONS EFFECTED	17:26	17:36	0:09	LINE FAULT
641	22-May-2021	MYSURU	66	HV1	KADABALLY_66	11:00	11:53	0:53	LINE CLEAR AVAILED
642	22-May-2021	MYSURU	66	HV1	KADABALLY_66	13:04	13:13	0:08	LINE CLEAR AVAILED
643	22-May-2021	MYSURU	66	KADABALLI-CR PATNA	KADABALLY_66	11:41	11:53	0:11	LINE CLEAR AVAILED
644	22-May-2021	MYSURU	66	KADAKOLA-NANJANGUDU	NO STATIONS EFFECTED	13:22	14:44	1:22	LINE CLEAR AVAILED
645	22-May-2021	MYSURU	66	KADAKOLA-THANDYA	NO STATIONS EFFECTED	11:02	14:44	3:42	LINE CLEAR AVAILED
646	22-May-2021	MYSURU	66	HV1	K_HONNALGERE_66	18:11	18:34	0:23	TRANSFORMER FAULT
647	22-May-2021	MYSURU	66	HV1	K_HONNALGERE_66	22:50	23:40	0:50	HAND TRIPPED
648	22-May-2021	MYSURU	66	KUSHALNAGARA-MYSORE-1	MIRLE_66	5:59	10:37	4:38	LINE FAULT
649	22-May-2021	MYSURU	66	KUSHALNAGARA-RAMANATHAPURA 1	CB HALLI_66 RUDRAPATNA_66 KANGAL_66 ALURSIDDAPURA_66	12:26	12:32	0:05	LINE FAULT
650	22-May-2021	MYSURU	66	HV5	SFC SIVA_66	7:50	20:13	12:22	LINE CLEAR AVAILED
651	22-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN, LINE CLEAR AVAILED
652	22-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN, LINE CLEAR AVAILED
653	22-May-2021	TUMKUR	220	TR-3(HV SIDE)	CHITRADURGA_220	20:31	20:42	0:11	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
654	22-May-2021	TUMKUR	220	ANCHEPALYA 220kV-VIJAYA STEEL	ANCHEPALYA_220	10:20	18:11	7:51	LINE CLEAR AVAILED
655	22-May-2021	TUMKUR	66	BALENAHALLI66-FEFCWIND IPP 66	FEFCWIND_IPP_66	12:31	12:58	0:26	LINE CLEAR AVAILED
656	22-May-2021	TUMKUR	66	TR-2	BALENAHALLI_66	16:20	16:29	0:09	TRANSFORMER FAULT
657	22-May-2021	TUMKUR	66	TR-1	BRAHMASANDRA_66	10:44	11:03	0:19	LINE CLEAR AVAILED
658	22-May-2021	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	20:31	20:45	0:13	TRANSFORMER FAULT
659	22-May-2021	TUMKUR	66	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	20:40	20:47	0:06	HAND TRIPPED
660	22-May-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	0:02	0:14	0:11	MAIN SUPPLY FAILURE
661	22-May-2021	TUMKUR	66	TR-3	HARIYABBE_66	7:26	7:36	0:09	TRANSFORMER FAULT
662	22-May-2021	TUMKUR	66	TR-3	HARIYABBE_66	9:16	9:23	0:07	TRANSFORMER FAULT
663	22-May-2021	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	5:43	6:16	0:32	LINE FAULT
664	22-May-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	5:43	6:21	0:37	LINE FAULT
665	22-May-2021	TUMKUR	66	HONNALLI 220KV-KUNDUR	KUNDUR_66,MALEBENNUR_66	14:43	14:48	0:05	LINE FAULT
666	22-May-2021	TUMKUR	66	HONNALLI 220KV-NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	15:04	15:15	0:11	LINE FAULT
667	22-May-2021	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	2:29	2:52	0:22	LINE FAULT
668	22-May-2021	TUMKUR	66	MADHUGIRI 220kV-KORATAGERE 1	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	14:58	16:06	1:07	LINE CLEAR AVAILED
669	22-May-2021	TUMKUR	66	MADHUGIRI 220kV-MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	14:58	16:06	1:07	LINE CLEAR AVAILED
670	22-May-2021	TUMKUR	66	MADHUGIRI 220kV-PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	15:00	16:01	1:01	LINE CLEAR AVAILED
671	22-May-2021	TUMKUR	66	TR-1	SOKKE_66	10:57	11:02	0:05	TRANSFORMER FAULT
672	22-May-2021	TUMKUR	66	TR-2	TUMKUR_66	19:45	20:21	0:35	TRANSFORMER FAULT
673	23-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
674	23-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
675	23-May-2021	BAGALKOT	110	RANEENNUR220-HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
676	23-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
677	23-May-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
678	23-May-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
679	23-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
680	23-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVAILED
681	23-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVAILED
682	23-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN, LINE CLEAR AVAILED
683	23-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN, LINE CLEAR AVAILED
684	23-May-2021	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	18:07 (18.05.2021)			LINE OPEN,LINE FAULT
685	23-May-2021	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MKHUBLI_220	15:09 (22.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
686	23-May-2021	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	12:55	13:37	0:42	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
687	23-May-2021	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	18:00	18:11	0:11	LINE FAULT
688	23-May-2021	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	12:49	13:11	0:22	LINE FAULT
689	23-May-2021	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	13:27	14:02	0:35	LINE FAULT
690	23-May-2021	BAGALKOT	220	BIDNAL-HARTI 2	BIDNAL_220	17:55 (23.05.2021)			LINE OPEN, LINE CLEAR AVAILED
691	23-May-2021	BAGALKOT	110	110/11KV,HV2	TORVI_110	8:22	8:24	0:02	TRANSFORMER FAULT
692	23-May-2021	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	15:44	15:55	0:11	LINE FAULT
693	23-May-2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	9:23	9:26	0:03	TRANSFORMER FAULT
694	23-May-2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	9:42	9:47	0:05	TRANSFORMER FAULT
695	23-May-2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	9:56	9:59	0:03	TRANSFORMER FAULT
696	23-May-2021	BAGALKOT	110	110/11KV, HV1	HOSAHONNATTI_110	7:15	7:24	0:09	TRANSFORMER FAULT
697	23-May-2021	BENGALURU	66	HV1	CHANDAPURA	15:10	15:15	0:05	TRANSFORMER FAULT
698	23-May-2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	8:00	8:09	0:09	LINE FAULT
699	23-May-2021	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	5:32	5:40	0:08	LINE FAULT
700	23-May-2021	BENGALURU	66	CHINTAMANI 220 - SRINIVASAPURA	SRINIVASAPURA, KODIHALLI	16:33	16:38	0:05	LINE FAULT
701	23-May-2021	BENGALURU	66	HV1	DEVANAHALLI	16:11	16:15	0:04	TRANSFORMER FAULT
702	23-May-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	6:54	7:04	0:10	LINE FAULT
703	23-May-2021	BENGALURU	66	HV1	MAASTHI	17:30	18:25	0:55	LINE CLEAR AVAILED
704	23-May-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	5:53	5:58	0:05	LINE FAULT
705	23-May-2021	BENGALURU	66	SOMENAHALLI - AFTL (IPP)	NO STATION AFFECTED	5:53	5:58	0:05	LINE FAULT
706	23-May-2021	BENGALURU	66	HV1	DEVARBISANHALLI	3:35	4:14	0:38	TRANSFORMER FAULT
707	23-May-2021	BENGALURU	66	HV1	ALLIMARDANAHALLI	12:07	12:12	0:04	TRANSFORMER FAULT
708	23-May-2021	BENGALURU	66	HV1	ISRO LAYOUT	8:07	8:19	0:12	TRANSFORMER FAULT
709	23-May-2021	BENGALURU	66	IISC - NRS 220	IISC	5:41	5:47	0:06	LOAD CHANGE OVER
710	23-May-2021	BENGALURU	66	C STATION - A STATION 220	C STATION	6:19	6:23	0:04	LOAD CHANGE OVER
711	23-May-2021	BENGALURU	66	HV1	CHATRA	15:57	16:12	0:15	TRANSFORMER FAULT
712	23-May-2021	BENGALURU	66	HSR LAYOUT - ST JOHNS	ST JOHNS	11:38	12:05	0:27	LINE FAULT
713	23-May-2021	BENGALURU	66	HV1	CHATRA	19:48(22-5-2021)	12:15(23-5-2021)	16:26hrs	TRANSFORMER CHARGED
714	23-May-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	NO STATION AFFECTED	8:21(22-5-2021)			LINE OPEN,LINE FAULT
715	23-May-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	23:04:06(22-5-2021)	9:17:36(23-5-2021)	10:12hrs	LINE CHARGED
716	23-May-2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400	2:55(16.05.2021)			LINE OPEN,LINE FAULT
717	23-May-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:04(15.05.2021)			LINE OPEN,LINE FAULT
718	23-May-2021	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	3:18	3:37	0:19	LINE FAULT
719	23-May-2021	GULBARGA	110	HV2	SHAHAPUR_220	17:40	18:06	0:26	TRANSFORMER FAULT
720	23-May-2021	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	23:34	23:44	0:10	LINE FAULT
721	23-May-2021	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,SHATVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAMALAPUR_110, MATRI_110,RBNS FACTORY	2:22	2:34	0:12	LINE FAULT
722	23-May-2021	GULBARGA	110	HV2	DEODURGA_110	18:35	18:45	0:10	TRANSFORMER FAULT
723	23-May-2021	GULBARGA	110	ALIPUR-METRI	METRI_110	2:20	2:30	0:10	MAIN SUPPLY FAILURE
724	23-May-2021	GULBARGA	110	HV1	METRI_110	21:20	21:25	0:05	TRANSFORMER FAULT
725	23-May-2021	GULBARGA	66	MUNIRABAD- VENKATAPUR	VENKATAPURA_66,RRSTEELS_IPP,UPA NAYAKANAHALLI_66,HAGARIBOMMAN AHALLI_66	18:55	18:59	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
726	23-May-2021	HASSAN	110	HV2	PUTTUR_110	9:34(15.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
727	23-May-2021	HASSAN	110	SORABA-SHR220	SORABA_110	12:31	13:05	0:34	MAIN SUPPLY FAILURE
728	23-May-2021	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	11:13	11:37	0:24	HAND TRIPPED
729	23-May-2021	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	11:40	17:10	5:30	LINE CLEAR AVAILED
730	23-May-2021	HASSAN	66	HV1	YESLUR_66	10:03	16:39	6:36	LINE CLEAR AVAILED
731	23-May-2021	HASSAN	66	YESLUR-SNVRST	YESLUR_66	10:03	16:39	6:36	LINE CLEAR AVAILED
732	23-May-2021	MYSURU	66	KABHALLY-CLEAN SOLAR	NO STATIONS EFFECTED	18:58	20:45	1:47	LINE CLEAR AVAILED
733	23-May-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	9:26	9:32	0:06	HAND TRIPPED
734	23-May-2021	MYSURU	66	KM DODDI-SCSL	NO STATIONS EFFECTED	6:55	14:06	7:11	LINE CLEAR AVAILED
735	23-May-2021	MYSURU	66	SHANIVARSANTHE-YESSLUR	YESSLUR_66	10:02	10:47	0:44	NFBC ISSUED
736	23-May-2021	MYSURU	66	HV5	SFC SIVA_66	13:10	22:02	8:51	LINE CLEAR AVAILED
737	23-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN, LINE CLEAR AVAILED
738	23-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN, LINE CLEAR AVAILED
739	23-May-2021	TUMKUR	220	TR-3(HV SIDE)	CHITRADURGA_220	19:43	20:05	0:22	TRANSFORMER FAULT
740	23-May-2021	TUMKUR	66	ANCHEPALYA 220kV-VIJAYA STEEL	ANCHEPALYA_220	11:00	19:17	8:16	LINE CLEAR AVAILED
741	23-May-2021	TUMKUR	66	BALENAHALLI66-FEFCWIND IPP 66	FEFCWIND IPP_66	14:06	15:05	0:59	LINE CLEAR AVAILED
742	23-May-2021	TUMKUR	66	TR-2	BALENAHALLI_66	1:26	1:30	0:03	TRANSFORMER FAULT
743	23-May-2021	TUMKUR	66	TR-2	BALENAHALLI_66	1:52	1:59	0:07	TRANSFORMER FAULT
744	23-May-2021	TUMKUR	66	CHITRADURGA 220kV-CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	20:12	20:13	0:01	HAND TRIPPED
745	23-May-2021	TUMKUR	66	CHITRADURGA 220kV-HIRIYUR	IMANGALA_66, ENERCON1 IPP_66, HIRIYUR_66	17:25	17:40	0:14	HAND TRIPPED
746	23-May-2021	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	19:43	20:07	0:24	TRANSFORMER FAULT
747	23-May-2021	TUMKUR	66	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	20:05	20:19	0:14	HAND TRIPPED
748	23-May-2021	TUMKUR	66	DAVANGERE SRS-KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:29	6:40	0:11	LINE FAULT
749	23-May-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:24	16:35	0:11	LINE FAULT
750	23-May-2021	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	11:42	11:50	0:08	HAND TRIPPED
751	23-May-2021	TUMKUR	66	HONNALLI 220KV-KUNDUR	KUNDUR_66,MALEBENNUR_66	5:53	6:13	0:19	LINE FAULT
752	23-May-2021	TUMKUR	66	MADHUGIRI 220kV-PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	5:29	5:48	0:18	LINE FAULT
753	23-May-2021	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	13:38	13:53	0:14	LINE FAULT
754	23-May-2021	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	5:51	6:23	0:31	LINE FAULT
755	23-May-2021	TUMKUR	66	TR-2	TELAGI_66	18:55	18:57	0:02	TRANSFORMER FAULT
756	23-May-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	15:37	17:00	1:22	LINE CLEAR AVAILED
757	23-May-2021	TUMKUR	66	TR-2	RANGANATHAPURA_66	16:00	17:00	1:00	LINE CLEAR AVAILED
758	23-May-2021	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-1	INFOSYS-1	10:33	10:43	0:10	LINE FAULT
759	24-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
760	24-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
761	24-May-2021	BAGALKOT	110	RANEENNUR220-HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
762	24-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
763	24-May-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
764	24-May-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
765	24-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
766	24-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVOIDED
767	24-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVOIDED
768	24-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN, LINE CLEAR AVOIDED
769	24-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN, LINE CLEAR AVOIDED
770	24-May-2021	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	18:07 (18.05.2021)			LINE OPEN,LINE FAULT
771	24-May-2021	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MKHUBLI_220	15:09 (22.05.2021)	11:29 (24.05.2021)	44:20HRS	TRANSFORMER CHARGED
772	24-May-2021	BAGALKOT	220	BIDNAL-HARTI 2	BIDNAL_220	17:55 (23.05.2021)			LINE OPEN, LINE CLEAR AVOIDED
773	24-May-2021	BAGALKOT	220	BAGALKOT-GADAG 2	BAGALKOT_220	1:28	2:02	0:34	LINE FAULT
774	24-May-2021	BAGALKOT	220	220/110KV,HV3 &LV3	BAGALKOT_220	1:28	1:48	0:20	TRANSFORMER FAULT
775	24-May-2021	BAGALKOT	220	BAGALKOT-GADAG 2	BAGALKOT_220	2:06	15:20	13:14	LINE CLEAR AVOIDED
776	24-May-2021	BAGALKOT	220	BAGALKOT-GADAG 1	BAGALKOT_220	9:14	15:20	6:06	LINE CLEAR AVOIDED
777	24-May-2021	BAGALKOT	220	BELGAUM-KANABARGI 1	BELGAUM_220	16:15	16:48	0:33	LINE FAULT
778	24-May-2021	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	16:33	16:58	0:25	HAND TRIPPED
779	24-May-2021	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110 &KERUR&KAROSHI_33	1:40	1:48	0:08	TRANSFORMER FAULT
780	24-May-2021	BAGALKOT	110	HIDIKAL-MAHALINGAPUR	HIDIKAL_110	9:26	9:45	0:19	HAND TRIPPED
781	24-May-2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, ALSANGI_33, DHULKED_33	10:21	10:30	0:09	TRANSFORMER FAULT
782	24-May-2021	BAGALKOT	110	110/33KV, HV2	RATTIHALLI_110, HALLUR_33, MASUR_33	11:35	11:47	0:12	LINE CLEAR AVOIDED
783	24-May-2021	BAGALKOT	220	NARENDRA-KANABARGI1(BELGAUM1)	NARENDRA_220	16:15	16:55	0:40	LINE FAULT
784	24-May-2021	BAGALKOT	110	110/11KV, HV2	KAGAWADA_110	19:00	19:10	0:10	LINE CLEAR AVOIDED
785	24-May-2021	BAGALKOT	220	KUDACHI- CHIKKODI2	KUDACHI_220	5:56	6:29	0:33	LINE FAULT
786	24-May-2021	BAGALKOT	110	110/11KV, HV1	ITANAL_110	12:30	12:59	0:29	TRANSFORMER FAULT
787	24-May-2021	BAGALKOT	110	HUNGUND- JINDAL (EHT)	HUNGUND_110	7:50	8:01	0:11	LINE FAULT
788	24-May-2021	BAGALKOT	110	110/11KV, HV4	HUKKERI_110	0:33	2:11	1:38	TRANSFORMER FAULT
789	24-May-2021	BAGALKOT	110	110/11KV, HV4	HUKKERI_110	12:15	12:27	0:12	HAND TRIPPED
790	24-May-2021	BAGALKOT	110	HUKKERI- HATTARGI	HATTARGI_110	13:14	13:20	0:06	HAND TRIPPED
791	24-May-2021	BAGALKOT	220	GADAG- LINGAPUR2 (DHONI2)	GADAG_220	12:22	14:08	1:46	LINE CLEAR AVOIDED
792	24-May-2021	BAGALKOT	220	DHONI- GADAG2	DHONI_400	12:22	14:46	2:24	LINE CLEAR AVOIDED
793	24-May-2021	BENGALURU	66	JAKKASANDRA - ADUGODI	JAKKASANDRA	14:05	14:10	0:05	LOAD CHANGE OVER
794	24-May-2021	BENGALURU	66	HV1	IISC	14:09	14:15	0:06	LINE CLEAR AVOIDED
795	24-May-2021	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT), ST JOHNS	15:23	15:40	0:17	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
796	24-May-2021	BENGALURU	66	HV1	AGALAKOTE	11:50	11:52	0:02	LINE CLEAR AVAILED
797	24-May-2021	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	11:26	11:38	0:12	LINE FAULT
798	24-May-2021	BENGALURU	66	HOSUR RAMAPURA - GOWRIBIDANUR 1	HOSUR RAMAPURA	15:25	15:45	0:20	LINE FAULT
799	24-May-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL	11:00	11:05	0:05	LINE FAULT
800	24-May-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	13:10	13:17	0:07	LOAD CHANGE OVER
801	24-May-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	13:10	13:17	0:07	LOAD CHANGE OVER
802	24-May-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	13:10	13:17	0:07	LOAD CHANGE OVER
803	24-May-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	14:25	14:29	0:04	LOAD CHANGE OVER
804	24-May-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	14:25	14:32	0:07	LOAD CHANGE OVER
805	24-May-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	14:25	14:32	0:07	LOAD CHANGE OVER
806	24-May-2021	BENGALURU	66	HV1	THIMMAMPALLI	12:20	12:25	0:05	LINE CLEAR AVAILED
807	24-May-2021	BENGALURU	66	HV2	THIMMAMPALLI	14:25	14:30	0:05	LINE CLEAR AVAILED
808	24-May-2021	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	5:48	6:01	0:13	LINE FAULT
809	24-May-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	NO STATION AFFECTED	8:21(22-5-2021)			LINE OPEN,LINE FAULT
810	24-May-2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400	2:55(16.05.2021)			LINE OPEN,LINE FAULT
811	24-May-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:04(15.05.2021)			LINE OPEN,LINE FAULT
812	24-May-2021	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	3:33	17:31	13:58	LINE CLEAR AVAILED
813	24-May-2021	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	1:25	1:49	0:24	LINE FAULT
814	24-May-2021	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	15:01	17:29	2:28	LINE CLEAR AVAILED
815	24-May-2021	GULBARGA	110	SINDHNOOR-TEKKALKOTE	TEKKALKOTE_110	1:55	2:15	0:20	MAIN SUPPLY FAILURE
816	24-May-2021	GULBARGA	110	SINDHNOOR-BENNUR	BENNUR_110	10:15	10:25	0:10	MAIN SUPPLY FAILURE
817	24-May-2021	GULBARGA	110	HV1	BENNUR_110	13:20	13:30	0:10	TRANSFORMER FAULT
818	24-May-2021	GULBARGA	110	HV2	GULBARGAUNIVERSITY_110	13:30	14:30	1:00	TRANSFORMER FAULT
819	24-May-2021	GULBARGA	110	GULBARGAUNIVERSITY-SHAHABAD2	GULBARGAUNIVERSITY_110	15:30	15:40	0:10	MAIN SUPPLY FAILURE
820	24-May-2021	GULBARGA	110	HV3	KEREHALLI_110	16:20	16:30	0:10	TRANSFORMER FAULT
821	24-May-2021	GULBARGA	110	HV3	KEREHALLI_110	16:40	16:50	0:10	TRANSFORMER FAULT
822	24-May-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	2:37	2:42	0:05	LINE FAULT
823	24-May-2021	GULBARGA	110	HV2	SHAHAPUR_220	11:50	18:30	6:40	TRANSFORMER FAULT
824	24-May-2021	GULBARGA	110	HV1	SHAHAPUR_220	15:27	15:40	0:13	TRANSFORMER FAULT
825	24-May-2021	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110,DHADESUGAR_110,TEKKALKOTE_110,NSLSUGAR_IPP	1:55	2:05	0:10	LINE FAULT
826	24-May-2021	GULBARGA	110	SINDHNOOR-RAICHUR2	KURDICROSS_110,MADALAPUR_110,M ANVI_110	5:35	6:15	0:40	LINE FAULT
827	24-May-2021	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADO NA_110,SRNAGAR_110,MALLAPUR_110	10:20	10:25	0:05	LINE CLEAR AVAILED
828	24-May-2021	GULBARGA	110	SINDHNOOR-RAICHUR2	KURDICROSS_110,MADALAPUR_110,M ANVI_110	19:35	19:50	0:15	LINE FAULT
829	24-May-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	2:26	2:36	0:10	LINE FAULT
830	24-May-2021	GULBARGA	110	HV2	KAMPLI_110	6:08	6:32	0:24	TRANSFORMER FAULT
831	24-May-2021	GULBARGA	110	HUMNABAD-NIRNA	NIRNA_110	6:55	7:10	0:15	MAIN SUPPLY FAILURE
832	24-May-2021	GULBARGA	110	HV1	NIRNA_110	11:00	11:05	0:05	TRANSFORMER FAULT
833	24-May-2021	GULBARGA	110	HV1	NIRNA_110	12:05	12:10	0:05	TRANSFORMER FAULT
834	24-May-2021	GULBARGA	110	HV1	NIRNA_110	16:05	16:10	0:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
835	24-May-2021	GULBARGA	110	SINDHNOOR-TEKKALKOTE	TEKKALKOTE_110	11:05	11:20	0:15	MAIN SUPPLY FAILURE
836	24-May-2021	GULBARGA	110	SINDHNOOR-MASKI	MASKI_110	4:23	4:33	0:10	MAIN SUPPLY FAILURE
837	24-May-2021	GULBARGA	110	MASKI-RENEWSOLAR_IPP	MASKI_110	4:23	4:33	0:10	LINE FAULT
838	24-May-2021	HASSAN	110	HV1	ALKOLA_110	14:12 (24.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
839	24-May-2021	HASSAN	110	LPH-MGHE 2	lph_gen	9:29 (24.05.2021)			LINE OPEN, LINE CLEAR AVAILED
840	24-May-2021	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	9:54	12:25	2:31	LINE CLEAR AVAILED
841	24-May-2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:26	13:22	2:56	NFBC ISSUED
842	24-May-2021	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:12	13:46	3:34	NFBC ISSUED
843	24-May-2021	HASSAN	66	HV1	AREHALLY_66	11:31	13:38	2:07	LINE CLEAR AVAILED
844	24-May-2021	HASSAN	66	BANDISH-HNPURA	BANDISHETIHALLY_66	18:34	18:40	0:06	HAND TRIPPED
845	24-May-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	7:06	7:21	0:15	LINE FAULT
846	24-May-2021	HASSAN	66	HV2	RAMPURA_66	10:54	11:35	0:41	LINE CLEAR AVAILED
847	24-May-2021	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	12:00	18:34	6:34	LINE CLEAR AVAILED
848	24-May-2021	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	12:00	18:34	6:34	LINE CLEAR AVAILED
849	24-May-2021	MYSURU	66	HV1	DUNDANAHALLI_66	10:15	10:35	0:20	LINE CLEAR AVAILED
850	24-May-2021	MYSURU	66	HANNUR-AMPS SOLAR	NO STATIONS EFFECTED	19:07	19:19	0:12	LINE FAULT
851	24-May-2021	MYSURU	66	HANNUR-KOTHANURU	NO STATIONS EFFECTED	12:18	12:31	0:12	LINE FAULT
852	24-May-2021	MYSURU	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	14:18	14:45	0:26	LINE FAULT
853	24-May-2021	MYSURU	66	KABHALLY-CLEAN SOLAR	NO STATIONS EFFECTED	18:36	20:05	1:28	LINE CLEAR AVAILED
854	24-May-2021	MYSURU	66	PERIYAPATNA-HANAGODU	PONNAMPET_66, VIRAJPET_66	22:48	22:55	0:06	LINE FAULT
855	24-May-2021	MYSURU	66	PERIYAPATNA-HANAGODU	PONNAMPET_66, VIRAJPET_66	22:55 (24/05/2021)			LINE OPEN,LINE FAULT
856	24-May-2021	MYSURU	66	PONNAMPETE-HANAGODU	PONNAMPET_66, VIRAJPET_66	23:18 (24/05/2021)			LINE OPEN, LINE CLEAR AVAILED
857	24-May-2021	MYSURU	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	11:17	11:22	0:04	LINE FAULT
858	24-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN, LINE CLEAR AVAILED
859	24-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN, LINE CLEAR AVAILED
860	24-May-2021	TUMKUR	220	TR-3	CHITRADURGA_220	18:52	19:21	0:28	TRANSFORMER FAULT
861	24-May-2021	TUMKUR	66	ANCHEPALYA 220kV-VIJAYA STEEL	ANCHEPALYA_220	11:10	14:04	2:53	LINE CLEAR AVAILED
862	24-May-2021	TUMKUR	66	TR-3(LV-SIDE)	CHITRADURGA_220	18:52	19:28	0:35	TRANSFORMER FAULT
863	24-May-2021	TUMKUR	66	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	19:22	19:30	0:07	HAND TRIPPED
864	24-May-2021	TUMKUR	66	CHITRADURGA 220kV-HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	19:22	19:30	0:07	HAND TRIPPED
865	24-May-2021	TUMKUR	66	CHITRADURGA 220kV-CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	19:22	19:30	0:07	HAND TRIPPED
866	24-May-2021	TUMKUR	66	CHITRADURGA 220kV-BALENAHALLI-66	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	19:22	19:30	0:07	HAND TRIPPED
867	24-May-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:31	18:43	0:12	LINE FAULT
868	24-May-2021	TUMKUR	66	DYAVARANAHALLI-CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	12:03	13:15	1:12	LINE CLEAR AVAILED
869	24-May-2021	TUMKUR	66	TR-1	GARAGA_66	14:13	15:10	0:56	LINE CLEAR AVAILED
870	24-May-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	23:33	23:42	0:09	LINE FAULT
871	24-May-2021	TUMKUR	66	HONNALLI 220kV-CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	16:20	16:29	0:09	LINE FAULT
872	24-May-2021	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	18:13	19:16	1:02	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
873	24-May-2021	TUMKUR	66	MADHUGIRI 220-KALLAMBELLA(SIRA-2)	KALLAMBELLA_66, SIRA_66	14:10	14:44	0:34	LINE FAULT
874	24-May-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	20:00	20:26	0:26	TRANSFORMER FAULT
875	24-May-2021	TUMKUR	66	TR-1	SHYLAPURA_66	3:24	3:33	0:09	TRANSFORMER FAULT
876	24-May-2021	TUMKUR	66	TR-2	SHYLAPURA_66	9:11	9:15	0:04	TRANSFORMER FAULT
877	24-May-2021	TUMKUR	66	TR-1	TUMKUR_66	15:00	15:36	0:35	TRANSFORMER FAULT