

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM : 08.12.2020 TO 14.12.2020

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	8-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
2	8-Dec-20	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
3	8-Dec-20	BAGALKOT	110	110/11KV,HV1	ANANDNAGAR_110	9:47	12:25	2:38	LINE CLEAR AVAILED
4	8-Dec-20	BAGALKOT	110	110/11KV,HV1	ANANDNAGAR_110	13:22	16:00	2:38	LINE CLEAR AVAILED
5	8-Dec-20	BAGALKOT	110	110/11KV,HV1	DAMBAL_110	02:44	12:25	9:41	TRANSFORMER FAULT
6	8-Dec-20	BAGALKOT	110	110/11KV,HV1	MUNAVALLI_110	16:05	16:50	0:45	LINE CLEAR AVAILED
7	8-Dec-20	BAGALKOT	110	110/11KV,HV1	MUNDAGOD_110	18:02	18:20	0:18	LINE CLEAR AVAILED
8	8-Dec-20	BAGALKOT	110	110/11KV,HV1,HV2	NIPPANI_110	13:02	15:17	2:15	LINE CLEAR AVAILED
9	8-Dec-20	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	12:30	14:20	1:50	LINE CLEAR AVAILED
10	8-Dec-20	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	17:15	17:30	0:15	LINE CLEAR AVAILED
11	8-Dec-20	BAGALKOT	110	110/11KV,HV2	NIDAGINDI_110	6:14	8:57	2:43	TRANSFORMER FAULT
12	8-Dec-20	BAGALKOT	110	110/11KV,HV2	ITNAL_110	9:35	9:44	0:09	TRANSFORMER FAULT
13	8-Dec-20	BAGALKOT	110	110/33KV,HV1,HV2	JAMAKHANDI_110,HIPPARAGI_33	12:03	13:30	1:27	LINE CLEAR AVAILED
14	8-Dec-20	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,KARADI_33,AMINAGAD_33,MY TRA SOLAR_33	08:15	08:24	0:09	TRANSFORMER FAULT
15	8-Dec-20	BAGALKOT	110	110/33KV,HV2	NIPPANI_110,JATRAT_33,BENADI_33	15:18	16:50	1:32	LINE CLEAR AVAILED
16	8-Dec-20	BAGALKOT	110	110/33KV,HV2	NIPPANI_110,JATRAT_33,BENADI_33	13:02	15:17	2:15	LINE CLEAR AVAILED
17	8-Dec-20	BAGALKOT	110	110/33KV,HV3	LAXMESHWAR_110,MMCL_33,SSM_33	14:18	15:24	1:06	TRANSFORMER FAULT
18	8-Dec-20	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110,ALNAVAR_33	01:10	01:40	0:30	TRANSFORMER FAULT
19	8-Dec-20	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
20	8-Dec-20	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN:LINE CLEAR AVAILED
21	8-Dec-20	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	11:41 (28.11.2020)			LINE OPEN:LINE CLEAR AVAILED
22	8-Dec-20	BAGALKOT	110	CHIKKODI-NIPPANI	NIPPANI_110	13:02	15:17	2:15	LINE CLEAR AVAILED
23	8-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
24	8-Dec-20	BAGALKOT	110	HSSK-NIPPANI	NIPPANI_110	13:02	15:17	2:15	LINE CLEAR AVAILED
25	8-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
26	8-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
27	8-Dec-20	BAGALKOT	110	NARENDRA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED MRUTHYUNJAYANAGAR_110	11:40	15:14	3:34	LINE CLEAR AVAILED
28	8-Dec-20	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
29	8-Dec-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
30	8-Dec-20	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	06:00	17:48	11:48	LINE FAULT
31	8-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN:LINE CLEAR AVAILED
32	8-Dec-20	BAGALKOT	220	BAGEWADI-MASUTI LIS	BAGEWADI_220	11:35	12:05	0:30	LINE CLEAR AVAILED
33	8-Dec-20	BAGALKOT	220	CHIMMALAGI LIS-BAGEWADI	BAGEWADI_220	05:50	06:12	0:22	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
34	8-Dec-20	BAGALKOT	220	GHATAPRABHA-CHIKKODI	GHATAPRABHA_220	6:39 (07.12.2020)			LINE OPEN:LINE CLEAR AVAILED
35	8-Dec-20	BAGALKOT	220	KUDUCHI-GHATAPRABHA	KUDUCHI_220	6:39 (07.12.2020)			LINE OPEN:LINE CLEAR AVAILED
36	8-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
37	8-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
38	8-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
39	8-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
40	8-Dec-20	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	10:10	10:45	00:35	LINE FAULT
41	8-Dec-20	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	13:10	13:15	00:05	LOAD CHANGE OVER
42	8-Dec-20	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	12:20	12:25	00:05	LINE FAULT
43	8-Dec-20	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	12:20	12:25	00:05	LINE FAULT
44	8-Dec-20	BENGALURU	66	KOLAR 220 - NARASAPURA 2	MALUR I/A, JADIGENAHALLI	14:10	14:25	00:15	LINE FAULT
45	8-Dec-20	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	06:26	06:36	00:10	LINE FAULT
46	8-Dec-20	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	12:36	12:40	00:04	LINE FAULT
47	8-Dec-20	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	11:51	11:55	00:04	LOAD CHANGE OVER
48	8-Dec-20	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	10:12	10:20	00:08	LOAD CHANGE OVER
49	8-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
50	8-Dec-20	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 1	NO STATION AFFECTED	23:08 (07-12-2020)	7:00(08/12/2020)	7:52HRS	LINE CHARGED
51	8-Dec-20	GULBARGA	66	GUDEKOTE-KUDLIGI	GUDEKOTE_66	10:05	17:55	07:50	NFBC ISSUED
52	8-Dec-20	GULBARGA	66	HOSAHALLI-CJHALLI	HOSAHALLI_66	10:00	18:00	08:00	LINE CLEAR AVAILED
53	8-Dec-20	GULBARGA	110	HANUMANAL-HIREGONNAGAR	HANUMANAL_110	20:20	21:10	00:50	MAIN SUPPLY FAILURE
54	8-Dec-20	GULBARGA	110	HANUMASAGAR-KUSHTAGI	HANUMASAGAR_110,HANUMNAL_110,HIREGO NNAGAR	20:25	20:40	00:15	MAIN SUPPLY FAILURE
55	8-Dec-20	GULBARGA	110	HV1,HV2	HANUMANAL_110	20:30	21:15	00:45	TRANSFORMER FAULT
56	8-Dec-20	GULBARGA	110	HV2	MANVI_110	13:24	13:33	00:09	TRANSFORMER FAULT
57	8-Dec-20	GULBARGA	110	HV2	MANVI_110	17:41	17:53	00:12	TRANSFORMER FAULT
58	8-Dec-20	GULBARGA	110	HV3	KOLAHR_110	15:41	15:50	00:09	LINE CLEAR AVAILED
59	8-Dec-20	GULBARGA	110	MANVI-MALLAT	MANVI_110	05:13	05:22	00:09	MAIN SUPPLY FAILURE
60	8-Dec-20	GULBARGA	220	ALIPUR-GOOTY	GOOTY_220	05:19	05:42	00:23	LINE FAULT
61	8-Dec-20	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	14:44	18:55	04:11	LINE CLEAR AVAILED
62	8-Dec-20	GULBARGA	400	JSWVL-GUTTUR	GUTTUR_400	21:36(7/12/2020)			LINE OPEN: LINE FAULT
63	8-Dec-20	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	10:36	13:42	03:06	LINE CLEAR AVAILED
64	8-Dec-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:56 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
65	8-Dec-20	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	16:26 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
66	8-Dec-20	HASSAN	66	CRPATNA-HNPURA	CRPATNA_220	09:33	11:47	02:14	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
67	8-Dec-20	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	17:38	17:40	00:02	HAND TRIPPED
68	8-Dec-20	HASSAN	66	HADAVAN-HNPURA	HADAVANAHALLY_66	10:00	17:40	07:40	NFBC ISSUED
69	8-Dec-20	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	10:03	17:35	07:32	LINE CLEAR AVAILED
70	8-Dec-20	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	10:04	17:28	07:24	LINE CLEAR AVAILED
71	8-Dec-20	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	10:04	17:36	07:32	LINE CLEAR AVAILED
72	8-Dec-20	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	17:47	18:23	00:36	LINE FAULT
73	8-Dec-20	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	10:04	17:36	07:32	LINE CLEAR AVAILED
74	8-Dec-20	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	10:03	17:32	07:29	LINE CLEAR AVAILED
75	8-Dec-20	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	10:03	17:34	07:31	LINE CLEAR AVAILED
76	8-Dec-20	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	10:03	17:34	07:31	LINE CLEAR AVAILED
77	8-Dec-20	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	10:03	17:34	07:31	LINE CLEAR AVAILED
78	8-Dec-20	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	10:03	17:33	07:30	LINE CLEAR AVAILED
79	8-Dec-20	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	10:26	17:33	07:07	LINE CLEAR AVAILED
80	8-Dec-20	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	10:26	17:35	07:09	LINE CLEAR AVAILED
81	8-Dec-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:04	17:44	07:40	MAIN SUPPLY FAILURE
82	8-Dec-20	HASSAN	66	HV1	BELUR_66	12:00	13:15	01:15	LINE CLEAR AVAILED
83	8-Dec-20	HASSAN	66	HV1	DUDDA_66	12:15	13:00	00:45	LINE CLEAR AVAILED
84	8-Dec-20	HASSAN	66	HV1	HANGARANAHALLY_66	10:05	17:30	07:25	LINE CLEAR AVAILED
85	8-Dec-20	HASSAN	66	HV1	HOLENARASIPURA_220	10:05	17:29	07:24	LINE CLEAR AVAILED
86	8-Dec-20	HASSAN	66	HV1	HNPURA_66	10:05	17:35	07:30	LINE CLEAR AVAILED
87	8-Dec-20	HASSAN	66	HV1	MALALI_66	10:06	17:36	07:30	MAIN SUPPLY FAILURE
88	8-Dec-20	HASSAN	66	HV1	MALALI_66	17:48	18:25	00:37	MAIN SUPPLY FAILURE
89	8-Dec-20	HASSAN	66	HV1	SHANTHIGRAMMA_66	10:05	17:45	07:40	MAIN SUPPLY FAILURE
90	8-Dec-20	HASSAN	66	HV1	SHANTHIGRAMMA_66	17:50	18:30	00:40	MAIN SUPPLY FAILURE
91	8-Dec-20	HASSAN	66	HV2	BELUR_66	10:41	12:10	01:29	LINE CLEAR AVAILED
92	8-Dec-20	HASSAN	66	HV2	HNPURA_66	10:05	17:35	07:30	LINE CLEAR AVAILED
93	8-Dec-20	HASSAN	66	HV2	HOLEHONNUR_66	15:09	16:03	00:54	LINE CLEAR AVAILED
94	8-Dec-20	HASSAN	66	HV2	SHANTHIGRAMMA_66	10:05	17:45	07:40	MAIN SUPPLY FAILURE
95	8-Dec-20	HASSAN	66	HV2	SHANTHIGRAMMA_66	17:50	18:30	00:40	MAIN SUPPLY FAILURE
96	8-Dec-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	12:54	13:44	00:50	LINE CLEAR AVAILED
97	8-Dec-20	HASSAN	66	Lv1	HOLENARASIPURA_220	10:06	17:28	07:22	LINE CLEAR AVAILED
98	8-Dec-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
99	8-Dec-20	HASSAN	66	Lv2	HOLENARASIPURA_220	10:06	17:28	07:22	LINE CLEAR AVAILED
100	8-Dec-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
101	8-Dec-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
102	8-Dec-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	10:06	17:43	07:37	MAIN SUPPLY FAILURE
103	8-Dec-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	17:48	18:32	00:44	MAIN SUPPLY FAILURE
104	8-Dec-20	HASSAN	66	MALALI-HASSAN	MALALI_66	10:06	17:36	07:30	MAIN SUPPLY FAILURE
105	8-Dec-20	HASSAN	66	MRSSHMBD-1	MRSMSG_220	16:26 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
106	8-Dec-20	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	10:45	12:39	01:54	LINE CLEAR AVAILED
107	8-Dec-20	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	09:34	11:49	02:15	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
108	8-Dec-20	HASSAN	66	SOMNHL-GDNEHALI	SOMANAHALI_66	10:53	17:36	06:43	MAIN SUPPLY FAILURE
109	8-Dec-20	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	19:02	20:01	00:59	LINE FAULT
110	8-Dec-20	HASSAN	110	HV1	MSEZ_220	17:46	19:41	01:55	LINE CLEAR AVAILED
111	8-Dec-20	HASSAN	110	HV1	BARANGI_110	12:04	14:20	02:16	LINE CLEAR AVAILED
112	8-Dec-20	HASSAN	110	HV1	KEMAR_220	10:35	11:53	01:18	LINE CLEAR AVAILED
113	8-Dec-20	HASSAN	110	HV2	HALADY_110	15:15	16:17	01:02	LINE CLEAR AVAILED
114	8-Dec-20	HASSAN	110	HV2	KULASHEKARA_110	09:50	14:09	04:19	LINE CLEAR AVAILED
115	8-Dec-20	HASSAN	110	HV2	NAVUNDA_110	10:24	16:50	06:26	LINE CLEAR AVAILED
116	8-Dec-20	HASSAN	110	LV2	SHIRALKOPPA_220	15:14	16:49	01:35	LINE CLEAR AVAILED
117	8-Dec-20	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:22	11:59	01:37	LINE CLEAR AVAILED
118	8-Dec-20	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	12:01	14:01	02:00	LINE CLEAR AVAILED
119	8-Dec-20	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	14:25	15:01	00:36	HAND TRIPPED
120	8-Dec-20	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	22:38 (8.12.2020)			LINE OPEN: LINE FAULT
121	8-Dec-20	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	10:06	13:16	03:10	LINE CLEAR AVAILED
122	8-Dec-20	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	14:27	14:58	00:31	HAND TRIPPED
123	8-Dec-20	HASSAN	220	HV2	SHIRALKOPPA_220	15:14	16:49	01:35	LINE CLEAR AVAILED
124	8-Dec-20	HASSAN	220	HV2	GOPALAPURA_220	09:01	20:30	11:29	LINE CLEAR AVAILED
125	8-Dec-20	HASSAN	220	KADUR-SHIMOGA	KADUR_220	18:33 (8.12.2020)			LINE OPEN: LINE FAULT
126	8-Dec-20	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	18:33 (8.12.2020)			LINE OPEN: LINE FAULT
127	8-Dec-20	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	14:25	15:01	00:36	HAND TRIPPED
128	8-Dec-20	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	22:38 (8.12.2020)			LINE OPEN: LINE FAULT
129	8-Dec-20	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	10:06	13:16	03:10	LINE CLEAR AVAILED
130	8-Dec-20	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	14:27	14:58	00:31	HAND TRIPPED
131	8-Dec-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:17(7.12.2020)	7:57 (8.12.2020)	8:39 hrs	LINE CHARGED
132	8-Dec-20	MYSORE	66	BOGADHI-HOOTAGALLI	BOGADHI_66	10:25	14:30	4:05	LINE CLEAR AVAILED
133	8-Dec-20	MYSORE	66	HOOTAGALLI-BARC2	NO STATIONS EFFECTED	15:10	15:22	0:12	LINE FAULT
134	8-Dec-20	MYSORE	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	11:18	12:36	1:18	LINE CLEAR AVAILED
135	8-Dec-20	MYSORE	66	HV1	MANDGERE_66	11:05	12:10	1:05	LINE CLEAR AVAILED
136	8-Dec-20	MYSORE	66	HV1	MANDGERE_66	14:35	15:00	0:25	LINE CLEAR AVAILED
137	8-Dec-20	MYSORE	66	HV1	NAGAMANGALA_66	12:50	12:56	0:06	HAND TRIPPED
138	8-Dec-20	MYSORE	66	HV2	NAGAMANGALA_66	12:50	12:57	0:07	HAND TRIPPED
139	8-Dec-20	MYSORE	66	HV2	SANTHEMARAHALLI_66	9:45 (08.12.2020)			LINE OPEN:LINE CLEAR AVAILED
140	8-Dec-20	MYSORE	66	HV2	CHANDAKAVADI_66	12:43 (07.12.2020)	14:35 (08.12.2020)	25:52HRS	LINE CHARGED
141	8-Dec-20	MYSORE	66	KADAKOLA-SARGUR 2	DOORA_66 HURA_66 HULLAHALLI_66	10:10	12:30	2:20	NFBC ISSUED
142	8-Dec-20	MYSORE	66	KALAMANDIR-BOGADHI	KALAMANDIRA_66	10:40	14:45	4:05	NFBC ISSUED
143	8-Dec-20	MYSORE	66	KIKKERI-KR PETE	KIKKERI_66	10:15	18:23	8:08	LINE CLEAR AVAILED
144	8-Dec-20	MYSORE	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	4:45 (19.11.2020)			LINE OPEN: LINE FAULT
145	8-Dec-20	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	17:28	17:34	0:06	LINE FAULT
146	8-Dec-20	MYSORE	66	MANDAGERE-HN PURA	MANDGERE_66	10:00	10:45	0:45	MAIN SUPPLY FAILURE
147	8-Dec-20	MYSORE	66	MANDAGERE-HN PURA	MANDGERE_66	16:00	17:35	1:35	MAIN SUPPLY FAILURE
148	8-Dec-20	MYSORE	66	VIJAYANAGARA-HOOTAGALLI	NO STATIONS EFFECTED	9:09	12:20	3:10	NFBC ISSUED
149	8-Dec-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	17:58	18:00	0:01	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
150	8-Dec-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	8:19	8:22	0:02	MAIN SUPPLY FAILURE
151	8-Dec-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	5:55	6:02	0:07	HAND TRIPPED
152	8-Dec-20	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	1:09	1:12	0:02	LINE FAULT
153	8-Dec-20	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	AVNTI_SLR_IPP_66	14:06	14:13	0:06	HAND TRIPPED
154	8-Dec-20	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	14:06	14:13	0:06	HAND TRIPPED
155	8-Dec-20	TUMKUR	66	MATHOD-RAMCO CEMENT _EHT_66	RAMCO CEMENT _EHT_66	14:06	14:13	0:06	HAND TRIPPED
156	8-Dec-20	TUMKUR	66	TR-1	MATHOD_66	14:05	14:12	0:06	HAND TRIPPED
157	8-Dec-20	TUMKUR	66	TR-2	HALURAMESHWARA_66	17:13(07.12.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
158	8-Dec-20	TUMKUR	66	TR-2	MATHOD_66	14:06	14:12	0:06	HAND TRIPPED
159	8-Dec-20	TUMKUR	110	K G TEMPLE-NITTUR220	KGTEMPLE_110	13:02	13:03	0:01	LINE CLEAR AVAILED
160	8-Dec-20	TUMKUR	220	TR-3	HIRIYUR_220	6:56	11:57	5:01	TRANSFORMER FAULT
161	9-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
162	9-Dec-20	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED VAJJRAMATTI	16:01	16:47	0:46	HAND TRIPPED
163	9-Dec-20	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	17:21	17:54	0:33	LINE CLEAR AVAILED
164	9-Dec-20	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
165	9-Dec-20	BAGALKOT	110	110/11KV,HV1	GULEDAGUDDA_110	11:19	11:33	0:14	LINE CLEAR AVAILED
166	9-Dec-20	BAGALKOT	110	110/11KV,HV2	GULEDAGUDDA_110	12:25	12:30	0:05	LINE CLEAR AVAILED
167	9-Dec-20	BAGALKOT	110	110/33KV,HV1(HV2)	GULEDAGUDDA_110,KAMATAGI_33,SHIRUR_110	11:04	11:17	0:13	LINE CLEAR AVAILED
168	9-Dec-20	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
169	9-Dec-20	BAGALKOT	110	AMBEWADI-SUPA1	STATION NOT AFFECTED AMBEWADI_220	6:26	06:39	0:13	LINE FAULT
170	9-Dec-20	BAGALKOT	110	ANKOLA-KUMTA2	STATION NOT AFFECTED ANKOLA_110	23:11 (09.12.2020)			LINE OPEN: LINE FAULT
171	9-Dec-20	BAGALKOT	110	BAGALKOT-NEERBUDIHAI	NEERBUDIHAI_110	15:29	16:08	0:39	LINE CLEAR AVAILED
172	9-Dec-20	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN:LINE CLEAR AVAILED
173	9-Dec-20	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	11:41 (28.11.2020)			LINE OPEN:LINE CLEAR AVAILED
174	9-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
175	9-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
176	9-Dec-20	BAGALKOT	110	KARWAR-ARGA	STATION NOT AFFECTED ARGA_110	15:18	15:35	0:17	HAND TRIPPED
177	9-Dec-20	BAGALKOT	110	KARWAR-ARGA	STATION NOT AFFECTED ARGA_110	17:52	17:59	0:07	HAND TRIPPED
178	9-Dec-20	BAGALKOT	110	KARWAR-SOLARIS(BINAGA)	BINAGA_110	16:04	17:52	1:48	LINE CLEAR AVAILED
179	9-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
180	9-Dec-20	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
181	9-Dec-20	BAGALKOT	110	SOUDATTI220-UDAKERI	UDIKERI_110	10:30	17:24	6:54	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
182	9-Dec-20	BAGALKOT	110	ZALKI-CHADACHAN	CHADACHAN_110	00:21	00:28	0:07	LINE FAULT
183	9-Dec-20	BAGALKOT	110	ZALKI-INDI	ZALAKI_110	00:21	00:28	0:07	LINE FAULT
184	9-Dec-20	BAGALKOT	220	220/110, HV1 & LV1	STATION NOT AFFECTED VAJJRAMATTI_220	09:44	11:16	1:32	LINE CLEAR AVOIDED
185	9-Dec-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
186	9-Dec-20	BAGALKOT	220	BAGALKOT-GADAG2	STATION NOT AFFECTED BAGALKOT_220	11:09 (09.12.2020)			LINE OPEN:LINE CLEAR AVOIDED
187	9-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN:LINE CLEAR AVOIDED
188	9-Dec-20	BAGALKOT	220	BAGEWADI-BALUTI LIS	BALUTI LIS_220	10:39	15:20	4:41	LINE CLEAR AVOIDED
189	9-Dec-20	BAGALKOT	220	GADAG-DHONI2	STATION NOT AFFECTED GADAG_220	16:39	17:10	0:31	LINE CLEAR AVOIDED
190	9-Dec-20	BAGALKOT	220	GHATAPRABHA-CHIKKODI	GHATAPRABHA_220	6:39 (07.12.2020)			LINE OPEN:LINE CLEAR AVOIDED
191	9-Dec-20	BAGALKOT	220	KARWAR-KADRA1	KARAWAR_220	16:04 (09.12.2020)			LINE OPEN: LINE FAULT
192	9-Dec-20	BAGALKOT	220	KARWAR-KADRA2	KARAWAR_220	11:25	17:40	6:15	LINE CLEAR AVOIDED
193	9-Dec-20	BAGALKOT	220	KUDUCHI-GHATAPRABHA	KUDUCHI_220	6:39 (07.12.2020)			LINE OPEN:LINE CLEAR AVOIDED
194	9-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
195	9-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
196	9-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVOIDED
197	9-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
198	9-Dec-20	BENGALURU	66	HV1	ATTUR YELAHANKA	20:00 (08-12-2020)	00:26	04:26	TRANSFORMER FAULT
199	9-Dec-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHAGAR, YEDUMADU, GODUR	08:45	09:58	01:13	LINE CLEAR AVOIDED
200	9-Dec-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHAGAR, YEDUMADU, GODUR	17:15	18:34	01:19	LINE CLEAR AVOIDED
201	9-Dec-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	09:51	10:35	00:43	LINE CLEAR AVOIDED
202	9-Dec-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	12:55	14:12	01:17	LINE CLEAR AVOIDED
203	9-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVOIDED
204	9-Dec-20	GULBARGA	110	HV2	MANVI_110	09:01	09:25	00:24	TRANSFORMER FAULT
205	9-Dec-20	GULBARGA	110	HV2	MANVI_110	12:31	12:41	00:10	TRANSFORMER FAULT
206	9-Dec-20	GULBARGA	110	HV2	YELBURGA_110	15:00	15:18	00:18	LINE CLEAR AVOIDED
207	9-Dec-20	GULBARGA	110	HV3	YELBURGA_110	15:00	17:04	02:04	LINE CLEAR AVOIDED
208	9-Dec-20	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	03:57	04:05	00:08	LINE FAULT
209	9-Dec-20	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	06:18	06:27	00:09	LINE FAULT
210	9-Dec-20	GULBARGA	220	HV1	RAICHUR_220	10:58	12:17	01:19	LINE CLEAR AVOIDED
211	9-Dec-20	GULBARGA	400	JSWVL-GUTTUR	GUTTUR_400	21:36(7/12/2020)	15:39(9/12/2020)	42:03 HRS	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
212	9-Dec-20	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:06	11:33	00:27	LINE FAULT
213	9-Dec-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:56 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
214	9-Dec-20	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	16:26 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
215	9-Dec-20	HASSAN	66	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	13:05	13:41	00:36	LINE CLEAR AVAILED
216	9-Dec-20	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	12:12	12:37	00:25	LINE CLEAR AVAILED
217	9-Dec-20	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	00:03	00:06	00:03	LINE FAULT
218	9-Dec-20	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	07:37	07:45	00:08	LINE FAULT
219	9-Dec-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	11:02	12:17	01:15	MAIN SUPPLY FAILURE
220	9-Dec-20	HASSAN	66	HV1	HANBALU_66	12:12	12:37	00:25	LINE CLEAR AVAILED
221	9-Dec-20	HASSAN	66	HV1	HNPURA_66	07:41	07:45	00:04	MAIN SUPPLY FAILURE
222	9-Dec-20	HASSAN	66	HV1	MALALI_66	11:02	13:34	02:32	LINE CLEAR AVAILED
223	9-Dec-20	HASSAN	66	HV2	HOLALUR_66	21:27(9.12.2020)			LINE OPEN:LINE CLEAR AVAILED
224	9-Dec-20	HASSAN	66	HV2	HNPURA_66	07:41	07:45	00:04	MAIN SUPPLY FAILURE
225	9-Dec-20	HASSAN	66	HV2	MATNAVILE_66	15:59	16:27	00:28	LINE CLEAR AVAILED
226	9-Dec-20	HASSAN	66	HV2	SHRAVANABELAGOLA_66	11:48	14:04	02:16	LINE CLEAR AVAILED
227	9-Dec-20	HASSAN	66	HV2	SHANTHIGRAMMA_66	08:40	10:17	01:37	LINE CLEAR AVAILED
228	9-Dec-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
229	9-Dec-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
230	9-Dec-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
231	9-Dec-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	11:01	12:16	01:15	LINE CLEAR AVAILED
232	9-Dec-20	HASSAN	66	MALALI-HASSAN	MALALI_66	11:02	12:16	01:14	LINE CLEAR AVAILED
233	9-Dec-20	HASSAN	66	MRSSHMBD-1	MRSMSG_220	16:26 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
234	9-Dec-20	HASSAN	66	PMWNGR-SHANTI	RAMESHWARNAGAR_66	12:08	12:17	00:09	HAND TRIPPED
235	9-Dec-20	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	11:23	11:27	00:04	HAND TRIPPED
236	9-Dec-20	HASSAN	66	SAKALE-IPCL2	SAKLESHUPURA_66	21:00	21:12	00:12	LINE FAULT
237	9-Dec-20	HASSAN	110	HV1	MSEZ_220	12:22	16:28	04:06	LINE CLEAR AVAILED
238	9-Dec-20	HASSAN	110	HV1	KONAJE_110	16:13	16:16	00:03	HAND TRIPPED
239	9-Dec-20	HASSAN	110	HV1	KONAJE_110	16:22	16:26	00:04	HAND TRIPPED
240	9-Dec-20	HASSAN	110	HV2	KONAJE_110	16:13	16:16	00:03	HAND TRIPPED
241	9-Dec-20	HASSAN	110	HV2	KONAJE_110	16:22	16:26	00:04	HAND TRIPPED
242	9-Dec-20	HASSAN	110	HV3	KONAJE_110	10:15	15:16	05:01	LINE CLEAR AVAILED
243	9-Dec-20	HASSAN	110	HV3	KONAJE_110	16:13	16:16	00:03	HAND TRIPPED
244	9-Dec-20	HASSAN	110	HV3	KONAJE_110	16:22	16:26	00:04	HAND TRIPPED
245	9-Dec-20	HASSAN	110	LV1	MSEZ_220	11:00	15:54	04:54	LINE CLEAR AVAILED
246	9-Dec-20	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	22:38 (8.12.2020)			LINE OPEN: LINE FAULT
247	9-Dec-20	HASSAN	220	HV1	MSEZ_220	11:00	15:54	04:54	LINE CLEAR AVAILED
248	9-Dec-20	HASSAN	220	KADU-SHIMOGA	KADUR_220	18:33 (8.12.2020)	9:18 (9.12.2020)	14:44 hrs	LINE CHARGED
249	9-Dec-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:16	11:51	01:35	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
250	9-Dec-20	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	18:33 (8.12.2020)	9:18 (9.12.2020)	14:44 hrs	LINE CHARGED
251	9-Dec-20	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	14:38	17:30	02:52	LINE FAULT
252	9-Dec-20	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	09:59	14:36	04:37	LINE CLEAR AVAILED
253	9-Dec-20	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	22:38 (8.12.2020)			LINE OPEN: LINE FAULT
254	9-Dec-20	HASSAN	220	VARAH1-KEMAR1	varahi_gen	10:16	11:51	01:35	LINE CLEAR AVAILED
255	9-Dec-20	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	14:38	17:30	02:52	LINE FAULT
256	9-Dec-20	MYSORE	66	CR NAGARA-PANYADAHUNDI	NO STATIONS EFFECTED	19:18 (09.12.2020)			LINE OPEN:LINE CLEAR AVAILED
257	9-Dec-20	MYSORE	66	DEVNUR(N'GUD)-BAS 2	NO STATIONS EFFECTED	13:51	14:00	0:08	HAND TRIPPED
258	9-Dec-20	MYSORE	66	FTS-RAJEEV NAGARA	FTS_66	10:10	16:59	6:49	LINE CLEAR AVAILED
259	9-Dec-20	MYSORE	66	HV1	BILIKERE_66	14:45	16:43	1:58	LINE CLEAR AVAILED
260	9-Dec-20	MYSORE	66	HV1	DEVANOORNGUDU_66	17:05	17:20	0:15	LINE CLEAR AVAILED
261	9-Dec-20	MYSORE	66	HV1	PONNAMPET_66	11:00	13:20	2:20	LINE CLEAR AVAILED
262	9-Dec-20	MYSORE	66	HV2	DUNDANAHALLI_66	13:57	14:15	0:17	LINE CLEAR AVAILED
263	9-Dec-20	MYSORE	66	HV2	KADAKOLA_220	11:00	16:32	5:32	LINE CLEAR AVAILED
264	9-Dec-20	MYSORE	66	HV2	SANTHEMARAHALLI_66	9:45 (08.12.2020)			LINE OPEN:LINE CLEAR AVAILED
265	9-Dec-20	MYSORE	66	JYOTHINAGARA-FTS	FTS_66	10:36	16:14	5:37	NFBC ISSUED
266	9-Dec-20	MYSORE	66	KHB STATION-HOOTAGALLI	KHBCOLONY_66	10:30	16:37	6:07	LINE CLEAR AVAILED
267	9-Dec-20	MYSORE	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	4:45 (19.11.2020)			LINE OPEN:LINE CLEAR AVAILED
268	9-Dec-20	MYSORE	66	KR PETE-AKKIHEBBAL 1	AKKIHEBBAL_66	0:17	0:29	0:11	LINE FAULT
269	9-Dec-20	MYSORE	66	KR PETE-AKKIHEBBAL 1	AKKIHEBBAL_66	6:09	6:19	0:10	LINE FAULT
270	9-Dec-20	MYSORE	66	KR PETE-AKKIHEBBAL 2	AKKIHEBBAL_66	0:17	0:29	0:11	LINE FAULT
271	9-Dec-20	MYSORE	66	KR PETE-AKKIHEBBAL 2	AKKIHEBBAL_66	6:09	6:19	0:10	LINE FAULT
272	9-Dec-20	MYSORE	66	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	1:54	10:29	8:35	LINE CLEAR AVAILED
273	9-Dec-20	MYSORE	66	PERIYAPATNA-HANGOD	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	10:13	10:25	0:12	LINE FAULT
274	9-Dec-20	MYSORE	66	VAJMANGALA-BANNUR	BANNUR_66	11:47	11:54	0:07	LINE FAULT
275	9-Dec-20	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	17:59	18:20	0:21	LINE FAULT
276	9-Dec-20	TUMKUR	66	BASAVAPATNA-VESTAS	VESTAS SOLAR_IPP_66	2:13	2:53	0:40	LINE FAULT
277	9-Dec-20	TUMKUR	66	BASAVAPATNA-VESTAS	VESTAS SOLAR_IPP_66	7:38	7:48	0:10	LINE FAULT
278	9-Dec-20	TUMKUR	66	BASAVAPATNA-VESTAS	VESTAS SOLAR_IPP_66	12:44	12:49	0:05	LINE FAULT
279	9-Dec-20	TUMKUR	66	BASAVAPATNA-VESTAS	VESTAS SOLAR_IPP_66	13:19	13:21	0:01	LINE FAULT
280	9-Dec-20	TUMKUR	66	BENKIKERE-NALLUR	BENKIKERE_66	10:24	11:14	0:49	HAND TRIPPED
281	9-Dec-20	TUMKUR	66	CHITRADURGA 220kv- CHALLAKERE	CHALLAKERE_66,BALENAHALLI_66	1:51	2:05	0:13	LINE FAULT
282	9-Dec-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:05	11:17	0:12	LINE FAULT
283	9-Dec-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:36	12:00	0:23	LINE FAULT
284	9-Dec-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:21	12:42	0:21	LINE FAULT
285	9-Dec-20	TUMKUR	66	HARAPPANAHALLI-NEELAGUNDA	HARAPPANAHALLI_66	11:26	11:46	0:20	LINE FAULT
286	9-Dec-20	TUMKUR	66	HARAPPANAHALLI-SUZLON 2	SUZLON_IPP_66	11:46(09.12.2020)			LINE OPEN: LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
287	9-Dec-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	17:54	17:58	0:04	LINE FAULT
288	9-Dec-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	14:21	14:33	0:12	LINE FAULT
289	9-Dec-20	TUMKUR	66	TR-1	BENKIKERE_66	6:48	6:53	0:04	HAND TRIPPED
290	9-Dec-20	TUMKUR	66	TR-1	BENKIKERE_66	10:24	11:45	1:20	LINE CLEAR AVAILED
291	9-Dec-20	TUMKUR	66	TR-1	HOLALKERE_66	11:20	12:38	1:18	LINE CLEAR AVAILED
292	9-Dec-20	TUMKUR	66	TR-1	KATTIGE_66	14:09	14:40	0:31	MAIN SUPPLY FAILURE
293	9-Dec-20	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	9:53	13:08	3:15	LINE CLEAR AVAILED
294	9-Dec-20	TUMKUR	66	TR-2	BENKIKERE_66	10:24	11:46	1:21	LINE CLEAR AVAILED
295	9-Dec-20	TUMKUR	110	HONNAVALLI 110-DMKURKE	DMKURKE_110	15:03	16:55	1:51	LINE CLEAR AVAILED
296	9-Dec-20	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	12:54	14:40	1:45	LINE CLEAR AVAILED
297	9-Dec-20	TUMKUR	110	TR-2	SAMPIGE_110	3:04	3:14	0:10	TRANSFORMER FAULT
298	9-Dec-20	TUMKUR	110	TR-2	SAMPIGE_110	8:58	15:07	6:09	LINE CLEAR AVAILED
299	9-Dec-20	TUMKUR	220	TR-1(HV SIDE)	ANCHEPALYA_220	9:53	13:07	3:13	LINE CLEAR AVAILED
300	10-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
301	10-Dec-20	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
302	10-Dec-20	BAGALKOT	110	110/11KV,HV1	KADANAKOPPA_110	7:54	12:59	5:05	LINE CLEAR AVAILED
303	10-Dec-20	BAGALKOT	110	110/11KV,HV1	KADANAKOPPA_110	14:48	15:13	0:25	LINE CLEAR AVAILED
304	10-Dec-20	BAGALKOT	110	110/11KV,HV1	RANNABELAGALI_110	08:15	9:18	1:03	LINE CLEAR AVAILED
305	10-Dec-20	BAGALKOT	110	110/11KV,HV2	KADANAKOPPA_110	12:51	15:06	2:15	LINE CLEAR AVAILED
306	10-Dec-20	BAGALKOT	110	110/11KV,HV2	RANNABELAGALI_110	08:16	8:52	0:36	LINE CLEAR AVAILED
307	10-Dec-20	BAGALKOT	110	110/11KV,HV2	RANNABELAGALI_110	9:03	9:18	0:15	LINE CLEAR AVAILED
308	10-Dec-20	BAGALKOT	110	110/11KV,HV3	LOKAPUR_110	03:00	03:05	0:05	TRANSFORMER FAULT
309	10-Dec-20	BAGALKOT	110	110/33KV,HV3	TARIHAL_110,DUMMAVADA_33,IE_33	16:50	20:40	3:50	LINE CLEAR AVAILED
310	10-Dec-20	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
311	10-Dec-20	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED KUDACHI_220	12:39	16:11	3:32	LINE CLEAR AVAILED
312	10-Dec-20	BAGALKOT	110	ANKOLA-KUMTA2	STATION NOT AFFECTED ANKOLA_110	23:11 (09.12.2020)	8:02 (10.12.2020)	8:51	LINE FAULT
313	10-Dec-20	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN:LINE CLEAR AVAILED
314	10-Dec-20	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	11:41 (28.11.2020)			LINE OPEN:LINE CLEAR AVAILED
315	10-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
316	10-Dec-20	BAGALKOT	110	HUBLI-TARIHAL1	STATION NOT AFFECTED TARIHAL_110	10:55	13:36	2:41	LINE CLEAR AVAILED
317	10-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
318	10-Dec-20	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	10:47	11:06	0:19	HAND TRIPPED
319	10-Dec-20	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	19:53	20:03	0:10	HAND TRIPPED
320	10-Dec-20	BAGALKOT	110	KARWAR220-BINAGA(SOLARIS)	BINAGA(SOLARIS)_110	10:59	12:43	1:44	LINE CLEAR AVAILED
321	10-Dec-20	BAGALKOT	110	KARWAR220-BINAGA(SOLARIS)	BINAGA(SOLARIS)_110	19:53	20:02	0:09	HAND TRIPPED
322	10-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
323	10-Dec-20	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
324	10-Dec-20	BAGALKOT	110	VIJAY SUGAR-MUNDARGI	STATION NOT AFFECTED MUNDARGI 110	06:47	07:16	0:29	LINE FAULT
325	10-Dec-20	BAGALKOT	110	VIJAY SUGAR-MUNDARGI	STATION NOT AFFECTED MUNDARGI 110	10:27	14:51	4:24	LINE CLEAR AVOIDED
326	10-Dec-20	BAGALKOT	220	220/110KV HV1 & LV 1	BAGALKOT_220	11:24	13:21	1:57	LINE CLEAR AVOIDED
327	10-Dec-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR 220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
328	10-Dec-20	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED KUDACHI 220	12:39	16:09	3:30	LINE CLEAR AVOIDED
329	10-Dec-20	BAGALKOT	220	220/110KV,HV1,LV1	NO STATION AFFECTED HUBLI 220	10:42	12:55	2:13	LINE CLEAR AVOIDED
330	10-Dec-20	BAGALKOT	220	BAGALKOT-GADAG2	STATION NOT AFFECTED BAGALKOT 220	11:09 (09.12.2020)	15:41 (10.12.2020)	28:33hrs	LINE CHARGED
331	10-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI 220	16:21 (02.11.2020)			LINE OPEN:LINE CLEAR AVOIDED
332	10-Dec-20	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	21:57			LINE OPEN:LINE CLEAR AVOIDED
333	10-Dec-20	BAGALKOT	220	BIJAPUR-BAGEWADI 1	BIJAPUR_220	13:10	15:52	2:42	LINE FAULT
334	10-Dec-20	BAGALKOT	220	GHATAPRABHA-CHIKKODI	GHATAPRABHA_220	6:39 (07.12.2020)			LINE OPEN:LINE CLEAR AVOIDED
335	10-Dec-20	BAGALKOT	220	KARWAR-KADRA1	KARWAR_220	16:04 (09.12.2020)	20:19 (10.12.2020)	28:33hrs	LINE CHARGED
336	10-Dec-20	BAGALKOT	220	KUDUCHI-GHATAPRABHA	GHATAPRABHA_220	6:39 (07.12.2020)			LINE OPEN:LINE CLEAR AVOIDED
337	10-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI 220	6:15 (28.11.2020)			LOAD CURTAILMENT
338	10-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI 220	6:15 (28.11.2020)			LOAD CURTAILMENT
339	10-Dec-20	BENGALURU	66	AVANI - KOLAR 220	AVANI, MULBAGAL	13:19	15:31	02:12	LINE CLEAR AVOIDED
340	10-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVOIDED
341	10-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
342	10-Dec-20	BENGALURU	66	CB PURA I/A - DB PURA 1	CB PURA I/A, CB PURA URBAN	17:49	19:29	01:39	LINE FAULT
343	10-Dec-20	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	11:10	11:20	00:10	LOAD CHANGE OVER
344	10-Dec-20	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	08:36	09:07	00:31	LOAD CHANGE OVER
345	10-Dec-20	BENGALURU	66	HV1	KORAMANGALA 220	12:50	13:03	00:13	LINE CLEAR AVOIDED
346	10-Dec-20	BENGALURU	66	HV1	SOMANAHALLI 220	07:58	08:16	00:18	LINE CLEAR AVOIDED
347	10-Dec-20	BENGALURU	66	HV1	KGF	15:06	16:13	01:07	LINE CLEAR AVOIDED
348	10-Dec-20	BENGALURU	66	HV2	EAST DIVISION COMPOUND 220	11:20	11:24	00:04	LINE CLEAR AVOIDED
349	10-Dec-20	BENGALURU	66	ISKON - SOMANAHALLI 220	ISKON	07:58	08:44	00:46	MAIN SUPPLY FAILURE
350	10-Dec-20	BENGALURU	66	ISKON - SUBRAMANYAPURA 220	ISKON	17:32	17:36	00:04	LOAD CHANGE OVER
351	10-Dec-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	13:19	15:28	02:08	LINE CLEAR AVOIDED
352	10-Dec-20	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	17:58	18:29	00:31	LINE CLEAR AVOIDED
353	10-Dec-20	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	15:35	15:50	00:15	LOAD CHANGE OVER
354	10-Dec-20	BENGALURU	66	RAJANUKUNTE - YELAHANKA 220	RAJANUKUNTE	10:45	11:00	00:15	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
355	10-Dec-20	BENGALURU	66	SARAKKI - JAYADEVA 1 & 2	SARAKKI	18:14	18:26	00:12	LOAD CHANGE OVER
356	10-Dec-20	BENGALURU	66	SARAKKI - SOMANAHALLI 220	SARAKKI	08:32	08:36	00:04	LOAD CHANGE OVER
357	10-Dec-20	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	07:58	08:15	00:17	LINE CLEAR AVAILED
358	10-Dec-20	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	NO STATION AFFECTED	07:58	17:24	09:26	LINE FAULT
359	10-Dec-20	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 2	BRIGADE MEADOWS, SHOBHA FOREST	07:58	08:18	00:20	LINE CLEAR AVAILED
360	10-Dec-20	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	17:45	17:50	00:05	LOAD CHANGE OVER
361	10-Dec-20	BENGALURU	66	TUBUGERE - AFTL SOLAR IPP	NO STATION AFFECTED	17:49	18:37	00:48	LINE FAULT
362	10-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
363	10-Dec-20	BENGALURU	220	LV1	SOMANAHALLI 220	07:58	08:14	00:16	TRANSFORMER FAULT
364	10-Dec-20	BENGALURU	220	YARANDANAHALLI 220 - HOSUR 220	NO STATION AFFECTED	08:45	10:52	02:07	LINE CLEAR AVAILED
365	10-Dec-20	GULBARGA	110	GURUMITKAL-GAMESH WIND _IPP	GURUMITAKAL_110	12:45	17:56	05:11	LINE CLEAR AVAILED
366	10-Dec-20	GULBARGA	110	GURUMITKAL-KONKAL	KONKAL_110	20:26	20:32	00:06	LINE CLEAR AVAILED
367	10-Dec-20	GULBARGA	110	HV1	SHAHAPUR_220	11:22	11:40	00:18	TRANSFORMER FAULT
368	10-Dec-20	GULBARGA	110	HV1	HOLAGUNDI_110	06:55	09:50	02:55	LINE CLEAR AVAILED
369	10-Dec-20	GULBARGA	110	HV1	HOLAGUNDI_110	10:40	11:40	01:00	LINE CLEAR AVAILED
370	10-Dec-20	GULBARGA	110	HV1	HOLAGUNDI_110	12:45	13:15	00:30	LINE CLEAR AVAILED
371	10-Dec-20	GULBARGA	110	HV2	NIRNA_110	15:15	15:21	00:06	TRANSFORMER FAULT
372	10-Dec-20	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	04:05	04:20	00:15	LINE FAULT
373	10-Dec-20	GULBARGA	220	HV1	KAPNOOR_220	10:30	12:55	02:25	TRANSFORMER FAULT
374	10-Dec-20	GULBARGA	220	HV2	KAPNOOR_220	10:30	10:44	00:14	TRANSFORMER FAULT
375	10-Dec-20	GULBARGA	400	YTPS-BPS2	YTPS_400	14:07			LINE OPEN:LINE CLEAR AVAILED
376	10-Dec-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:56 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
377	10-Dec-20	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	16:26 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
378	10-Dec-20	HASSAN	66	HV2	HOLALUR_66	21:27(9.12.2020)	0:05(10.12.2020)	2:37 hrs	LINE CHARGED
379	10-Dec-20	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
380	10-Dec-20	HASSAN	66	LV3	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
381	10-Dec-20	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
382	10-Dec-20	HASSAN	66	MRSSHM-BD-1	MRSMG_220	16:26 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
383	10-Dec-20	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	02:10	14:39	12:29	LINE FAULT
384	10-Dec-20	HASSAN	110	HALADY11-HIRIYADKA	HALADY_110	19:25	20:04	00:39	LINE FAULT
385	10-Dec-20	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	19:25	20:04	00:39	LINE FAULT
386	10-Dec-20	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	19:33	19:52	00:19	LOAD CURTAILMENT
387	10-Dec-20	HASSAN	110	HV1	HIRENALLUR_66	15:37	17:52	02:15	LINE CLEAR AVAILED
388	10-Dec-20	HASSAN	110	HV2	ESSUR_110	13:00	13:19	00:19	LINE CLEAR AVAILED
389	10-Dec-20	HASSAN	110	HV2	HALADY_110	19:25	20:09	00:44	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
390	10-Dec-20	HASSAN	110	HV2	KONAJE_110	12:41	12:50	00:09	LOAD CURTAILMENT
391	10-Dec-20	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	19:25	19:42	00:17	LINE FAULT
392	10-Dec-20	HASSAN	110	LV2	MSEZ_220	10:08	14:52	04:44	LINE CLEAR AVAILED
393	10-Dec-20	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	22:38 (8.12.2020)			LINE OPEN: LINE FAULT
394	10-Dec-20	HASSAN	220	HV2	MSEZ_220	10:08	14:52	04:44	LINE CLEAR AVAILED
395	10-Dec-20	HASSAN	220	KEMAR-Varahi3	KEMAR_220	19:45(10.12.2020)			LINE OPEN: LINE FAULT
396	10-Dec-20	HASSAN	220	KEMAR-Varahi3	KEMAR_220	19:25	19:45	00:20	LINE FAULT
397	10-Dec-20	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	22:38 (8.12.2020)	12:34(10.12.2020)	37:55 hrs	LINE CHARGED
398	10-Dec-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	17:44	17:51	00:07	LINE FAULT
399	10-Dec-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	18:00	18:25	00:25	LINE FAULT
400	10-Dec-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	18:36	19:33	00:57	LINE FAULT
401	10-Dec-20	HASSAN	220	VARAHI-KEMAR3	varahi_gen	19:25(10.12.2020)			LINE OPEN: LINE FAULT
402	10-Dec-20	HASSAN	220	VBARAHI-KEMAR1	varahi_gen	18:36	19:33	00:57	LINE FAULT
403	10-Dec-20	MYSORE	66	CR NAGARA-PANYADAHUNDI	NO STATIONS EFFECTED	19:18 (09.12.2020)	13:29 (10.12.2020)	18:11 HRS	LINE CHARGED
404	10-Dec-20	MYSORE	66	HV1	SATHEGALA_66	11:50	14:10	2:20	LINE CLEAR AVAILED
405	10-Dec-20	MYSORE	66	HV1	ATTIGULIPURA_66	16:02	16:23	0:21	LINE CLEAR AVAILED
406	10-Dec-20	MYSORE	66	HV1	BOMMALAPURA_66	14:08	15:31	1:22	LINE CLEAR AVAILED
407	10-Dec-20	MYSORE	66	HV1	PONNAMPET_66	16:28	17:51	1:22	LINE CLEAR AVAILED
408	10-Dec-20	MYSORE	66	HV2	SATHEGALA_66	16:31	16:44	0:13	LINE CLEAR AVAILED
409	10-Dec-20	MYSORE	66	HV2	BILIKERE_66	13:40	13:54	0:13	LINE CLEAR AVAILED
410	10-Dec-20	MYSORE	66	HV2	BOMMALAPURA_66	12:40	14:04	1:24	LINE CLEAR AVAILED
411	10-Dec-20	MYSORE	66	HV2	MADIKERI_66	12:57	15:38	2:40	LINE CLEAR AVAILED
412	10-Dec-20	MYSORE	66	HV2	MADIKERI_66	15:54	17:05	1:10	LINE CLEAR AVAILED
413	10-Dec-20	MYSORE	66	HV2	PONNAMPET_66	16:28	17:51	1:22	LINE CLEAR AVAILED
414	10-Dec-20	MYSORE	66	HV2	SANTHEMARAHALLI_66	9:45 (08.12.2020)			LINE OPEN:LINE CLEAR AVAILED
415	10-Dec-20	MYSORE	66	HV3	KIKKERI_66	15:50	16:20	0:29	LINE CLEAR AVAILED
416	10-Dec-20	MYSORE	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	4:45 (19.11.2020)			LINE OPEN:LINE CLEAR AVAILED
417	10-Dec-20	MYSORE	66	KR PETE-AKKIHEBBAL1	AKKIHEBBAL_66	4:37	4:49	0:11	LINE FAULT
418	10-Dec-20	MYSORE	66	KR PETE-AKKIHEBBAL2	AKKIHEBBAL_66	4:37	4:49	0:11	LINE FAULT
419	10-Dec-20	MYSORE	66	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	18:20	18:29	0:09	LINE FAULT
420	10-Dec-20	MYSORE	66	KUSHALNAGARA 220-RAMANTHAPURA1	ALUR SIDDAPURA_66 KANAGAL_66	2:09	14:18	12:09	LINE FAULT
421	10-Dec-20	MYSORE	66	MADHUVANAHALLI-KOLLEGALA 1	KOLLEGALA_66 PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	18:23 (10.12.2020)			LINE OPEN: LINE FAULT
422	10-Dec-20	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	20:18	20:31	0:13	LINE FAULT
423	10-Dec-20	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	18:14 (10.12.2020)			LINE OPEN: LINE FAULT
424	10-Dec-20	MYSORE	66	MUGUR-KUNTHUR	MUGUR_66 THAYURU_66 JANNUR_66 TNARASIPURA_66	18:17	18:37	0:20	LINE FAULT
425	10-Dec-20	MYSORE	66	SFC SIVA-HEBBANI 9	SATHEGALA_66	18:23	18:44	0:21	LINE FAULT
426	10-Dec-20	MYSORE	66	VIJAYANAGARA-BANNIMANTAPA	VIJAYANAGRAMYS_66	10:06	16:55	6:49	LINE CLEAR AVAILED
427	10-Dec-20	MYSORE	66	VIJAYANAGARA-HOOTAGALLI	VIJAYANAGRAMYS_66	10:06	16:44	6:38	LINE CLEAR AVAILED
428	10-Dec-20	MYSORE	220	HV1	MADHUVANAHALLI_220	18:24	18:44	0:20	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
429	10-Dec-20	MYSORE	220	HV2	MADHUVANAHALLI_220	18:24	18:44	0:20	TRANSFORMER FAULT
430	10-Dec-20	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	15:48	20:37	4:49	LINE FAULT
431	10-Dec-20	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 1	CHITRADURGA_66	10:54	12:31	1:37	LINE CLEAR AVAILED
432	10-Dec-20	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_66	10:54	12:33	1:38	LINE CLEAR AVAILED
433	10-Dec-20	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 2	CHITRADURGA_66	10:54	12:22	1:28	LINE CLEAR AVAILED
434	10-Dec-20	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	23:05	23:20	0:15	LINE FAULT
435	10-Dec-20	TUMKUR	66	HARAPPANAHALLI-SUZLON 2	SUZLON_IPP_66	11:46(09.12.2020)			LINE OPEN: LINE FAULT
436	10-Dec-20	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	13:02	13:05	0:03	LINE FAULT
437	10-Dec-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	0:24	0:26	0:02	LINE FAULT
438	10-Dec-20	TUMKUR	66	MATHOD-RAMCO CEMENT _EHT_66	RAMCO CEMENT _EHT_66	6:36	6:40	0:03	MAIN SUPPLY FAILURE
439	10-Dec-20	TUMKUR	66	TR-1	KALAMARANAHALLI_66	18:01	18:13	0:12	LINE CLEAR AVAILED
440	10-Dec-20	TUMKUR	66	TR-1	MYLANAHALLI_66	18:21	18:46	0:24	LINE CLEAR AVAILED
441	10-Dec-20	TUMKUR	66	TR-1	YEDIYUR_66	13:01	13:26	0:25	LINE CLEAR AVAILED
442	10-Dec-20	TUMKUR	66	TR-1	YEDIYUR_66	20:44	20:55	0:10	LINE CLEAR AVAILED
443	10-Dec-20	TUMKUR	66	YEDIYUR- ANCHEPALYA	YEDIYUR_66	16:32	20:55	4:22	LINE CLEAR AVAILED
444	10-Dec-20	TUMKUR	66	YEDIYUR- BGNAGARA_66	YEDIYUR_66	16:32	20:55	4:22	LINE CLEAR AVAILED
445	10-Dec-20	TUMKUR	110	KALLUR- NITTUR	KALLUR_110	6:15	6:31	0:15	MAIN SUPPLY FAILURE
446	10-Dec-20	TUMKUR	110	KALLUR- NITTUR	KALLUR_110	6:46	7:21	0:35	MAIN SUPPLY FAILURE
447	10-Dec-20	TUMKUR	110	KALLUR- NITTUR	KALLUR_110	16:07	16:21	0:13	LINE CLEAR AVAILED
448	10-Dec-20	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	5:55	6:18	0:23	LINE FAULT
449	10-Dec-20	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	6:33	7:17	0:43	LINE FAULT
450	10-Dec-20	TUMKUR	110	TR-1	DODDAGUNI_110	10:00	15:00	5:00	LINE CLEAR AVAILED
451	10-Dec-20	TUMKUR	110	TR-1	KALLUR_110	15:00	16:22	1:21	LINE CLEAR AVAILED
452	10-Dec-20	TUMKUR	220	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	10:48	12:31	1:43	LINE CLEAR AVAILED
453	10-Dec-20	TUMKUR	220	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	14:44	15:47	1:03	LINE CLEAR AVAILED
454	10-Dec-20	TUMKUR	220	THALLAK 220kV-HIRIYUR	THALLAKK_220	10:48	12:31	1:43	LINE CLEAR AVAILED
455	10-Dec-20	TUMKUR	220	THALLAK 220kV-HIRIYUR	THALLAKK_220	14:44	15:47	1:03	LINE CLEAR AVAILED
456	11-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
457	11-Dec-20	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
458	11-Dec-20	BAGALKOT	110	110/11KV,HV 1	BASAVANAKATTI_110	11:12	17:04	5:52	LINE CLEAR AVAILED
459	11-Dec-20	BAGALKOT	110	110/11KV,HV 1	BETAGERI_110	12:25	12:42	0:17	LINE CLEAR AVAILED
460	11-Dec-20	BAGALKOT	110	110/11KV,HV 1	DAMBAL_110	8:59	9:06	0:07	TRANSFORMER FAULT
461	11-Dec-20	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
462	11-Dec-20	BAGALKOT	110	BELGAUM220- VADAGOAN	VADAGOAN_110	3:21	12:24	9:03	LINE FAULT
463	11-Dec-20	BAGALKOT	110	BELGAUM220- VADAGOAN	VADAGOAN_110	14:18	19:03	4:45	LINE CLEAR AVAILED
464	11-Dec-20	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	13:21	13:23	0:02	HAND TRIPPED
465	11-Dec-20	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	23:46 (11.12.2020)			LINE OPEN: LINE FAULT
466	11-Dec-20	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN:LINE CLEAR AVAILED
467	11-Dec-20	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	11:41 (28.11.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
468	11-Dec-20	BAGALKOT	110	GADAG-BETAGERI	BETAGERI_220	13:11	13:36	0:25	LINE FAULT
469	11-Dec-20	BAGALKOT	110	GAMESHA- RON	RON_110	13:50	14:02	0:12	HAND TRIPPED
470	11-Dec-20	BAGALKOT	110	GHATAPRABHA-NARENDRA 2	GHATAPRABHA_220	14:21	15:11	0:50	LINE FAULT
471	11-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
472	11-Dec-20	BAGALKOT	110	HAVERI-AFT SOLAR	BASAVANAKATTI_110	12:48	18:12	5:24	LINE CLEAR AVAILED
473	11-Dec-20	BAGALKOT	110	HAVERI-BASAVANAKATTI	BASAVANAKATTI_110	11:34	17:03	5:29	LINE CLEAR AVAILED
474	11-Dec-20	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	16:36	18:35	1:59	LINE FAULT
475	11-Dec-20	BAGALKOT	110	HAVERI-GUTTAL SWTCHING S/S	BASAVANAKATTI_110	11:36	17:04	5:28	LINE CLEAR AVAILED
476	11-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
477	11-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
478	11-Dec-20	BAGALKOT	110	KUMATA- SIRSI1	KUMATA_110	17:23	17:44	0:21	LINE CLEAR AVAILED
479	11-Dec-20	BAGALKOT	110	NARENDRA- BELUR1	STATION NOT AFFECTED BELUR_110	11:40	18:56	7:16	LINE CLEAR AVAILED
480	11-Dec-20	BAGALKOT	110	RANEBENNUR220- BYDAGAI	BYADAGI_110	17:37	19:28	1:51	LINE CLEAR AVAILED
481	11-Dec-20	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
482	11-Dec-20	BAGALKOT	110	SUARNASOUDA- MACHE	MACHE_110	14:59	15:10	0:11	HAND TRIPPED
483	11-Dec-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
484	11-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN:LINE CLEAR AVAILED
485	11-Dec-20	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	21:57 (10.12.2020)	8:05 11.12.2020)	10:02 hrs	LINE CHARGED
486	11-Dec-20	BAGALKOT	220	GHATAPRABHA- KUDACHI	GHATAPRABHA_220	6:39 (07.12.2020)			LINE OPEN:LINE CLEAR AVAILED
487	11-Dec-20	BAGALKOT	220	GHATAPRABHA-CHIKKODI	GHATAPRABHA_220	6:39 (07.12.2020)			LINE OPEN:LINE CLEAR AVAILED
488	11-Dec-20	BAGALKOT	220	GM NAVAR 1-BAGEWADI	BAGEWADI_220	16:45	17:47	1:02	LINE CLEAR AVAILED
489	11-Dec-20	BAGALKOT	220	MKHUBLI- NARENDRA1	MK HUBLI_220	14:06	19:45	5:39	LINE FAULT
490	11-Dec-20	BAGALKOT	220	NAGJHARI1- HUBLI	HUBLI_220	9:06	16:46	7:40	LINE CLEAR AVAILED
491	11-Dec-20	BAGALKOT	220	NAGJHARI2- HUBLI	HUBLI_220	9:06	17:06	8:00	LINE CLEAR AVAILED
492	11-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
493	11-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
494	11-Dec-20	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR2	VAJRAMATTI_220	16:25	17:06	0:41	LINE CLEAR AVAILED
495	11-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
496	11-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
497	11-Dec-20	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	17:27	18:06	00:38	LINE CLEAR AVAILED
498	11-Dec-20	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	11:49	12:14	00:24	LINE CLEAR AVAILED
499	11-Dec-20	BENGALURU	66	HOODY 220 - HP(EHT)	HP(EHT)	10:25	10:32	00:07	LINE CLEAR AVAILED
500	11-Dec-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	16:31	17:15	00:43	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
501	11-Dec-20	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	06:21	06:36	00:15	LINE FAULT
502	11-Dec-20	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	09:40	09:50	00:10	LOAD CHANGE OVER
503	11-Dec-20	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	18:15	18:20	00:05	LOAD CHANGE OVER
504	11-Dec-20	BENGALURU	66	HV1	ITI	13:23	15:40	02:17	LINE CLEAR AVAILED
505	11-Dec-20	BENGALURU	66	HV1	JIGANI LINK ROAD	15:45	17:20	01:35	LOAD CHANGE OVER
506	11-Dec-20	BENGALURU	66	HV1	MANDIKAL	11:11	13:05	01:54	LOAD CHANGE OVER
507	11-Dec-20	BENGALURU	66	HV2	JAYADEVA	10:43	12:04	01:21	LINE CLEAR AVAILED
508	11-Dec-20	BENGALURU	66	HV3	YARANDANAHALLI 220	12:47	13:28	00:41	LINE CLEAR AVAILED
509	11-Dec-20	BENGALURU	66	HV3	HOSKOTE 66	01:40	01:45	00:05	TRANSFORMER FAULT
510	11-Dec-20	BENGALURU	66	HV3	HOSKOTE 66	03:35	03:45	00:10	TRANSFORMER FAULT
511	11-Dec-20	BENGALURU	66	KEMPANAHALLI - BIDADI 220	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	12:24	14:00	01:35	LINE CLEAR AVAILED
512	11-Dec-20	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NO STATION AFFECTED	10:43	10:49	00:06	LINE FAULT
513	11-Dec-20	BENGALURU	66	KOTHIPURA 220kv - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	12:03	12:06	00:03	LINE FAULT
514	11-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
515	11-Dec-20	BENGALURU	220	HV1	KOLAR 220	13:00	13:32	00:32	TRANSFORMER FAULT
516	11-Dec-20	GULBARGA	66	HV2	TAMBARAHALLI_66	08:50	09:00	00:10	TRANSFORMER FAULT
517	11-Dec-20	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJAINI_66,BENNEHALLI_66	22:05	22:18	00:13	LINE FAULT
518	11-Dec-20	GULBARGA	66	ITTAGI-HIREHADAGALI1&2	HIREHADAGALI_66,GIRIYAPURA_66,MAGALA_66,SOVENHALLI_66,TUNGABHADRA IPP	09:25	18:00	08:35	LINE CLEAR AVAILED
519	11-Dec-20	GULBARGA	66	ITTAGI-HIREHADAGALI1&2	HIREHADAGALI_66,GIRIYAPURA_66,MAGALA_66,SOVENHALLI_66,TUNGABHADRA IPP	10:55	18:00	07:05	LINE CLEAR AVAILED
520	11-Dec-20	GULBARGA	66	ITTAGI-KOTTURU	KOTTUR_66	06:20	06:40	00:20	MAIN SUPPLY FAILURE
521	11-Dec-20	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_110	13:40	15:25	01:45	LINE CLEAR AVAILED
522	11-Dec-20	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_110	18:11	18:36	00:25	LINE CLEAR AVAILED
523	11-Dec-20	GULBARGA	110	HV1	KUDITINI_110	15:54	16:23	00:29	TRANSFORMER FAULT
524	11-Dec-20	GULBARGA	110	HV1&2	ITTAGI_220	11:50	14:45	02:55	LINE CLEAR AVAILED
525	11-Dec-20	GULBARGA	110	HV2	MANVI_110	09:01	09:07	00:06	TRANSFORMER FAULT
526	11-Dec-20	GULBARGA	110	HV2	HALIKHED_110	12:42	13:21	00:39	LINE CLEAR AVAILED
527	11-Dec-20	GULBARGA	110	HV2	ITTAGI_220	14:50	18:00	03:10	LINE CLEAR AVAILED
528	11-Dec-20	GULBARGA	110	HV2	JEEWARGI_110	23:11	23:24	00:13	LINE CLEAR AVAILED
529	11-Dec-20	GULBARGA	110	HV3	SHORAPUR_110	09:25	09:35	00:10	TRANSFORMER FAULT
530	11-Dec-20	GULBARGA	110	HV3	HALIKHED_110	12:38	12:42	00:04	LINE CLEAR AVAILED
531	11-Dec-20	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	06:48	10:45	03:57	LINE CLEAR AVAILED
532	11-Dec-20	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	20:00	20:06	00:06	LINE FAULT
533	11-Dec-20	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	12:15	14:17	02:02	LINE CLEAR AVAILED
534	11-Dec-20	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	17:05	17:25	00:20	LINE CLEAR AVAILED
535	11-Dec-20	GULBARGA	220	HV2	SEDAM_220	13:00	14:12	01:12	TRANSFORMER FAULT
536	11-Dec-20	GULBARGA	220	HV2	KUSTAGI_220	17:36	18:00	00:24	TRANSFORMER FAULT
537	11-Dec-20	GULBARGA	220	HV2	ITTAGI_220	06:18	06:55	00:37	TRANSFORMER FAULT
538	11-Dec-20	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	11:57	12:40	00:43	LINE FAULT
539	11-Dec-20	GULBARGA	220	LINGAPUR-MUNIRABAD1	MUNIRABAD_220	08:54	13:32	04:38	LINE CLEAR AVAILED
540	11-Dec-20	GULBARGA	220	SEDAM-SHREECEMENTS_IPP	SEDAM_220	12:20	16:42	04:22	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
541	11-Dec-20	GULBARGA	400	YTPS-BPS2	YTPS_400	14:07(10/12/2020)	16:51(11/12/2020)	26:44 HRS	NFBC ISSUED
542	11-Dec-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:56 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
543	11-Dec-20	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	16:26 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
544	11-Dec-20	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	14:19	16:47	02:28	LINE FAULT
545	11-Dec-20	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	06:26	06:35	00:09	LINE FAULT
546	11-Dec-20	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	11:52	12:03	00:11	LINE FAULT
547	11-Dec-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	11:55	12:10	00:15	TRANSFORMER FAULT
548	11-Dec-20	HASSAN	66	HV1	MALALI_66	11:54	12:04	00:10	MAIN SUPPLY FAILURE
549	11-Dec-20	HASSAN	66	HV2	RAMNATHPURA_66	11:31	16:45	05:14	TRANSFORMER FAULT
550	11-Dec-20	HASSAN	66	LV1	CRPATNA_220	07:51	08:03	00:12	TRANSFORMER FAULT
551	11-Dec-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
552	11-Dec-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
553	11-Dec-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
554	11-Dec-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	11:54	12:05	00:11	MAIN SUPPLY FAILURE
555	11-Dec-20	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	16:26 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
556	11-Dec-20	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	15:17	18:24	03:07	LINE FAULT
557	11-Dec-20	HASSAN	110	HV1	GANDSI_110	12:13	12:49	00:36	TRANSFORMER FAULT
558	11-Dec-20	HASSAN	110	HV2	ESSUR_110	12:51	15:29	02:38	TRANSFORMER FAULT
559	11-Dec-20	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	10:33	11:27	00:54	LINE FAULT
560	11-Dec-20	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	12:43	13:42	00:59	LINE FAULT
561	11-Dec-20	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	16:22	18:52	02:30	LINE FAULT
562	11-Dec-20	HASSAN	220	HV1	CRPATNA_220	07:51	08:03	00:12	TRANSFORMER FAULT
563	11-Dec-20	HASSAN	220	KEMAR-Varahi3	KEMAR_220	19:45(10.12.2020)	11:41 (11.12.2020)	16:55 hrs	LINE CHARGED
564	11-Dec-20	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	11:53	14:11	02:18	LINE FAULT
565	11-Dec-20	HASSAN	220	VARAHI-KEMAR3	varahi_gen	19:25(10.12.2020)	11:41 (11.12.2020)	16:15 hrs	LINE CHARGED
566	11-Dec-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:50 (11.12.2020)			LINE OPEN: LINE FAULT
567	11-Dec-20	MYSORE	66	HOOTAGALLI-FTS 2	NO STATIONS EFFECTED	11:35	19:12	7:37	LINE CLEAR AVAILED
568	11-Dec-20	MYSORE	66	HV1	DODDINADUVADI_66	14:04	14:39	0:35	LINE CLEAR AVAILED
569	11-Dec-20	MYSORE	66	HV1	SATHEGALA_66	13:00	13:08	0:08	LINE CLEAR AVAILED
570	11-Dec-20	MYSORE	66	HV1	TARIPURA_66	11:29	14:10	2:40	LINE CLEAR AVAILED
571	11-Dec-20	MYSORE	66	HV1	KRPET_220	10:23	15:24	5:00	LINE CLEAR AVAILED
572	11-Dec-20	MYSORE	66	HV2	MADIKERI_66	10:29	10:40	0:11	LINE CLEAR AVAILED
573	11-Dec-20	MYSORE	66	HV2	MADIKERI_66	11:41	13:10	1:28	LINE CLEAR AVAILED
574	11-Dec-20	MYSORE	66	HV2	KRPET_220	10:13	17:17	7:04	LINE CLEAR AVAILED
575	11-Dec-20	MYSORE	66	HV2	SANTHEMARAHALLI_66	9:45 (08.12.2020)	18:30 (11.12.2020)	80:45 HRS	TRANSFORMER CHARGED
576	11-Dec-20	MYSORE	66	KABHALLY-CLEAN SOLAR	NO STATIONS EFFECTED	18:22	18:56	0:34	LINE FAULT
577	11-Dec-20	MYSORE	66	KABHALLY-GUNDLUPETE	NO STATIONS EFFECTED	7:02	7:10	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
578	11-Dec-20	MYSORE	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	4:45 (19.11.2020)			LINE OPEN:LINE CLEAR AVAILED
579	11-Dec-20	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 MADESWARAPURA_66 NAGAMANGALA_66	16:12	16:14	0:02	LINE FAULT
580	11-Dec-20	MYSORE	66	MADHUVANAHALLI-KOLLEGALA 1	KOLLEGALA_66 PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	18:23 (10.12.2020)			LINE OPEN: LINE FAULT
581	11-Dec-20	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	15:46	15:52	0:06	LINE FAULT
582	11-Dec-20	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	20:43	22:23	1:39	LINE CLEAR AVAILED
583	11-Dec-20	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	18:14 (10.12.2020)	10:23 (11.12.2020)	16:08 HRS	LINE CHARGED
584	11-Dec-20	MYSORE	66	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	23:21	23:35	0:13	HAND TRIPPED
585	11-Dec-20	MYSORE	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	11:05	13:00	1:55	LINE CLEAR AVAILED
586	11-Dec-20	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	11:04	11:11	0:07	LINE FAULT
587	11-Dec-20	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	CHITRADURGA_66	14:54	15:17	0:23	LINE CLEAR AVAILED
588	11-Dec-20	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	17:48	17:59	0:11	HAND TRIPPED
589	11-Dec-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	17:50	17:54	0:03	LINE FAULT
590	11-Dec-20	TUMKUR	66	GARAGA-MTHD-PNCHLI	GARAGA_66	11:27	11:30	0:02	HAND TRIPPED
591	11-Dec-20	TUMKUR	66	HARAPPANAHALLI-SUZLON 2	SUZLON_IPP_66	11:46:12(09.12.2020)			LINE OPEN: LINE FAULT
592	11-Dec-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:48	6:55	0:07	LINE FAULT
593	11-Dec-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	7:07	7:15	0:07	LINE FAULT
594	11-Dec-20	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:48	11:55	0:06	LINE FAULT
595	11-Dec-20	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:05	12:13	0:08	LINE FAULT
596	11-Dec-20	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	15:04	15:07	0:03	LINE FAULT
597	11-Dec-20	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66	14:33	14:52	0:19	LINE FAULT
598	11-Dec-20	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	14:32	14:38	0:06	LINE FAULT
599	11-Dec-20	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	14:32	14:54	0:21	LINE FAULT
600	11-Dec-20	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	16:16	17:02	0:46	LINE FAULT
601	11-Dec-20	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEI DIAMOND SOLAR_IPP_66	14:32	14:50	0:17	LINE FAULT
602	11-Dec-20	TUMKUR	66	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	14:32	14:50	0:17	LINE FAULT
603	11-Dec-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR	WELSPUNSOLAR2_IPP_66	14:32	14:52	0:20	LINE FAULT
604	11-Dec-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	14:32	14:53	0:20	LINE FAULT
605	11-Dec-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	14:59	15:22	0:23	LINE FAULT
606	11-Dec-20	TUMKUR	66	TR-1	GARAGA_66	11:27	11:30	0:02	HAND TRIPPED
607	11-Dec-20	TUMKUR	66	TR-1	MAVINAKATTE_66	15:47	16:10	0:22	TRANSFORMER FAULT
608	11-Dec-20	TUMKUR	66	TR-1	PAVAGADA_220	9:07	9:15	0:07	TRANSFORMER FAULT
609	11-Dec-20	TUMKUR	66	TR-1	SOKKE_66	15:43	15:48	0:04	HAND TRIPPED
610	11-Dec-20	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	14:24	14:40	0:16	TRANSFORMER FAULT
611	11-Dec-20	TUMKUR	66	TR-2	GARAGA_66	11:28	13:16	1:48	TRANSFORMER FAULT
612	11-Dec-20	TUMKUR	66	TR-2	KORA_66	12:12	13:37	1:24	LINE CLEAR AVAILED
613	11-Dec-20	TUMKUR	66	TR-2	NAYAKANAHATTI_66	16:30	16:38	0:08	TRANSFORMER FAULT
614	11-Dec-20	TUMKUR	66	TR-2	NAYAKANAHATTI_66	16:57	17:07	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
615	11-Dec-20	TUMKUR	66	TR-2(LV SIDE)	THALLAKK_220	14:24	14:48	0:23	TRANSFORMER FAULT
616	11-Dec-20	TUMKUR	66	TR-3	HARIYABBE_66	17:43	17:49	0:05	TRANSFORMER FAULT
617	11-Dec-20	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	0:51	7:20	6:28	LINE FAULT
618	11-Dec-20	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	15:26	19:27	4:01	LINE FAULT
619	11-Dec-20	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	14:12	19:26	5:14	LINE FAULT
620	11-Dec-20	TUMKUR	220	THALLAK 220kV- HIREMALLANAHOLE 2	THALLAK_220	14:12	14:30	0:17	LINE FAULT
621	11-Dec-20	TUMKUR	220	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEL DIAMOND SOLAR_IPP_66	14:12	14:45	0:33	LINE FAULT
622	11-Dec-20	TUMKUR	220	THALLAK 220kV-HIRIYUR	THALLAKK_220	14:12	15:08	0:56	LINE FAULT
623	11-Dec-20	TUMKUR	220	TR-2(HV SIDE)	DAVANGERE_SRS_220	10:03	13:42	3:38	LINE CLEAR AVAILED
624	12-Dec-20	BAGALKOT	66	66/33KV, HV4	HARIHAR- HOSPET_66	13:37	14:01	0:24	LINE CLEAR AVAILED
625	12-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
626	12-Dec-20	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	00:49	01:24	0:35	TRANSFORMER FAULT
627	12-Dec-20	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	08:11	08:51	0:40	TRANSFORMER FAULT
628	12-Dec-20	BAGALKOT	110	110/11KV, HV1	SHIRGOAN_110	15:31	17:17	1:46	LINE CLEAR AVAILED
629	12-Dec-20	BAGALKOT	110	110/11KV, HV2	SHIRGOAN_110	15:31	17:17	1:46	LINE CLEAR AVAILED
630	12-Dec-20	BAGALKOT	110	110/11KV, HV2	PG HUNSHYAL_110	12:22	13:21	0:59	LINE CLEAR AVAILED
631	12-Dec-20	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	13:25	15:11	1:46	LINE CLEAR AVAILED
632	12-Dec-20	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
633	12-Dec-20	BAGALKOT	110	110/33KV, HV3	HUBLI_220	11:40	16:35	4:55	LINE CLEAR AVAILED
634	12-Dec-20	BAGALKOT	110	110/33KV, HV3	NIPPANI_110, BENADI_33, JATRAT_33	5:46	7:23	1:37	TRANSFORMER FAULT
635	12-Dec-20	BAGALKOT	110	110/33KV, HV3	NIPPANI_110, BENADI_33, JATRAT_33	8:05	8:10	0:05	TRANSFORMER FAULT
636	12-Dec-20	BAGALKOT	110	110/33KV,HV2	HANAGAL_110 & BELAGALPET,BOMMANALLI,AKKIALUR&LAXMIP UR_33	8:08	8:15	0:07	TRANSFORMER FAULT
637	12-Dec-20	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
638	12-Dec-20	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110	03:56	04:06	0:10	LINE FAULT
639	12-Dec-20	BAGALKOT	110	ANKOLA-KUMATA(L2)	ANKOLA_110	3:20	07:34	4:14	LINE FAULT
640	12-Dec-20	BAGALKOT	110	BAGALKOT-NEERBUDIHAI(KATARAKI)	NEERBUDIHAI_110	11:20	12:01	0:41	LINE CLEAR AVAILED
641	12-Dec-20	BAGALKOT	110	BAGALKOT-NEERBUDIHAI(KATARAKI)	NEERBUDIHAI_110	12:32	14:23	1:51	LINE CLEAR AVAILED
642	12-Dec-20	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	23:46 (11.12.2020)			LINE OPEN: LINE FAULT
643	12-Dec-20	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	01:56	11:00	9:04	LINE FAULT
644	12-Dec-20	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN:LINE CLEAR AVAILED
645	12-Dec-20	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	11:41 (28.11.2020)			LINE OPEN:LINE CLEAR AVAILED
646	12-Dec-20	BAGALKOT	110	GAJENDRAGAD-RON 1&2	GAJENDRAGAD_110	2:02	2:08	0:06	HAND TRIPPED
647	12-Dec-20	BAGALKOT	110	GAJENDRAGAD-RON 1&2	GAJENDRAGAD_110	13:18	13:39	0:21	HAND TRIPPED
648	12-Dec-20	BAGALKOT	110	GAJENDRAGAD-RON 1&2	GAJENDRAGAD_110	9:33	12:03	2:30	LINE CLEAR AVAILED
649	12-Dec-20	BAGALKOT	110	GAMESHA- RON	RON_110	0:06	0:27	0:21	HAND TRIPPED
650	12-Dec-20	BAGALKOT	110	HALSIDDANATH- NIPPANI	NIPPANI_110	5:45	7:23	1:38	LINE FAULT
651	12-Dec-20	BAGALKOT	110	HALSIDDANATH- NIPPANI	NIPPANI_110	8:04	8:37	0:33	LINE FAULT
652	12-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
653	12-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
654	12-Dec-20	BAGALKOT	110	ITANAL-RAIBAG 1(HIDIKAL(2))	RAIBAG_110	18:19	18:41	0:22	HAND TRIPPED
655	12-Dec-20	BAGALKOT	110	ITANAL-RAIBAG 2(HIDIKAL(2))	RAIBAG_110	18:43	19:00	0:17	HAND TRIPPED
656	12-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
657	12-Dec-20	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIAKAL_110	12:11	18:28	6:17	LINE CLEAR AVAILED
658	12-Dec-20	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	RABAKAVI_110	12:11 (12.12.2020)			LINE OPEN:LINE CLEAR AVAILED
659	12-Dec-20	BAGALKOT	110	MMCL- SOUDATTI220	SOUDATTI_220	13:51	14:19	0:28	LINE CLEAR AVAILED
660	12-Dec-20	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
661	12-Dec-20	BAGALKOT	110	RON- GAJENDRAGAD1&2	GAJENDRAGAD_110	13:50	14:16	0:26	HAND TRIPPED
662	12-Dec-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
663	12-Dec-20	BAGALKOT	220	220/110KV,HV3&LV3	MAHALINGAPUR_220	12:12	18:09	5:57	LINE CLEAR AVAILED
664	12-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN:LINE CLEAR AVAILED
665	12-Dec-20	BAGALKOT	220	GHATAPRABHA- KUDACHI	GHATAPRABHA_220	6:39 (07.12.2020)			LINE OPEN:LINE CLEAR AVAILED
666	12-Dec-20	BAGALKOT	220	GHATAPRABHA-CHIKKODI	GHATAPRABHA_220	6:39 (07.12.2020)			LINE OPEN:LINE CLEAR AVAILED
667	12-Dec-20	BAGALKOT	220	KADRA 1-KARWAR	KARWAR_220	16:31	17:24	0:53	HAND TRIPPED
668	12-Dec-20	BAGALKOT	220	NAGJHARI1- HUBLI	HUBLI_220	8:18	17:37	9:19	LINE CLEAR AVAILED
669	12-Dec-20	BAGALKOT	220	NAGJHARI2- HUBLI	HUBLI_220	8:18	17:37	9:19	LINE CLEAR AVAILED
670	12-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
671	12-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
672	12-Dec-20	BAGALKOT	220	VAJRAMATTI- BAGALKOT1	VAJRAMATTI_220	13:04	15:04	2:00	LINE FAULT
673	12-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
674	12-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
675	12-Dec-20	BENGALURU	66	HANUMANTHNAGAR - KANAKAPURA 220	HANUMANTHNAGAR	17:45	17:50	00:05	LOAD CHANGE OVER
676	12-Dec-20	BENGALURU	66	HANUMANTHNAGAR - SOMANAHALLI 220	HANUMANTHNAGAR	19:15	20:00	00:45	LOAD CHANGE OVER
677	12-Dec-20	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	20:30	20:35	00:05	LOAD CHANGE OVER
678	12-Dec-20	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	17:48	18:12	00:24	MAIN SUPPLY FAILURE
679	12-Dec-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	15:57	16:37	00:40	LINE FAULT
680	12-Dec-20	BENGALURU	66	HV1	EPIP 220	10:20	12:51	02:31	LINE CLEAR AVAILED
681	12-Dec-20	BENGALURU	66	HV1	NAGANATHPURA 220	00:33	00:40	00:07	TRANSFORMER FAULT
682	12-Dec-20	BENGALURU	66	HV1	MAGADI 220	00:42	11:15	10:33	LINE CLEAR AVAILED
683	12-Dec-20	BENGALURU	66	HV1	RANGANDODDI	10:47	11:25	00:38	LINE CLEAR AVAILED
684	12-Dec-20	BENGALURU	66	HV2	EPIP 220	14:20	16:40	02:20	LINE CLEAR AVAILED
685	12-Dec-20	BENGALURU	66	HV2	YARANDANAHALLI 220	00:32	00:48	00:16	LINE CLEAR AVAILED
686	12-Dec-20	BENGALURU	66	HV2	RANGANDODDI	10:47	11:25	00:38	LINE CLEAR AVAILED
687	12-Dec-20	BENGALURU	66	HV3	EPIP 220	14:20	16:20	02:00	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
688	12-Dec-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU,GODUR	09:10	09:55	00:45	LINE CLEAR AVAILED
689	12-Dec-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI,YEDUMADU,GODUR	17:43	19:21	01:38	LINE CLEAR AVAILED
690	12-Dec-20	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	00:33	00:39	00:06	LINE FAULT
691	12-Dec-20	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	09:36	09:54	00:18	LINE FAULT
692	12-Dec-20	BENGALURU	66	VIDYANAGAR - SAHAKARINAGAR	HENNUR CROSS	19:31	20:32	01:00	LINE FAULT
693	12-Dec-20	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	00:32	00:49	00:17	LINE CLEAR AVAILED
694	12-Dec-20	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	04:15	04:31	00:15	LINE FAULT
695	12-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
696	12-Dec-20	BENGALURU	220	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	9:10(12/12/2020)			LINE OPEN:LINE CLEAR AVAILED
697	12-Dec-20	BENGALURU	220	HV1	YARANDANAHALLI 220	00:32	00:48	00:16	TRANSFORMER FAULT
698	12-Dec-20	BENGALURU	220	HV1	MAGADI 220	00:42	11:03	10:21	TRANSFORMER FAULT
699	12-Dec-20	GULBARGA	66	ITTAGI-KUDLIGI1	KOGALI_66,KUDLIGI_66,HANASI_66	12:26	12:56	00:30	MAIN SUPPLY FAILURE
700	12-Dec-20	GULBARGA	110	HV1	KUDITINI_110	18:33	18:38	00:05	TRANSFORMER FAULT
701	12-Dec-20	GULBARGA	110	HV2	SINDHNOOR_110	00:08	00:19	00:11	LINE CLEAR AVAILED
702	12-Dec-20	GULBARGA	110	HV2	SINDHNOOR_110	00:30	00:36	00:06	LINE CLEAR AVAILED
703	12-Dec-20	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	04:27	04:37	00:10	LINE FAULT
704	12-Dec-20	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	05:17	05:29	00:12	LINE FAULT
705	12-Dec-20	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HANUMANAL_110,HIREG ONNAGAR_110	09:35	09:50	00:15	LINE FAULT
706	12-Dec-20	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HANUMANAL_110,HIREG ONNAGAR_110	11:45	12:09	00:24	LINE FAULT
707	12-Dec-20	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110	01:58	02:06	00:08	LINE FAULT
708	12-Dec-20	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110	05:34	06:06	00:32	LINE FAULT
709	12-Dec-20	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110	20:04	20:20	00:16	LINE FAULT
710	12-Dec-20	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	22:22	22:28	00:06	LINE FAULT
711	12-Dec-20	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	22:40	22:45	00:05	LINE FAULT
712	12-Dec-20	GULBARGA	110	PDHALLI-CLNSLR_IPP	PDHALLI_110	18:29	23:45	05:16	LINE CLEAR AVAILED
713	12-Dec-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:56 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
714	12-Dec-20	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	16:26 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
715	12-Dec-20	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	11:30	12:35	01:05	LINE FAULT
716	12-Dec-20	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	06:48	07:00	00:12	LINE FAULT
717	12-Dec-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	17:15	17:55	00:40	TRANSFORMER FAULT
718	12-Dec-20	HASSAN	66	HV1	HOLALUR_66	10:37	15:07	04:30	TRANSFORMER FAULT
719	12-Dec-20	HASSAN	66	HV2	HOLALUR_66	10:36	13:34	02:58	TRANSFORMER FAULT
720	12-Dec-20	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
721	12-Dec-20	HASSAN	66	LV3	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
722	12-Dec-20	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
723	12-Dec-20	HASSAN	66	MRSSHM-BD-1	MRSMG_220	16:26 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
724	12-Dec-20	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	12:54	13:21	00:27	LINE FAULT
725	12-Dec-20	HASSAN	110	LV1	ARASIKERE_220	12:54	13:22	00:28	TRANSFORMER FAULT
726	12-Dec-20	HASSAN	220	ARSK2-HSN	ARASIKERE_220	9:11 (12.12.2020)			LINE OPEN:LINE CLEAR AVAILED
727	12-Dec-20	HASSAN	220	HV1	ARASIKERE_220	12:54	13:22	00:28	TRANSFORMER FAULT
728	12-Dec-20	HASSAN	220	KADUR-DABUSET	KADUR_220	9:12 (12.12.2020)			LINE OPEN:LINE CLEAR AVAILED
729	12-Dec-20	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	13:47	14:18	00:31	LINE FAULT
730	12-Dec-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:50 (11.12.2020)			LINE OPEN:LINE CLEAR AVAILED
731	12-Dec-20	MYSORE	66	CR NAGARA-YALANDUR	YELANDUR_66	10:40	10:52	0:11	LINE FAULT
732	12-Dec-20	MYSORE	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	4:45 (19.11.2020)			LINE OPEN:LINE CLEAR AVAILED
733	12-Dec-20	MYSORE	66	MADHUVANAHALLI-KOLLEGALA 1	KOLLEGALA_66 PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	18:23 (10.12.2020)	18:17 (12.12.2020)	47:54 HRS	LINE CHARGED
734	12-Dec-20	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	11:23	11:29	0:06	LINE FAULT
735	12-Dec-20	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	13:02	13:35	0:32	LINE CLEAR AVAILED
736	12-Dec-20	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	17:40	17:58	0:17	LINE CLEAR AVAILED
737	12-Dec-20	MYSORE	66	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	10:12	10:20	0:08	HAND TRIPPED
738	12-Dec-20	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	7:05	12:04	4:59	LINE CLEAR AVAILED
739	12-Dec-20	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	7:07	12:07	4:59	LINE CLEAR AVAILED
740	12-Dec-20	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJIHALLI_66	10:02	13:03	3:01	LINE CLEAR AVAILED
741	12-Dec-20	TUMKUR	66	HARAPPANAHALLI-SUZLON 2	SUZLON_IPP_66	11:46:12 (09.12.2020)	15:49:10 (12.12.2020)	76:03 hrs	LINE CHARGED
742	12-Dec-20	TUMKUR	66	PAVAGADA-SHYLAPURA	SHYLAPURA_66,YNHOSKOTE_66,LINGDHALLI_6 6,MANGALWADA_66	15:29	15:30	0:01	LINE FAULT
743	12-Dec-20	TUMKUR	66	TR-2	RANGANATHAPURA_66	7:55	8:40	0:45	LINE CLEAR AVAILED
744	12-Dec-20	TUMKUR	66	TR-3	HARIYABBE_66	11:48	12:52	1:04	TRANSFORMER FAULT
745	12-Dec-20	TUMKUR	66	VENKATAPURA- GOWRIBIDNUR	VENKATAPUR_66	12:27	13:06	0:38	LINE CLEAR AVAILED
746	12-Dec-20	TUMKUR	110	HONNAVALLI 110- KADUR	HONNAVALLI_110	12:58	13:00	0:01	MAIN SUPPLY FAILURE
747	12-Dec-20	TUMKUR	110	HONNAVALLI 110-ADAN SOLAR_IPP_66	ADAN SOLAR_IPP_66	12:25	12:54	0:29	LINE CLEAR AVAILED
748	12-Dec-20	TUMKUR	110	HONNAVALLI 110-ADAN SOLAR_IPP_66	ADAN SOLAR_IPP_66	17:42	17:44	0:01	LINE CLEAR AVAILED
749	12-Dec-20	TUMKUR	110	TR-1	SAMPIGE_110	17:45	18:26	0:40	LINE CLEAR AVAILED
750	12-Dec-20	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	2:31	11:43	9:12	LINE FAULT
751	13-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
752	13-Dec-20	BAGALKOT	110	110/11KV, HV2	TARIHAL_110	10:16	18:05	7:49	LINE CLEAR AVAILED
753	13-Dec-20	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
754	13-Dec-20	BAGALKOT	110	110/33KV, HV3	TARIHAL_110, DHUMMAWAD_33, IE_33	10:16	19:05	8:49	LINE CLEAR AVAILED
755	13-Dec-20	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
756	13-Dec-20	BAGALKOT	110	BAGEWADI1- MAMADAPUR(B)	STATION NOT AFFECTED MAMADAPUR(B)_110	15:36	17:12	1:36	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
757	13-Dec-20	BAGALKOT	110	BAGEWADI-MAMADAPUR 1	MAMADAPUR_110	06:30	06:50	0:20	LINE FAULT
758	13-Dec-20	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	23:46 (11.12.2020)	00:02 (12.12.2020)	0:16 hrs	LINE CHARGED
759	13-Dec-20	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN:LINE CLEAR AVAILED
760	13-Dec-20	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	11:41 (28.11.2020)			LINE OPEN:LINE CLEAR AVAILED
761	13-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
762	13-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
763	13-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
764	13-Dec-20	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	RABAKAVI_110	12:11 (12.12.2020)	10:18 (13.12.2020)	22:29 hrs	LINE CHARGED
765	13-Dec-20	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
766	13-Dec-20	BAGALKOT	110	SATTI- RABAKAVI	RABAKAVI_110	10:00	10:19	0:19	HAND TRIPPED
767	13-Dec-20	BAGALKOT	110	SUARNASOUDA- MACHE	MACHE_110	8:45	18:34	9:49	LINE CLEAR AVAILED
768	13-Dec-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
769	13-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN:LINE CLEAR AVAILED
770	13-Dec-20	BAGALKOT	220	GHATAPRABHA- KUDACHI	GHATAPRABHA_220	6:39 (07.12.2020)			LINE OPEN:LINE CLEAR AVAILED
771	13-Dec-20	BAGALKOT	220	GHATAPRABHA-CHIKKODI	GHATAPRABHA_220	6:39 (07.12.2020)			LINE OPEN:LINE CLEAR AVAILED
772	13-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
773	13-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
774	13-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
775	13-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
776	13-Dec-20	BENGALURU	66	DABUSPETE 220 - HIREHALLI	HIREHALLI	10:05	17:08	07:03	LINE CLEAR AVAILED
777	13-Dec-20	BENGALURU	66	HV1	KOLAR 220	13:00	13:46	00:46	MAIN SUPPLY FAILURE
778	13-Dec-20	BENGALURU	66	HV2	KOLAR 220	13:00	13:45	00:45	MAIN SUPPLY FAILURE
779	13-Dec-20	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	13:00	13:48	00:48	LINE FAULT
780	13-Dec-20	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	13:00	13:47	00:47	MAIN SUPPLY FAILURE
781	13-Dec-20	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	21:51	23:13	01:22	LINE CLEAR AVAILED
782	13-Dec-20	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	13:00	13:56	00:56	LINE FAULT
783	13-Dec-20	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	13:00	13:46	00:46	MAIN SUPPLY FAILURE
784	13-Dec-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	14:06	18:28	04:21	LINE CLEAR AVAILED
785	13-Dec-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	21:42	23:14	01:32	LINE CLEAR AVAILED
786	13-Dec-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	13:00	13:46	00:46	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
787	13-Dec-20	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	16:06	16:12	00:06	LINE FAULT
788	13-Dec-20	BENGALURU	66	KOTHIPURA 220kV - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	10:51	10:54	00:03	LINE FAULT
789	13-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
790	13-Dec-20	BENGALURU	220	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	9:10(12/12/2020)			LINE OPEN:LINE CLEAR AVAILED
791	13-Dec-20	BENGALURU	220	HV2	KOLAR 220	13:00	13:36	00:36	TRANSFORMER FAULT
792	13-Dec-20	GULBARGA	66	HV2	TAMBRAHALLI_66	10:00	17:16	07:16	LOAD CHANGE OVER
793	13-Dec-20	GULBARGA	110	HANUMASAGAR-VARIKAL	VARIKAL_110	12:45	12:48	00:03	LINE FAULT
794	13-Dec-20	GULBARGA	110	KUDITINI-TORANGALU	TORANGALU_110	00:36	00:40	00:04	LINE FAULT
795	13-Dec-20	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HANUMANAL_110,HIREG ONNAGAR_110	09:44	09:54	00:10	LINE FAULT
796	13-Dec-20	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HANUMANAL_110,HIREG ONNAGAR_110	12:26	12:43	00:17	LINE FAULT
797	13-Dec-20	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HANUMANAL_110,HIREG ONNAGAR_110	12:54(13.12.20)			LINE OPEN: LINE FAULT
798	13-Dec-20	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110	05:52	05:56	00:04	LINE FAULT
799	13-Dec-20	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110	06:18	06:24	00:06	LINE FAULT
800	13-Dec-20	GULBARGA	110	PDHALLI-CLNSLR_IPP	PDHALLI_110	00:00	03:31	03:31	LINE FAULT
801	13-Dec-20	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	02:03	02:13	00:10	LINE FAULT
802	13-Dec-20	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	03:12	03:20	00:08	LINE FAULT
803	13-Dec-20	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	05:40	05:56	00:16	LINE FAULT
804	13-Dec-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	03:52	04:05	00:13	LINE FAULT
805	13-Dec-20	GULBARGA	220	LINGAPUR-KUSHTAGI	LINGAPUR_220	04:18	04:47	00:29	LINE FAULT
806	13-Dec-20	GULBARGA	220	MALLAT-RTPS1	MALLAT_220	02:44	02:57	00:13	LINE FAULT
807	13-Dec-20	GULBARGA	400	JSWVL-BPS1	JINDAL_400	06:16	08:53	02:37	LINE FAULT
808	13-Dec-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:56 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
809	13-Dec-20	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	16:26 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
810	13-Dec-20	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	13:49	14:01	00:12	LINE FAULT
811	13-Dec-20	HASSAN	66	HV1	MAGGE_66	08:58	09:40	00:42	MAIN SUPPLY FAILURE
812	13-Dec-20	HASSAN	66	HV1	MALALI_66	13:52	14:03	00:11	MAIN SUPPLY FAILURE
813	13-Dec-20	HASSAN	66	HV1	YESLUR_66	11:47	12:59	01:12	TRANSFORMER FAULT
814	13-Dec-20	HASSAN	66	HV2	MAGGE_66	08:58	09:40	00:42	MAIN SUPPLY FAILURE
815	13-Dec-20	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	08:57	09:37	00:40	LINE FAULT
816	13-Dec-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
817	13-Dec-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
818	13-Dec-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
819	13-Dec-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	13:57	14:03	00:06	MAIN SUPPLY FAILURE
820	13-Dec-20	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	16:26 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
821	13-Dec-20	HASSAN	66	SAKALE-HASSAN1	SAKLESHPUR_66	08:57	09:51	00:54	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
822	13-Dec-20	HASSAN	110	HV1	ALKOLA_110	09:35	17:40	08:05	TRANSFORMER FAULT
823	13-Dec-20	HASSAN	110	HV2	ALKOLA_110	09:35	17:41	08:06	TRANSFORMER FAULT
824	13-Dec-20	HASSAN	110	HV2	BAIKAMPADI_110	11:20	12:20	01:00	TRANSFORMER FAULT
825	13-Dec-20	HASSAN	110	HV2	KULASHEKARA_110	11:35	17:20	05:45	TRANSFORMER FAULT
826	13-Dec-20	HASSAN	110	HV3	ALKOLA_110	09:35	17:41	08:06	TRANSFORMER FAULT
827	13-Dec-20	HASSAN	110	JOG110-LPH	JOG_110	16:01	19:51	03:50	LINE FAULT
828	13-Dec-20	HASSAN	220	ARSK2-HSN	ARASIKERE_220	9:11 (12.12.2020)			LINE OPEN:LINE CLEAR AVAILED
829	13-Dec-20	HASSAN	220	KADUR-DABUSET	KADUR_220	9:12 (12.12.2020)			LINE OPEN:LINE CLEAR AVAILED
830	13-Dec-20	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	12:01	15:10	03:09	LINE FAULT
831	13-Dec-20	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	12:01	15:10	03:09	LINE FAULT
832	13-Dec-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:50 (11.12.2020)			LINE OPEN:LINE CLEAR AVAILED
833	13-Dec-20	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	20:35	20:40	0:04	LINE FAULT
834	13-Dec-20	MYSORE	66	DR PETE-KUNTHUR	SANTHEMARAHALLI_66	10:15	16:25	6:09	NFBC ISSUED
835	13-Dec-20	MYSORE	66	HV2	BOMMALAPURA_66	8:30	8:51	0:21	TRANSFORMER FAULT
836	13-Dec-20	MYSORE	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	4:45 (19.11.2020)			LINE OPEN:LINE CLEAR AVAILED
837	13-Dec-20	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	8:30	8:35	0:05	LINE FAULT
838	13-Dec-20	MYSORE	66	MUGUR-KUNTHUR	SANTHEMARAHALLI_66	10:13	16:25	6:11	NFBC ISSUED
839	13-Dec-20	MYSORE	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66 BELAGOLA_66	9:11	9:18	0:06	LINE FAULT
840	13-Dec-20	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	6:45	15:08	8:22	LINE CLEAR AVAILED
841	13-Dec-20	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	16:35	17:00	0:25	LINE CLEAR AVAILED
842	13-Dec-20	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	6:45	15:10	8:24	LINE CLEAR AVAILED
843	13-Dec-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:47	9:51	0:04	LINE FAULT
844	13-Dec-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:26	15:38	0:11	HAND TRIPPED
845	13-Dec-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	15:26	15:39	0:13	MAIN SUPPLY FAILURE
846	13-Dec-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66, BASAVAPATNA_66	14:23	14:32	0:09	LINE FAULT
847	13-Dec-20	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66	6:34	7:20	0:45	LINE CLEAR AVAILED
848	13-Dec-20	TUMKUR	66	TR-1(LV SIDE)	DAVANGERE_SRS_220	14:40	15:19	0:39	TRANSFORMER FAULT
849	13-Dec-20	TUMKUR	66	TR-3	HARIYABBE_66	9:55	10:04	0:09	TRANSFORMER FAULT
850	13-Dec-20	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	14:40	18:18	3:38	LINE FAULT
851	13-Dec-20	TUMKUR	220	HONNALLI 220kV- DAVANAGERE 220kV	HONNALLI_220	14:39	15:26	0:47	LINE FAULT
852	13-Dec-20	TUMKUR	220	HONNALLI 220kV- SUZLON2	SUZLON_IPP_66	15:27	17:45	2:17	MAIN SUPPLY FAILURE
853	13-Dec-20	TUMKUR	220	TR-1(HV SIDE)	DAVANGERE_SRS_220	14:40	15:19	0:39	TRANSFORMER FAULT
854	14-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
855	14-Dec-20	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TIKOTA_110	10:24	10:37	0:13	LINE CLEAR AVOIDED
856	14-Dec-20	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TIKOTA_110	16:51	17:34	0:43	LINE CLEAR AVOIDED
857	14-Dec-20	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED VAJRAMATTI_110	12:34	12:49	0:15	TRANSFORMER FAULT
858	14-Dec-20	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
859	14-Dec-20	BAGALKOT	110	110/11KV,HV1	HATTARAGI_110	12:31	14:01	1:30	LINE CLEAR AVOIDED
860	14-Dec-20	BAGALKOT	110	110/11KV,HV2	HUNGUND_110	08:08	08:12	0:04	TRANSFORMER FAULT
861	14-Dec-20	BAGALKOT	110	110/11KV,HV2	MUKARTIHAL_110	11:55	13:05	1:10	LINE CLEAR AVOIDED
862	14-Dec-20	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110 &ALNAVAR_33	09:22	9:28	0:06	TRANSFORMER FAULT
863	14-Dec-20	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
864	14-Dec-20	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED NAREGAL_110	13:17	18:15	4:58	LINE CLEAR AVOIDED
865	14-Dec-20	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN:LINE CLEAR AVOIDED
866	14-Dec-20	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	11:41 (28.11.2020)			LINE OPEN:LINE CLEAR AVOIDED
867	14-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVOIDED
868	14-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVOIDED
869	14-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
870	14-Dec-20	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN: LINE FAULT
871	14-Dec-20	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	STATION NOT AFFECTED GAJENDRAGAD_110	13:11	14:15	1:04	LINE CLEAR AVOIDED
872	14-Dec-20	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	STATION NOT AFFECTED BANAHATTI_110	18:45 (14.12.2020)			LINE OPEN: LINE FAULT
873	14-Dec-20	BAGALKOT	110	NAREGAL-BETAGERI	STATION NOT AFFECTED BETAGERI_110	13:16	18:16	5:00	LINE CLEAR AVOIDED
874	14-Dec-20	BAGALKOT	110	NAREGAL-RON	NAREGAL_110	18:16	18:38	0:22	HAND TRIPPED
875	14-Dec-20	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
876	14-Dec-20	BAGALKOT	110	RON-BELAVANKI	BELAVANKI_110	13:10	13:25	0:15	HAND TRIPPED
877	14-Dec-20	BAGALKOT	110	RON-BELAVANKI	BELAVANKI_110	18:30	18:40	0:10	HAND TRIPPED
878	14-Dec-20	BAGALKOT	110	RON-GAJENDRAGAD1&2	GAJENDRAGAD_110	13:15	13:25	0:10	HAND TRIPPED
879	14-Dec-20	BAGALKOT	110	RON-GAJENDRAGAD1&2	GAJENDRAGAD_110	18:30	18:40	0:10	HAND TRIPPED
880	14-Dec-20	BAGALKOT	110	RON-GAMESH	RON_110	13:27	13:34	0:07	HAND TRIPPED
881	14-Dec-20	BAGALKOT	110	RON-GAMESH	STATION NOT AFFECTED RON_110	18:43	19:02	0:19	HAND TRIPPED
882	14-Dec-20	BAGALKOT	110	RON-HIREHAL	STATION NOT AFFECTED HIREHAL_110	18:43	18:45	0:02	HAND TRIPPED
883	14-Dec-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
884	14-Dec-20	BAGALKOT	220	220/110KV,HV1,LV1	KUDUCHI_220,	13:25	13:50	0:25	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
885	14-Dec-20	BAGALKOT	220	220/110KV,HV2,LV2	KUDUCHI_220,MORAB_110,AINAPUR_110,YELL APARHATTI_110,KUDUCHI_110,UGAR KHUD_110,SHIRAGUPPI_110	13:00	13:20	0:20	TRANSFORMER FAULT
886	14-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN:LINE CLEAR AVAILED
887	14-Dec-20	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	21:06 (14.12.2020)			LOAD CURTAILMENT
888	14-Dec-20	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	21:04 (14.12.2020)			LOAD CURTAILMENT
889	14-Dec-20	BAGALKOT	220	BIDNAL-HIREBENDIGER1	STATION NOT AFFECTED BIDNAL_220	15:03	17:20	2:17	NFBC ISSUED
890	14-Dec-20	BAGALKOT	220	GHATAPRABHA- KUDACHI	GHATAPRABHA_220	6:39 (07.12.2020)			LINE OPEN:LINE CLEAR AVAILED
891	14-Dec-20	BAGALKOT	220	GHATAPRABHA-CHIKKODI	GHATAPRABHA_220	6:39 (07.12.2020)			LINE OPEN:LINE CLEAR AVAILED
892	14-Dec-20	BAGALKOT	220	HUBLI- NAGJHARI1	HUBLI_220	9:57	21:43	11:46	LINE CLEAR AVAILED
893	14-Dec-20	BAGALKOT	220	HUBLI- NAGJHARI1	HUBLI_220	9:57	21:44	11:47	LINE CLEAR AVAILED
894	14-Dec-20	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	09:07	15:47	6:40	LINE CLEAR AVAILED
895	14-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
896	14-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
897	14-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
898	14-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
899	14-Dec-20	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	12:54	13:09	00:15	LINE CLEAR AVAILED
900	14-Dec-20	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	14:30	14:40	00:10	LINE CLEAR AVAILED
901	14-Dec-20	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	10:00	10:05	00:05	LOAD CHANGE OVER
902	14-Dec-20	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	06:20	06:33	00:13	MAIN SUPPLY FAILURE
903	14-Dec-20	BENGALURU	66	HV1	VIKAS TECH PARK 220	11:48	12:18	00:30	LINE CLEAR AVAILED
904	14-Dec-20	BENGALURU	66	HV2	DODDABELAVANGALA	15:56	17:35	01:39	LINE CLEAR AVAILED
905	14-Dec-20	BENGALURU	66	HV2	MAASTI	13:01	14:35	01:34	LINE CLEAR AVAILED
906	14-Dec-20	BENGALURU	66	VIDYANAGARA - HENNUR CORSS	NO STATION AFFECTED	06:20	09:50	03:30	LINE FAULT
907	14-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
908	14-Dec-20	BENGALURU	220	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	9:10(12/12/2020)			LINE OPEN:LINE CLEAR AVAILED
909	14-Dec-20	GULBARGA	66	HV1	KUDLIGI_66	12:19	13:10	00:51	LINE CLEAR AVAILED
910	14-Dec-20	GULBARGA	66	HV1	KUDLIGI_66	14:38	15:34	00:56	LINE CLEAR AVAILED
911	14-Dec-20	GULBARGA	66	ITTAGI-KUDLIGI	KUDLIGI_66	17:05	17:15	00:10	MAIN SUPPLY FAILURE
912	14-Dec-20	GULBARGA	110	HV1	HANUMASAGAR_110	16:05	16:25	00:20	LINE CLEAR AVAILED
913	14-Dec-20	GULBARGA	110	SEDAM-SHAHABAD(CHITAPUR)	CHITAPUR_110,KORAWAR TEMPLE_110,RAJASHREE CEMENTS_IPP	06:47	06:57	00:10	LINE FAULT
914	14-Dec-20	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	05:47	06:01	00:14	LINE FAULT
915	14-Dec-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKKUNDA_110,KAMPLI_GLB_110,MALLAPUR A_110,SRERAMANAGAR_IPP,YERADONA_110	11:15	11:25	00:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
916	14-Dec-20	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	10:03	19:22	09:19	LINE CLEAR AVAILED
917	14-Dec-20	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	14:58	15:06	00:08	LINE FAULT
918	14-Dec-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:56 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
919	14-Dec-20	HASSAN	66	BHADRA-SHMG 1	bhadra_gen	16:26 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
920	14-Dec-20	HASSAN	66	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	15:05	15:26	00:21	HAND TRIPPED
921	14-Dec-20	HASSAN	66	HASSN220-MALLALI	HASSAN_220	14:25	14:55	00:30	HAND TRIPPED
922	14-Dec-20	HASSAN	66	HASSN220-R R NAGAR	HASSAN_220	14:25	15:24	00:59	HAND TRIPPED
923	14-Dec-20	HASSAN	66	HASSN220-UDDURKOPLU	HASSAN_220	14:25	14:55	00:30	HAND TRIPPED
924	14-Dec-20	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	09:11	09:20	00:09	LINE FAULT
925	14-Dec-20	HASSAN	66	HV1	SHRAVANABELAGOLA_66	04:03	04:20	00:17	TRANSFORMER FAULT
926	14-Dec-20	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	13:40	15:47	02:07	LINE CLEAR AVAILED
927	14-Dec-20	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
928	14-Dec-20	HASSAN	66	LV3	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
929	14-Dec-20	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
930	14-Dec-20	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	10:50	11:08	00:18	LINE FAULT
931	14-Dec-20	HASSAN	66	MATTNAV-DIDGTHL	MATTNAVILE_66	04:54	05:09	00:15	LINE FAULT
932	14-Dec-20	HASSAN	66	MATTNAV-DIDGTHL	MATTNAVILE_66	14:55	15:09	00:14	HAND TRIPPED
933	14-Dec-20	HASSAN	66	MRSSH-BD-1	MRSMG_220	16:26 (5.12.2020)			LINE OPEN:LINE CLEAR AVAILED
934	14-Dec-20	HASSAN	66	SAKALE-HASSAN	SAKLESHPUA_66	13:40	15:48	02:08	NFBC ISSUED
935	14-Dec-20	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	13:14	13:24	00:10	LINE FAULT
936	14-Dec-20	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	23:12	23:21	00:09	LINE FAULT
937	14-Dec-20	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	18:37	19:02	00:25	LINE FAULT
938	14-Dec-20	HASSAN	110	HV1	BANTWAL_110	10:15	15:10	04:55	LINE CLEAR AVAILED
939	14-Dec-20	HASSAN	110	HV2	ESSUR_110	12:12	12:21	00:09	LINE CLEAR AVAILED
940	14-Dec-20	HASSAN	110	HV3	HIRIYADKA_110	10:23	11:33	01:10	LINE CLEAR AVAILED
941	14-Dec-20	HASSAN	110	HV4	MANIPAL_110	14:58	15:46	00:48	TRANSFORMER FAULT
942	14-Dec-20	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	11:45	11:50	00:05	LINE FAULT
943	14-Dec-20	HASSAN	110	MADHUV-HIRIYADKA	MADHUVANA_110	18:38	19:03	00:25	MAIN SUPPLY FAILURE
944	14-Dec-20	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	11:43	18:27	06:44	LINE CLEAR AVAILED
945	14-Dec-20	HASSAN	110	SAGARA-TAL	SAGARA_110	10:31	13:45	03:14	NFBC ISSUED
946	14-Dec-20	HASSAN	220	ARSK2-HSN	ARASIKERE_220	9:11 (12.12.2020)			LINE OPEN:LINE CLEAR AVAILED
947	14-Dec-20	HASSAN	220	HASSN220-NITTUR	HASSAN_220	14:25	15:20	00:55	LINE FAULT
948	14-Dec-20	HASSAN	220	KADUR-DABUSET	KADUR_220	9:12 (12.12.2020)			LINE OPEN:LINE CLEAR AVAILED
949	14-Dec-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:50 (11.12.2020)	9:04 (14.12.2020)	59:13 hrs	LINE CHARGED
950	14-Dec-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:19 (14.12.2020)			LINE OPEN:LINE CLEAR AVAILED
951	14-Dec-20	MYSORE	66	ANEGOLA-HUYGONAHALLY	ANEGOLAL_66	14:05	14:30	0:25	LINE CLEAR AVAILED
952	14-Dec-20	MYSORE	66	ANEGOLA-HUYGONAHALLY	ANEGOLAL_66	15:50	15:55	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
953	14-Dec-20	MYSORE	66	ANEGOLA-HUYGONAHALLY	ANEGOLAL_66	16:04	16:08	0:03	LINE FAULT
954	14-Dec-20	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	0:09	0:14	0:05	LINE FAULT
955	14-Dec-20	MYSORE	66	HV1	DEVANOORNGUDU_66	13:09	14:40	1:30	LINE CLEAR AVAILED
956	14-Dec-20	MYSORE	66	HV2	DEVANOORNGUDU_66	12:15	13:50	1:35	LINE CLEAR AVAILED
957	14-Dec-20	MYSORE	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	4:45 (19.11.2020)	16:00 (14.12.2020)	611:15 HRS	LINE CHARGED
958	14-Dec-20	MYSORE	66	KUNTHUR-DR PETE	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 SANTHEMARAHALLI_66	17:50	17:58	0:08	LINE FAULT
959	14-Dec-20	MYSORE	66	KUNTHUR-DR PETE	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 SANTHEMARAHALLI_66	6:15	6:20	0:05	LINE FAULT
960	14-Dec-20	MYSORE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	15:59	16:04	0:05	LINE FAULT
961	14-Dec-20	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	16:24	16:31	0:07	LINE FAULT
962	14-Dec-20	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	7:16	7:23	0:07	LINE FAULT
963	14-Dec-20	MYSORE	66	VAJMANGALA-MEGALAPURA	BGPURA_66 CHIDRAVALI_66 GARGESHWARI_66 MEGALAPURA_66 THUMBLA_66 VYASRAJPURA_66	13:14	13:22	0:08	LINE FAULT
964	14-Dec-20	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	16:53	18:05	1:12	LOAD CURTAILMENT
965	14-Dec-20	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	13:22	13:33	0:11	LINE FAULT
966	14-Dec-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:22	12:30	0:08	LINE FAULT
967	14-Dec-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	14:15	14:48	0:32	LINE CLEAR AVAILED
968	14-Dec-20	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66, UCHCHANGIDURGA_66, P ALLAGATTE_66, SOKKE_66	9:03	9:14	0:10	LINE FAULT
969	14-Dec-20	TUMKUR	66	SAVALANGA 66kv-HNLI220_NYMT	SAVALANGA_66	10:09	13:16	3:07	LINE CLEAR AVAILED
970	14-Dec-20	TUMKUR	66	TR-1	BENKIKERE_66	10:33	10:41	0:07	TRANSFORMER FAULT
971	14-Dec-20	TUMKUR	66	TR-1	BENKIKERE_66	10:45	10:49	0:04	TRANSFORMER FAULT
972	14-Dec-20	TUMKUR	66	TR-1	MADHUGIRI_66	12:34	13:19	0:45	LINE CLEAR AVAILED
973	14-Dec-20	TUMKUR	66	TR-1	MYLANAHALLI_66	7:52	8:22	0:29	LINE CLEAR AVAILED
974	14-Dec-20	TUMKUR	66	TR-1	PAVAGADA_220	15:30	15:33	0:03	TRANSFORMER FAULT
975	14-Dec-20	TUMKUR	66	TR-1	SAVALANGA_66	8:25	13:35	5:09	LINE CLEAR AVAILED
976	14-Dec-20	TUMKUR	66	TR-2	BENNEHALLI_66	13:48	14:13	0:25	LINE CLEAR AVAILED
977	14-Dec-20	TUMKUR	66	TR-2	MADHUGIRI_66	12:37	13:00	0:23	LINE CLEAR AVAILED
978	14-Dec-20	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	10:37	12:44	2:06	LINE CLEAR AVAILED
979	14-Dec-20	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	16:08	16:19	0:10	LINE CLEAR AVAILED
980	14-Dec-20	TUMKUR	66	TR-3	HARIYABBE_66	11:27	11:34	0:06	LINE CLEAR AVAILED
981	14-Dec-20	TUMKUR	66	TR-3	HARIYABBE_66	11:40	11:48	0:07	LINE CLEAR AVAILED
982	14-Dec-20	TUMKUR	66	TR-3	HARIYABBE_66	15:36	15:43	0:06	LINE CLEAR AVAILED
983	14-Dec-20	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	10:15	11:03	0:48	LINE CLEAR AVAILED
984	14-Dec-20	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	16:08	16:18	0:09	LINE CLEAR AVAILED