

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 01.10.2019 TO 07.10.2019**

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	1-Oct-19	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	12:25	12:43	0:18	LINE FAULT
2	1-Oct-19	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	14:38	15:07	0:29	LINE CLEAR AVAILED
3	1-Oct-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	15:47	16:31	0:44	LINE CLEAR AVAILED
4	1-Oct-19	BAGALKOT	110	110/11KV,HV2	KAGAWADA_110	10:26	10:38	0:12	TRANSFORMER FAULT
5	1-Oct-19	BAGALKOT	220	KADRA2-KARWAR	KARWAR_220	7:57	10:26	2:29	LINE FAULT
6	1-Oct-19	BAGALKOT	110	KARWAR220-BINAGA	BINAGA_110	7:57	14:18	6:21	LINE FAULT
7	1-Oct-19	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	12:02	14:20	2:18	LINE CLEAR AVAILED
8	1-Oct-19	BAGALKOT	220	NAGJHARI2-HUBLI	HUBLI_220	12:38	16:25	3:47	LINE CLEAR AVAILED
9	1-Oct-19	BAGALKOT	220	CHIKKODI-MUDASHINGI	CHIKKODI_220	0:00	17:05	17:05	LINE CLEAR AVAILED
10	1-Oct-19	BAGALKOT	220	CHIKKODI-TALANDGE	CHIKKODI_220	10:44	17:02	6:18	LINE CLEAR AVAILED
11	1-Oct-19	BAGALKOT	110	BELGAUM 220-ANKALAGI	ANKALAGI_110	19:18	23:59	4:41	LOAD CHANGE OVER
12	1-Oct-19	BAGALKOT	220	HAVERI-GUTTUR2	HAVERI_220	15:47	16:31	0:44	LINE CLEAR AVAILED
13	1-Oct-19	BAGALKOT	110	RANEENNUR-HIREKERUR	HIREKERUR_110	3:29	11:58	8:29	LINE FAULT
14	1-Oct-19	BAGALKOT	220	HUBLI-NAGJHARI1	HUBLI_220	0:00	16:46	16:46	LINE CLEAR AVAILED
15	1-Oct-19	BAGALKOT	110	AMBEWADI-KADANKOPPA	KADANKOPPA_110	21:22	21:49	0:27	LINE FAULT
16	1-Oct-19	BAGALKOT	110	MYFAIR SOLAR-HIREHAL	HIREHAL_110	20:28	23:59	3:31	LINE CLEAR AVAILED
17	1-Oct-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, SOMAYAJANAHALLI, ADDAGAL	5:04	5:17	0:13	LINE FAULT
18	1-Oct-19	BENGALURU	66	AVANI - KOLAR 220	AVANI, MULBAGAL	15:40	21:35	5:55	LINE CLEAR AVAILED
19	1-Oct-19	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	23:09	23:24	0:14	LINE FAULT
20	1-Oct-19	BENGALURU	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	21:58	22:14	0:16	LINE FAULT
21	1-Oct-19	BENGALURU	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	23:29	23:42	0:13	LINE FAULT
22	1-Oct-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	19:00	19:05	0:05	LINE FAULT
23	1-Oct-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	21:58	22:08	0:10	LINE FAULT
24	1-Oct-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	22:15	22:19	0:03	LINE FAULT
25	1-Oct-19	BENGALURU	66	ARMY WELFARE ORGANIZATION - KADUGODI	ARMY WELFARE ORGANIZATION, KONDASPURA	12:03	12:37	0:34	LINE CLEAR AVAILED
26	1-Oct-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	11:18	11:56	0:37	LINE CLEAR AVAILED
27	1-Oct-19	BENGALURU	66	YELAHANKA 220 - LINE 4	ESCORTS (EHT)	21:24	23:59	2:34	LINE FAULT
28	1-Oct-19	BENGALURU	66	SAHAKARINAGARA - DG 4	SAHAKARINAGARA	21:24	21:37	0:12	MAIN SUPPLY FAILURE
29	1-Oct-19	BENGALURU	66	HOODY 220 - RAILWAYS 1 (EHT)	RAILWAYS 1 (EHT)	9:42	14:15	4:33	LINE FAULT
30	1-Oct-19	BENGALURU	220	HV2	HOODY 220	9:42	10:05	0:23	TRANSFORMER FAULT
31	1-Oct-19	BENGALURU	220	HV3	HOODY 220	9:42	10:33	0:51	TRANSFORMER FAULT
32	1-Oct-19	BENGALURU	66	HOODY 220 - BMRL (EHT)	BMRL (EHT)	9:44	10:35	0:51	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
33	1-Oct-19	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	9:44	10:35	0:51	LINE CLEAR AVAILED
34	1-Oct-19	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	9:44	10:35	0:51	LINE CLEAR AVAILED
35	1-Oct-19	BENGALURU	66	HOODY 220 - HP (EHT)	HP (EHT)	9:44	10:35	0:51	LINE CLEAR AVAILED
36	1-Oct-19	BENGALURU	66	HOODY 220 - SHANTHINIKETHAN	SHANTHINIKETHAN	9:44	10:35	0:51	LINE CLEAR AVAILED
37	1-Oct-19	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	9:44	10:35	0:51	LINE CLEAR AVAILED
38	1-Oct-19	BENGALURU	66	HOODY 220 - ITI	ITI	9:44	10:35	0:51	LINE CLEAR AVAILED
39	1-Oct-19	BENGALURU	66	HV2	HOODY 220	9:44	10:35	0:51	LINE CLEAR AVAILED
40	1-Oct-19	BENGALURU	66	HV2	HOODY 220	11:10	11:50	0:40	LINE CLEAR AVAILED
41	1-Oct-19	BENGALURU	66	HOODY 220 - GRAPHITE INDIA (EHT)	GRAPHITE INDIA (EHT)	11:37	13:39	2:02	LINE FAULT
42	1-Oct-19	BENGALURU	66	REMCO-SUBRAMANYAPURA 220	GLOBAL VILLAGE (EHT)	16:45	16:56	0:11	MAIN SUPPLY FAILURE
43	1-Oct-19	BENGALURU	66	REMCO-VRISHABHAVATHI 220	GLOBAL VILLAGE (EHT)	18:24	18:30	0:06	LOAD CHANGE OVER
44	1-Oct-19	BENGALURU	66	HV2	VIJAYANAGARA	23:12	23:22	0:10	TRANSFORMER FAULT
45	1-Oct-19	BENGALURU	66	HV2	YARANDANAHALLI 220	20:55	21:55	1:00	LOAD CHANGE OVER
46	1-Oct-19	BENGALURU	66	HV3	YARANDANAHALLI 220	20:55	21:55	1:00	LOAD CHANGE OVER
47	1-Oct-19	GULBARGA	110	HV2	SHORAPUR_110	8:01	9:28	1:27	LINE CLEAR AVAILED
48	1-Oct-19	GULBARGA	110	GABBUR-BPSLR_IPP	GABBUR_110	4:20	4:25	0:05	LINE FAULT
49	1-Oct-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	12:15	12:20	0:05	LINE FAULT
50	1-Oct-19	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	1:16	1:26	0:10	LINE FAULT
51	1-Oct-19	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	3:51	3:58	0:07	LINE FAULT
52	1-Oct-19	GULBARGA	110	HV1	SHAHPUR_220	15:44	15:58	0:14	TRANSFORMER FAULT
53	1-Oct-19	GULBARGA	110	GABBUR-DEODURGA	GABUR_110	20:35	23:59	3:24	LINE CLEAR AVAILED
54	1-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	14:12	23:59	9:47	LINE CLEAR AVAILED
55	1-Oct-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	5:02	5:02	LINE CLEAR AVAILED
56	1-Oct-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	0:00	9:32	9:32	LINE FAULT
57	1-Oct-19	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	0:00	9:32	9:32	LINE FAULT
58	1-Oct-19	HASSAN	110	HV1	BAIKAMPADI_110	0:00	13:46	13:46	TRANSFORMER FAULT
59	1-Oct-19	HASSAN	110	HV2	BARANGI_110	11:23	18:02	6:39	LINE CLEAR AVAILED
60	1-Oct-19	HASSAN	110	HV2	GERUMARA_110	12:35	13:08	0:33	LINE CLEAR AVAILED
61	1-Oct-19	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	10:49	12:45	1:56	LINE CLEAR AVAILED
62	1-Oct-19	HASSAN	110	SAGARA-JST1	SAGARA_110	13:39	14:04	0:25	LINE FAULT
63	1-Oct-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:44	15:52	0:08	LINE FAULT
64	1-Oct-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	7:50	8:10	0:20	LINE FAULT
65	1-Oct-19	HASSAN	66	HV2	KIADB_66	10:27	10:33	0:06	TRANSFORMER FAULT
66	1-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	18:14	18:14	LINE CLEAR AVAILED
67	1-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:19	23:59	1:40	LINE CLEAR AVAILED
68	1-Oct-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	14:47	23:59	9:12	LINE CLEAR AVAILED
69	1-Oct-19	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	14:44	23:59	9:15	LINE CLEAR AVAILED
70	1-Oct-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	10:29	14:13	3:44	LINE CLEAR AVAILED
71	1-Oct-19	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	11:05	11:17	0:12	LINE FAULT
72	1-Oct-19	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	13:41	14:11	0:30	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
73	1-Oct-19	HASSAN	66	HV2	HALEBEEDU_66	20:56	21:16	0:20	TRANSFORMER FAULT
74	1-Oct-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	15:23	15:48	0:25	LINE FAULT
75	1-Oct-19	MYSORE	66	HANNUR-MADHUVANAHALLI 1	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66, KOTTANUR_66	7:07	7:17	0:09	LINE FAULT
76	1-Oct-19	MYSORE	66	HANNUR-MADHUVANAHALLI 1	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66, KOTTANUR_66	8:30	8:40	0:10	LINE FAULT
77	1-Oct-19	MYSORE	66	HV2	KIRUGAVALU_66	11:57	17:24	5:27	TRANSFORMER FAULT
78	1-Oct-19	MYSORE	66	MADHUVANAHALLI -HANNUR 2	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	7:07	7:15	0:07	LINE CLEAR AVAILED
79	1-Oct-19	MYSORE	66	MADHUVANAHALLI -HANNUR 2	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	8:30	8:37	0:07	LINE FAULT
80	1-Oct-19	MYSORE	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66, PANDAVAPURA_66	0:16	0:23	0:07	LINE FAULT
81	1-Oct-19	TUMKUR	110	TR-1	GUBBI_110	7:50	16:25	8:34	TRANSFORMER FAULT
82	1-Oct-19	TUMKUR	110	TR-1	GUBBI_110	19:22	19:26	0:04	TRANSFORMER FAULT
83	1-Oct-19	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	19:45	19:49	0:04	LINE FAULT
84	1-Oct-19	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	18:30	18:57	0:27	LINE FAULT
85	1-Oct-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	14:43	19:08	4:24	LINE FAULT
86	1-Oct-19	TUMKUR	66	HARIHARA-DAVANGERE_HARIHAR	HARIHAR_66	15:33	19:00	3:27	LINE CLEAR AVAILED
87	1-Oct-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	17:21	18:42	1:21	LINE FAULT
88	1-Oct-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	18:24	18:34	0:10	LINE FAULT
89	2-Oct-19	BAGALKOT	110	BELGAUM 220-ANKALAGI	ANKALAGI_110	0:00	11:13	11:13	LINE CLEAR AVAILED
90	2-Oct-19	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	5:39	13:51	8:12	LINE FAULT
91	2-Oct-19	BAGALKOT	220	BIDNAL-HAVERI	BIDNAL_220	17:37	18:14	0:37	HAND TRIPPED
92	2-Oct-19	BAGALKOT	110	BIDNAL-PH COMPOUND	PH COMPOUND_110	0:00	13:37	13:37	LINE CLEAR AVAILED
93	2-Oct-19	BAGALKOT	110	BIDNAL-PH COMPOUND	PH COMPOUND_110	14:56	15:51	0:55	NFBC ISSUED
94	2-Oct-19	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA 2	GHTAPRABHA_110	6:17	6:34	0:17	LINE FAULT
95	2-Oct-19	BAGALKOT	110	HATTARAGI-DADDI	DADDI_110	6:37	6:45	0:08	LINE FAULT
96	2-Oct-19	BAGALKOT	220	HAVERI-NARENDRA	HAVERI_220	14:05	21:08	7:03	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
97	2-Oct-19	BAGALKOT	220	HAVERI-BIDNAL	HAVERI_220	17:36	18:14	0:38	LINE CLEAR AVAILED
98	2-Oct-19	BAGALKOT	110	110/33KV, HV1	YARGATTI_110, SHIVAPURA_33, LIS_33, BOSH SOLAR_33	17:43	18:07	0:24	LINE CLEAR AVAILED
99	2-Oct-19	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	14:06	19:38	5:32	LINE FAULT
100	2-Oct-19	BAGALKOT	110	110/11KV, HV2	PG HUNSHYAL_110	11:30	11:42	0:12	LINE CLEAR AVAILED
101	2-Oct-19	BAGALKOT	220	NARENDRA-HAVERI	NARENDRA_220	14:05	21:08	7:03	LINE FAULT
102	2-Oct-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	21:16	23:59	2:43	LINE CLEAR AVAILED
103	2-Oct-19	BAGALKOT	110	110/33KV,HV4	LAKMANHALLI_110, ALNAVAR_33	18:02	18:16	0:14	TRANSFORMER FAULT
104	2-Oct-19	BAGALKOT	110	110/11KV,HV2	KAGAWADA_110	10:26	10:38	0:12	TRANSFORMER FAULT
105	2-Oct-19	BAGALKOT	110	SHIROL-JAMKHANDI	JAMKAHANDI_110, NAVALGI_110	22:05	22:44	0:39	LINE FAULT
106	2-Oct-19	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	20:27	20:43	0:16	TRANSFORMER FAULT
107	2-Oct-19	BAGALKOT	110	MYFAIR SOLAR-HIREHAL	HIREHAL_110	0:00	6:12	6:12	LINE CLEAR AVAILED
108	2-Oct-19	BAGALKOT	110	MYFAIR SOLAR-HIREHAL	HIREHAL_110	20:42	23:59	3:17	LINE CLEAR AVAILED
109	2-Oct-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	2:38	2:57	0:19	LINE FAULT
110	2-Oct-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	2:38	2:57	0:18	LINE FAULT
111	2-Oct-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	18:26	18:37	0:10	LINE FAULT
112	2-Oct-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	18:37	18:40	0:02	LINE FAULT
113	2-Oct-19	BENGALURU	66	HV1	HOSKOTE 66	13:49	14:25	0:35	TRANSFORMER FAULT
114	2-Oct-19	BENGALURU	66	KOLAR 220 - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI, KEMBODI	8:11	8:33	0:22	LINE FAULT
115	2-Oct-19	BENGALURU	66	HV1	KOLAR 220	18:11	21:11	3:00	TRANSFORMER FAULT
116	2-Oct-19	BENGALURU	66	HV1	NARASAPURA	11:30	11:51	0:21	LINE CLEAR AVAILED
117	2-Oct-19	BENGALURU	66	HV1	SURYANAGARA	14:21	14:40	0:19	LINE CLEAR AVAILED
118	2-Oct-19	BENGALURU	66	YELAHANKA 220 - LINE 4	ESCORTS (EHT)	0:00	0:01	0:01	LINE FAULT
119	2-Oct-19	BENGALURU	66	HV1	RANGANADODDI	12:11	14:09	1:58	LINE CLEAR AVAILED
120	2-Oct-19	BENGALURU	220	YELAHANKA 220 - MANYATA TECH PARK 220	MANYATA TECH PARK 220	8:34	9:02	0:28	LINE FAULT
121	2-Oct-19	BENGALURU	220	MANYAT TECH PARK 220 - HOODY 220	MANYATA TECH PARK 220	11:01	11:13	0:12	LOAD CHANGE OVER
122	2-Oct-19	BENGALURU	66	SAHAKARINAGARA - MANYATA TECH PARK 220	SAHAKARINAGARA	1:24	1:34	0:10	LOAD CHANGE OVER
123	2-Oct-19	BENGALURU	66	HEBBAL 220 - C STATION 1 & 2	C STATION	8:36	9:02	0:26	LINE CLEAR AVAILED
124	2-Oct-19	BENGALURU	66	HEBBAL 220 - C STATION 1 & 2	C STATION	11:38	11:42	0:04	LOAD CHANGE OVER
125	2-Oct-19	BENGALURU	66	HEBBAL 220 - IISC	IISC	8:36	9:02	0:26	LINE CLEAR AVAILED
126	2-Oct-19	BENGALURU	66	HEBBAL 220 - IISC	IISC	11:38	11:42	0:04	LOAD CHANGE OVER
127	2-Oct-19	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	8:36	9:02	0:26	LINE CLEAR AVAILED
128	2-Oct-19	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	11:38	11:42	0:04	LOAD CHANGE OVER
129	2-Oct-19	BENGALURU	66	HV1	HEBBAL 220	8:36	9:02	0:26	LINE CLEAR AVAILED
130	2-Oct-19	BENGALURU	66	HV1	HEBBAL 220	11:38	11:42	0:04	LOAD CHANGE OVER
131	2-Oct-19	BENGALURU	66	HV3	HEBBAL 220	8:36	9:02	0:26	LINE CLEAR AVAILED
132	2-Oct-19	BENGALURU	66	HV3	HEBBAL 220	11:38	11:42	0:04	LOAD CHANGE OVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
133	2-Oct-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	16:20	16:28	0:08	LOAD CHANGE OVER
134	2-Oct-19	BENGALURU	66	HV2	NGEF	16:11	16:33	0:22	TRANSFORMER FAULT
135	2-Oct-19	GULBARGA	110	GABBUR-DEODURGA	GABUR_110	0:00	2:55	2:55	LINE CLEAR AVAILED
136	2-Oct-19	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	4:50	4:56	0:06	LINE FAULT
137	2-Oct-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	6:02	6:13	0:11	LINE FAULT
138	2-Oct-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	19:01	19:12	0:11	LINE FAULT
139	2-Oct-19	GULBARGA	66	LV1	ITTAGI_220	7:10	7:18	0:08	TRANSFORMER FAULT
140	2-Oct-19	GULBARGA	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	17:53	19:55	2:02	LINE CLEAR AVAILED
141	2-Oct-19	GULBARGA	66	ITTAGI-RENEWSOLAR1_IPP	ITTAGI_220	19:23	19:56	0:33	LINE CLEAR AVAILED
142	2-Oct-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	8:37	8:56	0:19	LINE FAULT
143	2-Oct-19	GULBARGA	110	KEMBHAVI-UGARSUGARS_IPP	UGARSUGARS_IPP	16:09	17:30	1:21	LINE FAULT
144	2-Oct-19	GULBARGA	110	KEMBHAVI-ASKI_110	ASKI_110	16:10	17:30	1:20	LINE FAULT
145	2-Oct-19	GULBARGA	110	KEMBHAVI-SHAHPUR220	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110	21:55	22:05	0:10	LINE FAULT
146	2-Oct-19	MYSORE	66	BOOKANAKERE-CHINAKURALLI	BANANGADI_66, CHINAKURALI_66	7:40	7:47	0:07	LINE FAULT
147	2-Oct-19	MYSORE	66	CR NAGARA-KABBALLI	HARVEY_66	16:21	16:27	0:06	LINE FAULT
148	2-Oct-19	MYSORE	66	HV2	HAMPAPURA_66	23:41	23:52	0:10	TRANSFORMER FAULT
149	2-Oct-19	MYSORE	66	HV2	HAMPAPURA_66	23:55	23:59	0:04	TRANSFORMER FAULT
150	2-Oct-19	MYSORE	66	HANNUR-MADHUVANAHALLI 1	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66, KOTTANUR_66	8:09	8:31	0:21	LINE FAULT
151	2-Oct-19	MYSORE	66	HANNUR-MADHUVANAHALLI 1	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	23:40	23:46	0:05	LINE FAULT
152	2-Oct-19	MYSORE	66	HANNUR-KOTHANUR	KOTTANUR_66	23:40	23:44	0:04	LINE FAULT
153	2-Oct-19	MYSORE	66	HV1	KADAKOLA_220	12:43	16:24	3:41	LINE CLEAR AVAILED
154	2-Oct-19	MYSORE	66	HV3	KUSHALANAGARA_66	19:33	20:32	0:58	TRANSFORMER FAULT
155	2-Oct-19	MYSORE	66	MADHUVANAHALLI -HANNUR 2	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	8:09	8:17	0:08	LINE FAULT
156	2-Oct-19	MYSORE	66	MADHUVANAHALLI -HANNUR 2	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	8:17	8:36	0:18	LINE FAULT
157	2-Oct-19	MYSORE	66	HV1	SATHEGALA_66	12:28	13:01	0:32	LINE CLEAR AVAILED
158	2-Oct-19	MYSORE	66	HV1	TARIPURA_66	15:24	15:45	0:21	LINE CLEAR AVAILED
159	2-Oct-19	TUMKUR	220	TR-3(HV SIDE)	CHITRADURGA_220	13:36	14:35	0:58	LINE FAULT
160	2-Oct-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	2:47	10:57	8:10	LINE FAULT
161	2-Oct-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	11:00	11:03	0:03	HAND TRIPPED
162	2-Oct-19	TUMKUR	110	TR-1	KBCROSS_220	13:31	14:45	1:14	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
163	2-Oct-19	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	ANCHEPALYA_220	5:29	5:49	0:20	LINE FAULT
164	2-Oct-19	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	11:07	11:36	0:28	LINE FAULT
165	2-Oct-19	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	4:00	6:19	2:19	LINE CLEAR AVAILED
166	3-Oct-19	BAGALKOT	220	NAGJHARI 2-AMBEWADI	AMBEWADI_220	10:11	13:42	3:31	LINE CLEAR AVAILED
167	3-Oct-19	BAGALKOT	220	NAGJHARI 2-AMBEWADI	AMBEWADI_220	14:50	16:18	1:28	LINE FAULT
168	3-Oct-19	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	14:08	16:18	2:10	LINE FAULT
169	3-Oct-19	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	11:16	11:22	0:06	TRANSFORMER FAULT
170	3-Oct-19	BAGALKOT	110	110/11KV,HV3	BELUR_110	12:46	17:20	4:34	TRANSFORMER FAULT
171	3-Oct-19	BAGALKOT	220	BIDNAL-HUBLI 1	BIDNAL_220	9:06	18:24	9:18	NFBC ISSUED
172	3-Oct-19	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	13:32	18:20	4:48	LINE FAULT
173	3-Oct-19	BAGALKOT	220	BELGAUM-KANABARGI1(NARENDRA 1)	BELGAUM_220	16:13	16:33	0:20	MAIN SUPPLY FAILURE
174	3-Oct-19	BAGALKOT	220	BELGAUM-KANABARGI2(NARENDRA 2)	BELGAUM_220	16:13	21:04	4:51	LINE FAULT
175	3-Oct-19	BAGALKOT	110	BELGAUM220-ANKALAGI(HUDLI)	HUDLI_110	8:35	9:20	0:45	HAND TRIPPED
176	3-Oct-19	BAGALKOT	110	BELGAUM220-HUKKERI	HUKKERI_110	16:13	16:20	0:07	LINE FAULT
177	3-Oct-19	BAGALKOT	110	BELGAUM220-ANKALAGI(HUDLI)	HUDLI_110	16:13	16:17	0:04	LINE FAULT
178	3-Oct-19	BAGALKOT	110	BELGAUM220-BELGAUM(NEHRU NAGAR)	NEHRU NAGAR_110	16:13	16:27	0:14	LINE FAULT
179	3-Oct-19	BAGALKOT	220	220/110KV,HV 2&LV 2	CHIKKODI_220	15:38	16:00	0:22	TRANSFORMER FAULT
180	3-Oct-19	BAGALKOT	220	CHIKKODI-GHATAPRABHA 1	CHIKKODI_220	15:38	15:59	0:21	LINE FAULT
181	3-Oct-19	BAGALKOT	220	CHIKKODI-GHATAPRABHA2(KUDACHI)	CHIKKODI_220	15:38	16:21	0:43	LINE FAULT
182	3-Oct-19	BAGALKOT	220	220/110KV,HV 1&LV 1	GADAG_220	16:23	17:45	1:22	TRANSFORMER FAULT
183	3-Oct-19	BAGALKOT	110	GADAG-SAMBAPUR	SAMBAPUR_110	16:23	19:25	3:02	LINE FAULT
184	3-Oct-19	BAGALKOT	110	110/11KV,HV3	GAJENDRAGAD_110	10:02	17:43	7:41	LINE CLEAR AVAILED
185	3-Oct-19	BAGALKOT	110	GAJENDRAGAD -RON 1&2	GAJENDRAGAD_110	17:12	17:54	0:42	MAIN SUPPLY FAILURE
186	3-Oct-19	BAGALKOT	110	110/11KV,HV4	GHATAPRABHA_111	17:15	17:40	0:25	TRANSFORMER FAULT
187	3-Oct-19	BAGALKOT	110	VAJRAMATTI220-MANTUR1&2	VAJRAMATTI_220	10:59	16:42	5:43	LINE CLEAR AVAILED
188	3-Oct-19	BAGALKOT	110	ZALKI-CHADCHAN(INCHAGERI)	INCHAGERI_110	16:11	17:25	1:14	LINE CLEAR AVAILED
189	3-Oct-19	BAGALKOT	110	JAMKHANDI SUGARS-TODALBAGI	TODALBAGI_110	0:38	0:45	0:07	LINE FAULT
190	3-Oct-19	BAGALKOT	110	SIRSI-KUMTA1	SIRSI_110	12:41	18:56	6:15	LINE FAULT
191	3-Oct-19	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	12:51	14:13	1:22	LINE CLEAR AVAILED
192	3-Oct-19	BAGALKOT	110	110/11KV, HV1	SAIDAPUR_110	20:53	23:59	3:06	TRANSFORMER FAULT
193	3-Oct-19	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	16:02	16:11	0:09	TRANSFORMER FAULT
194	3-Oct-19	BAGALKOT	110	110/33KV, HV3	NIPPANI_110, BENADI_33	16:02	16:19	0:17	TRANSFORMER FAULT
195	3-Oct-19	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	14:12	15:41	1:29	LINE FAULT
196	3-Oct-19	BAGALKOT	220	HUBLI-NAGJHARI2	HUBLI_220	12:07	12:49	0:42	LINE FAULT
197	3-Oct-19	BAGALKOT	220	HUBLI-NAGJHARI2	HUBLI_220	13:47	14:18	0:31	LINE FAULT
198	3-Oct-19	BAGALKOT	220	HUBLI-BIDNAL	HUBLI_220	10:07	18:24	8:17	LINE CLEAR AVAILED
199	3-Oct-19	BAGALKOT	220	SHIROLAKOPPA-RANEENNUR	RANEENNUR_220	17:15	23:59	6:44	LINE CLEAR AVAILED
200	3-Oct-19	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	9:34	10:35	1:01	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
201	3-Oct-19	BAGALKOT	110	NARENDRA-BELUR1&2	BELUR_110	12:45	12:51	0:06	LINE FAULT
202	3-Oct-19	BAGALKOT	110	VIJAYNAGAR SUGARS-MUNDARGI	MUNDARGI_110	16:24	18:11	1:47	LINE FAULT
203	3-Oct-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	0:00	9:34	9:34	LINE CLEAR AVAILED
204	3-Oct-19	BAGALKOT	110	110/33KV, HV1	KUMTA_110, ANKOLA_33, HONNAVAR_33	12:38	12:49	0:11	HAND TRIPPED
205	3-Oct-19	BAGALKOT	110	GAMESHA-KULIGOD	KULIGOD_110	17:55	18:52	0:57	LINE FAULT
206	3-Oct-19	BAGALKOT	110	110/11KV, HV1	KUD DHARWAD_110	16:40	16:56	0:16	LINE CLEAR AVAILED
207	3-Oct-19	BAGALKOT	110	BAGALKOT220-KERUR	KERUR_110	16:03	16:24	0:21	LINE FAULT
208	3-Oct-19	BAGALKOT	110	KERUR-BADAMI	BADAMI_110	16:03	23:59	7:56	LINE FAULT
209	3-Oct-19	BAGALKOT	110	BELAGUM220-KANABARGI LAGOUT	KANABARGI LAGOUT_110	15:47	16:19	0:32	MAIN SUPPLY FAILURE
210	3-Oct-19	BAGALKOT	110	MYFAIR SOLAR-HIREHAL	HIREHAL_110	0:00	7:01	7:01	LINE CLEAR AVAILED
211	3-Oct-19	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	14:46	14:58	0:12	HAND TRIPPED
212	3-Oct-19	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	6:05	6:13	0:08	LINE FAULT
213	3-Oct-19	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	9:33	13:12	3:39	LINE CLEAR AVAILED
214	3-Oct-19	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	15:22	17:01	1:39	LINE FAULT
215	3-Oct-19	BAGALKOT	110	110/11KV, HV1	HANGAL_110	11:19	13:15	1:56	LINE CLEAR AVAILED
216	3-Oct-19	BENGALURU	66	BIDADI-RAMANAGARA	KEMPANAHALLI,MELEHALLI,JALAMANGA LA,CHIKKAGANGANAWADI,KUTAGALLU, RAMANAGARA,BEVOOR	1:55	3:29	1:34	LINE FAULT
217	3-Oct-19	BENGALURU	66	BIDADI-RAMANAGARA	KEMPANAHALLI,MELEHALLI,JALAMANGA LA,CHIKKAGANGANAWADI,KUTAGALLU, RAMANAGARA,BEVOOR	4:49	7:47	2:58	LINE CLEAR AVAILED
218	3-Oct-19	BENGALURU	66	BIDADI-RAMANAGARA	KEMPANAHALLI,MELEHALLI,JALAMANGA LA,CHIKKAGANGANAWADI,KUTAGALLU, RAMANAGARA,BEVOOR	9:32	9:36	0:04	LINE FAULT
219	3-Oct-19	BENGALURU	66	BIDADI-RAMANAGARA	KEMPANAHALLI,MELEHALLI,JALAMANGA LA,CHIKKAGANGANAWADI,KUTAGALLU, RAMANAGARA,BEVOOR	11:24	13:44	2:20	LINE CLEAR AVAILED
220	3-Oct-19	BENGALURU	66	BRINDAVANA-SRS	BRINDAVANA	4:56	5:23	0:27	LOAD CHANGE OVER
221	3-Oct-19	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	3:16	3:51	0:35	MAIN SUPPLY FAILURE
222	3-Oct-19	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	23:20	23:25	0:05	LOAD CHANGE OVER
223	3-Oct-19	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	3:15	3:20	0:05	MAIN SUPPLY FAILURE
224	3-Oct-19	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	4:05	4:10	0:05	LOAD CHANGE OVER
225	3-Oct-19	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	4:51	5:00	0:09	MAIN SUPPLY FAILURE
226	3-Oct-19	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	5:16	5:21	0:05	LOAD CHANGE OVER
227	3-Oct-19	BENGALURU	66	MELLAHALLI-KEMPANAHALLI	MELLAHALLI	1:25	1:40	0:15	LINE FAULT
228	3-Oct-19	BENGALURU	66	MELLAHALLI-KEMPANAHALLI	MELLAHALLI	1:57	13:46	11:49	LINE CLEAR AVAILED
229	3-Oct-19	BENGALURU	66	NANDINI LAYOUT-SRS 220	NANDINI LAYOUT	3:16	3:51	0:35	MAIN SUPPLY FAILURE
230	3-Oct-19	BENGALURU	66	NANDINI LAYOUT-SRS 220	NANDINI LAYOUT	6:45	7:00	0:15	LOAD CHANGE OVER
231	3-Oct-19	BENGALURU	66	NANDINI LAYOUT-NRS 220	NANDINI LAYOUT	10:32	10:39	0:07	LOAD CHANGE OVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
232	3-Oct-19	BENGALURU	66	NANDINI LAYOUT-SRS 220	NANDINI LAYOUT	23:10	23:15	0:05	LOAD CHANGE OVER
233	3-Oct-19	BENGALURU	66	NELAKADARANAHALI-SRS 220	NELAKADARANAHALI	3:15	5:25	2:10	MAIN SUPPLY FAILURE
234	3-Oct-19	BENGALURU	66	HV2	NELAKADARANAHALI	5:25	5:45	0:20	TRANSFORMER FAULT
235	3-Oct-19	BENGALURU	66	HV2	NELAKADARANAHALI	12:50	12:55	0:05	LOAD CHANGE OVER
236	3-Oct-19	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	3:15	4:00	0:45	MAIN SUPPLY FAILURE
237	3-Oct-19	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	4:50	5:05	0:15	MAIN SUPPLY FAILURE
238	3-Oct-19	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	6:45	6:50	0:05	LOAD CHANGE OVER
239	3-Oct-19	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	3:16	3:37	0:21	MAIN SUPPLY FAILURE
240	3-Oct-19	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	3:54	3:58	0:04	LOAD CHANGE OVER
241	3-Oct-19	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	23:11	23:14	0:03	MAIN SUPPLY FAILURE
242	3-Oct-19	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	3:13	3:51	0:38	LOAD CHANGE OVER
243	3-Oct-19	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	4:45	4:51	0:06	LOAD CHANGE OVER
244	3-Oct-19	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	3:20	4:01	0:41	LINE FAULT
245	3-Oct-19	BENGALURU	66	HV2	CHAKKAVELU	18:00	18:51	0:51	TRANSFORMER FAULT
246	3-Oct-19	BENGALURU	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	10:05	10:10	0:05	LINE FAULT
247	3-Oct-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	15:45	16:09	0:24	LINE FAULT
248	3-Oct-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	16:09	18:48	2:39	LINE FAULT
249	3-Oct-19	BENGALURU	66	DB PURA 220-VIJAYAPURA	VIJAYAPURA,JANGAMAKOTE	23:11	23:23	0:12	LINE FAULT
250	3-Oct-19	BENGALURU	220	KOLAR 220 - PGCIL 1 & 2	KOLAR 220	14:08	14:24	0:16	MAIN SUPPLY FAILURE
251	3-Oct-19	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	14:08	14:27	0:19	MAIN SUPPLY FAILURE
252	3-Oct-19	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	13:16	17:43	4:27	LINE CLEAR AVAILED
253	3-Oct-19	BENGALURU	66	KOLAR 220 - NANGLI	MUDIYANUR, H GOLLAHALI, BAIRAKUR, NANGLI, KEMBODI	14:08	14:27	0:19	MAIN SUPPLY FAILURE
254	3-Oct-19	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	DRDO (EHT), MALLASANDRA, DALASANUR, YELDUR	13:25	13:30	0:05	LINE FAULT
255	3-Oct-19	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	DRDO (EHT), MALLASANDRA, DALASANUR, YELDUR	16:10	16:15	0:05	LINE FAULT
256	3-Oct-19	BENGALURU	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	14:08	14:28	0:20	MAIN SUPPLY FAILURE
257	3-Oct-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	14:08	14:27	0:19	MAIN SUPPLY FAILURE
258	3-Oct-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	14:08	14:27	0:19	MAIN SUPPLY FAILURE
259	3-Oct-19	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	14:08	14:27	0:19	MAIN SUPPLY FAILURE
260	3-Oct-19	GULBARGA	220	LINGASUGUR-SHAHPUR	SHAHPUR_220	5:40	6:10	0:30	LINE FAULT
261	3-Oct-19	GULBARGA	220	LINGASUGUR-SHAHPUR	SHAHPUR_220	14:32	15:50	1:18	LINE CLEAR AVAILED
262	3-Oct-19	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	9:34	10:23	0:49	LINE CLEAR AVAILED
263	3-Oct-19	GULBARGA	220	LINGASUGUR-SHAHPUR	SHAHPUR_220	20:04	23:59	3:55	LINE FAULT
264	3-Oct-19	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110	4:20	23:59	19:39	LINE CLEAR AVAILED



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
265	3-Oct-19	GULBARGA	110	HV2	SHORAPUR_110	18:07	18:22	0:15	TRANSFORMER FAULT
266	3-Oct-19	GULBARGA	110	HV2	SHORAPUR_110	21:46	21:52	0:06	TRANSFORMER FAULT
267	3-Oct-19	GULBARGA	110	DHADESUGUR-VEPSLR	DHADESUGUR_110	19:06	19:57	0:51	LINE CLEAR AVAILED
268	3-Oct-19	GULBARGA	110	SINHANOOR220-MUNIRABAD2	BTPS_WATER,MUKUNDA_110,KAMPLI_110	9:30	9:45	0:15	LINE FAULT
269	3-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	9:19	9:19	LINE CLEAR AVAILED
270	3-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:26	23:59	1:33	LINE CLEAR AVAILED
271	3-Oct-19	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	19:05	19:55	0:50	LINE CLEAR AVAILED
272	3-Oct-19	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	16:47	17:04	0:17	LINE FAULT
273	3-Oct-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	13:32	16:19	2:47	LINE FAULT
274	3-Oct-19	HASSAN	220	SHRAVTY-SHIMOGA2	sharavathy_gen	11:17	11:34	0:17	LINE FAULT
275	3-Oct-19	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	8:01	10:50	2:49	LINE FAULT
276	3-Oct-19	HASSAN	110	HV1	ANAVATTI_110	10:56	14:28	3:32	LINE CLEAR AVAILED
277	3-Oct-19	HASSAN	110	HV2	ANAVATTI_110	10:56	14:28	3:32	LINE CLEAR AVAILED
278	3-Oct-19	HASSAN	110	HV3	GURUVAYANAKERE_110	5:49	7:52	2:03	TRANSFORMER FAULT
279	3-Oct-19	HASSAN	110	HV1	HOSUR_110	12:10	19:40	7:30	LINE CLEAR AVAILED
280	3-Oct-19	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	17:14	17:25	0:11	LINE FAULT
281	3-Oct-19	HASSAN	66	HV1	CHIKMAGALUR_66	11:01	16:35	5:34	LINE CLEAR AVAILED
282	3-Oct-19	HASSAN	66	HV2	CHIKMAGALUR_66	10:40	16:37	5:57	LINE CLEAR AVAILED
283	3-Oct-19	HASSAN	66	HV1	HIRISAVE_66	11:03	12:42	1:39	LINE CLEAR AVAILED
284	3-Oct-19	HASSAN	66	MOSALEH-BIOMASS	MOSALEHOSAHALLI_66	11:52	12:13	0:21	LINE CLEAR AVAILED
285	3-Oct-19	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	11:52	12:13	0:21	LINE CLEAR AVAILED
286	3-Oct-19	HASSAN	66	HV1	MOSALEHOSAHALLI_66	11:51	12:18	0:27	LINE CLEAR AVAILED
287	3-Oct-19	HASSAN	66	HV2	RAMPURA_66	11:46	11:53	0:07	LINE CLEAR AVAILED
288	3-Oct-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	11:16	11:53	0:37	LINE CLEAR AVAILED
289	3-Oct-19	MYSORE	66	HV1	DKMAIDANA_66	12:09	13:36	1:27	LINE CLEAR AVAILED
290	3-Oct-19	MYSORE	66	HV2	HAMPAPURA_66	0:00	1:08	1:08	TRANSFORMER FAULT
291	3-Oct-19	MYSORE	66	JAKKANAHALLY-NAGAMANGALA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, NAGAMANGALA_66	0:16	0:45	0:28	LINE FAULT
292	3-Oct-19	MYSORE	66	KUSHALANAGARA 220-BYLUKUPPE	BYLUKUPPE_66	7:41	7:48	0:06	LINE FAULT
293	3-Oct-19	MYSORE	66	HV4	KUSHALNAGARA_220	13:40	15:25	1:45	LINE CLEAR AVAILED
294	3-Oct-19	MYSORE	66	PERIYAPATANA-KUSHALANAGARA 1	PERIYAPATNA_66, PONNAMPET_66, VIRAJPET_66	7:40	7:50	0:10	LINE FAULT
295	3-Oct-19	MYSORE	66	HV1	SANTHESARAGUR_66	10:10	10:21	0:11	TRANSFORMER FAULT
296	3-Oct-19	MYSORE	66	VAJAMANGALA-MEGHALAPURA	CHIDRAVALLI_66, MEGALAPURA_66, THUMBLA_66	3:40	3:52	0:11	LINE FAULT
297	3-Oct-19	TUMKUR	220	ANTHRASANAHALLI 220KV-VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	11:57	16:42	4:44	LINE CLEAR AVAILED
298	3-Oct-19	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	11:58	14:13	2:15	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
299	3-Oct-19	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	11:58	12:31	0:33	LINE FAULT
300	3-Oct-19	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	11:58	14:15	2:16	LINE FAULT
301	3-Oct-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	11:18	16:03	4:44	LINE CLEAR AVAILED
302	3-Oct-19	TUMKUR	220	TR-1(HV SIDE)	KBCROSS_220	12:11	18:44	6:33	LINE CLEAR AVAILED
303	3-Oct-19	TUMKUR	110	TR-1(HV SIDE)	KBCROSS_220	12:10	18:45	6:34	LINE CLEAR AVAILED
304	3-Oct-19	TUMKUR	66	DASUDI-M/S CLEAN SOLAR	M/S CLEAN SOLAR_IPP_66	9:55	10:14	0:19	MAIN SUPPLY FAILURE
305	3-Oct-19	TUMKUR	66	DODDASARANGI-ANCHEPALYA	DODDASARANGI_66	9:22	17:44	8:21	LINE CLEAR AVAILED
306	3-Oct-19	TUMKUR	66	TR-2(HV SIDE )	CHITRADURGA_220	11:58	12:34	0:36	MAIN SUPPLY FAILURE
307	3-Oct-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	16:39	16:49	0:09	LINE FAULT
308	3-Oct-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	15:51	16:13	0:22	LINE FAULT
309	3-Oct-19	TUMKUR	66	TR-1& TR-2	HIREGUNTANUR_66	12:22	17:18	4:55	LINE CLEAR AVAILED
310	3-Oct-19	TUMKUR	66	HIREGUNTANUR- SIRIGERE	SIRIGERE_66,BRAHMASAGARA_IPP_66	12:22	17:17	4:54	LINE CLEAR AVAILED
311	3-Oct-19	TUMKUR	66	TR-2	HONNALLI_220	15:24	18:53	3:28	LINE CLEAR AVAILED
312	3-Oct-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	13:23	13:34	0:10	LINE FAULT
313	3-Oct-19	TUMKUR	66	TR-2	HONNALLI_220	9:04	20:09	11:05	LINE CLEAR AVAILED
314	3-Oct-19	TUMKUR	66	I D HALLI- MEDIGESHI	IDHALLY_66	11:15	12:36	1:20	LINE CLEAR AVAILED
315	3-Oct-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	13:33	13:45	0:12	HAND TRIPPED
316	3-Oct-19	TUMKUR	66	MIDIGESHI-IDHALLI	IDHALLY_66,KODIGENAHALLI_6	11:12	12:36	1:23	LINE CLEAR AVAILED
317	3-Oct-19	TUMKUR	66	TR-1	NYAMATHI_66	10:34	20:21	9:47	LINE CLEAR AVAILED
318	3-Oct-19	TUMKUR	66	SAVALANGA 66kV-HNLI220_NYMT	SAVALANGA_66	10:33	18:17	7:43	LINE CLEAR AVAILED
319	3-Oct-19	TUMKUR	66	TR-1	SAVALANGA_66	10:31	20:18	9:46	LINE CLEAR AVAILED
320	3-Oct-19	TUMKUR	66	TR-2	THOVINAKERE_66	17:02	17:32	0:30	LINE CLEAR AVAILED
321	3-Oct-19	TUMKUR	66	TR-2	THOVINAKERE_66	18:38	18:47	0:09	TRANSFORMER FAULT
322	4-Oct-19	BAGALKOT	110	110/11KV,HV2	ANKALI_110	12:43	13:20	0:37	LINE CLEAR AVAILED
323	4-Oct-19	BAGALKOT	110	110/33V,HV 3	ANKALI_110&NANDIKURALI_33	13:47	14:28	0:41	LINE CLEAR AVAILED
324	4-Oct-19	BAGALKOT	220	BAGALKOT-GADAG 2	BAGALKOT_220	15:34	17:54	2:20	NFBC ISSUED
325	4-Oct-19	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	11:39	14:09	2:30	LINE CLEAR AVAILED
326	4-Oct-19	BAGALKOT	110	MK HUBLI 1-BAILHONGAL	BAILHONGAL_110	17:44	17:53	0:09	HAND TRIPPED
327	4-Oct-19	BAGALKOT	110	110/11KV,HV1	BILAGI_110	10:39	10:56	0:17	HAND TRIPPED
328	4-Oct-19	BAGALKOT	220	220/110KV,HV2&LV2	GADAG_220	14:44	18:12	3:28	LINE CLEAR AVAILED
329	4-Oct-19	BAGALKOT	110	GADAG-SAMBAPUR	SAMBAPUR_110	11:04	11:06	0:02	LINE CLEAR AVAILED
330	4-Oct-19	BAGALKOT	110	HIREHAL-MFR SOLAR	HIREHAL_110	16:52	17:04	0:12	HAND TRIPPED
331	4-Oct-19	BAGALKOT	110	ZALKI-CHADCHAN(INCAGERI)	INCHAGERI_110	13:51	15:22	1:31	LINE CLEAR AVAILED
332	4-Oct-19	BAGALKOT	110	VAJRAMATTI220-BILAGI	BILAGI_110, SHIRGUPPI_110	6:39	6:57	0:18	LINE FAULT
333	4-Oct-19	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	10:45	11:49	1:04	LINE CLEAR AVAILED
334	4-Oct-19	BAGALKOT	110	SINDAGI-ALMEL	ALMEL_110	0:14	0:28	0:14	LINE FAULT
335	4-Oct-19	BAGALKOT	110	SINDAGI-ALMEL	ALMEL_110	5:28	5:31	0:03	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
336	4-Oct-19	BAGALKOT	110	SINDAGI-ALMEL	ALMEL_110	21:40	21:47	0:07	LINE FAULT
337	4-Oct-19	BAGALKOT	110	110/11KV, HV1	SAIDAPUR_110	0:00	9:50	9:50	LINE CLEAR AVAILED
338	4-Oct-19	BAGALKOT	110	110/33KV, HV2	SADALAGA_110, BHOJ_33	14:11	15:00	0:49	LINE CLEAR AVAILED
339	4-Oct-19	BAGALKOT	110	110/11KV, HV1	PG HUNSHYAL_110	10:25	11:38	1:13	LINE CLEAR AVAILED
340	4-Oct-19	BAGALKOT	110	110/11KV, HV2	PG HUNSHYAL_110	11:38	12:38	1:00	LINE CLEAR AVAILED
341	4-Oct-19	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	16:09	18:03	1:54	TRANSFORMER FAULT
342	4-Oct-19	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	14:20	15:11	0:51	LINE FAULT
343	4-Oct-19	BAGALKOT	110	NAREGAL-RON	RON_110	14:45	16:20	1:35	LINE CLEAR AVAILED
344	4-Oct-19	BAGALKOT	110	BALAJI SUGARS- MUDDEBIHAL	MUDDEBIHAL_110	7:05	19:47	12:42	LINE CLEAR AVAILED
345	4-Oct-19	BAGALKOT	110	MK HUBLI220-BAILHONGAL	BAILHONGAL_110	17:42	17:55	0:13	LINE CLEAR AVAILED
346	4-Oct-19	BAGALKOT	110	GAMESHA-KULIGOD	KULIGOD_110	15:10	15:45	0:35	HAND TRIPPED
347	4-Oct-19	BAGALKOT	110	KADAL SANGAM-HUNGUND	HUNGUND_110	20:40	21:10	0:30	LINE FAULT
348	4-Oct-19	BAGALKOT	110	KARWAR220-SOLARIS(BINAGA)	BINAGA_LIS	23:15	23:59	0:44	LINE FAULT
349	4-Oct-19	BENGALURU	66	HV1	BAIRAKUR	18:09	18:15	0:05	LINE CLEAR AVAILED
350	4-Oct-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	7:19	7:23	0:03	LINE FAULT
351	4-Oct-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	11:19	11:23	0:04	LINE FAULT
352	4-Oct-19	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	16:40	16:44	0:03	LINE FAULT
353	4-Oct-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1 & 2	KUNDANA, DEVANAHALLI	17:54	18:00	0:05	LINE CLEAR AVAILED
354	4-Oct-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	19:57	20:14	0:17	LINE CLEAR AVAILED
355	4-Oct-19	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	16:10	16:27	0:17	LINE CLEAR AVAILED
356	4-Oct-19	BENGALURU	66	HV1	KOLAR 220	12:02	14:04	2:01	LINE CLEAR AVAILED
357	4-Oct-19	BENGALURU	66	HV2	KOLAR 220	13:05	13:20	0:15	LINE CLEAR AVAILED
358	4-Oct-19	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	17:38	17:55	0:16	LINE FAULT
359	4-Oct-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	17:38	18:00	0:22	MAIN SUPPLY FAILURE
360	4-Oct-19	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	17:38	17:59	0:21	MAIN SUPPLY FAILURE
361	4-Oct-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	17:38	17:58	0:20	MAIN SUPPLY FAILURE
362	4-Oct-19	BENGALURU	66	WELCAST - ABBIGERE	WELCAST	4:04	4:08	0:04	LOAD CHANGE OVER
363	4-Oct-19	BENGALURU	220	MALUR 220 - SARJAPURA 220	VIKAS TECH PARK 220	17:38	17:54	0:16	LINE FAULT
364	4-Oct-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	17:41	17:50	0:09	LINE FAULT
365	4-Oct-19	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	3:55	4:04	0:09	LOAD CHANGE OVER
366	4-Oct-19	BENGALURU	66	YELAHANKA 220 - LINE 6	SOLADEVANAHALLI	19:49	20:15	0:25	LINE FAULT
367	4-Oct-19	BENGALURU	66	YELAHANKA 220 - LINE 7	KANASWADI	19:43	21:06	1:23	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
368	4-Oct-19	BENGALURU	66	YELAHANKA 220 - LINE 8	RAJANAKUNTE	19:43	20:10	0:27	LINE FAULT
369	4-Oct-19	GULBARGA	220	LINGASUGUR-SHAHPUR	SHAHPUR_220	0:00	14:55	14:55	LINE FAULT
370	4-Oct-19	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110	0:00	16:03	16:03	LOAD CHANGE OVER
371	4-Oct-19	GULBARGA	110	KEMBHAVI-SHAHPUR220	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110	2:42	2:51	0:09	LINE FAULT
372	4-Oct-19	GULBARGA	220	RRTPS-LINGASUGUR2	LINGASUGUR+_220	2:17	9:10	6:53	LINE FAULT
373	4-Oct-19	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	5:15	5:21	0:06	LINE FAULT
374	4-Oct-19	GULBARGA	110	GURUMITKAL-KONKAL	KONKAL_110	15:55	16:05	0:10	LINE CLEAR AVAILED
375	4-Oct-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	20:55	21:05	0:10	LINE FAULT
376	4-Oct-19	GULBARGA	110	HV1	HUMNABAD_220	15:50	15:55	0:05	TRANSFORMER FAULT
377	4-Oct-19	GULBARGA	110	HV4	SEDAM_220	0:45	1:56	1:11	LINE CLEAR AVAILED
378	4-Oct-19	GULBARGA	110	SEDAM-KURUKUNTA	KURKUNTA_110	18:15	21:45	3:30	LINE FAULT
379	4-Oct-19	GULBARGA	110	SEDAM-VICATASAGAR	VICATASAGAR CEMENTS_IPP	19:30	20:15	0:45	LINE FAULT
380	4-Oct-19	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	15:40	15:55	0:15	LINE FAULT
381	4-Oct-19	GULBARGA	110	HV2	SHAHPUR_220	18:40	18:45	0:05	TRANSFORMER FAULT
382	4-Oct-19	GULBARGA	110	STARMETALLIC-MUNIRABAD	MUNIRABAD_220	16:50	16:55	0:05	LINE FAULT
383	4-Oct-19	GULBARGA	110	MALLAT-MADALAPUR	MADALAPUR_110	12:05	14:25	2:20	NFBC ISSUED
384	4-Oct-19	GULBARGA	66	LV1	ITTAGI_220	17:35	17:43	0:08	TRANSFORMER FAULT
385	4-Oct-19	GULBARGA	66	HV2	CHORNOOR_66	20:13	20:19	0:06	TRANSFORMER FAULT
386	4-Oct-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:48	16:13	3:25	LINE FAULT
387	4-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	7:29	7:29	LINE CLEAR AVAILED
388	4-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:58	23:59	2:01	LINE CLEAR AVAILED
389	4-Oct-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	14:12	14:19	0:07	HAND TRIPPED
390	4-Oct-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	14:12	14:18	0:06	HAND TRIPPED
391	4-Oct-19	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	17:26	18:21	0:55	LINE FAULT
392	4-Oct-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	14:14	14:41	0:27	LINE FAULT
393	4-Oct-19	HASSAN	110	HV1	HIRENALLUR_66	10:37	15:30	4:53	LINE CLEAR AVAILED
394	4-Oct-19	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_66	10:38	15:30	4:52	LINE CLEAR AVAILED
395	4-Oct-19	HASSAN	110	HV2	HOSNGADI_66	14:14	16:28	2:14	TRANSFORMER FAULT
396	4-Oct-19	HASSAN	110	KADUR-NGNHL	KADUR_220	12:55	14:43	1:48	LINE FAULT
397	4-Oct-19	HASSAN	110	HV2	NERALAKERE_110	14:31	14:59	0:28	LINE CLEAR AVAILED
398	4-Oct-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:11	14:40	4:29	LINE CLEAR AVAILED
399	4-Oct-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:18	14:06	3:48	LINE CLEAR AVAILED
400	4-Oct-19	HASSAN	66	HV1	ALDUR_66	10:18	17:11	6:53	LINE CLEAR AVAILED
401	4-Oct-19	HASSAN	66	BANDISH-ADANI	BANDISH	14:31	14:39	0:08	LINE FAULT
402	4-Oct-19	HASSAN	66	L1-ALDUR	CHIKMAGALUR_66	10:16	14:05	3:49	LINE CLEAR AVAILED
403	4-Oct-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	17:28	17:50	0:22	LINE FAULT
404	4-Oct-19	MYSORE	66	HV2	CHANDAKAVADI_66	16:45	17:05	0:19	HAND TRIPPED
405	4-Oct-19	MYSORE	66	HV1	HAMPAPURA(K)_66	12:41	13:18	0:36	LINE CLEAR AVAILED
406	4-Oct-19	MYSORE	66	HV2	HAMPAPURA(K)_66	12:40	14:00	1:20	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
407	4-Oct-19	MYSORE	66	JAKKANAHALLY-NAGAMANGALA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, NAGAMANGALA_66	17:24	17:31	0:06	LINE FAULT
408	4-Oct-19	MYSORE	66	HV1	K_HONNALGERE_66	6:52	7:10	0:18	HAND TRIPPED
409	4-Oct-19	MYSORE	66	HV2	K_HONNALGERE_66	6:52	7:10	0:18	HAND TRIPPED
410	4-Oct-19	MYSORE	66	KESLAGERE-TUBINAKERE	BASARALU_66 KESLAGERE_66	15:25	18:15	2:50	LINE FAULT
411	4-Oct-19	MYSORE	66	HV1	KIADBMANDYA_66	6:55	7:10	0:15	HAND TRIPPED
412	4-Oct-19	MYSORE	66	HV2	KIADBMANDYA_66	6:55	7:10	0:15	HAND TRIPPED
413	4-Oct-19	MYSORE	66	HV1	KIADBMANDYA_66	9:26	9:36	0:10	HAND TRIPPED
414	4-Oct-19	MYSORE	66	HV2	KIADBMANDYA_66	9:26	9:36	0:10	HAND TRIPPED
415	4-Oct-19	MYSORE	66	HV2	KIRUGAVALU_66	11:52	12:17	0:25	LINE CLEAR AVAILED
416	4-Oct-19	MYSORE	66	KOLLEGALA-PARINAMIPURA	BGPURA_66,CHANDALLI_66, PARINAMIPURA_66, THALAKADU_66	7:10	7:22	0:12	LINE FAULT
417	4-Oct-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 KESLAGERE_66	15:09	15:15	0:06	LINE FAULT
418	4-Oct-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	0:10	8:17	8:07	LINE FAULT
419	4-Oct-19	TUMKUR	220	TR-1(HV SIDE)	KBCROSS_220	8:57	18:29	9:31	LINE CLEAR AVAILED
420	4-Oct-19	TUMKUR	110	TR-3(HV SIDE)	GUBBI_110	11:56	13:52	1:55	LINE CLEAR AVAILED
421	4-Oct-19	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	8:57	18:29	9:31	LINE CLEAR AVAILED
422	4-Oct-19	TUMKUR	66	ANCHEPALYA 66KV-ANCHEPALYA 1	ANCHEPALYA_66	10:05	10:25	0:20	HAND TRIPPED
423	4-Oct-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	8:34	10:40	2:05	LINE FAULT
424	4-Oct-19	TUMKUR	66	TR-2	CHIKKABANAGERE_66	11:55	13:08	1:13	LINE CLEAR AVAILED
425	4-Oct-19	TUMKUR	66	TR-2	DAVANAGERE_66	15:44	16:02	0:17	TRANSFORMER FAULT
426	4-Oct-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	15:51	16:14	0:22	LINE FAULT
427	4-Oct-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	16:59	17:54	0:54	LINE FAULT
428	4-Oct-19	TUMKUR	66	HARIHARA-DAVANGERE_HARIHAR	HARIHAR_66	15:07	17:48	2:40	LINE CLEAR AVAILED
429	4-Oct-19	TUMKUR	66	TR-1	HARIHAR_66	15:07	17:48	2:41	LINE CLEAR AVAILED
430	4-Oct-19	TUMKUR	66	TR-2	HARIHAR_66	15:07	17:46	2:39	LINE CLEAR AVAILED
431	4-Oct-19	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	5:22	18:29	13:06	LINE CLEAR AVAILED
432	4-Oct-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	0:13	0:36	0:23	HAND TRIPPED
433	4-Oct-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	10:19	10:27	0:08	HAND TRIPPED
434	4-Oct-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	11:20	11:25	0:04	HAND TRIPPED
435	4-Oct-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	0:12	0:36	0:24	HAND TRIPPED
436	4-Oct-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP1_IPP_66	0:12	0:36	0:24	HAND TRIPPED
437	4-Oct-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	0:11	8:29	8:17	LINE CLEAR AVAILED
438	4-Oct-19	TUMKUR	66	TR-2	HONNALLI_220	12:27	13:36	1:08	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
439	4-Oct-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	6:36	6:48	0:12	LINE FAULT
440	4-Oct-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	6:51	7:07	0:15	LINE FAULT
441	4-Oct-19	TUMKUR	66	HOSAKERE- MIDIGESHI	MEDIGESHI_66, PAVAGADA_66, VENKATAPURA_66	10:37	10:43	0:06	LINE FAULT
442	4-Oct-19	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR_IPP_66	TATA SOLAR_IPP_66	10:32	10:38	0:06	MAIN SUPPLY FAILURE
443	4-Oct-19	TUMKUR	66	TR-1	KATTIGE_66	16:17	16:27	0:09	HAND TRIPPED
444	4-Oct-19	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	15:38	15:51	0:12	LINE FAULT
445	4-Oct-19	TUMKUR	66	TR-2	NITRAHALLI_66	0:29	0:40	0:11	TRANSFORMER FAULT
446	4-Oct-19	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	1:07	1:19	0:12	HAND TRIPPED
447	4-Oct-19	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	5:56	6:21	0:25	HAND TRIPPED
448	4-Oct-19	TUMKUR	66	PAVAGADA-MADHUGIRI(PAVAGADA 220)	PAVAGADA_66	0:42	6:31	5:48	LINE CLEAR AVAILED
449	4-Oct-19	TUMKUR	66	TR-2 & TR-1	PAVAGADA_66	1:18	1:26	0:07	HAND TRIPPED
450	4-Oct-19	TUMKUR	66	TR-2 & TR-1	PAVAGADA_66	6:23	6:32	0:09	HAND TRIPPED
451	4-Oct-19	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	1:15	1:27	0:12	HAND TRIPPED
452	4-Oct-19	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	6:17	6:41	0:23	HAND TRIPPED
453	4-Oct-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	11:48	14:52	3:03	MAIN SUPPLY FAILURE
454	4-Oct-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	11:13	11:27	0:13	HAND TRIPPED
455	4-Oct-19	TUMKUR	66	TR-1	TUMKUR_66	17:48	17:58	0:10	TRANSFORMER FAULT
456	5-Oct-19	BAGALKOT	110	ANKOLA-KUMTA	KUMTA_110	23:05	23:22	0:17	LINE FAULT
457	5-Oct-19	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	17:25	17:40	0:15	LINE CLEAR AVAILED
458	5-Oct-19	BAGALKOT	110	INDI220-ATHARGA	ATHARGA_110	17:57	18:09	0:12	LINE CLEAR AVAILED
459	5-Oct-19	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	HIDIKAL DAM_110	11:25	13:50	2:25	LINE CLEAR AVAILED
460	5-Oct-19	BAGALKOT	110	110/33KV,HV3	BELUR_110,TATA1&2_33,SOUTHERMFERRO_33,UAS_33,UDL_33	16:47	17:14	0:27	LINE CLEAR AVAILED
461	5-Oct-19	BAGALKOT	220	BIDNAL-HUBLI1	BIDNAL_220	9:10	13:08	3:58	NFBC ISSUED
462	5-Oct-19	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	17:52	23:59	6:07	LINE FAULT
463	5-Oct-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	23:46	23:59	0:13	HAND TRIPPED
464	5-Oct-19	BAGALKOT	110	GAJENDRAGAD-RON2	RON_110	4:37	14:35	9:58	LINE FAULT
465	5-Oct-19	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD_110	14:00	23:59	9:59	LINE CLEAR AVAILED
466	5-Oct-19	BAGALKOT	220	GHATAPRABHA-NARENDRA1	GHATAPRABHA_220	23:05	23:59	0:54	LINE FAULT
467	5-Oct-19	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	19:31	23:59	4:28	LINE FAULT
468	5-Oct-19	BAGALKOT	110	110/11KV,HV5	INDI_110	15:56	18:08	2:12	LINE CLEAR AVAILED
469	5-Oct-19	BAGALKOT	110	110/11KV,HV2	ITNAL_110	9:03	10:56	1:53	LINE CLEAR AVAILED
470	5-Oct-19	BAGALKOT	110	SHIROL-JAMAKHANDI	JAMAKHANDI_110	16:20	16:45	0:25	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
471	5-Oct-19	BAGALKOT	110	110/33KV, HV3	TARIHAL_110, DUMMWAD_33, IE_33	18:45	20:30	1:45	TRANSFORMER FAULT
472	5-Oct-19	BAGALKOT	110	SODATTI220-UDIKERI	UDIKERI_110	18:44	18:55	0:11	LINE CLEAR AVAILED
473	5-Oct-19	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	12:19	17:45	5:26	LINE CLEAR AVAILED
474	5-Oct-19	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	10:23	15:16	4:53	LINE CLEAR AVAILED
475	5-Oct-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	13:20	18:42	5:22	LINE FAULT
476	5-Oct-19	BAGALKOT	110	RANEENNUR220-HIREKERUR	HIREKERUR_110	11:40	13:27	1:47	LINE CLEAR AVAILED
477	5-Oct-19	BAGALKOT	110	NAREGAL-RON	RON_110	13:51	14:30	0:39	LINE CLEAR AVAILED
478	5-Oct-19	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	21:40	23:59	2:19	LINE CLEAR AVAILED
479	5-Oct-19	BAGALKOT	110	KARWAR220-SOLARIS(BINAGA)	BINAGA_LIS	0:00	13:10	13:10	LINE CLEAR AVAILED
480	5-Oct-19	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	11:13	13:10	1:57	LINE CLEAR AVAILED
481	5-Oct-19	BAGALKOT	110	110/11KV, HV2	KAGAWAD_110	9:39	9:50	0:11	TRANSFORMER FAULT
482	5-Oct-19	BENGALURU	66	KANASWADI - DB PURA 220	KANASWADI	6:20	6:25	0:05	LOAD CHANGE OVER
483	5-Oct-19	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	14:37	14:41	0:03	LINE FAULT
484	5-Oct-19	BENGALURU	220	HV2	DABUSPET 220	12:08	12:29	0:21	TRANSFORMER FAULT
485	5-Oct-19	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	12:08	12:48	0:40	LINE FAULT
486	5-Oct-19	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	12:08	12:49	0:40	MAIN SUPPLY FAILURE
487	5-Oct-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	12:16	13:48	1:31	LINE FAULT
488	5-Oct-19	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	13:11	13:45	0:33	LINE CLEAR AVAILED
489	5-Oct-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	14:45	14:57	0:11	LINE FAULT
490	5-Oct-19	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	13:11	13:45	0:33	LINE CLEAR AVAILED
491	5-Oct-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	11:27	14:04	2:36	LINE CLEAR AVAILED
492	5-Oct-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	20:01	21:01	0:59	LINE FAULT
493	5-Oct-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	20:08	21:06	0:57	LINE FAULT
494	5-Oct-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	21:06	23:59	2:53	LINE FAULT
495	5-Oct-19	BENGALURU	220	HV2	MALUR 220	21:06	21:40	0:34	TRANSFORMER FAULT
496	5-Oct-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT), JADIGENAHALLI	21:06	21:54	0:48	MAIN SUPPLY FAILURE
497	5-Oct-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	21:06	21:42	0:36	MAIN SUPPLY FAILURE
498	5-Oct-19	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	8:30	8:40	0:10	LOAD CHANGE OVER
499	5-Oct-19	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	13:39	13:52	0:13	LOAD CHANGE OVER
500	5-Oct-19	BENGALURU	66	HV1	JIGANI 220	13:39	13:52	0:13	LINE CLEAR AVAILED
501	5-Oct-19	BENGALURU	66	GOWRIBIDANUR 220 - DB 2	THONDEBHAVI, MANCHENAHALLI	16:55	17:10	0:15	LINE FAULT
502	5-Oct-19	GULBARGA	220	RTPS-RAICHUR1	RAICHUR_220	10:20	11:06	0:46	LINE FAULT
503	5-Oct-19	GULBARGA	220	KAPNOOR-SHAHBAD	KAPNOOR_220	19:20	19:47	0:27	LINE FAULT
504	5-Oct-19	GULBARGA	110	HANUMASAGAR-HIREGONNAGAR	HIRGONNANAGR_110	14:15	14:30	0:15	LINE CLEAR AVAILED
505	5-Oct-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	7:14	7:22	0:08	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
506	5-Oct-19	GULBARGA	110	MALLAT-MADALAPUR	MADALAPUR_110	10:40	10:50	0:10	LINE FAULT
507	5-Oct-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	16:20	16:40	0:20	LINE FAULT
508	5-Oct-19	GULBARGA	110	SIDHANOOR-NIRLOOTI_IPP	SIDHANOOR_220	5:27	5:37	0:10	LINE FAULT
509	5-Oct-19	GULBARGA	110	SEDAM-VICATASAGAR	SEDAM_220	1:45	1:59	0:14	LINE FAULT
510	5-Oct-19	GULBARGA	110	SEDAM-VICATASAGAR	SEDAM_220	2:52	3:03	0:11	LINE FAULT
511	5-Oct-19	GULBARGA	110	SEDAM-VICATASAGAR	SEDAM_220	5:50	6:30	0:40	LINE FAULT
512	5-Oct-19	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	17:45	18:15	0:30	LINE FAULT
513	5-Oct-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	14:55	16:22	1:27	LINE FAULT
514	5-Oct-19	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	13:54	14:13	0:19	LINE FAULT
515	5-Oct-19	HASSAN	110	HV1	KEMAR_220	15:34	17:27	1:53	TRANSFORMER FAULT
516	5-Oct-19	HASSAN	110	HV2	KEMAR_220	15:39	16:17	0:38	LINE CLEAR AVAILED
517	5-Oct-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	13:54	14:12	0:18	LINE FAULT
518	5-Oct-19	HASSAN	220	MRSSHM-STRP11	MRSMSG_220	14:56	16:21	1:25	LINE FAULT
519	5-Oct-19	HASSAN	110	HV2	HALADY_110	16:57	17:05	0:08	TRANSFORMER FAULT
520	5-Oct-19	HASSAN	110	HV1	ANAVATTI_110	15:00	15:55	0:55	TRANSFORMER FAULT
521	5-Oct-19	HASSAN	110	HV2	ANAVATTI_110	15:00	15:55	0:55	TRANSFORMER FAULT
522	5-Oct-19	HASSAN	110	HV2	BARANGI_110	9:07	10:06	0:59	LINE CLEAR AVAILED
523	5-Oct-19	HASSAN	110	HV1	KALLUSADARAHALLY_110	10:58	14:39	3:41	LINE CLEAR AVAILED
524	5-Oct-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	10:08	13:20	3:12	LINE FAULT
525	5-Oct-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	5:21	5:48	0:27	LINE FAULT
526	5-Oct-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	5:21	5:34	0:13	LINE FAULT
527	5-Oct-19	MYSORE	66	CR NAGARA-KABBALLI	KABHALLY_66	3:31	3:58	0:26	LINE FAULT
528	5-Oct-19	MYSORE	66	HV1	DUNDANAHALLI_66	20:48	20:53	0:05	HAND TRIPPED
529	5-Oct-19	MYSORE	66	HV2	DUNDANAHALLI_66	20:48	20:53	0:05	HAND TRIPPED
530	5-Oct-19	MYSORE	66	HV1	ELAVALA_66	12:12	12:33	0:21	TRANSFORMER FAULT
531	5-Oct-19	MYSORE	66	GUNDALUPETE-BEGUR	BEGUR_66 SINDHUVALI_66	3:31	3:50	0:18	LINE FAULT
532	5-Oct-19	MYSORE	66	GUNDALUPETE-HANGALA	BHARGI_66 HANGLA_66	3:30	4:35	1:05	LINE FAULT
533	5-Oct-19	MYSORE	66	GUNDALUPETE-HANGALA	BHARGI_66 HANGLA_66	4:42	11:55	7:13	LINE CLEAR AVAILED
534	5-Oct-19	MYSORE	66	GUNDALUPETE-BOMMALAPURA	BOMMALAPURA_66	10:01	11:52	1:50	NFBC ISSUED
535	5-Oct-19	MYSORE	66	HANNUR-KOTHANUR	KOTTANUR_66	2:34	2:40	0:05	LINE CLEAR AVAILED
536	5-Oct-19	MYSORE	66	HV1	HARVEY_66	3:39	5:45	2:06	LINE CLEAR AVAILED
537	5-Oct-19	MYSORE	66	HV2	HARVEY_66	3:35	5:45	2:10	LINE CLEAR AVAILED
538	5-Oct-19	MYSORE	66	HOOTAGALLY-BOGADHI	BOGADHI_66	18:34	22:39	4:05	LINE FAULT
539	5-Oct-19	MYSORE	66	HOOTAGALLY-DATAGALLI	DATTAGALLY_66 RKNAGARA_66	18:34	23:59	5:24	LINE FAULT
540	5-Oct-19	MYSORE	66	KABBALLI-GUNDALUPETE	KABHALLY_66	3:31	4:22	0:51	LINE FAULT
541	5-Oct-19	MYSORE	66	KADAKOLA-NANJANAGUDU 1	NANJANGUDU_66	12:00	16:23	4:23	NFBC ISSUED
542	5-Oct-19	MYSORE	66	RK NAGARA-DATAGALLI	DATTAGALLY_66 RKNAGARA_66	18:35	18:54	0:19	LINE FAULT
543	5-Oct-19	MYSORE	66	THANDYA-NANJANAGUDU	NANJANGUDU_66	12:04	16:24	4:19	NFBC ISSUED
544	5-Oct-19	TUMKUR	220	DAVANGERE SRS- GUTTUR66	GUTTUR_66	12:13	12:28	0:15	LINE FAULT
545	5-Oct-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	7:00	7:15	0:14	LINE FAULT



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
546	5-Oct-19	TUMKUR	66	TR-2	BENNEHALLI_66	23:09	23:10	0:01	TRANSFORMER FAULT
547	5-Oct-19	TUMKUR	66	CHANNAGIRI-LINGDHLI	CHANNAGIRI_66	14:44	17:51	3:06	MAIN SUPPLY FAILURE
548	5-Oct-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	18:15	19:29	1:14	LINE CLEAR AVAILED
549	5-Oct-19	TUMKUR	66	TR-2	DAVANAGERE_66	15:52	15:54	0:01	TRANSFORMER FAULT
550	5-Oct-19	TUMKUR	66	TR-2	DAVANAGERE_66	22:51	23:43	0:51	TRANSFORMER FAULT
551	5-Oct-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	12:35	13:12	0:37	HAND TRIPPED
552	5-Oct-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	21:22	21:35	0:12	LINE FAULT
553	5-Oct-19	TUMKUR	66	TR-3	DAVANGERE_SRS_220	12:38	12:56	0:18	LINE CLEAR AVAILED
554	5-Oct-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:35	13:09	0:33	HAND TRIPPED
555	5-Oct-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:35	13:02	0:27	HAND TRIPPED
556	5-Oct-19	TUMKUR	66	TR-1	HALUVAGALU_66	11:34	18:06	6:32	LINE CLEAR AVAILED
557	5-Oct-19	TUMKUR	66	TR-2	HARAPPANAHALLI_66	21:42	21:44	0:01	HAND TRIPPED
558	5-Oct-19	TUMKUR	66	HARAPPANAHALLI-SUZLON 1	SUZLON_IPP_66	21:42	21:54	0:11	HAND TRIPPED
559	5-Oct-19	TUMKUR	66	HARAPPANAHALLI-SUZLON 2	SUZLON_IPP_66	17:54	21:54	4:00	LINE CLEAR AVAILED
560	5-Oct-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	8:58	10:02	1:03	LINE CLEAR AVAILED
561	5-Oct-19	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	10:22	11:36	1:13	LINE CLEAR AVAILED
562	5-Oct-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	10:22	11:36	1:13	LINE CLEAR AVAILED
563	5-Oct-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	14:03	14:08	0:05	HAND TRIPPED
564	5-Oct-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR )	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	14:03	14:33	0:30	HAND TRIPPED
565	5-Oct-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR )	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	15:28	19:06	3:37	LINE CLEAR AVAILED
566	5-Oct-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	14:01	18:58	4:56	LINE CLEAR AVAILED
567	5-Oct-19	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	8:57	11:38	2:41	LINE CLEAR AVAILED
568	5-Oct-19	TUMKUR	66	LINGADAHALLI- P R PURA	LINGADAHALLY_66	7:33	8:54	1:20	LINE CLEAR AVAILED
569	5-Oct-19	TUMKUR	66	LINGADAHALLI- P R PURA	LINGADAHALLY_66	12:31	12:46	0:14	LINE CLEAR AVAILED
570	5-Oct-19	TUMKUR	66	TR-2	MALEBENNUR_66	9:42	10:07	0:24	LINE CLEAR AVAILED
571	5-Oct-19	TUMKUR	66	MIDIGESHI-IDHALLI	IDHALLY_66,KODIGENAHALLI_6	22:22	23:00	0:37	LINE FAULT
572	5-Oct-19	TUMKUR	66	NEELAGUNDA-HARPANAHALLI-1	HARAPPANAHALLI_66	21:26	21:39	0:12	HAND TRIPPED
573	5-Oct-19	TUMKUR	66	TR-2	NITRAHALLI_66	13:38	13:45	0:06	TRANSFORMER FAULT
574	5-Oct-19	TUMKUR	66	TR-2	NITRAHALLI_66	21:42	21:49	0:06	TRANSFORMER FAULT
575	5-Oct-19	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	22:25	22:42	0:17	LINE FAULT
576	5-Oct-19	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	22:25	22:32	0:06	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
577	5-Oct-19	TUMKUR	66	UCHANGIDURGA-I/C220SRSDAVANG(NEELAGUNDA)	UCHCHANGIDURGA_66	21:07	21:18	0:10	LINE FAULT
578	6-Oct-19	BAGALKOT	110	110/33KV,HV3	BELUR_110,TATA1&2_33,SOUTHERMFERRO_33,UAS_33,UDL_33	11:27	13:50	2:23	LINE CLEAR AVAILED
579	6-Oct-19	BAGALKOT	110	110/11KV,HV1	BYADAGI_110	16:53	17:09	0:16	TRANSFORMER FAULT
580	6-Oct-19	BAGALKOT	220	BAGALKOT-GADAG2	BAGALKOT_220	4:32	23:59	19:27	LINE CLEAR AVAILED
581	6-Oct-19	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	0:00	11:52	11:52	LINE CLEAR AVAILED
582	6-Oct-19	BAGALKOT	220	BIDNAL-NAGJHARI	BIDNAL_220	4:37	5:04	0:27	LINE FAULT
583	6-Oct-19	BAGALKOT	220	BIDNAL-NAGJHARI	BIDNAL_220	12:10	14:17	2:07	LINE CLEAR AVAILED
584	6-Oct-19	BAGALKOT	220	BIDNAL-NAGJHARI	BIDNAL_220	14:22	14:35	0:13	LINE FAULT
585	6-Oct-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	0:00	17:14	17:14	LINE CLEAR AVAILED
586	6-Oct-19	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	1:13	1:36	0:23	LINE FAULT
587	6-Oct-19	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	11:39	12:08	0:29	LINE CLEAR AVAILED
588	6-Oct-19	BAGALKOT	220	GHATAPRABHA-NARENDRA1	GHATAPRABHA_220	0:00	7:30	7:30	LINE CLEAR AVAILED
589	6-Oct-19	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	0:00	11:44	11:44	LINE CLEAR AVAILED
590	6-Oct-19	BAGALKOT	110	HUKKERI-HATTARGI	HATTARGI_110	3:07	8:09	5:02	LINE FAULT
591	6-Oct-19	BAGALKOT	110	VJRAMATTI-JAMBAGI	JAMBAGI_110	8:20	8:51	0:31	LINE FAULT
592	6-Oct-19	BAGALKOT	110	JAMBAGI-MUDHOL	MUDHOL_110	8:20	8:58	0:38	LINE FAULT
593	6-Oct-19	BAGALKOT	110	110/11KV, HV2	YELPHARATTI_110	15:18	15:22	0:04	TRANSFORMER FAULT
594	6-Oct-19	BAGALKOT	110	VAJRAMATTI220-KATARKI	KATARKI_110	0:26	0:32	0:06	LINE FAULT
595	6-Oct-19	BAGALKOT	110	JAMKHANDI SUGARS-TODALBAGI	TODALBAGI_110	4:29	4:37	0:08	LINE FAULT
596	6-Oct-19	BAGALKOT	110	110/33KV, HV3	TARIHAL_110, DUMMWAD_33, IE_33	10:45	19:28	8:43	LINE CLEAR AVAILED
597	6-Oct-19	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	4:37	15:09	10:32	LINE FAULT
598	6-Oct-19	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	10:29	16:49	6:20	LINE CLEAR AVAILED
599	6-Oct-19	BAGALKOT	110	SINDAGI-ALMEL	ALMEL_110	23:57	23:59	0:02	LINE FAULT
600	6-Oct-19	BAGALKOT	110	110/11KV, HV2	SHIROL_110	13:00	13:58	0:58	LINE CLEAR AVAILED
601	6-Oct-19	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	1:39	2:15	0:36	LINE FAULT
602	6-Oct-19	BAGALKOT	110	RANEENNUR220-AREMALLAPUR (HONNATTI)	HONNATTI_110	0:11	0:52	0:41	LINE FAULT
603	6-Oct-19	BAGALKOT	110	110/11KV, HV2	RANEENNUR_220	10:40	11:14	0:34	LINE CLEAR AVAILED
604	6-Oct-19	BAGALKOT	110	110/11KV, HV1	NANADI_110	15:52	16:51	0:59	LINE CLEAR AVAILED
605	6-Oct-19	BAGALKOT	110	110/11KV, HV2	NANADI_110	13:31	17:03	3:32	LINE CLEAR AVAILED
606	6-Oct-19	BAGALKOT	110	110/11KV, HV1	MUNDARGI_110	5:57	6:04	0:07	TRANSFORMER FAULT
607	6-Oct-19	BAGALKOT	110	110/11KV, HV2	MUDEDEBIHAL_110	8:55	9:03	0:08	TRANSFORMER FAULT
608	6-Oct-19	BAGALKOT	110	110/11KV, HV1	LOKAPUR_110	16:54	17:11	0:17	TRANSFORMER FAULT
609	6-Oct-19	BAGALKOT	110	110/33KV, HV3	LAKMANHALLI_110, ALNAVAR_33	2:40	2:44	0:04	TRANSFORMER FAULT
610	6-Oct-19	BAGALKOT	110	110/11KV, HV2	KAGAWAD_110	8:39	8:50	0:11	TRANSFORMER FAULT
611	6-Oct-19	BAGALKOT	110	110/11KV, HV2	KAGAWAD_110	17:01	17:17	0:16	TRANSFORMER FAULT
612	6-Oct-19	BAGALKOT	110	110/11KV, HV2	KAGAWAD_110	20:10	20:22	0:12	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
613	6-Oct-19	BENGALURU	220	HV2	MALUR 220	0:27	1:25	0:58	LINE CLEAR AVAILED
614	6-Oct-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT), JADIGENAHALLI	0:27	1:30	1:03	MAIN SUPPLY FAILURE
615	6-Oct-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	0:27	1:38	1:11	MAIN SUPPLY FAILURE
616	6-Oct-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	0:00	1:28	1:28	LINE FAULT
617	6-Oct-19	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1	PATHPALYA, THIMAMPALLI, SOMANATHAPURA	17:05	17:35	0:30	LOAD CHANGE OVER
618	6-Oct-19	BENGALURU	66	HV1	CHIKKABALLAPURA I/A	11:26	12:02	0:36	LINE CLEAR AVAILED
619	6-Oct-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	5:54	6:10	0:15	LINE FAULT
620	6-Oct-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	15:30	15:43	0:13	LINE FAULT
621	6-Oct-19	BENGALURU	66	HV2	KYALANUR	16:19	16:30	0:10	TRANSFORMER FAULT
622	6-Oct-19	GULBARGA	400	JSWVL400-GUTTUR	JSWVL_400	1:47	23:59	22:12	LINE CLEAR AVAILED
623	6-Oct-19	GULBARGA	220	JINDAL-LINGAPUR	JINDAL_220	3:56	6:50	2:54	LINE FAULT
624	6-Oct-19	GULBARGA	220	LINGAPUR-JVSL2	LINGAPUR_220	3:55	7:03	3:08	LINE FAULT
625	6-Oct-19	GULBARGA	220	LINGAPUR-GADAG2	LINGAPUR_220	4:47	9:43	4:56	LINE FAULT
626	6-Oct-19	GULBARGA	220	HV1	KUSTAGI_220	12:44	12:57	0:13	TRANSFORMER FAULT
627	6-Oct-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	9:25	9:44	0:19	LINE FAULT
628	6-Oct-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	10:22	10:30	0:08	LINE FAULT
629	6-Oct-19	GULBARGA	110	KOGALI-KUDILIGI	KUDILIGI_66	15:30	15:45	0:15	LINE FAULT
630	6-Oct-19	GULBARGA	110	HV2	CHORNOOR_66	8:44	10:40	1:56	LINE CLEAR AVAILED
631	6-Oct-19	GULBARGA	110	STARMETALLIC-MUNIRABAD	MUNIRABAD_220	7:00	7:30	0:30	LINE FAULT
632	6-Oct-19	GULBARGA	110	STARMETALLIC-MUNIRABAD	MUNIRABAD_220	7:40	8:30	0:50	LINE FAULT
633	6-Oct-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	10:39	10:44	0:05	LINE FAULT
634	6-Oct-19	GULBARGA	110	SINHANOOR220-TURVIHAL	TURVIHAL_110	13:40	14:10	0:30	LINE FAULT
635	6-Oct-19	GULBARGA	66	KOGALI-ASTROSLR	KOGALI_66	11:45	12:13	0:28	LINE CLEAR AVAILED
636	6-Oct-19	GULBARGA	66	HV1	KOTTUR_66	8:22	8:32	0:10	TRANSFORMER FAULT
637	6-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	19:10	19:10	LINE CLEAR AVAILED
638	6-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:54	23:59	1:05	LINE CLEAR AVAILED
639	6-Oct-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	16:59	23:59	7:00	LINE CLEAR AVAILED
640	6-Oct-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	16:59	17:15	0:16	HAND TRIPPED
641	6-Oct-19	HASSAN	220	UPCL-KEMAR2	upcl_gen	16:59	17:15	0:16	HAND TRIPPED
642	6-Oct-19	HASSAN	220	KADUR-DABUSET	KADUR_220	16:34	21:00	4:26	LINE FAULT
643	6-Oct-19	HASSAN	220	KEMAR-UPCL1	KEMAR_220	21:56	21:58	0:02	LINE FAULT
644	6-Oct-19	HASSAN	220	KEMAR-UPCL2	KEMAR_220	16:59	17:11	0:12	LINE FAULT
645	6-Oct-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	1:03	1:45	0:42	LINE FAULT
646	6-Oct-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	2:00	2:51	0:51	LINE FAULT
647	6-Oct-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	1:03	1:46	0:43	LINE FAULT
648	6-Oct-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	2:00	2:51	0:51	LINE FAULT
649	6-Oct-19	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	1:02	1:47	0:45	LINE FAULT
650	6-Oct-19	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	1:02	1:46	0:44	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
651	6-Oct-19	HASSAN	110	HV1	MANIPAL_110	6:12	6:21	0:09	TRANSFORMER FAULT
652	6-Oct-19	HASSAN	110	SAGARA-ALKLA	SAGARA_110	11:44	11:54	0:10	LINE FAULT
653	6-Oct-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	18:25	18:29	0:04	LINE FAULT
654	6-Oct-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	23:30	23:33	0:03	LINE FAULT
655	6-Oct-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:19	10:25	0:06	LINE FAULT
656	6-Oct-19	MYSORE	66	HV2	DEVANOORNGUDU_66	12:18	12:39	0:21	TRANSFORMER FAULT
657	6-Oct-19	MYSORE	66	HV1	DKMAIDANA_66	11:50	14:16	2:25	LINE CLEAR AVAILED
658	6-Oct-19	MYSORE	66	HV1	ELAVALA_66	11:54	12:12	0:17	TRANSFORMER FAULT
659	6-Oct-19	MYSORE	66	HANNUR-KOTHANUR	KOTTANUR_66	0:15	0:26	0:10	LINE FAULT
660	6-Oct-19	MYSORE	66	HANNUR-KOTHANUR	KOTTANUR_66	0:36	0:47	0:11	HAND TRIPPED
661	6-Oct-19	MYSORE	66	HV1	K_HONNALGERE_66	11:51	12:05	0:14	TRANSFORMER FAULT
662	6-Oct-19	MYSORE	66	MADHUVANAHALLI-HANNUR 1	BANDALLI, COWDALLI, HANNUR, MARTALLI & RAMAPURA	0:25	0:35	0:09	LINE FAULT
663	6-Oct-19	MYSORE	66	MADHUVANAHALLI-HANNUR 2	BANDALLI, COWDALLI, HANNUR, MARTALLI & RAMAPURA	0:25	0:35	0:09	LINE FAULT
664	6-Oct-19	TUMKUR	110	TR-1	BIDARE_110	14:12	14:43	0:31	LINE CLEAR AVAILED
665	6-Oct-19	TUMKUR	110	BIDARE- NITTUR	BIDARE_110	14:03	14:43	0:39	LINE CLEAR AVAILED
666	6-Oct-19	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	15:35	15:46	0:11	TRANSFORMER FAULT
667	6-Oct-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	9:53	12:04	2:10	LINE FAULT
668	6-Oct-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	9:53	10:13	0:19	LINE FAULT
669	6-Oct-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	14:41	15:15	0:33	LINE CLEAR AVAILED
670	6-Oct-19	TUMKUR	66	TR-2	DAVANAGERE_66	6:26	6:37	0:10	TRANSFORMER FAULT
671	6-Oct-19	TUMKUR	66	TR-2	DAVANAGERE_66	9:20	9:26	0:06	TRANSFORMER FAULT
672	6-Oct-19	TUMKUR	66	DAVANAGERE SRS- DAVANAGERE	DAVANAGERE_66	11:19	11:36	0:17	LINE FAULT
673	6-Oct-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	9:27	10:57	1:29	LINE CLEAR AVAILED
674	6-Oct-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	9:34	9:45	0:10	LINE FAULT
675	6-Oct-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	12:00	12:09	0:09	LINE FAULT
676	6-Oct-19	TUMKUR	66	I D HALLI- CLEAN MAX SOLAR	CLEANMAXSOLAR_IPP_66	6:08	7:28	1:19	LINE CLEAR AVAILED
677	6-Oct-19	TUMKUR	66	I D HALLI- CLEAN MAX SOLAR	CLEANMAXSOLAR_IPP_66	17:08	17:25	0:16	LINE CLEAR AVAILED
678	6-Oct-19	TUMKUR	66	TR-1	KATTIGE_66	6:39	7:11	0:31	TRANSFORMER FAULT
679	6-Oct-19	TUMKUR	66	MIDIGESHI-IDHALLI	IDHALLY_66,KODIGENAHALLI_6	0:30	1:42	1:12	LINE FAULT
680	6-Oct-19	TUMKUR	66	MIDIGESHI-IDHALLI	IDHALLY_66,KODIGENAHALLI_6	3:59	6:15	2:15	LINE FAULT
681	6-Oct-19	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	0:12	0:16	0:03	HAND TRIPPED
682	7-Oct-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	5:45	10:47	5:02	LINE FAULT
683	7-Oct-19	BAGALKOT	110	HUNAGUND-KUDALSANGAM	KUDALSANGAM_110	12:42	12:50	0:08	LINE FAULT
684	7-Oct-19	BAGALKOT	110	110/11KV,HV2	KAGAWADA_110	8:50	12:22	3:32	TRANSFORMER FAULT
685	7-Oct-19	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(G)_110	13:20	16:40	3:20	LINE CLEAR AVAILED
686	7-Oct-19	BAGALKOT	110	MANALI SUGARS-MALGHAN(S)	MALGHAN(S)_110	7:29	8:00	0:31	LINE FAULT
687	7-Oct-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	0:00	6:46	6:46	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
688	7-Oct-19	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	17:15	17:53	0:38	LINE FAULT
689	7-Oct-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	17:15	17:43	0:28	LINE FAULT
690	7-Oct-19	BAGALKOT	110	SINDAGI-ALMEL	ALMEL_110	0:01	0:34	0:33	LINE CLEAR AVAILED
691	7-Oct-19	BAGALKOT	110	SINDAGI-ALMEL	ALMEL_110	7:38	8:08	0:30	HAND TRIPPED
692	7-Oct-19	BAGALKOT	110	110/11KV,HV2	SHIROL_110	15:57	16:27	0:30	LINE CLEAR AVAILED
693	7-Oct-19	BAGALKOT	110	RANNABELAGALI-MUDHOL	MUDHOL_110	18:30	18:43	0:13	LINE FAULT
694	7-Oct-19	BENGALURU	66	CHELUR - ESUN SLR (IPP)	CHELUR	3:16	3:26	0:09	LINE FAULT
695	7-Oct-19	BENGALURU	66	CHELUR - YENIGADALE	CHELUR	3:16	3:24	0:08	LINE FAULT
696	7-Oct-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	3:16	3:22	0:05	LINE FAULT
697	7-Oct-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	3:48	4:02	0:13	LINE FAULT
698	7-Oct-19	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	4:20	4:34	0:14	LINE FAULT
699	7-Oct-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	9:50	9:57	0:06	LINE FAULT
700	7-Oct-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	11:13	11:19	0:05	LINE CLEAR AVAILED
701	7-Oct-19	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	17:35	18:20	0:45	LINE FAULT
702	7-Oct-19	BENGALURU	66	JIGANI 66 - BG ROAD	JIGANI 66	22:10	22:15	0:05	LOAD CHANGE OVER
703	7-Oct-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	1:19	1:32	0:12	LINE FAULT
704	7-Oct-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	17:45	17:55	0:10	LINE FAULT
705	7-Oct-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	17:55	23:59	6:04	LINE FAULT
706	7-Oct-19	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	4:22	4:26	0:03	LINE FAULT
707	7-Oct-19	BENGALURU	66	HV2	KYALANUR	7:26	7:47	0:20	LINE CLEAR AVAILED
708	7-Oct-19	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHBAD_220	6:29	7:14	0:45	LINE FAULT
709	7-Oct-19	GULBARGA	220	HV1,LV1	LINGASUGUR_220	12:20	12:36	0:16	TRANSFORMER FAULT
710	7-Oct-19	GULBARGA	220	HV2,LV2	LINGASUGUR_220	12:20	12:41	0:21	TRANSFORMER FAULT
711	7-Oct-19	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	13:10	17:16	4:06	LINE FAULT
712	7-Oct-19	GULBARGA	220	HV1	KUSTAGI_220	6:46	7:30	0:44	TRANSFORMER FAULT
713	7-Oct-19	GULBARGA	110	LINGASUGUR-MUDGAL	MUDGAL_110	12:20	17:00	4:40	LINE FAULT
714	7-Oct-19	GULBARGA	110	BETAGERA-KSHVCMNT_IPP	BETAGERA_110	17:50	18:05	0:15	LINE FAULT
715	7-Oct-19	GULBARGA	110	HV2	BEVOOR_110	5:59	6:15	0:16	TRANSFORMER FAULT
716	7-Oct-19	GULBARGA	110	PDHALLI-BASAI	PDHALLI_110	10:08	10:28	0:20	LINE FAULT
717	7-Oct-19	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	4:33	9:25	4:52	LINE FAULT
718	7-Oct-19	GULBARGA	110	HV2	SHORAPUR_110	8:10	8:15	0:05	TRANSFORMER FAULT
719	7-Oct-19	GULBARGA	110	SIDHANOOR-SUZLON1	SIDHANOOR_220	13:38	14:15	0:37	LINE FAULT
720	7-Oct-19	GULBARGA	110	SEDAM-VICATASAGAR	SEDAM_220	21:05	21:18	0:13	LINE FAULT
721	7-Oct-19	GULBARGA	110	KUSTAGI-YELBURGA	YELBURGA_110	6:46	8:07	1:21	LINE FAULT
722	7-Oct-19	GULBARGA	110	KUSTAGI-KANAKAGIRI	KANAKAGIRI_110	6:42	8:03	1:21	LINE FAULT
723	7-Oct-19	GULBARGA	110	KUSTAGI-KUSTAGISLR_IPP	KUSTAGI_220	8:10	10:59	2:49	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
724	7-Oct-19	GULBARGA	66	HV2	CHORNOOR_66	15:25	15:30	0:05	TRANSFORMER FAULT
725	7-Oct-19	GULBARGA	66	HV1	KOGALI_66	15:20	15:25	0:05	TRANSFORMER FAULT
726	7-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	8:29	8:29	LINE CLEAR AVAILED
727	7-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	16:42	23:59	7:17	LINE CLEAR AVAILED
728	7-Oct-19	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	11:19	12:59	1:40	LINE CLEAR AVAILED
729	7-Oct-19	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	11:19	12:59	1:40	LINE FAULT
730	7-Oct-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	20:35	20:44	0:09	LINE FAULT
731	7-Oct-19	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	18:30	20:05	1:35	LINE FAULT
732	7-Oct-19	HASSAN	66	HV1	MOSALEHOSAHALLI_66	20:39	20:44	0:05	TRANSFORMER FAULT
733	7-Oct-19	MYSORE	66	HV1	K HONNALAGERE-	23:05	23:11	0:06	HAND TRIPPED
734	7-Oct-19	MYSORE	66	HV2	K HONNALAGERE-	23:05	23:11	0:06	HAND TRIPPED
735	7-Oct-19	MYSORE	66	KIADB MANDYA-TK HALLI	KIADB MANDYA, MADUUR & SOMNAHALLI	6:46	7:15	0:29	LINE FAULT
736	7-Oct-19	MYSORE	66	KIADB MANDYA-TUMBEKERE	TUMBEKERE	6:46	7:13	0:27	LINE FAULT
737	7-Oct-19	MYSORE	66	HV1	KOPPA 66-	13:42	14:05	0:23	HAND TRIPPED
738	7-Oct-19	MYSORE	66	HV2	KOPPA 66-	13:42	14:05	0:22	HAND TRIPPED
739	7-Oct-19	MYSORE	66	KR PETE-KIKKERI	KIKKERI	21:23	21:34	0:10	LINE FAULT
740	7-Oct-19	MYSORE	66	KR PETE 220-CR PATNA	ANEGOLA & KRISHNAPURA STATIONS INTERRUPTED.	21:23	21:33	0:10	LINE FAULT
741	7-Oct-19	MYSORE	66	HV1	MALAVALLI-	15:41	17:07	1:26	LINE CLEAR AVAILED
742	7-Oct-19	MYSORE	66	HV2	MALAVALLI-	15:41	17:07	1:26	LINE CLEAR AVAILED
743	7-Oct-19	MYSORE	66	MALAVALLI-KADKOTHNAHALLI	HADLI & MALAVALLI	13:30	14:18	0:47	HAND TRIPPED
744	7-Oct-19	MYSORE	220	HV1	VAJAMANGALA-	10:00	12:23	2:22	TRANSFORMER FAULT
745	7-Oct-19	MYSORE	66	HV1	VAJAMANGALA-	12:29	12:31	0:02	HAND TRIPPED
746	7-Oct-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI & MARDIHUNDI STATIONS INTERRUPTED.	12:29	12:35	0:05	HAND TRIPPED
747	7-Oct-19	TUMKUR	220	TR-3	HIRIYUR_220	0:59	1:39	0:39	TRANSFORMER FAULT
748	7-Oct-19	TUMKUR	220	TR-1	KBCROSS_220	13:53	18:45	4:51	LINE CLEAR AVAILED
749	7-Oct-19	TUMKUR	110	TR-1	GUBBI_110	12:37	13:20	0:42	TRANSFORMER FAULT
750	7-Oct-19	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	13:38	13:44	0:05	LINE CLEAR AVAILED
751	7-Oct-19	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	13:35	18:45	5:10	LINE CLEAR AVAILED
752	7-Oct-19	TUMKUR	110	TR-2(LV SIDE )	KBCROSS_220	13:35	13:49	0:14	LINE CLEAR AVAILED
753	7-Oct-19	TUMKUR	110	SAMPIGE- DODDAGUNI	DODDAGUNI_110,AMMASANDRA_110,S AMPIGE_110	11:18	11:24	0:05	HAND TRIPPED
754	7-Oct-19	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	11:19	11:27	0:07	HAND TRIPPED
755	7-Oct-19	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	2:26	2:28	0:01	LINE FAULT
756	7-Oct-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:14	10:22	0:08	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
757	7-Oct-19	TUMKUR	66	GULIGENAHALLI- SIRA	GULIGENAHALLI_66	3:00	3:01	0:01	MAIN SUPPLY FAILURE
758	7-Oct-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	1:01	3:27	2:26	LINE CLEAR AVAILED
759	7-Oct-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	1:38	2:17	0:39	HAND TRIPPED
760	7-Oct-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	6:01	6:41	0:40	LINE FAULT
761	7-Oct-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	14:15	14:40	0:25	HAND TRIPPED
762	7-Oct-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	1:00	2:51	1:51	LINE CLEAR AVAILED
763	7-Oct-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP1_IPP_66	1:00	2:51	1:51	LINE CLEAR AVAILED
764	7-Oct-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	15:34	15:43	0:09	LINE FAULT
765	7-Oct-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	16:20	16:56	0:35	LINE FAULT
766	7-Oct-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	6:59	7:09	0:10	LINE FAULT
767	7-Oct-19	TUMKUR	66	MADHUGIRI 220- KALLAMBELLA	KALLAMBELLA_66, SIRA_66	1:15	1:30	0:15	LINE FAULT
768	7-Oct-19	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	4:37	6:05	1:27	LINE FAULT
769	7-Oct-19	TUMKUR	66	MADHUGIRI 220kv- SIRA 1	KALLAMBELLA_66, BUKKAPATNA_66	1:15	1:30	0:15	LINE FAULT
770	7-Oct-19	TUMKUR	66	MADHUGIRI 220kv- SIRA 1	KALLAMBELLA_66, BUKKAPATNA_66	1:46	2:58	1:11	LINE FAULT
771	7-Oct-19	TUMKUR	66	TR-2	NITRAHALLI_66	3:13	3:21	0:07	TRANSFORMER FAULT
772	7-Oct-19	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	3:26	3:45	0:19	LINE FAULT
773	7-Oct-19	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	10:04	10:35	0:30	LINE FAULT
774	7-Oct-19	TUMKUR	66	PAVAGADA-MADHUGIRI(PAVAGADA 220)	PAVAGADA_66	3:26	3:38	0:12	LINE FAULT
775	7-Oct-19	TUMKUR	66	TR-1	TUMKUR_66	1:47	2:03	0:16	TRANSFORMER FAULT