

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 20.11.2018 to 26.11.2018

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	20-Nov-18	BAGALKOT	110	110/11KV,HV1	DAMBAL_110	19:02	19:11	0:09	HAND TRIPPED
2	20-Nov-18	BAGALKOT	220	HARTI1-BIDNAL	BIDNAL_220	0:00	13:20	13:20	LINE CLEAR AVAILED
3	20-Nov-18	BAGALKOT	220	HARTI2-BIDNAL	BIDNAL_220	11:04	13:29	2:25	LINE CLEAR AVAILED
4	20-Nov-18	BAGALKOT	220	CHIKKODI2-BELGAUM	BELGAUM_220	2:03	7:04	5:01	HAND TRIPPED
5	20-Nov-18	BAGALKOT	220	CHIKKODI2-BELGAUM	BELGAUM_220	12:48	23:59	11:11	LINE CLEAR AVAILED
6	20-Nov-18	BAGALKOT	220	CHIKKODI1-BELGAUM	BELGAUM_220	13:46	13:53	0:07	HAND TRIPPED
7	20-Nov-18	BAGALKOT	220	CHIKKODI1-BELGAUM	BELGAUM_220	15:34	19:55	4:21	HAND TRIPPED
8	20-Nov-18	BAGALKOT	220	DHONI2(LINGAPUR2)-GADAG	GADAG_220	11:43	12:53	1:10	HAND TRIPPED
9	20-Nov-18	BAGALKOT	220	DHONI1(ARESS STEEL)-GADAG	GADAG_220	16:54	19:40	2:46	LINE CLEAR AVAILED
10	20-Nov-18	BAGALKOT	220	DHONI2(LINGAPUR2)-GADAG	GADAG_220	17:46	19:41	1:55	LINE CLEAR AVAILED
11	20-Nov-18	BAGALKOT	110	220/110KV,LV1	GADAG_220	12:36	15:04	2:28	HAND TRIPPED
12	20-Nov-18	BAGALKOT	110	110/33KV,HV2	GOPPANAKOPPA_110	13:22	14:08	0:46	LINE CLEAR AVAILED
13	20-Nov-18	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	12:44	15:10	2:26	LINE CLEAR AVAILED
14	20-Nov-18	BAGALKOT	110	110/11KV, HV1	KALADAGI_110	12:39	14:50	2:11	LINE CLEAR AVAILED
15	20-Nov-18	BAGALKOT	110	110/11KV, HV1	KERUR_110	10:47	12:04	1:17	LINE CLEAR AVAILED
16	20-Nov-18	BAGALKOT	110	110/33KV,HV3	ZALKI_110	2:08	2:19	0:11	TRANSFORMER FAULT
17	20-Nov-18	BAGALKOT	110	SAVANUR-SHIGGAON	SHIGGOAN_110	0:00	12:28	12:28	LINE CLEAR AVAILED
18	20-Nov-18	BAGALKOT	110	SHIVASAGAR SUGARS-SALAHALLI	SALAHALLI_110	12:44	17:38	4:54	LINE FAULT
19	20-Nov-18	BAGALKOT	220	SIRSI1-HUBLI	SIRSI_220	9:35	17:29	7:54	NBFC ISSUED
20	20-Nov-18	BAGALKOT	110	110/11KV,HV3	MUDALAGI_110	18:33	18:44	0:11	HAND TRIPPED
21	20-Nov-18	BAGALKOT	110	110/11KV,HV 2	MRUTYUNJAYANAGAR_110	11:37	12:45	1:08	LINE CLEAR AVAILED
22	20-Nov-18	BANGALORE	66	HV1	ATTIBELE	11:13	11:17	0:03	TRANSFORMER FAULT
23	20-Nov-18	BANGALORE	66	HV1	CHANNAPATNA	17:50	18:59	1:08	LINE CLEAR AVAILED
24	20-Nov-18	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	4:02	4:17	0:14	LINE FAULT
25	20-Nov-18	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	4:02	4:17	0:14	LINE FAULT
26	20-Nov-18	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	14:05	14:34	0:28	LINE CLEAR AVAILED
27	20-Nov-18	BANGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	14:33	14:41	0:07	LINE FAULT
28	20-Nov-18	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA, Y HUNSENHALLI	9:43	10:38	0:54	LINE CLEAR AVAILED
29	20-Nov-18	BANGALORE	66	DEVANAHALLI - DB PURA 1	DEVANAHALLI	8:04	8:15	0:10	LINE FAULT
30	20-Nov-18	BANGALORE	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	8:04	8:12	0:08	LINE FAULT
31	20-Nov-18	BANGALORE	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	8:04	8:12	0:08	LINE FAULT
32	20-Nov-18	BANGALORE	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSUR RAMAPURA	13:35	15:05	1:30	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
33	20-Nov-18	BANGALORE	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	13:35	15:05	1:30	MAIN SUPPLY FAILURE
34	20-Nov-18	BANGALORE	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI	13:35	15:05	1:30	MAIN SUPPLY FAILURE
35	20-Nov-18	BANGALORE	66	HV2	JANGAMKOTE	14:05	14:47	0:42	LINE CLEAR AVAILED
36	20-Nov-18	BANGALORE	66	HV2	KANAKAPURA 220	16:20	17:02	0:42	LINE CLEAR AVAILED
37	20-Nov-18	BANGALORE	66	KGF - BEML (EHT)	BEML (EHT)	11:01	11:21	0:19	LINE FAULT
38	20-Nov-18	BANGALORE	66	KGF - KYASAMBALLI	ANDERSONPET, KYASAMBALLI, DODDAKARI	11:01	11:20	0:19	LINE FAULT
39	20-Nov-18	BANGALORE	66	HV1	KOLAR 220	8:23	8:43	0:19	TRANSFORMER FAULT
40	20-Nov-18	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:05	15:12	0:06	LINE FAULT
41	20-Nov-18	BANGALORE	66	KEMBODI - KOLAR 220	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	10:00	12:00	2:00	LINE CLEAR AVAILED
42	20-Nov-18	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	11:01	11:17	0:15	LINE FAULT
43	20-Nov-18	BANGALORE	66	HV2	EPIP 220	9:45	11:01	1:16	LINE CLEAR AVAILED
44	20-Nov-18	BANGALORE	66	HV1	NGEF	20:17	22:15	1:57	TRANSFORMER FAULT
45	20-Nov-18	BANGALORE	66	HV2	POTTERY ROAD	11:23	11:30	0:06	LINE CLEAR AVAILED
46	20-Nov-18	BANGALORE	66	HV1	SOUTH CITY	15:45	16:19	0:34	TRANSFORMER FAULT
47	20-Nov-18	BANGALORE	220	HV2	TK HALLI 220	4:23	4:38	0:15	TRANSFORMER FAULT
48	20-Nov-18	BANGALORE	66	HV1	TK HALLI 220	4:23	4:43	0:20	MAIN SUPPLY FAILURE
49	20-Nov-18	BANGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, K HONALGERE	4:23	5:00	0:37	LINE FAULT
50	20-Nov-18	BANGALORE	66	TK HALLI 220 - SHIMSHA 2	TK HALLI 220	4:23	4:46	0:23	LINE FAULT
51	20-Nov-18	BANGALORE	66	TK HALLI 220 - SHIMSHA 1	TK HALLI 220	4:23	4:43	0:20	MAIN SUPPLY FAILURE
52	20-Nov-18	BANGALORE	66	TK HALLI 220 - IGGALURU	IGGALURU, AKKURMOLE	4:23	4:40	0:17	MAIN SUPPLY FAILURE
53	20-Nov-18	BANGALORE	66	TK HALLI 220 - SOMANAHALLI 2	HALAGUR	4:23	4:43	0:20	MAIN SUPPLY FAILURE
54	20-Nov-18	BANGALORE	220	HV1	HOODY 220	14:41	15:00	0:19	LINE CLEAR AVAILED
55	20-Nov-18	BANGALORE	220	HV4	HOODY 220	14:45	14:57	0:12	LINE CLEAR AVAILED
56	20-Nov-18	BANGALORE	220	HV1	HOODY 220	16:40	16:55	0:15	LINE CLEAR AVAILED
57	20-Nov-18	BANGALORE	220	HV4	HOODY 220	16:45	17:00	0:14	LINE CLEAR AVAILED
58	20-Nov-18	BANGALORE	66	HV1	HOODY 220	14:37	15:01	0:23	MAIN SUPPLY FAILURE
59	20-Nov-18	BANGALORE	66	HV1	HOODY 220	16:37	17:02	0:24	MAIN SUPPLY FAILURE
60	20-Nov-18	BANGALORE	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	14:39	15:03	0:24	MAIN SUPPLY FAILURE
61	20-Nov-18	BANGALORE	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	16:38	17:06	0:28	MAIN SUPPLY FAILURE
62	20-Nov-18	BANGALORE	66	HOODY 220 - HP (EHT)	HP (EHT)	14:41	15:04	0:23	MAIN SUPPLY FAILURE
63	20-Nov-18	BANGALORE	66	HOODY 220 - HP (EHT)	HP (EHT)	16:38	17:06	0:27	MAIN SUPPLY FAILURE
64	20-Nov-18	BANGALORE	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD, ITC (EHT)	14:39	15:03	0:24	MAIN SUPPLY FAILURE
65	20-Nov-18	BANGALORE	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD, ITC (EHT)	16:35	17:02	0:27	MAIN SUPPLY FAILURE
66	20-Nov-18	BANGALORE	66	HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTHINIKETHAN	14:37	15:03	0:25	MAIN SUPPLY FAILURE
67	20-Nov-18	BANGALORE	66	HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTHINIKETHAN	16:37	17:04	0:27	MAIN SUPPLY FAILURE
68	20-Nov-18	BANGALORE	66	HOODY 220 - GRAPHITE INDIA(EHT)	GRAPHITE INDIA(EHT)	14:39	15:02	0:23	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
69	20-Nov-18	BANGALORE	66	HOODY 220 - GRAPHITE INDIA(EHT)	GRAPHITE INDIA(EHT)	16:40	17:09	0:29	MAIN SUPPLY FAILURE
70	20-Nov-18	BANGALORE	66	BIDADI 220 - TTIPL(EHT)	TTIPL(EHT)	17:25	17:30	0:05	LINE FAULT
71	20-Nov-18	GULBARGA	400	JSWVL400-GUTTUR	GUTTUR_400	0:00	17:18	17:18	LINE FAULT
72	20-Nov-18	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220,MALLAT_220	10:37	12:50	2:13	LINE CLEAR AVAILED
73	20-Nov-18	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	0:00	13:20	13:20	LINE FAULT
74	20-Nov-18	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	0:00	16:50	16:50	NBFC ISSUED
75	20-Nov-18	GULBARGA	110	BETAGERA-KSHVCMNT_SLR	BETAGERA_110	4:47	5:02	0:15	LINE FAULT
76	20-Nov-18	GULBARGA	110	BHALKI-HALBARGA	BHALKI_110, LADHA_110	6:20	6:30	0:10	LINE FAULT
77	20-Nov-18	GULBARGA	110	HALBURGA-ACMEVSLR_IPP	HALBURGA_220	11:36	11:55	0:19	LINE FAULT
78	20-Nov-18	GULBARGA	110	HUMNABAD-MANEKHALLI,HUMNABAD110	MANEKHALLI_110,HUMNABAD_110	12:10	12:20	0:10	LINE CLEAR AVAILED
79	20-Nov-18	GULBARGA	110	SIDHANOOR-SINDHNOOR110	SINDHANOOR_110,MASKI_110,KAVITAL_110	12:38	13:40	1:02	LINE CLEAR AVAILED
80	20-Nov-18	GULBARGA	66	HV2	TAMBRAHALLI_66	0:00	13:46	13:46	LINE CLEAR AVAILED
81	20-Nov-18	GULBARGA	66	HV1	TAMBRAHALLI_66	13:00	13:40	0:40	LINE CLEAR AVAILED
82	20-Nov-18	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	8:44	10:02	1:18	MAIN SUPPLY FAILURE
83	20-Nov-18	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	8:43	9:33	0:50	MAIN SUPPLY FAILURE
84	20-Nov-18	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	8:56	9:28	0:32	HAND TRIPPED
85	20-Nov-18	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	8:56	9:44	0:48	HAND TRIPPED
86	20-Nov-18	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	8:56	9:33	0:37	HAND TRIPPED
87	20-Nov-18	HASSAN	220	KEMAR-UPCL1	KEMAR_220	8:36	12:04	3:28	LINE FAULT
88	20-Nov-18	HASSAN	220	KEMAR-UPCL2	KEMAR_220	9:04	9:16	0:12	MAIN SUPPLY FAILURE
89	20-Nov-18	HASSAN	220	KEMAR-Varahi2	KEMAR_220	8:38	9:15	0:37	LINE FAULT
90	20-Nov-18	HASSAN	220	KEMAR-Varahi2	KEMAR_220	9:19	16:08	6:49	LINE CLEAR AVAILED
91	20-Nov-18	HASSAN	220	KEMAR-Varahi3	KEMAR_220	8:37	9:14	0:37	LINE FAULT
92	20-Nov-18	HASSAN	220	KEMAR-Varahi3	KEMAR_220	12:09	19:14	7:05	LINE CLEAR AVAILED
93	20-Nov-18	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:47	9:30	0:43	MAIN SUPPLY FAILURE
94	20-Nov-18	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:48	9:30	0:42	MAIN SUPPLY FAILURE
95	20-Nov-18	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	8:47	9:28	0:41	MAIN SUPPLY FAILURE
96	20-Nov-18	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	8:47	9:43	0:56	MAIN SUPPLY FAILURE
97	20-Nov-18	HASSAN	220	PUTTUR-KEMAR1	PUTTUR_220	8:39	9:33	0:54	MAIN SUPPLY FAILURE
98	20-Nov-18	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	8:39	10:04	1:25	MAIN SUPPLY FAILURE
99	20-Nov-18	HASSAN	220	UPCL-KEMAR1	upcl_gen	8:36	12:04	3:28	LINE FAULT
100	20-Nov-18	HASSAN	220	UPCL-KEMAR2	upcl_gen	8:36	9:18	0:42	LINE FAULT
101	20-Nov-18	HASSAN	220	VARAHI-KEMAR1	varahi_gen	8:40	9:13	0:33	LINE FAULT
102	20-Nov-18	HASSAN	220	VARAHI-KEMAR2	varahi_gen	8:40	9:15	0:35	LINE FAULT
103	20-Nov-18	HASSAN	220	VARAHI-KEMAR2	varahi_gen	9:19	16:08	6:49	HAND TRIPPED
104	20-Nov-18	HASSAN	220	VARAHI-KEMAR3	varahi_gen	12:08	19:14	7:06	LINE FAULT
105	20-Nov-18	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	9:59	10:27	0:28	HAND TRIPPED
106	20-Nov-18	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	9:59	11:14	1:15	HAND TRIPPED
107	20-Nov-18	HASSAN	110	HV1	KEMAR_220	8:38	10:46	2:08	HAND TRIPPED
108	20-Nov-18	HASSAN	110	HV2	KEMAR_220	9:13	9:35	0:22	HAND TRIPPED
109	20-Nov-18	HASSAN	110	KEMAR-Manipal1	KEMAR_220	15:26	15:40	0:14	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
110	20-Nov-18	HASSAN	110	KEMAR-Manipal2	KEMAR_220	15:26	15:40	0:14	LINE FAULT
111	20-Nov-18	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	8:54	9:48	0:54	HAND TRIPPED
112	20-Nov-18	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	8:54	9:48	0:54	HAND TRIPPED
113	20-Nov-18	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	8:38	9:55	1:17	MAIN SUPPLY FAILURE
114	20-Nov-18	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	8:39	9:51	1:12	MAIN SUPPLY FAILURE
115	20-Nov-18	HASSAN	110	ANANDA-SHIMOGA	ANANDAPURA_110	11:35	13:12	1:37	HAND TRIPPED
116	20-Nov-18	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	10:31	11:14	0:43	MAIN SUPPLY FAILURE
117	20-Nov-18	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	8:39	10:00	1:21	MAIN SUPPLY FAILURE
118	20-Nov-18	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	8:47	9:57	1:10	MAIN SUPPLY FAILURE
119	20-Nov-18	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	8:39	10:26	1:47	MAIN SUPPLY FAILURE
120	20-Nov-18	HASSAN	110	HOSNGD-HULIKAL	HOSNGADI_110	8:38	10:04	1:26	MAIN SUPPLY FAILURE
121	20-Nov-18	HASSAN	110	KADUR-NGNHL	KADUR_220	15:15	15:31	0:16	LINE FAULT
122	20-Nov-18	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	8:39	10:32	1:53	MAIN SUPPLY FAILURE
123	20-Nov-18	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	8:39	9:35	0:56	MAIN SUPPLY FAILURE
124	20-Nov-18	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	15:28	15:40	0:12	HAND TRIPPED
125	20-Nov-18	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	8:40	9:55	1:15	MAIN SUPPLY FAILURE
126	20-Nov-18	HASSAN	110	SAGARA-ALKLA	SAGARA_110	11:33	13:05	1:32	HAND TRIPPED
127	20-Nov-18	HASSAN	110	SAGARA-SORABA	SAGARA_110	11:21	13:05	1:44	HAND TRIPPED
128	20-Nov-18	HASSAN	110	SORABA-SHR220	SORABA_110	11:23	11:27	0:04	LINE CLEAR AVAILED
129	20-Nov-18	HASSAN	110	HV1	SHIVAPURA_110	16:16	18:00	1:44	LINE CLEAR AVAILED
130	20-Nov-18	HASSAN	66	HASSN22-ARAKALGUD2	HASSAN_220	18:08	18:44	0:36	LINE FAULT
131	20-Nov-18	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	12:50	14:12	1:22	LINE CLEAR AVAILED
132	20-Nov-18	HASSAN	66	BELUR66MUDIGERE	BELUR_66	9:58	17:08	7:10	LINE CLEAR AVAILED
133	20-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	11:38	13:29	1:51	LINE CLEAR AVAILED
134	20-Nov-18	HASSAN	66	GENDEHA-HASSAN	GENDEHALLI_66	10:03	17:09	7:06	MAIN SUPPLY FAILURE
135	20-Nov-18	HASSAN	66	HV1	GENDEHALLI_66	11:05	17:14	6:09	MAIN SUPPLY FAILURE
136	20-Nov-18	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	17:04	17:11	0:07	MAIN SUPPLY FAILURE
137	20-Nov-18	HASSAN	66	HV1	JUTTANAHALLI_66	9:45	13:00	3:15	LINE CLEAR AVAILED
138	20-Nov-18	HASSAN	66	HV1	MALLAPURA_66	16:31	16:50	0:19	LINE CLEAR AVAILED
139	20-Nov-18	MYSORE	66	HV1	AKKIHEBBAL_66	15:01	15:15	0:13	TRANSFORMER FAULT
140	20-Nov-18	MYSORE	66	HV1	CHANDAKAVADI_66	14:04	15:06	1:02	LINE CLEAR AVAILED
141	20-Nov-18	MYSORE	66	HV2	CHANDAKAVADI_66	12:25	14:04	1:38	LINE CLEAR AVAILED
142	20-Nov-18	MYSORE	66	CR NAGARA-KABBALLI	HARVEY_66 KABHALLY_66	11:39	11:47	0:08	LINE FAULT
143	20-Nov-18	MYSORE	66	CR NAGARA-GUNDLUPETE 2	GUNDULPET_66 BHARGI_66 HANGLA_66 BOMMALAPURA_66 BEGUR_66 SINDHUVALLI_66 TERAKANAMBE_66	11:25	11:30	0:04	LINE FAULT
144	20-Nov-18	MYSORE	66	CR NAGARA-GUNDLUPETE 2	GUNDULPET_66 BHARGI_66 HANGLA_66 BOMMALAPURA_66 BEGUR_66 SINDHUVALLI_66 TERAKANAMBE_66	11:39	11:47	0:08	LINE FAULT
145	20-Nov-18	MYSORE	66	G UKKADA-METAGALLY	SRIRANGAPATNA_66	7:01	17:17	10:16	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
146	20-Nov-18	MYSORE	66	G UKKADA-PANDAVAPURA	GARUDANAUKADDA_66	10:50	15:45	4:54	LINE CLEAR AVAILED
147	20-Nov-18	MYSORE	66	HV1	HOOTAGALLY_220	1:38	14:00	12:22	TRANSFORMER FAULT
148	20-Nov-18	MYSORE	66	JAKKANAHALLY-MAHADESHWARAPURA	JAKKANAHALLY_66 G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI MANDYA_66 NAGAMANGALA_66	14:55	18:25	3:29	HAND TRIPPED
149	20-Nov-18	MYSORE	66	KM DODDI-MANDYA	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 K_HONNALGERE_66	4:20	4:52	0:32	HAND TRIPPED
150	20-Nov-18	MYSORE	66	HV2	NANJANGUDU_66	13:32	13:41	0:09	TRANSFORMER FAULT
151	20-Nov-18	MYSORE	66	HV2	NANJANGUDU_66	14:10	14:45	0:34	TRANSFORMER FAULT
152	20-Nov-18	MYSORE	66	HV2	NANJANGUDU_66	16:04	16:51	0:47	TRANSFORMER FAULT
153	20-Nov-18	MYSORE	66	HV2	NANJANGUDU_66	17:05	18:12	1:07	TRANSFORMER FAULT
154	20-Nov-18	MYSORE	66	HV2	NANJANGUDU_66	18:12	18:26	0:13	TRANSFORMER FAULT
155	20-Nov-18	MYSORE	66	HV2	NANJANGUDU_66	19:43	20:37	0:53	TRANSFORMER FAULT
156	20-Nov-18	MYSORE	66	HV2	NANJANGUDU_66	21:22	21:51	0:28	HAND TRIPPED
157	20-Nov-18	MYSORE	66	SANTHE SARGURU-B MATAKERE	B MATKERE_66	11:14	11:22	0:08	LINE FAULT
158	20-Nov-18	MYSORE	66	HV2	SUTTUR_66	9:20	15:49	6:28	LINE CLEAR AVAILED
159	20-Nov-18	MYSORE	66	HV1	SUTTUR_66	9:25	15:45	6:20	LINE CLEAR AVAILED
160	20-Nov-18	MYSORE	66	TALAKADU-ADANI	THALAKADU_66	10:05	16:48	6:42	LINE CLEAR AVAILED
161	20-Nov-18	MYSORE	66	TALAKADU-PARINAMIPURA	THALAKADU_66	10:05	16:47	6:41	LINE CLEAR AVAILED
162	20-Nov-18	TUMKUR	220	TR-2(HV2)	ANTHRASANAHALLI_220	15:10	15:18	0:08	LINE CLEAR AVAILED
163	20-Nov-18	TUMKUR	110	TR-1(HV SIDE)	GUBBI_110	12:06	12:10	0:03	TRANSFORMER FAULT
164	20-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- KUNIGAL	KUNIGAL_66	16:45	17:09	0:23	LINE CLEAR AVAILED
165	20-Nov-18	TUMKUR	66	TR-2 (LV2)	ANTHRASANAHALLI_220	15:10	15:18	0:08	LINE CLEAR AVAILED
166	20-Nov-18	TUMKUR	66	TR-2	BENNEHALLI_66	12:00	13:13	1:13	LINE CLEAR AVAILED
167	20-Nov-18	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	10:29	16:10	5:40	HAND TRIPPED
168	20-Nov-18	TUMKUR	66	TR-1	DEVARAHALLI_66	10:29	16:10	5:40	HAND TRIPPED
169	20-Nov-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:14	17:46	9:32	HAND TRIPPED
170	20-Nov-18	TUMKUR	66	HANAGAL- B G KERE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	7:03	9:48	2:44	LINE CLEAR AVAILED
171	20-Nov-18	TUMKUR	66	HANAGAL- RAMPURA	NAGASAMUDRA_66, RAMPURA_66	9:37	9:44	0:07	LINE CLEAR AVAILED
172	20-Nov-18	TUMKUR	66	TR-2	HARIHAR_66	16:02	17:49	1:47	LINE CLEAR AVAILED
173	20-Nov-18	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	CHIKKABANAGERE_66	15:35	16:10	0:34	LINE CLEAR AVAILED
174	20-Nov-18	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	CHIKKABANAGERE_66	17:19	18:58	1:39	LINE CLEAR AVAILED
175	20-Nov-18	TUMKUR	66	HIRIYUR 220kV- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	11:34	11:40	0:06	LINE CLEAR AVAILED
176	20-Nov-18	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	22:33	22:34	0:01	HAND TRIPPED
177	20-Nov-18	TUMKUR	66	TR-2	HONNALI_66	17:04	17:34	0:30	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
178	20-Nov-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	8:59	15:45	6:45	LINE CLEAR AVAILED
179	20-Nov-18	TUMKUR	66	TR-2	HULIYURDURGA_66	11:41	12:02	0:20	LINE CLEAR AVAILED
180	20-Nov-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:05	13:11	0:06	LINE FAULT
181	20-Nov-18	TUMKUR	66	NAGALAMADIKE- SUNDARRAJISOLAR_IPP_66	SUNDARRAJISOLAR_IPP_66	11:43	11:53	0:10	HAND TRIPPED
182	20-Nov-18	TUMKUR	66	NAGASAMUDRA- HANAGAL	NAGASAMUDRA_66, RAMPURA_66	7:59	9:56	1:57	LINE CLEAR AVAILED
183	20-Nov-18	TUMKUR	66	TR-1	NAGASAMUDRA_66	7:59	10:01	2:01	LINE CLEAR AVAILED
184	20-Nov-18	TUMKUR	66	NAGASAMUDRA- RAMPURA	RAMPURA_66	7:59	9:56	1:57	LINE CLEAR AVAILED
185	20-Nov-18	TUMKUR	66	TR-1	PAVAGADA_66	13:05	13:20	0:14	LINE CLEAR AVAILED
186	20-Nov-18	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	7:16	9:28	2:12	LINE CLEAR AVAILED
187	20-Nov-18	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:07	14:37	4:29	LINE FAULT
188	21-Nov-18	BAGALKOT	220	CHIKKODI1-BELGAUM	BELGAUM_220	16:25	16:47	0:22	HAND TRIPPED
189	21-Nov-18	BAGALKOT	220	CHIKKODI1-BELGAUM	BELGAUM_220	16:59	17:39	0:40	HAND TRIPPED
190	21-Nov-18	BAGALKOT	220	CHIKKODI1-BELGAUM	BELGAUM_220	20:01	23:59	3:58	HAND TRIPPED
191	21-Nov-18	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	8:13	8:19	0:06	TRANSFORMER FAULT
192	21-Nov-18	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	16:55	17:02	0:07	TRANSFORMER FAULT
193	21-Nov-18	BANGALORE	66	HV2	C STATION	2:03	5:10	3:06	LINE CLEAR AVAILED
194	21-Nov-18	BANGALORE	66	HV1	CB PURA I/A	14:28	14:55	0:26	LINE CLEAR AVAILED
195	21-Nov-18	BANGALORE	66	HV1	D CROSS	3:37	4:41	1:03	TRANSFORMER FAULT
196	21-Nov-18	BANGALORE	66	HV1	D CROSS	12:01	13:03	1:01	LINE CLEAR AVAILED
197	21-Nov-18	BANGALORE	66	D CROSS - DB PURA 220	D CROSS	3:37	4:41	1:03	LINE FAULT
198	21-Nov-18	BANGALORE	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	5:55	6:14	0:19	LINE FAULT
199	21-Nov-18	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALLI	12:03	12:13	0:09	LINE FAULT
200	21-Nov-18	GULBARGA	220	LINGAPUR-KUSTAGI	KUSTAGI_220	0:00	15:27	15:27	LINE CLEAR AVAILED
201	21-Nov-18	GULBARGA	220	LINGAPUR-KUSTAGI	KUSTAGI_220	15:39	23:59	8:20	LINE FAULT
202	21-Nov-18	GULBARGA	220	HV1	ITTAGI_220	8:55	9:05	0:10	HAND TRIPPED
203	21-Nov-18	GULBARGA	220	KUSTAGI-SUZLON2	KUSTAGI_220	22:20	23:59	1:39	LINE FAULT
204	21-Nov-18	GULBARGA	110	HV2	BETAGERA_110	9:45	9:51	0:06	TRANSFORMER FAULT
205	21-Nov-18	GULBARGA	110	HV2	DEODURGA_110	17:07	17:15	0:08	TRANSFORMER FAULT
206	21-Nov-18	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,JANAWADA_110,DIGGI_110,DONGRAGOAN_110	3:23	3:30	0:07	LINE FAULT
207	21-Nov-18	GULBARGA	110	HV2	UPANAYAKANAHALLI_66	10:15	23:59	13:44	LINE CLEAR AVAILED
208	21-Nov-18	GULBARGA	110	HV2	KAMPLI_110	15:24	15:36	0:12	TRANSFORMER FAULT
209	21-Nov-18	GULBARGA	110	LV1	KUSTAGI_220	12:30	12:50	0:20	TRANSFORMER FAULT
210	21-Nov-18	GULBARGA	110	LV1	KUSTAGI_220	21:35	21:55	0:20	TRANSFORMER FAULT
211	21-Nov-18	GULBARGA	66	HV1	GUDEKOTE_66	11:50	12:48	0:58	LINE CLEAR AVAILED
212	21-Nov-18	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66	11:51	12:41	0:50	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
213	21-Nov-18	GULBARGA	66	HV1	UPANAYAKANAHALLI_66	10:15	11:00	0:45	LINE CLEAR AVAILED
214	21-Nov-18	GULBARGA	66	LV2	ITTAGI_220	8:55	9:02	0:07	TRANSFORMER FAULT
215	21-Nov-18	GULBARGA	66	ITTAGI-CLN MAX1,2	ITTAGI_220	10:03	11:10	1:07	LINE CLEAR AVAILED
216	21-Nov-18	GULBARGA	66	ITTAGI-RNWSLR1,2	ITTAGI_220	10:03	11:10	1:07	LINE CLEAR AVAILED
217	21-Nov-18	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:18	13:28	3:10	LINE CLEAR AVAILED
218	21-Nov-18	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	14:59	15:21	0:22	LINE CLEAR AVAILED
219	21-Nov-18	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:18	13:28	3:10	NBFC ISSUED
220	21-Nov-18	HASSAN	110	HV2	NAVUNDA_110	4:56	17:36	12:40	TRANSFORMER FAULT
221	21-Nov-18	HASSAN	110	HV1	PUTTUR_220	9:57	12:44	2:47	LINE CLEAR AVAILED
222	21-Nov-18	HASSAN	110	HV1	SAGARA_110	19:49	21:25	1:36	TRANSFORMER FAULT
223	21-Nov-18	HASSAN	110	HV2	SORABA_110	10:39	11:20	0:41	LINE CLEAR AVAILED
224	21-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	10:27	11:14	0:47	TRANSFORMER FAULT
225	21-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	11:24	11:43	0:19	TRANSFORMER FAULT
226	21-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	12:38	12:51	0:13	TRANSFORMER FAULT
227	21-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	12:59	13:26	0:27	TRANSFORMER FAULT
228	21-Nov-18	MYSORE	66	BG NAGARA-NAGAMANGALA	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	10:32	10:44	0:12	LINE FAULT
229	21-Nov-18	MYSORE	66	HV2	BILIKERE_66	11:59	12:09	0:10	TRANSFORMER FAULT
230	21-Nov-18	MYSORE	66	HV1	KOPPA_66	16:25	16:56	0:31	TRANSFORMER FAULT
231	21-Nov-18	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	17:43	17:52	0:09	LINE FAULT
232	21-Nov-18	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	15:05	15:18	0:12	LINE FAULT
233	21-Nov-18	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	MRSMSG_220	13:17	15:20	2:03	LINE FAULT
234	21-Nov-18	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	15:29	15:46	0:16	LINE CLEAR AVAILED
235	21-Nov-18	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	15:16	15:18	0:02	HAND TRIPPED
236	21-Nov-18	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	15:16	15:21	0:05	HAND TRIPPED
237	21-Nov-18	TUMKUR	66	TR-2	BADDIHALLI_66	17:35	17:40	0:05	HAND TRIPPED
238	21-Nov-18	TUMKUR	66	TR-2	BUKKAPATNA_66	15:10	17:00	1:49	LINE CLEAR AVAILED
239	21-Nov-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:33	17:30	8:56	HAND TRIPPED
240	21-Nov-18	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	16:11	16:15	0:04	LINE FAULT
241	21-Nov-18	TUMKUR	66	TR-2	HONNALI_66	17:01	17:08	0:07	TRANSFORMER FAULT
242	21-Nov-18	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	16:11	16:21	0:10	MAIN SUPPLY FAILURE
243	21-Nov-18	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	16:11	16:21	0:09	MAIN SUPPLY FAILURE
244	21-Nov-18	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:14	16:29	6:15	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
245	22-Nov-18	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	0:00	7:03	7:03	HAND TRIPPED
246	22-Nov-18	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	12:09	13:12	1:03	LINE FAULT
247	22-Nov-18	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	20:59	23:59	3:00	HAND TRIPPED
248	22-Nov-18	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	11:20	17:19	5:59	LINE CLEAR AVAILED
249	22-Nov-18	BAGALKOT	110	NARAGUND-GOPANAKOPPA	GOPANAKOPPA_110	0:00	18:04	18:04	LINE CLEAR AVAILED
250	22-Nov-18	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	15:04	15:16	0:12	TRANSFORMER FAULT
251	22-Nov-18	BAGALKOT	110	NALAGUND-KONNUR	KONNUR_110	11:21	11:57	0:36	LINE CLEAR AVAILED
252	22-Nov-18	BAGALKOT	110	KONNUR-NAVALGUND	NAVALGUND_110	17:43	17:57	0:14	HAND TRIPPED
253	22-Nov-18	BAGALKOT	110	110/11KV, HV2	BHUTNAL_110	1:08	1:10	0:02	TRANSFORMER FAULT
254	22-Nov-18	BAGALKOT	110	110/11KV, HV2	BHUTNAL_110	1:13	1:15	0:02	TRANSFORMER FAULT
255	22-Nov-18	BAGALKOT	220	NAGJHARI2-HUBLI	HUBLI_220	12:49	13:30	0:41	LINE FAULT
256	22-Nov-18	BAGALKOT	110	INDIAN SUGAR-CHADCHAN	CHADCHAN_110	7:30	7:31	0:01	LINE FAULT
257	22-Nov-18	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	12:10	13:48	1:38	HAND TRIPPED
258	22-Nov-18	BAGALKOT	220	MAHALINGAPUR2-VAJRAMATTI	VAJRAMATTI_220	13:12	14:21	1:09	LINE CLEAR AVAILED
259	22-Nov-18	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	17:59	18:08	0:09	LINE CLEAR AVAILED
260	22-Nov-18	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	18:27	19:15	0:48	HAND TRIPPED
261	22-Nov-18	BAGALKOT	110	SIRSI-KUMTA2	KUMTA_110	18:27	19:17	0:50	HAND TRIPPED
262	22-Nov-18	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	13:25	13:54	0:29	HAND TRIPPED
263	22-Nov-18	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	15:20	16:53	1:33	HAND TRIPPED
264	22-Nov-18	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	6:56	7:04	0:07	LINE FAULT
265	22-Nov-18	BANGALORE	220	HV2	CHINTAMANI 220	15:43	17:38	1:54	TRANSFORMER FAULT
266	22-Nov-18	BANGALORE	220	HV2	CHINTAMANI 220	18:01	18:23	0:22	TRANSFORMER FAULT
267	22-Nov-18	BANGALORE	66	VR DODDI - SOMANAHALLI 220	VR DODDI	12:49	13:04	0:15	LOAD CHANGE OVER
268	22-Nov-18	BANGALORE	66	VR DODDI - SOMANAHALLI 220	VR DODDI	17:53	17:59	0:05	LOAD CHANGE OVER
269	22-Nov-18	BANGALORE	220	HV2	TK HALLI 220	15:03	17:32	2:28	LINE CLEAR AVAILED
270	22-Nov-18	BANGALORE	66	TK HALLI 220 - IGGALURU	IGGALURU, AKKURMOLE	15:01	17:33	2:32	MAIN SUPPLY FAILURE
271	22-Nov-18	BANGALORE	66	TK HALLI 220 - MANDYA 1 & 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA, K HONALGERE	15:02	17:33	2:30	MAIN SUPPLY FAILURE
272	22-Nov-18	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	15:01	17:36	2:35	MAIN SUPPLY FAILURE
273	22-Nov-18	BANGALORE	66	HV1	TK HALLI 220	15:01	17:44	2:43	MAIN SUPPLY FAILURE
274	22-Nov-18	BANGALORE	66	TK HALLI 220 - SHIMSHA 1	TK HALLI 220	15:01	17:33	2:32	MAIN SUPPLY FAILURE
275	22-Nov-18	BANGALORE	66	TK HALLI 220 - SHIMSHA 2	TK HALLI 220	15:01	17:33	2:32	MAIN SUPPLY FAILURE
276	22-Nov-18	BANGALORE	66	TK HALLI 220 - LIMVALLI	TK HALLI 220	15:01	17:33	2:32	MAIN SUPPLY FAILURE
277	22-Nov-18	BANGALORE	66	SRS PEENYA 220 - WIDIA	WIDIA, WIDIA (EHT), MEI LAYOUT	12:21	14:27	2:06	LINE FAULT
278	22-Nov-18	BANGALORE	66	HV1	SOUTH CITY	12:05	12:30	0:24	LINE CLEAR AVAILED
279	22-Nov-18	BANGALORE	66	HEBBAL 220 - BANASWADI	BANASWADI	23:20	23:35	0:14	LINE FAULT
280	22-Nov-18	GULBARGA	220	KUSTAGI-SUZLONWIND2	KUSTAGI_220	0:00	10:54	10:54	LINE FAULT
281	22-Nov-18	GULBARGA	220	ITTAGI-ESPLSLR	ITTAGI_220	16:53	17:25	0:32	LINE FAULT
282	22-Nov-18	GULBARGA	220	ITTAGI-VESTAS(HARAKNAL)	ITTAGI_220	17:05	17:15	0:10	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
283	22-Nov-18	GULBARGA	220	LINGAPUR-KUSTAGI	KUSTAGI_220	0:00	20:04	20:04	LINE FAULT
284	22-Nov-18	GULBARGA	220	LINGAPUR-KUSTAGI	KUSTAGI_220	20:06	23:59	3:53	LINE FAULT
285	22-Nov-18	GULBARGA	110	HV3	KUSTAGI_220	9:57	10:07	0:10	TRANSFORMER FAULT
286	22-Nov-18	GULBARGA	110	HV3	KUSTAGI_220	13:08	15:52	2:44	TRANSFORMER FAULT
287	22-Nov-18	GULBARGA	110	HV2	BHALKI_110	11:50	12:45	0:55	LINE CLEAR AVAILED
288	22-Nov-18	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGRAGAON_110,DI GGI_110	18:36	18:41	0:05	LINE FAULT
289	22-Nov-18	GULBARGA	66	HV1	UPANAYAKANAHALLI_66	15:30	15:54	0:24	LINE CLEAR AVAILED
290	22-Nov-18	GULBARGA	66	HV2	UPANAYAKANAHALLI_66	0:00	15:53	15:53	LINE CLEAR AVAILED
291	22-Nov-18	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	10:19	15:39	5:20	LINE CLEAR AVAILED
292	22-Nov-18	HASSAN	220	HV1	SHIRALKOPPA_220	11:15	12:14	0:59	LINE CLEAR AVAILED
293	22-Nov-18	HASSAN	110	LV1	SHIRALKOPPA_220	11:15	12:14	0:59	LINE CLEAR AVAILED
294	22-Nov-18	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	10:36	12:17	1:41	LINE CLEAR AVAILED
295	22-Nov-18	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	10:37	12:14	1:37	LINE CLEAR AVAILED
296	22-Nov-18	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	10:37	12:16	1:39	LINE CLEAR AVAILED
297	22-Nov-18	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	10:04	12:29	2:25	LINE CLEAR AVAILED
298	22-Nov-18	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	15:29	16:01	0:32	MAIN SUPPLY FAILURE
299	22-Nov-18	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	10:07	12:35	2:28	LINE CLEAR AVAILED
300	22-Nov-18	HASSAN	110	HV2	ANANDAPURA_110	11:37	12:01	0:24	LINE CLEAR AVAILED
301	22-Nov-18	HASSAN	110	HV1	ESSUR_110	15:00	17:25	2:25	LINE CLEAR AVAILED
302	22-Nov-18	HASSAN	110	HV3	GURUVAYANAKERE_110	10:44	14:13	3:29	LINE CLEAR AVAILED
303	22-Nov-18	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	10:03	12:30	2:27	LINE CLEAR AVAILED
304	22-Nov-18	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	15:30	16:00	0:30	MAIN SUPPLY FAILURE
305	22-Nov-18	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	15:32	17:37	2:05	MAIN SUPPLY FAILURE
306	22-Nov-18	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	15:30	16:40	1:10	MAIN SUPPLY FAILURE
307	22-Nov-18	HASSAN	110	KADUR-YGTI	KADUR_220	15:16	18:39	3:23	LINE CLEAR AVAILED
308	22-Nov-18	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	10:25	14:00	3:35	NBFC ISSUED
309	22-Nov-18	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	13:07	13:13	0:06	HAND TRIPPED
310	22-Nov-18	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	15:29	18:57	3:28	LINE FAULT
311	22-Nov-18	HASSAN	110	HV1	KEMAR_220	10:53	17:11	6:18	LINE CLEAR AVAILED
312	22-Nov-18	HASSAN	110	HV2	NAVUNDA_110	11:06	14:01	2:55	LINE CLEAR AVAILED
313	22-Nov-18	HASSAN	110	HV1	SAGARA_110	10:10	11:10	1:00	LINE CLEAR AVAILED
314	22-Nov-18	HASSAN	110	HV3	SAGARA_110	10:10	11:10	1:00	LINE CLEAR AVAILED
315	22-Nov-18	HASSAN	110	HV2	SORABA_110	7:02	8:12	1:10	LINE CLEAR AVAILED
316	22-Nov-18	HASSAN	110	HV2	SORABA_110	11:15	12:44	1:29	LINE CLEAR AVAILED
317	22-Nov-18	HASSAN	110	HV2	SORABA_110	13:11	13:53	0:42	LINE CLEAR AVAILED
318	22-Nov-18	HASSAN	110	HV2	SORABA_110	14:05	14:38	0:33	LINE CLEAR AVAILED
319	22-Nov-18	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	10:09	10:12	0:03	HAND TRIPPED
320	22-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	10:06	10:12	0:06	HAND TRIPPED
321	22-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	10:48	11:24	0:36	TRANSFORMER FAULT
322	22-Nov-18	HASSAN	66	HV1	BYACHANAHALLI_66	13:59	15:03	1:04	LINE CLEAR AVAILED
323	22-Nov-18	HASSAN	66	HV1	DODDAKADANUR_110	11:32	12:34	1:02	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
324	22-Nov-18	HASSAN	66	HV1	HAGARE_66	12:41	19:04	6:23	LINE CLEAR AVAILED
325	22-Nov-18	HASSAN	66	HV2	KIADB_66	14:47	16:52	2:05	LINE CLEAR AVAILED
326	22-Nov-18	MYSORE	66	HV1	ANEGOLA	15:28	15:39	0:10	HAND TRIPPED
327	22-Nov-18	MYSORE	66	KM DODDI-TK HALLI	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 K_HONNALGERE_66	15:41	17:45	2:03	HAND TRIPPED
328	22-Nov-18	MYSORE	66	HV2	MEGALAPURA_66	13:31	14:00	0:29	LINE CLEAR AVAILED
329	22-Nov-18	MYSORE	66	HV1	NAGAMANGALA_66	12:15	12:51	0:36	LINE CLEAR AVAILED
330	22-Nov-18	MYSORE	66	PANYADAHUNDI-DEVNUR(NGUD)	KARYA_66	7:38	7:51	0:12	LINE FAULT
331	22-Nov-18	MYSORE	66	SFC SIVA-MEGHALAPURA	BGPURA_66 CHIDRAVALI_66	6:36	6:48	0:11	LINE FAULT
332	22-Nov-18	TUMKUR	220	TR-1 & TR-2(HV SIDE)	ANCHEPALYA_220	18:48	18:54	0:06	LINE CLEAR AVAILED
333	22-Nov-18	TUMKUR	220	ANCHEPALYA 220kV- NElMANGALA 2	ANCHEPALYA_220	18:35	18:51	0:16	LINE CLEAR AVAILED
334	22-Nov-18	TUMKUR	220	CHITRADURGA 220kV- THALLAK	THALLAKK_220	17:47	18:50	1:03	LINE FAULT
335	22-Nov-18	TUMKUR	220	TR-1 (HV SIDE)	NEELAGUNDA_220	10:45	12:41	1:55	LINE CLEAR AVAILED
336	22-Nov-18	TUMKUR	110	TR-1 & TR-2(HV SIDE)	TURUVEKERE_110	12:25	14:07	1:42	HAND TRIPPED
337	22-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	17:26	19:03	1:36	LINE CLEAR AVAILED
338	22-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	17:27	19:03	1:36	LINE CLEAR AVAILED
339	22-Nov-18	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	17:27	19:03	1:36	LINE CLEAR AVAILED
340	22-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	17:27	19:03	1:36	LINE CLEAR AVAILED
341	22-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	17:26	19:03	1:36	LINE CLEAR AVAILED
342	22-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- KUNIGAL	KUNIGAL_66	17:27	19:03	1:36	LINE CLEAR AVAILED
343	22-Nov-18	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	18:51	18:54	0:03	LINE CLEAR AVAILED
344	22-Nov-18	TUMKUR	66	TR-2(LV SIDE)	ANCHEPALYA_220	18:48	18:58	0:10	LINE CLEAR AVAILED
345	22-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	17:26	19:03	1:36	LINE CLEAR AVAILED
346	22-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR	YEDIYUR_66	11:15	11:25	0:10	LINE FAULT
347	22-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR	YEDIYUR_66	17:27	19:03	1:36	LINE CLEAR AVAILED
348	22-Nov-18	TUMKUR	66	TR-1	CHIKKABANAGERE_66	13:11	13:51	0:39	HAND TRIPPED
349	22-Nov-18	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	9:59	15:47	5:48	MAIN SUPPLY FAILURE
350	22-Nov-18	TUMKUR	66	TR-1	DEVARAHALLI_66	9:59	15:47	5:48	MAIN SUPPLY FAILURE
351	22-Nov-18	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:55	10:07	0:12	LINE FAULT
352	22-Nov-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:12	17:40	9:28	HAND TRIPPED
353	22-Nov-18	TUMKUR	66	TR-1	HARIHAR_66	11:50	13:12	1:21	LINE CLEAR AVAILED
354	22-Nov-18	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	17:01	22:24	5:23	LINE CLEAR AVAILED
355	22-Nov-18	TUMKUR	66	TR-2	HONNALI_66	17:21	17:35	0:13	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
356	22-Nov-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	8:58	15:31	6:33	LINE CLEAR AVAILED
357	22-Nov-18	TUMKUR	66	TR-2	KUKKAWADA_66	8:40	8:53	0:12	TRANSFORMER FAULT
358	22-Nov-18	TUMKUR	66	TR-1 & TR-2	KUNIGAL_66	13:21	13:33	0:11	LINE CLEAR AVAILED
359	22-Nov-18	TUMKUR	66	TR-1(LV SIDE)	NEELAGUNDA_220	10:45	12:41	1:56	HAND TRIPPED
360	22-Nov-18	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66, PALLAGATTE_66, UCHCHANGIDURGA_66	10:44	10:49	0:05	HAND TRIPPED
361	22-Nov-18	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:19	10:38	0:18	LINE FAULT
362	22-Nov-18	TUMKUR	66	TR-2	TUMKUR_66	14:05	15:37	1:31	LINE CLEAR AVAILED
363	23-Nov-18	BAGALKOT	220	220/110,HV1	ATHANI_220	9:56	12:06	2:10	LINE CLEAR AVAILED
364	23-Nov-18	BAGALKOT	220	220/110,HV2	ATHANI_220	12:42	14:27	1:45	LINE CLEAR AVAILED
365	23-Nov-18	BAGALKOT	110	220/110,LV1	ATHANI_220	11:08	12:40	1:32	LINE CLEAR AVAILED
366	23-Nov-18	BAGALKOT	110	BAGALKOT -BAGALKOT 2 (F2)	BAGALKOT_110	6:21	6:31	0:10	MAIN SUPPLY FAILURE
367	23-Nov-18	BAGALKOT	220	BELGAUM 220-CHIKKODI 1	BELGAUM_220	0:00	7:08	7:08	HAND TRIPPED
368	23-Nov-18	BAGALKOT	110	110/11KV,HV4	BAILHONGAL_110	7:01	16:11	9:10	TRANSFORMER FAULT
369	23-Nov-18	BAGALKOT	110	L1-KIADB-BHUTANAL	BHUTANAL_110	12:11	12:16	0:05	LINE FAULT
370	23-Nov-18	BAGALKOT	110	110/11KV ,HV2	BANAHATTI_110	12:04	13:27	1:23	LINE CLEAR AVAILED
371	23-Nov-18	BAGALKOT	110	GADAG220-DAMBAL 2	DAMBAL_110	12:22	14:07	1:45	LINE CLEAR AVAILED
372	23-Nov-18	BAGALKOT	110	HIREBEVANUR-SHIVKUMAR SUGARS	SHIVKUMAR SUGARS_110	17:39	18:39	1:00	LINE FAULT
373	23-Nov-18	BAGALKOT	110	110/11KV,HV1	KHANAPUR_110	11:36	13:16	1:40	LINE CLEAR AVAILED
374	23-Nov-18	BAGALKOT	110	110/11,HV1	KUDACHI_220	14:18	14:25	0:07	TRANSFORMER FAULT
375	23-Nov-18	BAGALKOT	400	400/220/33,ICT2	DHONI_400	17:19	23:59	6:40	TRANSFORMER FAULT
376	23-Nov-18	BAGALKOT	110	110/11KV,HV2	UGARKHUD_110	10:46	10:52	0:06	HAND TRIPPED
377	23-Nov-18	BAGALKOT	110	110/11KV,HV2	SHIROL_110	9:21	9:27	0:06	TRANSFORMER FAULT
378	23-Nov-18	BAGALKOT	110	110/11KV,HV1	SANKESHWAR_110	12:50	13:00	0:10	HAND TRIPPED
379	23-Nov-18	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	10:59	11:27	0:28	HAND TRIPPED
380	23-Nov-18	BAGALKOT	110	110/33KV,HV3	SALAHALLI_110	16:24	17:36	1:12	HAND TRIPPED
381	23-Nov-18	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	11:11	15:43	4:32	LINE CLEAR AVAILED
382	23-Nov-18	BAGALKOT	110	110/11KV,HV1	NARAGAL_110	12:32	13:42	1:10	TRANSFORMER FAULT
383	23-Nov-18	BAGALKOT	110	110/11KV,HV2	MRUTHYUNJAY NAGAR_110	15:28	15:38	0:10	TRANSFORMER FAULT
384	23-Nov-18	BAGALKOT	110	BELGAUM SOLAR-MAMADAPUR(B)	MAMADAPUR(B)_110	18:04	21:30	3:26	HAND TRIPPED
385	23-Nov-18	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	6:24	6:41	0:17	LINE FAULT
386	23-Nov-18	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	7:01	7:14	0:13	LINE FAULT
387	23-Nov-18	BANGALORE	66	HV2	CHAKAVELU	14:13	14:19	0:06	TRANSFORMER FAULT
388	23-Nov-18	BANGALORE	66	DEVANAHALLI - DB PURA 220	DEVANAHALLI	16:45	16:56	0:11	LINE FAULT
389	23-Nov-18	BANGALORE	220	LV2	DB PURA 220	22:10	22:35	0:25	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
390	23-Nov-18	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	22:10	22:32	0:22	MAIN SUPPLY FAILURE
391	23-Nov-18	BANGALORE	66	DB PURA 220 - DEVANAHALLI 1	DEVANAHALLI	16:45	16:57	0:11	LINE FAULT
392	23-Nov-18	BANGALORE	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	8:20	8:34	0:14	LINE FAULT
393	23-Nov-18	BANGALORE	66	DB PURA 220 - TUBUGERE	TUBUGERE	22:10	22:32	0:22	MAIN SUPPLY FAILURE
394	23-Nov-18	BANGALORE	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	22:10	22:32	0:22	MAIN SUPPLY FAILURE
395	23-Nov-18	BANGALORE	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	15:06	18:08	3:01	LINE CLEAR AVAILED
396	23-Nov-18	BANGALORE	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	22:10	22:31	0:21	MAIN SUPPLY FAILURE
397	23-Nov-18	BANGALORE	66	GUNDAMGERE - DB PURA 220	GUNDAMGERE	15:10	15:21	0:11	LOAD CHANGEOVER
398	23-Nov-18	BANGALORE	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR	15:04	16:06	1:02	LINE CLEAR AVAILED
399	23-Nov-18	BANGALORE	66	HV1	HULLENAHALLI	10:54	12:25	1:30	LINE CLEAR AVAILED
400	23-Nov-18	BANGALORE	66	MALUR 220 - HOSKOTE 1	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	22:43	22:57	0:13	LINE FAULT
401	23-Nov-18	BANGALORE	66	TUBUGERE - DB PURA 220	TUBUGERE	8:20	8:28	0:08	LINE FAULT
402	23-Nov-18	BANGALORE	66	HV2	YELAHANKA 220	19:00	19:07	0:06	TRANSFORMER FAULT
403	23-Nov-18	BANGALORE	66	HV2	YELAHANKA 220	19:07	19:15	0:08	TRANSFORMER FAULT
404	23-Nov-18	BANGALORE	66	AUSTIN TOWN - KORAMANGALA	KORAMANGALA	13:52	14:23	0:30	LINE FAULT
405	23-Nov-18	BANGALORE	66	HV2	KORAMANGALA	13:52	14:23	0:30	MAIN SUPPLY FAILURE
406	23-Nov-18	BANGALORE	66	HV2	HEBBAL 220	12:41	12:50	0:08	LINE CLEAR AVAILED
407	23-Nov-18	BANGALORE	66	KADUGODI - ARMY WELFARE ORGANIZATION	ARMY WELFARE ORGANIZATION, ALUMBIC GLASS (EHT), KONDASPURA	16:36	17:16	0:40	LINE FAULT
408	23-Nov-18	BANGALORE	66	HV2	KUMBALAGODU	13:55	14:15	0:19	LINE CLEAR AVAILED
409	23-Nov-18	BANGALORE	220	SRS PEENYA 220 - NELAMANGALA 2	SRS PEENYA 220	15:20	22:36	7:16	LINE FAULT
410	23-Nov-18	BANGALORE	66	HV1	BANGARPET	7:15	7:22	0:07	TRANSFORMER FAULT
411	23-Nov-18	GULBARGA	220	KUSTAGI-BUSCOUPLER	KUSTAGI_220	9:30	9:50	0:20	LINE FAULT
412	23-Nov-18	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	16:35	16:45	0:10	LINE FAULT
413	23-Nov-18	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	16:58	17:00	0:02	LINE FAULT
414	23-Nov-18	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	17:13	17:21	0:08	LINE FAULT
415	23-Nov-18	GULBARGA	220	BTPS-LINGAPUR	LINGAPUR_220	13:45	17:30	3:45	LINE FAULT
416	23-Nov-18	GULBARGA	220	KUSHTAGI-LINGAPUR	KUSTAGI_220	0:00	18:34	18:34	LINE FAULT
417	23-Nov-18	GULBARGA	110	HV3	DEODURGA_110	11:49	13:30	1:41	LINE CLEAR AVAILED
418	23-Nov-18	GULBARGA	110	KUSTAGI-BUSCOUPLER	KUSTAGI_220	9:30	9:50	0:20	LINE FAULT
419	23-Nov-18	GULBARGA	110	SINDHANOOR220-PGLR_WIND	SIDHANOOR_220	1:52	2:36	0:44	LINE FAULT
420	23-Nov-18	GULBARGA	110	HUMNABAD220-SASTHAPUR	RAJESHWAR_110,SASTHAPUR_110,MAN THAL_110	11:14	13:41	2:27	LINE CLEAR AVAILED
421	23-Nov-18	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	2:10	2:18	0:08	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
422	23-Nov-18	GULBARGA	66	ITTAGI220-BENNEHALLI	BENNEHALLI_66,KOTTUR_66,UJJANI_66	11:20	11:45	0:25	LINE FAULT
423	23-Nov-18	GULBARGA	66	ITTAGI220-RENEWSOLAR2_IPP	ITTAGI_220	11:21	11:39	0:18	LINE FAULT
424	23-Nov-18	GULBARGA	66	LV2	ITTAGI_220	17:42	17:57	0:15	TRANSFORMER FAULT
425	23-Nov-18	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALI_66,GIRIYAPURA_66,SOVE NAHALLI_66, MAGALA_66	17:42	18:03	0:21	LINE FAULT
426	23-Nov-18	GULBARGA	66	ITTAGGI-RENEWSOLAR2	ITTAGI_220	17:42	18:16	0:34	LINE FAULT
427	23-Nov-18	GULBARGA	66	ITTAGGI-BENNAHALLI	KOTTUR_66,UJJANI_66,BENNAHALLI_66	17:42	18:00	0:18	LINE FAULT
428	23-Nov-18	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	10:32	12:21	1:49	LINE CLEAR AVAILED
429	23-Nov-18	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	12:56	13:21	0:25	LINE FAULT
430	23-Nov-18	HASSAN	220	PUTTUR-KEMAR1	PUTTUR_220	10:34	12:21	1:47	LINE CLEAR AVAILED
431	23-Nov-18	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	12:27	14:49	2:22	LINE CLEAR AVAILED
432	23-Nov-18	HASSAN	220	SSHRAVITY-IRISI 2	SHARAVATY_GEN	11:10	15:44	4:34	LINE CLEAR AVAILED
433	23-Nov-18	HASSAN	110	KADUR-YGTI	KADUR_220	8:52	14:43	5:51	LINE CLEAR AVAILED
434	23-Nov-18	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	20:15	21:38	1:23	LINE FAULT
435	23-Nov-18	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	2:53	3:10	0:17	MAIN SUPPLY FAILURE
436	23-Nov-18	HASSAN	110	HV2	MOODAB	2:53	3:10	0:17	MAIN SUPPLY FAILURE
437	23-Nov-18	HASSAN	110	MOODAB-SOHAM1	MOODAB	2:53	3:10	0:17	MAIN SUPPLY FAILURE
438	23-Nov-18	HASSAN	110	SMOODAB-OHAM2	MOODAB	2:53	3:10	0:17	MAIN SUPPLY FAILURE
439	23-Nov-18	HASSAN	110	SORABA-SHR220	SORABA_110	10:28	10:32	0:04	HAND TRIPPED
440	23-Nov-18	HASSAN	66	HV1	ALDUR_66	13:00	13:42	0:42	LINE CLEAR AVAILED
441	23-Nov-18	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMANGALUR_66	11:11	12:19	1:08	LINE CLEAR AVAILED
442	23-Nov-18	HASSAN	66	HV1	HASSN_66	9:10	14:30	5:20	LINE CLEAR AVAILED
443	23-Nov-18	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	17:22	17:31	0:09	LINE FAULT
444	23-Nov-18	HASSAN	66	HV2	SATHENAHALLY_66	6:10	6:18	0:08	TRANSFORMER FAULT
445	23-Nov-18	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	17:26	17:38	0:12	HAND TRIPPED
446	23-Nov-18	MYSORE	66	HV2	AKKIHBBAL_66	16:02	17:43	1:40	LINE CLEAR AVAILED
447	23-Nov-18	MYSORE	66	HV1	KOPPA_66	15:42	16:04	0:21	TRANSFORMER FAULT
448	23-Nov-18	MYSORE	66	HV2	KOPPA_66	15:42	16:04	0:21	TRANSFORMER FAULT
449	23-Nov-18	MYSORE	66	HV2	NAGAMANGALA_66	15:37	15:57	0:20	LINE CLEAR AVAILED
450	23-Nov-18	MYSORE	66	HV2	NANJANGUDU_66	9:59	10:11	0:11	TRANSFORMER FAULT
451	23-Nov-18	MYSORE	66	HV2	NANJANGUDU_66	13:10	15:19	2:08	HAND TRIPPED
452	23-Nov-18	MYSORE	66	HV1	PGPALYA_66	13:35	13:50	0:15	LINE CLEAR AVAILED
453	23-Nov-18	MYSORE	66	HV1	PGPALYA_66	13:52	14:14	0:21	LINE CLEAR AVAILED
454	23-Nov-18	MYSORE	66	HV1	PGPALYA_66	14:14	14:54	0:39	LINE CLEAR AVAILED
455	23-Nov-18	MYSORE	66	HV2	PGPALYA_66	13:00	13:25	0:25	LINE CLEAR AVAILED
456	23-Nov-18	MYSORE	66	PG PALYA-MADHUVANAHALLI	PGPALYA_66	14:46	14:52	0:06	LINE FAULT
457	23-Nov-18	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66	4:36	4:48	0:11	LINE FAULT
458	23-Nov-18	TUMKUR	220	CHITRADURGA 220kV- THALLAK	THALLAKK_220	17:39	17:53	0:14	LINE FAULT
459	23-Nov-18	TUMKUR	110	TR-1 (HV SIDE)	GUBBI_110	16:23	16:43	0:20	LINE CLEAR AVAILED
460	23-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR	YEDIYUR_66	15:10	15:23	0:12	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
461	23-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	13:07	13:17	0:10	LINE FAULT
462	23-Nov-18	TUMKUR	66	TR-2(HV2)	ANTHRASANAHALLI_220	12:37	14:07	1:30	LINE CLEAR AVAILED
463	23-Nov-18	TUMKUR	66	TR-2(HV2)	ANTHRASANAHALLI_220	16:33	16:45	0:11	LINE CLEAR AVAILED
464	23-Nov-18	TUMKUR	66	TR-2	BUKKAPATNA_66	8:33	10:58	2:24	LINE CLEAR AVAILED
465	23-Nov-18	TUMKUR	66	TR-2	CHIKKABANAGERE_66	11:53	12:11	0:17	LINE CLEAR AVAILED
466	23-Nov-18	TUMKUR	66	TR-2	CHIKKABANAGERE_66	13:02	13:55	0:52	LINE CLEAR AVAILED
467	23-Nov-18	TUMKUR	66	TR-2	CHIKKABANAGERE_66	15:04	15:32	0:27	LINE CLEAR AVAILED
468	23-Nov-18	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	13:42	14:01	0:19	HAND TRIPPED
469	23-Nov-18	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	13:42	14:01	0:19	HAND TRIPPED
470	23-Nov-18	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	13:23	13:59	0:35	HAND TRIPPED
471	23-Nov-18	TUMKUR	66	TR-1(HV SIDE)	DAVANGERE_SRS_220	13:06	13:11	0:05	HAND TRIPPED
472	23-Nov-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:27	17:36	9:08	HAND TRIPPED
473	23-Nov-18	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	1:01	1:07	0:05	LINE FAULT
474	23-Nov-18	TUMKUR	66	TR-2	HONNALI_66	2:10	2:19	0:08	TRANSFORMER FAULT
475	23-Nov-18	TUMKUR	66	TR-1	RANGANATHAPURA_66	15:09	15:55	0:46	LINE CLEAR AVAILED
476	23-Nov-18	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	7:23	8:27	1:03	LINE FAULT
477	23-Nov-18	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	10:49	12:10	1:20	LINE FAULT
478	24-Nov-18	BAGALKOT	220	220/110KV,HV-1&LV-1	GADAG_220	10:29	18:06	7:37	HAND TRIPPED
479	24-Nov-18	BAGALKOT	110	GOPANAKOPPA-GADAG ROAD	GADAG ROAD _110	9:15	17:55	8:40	LINE CLEAR AVAILED
480	24-Nov-18	BAGALKOT	110	KAGAWAD-SHIRAGUPPI SUGAR	KAGAWAD_110	16:01	16:07	0:06	LINE FAULT
481	24-Nov-18	BAGALKOT	110	BIDNAL 220-GADAG ROAD	GADAG ROAD _110	10:04	16:07	6:03	NBFC ISSUED
482	24-Nov-18	BAGALKOT	110	KAGAWADA-UGARKHUD	UGARKHUD_110	15:12	15:31	0:19	LINE FAULT
483	24-Nov-18	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:16	14:24	2:08	LINE CLEAR AVAILED
484	24-Nov-18	BAGALKOT	110	110/11KV, HV1	MAREGUDDI_110	10:04	12:43	2:39	LINE CLEAR AVAILED
485	24-Nov-18	BAGALKOT	110	110/33KV, HV3	MAMDAPUR(B)_110	9:19	9:40	0:21	LINE CLEAR AVAILED
486	24-Nov-18	BAGALKOT	400	400/220/33,ICT2	DHONI_400	0:00	16:52	16:52	LINE CLEAR AVAILED
487	24-Nov-18	BANGALORE	66	HV1	BANGARPET	10:59	11:11	0:12	TRANSFORMER FAULT
488	24-Nov-18	BANGALORE	66	HV1	CHANNAPATNA	11:13	11:20	0:07	LINE CLEAR AVAILED
489	24-Nov-18	BANGALORE	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	10:24	11:59	1:34	LINE CLEAR AVAILED
490	24-Nov-18	BANGALORE	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	10:24	11:59	1:34	LINE CLEAR AVAILED
491	24-Nov-18	BANGALORE	66	GUNDAMGERE - GOWRIBIDANUR 220	GUNDAMGERE	13:05	13:20	0:15	LOAD CHANGEOR
492	24-Nov-18	BANGALORE	66	HV1	KOLAR 220	8:40	9:01	0:21	TRANSFORMER FAULT
493	24-Nov-18	BANGALORE	66	HV2	SUGUTUR	15:15	15:33	0:17	TRANSFORMER FAULT
494	24-Nov-18	BANGALORE	66	HV2	YELAHANKA 220	13:10	13:40	0:29	TRANSFORMER FAULT
495	24-Nov-18	BANGALORE	66	KANASWADI - YELAHANKA 220	KANASWADI	13:07	13:15	0:08	LOAD CHANGEOR
496	24-Nov-18	BANGALORE	66	KANASWADI -DB PURA 220	KANASWADI	13:16	13:20	0:04	LOAD CHANGEOR
497	24-Nov-18	BANGALORE	66	HV1	BTM 4TH PHASE	9:54	10:00	0:05	TRANSFORMER FAULT
498	24-Nov-18	BANGALORE	66	HAL 220 - ADUGODI 1	LEELA VENTURE	10:45	10:46	0:01	LOAD CHANGEOR
499	24-Nov-18	BANGALORE	66	MATHIKERE - GOKULA	MATHIKERE	6:50	6:55	0:05	LOAD CHANGEOR
500	24-Nov-18	BANGALORE	66	HV2	RMV	10:46	10:50	0:04	TRANSFORMER FAULT
501	24-Nov-18	BANGALORE	220	HOODY 220 - RAILWAYS 2 (EHT)	RAILWAYS 2 (EHT)	14:32	16:32	2:00	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
502	24-Nov-18	BANGALORE	66	VG DODDI - ANCHEPALYA 220	VG DODDI	9:29	12:00	2:31	MAIN SUPPLY FAILURE
503	24-Nov-18	GULBARGA	220	LINGAPUR-BMMISPAT	BMMISPAT_IPP	10:06	14:02	3:56	LINE CLEAR AVAILED
504	24-Nov-18	GULBARGA	220	HV1, HV2	HALBURGA_220	12:03	12:11	0:08	TRANSFORMER FAULT
505	24-Nov-18	GULBARGA	110	HV3	SINDHANOOR_110	11:31	12:14	0:43	LINE CLEAR AVAILED
506	24-Nov-18	GULBARGA	110	RAICHUR220-SINDHANOOR1	ALKOD_110,BYAGAWAT_110,SIRWAR_110,VALKAMDINNI_110	1:30	6:48	5:18	LINE FAULT
507	24-Nov-18	GULBARGA	110	RAICHUR220-SINDHANOOR1	ALKOD_110,BYAGAWAT_110,SIRWAR_110,VALKAMDINNI_110	18:41	18:47	0:06	LINE FAULT
508	24-Nov-18	GULBARGA	110	RAICHUR220-SINDHANOOR1	ALKOD_110,BYAGAWAT_110,SIRWAR_110,VALKAMDINNI_110	23:25	23:32	0:07	LINE FAULT
509	24-Nov-18	GULBARGA	66	MUNIRABAD220-MSDLINE	HANASI_66	18:39	18:47	0:08	LINE FAULT
510	24-Nov-18	HASSAN	220	HV3	KAVOOR	10:35	14:45	4:10	LINE CLEAR AVAILED
511	24-Nov-18	HASSAN	220	SHRAVITY-SIRISI 2	SHRAVTY	10:45	15:17	4:32	LINE CLEAR AVAILED
512	24-Nov-18	HASSAN	110	GURUVA-KEMAR1	GURUVA	17:05	17:46	0:41	LINE FAULT
513	24-Nov-18	HASSAN	110	GURUVA-KEMAR2	GURUVA	17:05	17:45	0:40	LINE FAULT
514	24-Nov-18	HASSAN	110	HV1	HALADY1	9:44	10:30	0:46	LINE CLEAR AVAILED
515	24-Nov-18	HASSAN	110	HV1	HALADY1	11:32	12:21	0:49	LINE CLEAR AVAILED
516	24-Nov-18	HASSAN	110	HV1	HALADY1	16:19	17:01	0:42	LINE CLEAR AVAILED
517	24-Nov-18	HASSAN	110	HV2	HALADY1	9:45	10:31	0:46	LINE CLEAR AVAILED
518	24-Nov-18	HASSAN	110	HV2	HALADY1	16:19	17:01	0:42	LINE CLEAR AVAILED
519	24-Nov-18	HASSAN	110	KADUR-AJAMPURA	KADUR	16:00	18:21	2:21	LINE CLEAR AVAILED
520	24-Nov-18	HASSAN	110	KADUR-NGNHL	KADUR	10:17	13:19	3:02	LINE CLEAR AVAILED
521	24-Nov-18	HASSAN	110	KEMAR-Guruvykere1	KEMAR	17:05	17:47	0:42	LINE FAULT
522	24-Nov-18	HASSAN	110	KEMAR-Guruvykere2	KEMAR	17:05	17:46	0:41	LINE FAULT
523	24-Nov-18	HASSAN	110	HV1	KONAJE	10:33	10:44	0:11	LOAD CHANGE OVER
524	24-Nov-18	HASSAN	110	HV1	KONAJE	15:17	15:20	0:03	LOAD CHANGE OVER
525	24-Nov-18	HASSAN	110	HV2	KONAJE	10:33	15:20	4:47	LOAD CHANGE OVER
526	24-Nov-18	HASSAN	110	HV3	KONAJE	10:33	10:45	0:12	LOAD CHANGE OVER
527	24-Nov-18	HASSAN	110	HV3	KONAJE	15:17	15:20	0:03	LOAD CHANGE OVER
528	24-Nov-18	HASSAN	110	MSEZ-GSS31	MSEZ	12:35	12:50	0:15	LINE FAULT
529	24-Nov-18	HASSAN	110	HV1	SHIVAPU	12:07	12:51	0:44	LINE CLEAR AVAILED
530	24-Nov-18	HASSAN	66	HNPR2-HNPR1	HNPR2	10:29	12:12	1:43	LINE CLEAR AVAILED
531	24-Nov-18	MYSORE	66	HV1	CHINAKURALI_66	7:15	7:36	0:21	HAND TRIPPED
532	24-Nov-18	MYSORE	66	HANNUR-MADHUVANAHALLI 1	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	23:20	23:59	0:39	HAND TRIPPED
533	24-Nov-18	MYSORE	66	HANNUR-MADHUVANAHALLI 2	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	23:20	23:59	0:39	HAND TRIPPED
534	24-Nov-18	MYSORE	66	HANNUR-DODDINDUVADI	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	23:20	23:59	0:39	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
535	24-Nov-18	MYSORE	66	HANNUR-COWDALLI	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	23:20	23:59	0:39	HAND TRIPPED
536	24-Nov-18	MYSORE	66	KR PETE-KR PETE 2	KRPET_66 AKKIEBBAL_66 KIKKERI_66	13:33	13:43	0:10	LINE FAULT
537	24-Nov-18	MYSORE	66	HV2	MANDYA_66	10:32	11:45	1:12	LINE CLEAR AVAILED
538	24-Nov-18	MYSORE	66	HV1	RKNAGARA_66	10:32	14:23	3:51	LINE CLEAR AVAILED
539	24-Nov-18	MYSORE	66	HV1	SANTHESARAGUR_66	12:19	23:59	11:39	TRANSFORMER FAULT
540	24-Nov-18	MYSORE	66	TARIPURA-TUBINAKERE	TARIPURA_66	1:11	1:40	0:29	LINE FAULT
541	24-Nov-18	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	15:44	17:05	1:20	HAND TRIPPED
542	24-Nov-18	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	13:20	14:00	0:39	LINE CLEAR AVAILED
543	24-Nov-18	TUMKUR	66	ANTHRASANAHALI 220KV- KORA	KORA_66, THOVINAKERE_66	10:45	10:51	0:06	HAND TRIPPED
544	24-Nov-18	TUMKUR	66	TR-1	BAGUR_TMK_66	16:05	16:46	0:40	TRANSFORMER FAULT
545	24-Nov-18	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	9:36	9:47	0:10	LINE FAULT
546	24-Nov-18	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:08	12:18	0:10	LINE FAULT
547	24-Nov-18	TUMKUR	66	TR-2	HIREGUNTANUR_66	12:23	12:53	0:29	LINE CLEAR AVAILED
548	24-Nov-18	TUMKUR	66	TR-2	HONNALI_66	2:17	2:30	0:12	TRANSFORMER FAULT
549	24-Nov-18	TUMKUR	66	HULIYURDURGA- ANCHEPALYA	HULIYURDURGA_66	12:08	12:24	0:16	LINE CLEAR AVAILED
550	24-Nov-18	TUMKUR	66	TR-1	HULIYURDURGA_66	13:38	13:41	0:02	HAND TRIPPED
551	24-Nov-18	TUMKUR	66	TR-1	KATTIGE_66	10:00	10:10	0:09	TRANSFORMER FAULT
552	24-Nov-18	TUMKUR	66	TR-1	MYLANAHALLI_66	10:16	11:34	1:17	LINE CLEAR AVAILED
553	24-Nov-18	TUMKUR	66	TR-1	NAGALMADIKE_66	12:11	13:05	0:53	LINE CLEAR AVAILED
554	24-Nov-18	TUMKUR	66	TR-2	NAGALMADIKE_66	11:50	13:05	1:15	LINE CLEAR AVAILED
555	24-Nov-18	TUMKUR	66	NAGALAMADIKE- SUNDARRAISOLAR_IPP_66	SUNDARRAISOLAR_IPP_66	12:11	13:05	0:54	LOAD CURTAILMENT
556	24-Nov-18	TUMKUR	66	NEELAGUNDA 220kV- HALUVAGALU	HALUVAGALU_66	7:02	17:05	10:03	LINE CLEAR AVAILED
557	24-Nov-18	TUMKUR	66	PAVAGADA-MIDIGESHI	PAVAGADA_66, VENKATAPURA_66	11:36	11:50	0:13	LINE FAULT
558	24-Nov-18	TUMKUR	66	TR-1	PAVAGADA_66	13:52	14:08	0:15	LINE CLEAR AVAILED
559	24-Nov-18	TUMKUR	66	SIRA- MADHUGIRI 2	SS	12:42	13:15	0:32	HAND TRIPPED
560	24-Nov-18	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	7:44	7:57	0:12	LINE FAULT
561	25-Nov-18	BAGALKOT	110	110/11KV,HV-1&2		10:05	12:26	2:21	LINE CLEAR AVAILED
562	25-Nov-18	BAGALKOT	110	BIJAPUR 220-BAGEWADI	BIJAPUR_220	14:06	14:18	0:12	LINE FAULT
563	25-Nov-18	BAGALKOT	110	110/11KV,HV-2	ITANAL_110	16:24	17:32	1:08	LINE CLEAR AVAILED
564	25-Nov-18	BAGALKOT	220	SHARAVATTI 1-SIRSI	SIRSI_220	10:32	19:51	9:19	LINE CLEAR AVAILED
565	25-Nov-18	BAGALKOT	220	SHARAVATTI 2-SIRSI	SIRSI_220	10:32	19:52	9:20	LINE CLEAR AVAILED
566	25-Nov-18	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	10:33	19:42	9:09	LINE CLEAR AVAILED
567	25-Nov-18	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	10:34	19:45	9:11	LINE CLEAR AVAILED
568	25-Nov-18	BAGALKOT	110	110/11KV, HV2	SHIROL_110	13:13	13:46	0:33	LINE CLEAR AVAILED
569	25-Nov-18	BAGALKOT	110	SATTI SUGARS-PG HUNSYAL	PG HUNSYAL_110	15:20	15:26	0:06	LINE FAULT
570	25-Nov-18	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	10:34	19:44	9:10	LINE CLEAR AVAILED
571	25-Nov-18	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	10:34	19:46	9:12	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
572	25-Nov-18	BANGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	10:13	14:26	4:12	LINE CLEAR AVAILED
573	25-Nov-18	BANGALORE	66	KFG - KAMASAMUDRA	KAMASAMUDRA	14:44	15:26	0:41	LINE CLEAR AVAILED
574	25-Nov-18	BANGALORE	66	YELAHANKA 220 - LINE 6	SOLDEVANAHALLI	6:28	6:44	0:16	LINE FAULT
575	25-Nov-18	BANGALORE	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	7:10	7:18	0:08	LOAD CHANGEOR
576	25-Nov-18	BANGALORE	66	WELCAST STEEL - ABBIGERE	WELCAST STEEL	11:10	11:20	0:10	LOAD CHANGEOR
577	25-Nov-18	BANGALORE	66	HV1	WELCAST STEEL	9:50	11:46	1:56	LOAD CHANGEOR
578	25-Nov-18	BANGALORE	66	HV2	A STATION 66	11:23	11:26	0:02	LINE CLEAR AVAILED
579	25-Nov-18	BANGALORE	66	HV2	C STATION	11:10	14:17	3:07	LINE CLEAR AVAILED
580	25-Nov-18	BANGALORE	66	HV3	ELECTRONIC CITY P2 S1	2:31	10:09	7:38	HAND TRIPPED
581	25-Nov-18	BANGALORE	220	NAGANATHPURA 220 - SOMANAHALLI 220	NAGANATHPURA 220	16:42	17:07	0:24	LINE CLEAR AVAILED
582	25-Nov-18	BANGALORE	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	16:38	17:10	0:32	LINE CLEAR AVAILED
583	25-Nov-18	BANGALORE	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON (EHT), TECH MAHINDRA (EHT)	16:38	17:11	0:32	LINE CLEAR AVAILED
584	25-Nov-18	BANGALORE	66	HV1	NAGANATHPURA 220	16:38	17:10	0:32	LINE CLEAR AVAILED
585	25-Nov-18	BANGALORE	66	HV2	NAGANATHPURA 220	16:38	17:11	0:32	LINE CLEAR AVAILED
586	25-Nov-18	BANGALORE	66	HV1	TELECOM LAYOUT	15:39	15:46	0:06	LINE CLEAR AVAILED
587	25-Nov-18	BANGALORE	66	HV2	VICTORIA HOSPITAL	13:32	13:48	0:15	TRANSFORMER FAULT
588	25-Nov-18	BANGALORE	66	HV1	JIGANI 220	10:55	11:00	0:05	LOAD CHANGEOR
589	25-Nov-18	BANGALORE	66	HV2	JIGANI 220	10:55	11:00	0:05	LOAD CHANGEOR
590	25-Nov-18	BANGALORE	66	HV1	JIGANI 220	16:58	17:10	0:12	LOAD CHANGEOR
591	25-Nov-18	BANGALORE	66	HV2	JIGANI 220	16:58	17:10	0:12	LOAD CHANGEOR
592	25-Nov-18	BANGALORE	66	JIGANI 220 - JIGANI 66	JIGANI 66	10:55	10:58	0:03	LOAD CHANGEOR
593	25-Nov-18	BANGALORE	66	YARANDANAHALLI 220 -JIGANI 66	JIGANI 66	16:58	17:10	0:12	LOAD CHANGEOR
594	25-Nov-18	GULBARGA	110	HALBURGA-ACMESOLAR_IPP	HALBURGA_220	19:25	23:59	4:34	LINE FAULT
595	25-Nov-18	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	KAMPLI_GLB_110,MUKUNDA_110,BTPS_ WATER_WORKS	18:49	18:59	0:10	LINE FAULT
596	25-Nov-18	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	KAMPLI_GLB_110,MUKUNDA_110,BTPS_ WATER_WORKS	20:48	21:01	0:13	LINE FAULT
597	25-Nov-18	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	KAMPLI_GLB_110,MUKUNDA_110,BTPS_ WATER_WORKS	22:02	22:10	0:08	LINE FAULT
598	25-Nov-18	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	KAMPLI_GLB_110,MUKUNDA_110,BTPS_ WATER_WORKS	23:23	23:31	0:08	LINE FAULT
599	25-Nov-18	GULBARGA	110	RAICHUR220-SINDHANOOR1	ALKOD_110,BYAGAWAT_110,SIRWAR_11 O,VALKAMDINNI_110	11:25	11:35	0:10	LINE FAULT
600	25-Nov-18	GULBARGA	110	RAICHUR220-SINDHANOOR1	ALKOD_110,BYAGAWAT_110,SIRWAR_11 O,VALKAMDINNI_110	19:17	19:33	0:16	LINE FAULT
601	25-Nov-18	GULBARGA	110	RAICHUR220-SINDHANOOR1	ALKOD_110,BYAGAWAT_110,SIRWAR_11 O,VALKAMDINNI_110	20:17	20:24	0:07	LINE FAULT
602	25-Nov-18	GULBARGA	110	HV2	BETAGERA_110	9:41	9:58	0:17	TRANSFORMER FAULT
603	25-Nov-18	GULBARGA	110	HV2	HATTI_110	17:31	17:38	0:07	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
604	25-Nov-18	GULBARGA	110	HV1,HV2	LINGASUGUR_220	14:19	14:43	0:24	TRANSFORMER FAULT
605	25-Nov-18	HASSAN	220	HV3	KAVOOR	9:05	14:15	5:10	LINE CLEAR AVAILED
606	25-Nov-18	HASSAN	220	SHRAVTY-SIRISI 1	SHRAVTY	10:30	19:52	9:22	LINE CLEAR AVAILED
607	25-Nov-18	HASSAN	220	SHRAVTY-SIRISI 2	SHRAVTY	10:30	19:52	9:22	LINE CLEAR AVAILED
608	25-Nov-18	HASSAN	110	HV1	KONAJE	8:56	9:00	0:04	LOAD CHANGEOR
609	25-Nov-18	HASSAN	110	HV1	KONAJE	14:23	14:26	0:03	LOAD CHANGEOR
610	25-Nov-18	HASSAN	110	HV2	KONAJE	8:56	14:26	5:30	LOAD CHANGEOR
611	25-Nov-18	HASSAN	110	HV3	KONAJE	8:56	9:00	0:04	LOAD CHANGEOR
612	25-Nov-18	HASSAN	110	HV3	KONAJE	14:23	14:25	0:02	LOAD CHANGEOR
613	25-Nov-18	HASSAN	66	ARAKAL-MALLIPATNA	ARAKAL	2:32	2:49	0:17	LINE FAULT
614	25-Nov-18	HASSAN	66	ARAKAL-MALLIPATNA	ARAKAL	22:24	22:44	0:20	LINE FAULT
615	25-Nov-18	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNAT	6:29	6:34	0:05	LINE FAULT
616	25-Nov-18	MYSORE	66	HV1	HOOTAGALLY_220	9:42	9:47	0:05	LOAD CHANGEOR
617	25-Nov-18	MYSORE	66	HV2	HOOTAGALLY_220	9:41	9:48	0:06	LOAD CHANGEOR
618	25-Nov-18	MYSORE	220	HV3	HOOTAGALLY_220	9:17	23:59	14:41	LINE CLEAR AVAILED
619	25-Nov-18	MYSORE	66	KUSHALANAGARA 220-RAMANTHAPURA 1	ALUR SIDDAPUR_66 KANAGAL_66	6:11	6:21	0:09	LINE FAULT
620	25-Nov-18	MYSORE	66	TARIPURA-TUBINAKERE	TARIPURA_66	23:25	23:37	0:12	LINE FAULT
621	25-Nov-18	TUMKUR	66	BRAHMASANDRA- KORA	THOVINAKERE_66, KORA_66	5:47	8:31	2:44	LINE FAULT
622	25-Nov-18	TUMKUR	66	BRAHMASANDRA- SIRA	BRAHMASANDRA_66	5:47	8:31	2:44	LINE FAULT
623	25-Nov-18	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	10:54	16:00	5:05	LOAD CURTAILMENT
624	25-Nov-18	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	9:17	9:31	0:13	LINE FAULT
625	25-Nov-18	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	CHIKKABANAGERE_66	7:35	8:30	0:55	LINE FAULT
626	25-Nov-18	TUMKUR	66	TR-3	HOLALKERE_66	16:17	17:13	0:56	LINE CLEAR AVAILED
627	25-Nov-18	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	9:01	17:09	8:07	LINE CLEAR AVAILED
628	26-Nov-18	BAGALKOT	110	110/11KV,HV-2	BELUR_110	16:20	17:39	1:19	TRANSFORMER FAULT
629	26-Nov-18	BAGALKOT	110	BAGEWADI-MAMADAPUR 1	MAMADAPUR_110	23:39	23:44	0:05	LINE FAULT
630	26-Nov-18	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	JAMBAGI_110 NO STATION AFFECTED	16:21	23:59	7:38	LOAD CHANGEOR
631	26-Nov-18	BAGALKOT	110	110/33KV,HV-3	LAXMESHVAR_110	11:18	11:34	0:16	TRANSFORMER FAULT
632	26-Nov-18	BAGALKOT	110	BASAVA SUGARS-MALGHAN(B)	MALGHAN(B)_110	23:53	23:55	0:02	HAND TRIPPED
633	26-Nov-18	BAGALKOT	110	110/11KV, HV2	MUNAVALLY_110	17:04	18:06	1:02	LINE CLEAR AVAILED
634	26-Nov-18	BAGALKOT	110	110/33KV,HV2	MATTIHAL_110	8:23	8:28	0:05	TRANSFORMER FAULT
635	26-Nov-18	BAGALKOT	110	BAGEWADI1-MAMDAPUR(B)	MAMDAPUR(B)_110	23:39	23:45	0:06	LINE FAULT
636	26-Nov-18	BAGALKOT	110	110/33KV, HV4	ZALKI_110	9:29	9:33	0:04	TRANSFORMER FAULT
637	26-Nov-18	BAGALKOT	110	110/33KV, HV4	ZALKI_110	9:35	9:52	0:17	HAND TRIPPED
638	26-Nov-18	BAGALKOT	110	HUBLI-TARIHAL1	TARIHAL_110	10:20	13:45	3:25	LINE CLEAR AVAILED
639	26-Nov-18	BANGALORE	66	CHINTAMANI 220 - CHINTAMANI 66	GUNDAMGERE, DODDABELAVANGALA	11:36	11:40	0:04	LOAD CHANGEOR
640	26-Nov-18	BANGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	11:33	11:37	0:04	LOAD CHANGEOR

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
641	26-Nov-18	BANGALORE	66	HV2	HOSKOTE 66	7:28	7:51	0:23	LINE CLEAR AVAILED
642	26-Nov-18	BANGALORE	66	HV2	HOSKOTE 66	8:05	8:22	0:16	LINE CLEAR AVAILED
643	26-Nov-18	BANGALORE	66	KGF - BEML (EHT)	BEML (EHT)	14:50	15:04	0:14	LINE FAULT
644	26-Nov-18	BANGALORE	66	KGF - BEML (EHT)	BEML (EHT)	15:05	15:08	0:03	LINE FAULT
645	26-Nov-18	BANGALORE	66	YELAHANKA 220 - LINE 8	RAJANKUNTE	13:48	16:57	3:08	LINE FAULT
646	26-Nov-18	BANGALORE	66	YELAHANKA 220 - KANASWADI	KANASWADI	16:26	16:57	0:31	LINE CLEAR AVAILED
647	26-Nov-18	BANGALORE	66	HV1	DALASNUR	9:33	11:27	1:54	LINE CLEAR AVAILED
648	26-Nov-18	BANGALORE	66	HV2	DALASNUR	11:25	12:57	1:31	LINE CLEAR AVAILED
649	26-Nov-18	BANGALORE	66	HV1	BOODIGERE	2:07	2:47	0:40	TRANSFORMER FAULT
650	26-Nov-18	BANGALORE	66	ELECTRONIC CITY PH 2 SEC 2 - BIOCON (EHT)	BIOCON (EHT)	11:02	12:27	1:24	LINE FAULT
651	26-Nov-18	BANGALORE	66	ELECTRONIC CITY PH 2 SEC 2 - TECH MAHINDRA (EHT)	TECH MAHINDRA (EHT)	14:00	14:03	0:03	LINE FAULT
652	26-Nov-18	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, KODIHALLI, HUNSENAHALLI, BIJJALLI, HUKUNDA	12:19	12:40	0:20	LINE FAULT
653	26-Nov-18	GULBARGA	110	HALBURGA-ACMESOLAR_IPP	HALBURGA_220	0:00	9:20	9:20	LINE FAULT
654	26-Nov-18	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	KAMPLI_GLB_110,MUKUNDA_110,BTPS_WATER_WORKS	0:16	0:24	0:08	LINE FAULT
655	26-Nov-18	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	KAMPLI_GLB_110,MUKUNDA_110,BTPS_WATER_WORKS	3:00	3:10	0:10	LINE FAULT
656	26-Nov-18	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	KAMPLI_GLB_110,MUKUNDA_110,BTPS_WATER_WORKS	4:13	4:21	0:08	LINE FAULT
657	26-Nov-18	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	KAMPLI_GLB_110,MUKUNDA_110,BTPS_WATER_WORKS	6:14	6:44	0:30	LINE FAULT
658	26-Nov-18	GULBARGA	110	HV1	SIRWAR_110	6:38	6:40	0:02	TRANSFORMER FAULT
659	26-Nov-18	HASSAN	400	UPCL-HASSAN2	UPCL	10:47	23:59	13:12	LINE CLEAR AVAILED
660	26-Nov-18	HASSAN	220	ARSK2-HSN	ARSK2	14:20	15:02	0:42	HAND TRIPPED
661	26-Nov-18	HASSAN	220	ARSK2-SHMG	ARSK2	13:43	14:40	0:57	LINE FAULT
662	26-Nov-18	HASSAN	220	MRSSHM-HASSAN	MRSSHM	13:43	14:17	0:34	LINE FAULT
663	26-Nov-18	HASSAN	220	MRSSHM-VARAH12	MRSSHM	10:07	23:59	13:52	LINE CLEAR AVAILED
664	26-Nov-18	HASSAN	220	SHRAVITY-TALAGUPPA 2	SHRAVITY	10:35	17:02	6:27	LINE CLEAR AVAILED
665	26-Nov-18	HASSAN	220	TALAGU-SGS2	TALAGU	10:34	17:03	6:29	LINE CLEAR AVAILED
666	26-Nov-18	HASSAN	220	VARAHI-SHIMOAGA2	VARAHI	10:06	23:59	13:53	LINE CLEAR AVAILED
667	26-Nov-18	HASSAN	110	HV1	HALADY1	11:16	11:18	0:02	LINE CLEAR AVAILED
668	26-Nov-18	HASSAN	110	ARSK2-ARSKR	ARSK2	13:43	14:53	1:10	LINE FAULT
669	26-Nov-18	HASSAN	110	ARSK2-GANDASI	ARSK2	13:43	14:52	1:09	LINE FAULT
670	26-Nov-18	HASSAN	110	DMKURK-HONNAVALI	DMKURK	13:45	15:01	1:16	MAIN SUPPLY FAILURE
671	26-Nov-18	HASSAN	110	HV2	GANDAS	7:08	9:29	2:21	TRANSFORMER FAULT
672	26-Nov-18	HASSAN	66	BAGUR-RAMAPUR	BAGUR	5:51	6:16	0:25	LINE FAULT
673	26-Nov-18	HASSAN	66	GENDEHA-HASSAN	GENDEHA	14:10	14:17	0:07	MAIN SUPPLY FAILURE
674	26-Nov-18	HASSAN	66	GENDEHA-MUDIGERE	GENDEHA	14:10	14:18	0:08	MAIN SUPPLY FAILURE
675	26-Nov-18	MYSORE	66	CR NAGARA-YALANDUR	YELANDUR_66	18:04	18:12	0:07	LINE FAULT
676	26-Nov-18	MYSORE	66	HV1	K_HONNALGERE_66	9:12	9:38	0:25	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
677	26-Nov-18	MYSORE	66	HV1	KRNAGARA_66	5:05	5:17	0:12	TRANSFORMER FAULT
678	26-Nov-18	MYSORE	66	HV1	KRNAGARA_66	7:37	7:45	0:08	TRANSFORMER FAULT
679	26-Nov-18	MYSORE	66	MADHUVANAHALLI-YALANDUR	YELANDUR_66	18:05	18:13	0:08	LINE FAULT
680	26-Nov-18	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	6:51	7:14	0:22	LINE FAULT
681	26-Nov-18	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	9:15	15:11	5:56	LINE FAULT
682	26-Nov-18	MYSORE	66	MEGALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66 TNARASIPURA_66 THUMBLA_66	17:57	18:15	0:17	LINE FAULT
683	26-Nov-18	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	15:06	16:46	1:39	HAND TRIPPED
684	26-Nov-18	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	11:32	14:31	2:58	LINE CLEAR AVAILED
685	26-Nov-18	TUMKUR	220	NITTUR 220kV- HASSAN	NITTUR_220	14:31	15:06	0:35	LOAD CURTAILMENT
686	26-Nov-18	TUMKUR	110	TR-2	TURUVEKERE_110	13:17	13:38	0:20	TRANSFORMER FAULT
687	26-Nov-18	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	11:39	12:58	1:18	LOAD CURTAILMENT
688	26-Nov-18	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	15:06	15:22	0:15	LOAD CURTAILMENT
689	26-Nov-18	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	15:06	15:33	0:27	LOAD CURTAILMENT
690	26-Nov-18	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	16:19	16:33	0:14	LOAD CURTAILMENT
691	26-Nov-18	TUMKUR	66	TR-1	AMRUTHUR_66	4:34	6:30	1:55	TRANSFORMER FAULT
692	26-Nov-18	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	15:29	15:34	0:05	TRANSFORMER FAULT
693	26-Nov-18	TUMKUR	66	TR-2(LV SIDE)	ANCHEPALYA_220	15:29	15:37	0:08	TRANSFORMER FAULT
694	26-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	11:04	11:12	0:07	LOAD CHANGEOVER
695	26-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	14:41	14:47	0:06	LINE FAULT
696	26-Nov-18	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	10:00	15:19	5:18	LINE CLEAR AVAILED
697	26-Nov-18	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:44	12:30	1:46	LOAD CHANGEOVER
698	26-Nov-18	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:28	11:49	0:21	LOAD CHANGEOVER
699	26-Nov-18	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:05	16:19	0:13	LINE FAULT
700	26-Nov-18	TUMKUR	66	TR-1	HARAPPANAHALLI_66	12:22	14:07	1:44	TRANSFORMER FAULT
701	26-Nov-18	TUMKUR	66	TR-2	HONNALI_66	16:55	17:05	0:10	TRANSFORMER FAULT
702	26-Nov-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	13:55	15:51	1:56	LINE FAULT
703	26-Nov-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:44	11:50	0:06	LINE FAULT