

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 26.01.2021 TO 01.02.2021

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	26-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
2	26-Jan-2021	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	15:06	15:18	0:12	LINE CLEAR AVOIDED
3	26-Jan-2021	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(G)_110	18:22 (26.01.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
4	26-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
5	26-Jan-2021	BAGALKOT	110	110/11KV,HV1	GOKAK_110	18:21	19:47	1:26	TRANSFORMER FAULT
6	26-Jan-2021	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	15:24	15:35	0:11	TRANSFORMER FAULT
7	26-Jan-2021	BAGALKOT	110	110/33KV,HV2	ANKOLA_110 & MASTIKATTA,SEABIRD 33	23:27	23:34	0:07	TRANSFORMER FAULT
8	26-Jan-2021	BAGALKOT	110	ANKOLA-KUMATA(L2)	ANKOLA_110 (STATION NOT AFFECTED)	23:49 (25.01.2021)			LINE OPEN , LINE FAULT
9	26-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
10	26-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
11	26-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
12	26-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVOIDED
13	26-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN, LINE CLEAR AVOIDED
14	26-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
15	26-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
16	26-Jan-2021	BAGALKOT	110	KUMATA- SIRSI1	STATION NOT AFFECTED KUMTA_110	8:36	15:32	6:56	LINE CLEAR AVOIDED
17	26-Jan-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
18	26-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
19	26-Jan-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN , LINE FAULT
20	26-Jan-2021	BAGALKOT	110	SIRSI-KUMTA2	KUMTA_110	8:23	8:29	0:06	LINE FAULT
21	26-Jan-2021	BAGALKOT	220	BELGAUM-CHOKKODI 1	BELGAUM_220	21:02 (26.01.2021)			LOAD CURTAILMENT
22	26-Jan-2021	BAGALKOT	220	BELGAUM- NARENDRA1(KANABARGI1)	BELGAUM_220	15:20	16:33	1:13	LINE FAULT
23	26-Jan-2021	BAGALKOT	220	BELGAUM- NARENDRA1(KANABARGI1)	BELGAUM_220	21:04 (26.01.2021)			LOAD CURTAILMENT
24	26-Jan-2021	BAGALKOT	220	CHIKKODI-GHATAPRABHA	CHIKKODI_220 (STATION NOT AFFECTED)	9:45 (21.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
25	26-Jan-2021	BAGALKOT	220	CHOKKODI -BELGAUM1	CHIKKODI_220	21:04 (26.01.2021)			LOAD CURTAILMENT
26	26-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVOIDED
27	26-Jan-2021	BAGALKOT	220	GHATAPRABHA-CHIKKODI	STATION NOT AFFECTED GHATAPRABHA_220	9:47 (21.01.2021)			LINE OPEN , LINE FAULT
28	26-Jan-2021	BAGALKOT	220	GHATAPRABHA-KUDUCHI	STATION NOT AFFECTED GHATAPRABHA_220	9:13 (21.01.2021)			LINE OPEN , LINE FAULT
29	26-Jan-2021	BAGALKOT	220	KUDUCHI- GHATAPRABHA(CKD1)	STATION NOT AFFECTED KUDUCHI_220	9:12 (21.01.2021)			LINE OPEN , LINE FAULT
30	26-Jan-2021	BAGALKOT	220	NAGJHARI 2-BIDNAL	BIDNAL_220	12:45	15:05	2:20	LINE CLEAR AVOIDED
31	26-Jan-2021	BAGALKOT	220	NARENDRA- BELGAUM1	NARENDRA_220	15:19	16:30	1:11	LINE FAULT
32	26-Jan-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	19:00	19:11	0:11	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
33	26-Jan-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	19:02	19:11	0:09	HAND TRIPPED
34	26-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	17:30 (23.01.2021)	19:00 (26.01.2021)	73:30 hrs	LINE CHARGED
35	26-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	19:43 (26.01.2021)			LOAD CURTAILMENT
36	26-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:26 (23.01.2021)	19:00 (26.01.2021)	73:34 hrs	LINE CHARGED
37	26-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	19:43 (26.01.2021)			LOAD CURTAILMENT
38	26-Jan-2021	BENGALURU	66	GUNDLU KOTTUR - GOWRIBIDANUR 220	GUNDLU KOTTUR	15:46	18:32	02:46	LINE CLEAR AVAILED
39	26-Jan-2021	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	00:48	01:02	00:14	LINE FAULT
40	26-Jan-2021	BENGALURU	66	HV1	MUDIYANUR	11:50	12:04	00:14	TRANSFORMER FAULT
41	26-Jan-2021	BENGALURU	66	HV1	MUDIYANUR	12:05	12:10	00:05	TRANSFORMER FAULT
42	26-Jan-2021	BENGALURU	66	HV1	MUDIYANUR	15:54	16:03	00:09	TRANSFORMER FAULT
43	26-Jan-2021	BENGALURU	66	HV2	MANCHENAHALLI	17:30	18:19	00:49	LINE CLEAR AVAILED
44	26-Jan-2021	BENGALURU	66	HV3	DIVYASHREE TECH PARK	23:54(25/01/2021)	1:50(26/01/2021)	1:56hrs	TRANSFORMER CHARGED
45	26-Jan-2021	BENGALURU	66	IISC - NRS 220	IISC	16:28	16:31	00:03	LOAD CHANGE OVER
46	26-Jan-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	09:07	09:30	00:23	MAIN SUPPLY FAILURE
47	26-Jan-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	09:07	09:30	00:23	MAIN SUPPLY FAILURE
48	26-Jan-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	09:07	09:30	00:23	MAIN SUPPLY FAILURE
49	26-Jan-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	06:40	07:05	00:25	LINE FAULT
50	26-Jan-2021	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	10:51	11:41	00:50	LINE CLEAR AVAILED
51	26-Jan-2021	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	09:05	10:50	01:45	LINE FAULT
52	26-Jan-2021	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	09:07	09:30	00:23	MAIN SUPPLY FAILURE
53	26-Jan-2021	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	09:50	11:15	01:25	LINE CLEAR AVAILED
54	26-Jan-2021	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	09:07	09:30	00:23	MAIN SUPPLY FAILURE
55	26-Jan-2021	BENGALURU	220	HV1	KOLAR 220	09:07	09:25	00:18	TRANSFORMER FAULT
56	26-Jan-2021	BENGALURU	220	HV2	KOLAR 220	09:07	09:25	00:18	TRANSFORMER FAULT
57	26-Jan-2021	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	12:20	12:30	00:10	LINE FAULT
58	26-Jan-2021	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	13:25	13:35	00:10	LINE FAULT
59	26-Jan-2021	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	15:00	15:10	00:10	LINE FAULT
60	26-Jan-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	00:40	00:45	00:05	LINE FAULT
61	26-Jan-2021	GULBARGA	220	LINGAPUR-BTPS	BTPS_220	13:26	15:40	02:14	LINE FAULT
62	26-Jan-2021	GULBARGA	220	MALLAT-RTPS	MALLAT_220	05:00	15:15	10:15	LINE FAULT
63	26-Jan-2021	GULBARGA	220	RTPS-LINGASUGUR3	RTPS_220	05:01	05:15	00:14	LINE FAULT
64	26-Jan-2021	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	12:48	14:08	01:20	MAIN SUPPLY FAILURE
65	26-Jan-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	12:30	14:30	02:00	LINE CLEAR AVAILED
66	26-Jan-2021	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	11:29	14:27	02:58	LINE FAULT
67	26-Jan-2021	HASSAN	66	HV1	MAGGE_66	7:43 (19.01.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
68	26-Jan-2021	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	12:35	14:36	02:01	MAIN SUPPLY FAILURE
69	26-Jan-2021	HASSAN	66	HV1	HNPURA_66	02:57	03:12	00:15	TRANSFORMER FAULT
70	26-Jan-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
71	26-Jan-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
72	26-Jan-2021	HASSAN	110	HV1	ALKOLA_110	20:23	21:45	01:22	LINE CLEAR AVAILED
73	26-Jan-2021	HASSAN	110	HV2	PUTTUR_110	10:17(26.1.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
74	26-Jan-2021	HASSAN	110	HV3	HIRIYADKA_110	15:49	15:56	00:07	TRANSFORMER FAULT
75	26-Jan-2021	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	10:11	13:26	03:15	LINE CLEAR AVAILED
76	26-Jan-2021	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	10:50	12:45	01:55	LINE CLEAR AVAILED
77	26-Jan-2021	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN, LINE CLEAR AVAILED
78	26-Jan-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	14:25	17:19	02:54	LINE FAULT
79	26-Jan-2021	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	0:30(25.01.2021)			LINE OPEN , LINE FAULT
80	26-Jan-2021	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	11:11	13:37	02:26	LINE FAULT
81	26-Jan-2021	HASSAN	220	VARAHI-SHMG3	varahi_gen	11:11	13:37	02:26	LINE FAULT
82	26-Jan-2021	MYSURU	66	HV1	KIRUGAVALU_66	16:19	16:54	0:35	LINE CLEAR AVAILED
83	26-Jan-2021	MYSURU	66	JAKKANAHALLY-NAGAMANGLA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 NAGAMANGALA_66	18:07	18:13	0:06	LINE FAULT
84	26-Jan-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN, LINE CLEAR AVAILED
85	26-Jan-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
86	26-Jan-2021	MYSURU	66	KR PETE 220-KR PETE -1	AKKIEBBAL_66 KIKKERI_66 KRPET_66	6:39	6:47	0:08	LINE FAULT
87	26-Jan-2021	MYSURU	66	KR PETE -AKKIEBBAL-2	AKKIEBBAL_66 KIKKERI_66	6:42	7:00	0:18	LINE FAULT
88	26-Jan-2021	MYSURU	66	PARINAMIPURA-TALAKADU	CHANDALLI_66 THALAKADU_66	7:40	7:42	0:02	LINE FAULT
89	26-Jan-2021	MYSURU	66	SATHEGALA-BPCL	NO STATION EFFECTED	10:29 (22/01/2021)			LINE OPEN, LINE CLEAR AVAILED
90	26-Jan-2021	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	11:00	11:16	0:16	LINE FAULT
91	26-Jan-2021	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	11:33	11:40	0:06	LINE FAULT
92	26-Jan-2021	MYSURU	220	HV1	TUBINAKERE_220	11:00	11:13	0:13	TRANSFORMER FAULT
93	26-Jan-2021	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:12	11:26	0:14	HAND TRIPPED
94	26-Jan-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	06:45	06:58	0:12	LINE FAULT
95	26-Jan-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	07:59	08:06	0:06	LINE FAULT
96	26-Jan-2021	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	06:38	06:52	0:13	MAIN SUPPLY FAILURE
97	26-Jan-2021	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	06:38	06:52	0:14	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
98	26-Jan-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:28	18:31	0:03	MAIN SUPPLY FAILURE
99	26-Jan-2021	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	06:10	06:21	0:11	LINE FAULT
100	26-Jan-2021	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCH ANGIDURGA_66,PALLAGATTE _66, SOKKE_66	11:55	12:05	0:10	LINE FAULT
101	26-Jan-2021	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66	06:46	06:50	0:04	HAND TRIPPED
102	26-Jan-2021	TUMKUR	66	THALLAK 220kV -BGKERE 2	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	06:46	06:50	0:04	HAND TRIPPED
103	26-Jan-2021	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	06:45	07:14	0:28	HAND TRIPPED
104	26-Jan-2021	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	06:46	06:58	0:12	HAND TRIPPED
105	26-Jan-2021	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR IPP_66	SEI DIAMOND SOLAR_IPP_66	06:46	06:57	0:11	HAND TRIPPED
106	26-Jan-2021	TUMKUR	66	THALLAK 220kV- SEI VENUS DIAMOND IPP_66	SEI VENUS DIAMOND_IPP_66	06:46	06:57	0:11	HAND TRIPPED
107	26-Jan-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	06:45	07:05	0:19	HAND TRIPPED
108	26-Jan-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	06:34	07:18	0:44	LINE FAULT
109	26-Jan-2021	TUMKUR	66	TR-1	KUKKAWADA_66	16:44	17:23	0:39	LINE CLEAR AVAILED
110	26-Jan-2021	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	06:34	06:54	0:20	TRANSFORMER FAULT
111	26-Jan-2021	TUMKUR	66	TR-2	BEVINAHALLI_66	08:08	08:14	0:06	TRANSFORMER FAULT
112	26-Jan-2021	TUMKUR	66	TR-2	MELKOTE_66	10:58	11:43	0:44	LINE CLEAR AVAILED
113	26-Jan-2021	TUMKUR	66	TR-2	SANIKERE_66	10:35	10:37	0:01	TRANSFORMER FAULT
114	26-Jan-2021	TUMKUR	66	TR-2(LV SIDE)	THALLAKK_220	06:34	06:54	0:20	TRANSFORMER FAULT
115	26-Jan-2021	TUMKUR	66	UCHANGIDURGA- I/C220SRSDAVANG	UCHCHANGIDURGA_66	12:08	12:22	0:13	LINE FAULT
116	26-Jan-2021	TUMKUR	110	TR-2	MAYASANDRA_110	12:05	12:19	0:13	LINE CLEAR AVAILED
117	26-Jan-2021	TUMKUR	110	TR-2	SAMPIGE_110	09:38	10:52	1:13	LINE CLEAR AVAILED
118	26-Jan-2021	TUMKUR	110	TR-2	SHETYKERE_110	06:42	07:01	0:18	LINE CLEAR AVAILED
119	26-Jan-2021	TUMKUR	110	TR-2	SHETYKERE_110	07:46	07:50	0:03	LINE CLEAR AVAILED
120	26-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE CLEAR AVAILED
121	26-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE CLEAR AVAILED
122	26-Jan-2021	TUMKUR	220	HONNALLI 220kV- SUZLON1	SUZLON_IPP_66	04:49	05:23	0:34	LINE FAULT
123	26-Jan-2021	TUMKUR	220	HONNALLI 220kV- SUZLON2	SUZLON_IPP_66	04:49	05:23	0:34	LINE FAULT
124	27-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
125	27-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
126	27-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
127	27-Jan-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN , LINE FAULT
128	27-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN, LINE CLEAR AVAILED
129	27-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
130	27-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
131	27-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
132	27-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVALIED
133	27-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVALIED
134	27-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVALIED
135	27-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVALIED
136	27-Jan-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVALIED
137	27-Jan-2021	BAGALKOT	220	CHIKKODI-GHATAPRABHA 1	STATION NOT AFFECTED CHIKKODI_220	9:45 (21.01.2021)	18:01 (27.01.2021)	152:16HRS	LINE CHARGED
138	27-Jan-2021	BAGALKOT	220	KUDUCHI- GHATAPRABHA(CKD1)	STATION NOT AFFECTED KUDUCHI_220	9:12 (21.01.2021)	17:44 (27.01.2021)	152:32HRS	LINE CHARGED
139	27-Jan-2021	BAGALKOT	220	GHATAPRABHA-KUDUCHI	STATION NOT AFFECTED GHATAPRABHA_220	9:13 (21.01.2021)	17:42 (27.01.2021)	152:29HRS	LINE CHARGED
140	27-Jan-2021	BAGALKOT	220	GHATAPRABHA-CHIKKODI	STATION NOT AFFECTED GHATAPRABHA_220	9:47 (21.01.2021)	18:01 (27.01.2021)	151:55HRS	LINE CHARGED
141	27-Jan-2021	BAGALKOT	110	ANKOLA-KUMATA(L2)	STATION NOT AFFECTED ANKOLA_110	23:49 (25.01.2021)	11:37 (27.01.2021)	35:48HRS	LINE CHARGED
142	27-Jan-2021	BAGALKOT	220	BELGAUM- NARENDRA1(KANABARGI1)	BELGAUM_220	21:04 (26.01.2021)	8:01 (27.01.2021)	10:57HRS	LINE CHARGED
143	27-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	21:02 (26.01.2021)	8:10 (27.01.2021)	11:08HRS	LINE CHARGED
144	27-Jan-2021	BAGALKOT	220	CHOKKODI -BELGAUM1	CHIKKODI_220	21:04 (26.01.2021)	8:10 (27.01.2021)	11:06HRS	LINE CHARGED
145	27-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	19:43 (26.01.2021)			LOAD CURTAILMENT
146	27-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	19:43 (26.01.2021)			LOAD CURTAILMENT
147	27-Jan-2021	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(G)_110	18:22 (26.01.2021)	18:10 (27.01.2021)	23:48HRS	TRANSFORMER CHARGED
148	27-Jan-2021	BAGALKOT	110	110/11KV,HV1	ANKOLA_110	10:05	10:08	0:03	HAND TRIPPED
149	27-Jan-2021	BAGALKOT	110	BELLATTI-ENERCON2	BELLATTI_110 (STATION NOT AFFECTED)	13:42	13:50	0:08	HAND TRIPPED
150	27-Jan-2021	BAGALKOT	110	ALBAL-SAI PRIYA SUGARS	ALBAL_110 (STATION NOT AFFECTED)	06:50	07:20	0:30	LINE FAULT
151	27-Jan-2021	BAGALKOT	110	BIJAPUR-ENERCON(BAGEWADI)	BIJAPUR_220 (STATION NOT AFFECTED)	08:20	08:31	0:11	LINE FAULT
152	27-Jan-2021	BAGALKOT	110	BIJAPUR-ENERCON(BAGEWADI)	BIJAPUR_220(STATION NOT AFFECTED)	08:49	08:54	0:05	LINE FAULT
153	27-Jan-2021	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	12:24	12:30	0:06	TRANSFORMER FAULT
154	27-Jan-2021	BAGALKOT	110	TARIHAL- TADASINKOPPA	STATION NOT AFFECTED TADASINKOPPA_110	16:35	18:10	1:35	LINE CLEAR AVALIED
155	27-Jan-2021	BAGALKOT	110	LAXMESHWAR- BELLATTI	BELLATTI_110	5:11	5:52	0:41	LINE FAULT
156	27-Jan-2021	BAGALKOT	110	LAXMESHWAR- BELLATTI	BELLATTI_110	6:00	7:42	1:42	LINE FAULT
157	27-Jan-2021	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	17:25	18:01	0:36	LINE CLEAR AVALIED
158	27-Jan-2021	BAGALKOT	220	GUTTURI&2- HAVERI	HAVERI_220	11:58	18:50	6:52	LINE CLEAR AVALIED
159	27-Jan-2021	BAGALKOT	110	110/11KV, HV1	GELUDAGUDDA_110	10:18	10:26	0:08	TRANSFORMER FAULT
160	27-Jan-2021	BENGALURU	66	C STATION - HEBBAL 220	C STATION	08:05	08:11	00:06	LOAD CHANGE OVER
161	27-Jan-2021	BENGALURU	66	C STATION - A STATION 220	C STATION	18:55	19:02	00:07	LOAD CHANGE OVER
162	27-Jan-2021	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI	12:04	14:20	02:15	LINE CLEAR AVALIED
163	27-Jan-2021	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	18:09	18:49	00:39	LINE CLEAR AVALIED
164	27-Jan-2021	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	02:17	04:24	02:07	LINE CLEAR AVALIED
165	27-Jan-2021	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	02:18	04:23	02:05	LINE CLEAR AVALIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
166	27-Jan-2021	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNU	02:18	04:23	02:05	LINE CLEAR AVAILED
167	27-Jan-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	02:18	04:25	02:07	LINE CLEAR AVAILED
168	27-Jan-2021	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	14:08	14:20	00:12	LINE CLEAR AVAILED
169	27-Jan-2021	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	13:34	14:12	00:38	LINE CLEAR AVAILED
170	27-Jan-2021	BENGALURU	66	HEBBAL 220 - IISC	IISC	15:18	15:29	00:11	LINE CLEAR AVAILED
171	27-Jan-2021	BENGALURU	66	HANUMANTHNAGAR - KANAKAPURA 220	HANUMANTHNAGAR	11:20	11:32	00:11	LOAD CHANGE OVER
172	27-Jan-2021	BENGALURU	66	HANUMANTHNAGAR - YEDUMADU	HANUMANTHNAGAR	14:15	14:40	00:25	MAIN SUPPLY FAILURE
173	27-Jan-2021	BENGALURU	66	HANUMANTHNAGAR - YEDUMADU	HANUMANTHNAGAR	15:15	15:20	00:05	MAIN SUPPLY FAILURE
174	27-Jan-2021	BENGALURU	66	DODDABELAVANGALA - DB PURA 220	DODDABELAVANGALA	14:35	15:35	01:00	LINE CLEAR AVAILED
175	27-Jan-2021	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	10:27	10:52	00:24	LINE FAULT
176	27-Jan-2021	BENGALURU	66	HV1	HEBBAL 220	15:34	15:44	00:10	LINE CLEAR AVAILED
177	27-Jan-2021	BENGALURU	66	HV2	HEBBAL 220	15:49	16:00	00:11	LINE CLEAR AVAILED
178	27-Jan-2021	BENGALURU	66	HV3	HEBBAL 220	16:05	16:23	00:18	LINE CLEAR AVAILED
179	27-Jan-2021	BENGALURU	66	HV2	ELECTRONIC CITY P2 S2	12:07	12:12	00:04	TRANSFORMER FAULT
180	27-Jan-2021	BENGALURU	66	HV1	DODDABELAVANGALA	10:05	14:00	03:54	LINE CLEAR AVAILED
181	27-Jan-2021	BENGALURU	66	HV1	C STATION	18:04	19:04	00:59	LINE CLEAR AVAILED
182	27-Jan-2021	BENGALURU	66	HV2	C STATION	17:48	18:04	00:15	LINE CLEAR AVAILED
183	27-Jan-2021	BENGALURU	66	hv1	PRESTIGE SHANTINIKETHAN	13:15	13:25	00:10	TRANSFORMER FAULT
184	27-Jan-2021	BENGALURU	66	HV1	MALLASANDRA	05:45	08:55	03:10	TRANSFORMER FAULT
185	27-Jan-2021	BENGALURU	66	HV1	MALLASANDRA	11:30	11:35	00:05	LINE CLEAR AVAILED
186	27-Jan-2021	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	10:50	10:55	00:05	LINE CLEAR AVAILED
187	27-Jan-2021	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	17:10	17:15	00:05	LINE CLEAR AVAILED
188	27-Jan-2021	BENGALURU	66	HV1	MAASTHI	13:40	13:46	00:05	TRANSFORMER FAULT
189	27-Jan-2021	BENGALURU	220	HV1	KANAKAPURA 220	16:53	17:47	00:54	TRANSFORMER FAULT
190	27-Jan-2021	BENGALURU	220	HV2	KANAKAPURA 220	16:53	17:47	00:54	TRANSFORMER FAULT
191	27-Jan-2021	BENGALURU	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	16:53	17:49	00:56	MAIN SUPPLY FAILURE
192	27-Jan-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	16:53	17:59	01:06	MAIN SUPPLY FAILURE
193	27-Jan-2021	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU	16:53	17:49	00:56	MAIN SUPPLY FAILURE
194	27-Jan-2021	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	16:53	17:49	00:56	MAIN SUPPLY FAILURE
195	27-Jan-2021	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	16:53	17:49	00:56	MAIN SUPPLY FAILURE
196	27-Jan-2021	GULBARGA	220	LINGAPUR-JVSL-2	LINGAPUR_220	09:04	18:35	09:31	NFBC ISSUED
197	27-Jan-2021	GULBARGA	110	MALLAPURA-MUNIRABAD	MALLAPURA_110,KAMPLI_GL B_110	13:06	13:15	00:09	LINE FAULT
198	27-Jan-2021	GULBARGA	110	MALLAPURA-KAMPLI	KAMPLI_GLB_110	13:06	13:26	00:20	LINE FAULT
199	27-Jan-2021	GULBARGA	110	HV2	VALKAMDINNI_110	12:35	13:15	00:40	LINE CLEAR AVAILED
200	27-Jan-2021	GULBARGA	110	HV3	VALKAMDINNI_110	13:20	13:25	00:05	LINE CLEAR AVAILED
201	27-Jan-2021	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADLAPUR_110, KURDICROSS_110	06:10	07:10	01:00	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
202	27-Jan-2021	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADLAPUR_110, KURDICROSS_110	21:23	21:56	00:33	LINE FAULT
203	27-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALAKAMDI NI_110	00:07	00:18	00:11	LINE FAULT
204	27-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALAKAMDI NI_110	01:48	01:59	00:11	LINE FAULT
205	27-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALAKAMDI NI_110	02:54	03:24	00:30	LINE FAULT
206	27-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALAKAMDI NI_110	06:46	06:56	00:10	LINE FAULT
207	27-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	03:55	04:05	00:10	LINE FAULT
208	27-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	05:40	05:50	00:10	LINE FAULT
209	27-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	06:31	06:46	00:15	LINE FAULT
210	27-Jan-2021	MYSURU	66	HOOTAGALLY-BARC 2	NO STATION EFFECTED	9:14	12:10	2:56	LINE CLEAR AVAILED
211	27-Jan-2021	MYSURU	66	HOOTAGALLY-DODDAKADNUR	NO STATION EFFECTED	10:12	12:06	1:54	LINE CLEAR AVAILED
212	27-Jan-2021	MYSURU	220	KADAKOLA-BASTIPURA 1	NO STATION EFFECTED	9:40	12:19	2:38	LINE CLEAR AVAILED
213	27-Jan-2021	MYSURU	66	HV1	KIRUGAVALU_66	13:39	14:40	1:00	LINE CLEAR AVAILED
214	27-Jan-2021	MYSURU	66	HV1	KIRUGAVALU_66	16:10	18:50	2:40	LINE CLEAR AVAILED
215	27-Jan-2021	MYSURU	66	HV2	MALAVALLI_66	10:08	15:40	5:31	LINE CLEAR AVAILED
216	27-Jan-2021	MYSURU	66	MANDGERE-HOLENARSIPURA	MANDGERE_66	8:20	14:25	6:04	LINE CLEAR AVAILED
217	27-Jan-2021	MYSURU	66	HV2	NAGAMANGALA_66	13:38	14:00	0:21	LINE CLEAR AVAILED
218	27-Jan-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATION EFFECTED	11:37	12:08	0:31	HAND TRIPPED
219	27-Jan-2021	MYSURU	66	PANDAVAPURA-ATRIA 2	NO STATION EFFECTED	12:09	12:30	0:20	HAND TRIPPED
220	27-Jan-2021	MYSURU	66	HV1	RAMAPURA_MYS_66	11:34	12:40	1:05	LINE CLEAR AVAILED
221	27-Jan-2021	MYSURU	66	HV2	RAMAPURA_MYS_66	11:34	11:42	0:07	HAND TRIPPED
222	27-Jan-2021	MYSURU	66	HV2	RAMAPURA_MYS_66	12:35	12:40	0:05	HAND TRIPPED
223	27-Jan-2021	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	7:21	7:26	0:05	LINE FAULT
224	27-Jan-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
225	27-Jan-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN, LINE CLEAR AVAILED
226	27-Jan-2021	MYSURU	66	SATHEGALA-BPCL	NO STATION EFFECTED	10:29 (22/01/2021)			LINE OPEN, LINE CLEAR AVAILED
227	27-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE CLEAR AVAILED
228	27-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE CLEAR AVAILED
229	27-Jan-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	7:14	7:31	0:17	LINE FAULT
230	27-Jan-2021	TUMKUR	66	TR-2	AVAREGERE_66	16:58	18:22	1:23	LINE CLEAR AVAILED
231	27-Jan-2021	TUMKUR	66	TR-1	BELLAVI_66	15:44	19:56	4:11	LINE CLEAR AVAILED
232	27-Jan-2021	TUMKUR	66	TR-2	BELLAVI_66	11:14	15:40	4:26	LINE CLEAR AVAILED
233	27-Jan-2021	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	12:05	12:10	0:05	LINE FAULT
234	27-Jan-2021	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	6:20	6:36	0:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
235	27-Jan-2021	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	17:54	18:12	0:17	LINE FAULT
236	27-Jan-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	18:43	19:03	0:20	LINE FAULT
237	27-Jan-2021	TUMKUR	66	GULIGENAHALLI- SIRA	GULIGENAHALLI_66	14:22	14:31	0:08	LINE FAULT
238	27-Jan-2021	TUMKUR	66	TR-1	HOSADURGA_66	8:27	9:42	1:15	TRANSFORMER FAULT
239	27-Jan-2021	TUMKUR	66	TR-1	KANCHIPURA_66	20:46	20:59	0:12	TRANSFORMER FAULT
240	27-Jan-2021	TUMKUR	66	TR-1	LINGDHALLI_66	16:39	16:49	0:10	LINE CLEAR AVAILED
241	27-Jan-2021	TUMKUR	66	TR-2	LINGDHALLI_66	16:39	16:53	0:14	LINE CLEAR AVAILED
242	27-Jan-2021	TUMKUR	66	LINGADHALLI-SHIMOGA	LINGDHALLI_66	16:36	17:05	0:28	LINE CLEAR AVAILED
243	27-Jan-2021	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	13:19	14:18	0:58	LINE CLEAR AVAILED
244	27-Jan-2021	TUMKUR	66	MADHUGIRI 220kV- SIRA 1	SIRA_66,GULIGENAHALLI_66,	13:21	14:19	0:57	LINE CLEAR AVAILED
245	27-Jan-2021	TUMKUR	66	TR-1	MAYAKONDA_66	8:19	8:24	0:05	TRANSFORMER FAULT
246	27-Jan-2021	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDURGA_66,PALLAGATTE_66, SOKKE_66	6:46	7:05	0:19	LINE FAULT
247	27-Jan-2021	TUMKUR	66	TR-1	PULAMG_66	12:55	13:52	0:57	LINE CLEAR AVAILED
248	27-Jan-2021	TUMKUR	66	TR-1	SOKKE_66	15:03	15:29	0:25	HAND TRIPPED
249	27-Jan-2021	TUMKUR	66	TR-1	TAVAREKERE(C)_66	9:12	9:21	0:09	TRANSFORMER FAULT
250	27-Jan-2021	TUMKUR	66	TR-1	TAVAREKERE(C)_66	10:11	10:17	0:05	TRANSFORMER FAULT
251	27-Jan-2021	TUMKUR	66	TURUVANUR66-CHITRADURGA	TURUVANUR_66	6:19	6:55	0:36	LINE FAULT
252	27-Jan-2021	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,SOKKE_66	6:19	6:55	0:36	LINE FAULT
253	27-Jan-2021	TUMKUR	66	TR-1	UCHCHANGIDURGA_66	15:42	16:14	0:31	LINE CLEAR AVAILED
254	27-Jan-2021	TUMKUR	66	TR-2	UCHCHANGIDURGA_66	16:15	16:49	0:34	LINE CLEAR AVAILED
255	28-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
256	28-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
257	28-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
258	28-Jan-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN , LINE FAULT
259	28-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN, LINE CLEAR AVAILED
260	28-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
261	28-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
262	28-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT-NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
263	28-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
264	28-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
265	28-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
266	28-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
267	28-Jan-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
268	28-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	19:43 (26.01.2021)			LOAD CURTAILMENT
269	28-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	19:43 (26.01.2021)			LOAD CURTAILMENT
270	28-Jan-2021	BAGALKOT	220	ADPH2-BAGEWADI	BAGEWADI_220	11:08	13:25	2:17	LINE CLEAR AVOIDED
271	28-Jan-2021	BAGALKOT	110	110/11KV,HV3	BIJAPUR_110	14:13	15:18	1:05	LINE CLEAR AVOIDED
272	28-Jan-2021	BAGALKOT	110	GADAG-SAMBAPUR ROAD (DAMBAL 1)	GADAG_220 (STATION NOT AFFECTED)	15:40	17:10	1:30	LINE CLEAR AVOIDED
273	28-Jan-2021	BAGALKOT	110	KUSHTAGI-GAJENDRAGAD	GAJENDRAGAD_110 (STATION NOT AFFECTED)	14:22	17:46	3:24	LINE CLEAR AVOIDED
274	28-Jan-2021	BAGALKOT	220	BELGAUM-NARENDRA 1(KANABARGI 1)	BELGAUM_220	10:17	17:04	6:47	LINE CLEAR AVOIDED
275	28-Jan-2021	BAGALKOT	220	BIJAPUR-INDI2	BIJAPUR_220	13:40	14:26	0:46	LINE CLEAR AVOIDED
276	28-Jan-2021	BAGALKOT	110	110/11KV, HV2	TILUVALLI_110	08:09	08:23	0:14	LINE CLEAR AVOIDED
277	28-Jan-2021	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	8:59	9:12	0:13	TRANSFORMER FAULT
278	28-Jan-2021	BAGALKOT	110	GADAG220- SAMBAPUR ROAD	STATION NOT AFFECTED SAMBAPUR ROAD_110	15:40	17:11	1:31	LINE CLEAR AVOIDED
279	28-Jan-2021	BAGALKOT	220	NARENDRA- BELGAUM1 (KANABARGI1)	NARENDRA_220	10:15	17:03	6:48	LINE CLEAR AVOIDED
280	28-Jan-2021	BAGALKOT	110	110/11KV, HV4	KERUR_110	10:59	14:50	3:51	LINE CLEAR AVOIDED
281	28-Jan-2021	BAGALKOT	220	KUDACHI- ATHANI	KUDACHI_220	15:38	19:10	3:32	LINE CLEAR AVOIDED
282	28-Jan-2021	BAGALKOT	110	ILKAL1- HUNGUND	STATION NOT AFFECTED HUNGUND_110	18:29 (28.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
283	28-Jan-2021	BAGALKOT	110	ILKAL2- HUNGUND	STATION NOT AFFECTED HUNGUND_110	18:29 (28.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
284	28-Jan-2021	BAGALKOT	110	110/11KV, HV2	HIDIKAL DAM_110	13:13	13:35	0:22	LINE CLEAR AVOIDED
285	28-Jan-2021	BENGALURU	66	HV1	HSR LAYOUT 220	11:30	11:45	00:15	TRANSFORMER FAULT
286	28-Jan-2021	BENGALURU	66	HV1	ISRO LAYOUT	08:38	08:55	00:17	TRANSFORMER FAULT
287	28-Jan-2021	BENGALURU	66	JAYADEVA - ADUGODI 1	NO STATION AFFECTED	10:20	10:45	00:25	LINE FAULT
288	28-Jan-2021	BENGALURU	66	KORAMANGALA 220 - ADUGODI 2	NO STATION AFFECTED	05:51	10:46	04:55	LINE FAULT
289	28-Jan-2021	BENGALURU	66	HV2	MAHALAKSHMI LAYOUT	09:55	10:00	00:05	LINE CLEAR AVOIDED
290	28-Jan-2021	BENGALURU	66	HV2	MAHALAKSHMI LAYOUT	15:50	15:51	00:01	LINE CLEAR AVOIDED
291	28-Jan-2021	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	22:50	23:20	00:30	LINE FAULT
292	28-Jan-2021	BENGALURU	66	HV1	AGALAKOTE	17:36	17:58	00:22	TRANSFORMER FAULT
293	28-Jan-2021	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE, MATHIKERE	17:45	17:59	00:14	LINE FAULT
294	28-Jan-2021	BENGALURU	66	IRGMPLI	CHINTAMANI 220	13:41	14:07	00:25	LINE CLEAR AVOIDED
295	28-Jan-2021	BENGALURU	66	HV2	HBR LAYOUT	12:32	12:57	00:24	LINE CLEAR AVOIDED
296	28-Jan-2021	BENGALURU	66	HV2	HBR LAYOUT	13:51	14:03	00:12	LINE CLEAR AVOIDED
297	28-Jan-2021	BENGALURU	66	HV1	HBR LAYOUT	12:52	13:10	00:18	LINE CLEAR AVOIDED
298	28-Jan-2021	BENGALURU	66	HV3	HBR LAYOUT	13:12	13:30	00:18	LINE CLEAR AVOIDED
299	28-Jan-2021	BENGALURU	66	HV2	KODIHALLI KANAKAPURA	05:55	06:05	00:09	LINE CLEAR AVOIDED
300	28-Jan-2021	BENGALURU	66	HV2	MAASTHI	22:08	22:14	00:05	TRANSFORMER FAULT
301	28-Jan-2021	BENGALURU	66	HV1	MALLASANDRA	11:00	11:50	00:50	LINE CLEAR AVOIDED
302	28-Jan-2021	BENGALURU	66	HV2	MALLASANDRA	11:49	12:20	00:30	LINE CLEAR AVOIDED
303	28-Jan-2021	BENGALURU	66	HV1	VOLVO	10:57	11:00	00:02	LINE CLEAR AVOIDED
304	28-Jan-2021	BENGALURU	66	HV2	VOLVO	12:40	12:50	00:10	LINE CLEAR AVOIDED
305	28-Jan-2021	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	11:47	15:04	03:17	LINE CLEAR AVOIDED
306	28-Jan-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	10:55	11:55	01:00	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
307	28-Jan-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	15:07	15:21	00:14	LINE FAULT
308	28-Jan-2021	GULBARGA	220	HV1	KUSHTAGI_220	10:20(28.01.21)			TRANSFORMER OPEN,LINE CLEAR AVAILED
309	28-Jan-2021	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	08:29	15:14	06:45	LINE CLEAR AVAILED
310	28-Jan-2021	GULBARGA	220	LINGAPUR-JVSL-2	LINGAPUR_220	09:51	20:54	11:03	NFBC ISSUED
311	28-Jan-2021	GULBARGA	220	RTPS-LINGSUGUR2	LINGSUGUR_220	20:47	21:16	00:29	LINE FAULT
312	28-Jan-2021	GULBARGA	220	KUSHTAGI-LINGSUGUR	KUSHTAGI_220	10:04	19:07	09:03	LINE CLEAR AVAILED
313	28-Jan-2021	GULBARGA	220	HV2	KUSHTAGI_220	10:30	11:08	00:38	TRANSFORMER FAULT
314	28-Jan-2021	GULBARGA	110	LINGASUGUR-KUSTIGI	LINGASUGUR_220	10:07	19:07	09:00	NFBC ISSUED
315	28-Jan-2021	GULBARGA	110	HV2	BISIHALLI_110	07:28	07:46	00:18	TRANSFORMER FAULT
316	28-Jan-2021	GULBARGA	110	HANUMASAGAR-KUSHTAGI	HANUMASAGAR_110,HANU MANAL_110, HIREGONNAGAR_110	10:30	11:32	01:00	MAIN SUPPLY FAILURE
317	28-Jan-2021	GULBARGA	110	HATTI-SOMNAMARDI_IPP	HATTI-110	00:50	00:57	00:07	LINE FAULT
318	28-Jan-2021	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADLAPUR_110, KURDICROSS_110	06:10	07:10	01:00	LINE FAULT
319	28-Jan-2021	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERADONA_110,SRNAGAR_110, MALLAPURA_110	06:52	07:02	00:10	LINE FAULT
320	28-Jan-2021	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERADONA_110,SRNAGAR_110, MALLAPURA_110	10:17	10:27	00:10	LINE FAULT
321	28-Jan-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	SHAHAPUR_220	06:15	06:20	00:05	LINE FAULT
322	28-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALAKAMDI NI_110	00:07	00:18	00:11	LINE FAULT
323	28-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALAKAMDI NI_110	01:48	01:59	00:11	LINE FAULT
324	28-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALAKAMDI NI_110	02:54	03:24	00:30	LINE FAULT
325	28-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALAKAMDI NI_110	06:46	06:56	00:10	LINE FAULT
326	28-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	03:55	04:05	00:10	LINE FAULT
327	28-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	05:40	05:50	00:10	LINE FAULT
328	28-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	06:31	06:46	00:15	LINE FAULT
329	28-Jan-2021	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	10:10	18:00	07:50	LINE CLEAR AVAILED
330	28-Jan-2021	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	10:30	11:35	01:05	MAIN SUPPLY FAILURE
331	28-Jan-2021	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	17:30	17:40	00:10	MAIN SUPPLY FAILURE
332	28-Jan-2021	GULBARGA	66	HV3	KUDLIGI_66	07:20	07:40	00:20	TRANSFORMER FAULT
333	28-Jan-2021	HASSAN	66	HV1	MAGGE_66	7:43 (19.01.2021)	18:13(28.1.2021)	226:29 hrs	TRANSFORMER CHARGED
334	28-Jan-2021	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	17:27 (27.01.2021)	9:54 (28.01.2021)	16:26 hrs	LINE CHARGED
335	28-Jan-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
336	28-Jan-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
337	28-Jan-2021	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN, LINE CLEAR AVAILED
338	28-Jan-2021	HASSAN	110	HV2	PUTTUR_110	10:17(26.1.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
339	28-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	02:01	07:23	05:22	LINE CLEAR AVAILED
340	28-Jan-2021	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	10:44	14:40	03:56	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
341	28-Jan-2021	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:29	12:36	02:07	LINE CLEAR AVAILED
342	28-Jan-2021	HASSAN	110	HV1	BAIKAMPADI_110	09:55	12:14	02:19	LINE CLEAR AVAILED
343	28-Jan-2021	HASSAN	110	HV2	BARANGI_110	14:06	15:28	01:22	LINE CLEAR AVAILED
344	28-Jan-2021	HASSAN	110	HV1	BHADRAVATHI_110	09:42	18:53	09:11	LINE CLEAR AVAILED
345	28-Jan-2021	HASSAN	110	HV3	MANIPAL_110	08:32	08:45	00:13	LINE CLEAR AVAILED
346	28-Jan-2021	HASSAN	110	HV4	MANIPAL_110	08:32	08:44	00:12	LINE CLEAR AVAILED
347	28-Jan-2021	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	13:46	16:50	03:04	NFBC ISSUED
348	28-Jan-2021	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	13:46	16:51	03:05	NFBC ISSUED
349	28-Jan-2021	HASSAN	66	HV1	BALEHONNUR_66	10:50	12:18	01:28	LINE CLEAR AVAILED
350	28-Jan-2021	HASSAN	66	HV2	BALEHONNUR_66	11:29	13:11	01:42	LINE CLEAR AVAILED
351	28-Jan-2021	HASSAN	66	HV4	BALEHONNUR_66	11:34	13:36	02:02	LINE CLEAR AVAILED
352	28-Jan-2021	HASSAN	66	HAGARE-HASSAN	HAGARE_66	12:43	14:10	01:27	MAIN SUPPLY FAILURE
353	28-Jan-2021	HASSAN	66	HV1	HNPURA_66	07:23	08:06	00:43	TRANSFORMER FAULT
354	28-Jan-2021	HASSAN	66	HV1	HNPURA_66	11:51	12:07	00:16	LINE CLEAR AVAILED
355	28-Jan-2021	HASSAN	66	HV1	HOLALUR_66	10:36	18:38	08:02	LINE CLEAR AVAILED
356	28-Jan-2021	HASSAN	66	HV2	HOLALUR_66	10:36	18:38	08:02	LINE CLEAR AVAILED
357	28-Jan-2021	HASSAN	66	HV2	MAGGE_66	18:13	18:48	00:35	TRANSFORMER FAULT
358	28-Jan-2021	HASSAN	66	MALALI-CRPATNA	MALALI_66	11:36	16:36	05:00	LINE CLEAR AVAILED
359	28-Jan-2021	HASSAN	66	HV2	SALAGAME_66	11:37	12:27	00:50	LINE CLEAR AVAILED
360	28-Jan-2021	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	11:39	16:36	04:57	MAIN SUPPLY FAILURE
361	28-Jan-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	11:36	16:50	05:14	LINE CLEAR AVAILED
362	28-Jan-2021	MYSURU	66	HV1	BGNAGARA_66	10:24	16:05	5:41	LINE CLEAR AVAILED
363	28-Jan-2021	MYSURU	66	HV2	BGNAGARA_66	10:24	16:05	5:40	LINE CLEAR AVAILED
364	28-Jan-2021	MYSURU	66	HV1	BGNAGARA_66	16:56	17:20	0:23	LINE CLEAR AVAILED
365	28-Jan-2021	MYSURU	66	CHUNCHUNKATTE-KR NAGARA	CHUNCHUNKATTE_66	10:06	17:22	7:16	LINE CLEAR AVAILED
366	28-Jan-2021	MYSURU	66	CHUNCHUNKATTE-RAVANDUR	CHUNCHUNKATTE_66	10:00	17:20	7:20	LINE CLEAR AVAILED
367	28-Jan-2021	MYSURU	220	CR NAGARA-MADHUVANAHALLI 2	NO STATION EFFECTED	13:21	16:17	2:56	NFBC ISSUED
368	28-Jan-2021	MYSURU	220	CR NAGARA-BEGUR 2	NO STATION EFFECTED	16:20	18:03	1:43	LINE CLEAR AVAILED
369	28-Jan-2021	MYSURU	66	G UKKADA-SR PATNA	NO STATION EFFECTED	11:15	13:56	2:41	LINE CLEAR AVAILED
370	28-Jan-2021	MYSURU	66	G UKKADA-PANDAVAPURA	NO STATION EFFECTED	15:53	15:54	0:01	HAND TRIPPED
371	28-Jan-2021	MYSURU	66	HOOTAGALLY-BARC 1	NO STATION EFFECTED	9:13	12:11	2:57	LINE CLEAR AVAILED
372	28-Jan-2021	MYSURU	220	HOOTAGALLY-KADAKOLA	NO STATION EFFECTED	15:50	17:46	1:56	NFBC ISSUED
373	28-Jan-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATION EFFECTED	9:53	17:13	7:20	NFBC ISSUED
374	28-Jan-2021	MYSURU	66	HV1	KIRUGAVALU_66	12:23	13:33	1:10	LINE CLEAR AVAILED
375	28-Jan-2021	MYSURU	66	HV1	MADHUVANAHALLI_220	10:40	14:26	3:46	LINE CLEAR AVAILED
376	28-Jan-2021	MYSURU	66	HV1	MADHUVANAHALLI_220	17:26	17:28	0:02	HAND TRIPPED
377	28-Jan-2021	MYSURU	66	HV2	MYSORESOUTH_66	9:38	16:02	6:24	LINE CLEAR AVAILED
378	28-Jan-2021	MYSURU	66	HV1	PANDAVAPURA_66	13:50	13:55	0:05	HAND TRIPPED
379	28-Jan-2021	MYSURU	66	HV5	SFCSHIVA_66	6:50	13:43	6:53	TRANSFORMER FAULT
380	28-Jan-2021	MYSURU	66	SFC SIVA-PGL	NO STATION EFFECTED	11:58	12:05	0:06	LINE FAULT
381	28-Jan-2021	MYSURU	66	SFC SIVA-5 MW	NO STATION EFFECTED	12:00	12:04	0:04	LINE FAULT
382	28-Jan-2021	MYSURU	66	SFC SIVA-10 MW	NO STATION EFFECTED	12:00	12:02	0:02	LINE FAULT
383	28-Jan-2021	MYSURU	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	18:40	18:45	0:05	LINE FAULT
384	28-Jan-2021	MYSURU	66	TUBINAKERE-G UKKADA	GARUDANAUKADDA_66 SRIRANGAPATNA_66	22:20	22:29	0:09	LINE FAULT
385	28-Jan-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
386	28-Jan-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN, LINE CLEAR AVAILED
387	28-Jan-2021	MYSURU	66	SATHEGALA-BPCL	NO STATION EFFECTED	10:29 (22/01/2021)	16:10(28.01.21)	149:41 HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
388	28-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE CLEAR AVAILED
389	28-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE CLEAR AVAILED
390	28-Jan-2021	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	10:42	12:27	1:45	LINE CLEAR AVAILED
391	28-Jan-2021	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR IPP 66	AZURE POWER SOLAR_IPP_66	18:02	18:44	0:41	LINE CLEAR AVAILED
392	28-Jan-2021	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR IPP 66	AZURE POWER SOLAR_IPP_66	19:12	19:26	0:14	LINE CLEAR AVAILED
393	28-Jan-2021	TUMKUR	220	TR-1(HV SIDE)	NITTUR_220	17:11	18:42	1:30	LINE CLEAR AVAILED
394	28-Jan-2021	TUMKUR	110	TR-2	HULIYAR_110	10:40	19:04	8:24	LINE CLEAR AVAILED
395	28-Jan-2021	TUMKUR	110	TR-1(LV SIDE)	NITTUR_220	17:11	18:42	1:31	TRANSFORMER FAULT
396	28-Jan-2021	TUMKUR	110	TR-2	SAMPIGE_110	12:31	13:24	0:52	LINE CLEAR AVAILED
397	28-Jan-2021	TUMKUR	110	TR-2	SAMPIGE_110	13:27	14:20	0:52	LINE CLEAR AVAILED
398	28-Jan-2021	TUMKUR	110	TR-2	SAMPIGE_110	15:20	15:44	0:24	LINE CLEAR AVAILED
399	28-Jan-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	10:41	12:30	1:49	LINE CLEAR AVAILED
400	28-Jan-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	10:41	12:27	1:46	LINE CLEAR AVAILED
401	28-Jan-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	10:41	12:28	1:47	LINE CLEAR AVAILED
402	28-Jan-2021	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	10:41	12:26	1:45	LINE CLEAR AVAILED
403	28-Jan-2021	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	10:42	12:28	1:45	LINE CLEAR AVAILED
404	28-Jan-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	DODDASARANGI_66,MELKOT E_66, BADDIHALLI_66, HONNUDIKE_66, HIREHALLY_66	10:40	12:32	1:51	LINE CLEAR AVAILED
405	28-Jan-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	10:21	10:23	0:02	HAND TRIPPED
406	28-Jan-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	13:43	13:45	0:02	HAND TRIPPED
407	28-Jan-2021	TUMKUR	66	TR-2	AVAREGERE_66	10:39	12:56	2:16	LINE CLEAR AVAILED
408	28-Jan-2021	TUMKUR	66	TR-2	AVAREGERE_66	13:06	13:54	0:47	LINE CLEAR AVAILED
409	28-Jan-2021	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	11:47	12:26	0:38	MAIN SUPPLY FAILURE
410	28-Jan-2021	TUMKUR	66	BELADADARA- ANTHRASANAHALLI	BELADARA_66	11:41	12:34	0:53	MAIN SUPPLY FAILURE
411	28-Jan-2021	TUMKUR	66	TR-1	CHIKKABANAGERE_66	11:40	12:15	0:34	LINE CLEAR AVAILED
412	28-Jan-2021	TUMKUR	66	TR-1	CHIKKABANAGERE_66	17:59	18:45	0:45	HAND TRIPPED
413	28-Jan-2021	TUMKUR	66	TR-2	CHIKKABANAGERE_66	7:37	18:45	11:07	TRANSFORMER FAULT
414	28-Jan-2021	TUMKUR	66	CHITRADURGA 220KV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	13:18	13:26	0:08	LINE FAULT
415	28-Jan-2021	TUMKUR	66	TR-1	HALURAMESHWARA_66	16:23	16:29	0:06	TRANSFORMER FAULT
416	28-Jan-2021	TUMKUR	66	TR-2	HINDASGHATTA_66	12:47	13:38	0:50	LINE CLEAR AVAILED
417	28-Jan-2021	TUMKUR	66	TR-2	HIREGUNTANUR_66	10:07	10:41	0:34	TRANSFORMER FAULT
418	28-Jan-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	4:06	4:09	0:03	HAND TRIPPED
419	28-Jan-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NE ELAGUNDA_66	15:30	15:32	0:01	HAND TRIPPED
420	28-Jan-2021	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	16:17	17:56	1:38	LINE CLEAR AVAILED
421	28-Jan-2021	TUMKUR	66	TR-2	LINGDHALLI_66	14:32	14:34	0:01	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
422	28-Jan-2021	TUMKUR	66	TR-2	MADHUGIRI_66	12:02	12:15	0:13	TRANSFORMER FAULT
423	28-Jan-2021	TUMKUR	66	MADANAYAKANAHALLI-CHITRADURGA220	MADANAYAKANAHALLI_66	18:33	18:36	0:03	LINE CLEAR AVAILED
424	28-Jan-2021	TUMKUR	66	TR-2	MADANAYAKANAHALLI_66	15:10	18:37	3:27	LINE CLEAR AVAILED
425	28-Jan-2021	TUMKUR	66	ANTHRASANAHALLI 220KV-MELEKOTE	DODDASARANGI_66,MELKOTE_66, BADDIHALLI_66, HONNUDIKE_66, HIREHALLI_66	10:58	12:31	1:33	MAIN SUPPLY FAILURE
426	28-Jan-2021	TUMKUR	66	BADDIHALLI- MELEKOTE	BADDIHALLI_66	12:27	12:33	0:05	HAND TRIPPED
427	28-Jan-2021	TUMKUR	66	TR-2	PAVAGADA_66	14:04	14:46	0:42	LINE CLEAR AVAILED
428	28-Jan-2021	TUMKUR	66	TR-1	TUMKUR_66	10:22	10:26	0:04	MAIN SUPPLY FAILURE
429	28-Jan-2021	TUMKUR	66	TR-1	TUMKUR_66	13:43	13:47	0:03	MAIN SUPPLY FAILURE
430	28-Jan-2021	TUMKUR	66	TR-2	TUMKUR_66	10:22	10:27	0:04	MAIN SUPPLY FAILURE
431	28-Jan-2021	TUMKUR	66	TR-2	TUMKUR_66	13:43	13:46	0:03	MAIN SUPPLY FAILURE
432	29-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
433	29-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
434	29-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
435	29-Jan-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN , LINE FAULT
436	29-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN, LINE CLEAR AVAILED
437	29-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
438	29-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
439	29-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT-NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
440	29-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
441	29-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
442	29-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
443	29-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
444	29-Jan-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVAILED
445	29-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	19:43 (26.01.2021)	8:52 (29.01.2021)	61:09HRS	LINE CHARGED
446	29-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	19:43 (26.01.2021)	8:52 (29.01.2021)	61:09HRS	LINE CHARGED
447	29-Jan-2021	BAGALKOT	110	ILKAL1- HUNGUND	STATION NOT AFFECTED HUNGUND_110	18:29 (28.01.2021)	11:45 (29.01.2021)	17:16HRS	LINE CHARGED
448	29-Jan-2021	BAGALKOT	110	ILKAL2- HUNGUND	STATION NOT AFFECTED HUNGUND_110	18:29 (28.01.2021)	11:45 (29.01.2021)	17:16HRS	LINE CHARGED
449	29-Jan-2021	BAGALKOT	220	220/110KV,HV2 & LV2	ATHANI_220	12:28	13:11	0:43	HAND TRIPPED
450	29-Jan-2021	BAGALKOT	220	220/110KV,HV2 & LV2	ATHANI_220	16:37	16:45	0:08	HAND TRIPPED
451	29-Jan-2021	BAGALKOT	220	220/110KV,HV2 & LV2	ATHANI_220	16:49	17:26	0:37	HAND TRIPPED
452	29-Jan-2021	BAGALKOT	220	ATHANI-MAHALINGAPUR	ATHANI_220	10:07	19:20	9:13	LINE CLEAR AVAILED
453	29-Jan-2021	BAGALKOT	110	ATHANI-AIGALI	AIGALI_110	16:02	16:09	0:07	HAND TRIPPED
454	29-Jan-2021	BAGALKOT	110	ATHANI-AIGALI	AIGALI_110	16:37	16:47	0:10	HAND TRIPPED
455	29-Jan-2021	BAGALKOT	110	ATHANI-SATTI	SATTI_110	16:02	16:09	0:07	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
456	29-Jan-2021	BAGALKOT	110	ATHANI-SATTI	SATTI_110	16:37	16:48	0:11	HAND TRIPPED
457	29-Jan-2021	BAGALKOT	110	110/11KV,HV	ATHANI_220	16:37	16:49	0:12	HAND TRIPPED
458	29-Jan-2021	BAGALKOT	110	CHIKKODI-NIPPANI	NIPPANI_110 & KADAKLAT_110	14:15	14:35	0:20	LINE FAULT
459	29-Jan-2021	BAGALKOT	220	BELGAUM-NARENDRA2 (KANABARGI2)	BELGAUM_220	10:18	17:13	6:55	LINE CLEAR AVAILED
460	29-Jan-2021	BAGALKOT	110	MAHALINGAPUR-DHAHALESHWAR	DHAHALESHWAR_110	0:50	11:47	10:57	LINE FAULT
461	29-Jan-2021	BAGALKOT	110	DHAHALESHWAR-SAIDAPUR	SAIDAPUR_110	12:20	12:29	0:09	HAND TRIPPED
462	29-Jan-2021	BAGALKOT	110	GADAG-LAXMESHWAR2	GADAG_110 (STATION NOT AFFECTED)	16:04	18:00	1:56	LINE CLEAR AVAILED
463	29-Jan-2021	BAGALKOT	110	110/3KV,HV3	GADAG_110 & PIONEER,NAGAVI,MALASAM UDRA,KAPPATGUDDA_33	9:44	19:15	9:31	LINE CLEAR AVAILED
464	29-Jan-2021	BAGALKOT	110	KUSHTAGI-GAJENDRAGAD	GAJENDRAGAD_110 (STATION NOT AFFECTED)	13:37	21:35	7:58	LINE CLEAR AVAILED
465	29-Jan-2021	BAGALKOT	110	110/33KV,HV2	KIRUVATTI-110 & YALLAPUR_33	13:23	14:03	0:40	TRANSFORMER FAULT
466	29-Jan-2021	BAGALKOT	110	LAXMESHWAR-GADAG1	LAXMESHWAR_110 (STATION NOT AFFECTED)	16:00	18:00	2:00	NFBC ISSUED
467	29-Jan-2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, HANLSANGI_33	01:44	02:13	0:29	TRANSFORMER FAULT
468	29-Jan-2021	BAGALKOT	110	110/11KV, HV2	TILUVALLI_110	08:12	08:26	0:14	TRANSFORMER FAULT
469	29-Jan-2021	BAGALKOT	110	110/11KV, HV2	TARIHAL_110	10:17	10:27	0:10	TRANSFORMER FAULT
470	29-Jan-2021	BAGALKOT	110	110/11KV, HV2	TARIHAL_110	19:38	21:34	1:56	TRANSFORMER FAULT
471	29-Jan-2021	BAGALKOT	110	110/11KV, HV2	TARIHAL_110	22:44	22:55	0:11	TRANSFORMER FAULT
472	29-Jan-2021	BAGALKOT	220	SHARAVATHY1&2- SIRSI	SIRSI_220	23:09	23:13	0:04	HAND TRIPPED
473	29-Jan-2021	BAGALKOT	110	SIRSI- SIDDAPUR	SIDDAPUR_110	16:42	17:12	0:30	LINE CLEAR AVAILED
474	29-Jan-2021	BAGALKOT	110	SIRSI-JOG	SIRSI_110	16:42	17:12	0:30	LINE CLEAR AVAILED
475	29-Jan-2021	BAGALKOT	110	HIREHAL- RON	RON_110	13:36	13:54	0:18	LINE CLEAR AVAILED
476	29-Jan-2021	BAGALKOT	110	RON- GAJENDRAGAD1&2	RON_110	13:40	13:54	0:14	LINE CLEAR AVAILED
477	29-Jan-2021	BAGALKOT	110	110/33KV, HV2	RATTIHALI_110, HALLUR_33, MASUR_33	09:04	09:10	0:06	TRANSFORMER FAULT
478	29-Jan-2021	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	15:04	17:20	2:16	LINE CLEAR AVAILED
479	29-Jan-2021	BAGALKOT	110	110/11KV, HV1	NAVALGUND_110	10:50	13:18	2:28	LINE CLEAR AVAILED
480	29-Jan-2021	BAGALKOT	110	NAREGAL- RON	RON_110	13:45	14:05	0:20	HAND TRIPPED
481	29-Jan-2021	BAGALKOT	110	110/11KV, HV2	MUDDEBIHAL_110	20:00	20:25	0:25	TRANSFORMER FAULT
482	29-Jan-2021	BAGALKOT	110	110/11KV, HV2	MALGHAN(S)_110	15:43	16:30	0:47	LINE CLEAR AVAILED
483	29-Jan-2021	BENGALURU	66	HV2	APPAREL PARK	14:45	14:58	00:13	TRANSFORMER FAULT
484	29-Jan-2021	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	18:41	18:50	00:09	MAIN SUPPLY FAILURE
485	29-Jan-2021	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	20:12	20:18	00:06	LOAD CHANGE OVER
486	29-Jan-2021	BENGALURU	66	BRIGADE MEADOWS - SOMANAHALLI 220	BRIGADE MEADOWS	11:37	11:44	00:07	LOAD CHANGE OVER
487	29-Jan-2021	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA	13:46	15:39	01:53	LINE CLEAR AVAILED
488	29-Jan-2021	BENGALURU	66	ISCON - SOMANAHALLI 220	ISCON	11:27	11:34	00:07	LOAD CHANGE OVER
489	29-Jan-2021	BENGALURU	66	ISCON - SUBRAMANYAPURA 220	ISCON	15:50	15:55	00:05	LOAD CHANGE OVER
490	29-Jan-2021	BENGALURU	66	HV1	NGEF	12:59	16:16	03:17	LINE CLEAR AVAILED
491	29-Jan-2021	BENGALURU	66	HV2	NGEF	12:59	16:16	03:17	LINE CLEAR AVAILED
492	29-Jan-2021	BENGALURU	66	HV1	PRIMAL	11:15	11:20	00:05	LINE CLEAR AVAILED
493	29-Jan-2021	BENGALURU	66	HV2	PRIMAL	13:37	13:40	00:03	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
494	29-Jan-2021	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	11:25	11:30	00:05	LOAD CHANGE OVER
495	29-Jan-2021	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	14:20	14:28	00:08	LOAD CHANGE OVER
496	29-Jan-2021	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	NO STATION AFFECTED	18:42	19:55	01:13	LINE FAULT
497	29-Jan-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	15:47	15:53	00:05	LINE FAULT
498	29-Jan-2021	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	07:13	07:35	00:22	LINE FAULT
499	29-Jan-2021	BENGALURU	66	HV1	VOLVO	06:05	06:25	00:20	TRANSFORMER FAULT
500	29-Jan-2021	BENGALURU	66	HV1	VOLVO	08:05	08:10	00:05	TRANSFORMER FAULT
501	29-Jan-2021	BENGALURU	66	HV1	PATH PALYA	08:54	09:08	00:13	LINE CLEAR AVOIDED
502	29-Jan-2021	BENGALURU	66	HV1	SM MANGALA	14:28	15:00	00:32	LINE CLEAR AVOIDED
503	29-Jan-2021	BENGALURU	66	KORAMANGALA 220 - HSR 1	NO STATION AFFECTED	18:37(29/01/2021)			LINE OPEN , LINE FAULT
504	29-Jan-2021	GULBARGA	220	HV1	KUSHTAGI_220	10:20(28.01.2021)			TRANSFORMER OPEN,LINE CLEAR AVOIDED
505	29-Jan-2021	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	23:10(29.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
506	29-Jan-2021	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HANU MANAL_110,HIREGONNAGAR 110	21:30(29.1.21)			LINE OPEN, LINE CLEAR AVOIDED
507	29-Jan-2021	GULBARGA	220	KUSHTAGI-LINGAPUR	KUSHTAGI_220	10:13	21:17	11:04	LINE CLEAR AVOIDED
508	29-Jan-2021	GULBARGA	220	KUSHTAGI-LINGASUGUR	KUSHTAGI_220	10:35	13:35	03:00	LINE CLEAR AVOIDED
509	29-Jan-2021	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	22:38	23:10	00:32	LINE FAULT
510	29-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	01:04	01:14	00:10	LINE FAULT
511	29-Jan-2021	GULBARGA	110	MALLAT-ALKOD	ALOKD_110	01:55	02:05	00:10	LINE FAULT
512	29-Jan-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	08:23	08:38	00:15	LINE FAULT
513	29-Jan-2021	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	06:30	06:35	00:05	LINE FAULT
514	29-Jan-2021	GULBARGA	110	HV2	SHAHAPUR_220	05:01	05:12	00:11	TRANSFORMER FAULT
515	29-Jan-2021	GULBARGA	110	HV2	SHAHAPUR_220	10:35	10:40	00:05	TRANSFORMER FAULT
516	29-Jan-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	11:04	13:28	02:24	LINE CLEAR AVOIDED
517	29-Jan-2021	GULBARGA	220	HV2	HUMNABAD_220	15:08	16:11	01:03	LINE CLEAR AVOIDED
518	29-Jan-2021	GULBARGA	220	HV1	HUMNABAD_220	15:30	15:55	00:25	LINE CLEAR AVOIDED
519	29-Jan-2021	GULBARGA	110	HV1	HUMNABAD_220	15:29	16:05	00:36	LINE CLEAR AVOIDED
520	29-Jan-2021	GULBARGA	220	LINGAPUR-JVSL-1	JVSL_220	08:47	18:54	10:07	LINE CLEAR AVOIDED
521	29-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALAKAMDI NI_110	11:50	11:55	00:05	LINE FAULT
522	29-Jan-2021	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110	16:09	16:11	00:02	MAIN SUPPLY FAILURE
523	29-Jan-2021	GULBARGA	110	RAICHUR-GABBUR	GABBUR_110	20:05	20:10	00:05	MAIN SUPPLY FAILURE
524	29-Jan-2021	GULBARGA	110	KHUSTAGI-HANUMASAGAR	HANUMASAGAR_110	17:21	21:10	03:49	MAIN SUPPLY FAILURE
525	29-Jan-2021	GULBARGA	110	ALIPUR-KUDITINI	KUDITINI_110	19:08	19:14	00:06	LINE FAULT
526	29-Jan-2021	GULBARGA	110	KOTTUR-UJJANI	UJJANI_66	16:50	16:55	00:05	LINE CLEAR AVOIDED
527	29-Jan-2021	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	17:25	17:51	00:26	MAIN SUPPLY FAILURE
528	29-Jan-2021	GULBARGA	220	HV2	KUSHTAGI_220	10:37	13:14	02:37	LINE CLEAR AVOIDED
529	29-Jan-2021	GULBARGA	220	HV2	KUSHTAGI_220	17:24	17:37	00:13	MAIN SUPPLY FAILURE
530	29-Jan-2021	GULBARGA	220	KUSHTAGI-SUZLON WIND1,2 IPP	KUSHTAGI_220	10:35	13:41	03:06	LINE CLEAR AVOIDED
531	29-Jan-2021	GULBARGA	220	KUSHTAGI-ASTRO WIND_IPP	KUSHTAGI_220	10:35	13:41	03:06	LINE CLEAR AVOIDED
532	29-Jan-2021	GULBARGA	220	KUSHTAGI-ASTRO WIND_IPP	KUSHTAGI_220	10:35	13:41	03:06	LINE CLEAR AVOIDED
533	29-Jan-2021	GULBARGA	220	KUSHTAGI-SUZLON WIND1,2 IPP	KUSHTAGI_220	20:40	21:20	00:40	LINE CLEAR AVOIDED
534	29-Jan-2021	GULBARGA	220	KUSHTAGI-ASTRO WIND_IPP	KUSHTAGI_220	20:40	21:20	00:40	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
535	29-Jan-2021	GULBARGA	220	KUSHTAGI-ASTRO WIND_IPP	KUSHTAGI_220	20:40	21:20	00:40	LINE CLEAR AVAILED
536	29-Jan-2021	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	20:03	20:14	00:11	LOAD CURTAILMENT
537	29-Jan-2021	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)	9:51(29.01.2021)	646:28 hrs	LINE CHARGED
538	29-Jan-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
539	29-Jan-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
540	29-Jan-2021	HASSAN	110	HV2	PUTTUR_110	10:17(26.1.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
541	29-Jan-2021	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	19:08 (29.01.2021)			LINE CLEAR AVAILED
542	29-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:37 (29.01.2021)			LINE OPEN, LINE CLEAR AVAILED
543	29-Jan-2021	HASSAN	220	MRSSHM-HONNALLI	MRSMG_220	11:40 (29.01.2021)			LINE OPEN, LINE CLEAR AVAILED
544	29-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	00:07	07:30	07:23	LINE CLEAR AVAILED
545	29-Jan-2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	11:12	15:05	03:53	LINE CLEAR AVAILED
546	29-Jan-2021	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	11:12	15:05	03:53	NFBC ISSUED
547	29-Jan-2021	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	08:52	08:53	00:01	HAND TRIPPED
548	29-Jan-2021	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	08:52	08:53	00:01	HAND TRIPPED
549	29-Jan-2021	HASSAN	110	HV1	BHADRAVATHI_110	09:40	10:08	00:28	LINE CLEAR AVAILED
550	29-Jan-2021	HASSAN	110	HV2	BHADRAVATHI_110	10:00	18:25	08:25	LINE CLEAR AVAILED
551	29-Jan-2021	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	10:00	13:40	03:40	LINE CLEAR AVAILED
552	29-Jan-2021	HASSAN	110	SAGARA-SORABA	SAGARA_110	09:10	09:45	00:35	HAND TRIPPED
553	29-Jan-2021	HASSAN	110	HV1	SHIVPURA_110	10:10	12:20	02:10	LINE CLEAR AVAILED
554	29-Jan-2021	HASSAN	66	HV1	ALDUR_66	11:12	12:29	01:17	LINE CLEAR AVAILED
555	29-Jan-2021	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	18:48	18:52	00:04	MAIN SUPPLY FAILURE
556	29-Jan-2021	HASSAN	66	HV1	BANDISHETTYHALLI_66	18:48	18:50	00:02	MAIN SUPPLY FAILURE
557	29-Jan-2021	HASSAN	66	HV1	DUDDA_110	07:15	07:26	00:11	TRANSFORMER FAULT
558	29-Jan-2021	HASSAN	66	HV1	GORUR_66	09:41	09:55	00:14	TRANSFORMER FAULT
559	29-Jan-2021	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	18:46	18:49	00:03	LINE FAULT
560	29-Jan-2021	HASSAN	66	HV1	HOLEHONNUR_66	07:41	11:12	03:31	LINE CLEAR AVAILED
561	29-Jan-2021	HASSAN	66	HV1	MAGGE_66	11:04	13:26	02:22	LINE CLEAR AVAILED
562	29-Jan-2021	HASSAN	66	HV1	SALAGAME_66	11:16	12:24	01:08	LINE CLEAR AVAILED
563	29-Jan-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	11:18	11:36	00:18	LINE FAULT
564	29-Jan-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	19:51	20:05	00:14	LINE FAULT
565	29-Jan-2021	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATION EFFECTED	11:37	11:44	0:06	LINE FAULT
566	29-Jan-2021	MYSURU	66	HV1	DODDABYADARAHALLI_66	10:56	11:20	0:23	LINE CLEAR AVAILED
567	29-Jan-2021	MYSURU	66	HV2	DODDABYADARAHALLI_66	11:22	12:14	0:52	LINE CLEAR AVAILED
568	29-Jan-2021	MYSURU	66	HV1	JAKKANAHALLY_66	11:02	13:10	2:07	LINE CLEAR AVAILED
569	29-Jan-2021	MYSURU	66	JYOTHINAGARA-DK MAIDANA	NO STATION EFFECTED	11:49	13:30	1:40	NFBC ISSUED
570	29-Jan-2021	MYSURU	66	KADAKOLA-RK NAGARA	NO STATION EFFECTED	14:21	15:37	1:15	LINE CLEAR AVAILED
571	29-Jan-2021	MYSURU	66	KADAKOLA-RK NAGARA	NO STATION EFFECTED	15:37	15:54	0:17	LINE CLEAR AVAILED
572	29-Jan-2021	MYSURU	66	HV2	MALAVALLI_66	11:01	17:37	6:35	LINE CLEAR AVAILED
573	29-Jan-2021	MYSURU	66	HV2	MALAVALLI_66	17:39	21:01	3:22	TRANSFORMER FAULT
574	29-Jan-2021	MYSURU	66	HV2	MALAVALLI_66	21:01	21:55	0:53	HAND TRIPPED
575	29-Jan-2021	MYSURU	66	VIJAYANAGARA-HOOTAGALLI	NO STATION EFFECTED	10:51	13:37	2:46	NFBC ISSUED
576	29-Jan-2021	MYSURU	66	HOOTAGALLI-FTS1	NO STATION EFFECTED	9:55	11:25	1:30	NFBC ISSUED
577	29-Jan-2021	MYSURU	66	VAJMANGALA-KADAKOLA 1	MARADIHUNDI_66 AYRALLI_66	18:40	18:45	0:05	LINE FAULT
578	29-Jan-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
579	29-Jan-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN, LINE CLEAR AVAILED
580	29-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020			LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
581	29-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE CLEAR AVAILED
582	29-Jan-2021	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	19:08	19:16	0:07	TRANSFORMER FAULT
583	29-Jan-2021	TUMKUR	110	TR-2	HULIYAR_110	10:45	18:07	7:21	LINE CLEAR AVAILED
584	29-Jan-2021	TUMKUR	110	TR-1	SHETYKERE_110	8:04	8:33	0:29	LINE CLEAR AVAILED
585	29-Jan-2021	TUMKUR	66	TR-1	BADAVANAHALLI_66	15:07	18:28	3:20	LINE CLEAR AVAILED
586	29-Jan-2021	TUMKUR	66	BADAVANAHALLI-MADHUGIRI	BADAVANAHALLI_66	15:12	18:24	3:11	LINE CLEAR AVAILED
587	29-Jan-2021	TUMKUR	66	BALENAHALLI- FEFCWIND IPP 66	FEFCWIND_IPP_66	13:06	19:32	6:25	LINE CLEAR AVAILED
588	29-Jan-2021	TUMKUR	66	TR-1	BENKIKERE_66	12:03	12:13	0:10	TRANSFORMER FAULT
589	29-Jan-2021	TUMKUR	66	TR-1	BENKIKERE_66	13:02	13:05	0:03	TRANSFORMER FAULT
590	29-Jan-2021	TUMKUR	66	CHIKKABANAGERE- GLOBAL TECKPARK	GLOBAL TECKPARK_IPP_66	18:11	21:08	2:56	LINE CLEAR AVAILED
591	29-Jan-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:28	9:40	0:12	LINE FAULT
592	29-Jan-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	13:48	14:05	0:16	LINE FAULT
593	29-Jan-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	20:11	20:21	0:10	LINE FAULT
594	29-Jan-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	14:58	15:14	0:15	LINE FAULT
595	29-Jan-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIR I_66, BASAVAPATNA_66	15:08	15:16	0:07	LINE FAULT
596	29-Jan-2021	TUMKUR	66	TR-1	MYLANAHALLI_66	7:14	7:28	0:14	TRANSFORMER FAULT
597	29-Jan-2021	TUMKUR	66	TR-1	TAVAREKERE(C)_66	11:17	15:46	4:28	LINE CLEAR AVAILED
598	29-Jan-2021	TUMKUR	66	TR-2	TAVAREKERE(C)_66	10:49	11:13	0:23	LINE CLEAR AVAILED
599	30-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
600	30-Jan-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUDDEBIHAL_110	7:04	7:12	0:08	TRANSFORMER FAULT
601	30-Jan-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED RON_110	21:50	22:36	0:46	TRANSFORMER FAULT
602	30-Jan-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUNDARGI_110	15:00	15:18	0:18	TRANSFORMER FAULT
603	30-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
604	30-Jan-2021	BAGALKOT	110	110/33KV,HV2	MATTIHAL_110,KOLAR WATER SUPPLY_33,NTPC_33,KARJOL LIS_110	16:20	16:25	0:05	TRANSFORMER FAULT
605	30-Jan-2021	BAGALKOT	110	110/33KV,HV2	MATTIHAL_110,KOLAR WATER SUPPLY_33,NTPC_33,KARJOL LIS_110	16:34	16:43	0:09	TRANSFORMER FAULT
606	30-Jan-2021	BAGALKOT	110	110/33KV,HV4	GADAG_110,HULIKOTI_33,LA KKUNDI_33&TDPL1_33,TDPL2 33,	15:26	19:16	3:50	LINE CLEAR AVAILED
607	30-Jan-2021	BAGALKOT	110	GADAG220-SHIRAHATTI	SHIRAHATTI_110	12:27	18:37	6:10	LINE CLEAR AVAILED
608	30-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
609	30-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA 110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
610	30-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA 110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
611	30-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVOIDED
612	30-Jan-2021	BAGALKOT	110	HAVERI220-BYADAGI	STATION NOT AFFECTED HAVERI 220	08:31	09:00	0:29	LINE FAULT
613	30-Jan-2021	BAGALKOT	110	HAVERI220-BYADAGI	STATION NOT AFFECTED HAVERI 220	09:27	15:18	5:51	LINE FAULT
614	30-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI 110	17:35 (29.12.2020)			LINE OPEN, LINE CLEAR AVOIDED
615	30-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT-NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT 110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
616	30-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
617	30-Jan-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI 110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
618	30-Jan-2021	BAGALKOT	110	NAREGAL-RON	RON_110	11:30	11:38	0:08	HAND TRIPPED
619	30-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND 110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVOIDED
620	30-Jan-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN , LINE FAULT
621	30-Jan-2021	BAGALKOT	110	RON-BELAVANKI	BELAVANKI_110	11:25	11:40	0:15	HAND TRIPPED
622	30-Jan-2021	BAGALKOT	110	RON-BELAVANKI	BELAVANKI_110	21:50	22:40	0:50	LINE FAULT
623	30-Jan-2021	BAGALKOT	110	RON-GAJENDRAGAD1&2	STATION NOT AFFECTED GAJENDRAGAD 110	11:25	11:40	0:15	HAND TRIPPED
624	30-Jan-2021	BAGALKOT	110	RON-GAMESH IPP	STATION NOT AFFECTED RON 110	11:23	11:47	0:24	HAND TRIPPED
625	30-Jan-2021	BAGALKOT	110	RON-HIREHAL	RON_110	11:43	11:46	0:03	HAND TRIPPED
626	30-Jan-2021	BAGALKOT	110	RON-HIREHAL	STATION NOT AFFECTED HIREHAL 110	21:50	23:10	1:20	LINE FAULT
627	30-Jan-2021	BAGALKOT	110	SUZLON-BYADAGI	STATION NOT AFFECTED BYADAGI 110	09:18	09:50	0:32	LINE CLEAR AVOIDED
628	30-Jan-2021	BAGALKOT	220	220/110KV,HV1,LV1	GADAG 220	13:04	18:35	5:31	LINE CLEAR AVOIDED
629	30-Jan-2021	BAGALKOT	220	ATHANI220-MAHALINGAPUR	STATION NOT AFFECTED ATHANI 220	13:10	18:35	5:25	LINE CLEAR AVOIDED
630	30-Jan-2021	BAGALKOT	220	DHONI-GADAG1	STATION NOT AFFECTED DHONI 400	12:38	14:31	1:53	NFBC ISSUED
631	30-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVOIDED
632	30-Jan-2021	BAGALKOT	220	GADAG-DHONI1	NO STATION AFFECTED GADAG 220	12:38	14:42	2:04	LINE CLEAR AVOIDED
633	30-Jan-2021	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI 220	00:35	18:09	17:34	LINE FAULT
634	30-Jan-2021	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI 220	13:26	13:38	0:12	LOAD CURTAILMENT
635	30-Jan-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI 220	4:30	13:33	9:03	LOAD CURTAILMENT
636	30-Jan-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI 220	13:34 (30.01.2021)			LOAD CURTAILMENT
637	30-Jan-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI 220	4:30 (30.01.2021)			LOAD CURTAILMENT
638	30-Jan-2021	BENGALURU	66	ALUR - NELAMANGALA	ALUR, BIEC	09:25	09:32	00:07	LOAD CHANGE OVER
639	30-Jan-2021	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR, BIEC	07:40	08:10	00:30	MAIN SUPPLY FAILURE
640	30-Jan-2021	BENGALURU	66	AMAR JYOTHI - HAL 220	AMAR JYOTHI	20:00	20:55	00:55	MAIN SUPPLY FAILURE
641	30-Jan-2021	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	17:58	18:14	00:16	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
642	30-Jan-2021	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	13:00	14:45	01:45	LINE CLEAR AVAILED
643	30-Jan-2021	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI	13:54	17:55	04:01	LINE CLEAR AVAILED
644	30-Jan-2021	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	SRINIVASPURA	13:54	14:05	00:11	LOAD CHANGE OVER
645	30-Jan-2021	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA, BEL (EHT), HMT (EHT)	09:05	09:13	00:08	LOAD CHANGE OVER
646	30-Jan-2021	BENGALURU	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT), HMT (EHT)	07:40	08:02	00:22	MAIN SUPPLY FAILURE
647	30-Jan-2021	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	07:40	08:02	00:22	MAIN SUPPLY FAILURE
648	30-Jan-2021	BENGALURU	66	GOLF LINK - HAL 220	GOLF LINK	20:00	20:30	00:30	MAIN SUPPLY FAILURE
649	30-Jan-2021	BENGALURU	66	HAL 220 - ADUGODI 1	NO STATION AFFECTED	19:59:00(30/01/2021)			LINE OPEN , LINE FAULT
650	30-Jan-2021	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	10:20	10:40	00:20	LOAD CHANGE OVER
651	30-Jan-2021	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	19:35	19:40	00:05	LOAD CHANGE OVER
652	30-Jan-2021	BENGALURU	66	HV1	HSR LAYOUT 220	07:37	07:52	00:15	TRANSFORMER FAULT
653	30-Jan-2021	BENGALURU	66	HV1	YELDUR	13:55	14:25	00:30	LOAD CHANGE OVER
654	30-Jan-2021	BENGALURU	66	HV1	YELDUR	17:55	18:05	00:10	LOAD CHANGE OVER
655	30-Jan-2021	BENGALURU	66	HV2	DOMMASANDRA	12:00	12:15	00:15	LINE CLEAR AVAILED
656	30-Jan-2021	BENGALURU	66	HV2	YELDUR	13:55	14:25	00:30	LOAD CHANGE OVER
657	30-Jan-2021	BENGALURU	66	HV2	YELDUR	17:55	18:05	00:10	LOAD CHANGE OVER
658	30-Jan-2021	BENGALURU	66	KORAMANGALA 220 - HSR 1	NO STATION AFFECTED	18:37(29/01/2021)			LINE OPEN , LINE FAULT
659	30-Jan-2021	BENGALURU	66	LEELA VENTURE - HAL 220	LEELA VENTURE	20:00:00(30/01/2021)			LINE OPEN, LINE CLEAR AVAILED
660	30-Jan-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	02:44	02:59	00:15	LINE FAULT
661	30-Jan-2021	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, BUDHIKOTE, TEKAL, KAMASAMUDRA, KYASAMBALLI, DODDAKARI, ANDERSONPET, BEML(EHT)	12:11	13:00	00:49	LINE CLEAR AVAILED
662	30-Jan-2021	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	13:10	13:15	00:05	LINE FAULT
663	30-Jan-2021	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	07:48	08:12	00:24	LOAD CHANGE OVER
664	30-Jan-2021	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	09:25	09:29	00:04	LOAD CHANGE OVER
665	30-Jan-2021	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	11:36	11:44	00:08	LOAD CHANGE OVER
666	30-Jan-2021	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	07:41	08:04	00:23	LOAD CHANGE OVER
667	30-Jan-2021	BENGALURU	66	PRESTIGE SHANTINIKETHAN - HOODY 220	PRESTIGE SHANTINIKETHAN	12:30	14:10	01:40	LINE CLEAR AVAILED
668	30-Jan-2021	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	07:50	07:55	00:05	LOAD CHANGE OVER
669	30-Jan-2021	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	15:48	15:52	00:04	LOAD CHANGE OVER
670	30-Jan-2021	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	13:06	13:14	00:08	LINE CLEAR AVAILED
671	30-Jan-2021	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	14:42	14:47	00:05	LINE CLEAR AVAILED
672	30-Jan-2021	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI	13:00	13:40	00:40	LINE CLEAR AVAILED
673	30-Jan-2021	BENGALURU	220	HV1	SRS PEENYA 220	07:40	15:42	08:02	TRANSFORMER FAULT
674	30-Jan-2021	BENGALURU	220	HV2	SRS PEENYA 220	07:40	08:50	01:10	TRANSFORMER FAULT
675	30-Jan-2021	BENGALURU	220	HV4	SRS PEENYA 220	07:40	08:43	01:03	TRANSFORMER FAULT
676	30-Jan-2021	GULBARGA	66	UJJAINI-WINDPOWER_IPP	UJJANI_66	21:10	22:15	01:05	LINE CLEAR AVAILED
677	30-Jan-2021	GULBARGA	110	GULBARGA UNIVERSITY- GULBARGA SOUTH	GULBARGA UNIVERSITY_110	12:55	13:35	00:40	LINE FAULT
678	30-Jan-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARG OAN_110,KAMALANAGAR_110	18:43	18:46	00:03	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
679	30-Jan-2021	GULBARGA	110	HV1	GURUMITAKAL_110	23:45	24:00:00	00:15	TRANSFORMER FAULT
680	30-Jan-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	18:40	18:50	00:10	LINE FAULT
681	30-Jan-2021	GULBARGA	110	KUSHTAGI-KUSHTAGISOLAR IPP	KUSHTAGI_220	6:06(29.01.2021)	7:30(30.01.2021)	25:24HRS	LINE CHARGED
682	30-Jan-2021	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	13:26	16:02	02:36	MAIN SUPPLY FAILURE
683	30-Jan-2021	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HANU MANAL_110,HIREGONNAGAR 110	21:30(29.1.21)	13:12(30.1.2021)	15:42 HRS	LINE CHARGED
684	30-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALAKAMDI NI_110	02:50	03:00	00:10	LINE FAULT
685	30-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALAKAMDI NI_110	18:20	18:38	00:18	LINE FAULT
686	30-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	18:41	18:51	00:10	LINE FAULT
687	30-Jan-2021	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	07:54	07:57	00:03	LINE FAULT
688	30-Jan-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HU NSAGI_110	02:21	02:27	00:06	LINE FAULT
689	30-Jan-2021	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	18:28	18:40	00:12	LINE FAULT
690	30-Jan-2021	GULBARGA	110	SINDHANOOR-MUKUND	SIRIGUPPA_110,TEKKALKOTE_ 110,DHADESUGUR_110	21:02	21:15	00:13	LINE FAULT
691	30-Jan-2021	GULBARGA	110	SINDHANOOR-RAICHUR1	VALKAMDINNI_110	6:30(20.01.2021)	7:54(30.1.2021)	241:24 hrs	LINE CHARGED
692	30-Jan-2021	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADLAPUR_110, KURDICROSS_110	00:38	00:58	00:20	LINE FAULT
693	30-Jan-2021	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	10:45	15:40	04:55	LINE CLEAR AVAILED
694	30-Jan-2021	GULBARGA	110	VALKAMDINNI-RAICHUR2	VALKAMDINNI_110	6:50(21.01.2021)	7:50(30.1.2021)	217:00 HRS	LINE CHARGED
695	30-Jan-2021	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	07:40	07:50	00:10	MAIN SUPPLY FAILURE
696	30-Jan-2021	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	09:10	18:45	09:35	NFBC ISSUED
697	30-Jan-2021	GULBARGA	220	HV1	KUSHTAGI_220	10:20(28.01.2021)	18:10(30.01.2021)	55:50HRS	TRANSFORMER CHARGED
698	30-Jan-2021	GULBARGA	220	HV2	KUSHTAGI_220	13:40	13:55	00:15	LINE CLEAR AVAILED
699	30-Jan-2021	GULBARGA	220	KUSHTAGI-LINGSUGUR	LINGASUGUR_220	13:30(30.01.2021)			LINE OPEN , LINE FAULT
700	30-Jan-2021	GULBARGA	220	KUSHTAGI-SUZLON1&2_IPP	KUSHTAGI_220	13:40	14:12	00:32	LINE CLEAR AVAILED
701	30-Jan-2021	GULBARGA	220	LINGAPUR-JVSL-1	JVSL_220	09:09	17:19	08:10	LINE CLEAR AVAILED
702	30-Jan-2021	GULBARGA	220	LINGAPUR-JVSL-2	LINGAPUR_220	14:48	18:06	03:18	LINE CLEAR AVAILED
703	30-Jan-2021	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	23:10(29.01.2021)			LINE OPEN, LINE CLEAR AVAILED
704	30-Jan-2021	HASSAN	66	CHANNAR-SNVRSNT	YESLUR_66	22:25	22:30	00:05	MAIN SUPPLY FAILURE
705	30-Jan-2021	HASSAN	66	HV1	YESLUR_66	22:25	22:30	00:05	MAIN SUPPLY FAILURE
706	30-Jan-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
707	30-Jan-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
708	30-Jan-2021	HASSAN	66	MAALI-CRPATNA	MALALI_66	23:14	23:24	00:10	LINE FAULT
709	30-Jan-2021	HASSAN	110	HV1	GANDASI_110	09:12	09:29	00:17	TRANSFORMER FAULT
710	30-Jan-2021	HASSAN	110	HV1	TALAGUPPA_400	11:39	15:47	04:08	LINE CLEAR AVAILED
711	30-Jan-2021	HASSAN	110	HV2	PUTTUR_110	10:17(26.1.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
712	30-Jan-2021	HASSAN	110	HV2	HALADY_110	13:28	13:48	00:20	TRANSFORMER FAULT
713	30-Jan-2021	HASSAN	110	HV3	HIRIYADKIA_110	07:41	07:47	00:06	TRANSFORMER FAULT
714	30-Jan-2021	HASSAN	110	SAGARA-TAL	SAGARA_110	10:23	12:27	02:04	LINE CLEAR AVAILED
715	30-Jan-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	20:03	21:23	01:20	LINE FAULT
716	30-Jan-2021	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	20:03	21:24	01:21	LINE FAULT
717	30-Jan-2021	HASSAN	220	MRSSHM-HONNALLI	MRSMG_220	11:40 (29.01.2021)			LINE OPEN, LINE CLEAR AVAILED
718	30-Jan-2021	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	08:48	11:19	02:31	LINE CLEAR AVAILED
719	30-Jan-2021	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	19:08 (29.01.2021)			LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
720	30-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:37 (29.01.2021)	7:23 (30.01.2021)	7:45 hrs	LINE CHARGED
721	30-Jan-2021	MYSURU	66	BG NAGARA-ANCHEPALYA	ADICHUNCHANAGIRI_66 VADERALLI_66	1:15	1:25	0:09	LINE FAULT
722	30-Jan-2021	MYSURU	66	CR NAGARA-DR PETE 1	NO STATION EFFECTED	12:04	17:48	5:44	LINE CLEAR AVAILED
723	30-Jan-2021	MYSURU	66	DATAGALLY-RK NAGARA	NO STATION EFFECTED	10:07	16:39	6:31	LINE CLEAR AVAILED
724	30-Jan-2021	MYSURU	66	HV2	HAMPAPURA_66	12:45	14:31	1:46	LINE CLEAR AVAILED
725	30-Jan-2021	MYSURU	66	HV2	NAGAMANGALA_66	10:35	12:45	2:10	LINE CLEAR AVAILED
726	30-Jan-2021	MYSURU	66	HV2	SHIVALLY_66	15:00	16:30	1:30	LINE CLEAR AVAILED
727	30-Jan-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN, LINE CLEAR AVAILED
728	30-Jan-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
729	30-Jan-2021	MYSURU	66	RK NAGARA-DATAGALLI	NO STATION EFFECTED	20:10 (30/01/2021)			LINE OPEN, LINE CLEAR AVAILED
730	30-Jan-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATION EFFECTED	16:39	20:10	3:30	LINE CLEAR AVAILED
731	30-Jan-2021	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	1:16	1:21	0:04	LINE FAULT
732	30-Jan-2021	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	13:31	13:40	0:08	LINE CLEAR AVAILED
733	30-Jan-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	13:58	14:24	0:26	LINE FAULT
734	30-Jan-2021	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	07:35	07:47	0:12	LINE FAULT
735	30-Jan-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:06	16:43	2:37	LINE CLEAR AVAILED
736	30-Jan-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	17:36	17:56	0:19	HAND TRIPPED
737	30-Jan-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	17:32	17:44	0:12	HAND TRIPPED
738	30-Jan-2021	TUMKUR	66	TR-1	CHANNAGIRI_66	23:05	23:15	0:09	TRANSFORMER FAULT
739	30-Jan-2021	TUMKUR	66	TR-1	HIREGUNTANUR_66	12:15	13:53	1:37	LINE CLEAR AVAILED
740	30-Jan-2021	TUMKUR	66	TR-1	IDHALLY_66	12:40	12:50	0:10	LINE CLEAR AVAILED
741	30-Jan-2021	TUMKUR	66	TR-1	BENKIKERE_66	00:05	00:11	0:06	TRANSFORMER FAULT
742	30-Jan-2021	TUMKUR	66	TR-1	HIREGUNTANUR_66	09:16	13:24	4:07	LINE CLEAR AVAILED
743	30-Jan-2021	TUMKUR	66	TR-1	HIREGUNTANUR_66	16:40	17:33	0:53	LINE CLEAR AVAILED
744	30-Jan-2021	TUMKUR	66	TR-2	HIREGUNTANUR_66	12:15	13:53	1:37	LINE CLEAR AVAILED
745	30-Jan-2021	TUMKUR	66	TR-2	IDHALLY_66	12:32	12:50	0:18	LINE CLEAR AVAILED
746	30-Jan-2021	TUMKUR	66	TR-2	LINGDHALLI_66	09:10	11:46	2:36	LINE CLEAR AVAILED
747	30-Jan-2021	TUMKUR	66	TR-2	LINGADAHALLI_66 (SHYLAPURA)	14:03	15:15	1:12	LINE CLEAR AVAILED
748	30-Jan-2021	TUMKUR	66	TR-2	LINGADAHALLI_66 (SHYLAPURA)	14:15	15:15	1:00	LINE CLEAR AVAILED
749	30-Jan-2021	TUMKUR	66	TR-2	DAVANAGERE_66	04:35	05:29	0:53	TRANSFORMER FAULT
750	30-Jan-2021	TUMKUR	66	TR-2	DAVANAGERE_66	05:52	06:15	0:23	TRANSFORMER FAULT
751	30-Jan-2021	TUMKUR	66	TR-2	HIREGUNTANUR_66	09:16	13:24	4:07	LINE CLEAR AVAILED
752	30-Jan-2021	TUMKUR	66	TR-2	HIREGUNTANUR_66	16:40	17:33	0:53	LINE CLEAR AVAILED
753	30-Jan-2021	TUMKUR	66	TR-2	HOLALKERE_66	23:12	23:19	0:07	HAND TRIPPED
754	30-Jan-2021	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	00:41	01:13	0:31	LINE CLEAR AVAILED
755	30-Jan-2021	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110	11:04	11:09	0:04	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
756	30-Jan-2021	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETTYKERE_110	12:13	12:19	0:06	LINE CLEAR AVAILED
757	30-Jan-2021	TUMKUR	110	TR-2	HULIYAR_110	10:34	18:12	7:37	LINE CLEAR AVAILED
758	30-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE CLEAR AVAILED
759	30-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE CLEAR AVAILED
760	30-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE CLEAR AVAILED
761	30-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE CLEAR AVAILED
762	31-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
763	31-Jan-2021	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	10:51	12:02	1:11	LINE CLEAR AVAILED
764	31-Jan-2021	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	17:45	18:58	1:13	LINE CLEAR AVAILED
765	31-Jan-2021	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	19:00	19:30	0:30	TRANSFORMER FAULT
766	31-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
767	31-Jan-2021	BAGALKOT	110	110/11KV,HV2	KALAGATAGI_110	17:33	17:53	0:20	LINE CLEAR AVAILED
768	31-Jan-2021	BAGALKOT	110	110/11KV,HV2	KALAGATAGI_110	18:25	18:34	0:09	TRANSFORMER FAULT
769	31-Jan-2021	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	03:21	03:33	0:12	HAND TRIPPED
770	31-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
771	31-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
772	31-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
773	31-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
774	31-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN, LINE CLEAR AVAILED
775	31-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT-NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
776	31-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
777	31-Jan-2021	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	10:27 (29.01.2021)	21:02 (31.01.2021)	58:35 hrs	LINE CHARGED
778	31-Jan-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVAILED
779	31-Jan-2021	BAGALKOT	110	MK HUBLI-KITTUR	STATION NOT AFFECTED MK HUBLI_110	9:03 (31.01.2021)			LINE OPEN, LINE CLEAR AVAILED
780	31-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
781	31-Jan-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN , LINE FAULT
782	31-Jan-2021	BAGALKOT	110	UTTUR-YADAWAD	YADAWAD_110	06:06	06:19	0:13	LINE FAULT
783	31-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	02:10	08:31	6:21	LOAD CURTAILMENT
784	31-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	20:24 (31.01.2021)			LOAD CURTAILMENT
785	31-Jan-2021	BAGALKOT	220	BELGAUM-KANABARGI2	STATION NOT AFFECTED BELGAUM_220	20:23 (31.01.2021)			LOAD CURTAILMENT
786	31-Jan-2021	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	20:25 (31.01.2021)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
787	31-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
788	31-Jan-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
789	31-Jan-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
790	31-Jan-2021	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	STATION NOT AFFECTED VAJRAMATTI_220	20:57	22:50	1:53	LINE FAULT
791	31-Jan-2021	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	STATION NOT AFFECTED VAJRAMATTI_220	23:06 (31.01.2021)			LINE OPEN , LINE FAULT
792	31-Jan-2021	BAGALKOT	220	VAJRAMATTI-ENERCON IPP	STATION NOT AFFECTED VAJRAMATTI_220	21:40 (31.01.2021)			LINE OPEN , LINE FAULT
793	31-Jan-2021	GULBARGA	66	HV1	HAMPASAGAR_66	14:35	14:40	00:05	TRANSFORMER FAULT
794	31-Jan-2021	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	12:40	12:55	00:15	LINE FAULT
795	31-Jan-2021	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	13:45	14:05	00:20	LINE FAULT
796	31-Jan-2021	GULBARGA	110	GABUR-RAICHUR	GABUR_110	21:45	21:57	00:12	MAIN SUPPLY FAILURE
797	31-Jan-2021	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	00:00	00:05	00:05	LINE FAULT
798	31-Jan-2021	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	20:55	20:58	00:03	MAIN SUPPLY FAILURE
799	31-Jan-2021	GULBARGA	110	HIREGONNAGAR-HANUMANAL	HANUMANAL_110	10:35	11:30	00:55	MAIN SUPPLY FAILURE
800	31-Jan-2021	GULBARGA	110	HV1	HANUMANAL_110	06:50	07:50	01:00	LINE CLEAR AVAILED
801	31-Jan-2021	GULBARGA	110	HV2	BISIHALLI_110	10:35	10:47	00:12	TRANSFORMER FAULT
802	31-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALAKAMDI NI_110	19:43	19:58	00:15	LINE FAULT
803	31-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	06:12	06:39	00:27	LINE FAULT
804	31-Jan-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HU NSAGI_110	04:59	05:00	00:01	LINE FAULT
805	31-Jan-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	04:49	04:59	00:10	LINE FAULT
806	31-Jan-2021	GULBARGA	110	SINDHANOOR-RAICHUR1	VALKAMDINNI_110	6:30(20.01.2021)	7:54(30.1.2021)	241:24 hrs	LINE CHARGED
807	31-Jan-2021	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	18:08	18:25	00:17	LINE FAULT
808	31-Jan-2021	GULBARGA	220	BMM ISPAT-LINGAPUR	LINGAPUR_220	18:02	18:42	00:40	LINE FAULT
809	31-Jan-2021	GULBARGA	220	HV1	KUSHTAGI_220	10:15	11:15	01:00	TRANSFORMER FAULT
810	31-Jan-2021	GULBARGA	220	HV1	KUSHTAGI_220	10:15	11:50	01:35	TRANSFORMER FAULT
811	31-Jan-2021	GULBARGA	220	HV2	ITTAGGI_220	18:02	18:10	00:08	TRANSFORMER FAULT
812	31-Jan-2021	GULBARGA	220	KUSHTAGI-LINGSUGUR	LINGASUGUR_220	13:30(30.01.2021)			LINE OPEN , LINE FAULT
813	31-Jan-2021	GULBARGA	220	MALLAT-LINGASUGUR	LINGASUGUR_220	20:40	21:30	00:50	LINE FAULT
814	31-Jan-2021	GULBARGA	220	MALLAT-RTPS	MALLAT_220	06:18	06:38	00:20	LINE FAULT
815	31-Jan-2021	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	23:10(29.01.2021)			LINE OPEN, LINE CLEAR AVAILED
816	31-Jan-2021	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220,MALLAT_2 20	06:18	06:38	00:20	LINE FAULT
817	31-Jan-2021	GULBARGA	220	RTPS-SHAHAPUR2	SHAHAPUR_220	01:11	01:25	00:14	LINE FAULT
818	31-Jan-2021	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	21:10	21:54	00:44	LINE FAULT
819	31-Jan-2021	GULBARGA	220	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	20:55	21:10	00:15	LINE FAULT
820	31-Jan-2021	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	22:29	22:31	00:02	LINE FAULT
821	31-Jan-2021	HASSAN	66	BASAVAG-DUDDA	BASAVAGHATTA_66	11:13	12:14	01:01	MAIN SUPPLY FAILURE
822	31-Jan-2021	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	14:30	15:05	00:35	LINE FAULT
823	31-Jan-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	14:30	15:15	00:45	LINE FAULT
824	31-Jan-2021	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	14:30	14:55	00:25	LINE FAULT
825	31-Jan-2021	HASSAN	66	LV2	MRS MG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
826	31-Jan-2021	HASSAN	66	LV4	MRS MG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
827	31-Jan-2021	HASSAN	110	HV1	SAGARA_110	11:34	12:07	00:33	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
828	31-Jan-2021	HASSAN	110	HV2	PUTTUR_110	10:17(26.1.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
829	31-Jan-2021	HASSAN	220	MRSSHM-HONNALLI	MRSMG_220	11:40 (29.01.2021)			LINE OPEN, LINE CLEAR AVAILED
830	31-Jan-2021	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	19:08 (29.01.2021)			LINE CLEAR AVAILED
831	31-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	18:17 (31.01.2021)			LINE OPEN, LINE CLEAR AVAILED
832	31-Jan-2021	MYSURU	66	BILIKERE-GV GUDI	GVGUDI_66	7:30	7:38	0:08	LINE FAULT
833	31-Jan-2021	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATION EFFECTED	9:34	9:39	0:04	LINE FAULT
834	31-Jan-2021	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATION EFFECTED	15:06	15:12	0:06	LINE FAULT
835	31-Jan-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN, LINE CLEAR AVAILED
836	31-Jan-2021	MYSURU	66	KADAKOLA-SARGURU 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66	7:01	7:06	0:05	LINE FAULT
837	31-Jan-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
838	31-Jan-2021	MYSURU	66	KUSHALANAGARA 220- BETTADAPURA	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	6:42	7:00	0:17	LINE FAULT
839	31-Jan-2021	MYSURU	66	MADHUVANAHALLY-HEBBANI	NO STATION EFFECTED	18:18	18:24	0:05	LINE FAULT
840	31-Jan-2021	MYSURU	66	RK NAGARA-DATAGALLI	NO STATION EFFECTED	20:10 (30/01/2021)			LINE OPEN, LINE CLEAR AVAILED
841	31-Jan-2021	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66	4:38	4:45	0:07	LINE FAULT
842	1-Feb-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
843	1-Feb-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
844	1-Feb-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
845	1-Feb-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN , LINE FAULT
846	1-Feb-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN, LINE CLEAR AVAILED
847	1-Feb-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
848	1-Feb-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
849	1-Feb-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
850	1-Feb-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
851	1-Feb-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
852	1-Feb-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
853	1-Feb-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
854	1-Feb-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVAILED
855	1-Feb-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
856	1-Feb-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
857	1-Feb-2021	BAGALKOT	220	BELGAUM-KANABARGI2	STATION NOT AFFECTED BELGAUM_220	20:23 (31.01.2021)	7:52 (01.02.2021)	11:29hrs	LINE CHARGED
858	1-Feb-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	20:24 (31.01.2021)	8:10 (01.02.2021)	11:46hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
859	1-Feb-2021	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED CHIKKODI 220	20:25 (31.01.2021)	8:10 (01.02.2021)	11:45hrs	LINE CHARGED
860	1-Feb-2021	BAGALKOT	110	MK HUBLI-KITTUR	STATION NOT AFFECTED MK HUBLI 110	9:03 (31.01.2021)	12:45 (01.02.2021)	27:42hrs	LINE CHARGED
861	1-Feb-2021	BAGALKOT	220	VAJRAMATTI-ENERCON IPP	STATION NOT AFFECTED VAJRAMATTI 220	21:40 (31.01.2021)	2:25 (01.02.2021)	4:45hrs	LINE CHARGED
862	1-Feb-2021	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	STATION NOT AFFECTED VAJRAMATTI 220	23:06 (31.01.2021)	2:34 (01.02.2021)	3:28hrs	LINE CHARGED
863	1-Feb-2021	BAGALKOT	220	ATHANI-MAHALINGAPUR	STATION NOT AFFECTED ATHANI 220	10:18	14:40	4:22	LINE CLEAR AVAILED
864	1-Feb-2021	BAGALKOT	110	110/11KV,HV1(HV2)	ANKOLA 110,MASIKATTA_33 &SEA BIRD 33	13:17	13:23	0:06	TRANSFORMER FAULT
865	1-Feb-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR(B)_110	06:40	06:58	0:18	LINE FAULT
866	1-Feb-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR(B)_110	06:40	06:58	0:18	LINE FAULT
867	1-Feb-2021	BAGALKOT	220	BAGALKOT-GADAG2	STATION NOT AFFECTED BAGALKOT 220	10:33	13:23	2:50	NFBC ISSUED
868	1-Feb-2021	BAGALKOT	220	BAGALKOT-GADAG1	STATION NOT AFFECTED BAGALKOT 220	10:34	13:22	2:48	NFBC ISSUED
869	1-Feb-2021	BAGALKOT	220	BAGEWADI-RBRK	STATION NOT AFFECTED BAGEWADI 220	11:05	11:14	0:09	LINE FAULT
870	1-Feb-2021	BAGALKOT	220	NARENDRA-AMBEWADI1	STATION NOT AFFECTED NARENDRA 220	14:43	16:54	2:11	LINE CLEAR AVAILED
871	1-Feb-2021	BAGALKOT	110	110/33KV, HV3	RATTIHALLI_110, MASUR_33, & HALLUR 33	10:00	12:15	2:15	LINE CLEAR AVAILED
872	1-Feb-2021	BAGALKOT	110	110/33KV, HV3	RATTIHALLI_110, MASUR_33, & HALLUR 33	12:00	17:43	5:43	LINE CLEAR AVAILED
873	1-Feb-2021	BAGALKOT	110	110/11KV, HV2	RATTIHALLI 110	10:00	17:43	7:43	LINE CLEAR AVAILED
874	1-Feb-2021	BAGALKOT	110	110/11KV, HV1	RATTIHALLI 110	13:05	17:40	4:35	LINE CLEAR AVAILED
875	1-Feb-2021	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMATA 110	19:03			LINE OPEN, LINE CLEAR AVAILED
876	1-Feb-2021	BAGALKOT	110	KUMTA-SIRSI2	STATION NOT AFFECTED KUMATA 110	19:01			LINE OPEN, LINE CLEAR AVAILED
877	1-Feb-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KUD DHARWAD 110	20:49			TRANSFORMER OPEN, TRANSFORMER FAULT
878	1-Feb-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED BILAGI 110	15:30	17:23	1:53	LINE CLEAR AVAILED
879	1-Feb-2021	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED BILAGI 110	15:30	17:33	2:03	LINE CLEAR AVAILED
880	1-Feb-2021	BENGALURU	66	GOLF LINK - KORAMANGALA 220	GOLF LINK	15:00	15:07	00:07	LOAD CHANGE OVER
881	1-Feb-2021	BENGALURU	66	HV2	KADUGODI	13:45	13:50	00:05	LINE CLEAR AVAILED
882	1-Feb-2021	BENGALURU	66	KODIGEHALLI - TAVAREKERE	TAVAREKERE	13:37	15:37	02:00	LINE CLEAR AVAILED
883	1-Feb-2021	BENGALURU	66	HV2	LEELA VENTURE	17:04	17:06	00:02	LOAD CHANGE OVER
884	1-Feb-2021	BENGALURU	66	HV1	AGALAKOTE	16:20	16:32	00:12	TRANSFORMER FAULT
885	1-Feb-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	06:37	06:53	00:16	LINE FAULT
886	1-Feb-2021	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	08:12	08:57	00:45	LINE FAULT
887	1-Feb-2021	BENGALURU	66	DEVANAHALLI - DB PURA 2	DEVANAHALLI	06:37	06:53	00:15	LINE FAULT
888	1-Feb-2021	BENGALURU	66	DOMMASANDRA - KACHMARANAHALLI	DOMMASANDRA	15:30	15:40	00:10	LINE CLEAR AVAILED
889	1-Feb-2021	BENGALURU	66	DOMMASANDRA - KACHMARANAHALLI	DOMMASANDRA	17:55	18:15	00:20	LINE CLEAR AVAILED
890	1-Feb-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:24	12:30	00:06	LINE FAULT
891	1-Feb-2021	BENGALURU	66	HV2	SOMAYAJJANAHALLI	20:53	21:13	00:20	TRANSFORMER FAULT
892	1-Feb-2021	BENGALURU	66	KORAMANGALA 220 - HSR 1	NO STATION AFFECTED	18:37(29/01/2021)			LINE OPEN , LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
893	1-Feb-2021	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	23:10(29.01.2021)			LINE OPEN, LINE CLEAR AVAILED
894	1-Feb-2021	GULBARGA	220	KUSHTAGI-LINGSUGUR	LINGASUGUR_220	13:30(30.01.2021)	17:55(1.2.2021)	59:25 HRS	LINE FAULT
895	1-Feb-2021	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	11:43	13:48	02:05	LINE CLEAR AVAILED
896	1-Feb-2021	GULBARGA	110	HV2	BISIHALLI_110	13:58	14:05	00:07	TRANSFORMER FAULT
897	1-Feb-2021	GULBARGA	110	LV1	RAICHUR_220	06:53	07:15	00:22	TRANSFORMER FAULT
898	1-Feb-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABUR_110,DEODURGA_110	06:30	06:35	00:05	LINE FAULT
899	1-Feb-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABUR_110,DEODURGA_110	06:43	11:03	04:20	LINE FAULT
900	1-Feb-2021	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	00:18	00:28	00:10	LINE FAULT
901	1-Feb-2021	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADLAPUR_110, KURDICROSS_110	05:30	05:55	00:25	LINE FAULT
902	1-Feb-2021	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	05:46	06:01	00:15	LINE FAULT
903	1-Feb-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALAKAMDI NI_110	23:57(1.02.2021)	00:07(02.02.2021)	0:10hrs	LINE FAULT
904	1-Feb-2021	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADLAPUR_110, KURDICROSS_110	22:20	22:30	00:10	LINE FAULT
905	1-Feb-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABUR_110,DEODURGA_110	17:32	17:43	00:11	LINE FAULT
906	1-Feb-2021	GULBARGA	66	HV1	CHORNOOR_66	09:30	10:35	01:05	TRANSFORMER FAULT
907	1-Feb-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
908	1-Feb-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
909	1-Feb-2021	HASSAN	110	HV2	PUTTUR_110	10:17(26.1.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
910	1-Feb-2021	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	19:08 (29.01.2021)			LINE CLEAR AVAILED
911	1-Feb-2021	HASSAN	220	MRSSHM-HONNALLI	MRSMG_220	11:40 (29.01.2021)			LINE OPEN, LINE CLEAR AVAILED
912	1-Feb-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	18:17 (31.01.2021)	6:49(01.2.2021)	12:32hrs	LINE CHARGED
913	1-Feb-2021	HASSAN	220	MRSSHM-HSN4001	MRSMG_220	14:09	16:56	02:47	LINE FAULT
914	1-Feb-2021	HASSAN	66	MRSSHM-DVG2	MRSMG_220	14:57	15:11	00:14	LINE FAULT
915	1-Feb-2021	HASSAN	66	MRSSHMDVG2	MRSMG_220	16:41	16:53	00:12	LINE FAULT
916	1-Feb-2021	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	11:26	15:18	03:52	LINE CLEAR AVAILED
917	1-Feb-2021	HASSAN	110	HV1	SAGARA_110	11:11	11:48	00:37	LINE CLEAR AVAILED
918	1-Feb-2021	HASSAN	66	HV1	BYCHANAHALLY_66	21:00	21:10	00:10	TRANSFORMER FAULT
919	1-Feb-2021	HASSAN	66	HV1	BYCHANAHALLY_66	18:30	18:35	00:05	TRANSFORMER FAULT
920	1-Feb-2021	HASSAN	66	HV2	KANDLI_66	10:51	12:40	01:49	LINE CLEAR AVAILED
921	1-Feb-2021	MYSURU	66	HV1	KABHALLY_66	11:07	11:11	0:03	TRANSFORMER FAULT
922	1-Feb-2021	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	16:23	16:25	0:02	LINE FAULT
923	1-Feb-2021	MYSURU	220	MADHUVANAHALLI-CR NAGARA-2	NO STATION EFFECTED	12:46	13:15	0:29	LINE FAULT
924	1-Feb-2021	MYSURU	66	HV1	MADHUVANAHALLI_220	16:52 (01/02/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
925	1-Feb-2021	MYSURU	66	HV1	MALAVALLI_66	11:08	13:00	1:51	LINE CLEAR AVAILED
926	1-Feb-2021	MYSURU	66	HV1	MALAVALLI_66	18:14	18:23	0:09	LINE CLEAR AVAILED
927	1-Feb-2021	MYSURU	66	HV2	MALAVALLI_66	13:13	14:01	0:48	LINE CLEAR AVAILED
928	1-Feb-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	16:40	17:00	0:20	HAND TRIPPED
929	1-Feb-2021	MYSURU	66	HV2	SRIRANGAPATNA_66	16:40	17:00	0:20	HAND TRIPPED
930	1-Feb-2021	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN, LINE CLEAR AVAILED
931	1-Feb-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN, LINE CLEAR AVAILED
932	1-Feb-2021	MYSURU	66	RK NAGARA-DATAGALLI	NO STATION EFFECTED	20:10 (30/01/2021)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
933	1-Feb-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE CLEAR AVAILED
934	1-Feb-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE CLEAR AVAILED
935	1-Feb-2021	TUMKUR	66	ANCHEPALYA 220kv- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE 66	12:37	12:44	0:06	HAND TRIPPED
936	1-Feb-2021	TUMKUR	66	BADAVANAHALLI-MADHUGIRI	BADAVANAHALLI_66	22:31	22:59	0:27	LINE FAULT
937	1-Feb-2021	TUMKUR	66	TR-1	BELADARA_66	13:50	14:13	0:23	LINE CLEAR AVAILED
938	1-Feb-2021	TUMKUR	66	TR-1	CHITRADURGA_66	6:03	7:32	1:29	TRANSFORMER FAULT
939	1-Feb-2021	TUMKUR	66	TR-1	CHITRADURGA_66	16:59	18:23	1:23	LINE CLEAR AVAILED
940	1-Feb-2021	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	15:20	15:36	0:16	LINE FAULT
941	1-Feb-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI 66	16:39	16:44	0:04	LINE FAULT
942	1-Feb-2021	TUMKUR	66	TR-2	HULIYURDURGA_66	12:29	12:33	0:04	HAND TRIPPED
943	1-Feb-2021	TUMKUR	66	TR-1	KUKKAWADA_66	16:20	17:23	1:02	LINE CLEAR AVAILED
944	1-Feb-2021	TUMKUR	66	TR-1	LINGDHALLI_66	16:01	16:19	0:17	LINE CLEAR AVAILED