

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM: 25.05.21 TO 31.05.2021

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	25-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
2	25-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVOIDED
3	25-May-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
4	25-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVOIDED
5	25-May-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVOIDED
6	25-May-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
7	25-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
8	25-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVOIDED
9	25-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVOIDED
10	25-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVOIDED
11	25-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVOIDED
12	25-May-2021	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	18:07 (18.05.2021)			LINE OPEN, LINE FAULT
13	25-May-2021	BAGALKOT	220	BIDNAL-HARTI 2	BIDNAL_220	17:55 (23.05.2021)			LINE OPEN,LINE CLEAR AVOIDED
14	25-May-2021	BAGALKOT	110	110/11KV, HV1	BABALESHWAR_110	16:50	18:17	1:27	LINE CLEAR AVOIDED
15	25-May-2021	BAGALKOT	110	110/11KV, HV1	BABALESHWAR_110	18:42	18:48	0:06	LINE CLEAR AVOIDED
16	25-May-2021	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	11:02	13:55	2:53	LINE CLEAR AVOIDED
17	25-May-2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	10:26	10:30	0:04	TRANSFORMER FAULT
18	25-May-2021	BAGALKOT	110	110/11KV, HV1	TUMMINKATTI_110	16:00	18:02	2:02	LINE CLEAR AVOIDED
19	25-May-2021	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	10:05	10:11	0:06	HAND TRIPPED
20	25-May-2021	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	10:22	10:35	0:13	HAND TRIPPED
21	25-May-2021	BAGALKOT	110	110/11KV, HV1	KHANAPUR_110	4:26	4:59	0:33	TRANSFORMER FAULT
22	25-May-2021	BAGALKOT	110	110/11KV, HV1	ITANAL_110	12:30	14:49	2:19	LINE CLEAR AVOIDED
23	25-May-2021	BAGALKOT	110	110/11KV, HV1	TAKKALAKI_110	10:16	10:19	0:03	HAND TRIPPED
24	25-May-2021	BAGALKOT	110	110/11KV, HV2	TAKKALAKI_110	10:10	10:16	0:06	TRANSFORMER FAULT
25	25-May-2021	BENGALURU	66	IISC - HEBBAL	IISC	11:54	12:00	0:06	LOAD CHANGE OVER
26	25-May-2021	BENGALURU	66	IISC - HEBBAL	IISC	14:03	14:10	0:07	LOAD CHANGE OVER
27	25-May-2021	BENGALURU	66	KADUGODI - ARMY WELFARE ORGANIZATION	ARMY WELFARE ORGANIZATION	16:10	17:05	0:55	LINE CLEAR AVOIDED
28	25-May-2021	BENGALURU	66	KONDASPURA - HOSKOTE 220	KONDASPURA	16:07	16:11	0:04	LOAD CHANGE OVER
29	25-May-2021	BENGALURU	66	KONDASPURA - KADUGODI	KONDASPURA	17:13	17:17	0:04	LOAD CHANGE OVER
30	25-May-2021	BENGALURU	66	KORMANGALA - AUSTIN TOWN 1	NO STATION AFFECTED	17:39	18:48	1:09	LINE FAULT
31	25-May-2021	BENGALURU	66	KORMANGALA - AUSTIN TOWN 1	NO STATION AFFECTED	23:45	23:49	0:04	LINE CLEAR AVOIDED
32	25-May-2021	BENGALURU	66	KORMANGALA - AUSTIN TOWN 2	NO STATION AFFECTED	23:45	23:49	0:04	LINE CLEAR AVOIDED
33	25-May-2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALI	18:26	18:45	0:19	MAIN SUPPLY FAILURE
34	25-May-2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	18:26	18:35	0:09	MAIN SUPPLY FAILURE
35	25-May-2021	BENGALURU	220	HV3	SUBRAMANYAPURA 220	18:26	19:11	0:45	TRANSFORMER FAULT
36	25-May-2021	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	18:16	18:27	0:11	LINE FAULT
37	25-May-2021	BENGALURU	220	HV2	GOWRIBIDANUR 220	12:12	14:54	2:42	TRANSFORMER FAULT
38	25-May-2021	BENGALURU	66	HV1	MAASTI	18:13	18:47	0:34	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
39	25-May-2021	BENGALURU	220	NELMANGALA 400 - YELAHANKA 220	NO STATION AFFECTED	6:54	9:46	2:52	LINE FAULT
40	25-May-2021	BENGALURU	220	HOODY 220 - MANYATHA 220	MANYATHA 220	13:01	15:33	2:31	LINE FAULT
41	25-May-2021	BENGALURU	66	MANYATHA 220 - HOSKOTE 2	SHOBHA CITY, HENNUR CROSS, PURVANKARA PALM BEACH	13:01	13:22	0:20	MAIN SUPPLY FAILURE
42	25-May-2021	BENGALURU	66	MANYATHA 220 - PEENYA 2	SAHAKARINAGAR	13:01	13:23	0:21	MAIN SUPPLY FAILURE
43	25-May-2021	BENGALURU	66	HV3	MANYATHA 220	13:01	13:25	0:23	MAIN SUPPLY FAILURE
44	25-May-2021	BENGALURU	220	HV1	NIMHANS 220	13:09	15:35	2:26	LINE CLEAR AVAILED
45	25-May-2021	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	11:20	13:52	2:32	LINE CLEAR AVAILED
46	25-May-2021	BENGALURU	66	REMCO - SUBRAMANYAPURA 220	REMCO	18:25	18:31	0:06	LOAD CHANGE OVER
47	25-May-2021	BENGALURU	66	HV1	CHATRA	11:03	11:13	0:09	TRANSFORMER FAULT
48	25-May-2021	BENGALURU	66	HV1	CHATRA	22:24	22:35	0:10	TRANSFORMER FAULT
49	25-May-2021	BENGALURU	66	HEBBAL 220 - IISC	NO STATION AFFECTED	12:05	13:24	1:19	LINE CLEAR AVAILED
50	25-May-2021	BENGALURU	220	SRS PEENYA 220 - HEBBAL 220	NO STATION AFFECTED	6:54	9:52	2:58	LINE FAULT
51	25-May-2021	BENGALURU	66	HV1	SIDDLAGHATTA	22:01:29(25-5-2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
52	25-May-2021	BENGALURU	66	HV1	KHW PARK	19:55:41(25-5-2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
53	25-May-2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400	2:55(16.05.2021)			LINE OPEN, LINE FAULT
54	25-May-2021	GULBARGA	400	BTSPG-HIRIYUR2	HIRIYUR_400	22:04(15.05.2021)			LINE OPEN, LINE FAULT
55	25-May-2021	GULBARGA	110	YELBURGA-EASTMANSOLAR_IPP	YELBURGA_110	19:05(25.05.2021)			LINE OPEN, LINE FAULT
56	25-May-2021	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHICKSUGUR_110,SHAKTINAGAR_110,SURANA_IPP	17:07	17:12	0:05	LINE FAULT
57	25-May-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREEN_IPP,	21:11	21:20	0:09	LINE FAULT
58	25-May-2021	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	11:10	11:50	0:40	LINE CLEAR AVAILED
59	25-May-2021	GULBARGA	110	HV1	SANKLAPUR_110	10:40	10:45	0:05	TRANSFORMER FAULT
60	25-May-2021	GULBARGA	110	KUSHATAGI-YELBURGA	YELBURGA_110	19:10	19:48	0:38	MAIN SUPPLY FAILURE
61	25-May-2021	GULBARGA	110	HV2	YELBURGA_110	19:05	20:01	0:56	TRANSFORMER FAULT
62	25-May-2021	GULBARGA	110	BELLARYNORTH-BISIHALLI	BISIHALLI_110	16:15	17:15	1:00	MAIN SUPPLY FAILURE
63	25-May-2021	GULBARGA	110	HV1	NIRNA_110	14:00	14:05	0:05	TRANSFORMER FAULT
64	25-May-2021	GULBARGA	110	HV1	NIRNA_110	14:15	14:20	0:05	TRANSFORMER FAULT
65	25-May-2021	GULBARGA	110	HV1	NIRNA_110	15:16	15:22	0:06	TRANSFORMER FAULT
66	25-May-2021	GULBARGA	110	HV1	NIRNA_110	15:25	15:30	0:05	TRANSFORMER FAULT
67	25-May-2021	GULBARGA	110	HV1	BENNUR_110	15:19	15:35	0:16	TRANSFORMER FAULT
68	25-May-2021	GULBARGA	110	BELLARY-KUDITINI	KUDITINI_110,TORANGALLU_110	9:10	9:15	0:05	LINE FAULT
69	25-May-2021	HASSAN	110	HV2	PUTTUR_110	9:34(15.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
70	25-May-2021	HASSAN	110	HV1	ALKOLA_110	14:12 (24.05.2021)	12:34(25.5.2021)	24:22hrs	TRANSFORMER CHARGED
71	25-May-2021	HASSAN	110	LPH-MGHE 2	lph_gen	9:29 (24.05.2021)			LINE OPEN,LINE CLEAR AVAILED
72	25-May-2021	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	15:36(25.05.2021)			LINE OPEN, LINE FAULT
73	25-May-2021	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	20:42(25.05.2021)			LINE OPEN,LINE CLEAR AVAILED
74	25-May-2021	HASSAN	220	MRSSHM-VARAH3	MRSMSG_220	19:23(25.05.2021)			LINE OPEN,LINE CLEAR AVAILED
75	25-May-2021	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	15:38(25.05.2021)			LINE OPEN, LINE FAULT
76	25-May-2021	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	20:45(25.05.2021)			LINE OPEN,LINE CLEAR AVAILED
77	25-May-2021	HASSAN	220	VARAH1-SHMG3	varahi_gen	13:47(25.05.2021)			LINE OPEN, LINE FAULT
78	25-May-2021	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	16:42	17:00	0:18	LINE FAULT
79	25-May-2021	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	11:35	11:57	0:22	HAND TRIPPED
80	25-May-2021	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	13:46	15:36	1:50	LINE FAULT
81	25-May-2021	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	13:46	15:38	1:52	LINE FAULT
82	25-May-2021	HASSAN	220	MRSSHM-VARAH3	MRSMSG_220	14:40	15:51	1:11	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
83	25-May-2021	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	15:53	19:10	3:17	LINE CLEAR AVAILED
84	25-May-2021	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	10:37	14:05	3:28	NFBC ISSUED
85	25-May-2021	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	10:37	14:05	3:28	LINE CLEAR AVAILED
86	25-May-2021	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	13:46	15:38	1:52	LINE FAULT
87	25-May-2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	13:46	15:40	1:54	LINE FAULT
88	25-May-2021	HASSAN	110	ARSK2-HV1	ARASIKERE_220	11:33	14:25	2:52	LINE CLEAR AVAILED
89	25-May-2021	HASSAN	110	ARSK2-LV1	ARASIKERE_220	11:33	14:25	2:52	LINE CLEAR AVAILED
90	25-May-2021	HASSAN	110	HV1	KADUR_220	12:11	12:58	0:47	LINE CLEAR AVAILED
91	25-May-2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	11:26	11:49	0:23	LINE FAULT
92	25-May-2021	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:51	13:26	2:35	LINE CLEAR AVAILED
93	25-May-2021	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	14:38	14:52	0:14	LINE FAULT
94	25-May-2021	HASSAN	66	BALLUPE-KANDLI	BALLUPe66_66	12:51	16:23	3:32	LINE CLEAR AVAILED
95	25-May-2021	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	11:15	12:57	1:42	LINE CLEAR AVAILED
96	25-May-2021	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	14:05	14:15	0:10	HAND TRIPPED
97	25-May-2021	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	14:25	15:03	0:38	NFBC ISSUED
98	25-May-2021	HASSAN	66	HV1	MAGGE_66	11:16	12:53	1:37	MAIN SUPPLY FAILURE
99	25-May-2021	HASSAN	66	HV1	MAGGE_66	14:11	14:15	0:04	MAIN SUPPLY FAILURE
100	25-May-2021	HASSAN	66	HV1	MAGGE_66	14:17	15:08	0:51	MAIN SUPPLY FAILURE
101	25-May-2021	HASSAN	66	HV2	MAGGE_66	11:16	12:53	1:37	MAIN SUPPLY FAILURE
102	25-May-2021	HASSAN	66	HV2	MAGGE_66	14:11	14:15	0:04	MAIN SUPPLY FAILURE
103	25-May-2021	HASSAN	66	HV2	MAGGE_66	14:17	15:08	0:51	MAIN SUPPLY FAILURE
104	25-May-2021	HASSAN	66	SAKALE-HASSAN1	SAKLESHPURA_66	11:15	12:55	1:40	NFBC ISSUED
105	25-May-2021	HASSAN	66	SAKALE-HASSAN2	SAKLESHPURA_66	12:57	16:25	3:28	NFBC ISSUED
106	25-May-2021	HASSAN	66	SAKALE-HASSAN1	SAKLESHPURA_66	14:35	15:05	0:30	LINE CLEAR AVAILED
107	25-May-2021	HASSAN	66	UDDURKO-CKNDGL	UDDURKOPLU_66	10:21	11:05	0:44	LINE CLEAR AVAILED
108	25-May-2021	MYSURU	66	KR PETE 220-CR PATNA	ANEGOLA_66 KRISHNAPURA_66	16:01	16:06	0:05	LINE FAULT
109	25-May-2021	MYSURU	66	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	15:15	15:24	0:09	LINE FAULT
110	25-May-2021	MYSURU	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66 SOMANAHALLI_66 MADDUR_66 TUMBEKERE_66	18:16	18:32	0:16	LINE FAULT
111	25-May-2021	MYSURU	66	MUGUR-KUNTHUR	MUGUR_66 JANNUR_66 THAYURU_66 TNARASIPURA_66	15:15	15:35	0:19	LINE FAULT
112	25-May-2021	MYSURU	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	20:01	20:11	0:10	LINE FAULT
113	25-May-2021	MYSURU	220	BEGUR-HV1	NO STATIONS EFFECTED	11:50	14:16	2:26	LINE CLEAR AVAILED
114	25-May-2021	MYSURU	66	PERIYAPATNA-HANAGODU	PONNAMPET_66, VIRAJPET_66	22:55 (24/05/2021)	8:00 (25/05/2021)	9:04HRS	LINE CHARGED
115	25-May-2021	MYSURU	66	PONNAMPETE-HANAGODU	PONNAMPET_66, VIRAJPET_66	23:18 (24/05/2021)	8:00 (25/05/2021)	8:41HRS	LINE CHARGED
116	25-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN, LINE CLEAR AVAILED
117	25-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN, LINE CLEAR AVAILED
118	25-May-2021	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	17:51PM(25.05.2021)			LINE OPEN, LINE FAULT
119	25-May-2021	TUMKUR	220	TR-3(HV SIDE)	CHITRADURGA_220	17:21	17:31	0:09	TRANSFORMER FAULT
120	25-May-2021	TUMKUR	220	HONNALLI 220kv- SHIMOGA 220kv	MRSMSG_220	15:24	15:38	0:13	HAND TRIPPED
121	25-May-2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENHALI_66,SRI GIRI PURA_66	18:53	19:27	0:33	LINE FAULT
122	25-May-2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENHALI_66,SRI GIRI PURA_66	19:28	21:27	1:59	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
123	25-May-2021	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	17:51	18:30	0:39	LINE FAULT
124	25-May-2021	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	21:06	21:35	0:29	LINE FAULT
125	25-May-2021	TUMKUR	66	TR-1	ANTHRASANAHALI_220	11:26	12:49	1:22	LINE CLEAR AVAILED
126	25-May-2021	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR(HGML)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	17:30	17:38	0:07	HAND TRIPPED
127	25-May-2021	TUMKUR	66	TR-2	CHITRADURGA_220	17:30	17:38	0:07	TRANSFORMER FAULT
128	25-May-2021	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	17:22	17:36	0:13	TRANSFORMER FAULT
129	25-May-2021	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	17:30	17:37	0:07	HAND TRIPPED
130	25-May-2021	TUMKUR	66	CHITRADURGA 66kv- PANDARAHALLI 1	CHITRADURGA_66 OLD MUSS,PANDARAHALLI_66,CHITRA HALLI_66,HDPURA_66,HOLALKERE_66,RAMGIRI_66	6:18	19:20	13:02	LINE CLEAR AVAILED
131	25-May-2021	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	21:42	21:54	0:11	LINE FAULT
132	25-May-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	3:08	3:17	0:08	LINE FAULT
133	25-May-2021	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:42	16:08	0:26	LINE FAULT
134	25-May-2021	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	12:16	12:30	0:14	LINE FAULT
135	25-May-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:06	11:13	0:06	LINE FAULT
136	25-May-2021	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	20:40	20:52	0:12	LINE FAULT
137	25-May-2021	TUMKUR	66	TR-1	PAVAGADA_66	20:52	20:53	0:01	HAND TRIPPED
138	25-May-2021	TUMKUR	66	TR-2	PAVAGADA_66	20:52	20:54	0:01	HAND TRIPPED
139	25-May-2021	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	9:29	9:35	0:05	LINE FAULT
140	25-May-2021	TUMKUR	66	PAVAGADA_220-NAGALMADIKE	PAVAGADA_220	19:44	19:50	0:05	LINE FAULT
141	25-May-2021	TUMKUR	66	TR-1	SAVALANGA_66	16:23	16:46	0:23	MAIN SUPPLY FAILURE
142	25-May-2021	TUMKUR	66	TR-1	MATHOD_66	2:14	2:28	0:14	TRANSFORMER FAULT
143	25-May-2021	TUMKUR	66	TR-1	MATHOD_66	22:46	22:51	0:05	TRANSFORMER FAULT
1	26-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
2	26-May-2021	BAGALKOT	110	110/11KV, HV1	ZALKI_110	9:05	9:50	0:45	TRANSFORMER FAULT
3	26-May-2021	BAGALKOT	110	110/11KV, HV1	ZALKI_110	20:00	20:45	0:45	TRANSFORMER FAULT
4	26-May-2021	BAGALKOT	110	110/11KV, HV1	MKHUBLI_110, GANDIGWAD_33, ACHME SOLAR_33	16:05	17:16	1:11	TRANSFORMER FAULT
5	26-May-2021	BAGALKOT	110	110/11KV, HV4	VADAGOAN_110	11:32	12:26	0:54	LINE CLEAR AVAILED
6	26-May-2021	BAGALKOT	110	110/11KV,HV1	KHANAPUR_110	22:36	22:59	0:23	TRANSFORMER FAULT
7	26-May-2021	BAGALKOT	110	110/11KV,HV2	HIDIKAL DAM_110	17:18	17:41	0:23	TRANSFORMER FAULT
8	26-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
9	26-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
10	26-May-2021	BAGALKOT	110	CHIKKODI220-CHIKKODI 1 110	CHIKKODI_110(STATIO NOT AFFECTED)	19:18 (26.05.2021)			LINE OPEN, LINE FAULT
11	26-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION AFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
12	26-May-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
13	26-May-2021	BAGALKOT	110	SUPA 1-AMBEWADI	AMBEWADI_220	19:37	19:47	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
14	26-May-2021	BAGALKOT	220	AMBEEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	18:07 (18.05.2021)			LINE OPEN, LINE FAULT
15	26-May-2021	BAGALKOT	220	BIDNAL-HARTI 2	BIDNAL_220	17:55 (23.05.2021)	10:27(26.05.2021)	64:32 hrs	LINE CHARGED
16	26-May-2021	BAGALKOT	220	GADAG-HARTI1	GADAG_220	9:09	10:38	1:29	LINE FAULT
17	26-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
18	26-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
19	26-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
20	26-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
21	26-May-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
22	26-May-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
23	26-May-2021	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	23:39	23:43	0:04	LOAD CHANGE OVER
24	26-May-2021	BENGALURU	66	BIDADI 220 - BOSCH (EHT)	BOSCH (EHT)	16:25	16:35	0:10	MAIN SUPPLY FAILURE
25	26-May-2021	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	16:25	16:35	0:10	MAIN SUPPLY FAILURE
26	26-May-2021	BENGALURU	66	BIDADI 220 - RAMANAGARA	UGRAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	16:25	16:35	0:09	MAIN SUPPLY FAILURE
27	26-May-2021	BENGALURU	66	BYADRAHALLI - SRS PEENYA 220	BYADRAHALLI, TAVAREKERE, KODIHALLI	19:06	19:36	0:30	LINE FAULT
28	26-May-2021	BENGALURU	66	HV1	BTM 4TH PHASE	22:01	22:23	0:22	MAIN SUPPLY FAILURE
29	26-May-2021	BENGALURU	66	HV1	KHODAYS 220	22:01	22:23	0:21	MAIN SUPPLY FAILURE
30	26-May-2021	BENGALURU	66	HV1	REMCO	6:17	6:21	0:04	MAIN SUPPLY FAILURE
31	26-May-2021	BENGALURU	66	HV1	TEKAL	10:36	17:16	6:39	TRANSFORMER FAULT
32	26-May-2021	BENGALURU	66	HV1	BIDADI 220	16:25	16:35	0:09	MAIN SUPPLY FAILURE
33	26-May-2021	BENGALURU	66	HV1	SIDDLAGHATTA	22:01:29(25-5-2021)	10:10	12:09	TRANSFORMER FAULT
34	26-May-2021	BENGALURU	66	HV1	KHW PARK	19:55:41(25-5-2021)	0:16	4:21	TRANSFORMER FAULT
35	26-May-2021	BENGALURU	66	HV2	BTM 4TH PHASE	22:01	22:24	0:23	MAIN SUPPLY FAILURE
36	26-May-2021	BENGALURU	66	HV2	KHODAYS 220	22:01	22:23	0:21	MAIN SUPPLY FAILURE
37	26-May-2021	BENGALURU	66	HV2	REMCO	6:17	6:19	0:02	MAIN SUPPLY FAILURE
38	26-May-2021	BENGALURU	66	HV3	KGF	15:12	15:55	0:42	LINE CLEAR AVAILED
39	26-May-2021	BENGALURU	66	JAKKASANDRA - ADUGODI	ADUGODI	18:28	18:45	0:17	LINE FAULT
40	26-May-2021	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	18:28	18:55	0:26	LINE FAULT
41	26-May-2021	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	22:01	22:24	0:22	MAIN SUPPLY FAILURE
42	26-May-2021	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	10:40	10:45	0:05	LOAD CHANGE OVER
43	26-May-2021	BENGALURU	66	RAJANKUNTE - YELAHANKA 220	RAJANKUNTE	14:30	14:35	0:05	LOAD CHANGE OVER
44	26-May-2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	22:01	22:13	0:11	MAIN SUPPLY FAILURE
45	26-May-2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	22:01	22:30	0:28	MAIN SUPPLY FAILURE
46	26-May-2021	BENGALURU	220	HV1	KHODAYS 220	22:01	22:20	0:19	MAIN SUPPLY FAILURE
47	26-May-2021	BENGALURU	220	HV1	BIDADI 220	16:25	16:35	0:09	TRANSFORMER FAULT
48	26-May-2021	BENGALURU	220	HV2	SUBRAMANYAPURA 220	22:01	22:16	0:15	MAIN SUPPLY FAILURE
49	26-May-2021	BENGALURU	220	HV3	SUBRAMANYAPURA 220	22:01	22:16	0:15	MAIN SUPPLY FAILURE
50	26-May-2021	BENGALURU	220	KHODAYS 220 - SOMANAHALLI 220	KHODAYS 220, SUBRAMANYAPURA 220	22:01	22:20	0:18	LINE FAULT
51	26-May-2021	BENGALURU	220	KHODAYS 220 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 220	22:01	22:16	0:14	MAIN SUPPLY FAILURE
52	26-May-2021	BENGALURU	220	SUBRAMANYAPURA 220 - SOMANAHALLI 220	SUBRAMANYAPURA 220	22:01	22:16	0:14	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
53	26-May-2021	GULBARGA	66	ITTAGI-CLEANMAX2_IPP	ITTAGI_220	11:58	12:05	0:07	LINE CLEAR AVAILED
54	26-May-2021	GULBARGA	66	ITTAGI-RENEWSOLAR1_IPP	ITTAGI_220	11:32	11:37	0:05	LINE CLEAR AVAILED
55	26-May-2021	GULBARGA	110	HV1	MANVI_110	13:19	14:27	1:08	TRANSFORMER FAULT
56	26-May-2021	GULBARGA	110	HV1	NIRNA_110	11:10	11:15	0:05	TRANSFORMER FAULT
57	26-May-2021	GULBARGA	110	HV1	NIRNA_110	13:20	13:25	0:05	TRANSFORMER FAULT
58	26-May-2021	GULBARGA	110	HV1	NIRNA_110	14:45	14:50	0:05	TRANSFORMER FAULT
59	26-May-2021	GULBARGA	110	HV1	NIRNA_110	16:00	16:05	0:05	TRANSFORMER FAULT
60	26-May-2021	GULBARGA	110	HV2	YELBURGA_110	9:43	21:02	11:19	TRANSFORMER FAULT
61	26-May-2021	GULBARGA	110	HV2	BISIHALLI_110	6:10	6:15	0:05	TRANSFORMER FAULT
62	26-May-2021	GULBARGA	110	HV2	SHAHAPUR_220	0:51	1:13	0:22	TRANSFORMER FAULT
63	26-May-2021	GULBARGA	110	HV2	SHAHAPUR_220	1:34	1:43	0:09	TRANSFORMER FAULT
64	26-May-2021	GULBARGA	110	HV2	SHAHAPUR_220	2:10	2:16	0:06	TRANSFORMER FAULT
65	26-May-2021	GULBARGA	110	HV2	SHAHAPUR_220	18:25	18:37	0:12	TRANSFORMER FAULT
66	26-May-2021	GULBARGA	110	HV2	SHAHAPUR_220	19:30	19:43	0:13	TRANSFORMER FAULT
67	26-May-2021	GULBARGA	110	HV2	MANVI_110	13:31	13:39	0:08	TRANSFORMER FAULT
68	26-May-2021	GULBARGA	110	HV2	YELBURGA_110	21:42	22:12	0:30	TRANSFORMER FAULT
69	26-May-2021	GULBARGA	110	KUSHTAGI-ILKAL1	ILKAL_110	19:12	19:35	0:23	LINE FAULT
70	26-May-2021	GULBARGA	110	KUSHTAGI-ILKAL2	ILKAL_110(STATIO NOT AFFECTED)	19:12(26.05.2021)			LINE OPEN, LINE FAULT
71	26-May-2021	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI_110	4:25	4:30	0:05	LINE FAULT
72	26-May-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	19:20	19:55	0:35	LINE FAULT
73	26-May-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:25	20:35	0:10	LINE FAULT
74	26-May-2021	GULBARGA	110	RAJESHWAR-WARDHASOLAR_IPP	RAJESHWAR_110	14:45	15:05	0:20	LINE CLEAR AVAILED
75	26-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,D EVANGAON_110,RENUKA_IPP,AFZ ALPUR_110,KARAJAGI_110	8:55	15:05	6:10	LINE CLEAR AVAILED
76	26-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,D EVANGAON_110,RENUKA_IPP,AFZ ALPUR_110,KARAJAGI_110	6:57	8:50	1:53	LINE FAULT
77	26-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YEDRAMI_110,MORATAGI_110	6:57	8:25	1:28	LINE FAULT
78	26-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YEDRAMI_110,MORATAGI_110	10:44	14:54	4:10	LINE CLEAR AVAILED
79	26-May-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,W ADAGERA_110,SANNATHI_IPP,COR EGREEN_IPP,	14:35	15:19	0:44	LINE CLEAR AVAILED
80	26-May-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400(STATION NOT AFFECTED)	22:04(15.05.2021)			LINE OPEN, LINE FAULT
81	26-May-2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400(STATION NOT AFFECTED)	2:55(16.05.2021)			LINE OPEN, LINE FAULT
82	26-May-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	11:18	14:07	2:49	LINE CLEAR AVAILED
83	26-May-2021	HASSAN	66	HASSN22-SKPURA	HASSAN_220	10:33	17:50	7:17	LINE CLEAR AVAILED
84	26-May-2021	HASSAN	66	HV1	HALEBEDU_66	19:13	19:48	0:35	TRANSFORMER FAULT
85	26-May-2021	HASSAN	66	HV1	KANDLI_66	11:38	13:42	2:04	LINE CLEAR AVAILED
86	26-May-2021	HASSAN	66	HV2	KANDLI_66	10:16	16:38	6:22	LINE CLEAR AVAILED
87	26-May-2021	HASSAN	66	HV2	RAMNATHPUR_66	13:51	13:55	0:04	LINE CLEAR AVAILED
88	26-May-2021	HASSAN	66	HV2	SALAGAME_66	13:28	13:38	0:10	TRANSFORMER FAULT
89	26-May-2021	HASSAN	66	KANDALI-HASSAN	KANDLI_66	10:17	17:50	7:33	LINE CLEAR AVAILED
90	26-May-2021	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	11:31	18:56	7:25	LINE CLEAR AVAILED
91	26-May-2021	HASSAN	110	HV1	BARANGI_110	11:14	12:21	1:07	LINE CLEAR AVAILED
92	26-May-2021	HASSAN	110	HV1	KADUR_220	10:35	11:03	0:28	LINE CLEAR AVAILED
93	26-May-2021	HASSAN	110	HV2	KONDENALU_110	4:48	8:05	3:17	TRANSFORMER FAULT
94	26-May-2021	HASSAN	110	HV2	VITTALA_110	10:47	11:35	0:48	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
95	26-May-2021	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	15:36(25.05.2021)	15:27 (26.05.2021)	23:51hrs	LINE CHARGED
96	26-May-2021	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	20:42(25.05.2021)	15:31(26.05.2021)	18:49hrs	LINE CHARGED
97	26-May-2021	HASSAN	220	MRSSHM-VARAH3	MRSMSG_220	19:23(25.05.2021)	19:31(26.05.2021)	14:08hrs	LINE CHARGED
98	26-May-2021	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	15:38(25.05.2021)	15:30 (26.05.2021)	23:52hrs	LINE CHARGED
99	26-May-2021	HASSAN	220	VARAH1-SHMG3	varahi_gen	13:47(25.05.2021)	19:31 (26.05.2021)	29:44hrs	LINE CHARGED
100	26-May-2021	MYSURU	66	HUNSUR-HANAGODU	NO STATIONS AFFECTED	13:57 (26/05/2021)			LINE OPEN,LINE CLEAR AVAILED
101	26-May-2021	MYSURU	66	HV1	HANGLA_66	14:33	14:53	0:19	LINE CLEAR AVAILED
102	26-May-2021	MYSURU	66	HV1	JAKKANAHALLY_66	8:16	8:45	0:29	TRANSFORMER FAULT
103	26-May-2021	MYSURU	66	HV1	SANIVARASANTHE_66	22:11	22:26	0:15	TRANSFORMER FAULT
104	26-May-2021	MYSURU	66	HV5	SFC SIVA_66	13:50	17:03	3:13	LINE CLEAR AVAILED
105	26-May-2021	MYSURU	66	JAKKANAHALLI-NAGMANANGALA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 NAGAMANGALA_66	5:15	5:22	0:06	LINE FAULT
106	26-May-2021	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	12:06	12:14	0:08	LINE FAULT
107	26-May-2021	MYSURU	66	KOLLEGALA-PARINAMIPURA	CHANDALLI_66, PARINAMIPURA_66 , THALAKADU_66	16:48	16:53	0:04	LINE FAULT
108	26-May-2021	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	18:15	18:30	0:15	LINE FAULT
109	26-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS AFFECTED	15:09 (30/04/2021)			LINE OPEN,LINE CLEAR AVAILED
110	26-May-2021	MYSURU	66	SFC SIVA-10MW	NO STATIONS EFFECTED	3:05	6:45	3:40	LINE FAULT
111	26-May-2021	MYSURU	66	SFC SIVA-10MW	NO STATIONS EFFECTED	14:30	14:35	0:05	LINE FAULT
112	26-May-2021	MYSURU	66	SFC SIVA-5MW	NO STATIONS EFFECTED	3:05	6:05	3:00	LINE FAULT
113	26-May-2021	MYSURU	66	SFC SIVA-5MW	NO STATIONS EFFECTED	14:30	14:36	0:06	LINE FAULT
114	26-May-2021	MYSURU	220	KADAKOLA-KOZHIKODE	NO STATIONS AFFECTED	6:30 (20/04/2021)			LINE OPEN,LINE CLEAR AVAILED
115	26-May-2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	13:43	14:04	0:20	HAND TRIPPED
116	26-May-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	17:51(25.05.2021)	12:11(26.05.2021)	18:59 hrs	LINE CHARGED
117	26-May-2021	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	10:26	16:20	5:53	LINE FAULT
118	26-May-2021	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	10:23	16:30	6:06	LINE FAULT
119	26-May-2021	TUMKUR	66	BALENAHALLI-FEFCWIND	BALENAHALLI_66	10:52	16:30	5:37	LINE FAULT
120	26-May-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	16:12	16:23	0:11	LINE FAULT
121	26-May-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	8:50	9:05	0:15	LINE FAULT
122	26-May-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:15	9:25	0:10	LINE FAULT
123	26-May-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	10:52	10:54	0:01	LINE FAULT
124	26-May-2021	TUMKUR	66	TR-1	GARAGA_66	17:50	17:55	0:05	HAND TRIPPED
125	26-May-2021	TUMKUR	66	TR-1	HONNALLI_66	17:00	17:24	0:24	TRANSFORMER FAULT
126	26-May-2021	TUMKUR	66	TR-1	HULIYURDURGA_66	17:00	17:10	0:09	TRANSFORMER FAULT
127	26-May-2021	TUMKUR	66	TR-1	MADHUGIRI_220	13:30	13:58	0:27	LINE CLEAR AVAILED
128	26-May-2021	TUMKUR	66	TR-1	MATHOD_66	23:50(25.05.2021)	12:00:00 AM(26.05.2021)	0:10HRS	TRANSFORMER CHARGED
129	26-May-2021	TUMKUR	66	TR-1	SOKKE_66	17:16	17:25	0:09	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
130	26-May-2021	TUMKUR	66	TR-2	BALENAHALLI_66	9:55	16:25	6:30	LINE CLEAR AVAILED
1	27-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
2	27-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
3	27-May-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
4	27-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
5	27-May-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
6	27-May-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
7	27-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
8	27-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
9	27-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
10	27-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
11	27-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
12	27-May-2021	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	18:07 (18.05.2021)			LINE OPEN, LINE FAULT
13	27-May-2021	BAGALKOT	110	CHIKKODI220-CHIKKODI 1 110	CHIKKODI_110	19:18 (26.05.2021)	01:19 (27.05.2021)	6:01HRS	LINE CHARGED
14	27-May-2021	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	10:44	15:24	4:40	LINE CLEAR AVAILED
15	27-May-2021	BAGALKOT	110	AMBEWADI-NK 2	KAVALWAD_110	11:14	11:26	0:12	LINE FAULT
16	27-May-2021	BAGALKOT	110	AMBEWADI-NK 2	KAVALWAD_110	12:14	12:44	0:30	LINE FAULT
17	27-May-2021	BAGALKOT	110	AMBEWADI-NK 2	KAVALWAD_110	18:57	19:01	0:04	HAND TRIPPED
18	27-May-2021	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	18:20	19:51	1:31	LINE CLEAR AVAILED
19	27-May-2021	BAGALKOT	110	110/11KV, HV2	ZALKI_110	20:45	20:52	0:07	TRANSFORMER FAULT
20	27-May-2021	BAGALKOT	110	110/11KV, HV2	YARGATTI_110	10:07	10:23	0:16	TRANSFORMER FAULT
21	27-May-2021	BAGALKOT	110	110/11KV, HV4	VADAGOAN_110	5:11	5:56	0:45	TRANSFORMER FAULT
22	27-May-2021	BAGALKOT	110	110/11KV, HV4	VADAGOAN_110	10:17	16:12	5:55	LINE CLEAR AVAILED
23	27-May-2021	BAGALKOT	110	SIRSI220- UMMACHAGI	UMMACHAGI_110	17:03	19:10	2:07	LINE CLEAR AVAILED
24	27-May-2021	BAGALKOT	110	SIRSI- KUMTA2	SIRSI_110	11:24	12:49	1:25	LINE CLEAR AVAILED
25	27-May-2021	BAGALKOT	110	BAGEWADI2(NIDAGUNDI)- MUKARTIHAL	MUKARTIHAL_110	15:18	15:27	0:09	LINE CLEAR AVAILED
26	27-May-2021	BAGALKOT	110	110/11KV, HV1	MUDEBIHAL_110	11:17	12:24	1:07	LINE CLEAR AVAILED
27	27-May-2021	BAGALKOT	110	110/11KV, HV2	HIDIKALDAM_110	19:30	20:48	1:18	TRANSFORMER FAULT
28	27-May-2021	BAGALKOT	110	CHIKKODI110- WINDMILL(DODDANNAVAR)	CHIKKODI_110	1:22	1:41	0:19	HAND TRIPPED
29	27-May-2021	BENGALURU	66	HV2	AUSTIN TOWN	12:07	12:11	0:04	LINE CLEAR AVAILED
30	27-May-2021	BENGALURU	66	EPID 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	9:40	9:54	0:14	LINE FAULT
31	27-May-2021	BENGALURU	66	HV1	KADUGODI	9:40	15:30	5:50	TRANSFORMER FAULT
32	27-May-2021	BENGALURU	66	HV4	MANYATHA TECH PARK 220	11:00	11:20	0:20	LINE CLEAR AVAILED
33	27-May-2021	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	16:17	16:20	0:03	LOAD CHANGE OVER
34	27-May-2021	BENGALURU	66	HV2	REMCO	17:25	17:27	0:02	LOAD CHANGE OVER
35	27-May-2021	BENGALURU	66	HV1	T K HALLI 220	11:29	11:31	0:02	TRANSFORMER FAULT
36	27-May-2021	BENGALURU	66	HV1	T K HALLI 220	12:29	12:32	0:03	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
37	27-May-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	15:50	16:05	0:15	LINE FAULT
38	27-May-2021	BENGALURU	66	HV1	CHANDAPURA	17:31	17:47	0:15	TRANSFORMER FAULT
39	27-May-2021	BENGALURU	66	HV2	GUNDAMGERE	12:22	13:00	0:37	LINE CLEAR AVAILED
40	27-May-2021	BENGALURU	66	HV1	MAASTHI	19:50	21:00	1:09	LINE CLEAR AVAILED
41	27-May-2021	BENGALURU	66	HV2	MAASTHI	20:48	21:00	0:11	LINE CLEAR AVAILED
42	27-May-2021	BENGALURU	66	HV1	PATH PALYA	12:35	12:42	0:07	TRANSFORMER FAULT
43	27-May-2021	BENGALURU	66	HV2	VOLVO	21:00	22:34	1:34	TRANSFORMER FAULT
44	27-May-2021	BENGALURU	66	MAGADI 66 - ANCHEPALYA 220	MAGADI 66	7:55	7:57	0:02	LINE FAULT
45	27-May-2021	BENGALURU	220	NELAMANGALA 400 - KB CROSS 220	NO STATION AFFECTED	11:28	19:34	8:05	LINE FAULT
46	27-May-2021	BENGALURU	66	ACHALU - KANAKPURA 220	ACHALU, HONNIGANAHALLI, DODDALAHALLI	19:50	20:05	0:15	LINE FAULT
47	27-May-2021	BENGALURU	66	ACHALU - HONNIGANAHALLI	HONNIGANAHALLI, DODDALAHALLI	19:50	20:15	0:25	LINE FAULT
48	27-May-2021	BENGALURU	66	HV1	HUKUNDA	14:14	14:25	0:11	TRANSFORMER FAULT
49	27-May-2021	BENGALURU	66	HV1	HUKUNDA	14:31	14:34	0:03	TRANSFORMER FAULT
50	27-May-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	NO STATION AFFECTED	8:21(22-5-2021)			LINE OPEN, LINE FAULT
51	27-May-2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400	2:55(16.05.2021)			LINE OPEN, LINE FAULT
52	27-May-2021	GULBARGA	400	BTSPG-HIRIYUR2	HIRIYUR_400	22:04(15.05.2021)			LINE OPEN, LINE FAULT
53	27-May-2021	GULBARGA	110	HALBARGA-KOLHAR	KOLHAR_110	17:49(27.05.2021)			LINE OPEN,LINE CLEAR AVAILED
54	27-May-2021	GULBARGA	110	YELBURGA-PRPJ_SLR	YELBURGA_110	21:48(27.05.2021)			LINE OPEN,LINE CLEAR AVAILED
55	27-May-2021	GULBARGA	110	KUSHTAGI-ILKAL2	ILKAL_110	19:12(26.05.2021)	7:50(27.05.2021)	12:38HRS	LINE CHARGED
56	27-May-2021	GULBARGA	110	MUNIRABAD-STAR METTALIC	MUNIRABAD_220	6:20	6:30	0:10	LINE FAULT
57	27-May-2021	GULBARGA	110	HV1	KUSHATGI_220	14:32	14:54	0:22	TRANSFORMER FAULT
58	27-May-2021	GULBARGA	110	HV1	KUSHATGI_220	15:20	15:30	0:10	TRANSFORMER FAULT
59	27-May-2021	GULBARGA	110	HV3	KUSHATGI_220	20:25	20:30	0:05	TRANSFORMER FAULT
60	27-May-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	4:00	4:08	0:08	LINE FAULT
61	27-May-2021	GULBARGA	110	SINDHNOOR-NIRLOOTI_IPP	SINDHANOOR_220	3:00	3:10	0:10	LINE FAULT
62	27-May-2021	GULBARGA	110	CHITGUPPA-HUMNABAD	CHITAGUPPA_110	19:45	19:50	0:05	LINE FAULT
63	27-May-2021	GULBARGA	110	HV2	DEODURGA_110	11:05	11:19	0:14	TRANSFORMER FAULT
64	27-May-2021	GULBARGA	110	HV2	DEODURGA_110	13:54	14:03	0:09	TRANSFORMER FAULT
65	27-May-2021	GULBARGA	110	HV3	KAMPLI_110	10:10	11:30	1:20	LINE CLEAR AVAILED
66	27-May-2021	GULBARGA	110	HV1	KUDITINI_110	7:10	8:40	1:30	LINE CLEAR AVAILED
67	27-May-2021	GULBARGA	110	HV3	KOLHAR_110	14:50	15:05	0:15	TRANSFORMER FAULT
68	27-May-2021	GULBARGA	110	HV1	NIRNA_110	9:40	9:45	0:05	TRANSFORMER FAULT
69	27-May-2021	GULBARGA	110	HUMNABAD-NIRNA	NIRNA_110	19:45	19:55	0:10	MAIN SUPPLY FAILURE
70	27-May-2021	GULBARGA	110	KUSHTAGI-NAVALI	NAVALI_110	8:45	9:10	0:25	MAIN SUPPLY FAILURE
71	27-May-2021	GULBARGA	110	MUNIRABAD-STAR METTALIC_IPP	MUNIRABAD_220	6:20	6:30	0:10	LINE FAULT
72	27-May-2021	GULBARGA	66	HV1	CHORNOOR_66	6:43	6:47	0:04	TRANSFORMER FAULT
73	27-May-2021	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	21:48(27.5.2021)			LINE OPEN,LINE CLEAR AVAILED
74	27-May-2021	HASSAN	220	ARSK2-NITTUR	ARSIKERE_220	15:15	19:20	4:05	NFBC ISSUED
75	27-May-2021	HASSAN	220	KADUR-DABUSET	KADUR_220	15:03	19:28	4:25	NFBC ISSUED
76	27-May-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:14	12:10	1:56	LINE CLEAR AVAILED
77	27-May-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	15:09	19:21	4:12	LINE CLEAR AVAILED
78	27-May-2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	9:36	14:20	4:44	LINE CLEAR AVAILED
79	27-May-2021	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	9:36	14:20	4:44	NFBC ISSUED
80	27-May-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:14	12:10	1:56	NFBC ISSUED
81	27-May-2021	HASSAN	110	HV2	GURUVAYANAKERE_110	12:37	17:41	5:04	LINE CLEAR AVAILED
82	27-May-2021	HASSAN	110	HV2	KONDENALU_110	10:09	11:32	1:23	LINE CLEAR AVAILED
83	27-May-2021	HASSAN	110	HV2	MANIPAL_110	11:37	12:25	0:48	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
84	27-May-2021	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	2:46	3:35	0:49	LINE FAULT
85	27-May-2021	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	13:44	13:49	0:05	HAND TRIPPED
86	27-May-2021	HASSAN	110	SAGARA-ALKOLA	SAGARA_110	21:29	21:34	0:05	HAND TRIPPED
87	27-May-2021	MYSURU	66	HV2	BILIKERE_66	10:08	10:14	0:05	TRANSFORMER FAULT
88	27-May-2021	MYSURU	66	FTS-BANNIMANTAPA	NO STATIONS EFFECTED	19:08	19:25	0:17	LINE FAULT
89	27-May-2021	MYSURU	66	KADAKOLA-SARGUR1	JAIPUR_66 HAMPAPURA_66	5:53	5:58	0:05	LINE FAULT
90	27-May-2021	MYSURU	66	K HONNALAGERE-HV1	K_HONNALGERE_66	15:50	16:05	0:15	HAND TRIPPED
91	27-May-2021	MYSURU	66	HV2	PONNAMPET_66	17:40	18:01	0:21	TRANSFORMER FAULT
92	27-May-2021	MYSURU	66	HV2	SANTHEBACHALLI_66	11:39	13:18	1:39	LINE CLEAR AVAILED
93	27-May-2021	MYSURU	66	SFC SIVA-HEBBANI 1	NO STATIONS EFFECTED	11:42	14:41	2:58	LINE CLEAR AVAILED
94	27-May-2021	MYSURU	66	HV1	TUBINAKERE_220	18:06	19:45	1:39	TRANSFORMER FAULT
95	27-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN, LINE CLEAR AVAILED
96	27-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN, LINE CLEAR AVAILED
97	27-May-2021	MYSURU	66	HUNSUR-HANAGODU	NO STATIONS EFFECTED	13:57 (26/05/2021)			LINE OPEN, LINE CLEAR AVAILED
98	27-May-2021	MYSURU	66	KR PETE 220-CR PATNA	ANEGOLAL_66 KRISHNAPURA_66	23:58 (27/05/2021)			LINE OPEN, LINE FAULT
99	27-May-2021	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	11:29	19:32	8:02	LINE FAULT
100	27-May-2021	TUMKUR	220	NITTUR 220kV- ARASIKERE(HASAN)	NITTUR_220	15:15	19:21	4:05	LINE CLEAR AVAILED
101	27-May-2021	TUMKUR	220	ANTHRASANAHALLI 220kV- SHIMOGA	ANTHRASANAHALLI_220	15:30	19:21	3:51	LINE CLEAR AVAILED
102	27-May-2021	TUMKUR	110	TR-2	BANDIHALLI_110	12:42	13:31	0:48	LINE CLEAR AVAILED
103	27-May-2021	TUMKUR	110	TR-1	KBCROSS_220	12:10	12:49	0:39	TRANSFORMER FAULT
104	27-May-2021	TUMKUR	110	TR-2	SAMPIGE_110	21:03	22:10	1:07	TRANSFORMER FAULT
105	27-May-2021	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	13:10	15:43	2:33	TRANSFORMER FAULT
106	27-May-2021	TUMKUR	66	TR-2	BHAKTHARAHALLI_66	15:15	15:40	0:25	LINE CLEAR AVAILED
107	27-May-2021	TUMKUR	66	TR-1	BRAHMASANDRA_66	12:22	12:51	0:29	HAND TRIPPED
108	27-May-2021	TUMKUR	66	TR-1	DYAVARANAHALLI_66	17:29	18:19	0:50	LINE CLEAR AVAILED
109	27-May-2021	TUMKUR	66	HIRIYUR 220KV- ENERCON1_IPP_66	ENERCON1_IPP_66	17:52	18:02	0:10	LINE FAULT
110	27-May-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	3:24	3:32	0:08	LINE FAULT
111	27-May-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:11	9:25	0:13	LINE FAULT
112	27-May-2021	TUMKUR	66	TR-1	HULIYURDURGA_66	6:57	7:10	0:12	TRANSFORMER FAULT
113	27-May-2021	TUMKUR	66	TR-1	HULIYURDURGA_66	13:22	13:35	0:12	TRANSFORMER FAULT
114	27-May-2021	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	9:32	9:39	0:07	HAND TRIPPED
115	27-May-2021	TUMKUR	66	TR-2	NAYAKANAHATTI_66	14:16	14:28	0:11	TRANSFORMER FAULT
116	27-May-2021	TUMKUR	66	TR-1	PAVAGADA_66	7:45	7:59	0:14	TRANSFORMER FAULT
117	27-May-2021	TUMKUR	66	TR-1	PAVAGADA_220	9:32	9:39	0:06	TRANSFORMER FAULT
118	27-May-2021	TUMKUR	66	TR-1	PAVAGADA_220	10:03	10:06	0:02	TRANSFORMER FAULT
119	27-May-2021	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	18:58	19:35	0:36	LINE CLEAR AVAILED
120	27-May-2021	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	18:58	19:35	0:36	LINE CLEAR AVAILED
1	28-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
2	28-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
3	28-May-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
4	28-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
5	28-May-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
6	28-May-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
7	28-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
8	28-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
9	28-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
10	28-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
11	28-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
12	28-May-2021	BAGALKOT	220	AMBEEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	18:07 (18.05.2021)			LINE OPEN, LINE FAULT
13	28-May-2021	BAGALKOT	110	ANKOLA-ARGA(L1)	ANKOLA_110	9:05	9:14	0:09	HAND TRIPPED
14	28-May-2021	BAGALKOT	110	ANNIGERI-GADAG	ANNIGERI_110	20:07	21:29	1:22	LINE FAULT
15	28-May-2021	BAGALKOT	110	110/11KV,HV2	BABALESHWAR_110	17:44	17:56	0:12	HAND TRIPPED
16	28-May-2021	BAGALKOT	220	BIDNAL-HUBLI2	BIDNAL_220	9:21	14:58	5:37	NFBC ISSUED
17	28-May-2021	BAGALKOT	220	BIDNAL-HARTI 2	BIDNAL_220	17:05	18:11	1:06	LINE CLEAR AVAILED
18	28-May-2021	BAGALKOT	110	VAJRAMATTI220- BILAGI	BILAGI_110, SHIRGUPPI_110, TOLAMATTI_110, GIRISAGAR_110	21:33	0:00	2:27	LINE FAULT
19	28-May-2021	BAGALKOT	110	VAJRAMATTI220-KATARKI	KATARKI_110	22:35	22:37	0:02	LINE FAULT
20	28-May-2021	BAGALKOT	110	SIRSI220- SIRSI1	SIRSI_110	21:50 (28.05.2021)			LINE OPEN,LINE CLEAR AVAILED
21	28-May-2021	BAGALKOT	110	110/11KV, HV2	SHIGGOAN_110	9:35	9:51	0:16	TRANSFORMER FAULT
22	28-May-2021	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	21:07	21:27	0:20	TRANSFORMER FAULT
23	28-May-2021	BAGALKOT	220	HUBLI- BIDNAL2	HUBLI_220	9:29	14:58	5:29	LINE CLEAR AVAILED
24	28-May-2021	BAGALKOT	110	KARWAR220- ARGA	ARGA_110	9:11	12:05	2:54	LINE CLEAR AVAILED
25	28-May-2021	BAGALKOT	110	110/11KV, HV1	HOSAHONNATTI_110	4:06	4:17	0:11	TRANSFORMER FAULT
26	28-May-2021	BAGALKOT	110	GHATAPRABHA220- GOKAK	GOKAK_110	0:31	0:39	0:08	LINE FAULT
27	28-May-2021	BENGALURU	66	HV2	CHAKAVELU	11:49	11:55	0:06	LINE CLEAR AVAILED
28	28-May-2021	BENGALURU	66	HV1	CHANDAPURA	1:29	2:05	0:36	TRANSFORMER FAULT
29	28-May-2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	16:29	16:37	0:08	LINE FAULT
30	28-May-2021	BENGALURU	66	HV2	KGF	10:55	11:30	0:35	LINE CLEAR AVAILED
31	28-May-2021	BENGALURU	66	HV3	KGF	15:20	16:00	0:40	LINE CLEAR AVAILED
32	28-May-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	7:10	7:21	0:11	LINE FAULT
33	28-May-2021	BENGALURU	66	HV1	MAASTHI	9:15	9:55	0:40	LINE CLEAR AVAILED
34	28-May-2021	BENGALURU	66	HV2	MAASTHI	9:25	9:55	0:30	LINE CLEAR AVAILED
35	28-May-2021	BENGALURU	220	LV1	MITTEMARI	22:03	22:09	0:06	TRANSFORMER FAULT
36	28-May-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	22:03	22:11	0:08	LINE CLEAR AVAILED
37	28-May-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	22:03	22:11	0:08	LINE CLEAR AVAILED
38	28-May-2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	22:03	22:11	0:08	LINE CLEAR AVAILED
39	28-May-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	22:03	22:09	0:06	LINE CLEAR AVAILED
40	28-May-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, YENNIGADALE, CHELUR	22:03	22:09	0:06	LINE CLEAR AVAILED
41	28-May-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	22:03	22:09	0:06	LINE CLEAR AVAILED
42	28-May-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	22:03	22:09	0:06	LINE CLEAR AVAILED
44	28-May-2021	BENGALURU	66	HV1	PATHPALYA	15:55	16:00	0:05	LINE CLEAR AVAILED
45	28-May-2021	BENGALURU	66	HV2	VOLVO	10:00	12:10	2:10	LINE CLEAR AVAILED
46	28-May-2021	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	RBI, SOUTH CITY	0:05	0:23	0:18	LINE FAULT
47	28-May-2021	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	0:06	0:23	0:17	LOAD CHANGE OVER
48	28-May-2021	BENGALURU	66	HV1	MANYATHA TECH PARK 220	6:24	6:31	0:06	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
49	28-May-2021	BENGALURU	66	HV3	MANYATHA TECH PARK 220	6:36	6:46	0:09	LINE CLEAR AVAILED
50	28-May-2021	BENGALURU	66	HV2	PADMANBHANAGAR	9:13	9:16	0:02	TRANSFORMER FAULT
51	28-May-2021	BENGALURU	66	HV2	C STATION	12:27	13:07	0:40	TRANSFORMER FAULT
52	28-May-2021	BENGALURU	66	ST JOHNS - ADUGODI	ST JOHNS	15:04	15:11	0:07	LOAD CHANGE OVER
53	28-May-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	NO STATION AFFECTED	8:21(22-5-2021)	15:52(28.05.21)	152:31HRS	LINE CHARGED
54	28-May-2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400	2:55(16.05.2021)			LINE OPEN, LINE FAULT
55	28-May-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:04(15.05.2021)			LINE OPEN, LINE FAULT
56	28-May-2021	GULBARGA	110	HALBARGA-KOLHAR2	KOLHAR_110	17:49(27.05.2021)	12:20(28.05.2021)	18:31HRS	LINE CHARGED
57	28-May-2021	GULBARGA	110	YELBURGA-PRPJ_SLR	YELBURGA_110	21:48(27.05.2021)	5:50(28.05.2021)	8:02HRS	LINE CHARGED
58	28-May-2021	GULBARGA	110	KUSHTAGI-NAVALI	NAVALI_110	9:05	9:15	0:10	MAIN SUPPLY FAILURE
59	28-May-2021	GULBARGA	110	MALLAT-BYAGWATH2	MADLAPUR_110,MANVI_110	4:09	4:19	0:10	LINE FAULT
60	28-May-2021	GULBARGA	110	HALBARGA-KOLHAR2	KOLHAR_110	12:50	17:20	4:30	LINE CLEAR AVAILED
61	28-May-2021	GULBARGA	110	PDHALLI-CLEANMAXSOLAR_IPP	PD_HALLI_110	18:45	23:50	5:05	LINE CLEAR AVAILED
62	28-May-2021	GULBARGA	110	SINDHNOOR-VALKAMDINNI	BYAGWAT_110,VALKAMDINNI_110	5:05	5:10	0:05	MAIN SUPPLY FAILURE
63	28-May-2021	GULBARGA	110	SINDHNOOR-TEKKALKOTE	TEKKALKOTE_110	0:42	0:47	0:05	MAIN SUPPLY FAILURE
64	28-May-2021	GULBARGA	110	NIRNA-RENEWSOLAR_IPP	NIRNA_110	19:28	20:02	0:34	LINE CLEAR AVAILED
65	28-May-2021	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	21:48(27.5.2021)	11:02(28.5.2021)	13:14hrs	LINE CHARGED
66	28-May-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	9:01(28.5.2021)			LINE OPEN,LINE CLEAR AVAILED
67	28-May-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	9:30	12:42	3:12	NFBC ISSUED
68	28-May-2021	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	9:39	14:31	4:52	LINE CLEAR AVAILED
69	28-May-2021	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	9:20	15:05	5:45	LINE CLEAR AVAILED
70	28-May-2021	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	10:05	11:03	0:58	LINE CLEAR AVAILED
71	28-May-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	9:31	12:42	3:11	NFBC ISSUED
72	28-May-2021	HASSAN	220	VARAHI-SHMG3	varahi_gen	9:40	14:32	4:52	NFBC ISSUED
73	28-May-2021	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	19:05	20:52	1:47	LINE FAULT
74	28-May-2021	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	9:21	15:05	5:44	NFBC ISSUED
75	28-May-2021	HASSAN	110	HV2	HALADY_110	18:08	18:16	0:08	TRANSFORMER FAULT
76	28-May-2021	HASSAN	110	JOG-JLT4	mghejog_gen	13:16	13:39	0:23	LINE FAULT
77	28-May-2021	HASSAN	110	JOG-JST1	mghejog_gen	13:16	13:36	0:20	LINE FAULT
78	28-May-2021	HASSAN	110	JOG-JST2	mghejog_gen	13:16	13:36	0:20	LINE FAULT
79	28-May-2021	HASSAN	110	JOG110-MGHE	JOG_110	13:16	13:42	0:26	LINE FAULT
80	28-May-2021	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	11:47	12:06	0:19	MAIN SUPPLY FAILURE
81	28-May-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	11:47	12:06	0:19	MAIN SUPPLY FAILURE
82	28-May-2021	HASSAN	110	HV3	PUTTUR_110	14:05	14:13	0:08	TRANSFORMER FAULT
83	28-May-2021	HASSAN	110	SAGARA-SORABA	SAGARA_110	6:33	7:04	0:31	HAND TRIPPED
84	28-May-2021	HASSAN	110	SAGARA-SORABA	SAGARA_110	11:22	11:29	0:07	HAND TRIPPED
85	28-May-2021	HASSAN	110	SAGARA-JST2	SAGARA_110	13:16	13:35	0:19	LINE FAULT
86	28-May-2021	HASSAN	110	SORABA-MAVALLI	SORABA_110	6:30	7:05	0:35	MAIN SUPPLY FAILURE
87	28-May-2021	HASSAN	66	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	12:12	12:24	0:12	HAND TRIPPED
88	28-May-2021	HASSAN	66	CRPATNA2-MATTANAVILE	CRPATNA_220	12:53	12:59	0:06	HAND TRIPPED
89	28-May-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	11:05	17:27	6:22	LINE CLEAR AVAILED
90	28-May-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	11:05	17:27	6:22	LINE CLEAR AVAILED
91	28-May-2021	MYSURU	66	HV1	CHUNCHUNKATTE-	13:55	15:16	1:20	TRANSFORMER FAULT
92	28-May-2021	MYSURU	66	HV1	CHUNCHUNKATTE-	17:51	18:06	0:15	TRANSFORMER FAULT
93	28-May-2021	MYSURU	66	CHUNCHUNKATTE-KR NAGARA	CHUNCHUNKATTE-	13:55	15:10	1:14	LINE FAULT
94	28-May-2021	MYSURU	66	CHUNCHUNKATTE-KR NAGARA	CHUNCHUNKATTE-	17:51	18:09	0:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
95	28-May-2021	MYSURU	66	CHUNCHUNKATTE-RAVANDUR	CHUNCHUNKATTE-	14:00	15:10	1:10	LINE FAULT
96	28-May-2021	MYSURU	66	CHUNCHUNKATTE-RAVANDUR	CHUNCHUNKATTE-	17:52	18:10	0:18	LINE FAULT
97	28-May-2021	MYSURU	66	HANAGODU-PONNAMPETE	PONNAMPET_66, VIRAJPET_66	9:31	15:58	6:26	NFBC ISSUED
98	28-May-2021	MYSURU	66	HANNUR-AMPS SOLAR	NO STATIONS EFFECTED	17:04	17:15	0:10	LINE FAULT
99	28-May-2021	MYSURU	66	KADAKOLA-SARAGURU 2	DOORA_66 HURA_66 HULLAHALLI_66	6:44	6:56	0:11	LINE FAULT
100	28-May-2021	MYSURU	66	KR NAGARA-MYSORE 1	BILIKERE_66 BHERYA_66 DMG_HALLI_66 GVGUDI_66 KRNAGARA_66	13:59	14:06	0:07	LINE FAULT
101	28-May-2021	MYSURU	66	KR NAGARA-MYSORE 1	BILIKERE_66 BHERYA_66 DMG_HALLI_66 GVGUDI_66 KRNAGARA_66	14:27	14:36	0:09	LINE FAULT
102	28-May-2021	MYSURU	66	KR NAGARA-MYSORE 1	BILIKERE_66 BHERYA_66 DMG_HALLI_66 GVGUDI_66 KRNAGARA_66	14:57	15:04	0:07	LINE FAULT
103	28-May-2021	MYSURU	66	KR NAGARA-MYSORE 1	BILIKERE_66 BHERYA_66 DMG_HALLI_66 GVGUDI_66 KRNAGARA_66	17:51	18:01	0:10	LINE FAULT
104	28-May-2021	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATION EFFECTED.	5:54	6:00	0:06	LINE FAULT
105	28-May-2021	MYSURU	66	PERIYAPATNA -HANAGODU	PONNAMPET_66, VIRAJPET_66	9:09	15:47	6:37	LINE CLEAR AVAILED
106	28-May-2021	MYSURU	66	HV1	SANIVARASANTHE_66	8:04	8:10	0:05	TRANSFORMER FAULT
107	28-May-2021	MYSURU	66	HV5	SFC SIVA_66	11:46	11:54	0:08	TRANSFORMER FAULT
108	28-May-2021	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	11:46	11:57	0:11	LINE FAULT
109	28-May-2021	MYSURU	66	SFC SIVA-HEBBANI 1	NO STATIONS EFFECTED	11:46	12:07	0:21	LINE FAULT
110	28-May-2021	MYSURU	66	SFC SIVA-HEBBANI 2	NO STATIONS EFFECTED	11:46	12:07	0:20	LINE FAULT
111	28-May-2021	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66	6:02	6:13	0:10	LINE FAULT
112	28-May-2021	MYSURU	66	VAJAMANGALA-MEGHALAPURA	MEGALAPURA_66	5:15	5:21	0:06	LINE FAULT
113	28-May-2021	MYSURU	66	YELANDURU-MADHUVANAHALLI	NO STATIONS EFFECTED	5:45	5:53	0:07	LINE FAULT
114	28-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN,LINE CLEAR AVAILED
115	28-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN,LINE CLEAR AVAILED
116	28-May-2021	MYSURU	66	HUNSUR-HANAGODU	NO STATIONS EFFECTED	13:57 (26/05/2021)	9:24(28.5.21)	43:27 HRS	LINE CHARGED
117	28-May-2021	MYSURU	66	KR PETE 220-CR PATNA	ANEGOLAL_66 KRISHNAPURA_66	23:58 (27/05/2021)	0:04(28.5.21)	0:06 HRS	LINE CHARGED
118	28-May-2021	TUMKUR	110	TR-1	GUNGURMALE_110	0:10:59	15:42:38	15:31	LINE CLEAR AVAILED
119	28-May-2021	TUMKUR	110	TR-1	SAMPIGE_110	9:20:46	11:02:10	1:41	LINE CLEAR AVAILED
120	28-May-2021	TUMKUR	110	TR-2	SAMPIGE_110	9:20:46	11:02:10	1:41	LINE CLEAR AVAILED
121	28-May-2021	TUMKUR	66	TR-1	BRAHMASANDRA_66	11:39:30	13:28:46	1:49	LINE CLEAR AVAILED
122	28-May-2021	TUMKUR	66	TR-1	CHANNAGIRI_66	9:28	9:53	0:24	TRANSFORMER FAULT
123	28-May-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:17	12:27	0:09	LINE FAULT
124	28-May-2021	TUMKUR	66	TR-1	KUNDUR_66	6:11	6:23	0:12	TRANSFORMER FAULT
125	28-May-2021	TUMKUR	66	PALLAGATTE66-(DVG SOKKE)NEELAGUNDA	PALLAGATTE_66	8:01:18	8:05:31	0:04	HAND TRIPPED
126	28-May-2021	TUMKUR	66	TR-2	RAMPURA_66	13:24	13:38	0:14	TRANSFORMER FAULT
127	28-May-2021	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	15:00	16:40	1:40	LINE CLEAR AVAILED
1	29-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
2	29-May-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED ZALKI_110	16:29	18:01	1:32	LINE CLEAR AVAILED
3	29-May-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUNDAGANUR_110	22:45	22:50	0:05	LOAD CURTAILMENT
4	29-May-2021	BAGALKOT	110	110/11KV, HV1 (HV2)	UGARKHOD_110	11:44	11:57	0:13	LINE CLEAR AVAILED
5	29-May-2021	BAGALKOT	110	110/11KV, HV1 (HV2)	UGARKHOD_110	12:32	12:55	0:23	LINE CLEAR AVAILED
6	29-May-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SANKESHWAR_110	22:45	22:56	0:11	LOAD CURTAILMENT
7	29-May-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MALAGHAN(S)_110	11:36	11:40	0:04	TRANSFORMER FAULT
8	29-May-2021	BAGALKOT	110	110/11KV,HV1	AKSHAYA COLONY_110	9:50	10:30	0:40	LINE CLEAR AVAILED
9	29-May-2021	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	10:45	22:54	12:09	LOAD CURTAILMENT
10	29-May-2021	BAGALKOT	110	110/11KV,HV1	LAXMESHWAR_110	22:45	22:59	0:14	LOAD CURTAILMENT
11	29-May-2021	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	22:40	22:49	0:09	LOAD CURTAILMENT
12	29-May-2021	BAGALKOT	110	110/11KV,HV2	KALAGATAGI_110	9:38	9:40	0:02	TRANSFORMER FAULT
13	29-May-2021	BAGALKOT	110	110/11KV,HV2(HV4)	GAJENDRAGAD_110	22:40	22:50	0:10	LOAD CURTAILMENT
14	29-May-2021	BAGALKOT	110	110/11KV,HV3(HV1)	KALADAGI_110	6:51	6:55	0:04	TRANSFORMER FAULT
15	29-May-2021	BAGALKOT	110	110/33KV,HV1	PALA_33 STATION NOT AFFECTED HANAGAL_110	22:45	22:51	0:06	LOAD CURTAILMENT
16	29-May-2021	BAGALKOT	110	110/33KV,HV2	YELLAPUR_33 STATION NOT AFFECTED KIRUVATTI_110	10:36	15:07	4:31	LINE CLEAR AVAILED
17	29-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
18	29-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
19	29-May-2021	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	4:46	5:03	0:17	LINE FAULT
20	29-May-2021	BAGALKOT	110	KAHABARAGI LAYOUT-NEHARU NAGAR	STATION NOT AFFECTED KAHABARAGI LAYOUT_110	21:53	21:55	0:02	LINE CLEAR AVAILED
21	29-May-2021	BAGALKOT	110	KAHABARAGI LAYOUT-NEHARU NAGAR	STATION NOT AFFECTED KAHABARAGI LAYOUT_110	23:01	23:50	0:49	LINE CLEAR AVAILED
22	29-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
23	29-May-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
24	29-May-2021	BAGALKOT	110	SIRSI220- SIRSI1	STATION NOT AFFECTED SIRSI_110	21:50 (28.05.2021)	13:09 (29.05.2021)	15:19hrs	LINE CHARGED
25	29-May-2021	BAGALKOT	110	SIRSI-JOG2	STATION NOT AFFECTED SIRSI_110	10:32	13:45	3:13	LINE CLEAR AVAILED
26	29-May-2021	BAGALKOT	110	SIRSI-SIDDAPUR (JOG1)	SIDDAPUR_110	10:32	11:00	0:28	HAND TRIPPED
27	29-May-2021	BAGALKOT	110	VAJJRAMATTI220-KATARKI	KATARKI_110	20:29	20:47	0:18	LINE FAULT
28	29-May-2021	BAGALKOT	110	YARAGATTI-BENKATTI	BENKATTI_110	3:18	3:34	0:16	LINE FAULT
29	29-May-2021	BAGALKOT	110	YARAGATTI-KATKOL	KATAKOL_110	3:36	3:55	0:19	LINE FAULT
30	29-May-2021	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	18:07 (18.05.2021)			LINE OPEN, LINE FAULT
31	29-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
32	29-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
33	29-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
34	29-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
35	29-May-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
36	29-May-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
37	29-May-2021	BENGALURU	66	BYDRAHALLI - T G HALLI	KODIGEHALLI	7:15	7:55	0:40	LINE FAULT
38	29-May-2021	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI, ID HALLI	23:08	23:16	0:08	LINE FAULT
39	29-May-2021	BENGALURU	66	HV1	MULBAGALU	10:56	19:15	8:19	LINE CLEAR AVAILED
40	29-May-2021	BENGALURU	66	HV1	KGF	11:49	13:00	1:10	LINE CLEAR AVAILED
41	29-May-2021	BENGALURU	66	HV1	ITI 220	17:42	19:24	1:42	TRANSFORMER FAULT
42	29-May-2021	BENGALURU	66	HV2	DEVANAHALLI 66	16:40	18:40	2:00	LINE CLEAR AVAILED
43	29-May-2021	BENGALURU	66	HV2	AMAR JYOTHI	11:40	13:30	1:50	LINE CLEAR AVAILED
44	29-May-2021	BENGALURU	66	HV2	MANYATHA TECH PARK 220	6:27	6:36	0:09	LINE CLEAR AVAILED
45	29-May-2021	BENGALURU	66	KODIGEHALLI - TAVAREKERE	TAVAREKERE	7:15	8:08	0:53	LINE FAULT
46	29-May-2021	BENGALURU	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	2:18	2:25	0:07	LINE FAULT
47	29-May-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	12:10	12:18	0:08	MAIN SUPPLY FAILURE
48	29-May-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	12:10	12:18	0:08	MAIN SUPPLY FAILURE
49	29-May-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	12:10	12:18	0:08	MAIN SUPPLY FAILURE
50	29-May-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	12:10	12:18	0:08	MAIN SUPPLY FAILURE
51	29-May-2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	12:10	12:55	0:45	LINE CLEAR AVAILED
52	29-May-2021	BENGALURU	220	HV1	GOWRIBIDANUR 220	16:10	22:24	6:14	TRANSFORMER FAULT
53	29-May-2021	BENGALURU	220	HV1	MITTEMARI 220	12:10	12:18	0:08	MAIN SUPPLY FAILURE
54	29-May-2021	GULBARGA	110	HV1,HV2	RAJESHWAR_110	22:45	22:52	0:07	LOAD CURTAILMENT
55	29-May-2021	GULBARGA	110	HV2	NALWAR_110	17:49	19:05	1:16	TRANSFORMER FAULT
56	29-May-2021	GULBARGA	110	HV2	DEODURGA_110	20:37	20:45	0:08	TRANSFORMER FAULT
57	29-May-2021	GULBARGA	110	HV2	HATTI_110	23:42	23:45	0:03	LOAD CURTAILMENT
58	29-May-2021	GULBARGA	110	HV2	MANTHAL_110	22:40	23:00	0:20	TRANSFORMER FAULT
59	29-May-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	13:29	13:41	13:41	LINE FAULT
60	29-May-2021	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	11:35	17:10	5:35	LINE CLEAR AVAILED
61	29-May-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	5:14	5:27	0:13	LINE FAULT
62	29-May-2021	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220(STATION NOT AFFECTED)	21:37(29.05.2021)			LINE OPEN, LINE FAULT
63	29-May-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	11:15	13:28	2:13	LINE CLEAR AVAILED
64	29-May-2021	GULBARGA	110	SINDHNOOR-RAICHUR2	ADVIAWARESHWARA_110	20:35	20:45	0:10	LINE FAULT
65	29-May-2021	GULBARGA	110	YELBURGA-TALTSR	YELBURGA_110(STATION NOT AFFECTED)	21:30(29.5.2021)			LINE OPEN,LINE CLEAR AVAILED
66	29-May-2021	GULBARGA	220	HV1	KUSHTAGI_220	10:50	11:02	0:12	TRANSFORMER FAULT
67	29-May-2021	GULBARGA	220	HV1	SEDAM_220(STATION NOT AFFECTED)	21:37(29.05.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
68	29-May-2021	GULBARGA	220	KUSHTAGI-LINGSUGUR	KUSHTAGI_220	7:45	8:59	1:14	MAIN SUPPLY FAILURE
69	29-May-2021	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220(STATION NOT AFFECTED)	22:11(29.05.2021)			LINE OPEN, LINE FAULT
70	29-May-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400(NO STATION AFFECTED)	22:04(15.05.2021)			LINE OPEN, LINE FAULT
71	29-May-2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400(NO STATION AFFECTED)	2:55(16.05.2021)			LINE OPEN, LINE FAULT
72	29-May-2021	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	11:04	11:12	0:08	HAND TRIPPED
73	29-May-2021	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	14:42	14:47	0:05	HAND TRIPPED
74	29-May-2021	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	11:04	11:12	0:08	HAND TRIPPED
75	29-May-2021	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	14:42	14:47	0:05	HAND TRIPPED
76	29-May-2021	HASSAN	66	MRSSHM-DVG1	MRSMSG_220	11:04	11:12	0:08	HAND TRIPPED
77	29-May-2021	HASSAN	66	MRSSHM-DVG1	MRSMSG_220	14:42	14:47	0:05	HAND TRIPPED
78	29-May-2021	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	11:04	11:12	0:08	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
79	29-May-2021	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	14:42	14:47	0:05	HAND TRIPPED
80	29-May-2021	HASSAN	66	TAVAREC-IDLE	TAVARECHATNAHALLI_66	11:05	11:10	0:05	LOAD CURTAILMENT
81	29-May-2021	HASSAN	66	TAVAREC-IDLE	TAVARECHATNAHALLI_66	14:45	14:50	0:05	LOAD CURTAILMENT
82	29-May-2021	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	9:55	13:18	3:23	LINE CLEAR AVAILED
83	29-May-2021	HASSAN	110	HV2	BANAVARA_110	22:40	22:50	0:10	LOAD CURTAILMENT
84	29-May-2021	HASSAN	110	HV2	GERUMARA_110	22:41	23:02	0:21	LOAD CURTAILMENT
85	29-May-2021	HASSAN	220	HV3	MRSMSG_220	11:23	14:40	3:17	LINE CLEAR AVAILED
86	29-May-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	9:01(28.5.2021)			LINE OPEN,LINE CLEAR AVAILED
87	29-May-2021	MYSURU	66	DODDARAYAPETE-MADHUVANALLI	MUGUR_66 JANNUR_66 SANTHEMARAHALLI_66 TNARASIPURA_66	10:28	10:31	0:03	LINE FAULT
88	29-May-2021	MYSURU	66	HV1	BGNAGARA_66	22:40	22:47	0:07	LOAD CURTAILMENT
89	29-May-2021	MYSURU	66	HV1	BILIKERE_66	22:40	22:51	0:11	LOAD CURTAILMENT
90	29-May-2021	MYSURU	66	HV1	DODDINADUVADI_66	22:43	22:57	0:14	LOAD CURTAILMENT
91	29-May-2021	MYSURU	66	HV1	HANAGODU_66	22:42	22:56	0:14	LOAD CURTAILMENT
92	29-May-2021	MYSURU	66	HV1	NAGAMANGALA_66	22:42	23:01	0:19	LOAD CURTAILMENT
93	29-May-2021	MYSURU	66	HV1	RAMAPURA_MYS_66	22:40	22:45	0:05	LOAD CURTAILMENT
94	29-May-2021	MYSURU	66	HV1	KUSHALNAGARA_66	22:42	22:50	0:08	LOAD CURTAILMENT
95	29-May-2021	MYSURU	66	HV1	KRPET_66	22:42	22:51	0:09	LOAD CURTAILMENT
96	29-May-2021	MYSURU	66	HV1	MADIKERI_66	11:30	19:25	7:54	LINE CLEAR AVAILED
97	29-May-2021	MYSURU	66	HV2	AKKIEBBAL_66	22:43	22:53	0:10	LOAD CURTAILMENT
98	29-May-2021	MYSURU	66	HV2	BOOKANAKERE_66	22:45	22:54	0:09	LOAD CURTAILMENT
99	29-May-2021	MYSURU	66	HV2	CHINAKURALI_66	22:43	22:53	0:10	LOAD CURTAILMENT
100	29-May-2021	MYSURU	66	HV2	ELAVALA_66	22:42	23:03	0:21	LOAD CURTAILMENT
101	29-May-2021	MYSURU	66	HV2	HANNUR_66	22:45	22:50	0:05	LOAD CURTAILMENT
102	29-May-2021	MYSURU	66	HV2	HDKOTE_66	22:30	22:56	0:26	LOAD CURTAILMENT
103	29-May-2021	MYSURU	66	HV2	JAIPUR_66	22:42	22:53	0:11	LOAD CURTAILMENT
104	29-May-2021	MYSURU	66	HV2	MALAVALLI_66	22:42	22:53	0:11	LOAD CURTAILMENT
105	29-May-2021	MYSURU	66	HV2	SANTHEMARAHALLI_66	22:40	22:45	0:05	LOAD CURTAILMENT
106	29-May-2021	MYSURU	66	HV2	KIRUGAVALU_66	22:50	23:05	0:15	LOAD CURTAILMENT
107	29-May-2021	MYSURU	66	HV2	KMDODDI_66	22:42	23:00	0:18	LOAD CURTAILMENT
108	29-May-2021	MYSURU	66	KADAKOLA-SARGUR 2	HULLAHALLI_66 DOORA_66 HURA_66	23:00	23:03	0:03	LINE FAULT
109	29-May-2021	MYSURU	66	KIRUGAVALU-VADKEPURA	NO STATIONS INTERRUPTED.	14:16	14:23	0:06	LINE FAULT
110	29-May-2021	MYSURU	66	KUNTHUR-MADHUVANALLI	NO STATIONS INTERRUPTED.	18:39	18:45	0:05	LINE FAULT
111	29-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN,LINE CLEAR AVAILED
112	29-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN,LINE CLEAR AVAILED
113	29-May-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	5:38	7:09	1:30	LINE FAULT
114	29-May-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:40	10:48	0:07	LINE FAULT
115	29-May-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAG UNDA_66	11:50	13:30	1:40	LINE CLEAR AVAILED
116	29-May-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	13:16	13:33	0:17	LINE FAULT
117	29-May-2021	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	9:04	9:56	0:51	LINE FAULT
118	29-May-2021	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	9:04	9:55	0:51	LINE FAULT
119	29-May-2021	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	10:01	11:33	1:31	LINE CLEAR AVAILED
120	29-May-2021	TUMKUR	66	TAVAREKERE (H)- PATTNAYAKANAHALLI	TAVAREKERE(H)_66	18:44	19:05	0:20	HAND TRIPPED
121	29-May-2021	TUMKUR	66	TR-1	CHANNAGIRI_66	9:56	9:57	0:01	TRANSFORMER FAULT
122	29-May-2021	TUMKUR	66	TR-1	HANGAL_66	22:40	22:44	0:03	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
123	29-May-2021	TUMKUR	66	TR-1	PATNAYAKANAHALLI_66	18:44	19:00	0:16	HAND TRIPPED
124	29-May-2021	TUMKUR	66	TR-1	PAVAGADA_220	10:50	11:27	0:37	TRANSFORMER FAULT
125	29-May-2021	TUMKUR	66	TR-1	SHYLAPURA_66	11:38	11:45	0:06	TRANSFORMER FAULT
126	29-May-2021	TUMKUR	66	TR-2	CHANNAGIRI_66	8:32	8:34	0:01	TRANSFORMER FAULT
127	29-May-2021	TUMKUR	66	TR-2	HANGAL_66	22:40	22:44	0:03	LOAD CURTAILMENT
128	29-May-2021	TUMKUR	66	TR-2	PATNAYAKANAHALLI_66	18:44	19:01	0:16	HAND TRIPPED
129	29-May-2021	TUMKUR	66	TR-2	SANEKERE_66	23:11	23:18	0:06	TRANSFORMER FAULT
130	29-May-2021	TUMKUR	66	TR-2	THALLAKK_220	8:18	8:24	0:06	HAND TRIPPED
131	29-May-2021	TUMKUR	66	TR-3	HOLALKERE_66	14:12	14:44	0:32	LINE CLEAR AVAILED
132	29-May-2021	TUMKUR	66	TR-3	HOLALKERE_66	22:40	22:56	0:16	TRANSFORMER FAULT
133	29-May-2021	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	16:06	16:56	0:49	LINE CLEAR AVAILED
134	29-May-2021	TUMKUR	110	NITTUR 220kv- GUBBI	GUBBI_110	6:33	6:41	0:08	LINE FAULT
135	29-May-2021	TUMKUR	110	TR-1	GUNGURMALE_110	11:40	12:26	0:46	TRANSFORMER FAULT
136	29-May-2021	TUMKUR	110	TR2	NITTUR_220	9:03	9:08	0:05	TRANSFORMER FAULT
137	29-May-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	14:51	17:37	2:46	LINE FAULT
138	29-May-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220(STATION NOT AFFECTED)	5:37:26 PM (29.05.2021)			LINE OPEN, LINE FAULT
139	29-May-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220(STATION NOT AFFECTED)	14:51(29.05.21)			LINE OPEN, LINE FAULT
140	29-May-2021	TUMKUR	400	GUTTUR 400KV- NARENDRA2	GUTUR_400	11:11	11:24	0:12	HAND TRIPPED
141	30-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
142	30-May-2021	BAGALKOT	110	110/11KV,HV1	KAHABARAGI LAYOUT_110	13:20	13:54	0:34	LINE CLEAR AVAILED
143	30-May-2021	BAGALKOT	110	110/11KV,HV1	KUDAL SANGAM_110	12:05	12:32	0:27	TRANSFORMER FAULT
144	30-May-2021	BAGALKOT	110	110/11KV,HV2	KALAGATAGI_110	7:04	7:08	0:04	TRANSFORMER FAULT
145	30-May-2021	BAGALKOT	110	110/11KV,HV2(HV3)	HIREKERUR_110	8:12	8:15	0:03	TRANSFORMER FAULT
146	30-May-2021	BAGALKOT	110	110/33KV, HV3	HORTI_33 STATION NOT AFFECTED ZALKI_110	22:06	22:10	0:04	HAND TRIPPED
147	30-May-2021	BAGALKOT	110	110/33KV, HV4	DULKHED_33, HALASANGI_33, NEVARGI_33 STATION NOT AFFECTED ZALKI_110	22:06	22:43	0:37	HAND TRIPPED
148	30-May-2021	BAGALKOT	110	110/33KV,HV2	CHINCHALI_33 STATION NOT AFFECTED KUDCHI_110	11:50	11:57	0:07	TRANSFORMER FAULT
149	30-May-2021	BAGALKOT	110	110/33KV,HV4	ALAGAWADI_33 STATION NOT AFFECTED HIDIKAL_110	11:49	13:01	1:12	TRANSFORMER FAULT
150	30-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
151	30-May-2021	BAGALKOT	110	BAGALKOT220-NEERBUDIHAI	NEERBUDIHAI_110	14:37	16:32	1:55	LINE FAULT
152	30-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
153	30-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
154	30-May-2021	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	12:54	12:55	0:01	HAND TRIPPED
155	30-May-2021	BAGALKOT	110	MALAGHAN(S)-MANALI SUGARS	MANALI SUGARS STATION NOT AFFECTED MALAGHAN(S)_110	22:11	22:15	0:04	LINE FAULT
156	30-May-2021	BAGALKOT	110	NARAGUND-BPCL IPP	BPCL IPP_110 STATION NOT AFFECTED NARAGUND_110	16:21	16:50	0:29	LINE FAULT
157	30-May-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
158	30-May-2021	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	18:07 (18.05.2021)			LINE OPEN, LINE FAULT
159	30-May-2021	BAGALKOT	220	MAHALINGAPUR220-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR_220	18:58	19:59	1:01	LINE FAULT
160	30-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
161	30-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
162	30-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
163	30-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	15:17 (15.05.2021)			LINE OPEN,LINE CLEAR AVAILED
164	30-May-2021	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	20:01	20:03	0:02	HAND TRIPPED
165	30-May-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
166	30-May-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
167	30-May-2021	BENGALURU	66	GOKULA - SRS PEENYA 1	NO STATION AFFECTED	16:55	18:17	1:22	LINE FAULT
168	30-May-2021	BENGALURU	66	HV1	KYALANUR	21:16	21:27	0:11	TRANSFORMER FAULT
169	30-May-2021	BENGALURU	66	HV2	DALSANUR	7:37	7:52	0:14	TRANSFORMER FAULT
170	30-May-2021	BENGALURU	66	HV2	ITI 220	17:00	17:39	0:39	TRANSFORMER FAULT
171	30-May-2021	BENGALURU	66	KODIGEHALI - TAVAREKERE	TAVAREKERE	11:45	12:09	0:24	LINE CLEAR AVAILED
172	30-May-2021	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION EFFECTED	11:47	11:54	0:07	LINE FAULT
173	30-May-2021	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	5:25	6:32	1:06	LINE CLEAR AVAILED
174	30-May-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	7:00	7:04	0:04	LINE CLEAR AVAILED
175	30-May-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	7:00	7:04	0:04	LINE CLEAR AVAILED
176	30-May-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	7:00	7:04	0:04	LINE CLEAR AVAILED
177	30-May-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	7:00	7:04	0:04	LINE CLEAR AVAILED
178	30-May-2021	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	5:40	5:50	0:10	LINE FAULT
179	30-May-2021	BENGALURU	66	SRS PEENYA 220 - HEBBALA 1	NO STATION AFFECTED	16:55	18:15	1:20	LINE FAULT
180	30-May-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	1:37	1:43	0:06	LINE FAULT
181	30-May-2021	GULBARGA	66	HANASI-MUNIRABAD	HANASI_66	7:50	8:05	0:15	LINE FAULT
182	30-May-2021	GULBARGA	66	ITTAGI-KUDLIGI	KUDLIGI_66	7:50	8:05	0:15	LINE FAULT
183	30-May-2021	GULBARGA	110	HV1,HV2	NIRNA_110	9:12	9:50	0:38	LINE CLEAR AVAILED
184	30-May-2021	GULBARGA	110	HV2	MANVI_110	9:47	10:10	0:23	TRANSFORMER FAULT
185	30-May-2021	GULBARGA	110	HV2	MANVI_110	6:13	6:17	0:04	TRANSFORMER FAULT
186	30-May-2021	GULBARGA	110	KUDITINI-BELLARY,TORANGALLU	TORANGALLU_110	20:11	20:17	0:06	LINE FAULT
187	30-May-2021	GULBARGA	110	MANVI-RAICHUR	MANVI_110	16:26	16:36	0:10	MAIN SUPPLY FAILURE
188	30-May-2021	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	4:36	4:40	0:04	LINE FAULT
189	30-May-2021	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	9:20	9:36	0:16	LINE FAULT
190	30-May-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	16:54	17:09	0:15	LINE FAULT
191	30-May-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110 ,MANVI_110	15:27	15:37	0:10	LINE FAULT
192	30-May-2021	GULBARGA	110	RAJESHWAR-SASTHAPUR	SASTHAPUR_110	7:02	12:09	5:07	LINE CLEAR AVAILED
193	30-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,D EVANGAON_110,RENUKA_IPP,AFZ ALPUR_110,KARAJAGI_110	16:15	16:20	0:05	LINE FAULT
194	30-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,D EVANGAON_110,RENUKA_IPP,AFZ ALPUR_110,KARAJAGI_110	16:20(30.5.21)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
195	30-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YEDRAMI_110,MORATAGI_110(STATION NOT AFFECTED)	23:52(30.5.21)			LINE OPEN,LINE CLEAR AVAILED
196	30-May-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADONA_110,SRNAGAR_110,MALLAPUR_110	11:01	11:09	0:08	LINE FAULT
197	30-May-2021	GULBARGA	110	SINDHNOOR-RAICHUR2	ADVIAWARESHWARA_110	4:03	4:23	0:20	LINE FAULT
198	30-May-2021	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110,DHADESUGAR_110,TEKKALKOTE_110,NSLSUGAR_IPP	4:05	4:28	0:23	LINE FAULT
199	30-May-2021	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110,DHADESUGAR_110,TEKKALKOTE_110,NSLSUGAR_IPP	4:55	5:08	0:13	LINE FAULT
200	30-May-2021	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	7:45	9:01	1:16	MAIN SUPPLY FAILURE
201	30-May-2021	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	10:51	11:08	0:17	MAIN SUPPLY FAILURE
202	30-May-2021	GULBARGA	110	YELBURGA-TALTSR	YELBURGA_110	21:30(29.5.2021)	3:55(30.05.2021)	6:25 HRS	LINE CHARGED
203	30-May-2021	GULBARGA	220	HV1	SEDAM_220	21:37(29.05.2021)	12:06(30.05.2021)	14:29HRS	TRANSFORMER CHARGED
204	30-May-2021	GULBARGA	220	MALLAT-ALKOD	ALKOD_110	2:41	2:51	0:10	LINE FAULT
205	30-May-2021	GULBARGA	220	SEDAM-VCATSAGAR_IPP	SEDAM_220(STATION NOT AFFECTED)	21:37(29.05.2021)			LINE OPEN, LINE FAULT
206	30-May-2021	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	22:11(29.05.2021)	18:17(30.05.2021)	20:06HRS	LINE CHARGED
207	30-May-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400(NO STATION AFFECTED)	22:04(15.05.2021)			LINE OPEN, LINE FAULT
208	30-May-2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400(NO STATION AFFECTED)	2:55(16.05.2021)			LINE OPEN,LINE CLEAR AVAILED
209	30-May-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHUPURA_66	12:05	17:40	5:35	LINE CLEAR AVAILED
210	30-May-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHUPURA_66	12:05	17:40	5:35	LINE CLEAR AVAILED
211	30-May-2021	HASSAN	66	SBELAG-SNTBCHL	SHRAVANABELAGOLA_66	6:00	6:25	0:25	LINE FAULT
212	30-May-2021	HASSAN	66	SBELAG-SNTBCHL	SHRAVANABELAGOLA_66	10:00	11:07	1:07	LINE FAULT
213	30-May-2021	HASSAN	110	HV1	DMKURKE_110	6:20	8:50	2:30	TRANSFORMER FAULT
214	30-May-2021	HASSAN	110	KADUR-TNGL	KADUR_220	15:36	17:00	1:24	LINE FAULT
215	30-May-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	9:01(28.5.2021)	8:43(30.05.2021)	23:41 hrs	LINE CHARGED
216	30-May-2021	MYSURU	66	CR NAGARA-KABBALLY	NO STATIONS INTERRUPTED.	5:40	5:58	0:17	LINE FAULT
217	30-May-2021	MYSURU	66	HV1	K_HONNAGERE_66	1:34	1:48	0:14	HAND TRIPPED
218	30-May-2021	MYSURU	66	HV1	JAKKANAHALLY_66	10:55	12:03	1:08	TRANSFORMER FAULT
219	30-May-2021	MYSURU	66	HV2	K_HONNAGERE_66	1:34	1:48	0:14	HAND TRIPPED
220	30-May-2021	MYSURU	66	HV4	SFCSHIVA_66	8:11	8:26	0:15	TRANSFORMER FAULT
221	30-May-2021	MYSURU	66	KR PETE 220-MADESHWARAPURA	MADESHWARAPURA_66 JAKKANAHALLY_66NAGAMANGALA_66 G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI_66	10:42	10:49	0:07	LINE FAULT
222	30-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN,LINE CLEAR AVAILED
223	30-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN,LINE CLEAR AVAILED
224	30-May-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:36	13:48	0:12	LINE FAULT
225	30-May-2021	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	16:17	16:23	0:05	LINE FAULT
226	30-May-2021	TUMKUR	66	TR-1	HIREGUNTANUR_66	15:38	16:23	0:44	LINE CLEAR AVAILED
227	30-May-2021	TUMKUR	66	TR-1	PAVAGADA_220	15:27	15:29	0:02	TRANSFORMER FAULT
228	30-May-2021	TUMKUR	66	TR-1	THOVINAKERE_66	13:17	14:48	1:31	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
229	30-May-2021	TUMKUR	66	TR-2	HIREGUNTANUR_66	15:38	16:23	0:44	LINE CLEAR AVAILED
230	30-May-2021	TUMKUR	66	TR-2	HOLALKERE_66	13:35	13:41	0:06	TRANSFORMER FAULT
231	30-May-2021	TUMKUR	66	TR-2	SASALUHALLA_66	12:20	12:51	0:30	LINE CLEAR AVAILED
1	31-May-2021	BAGALKOT	110	BAGEWADI220-MUDEDEBIHAL(ACHNUR)	MUDEDEBIHAL_110	3:04	3:17	0:13	LINE FAULT
2	31-May-2021	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED BILAGI_110	14:35	14:38	0:03	HAND TRIPPED
3	31-May-2021	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR_220	8:26	11:50	3:24	NFBC ISSUED
4	31-May-2021	BAGALKOT	110	220/110KV, LV3	RABAKAVI_110,HIDIKAL_110 STATION NOT AFFECTED MAHALINGAPUR_220	16:21	16:44	0:23	TRANSFORMER FAULT
5	31-May-2021	BAGALKOT	110	MAHALINGAPUR220-GSML	GSML_110 STATION NOT AFFECTED MAHALINGAPUR_220	10:30	11:50	1:20	LINE FAULT
6	31-May-2021	BAGALKOT	220	SOUADATTI220-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	8:15	11:53	3:38	LINE CLEAR AVAILED
7	31-May-2021	BAGALKOT	110	110/11KV,HV1	MANTUR(G)_110	22:13	22:19	0:06	TRANSFORMER FAULT
8	31-May-2021	BAGALKOT	110	110/11KV,HV1	MANTUR(G)_110	22:13	22:19	0:06	TRANSFORMER FAULT
9	31-May-2021	BAGALKOT	110	TAKKALAKI-WARADA SOLAR	STATION NOT AFFECTED TAKKALAKI_110	14:52 (31.05.2021)			LINE OPEN, LINE CLEAR AVAILED
10	31-May-2021	BAGALKOT	110	VAJRAMATTI220-BILAGI	BILAGI_110	16:01	16:10	0:09	HAND TRIPPED
11	31-May-2021	BENGALURU	66	HV2	APPAREL PARK	10:40	10:46	0:06	TRANSFORMER FAULT
12	31-May-2021	BENGALURU	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT), HMT (EHT)	18:59	19:38	0:39	LINE FAULT
13	31-May-2021	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	18:59	19:38	0:39	MAIN SUPPLY FAILURE
14	31-May-2021	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA, BEL (EHT), HMT (EHT)	22:15	22:20	0:05	LOAD CHANGE OVER
15	31-May-2021	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	16:20	16:52	0:32	LINE FAULT
16	31-May-2021	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	14:31	14:37	0:06	LINE FAULT
17	31-May-2021	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	18:55	19:06	0:11	MAIN SUPPLY FAILURE
18	31-May-2021	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	22:35	22:40	0:05	LOAD CHANGE OVER
19	31-May-2021	BENGALURU	66	HV2	R R NAGAR	8:25	8:36	0:11	TRANSFORMER FAULT
20	31-May-2021	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	18:59	19:12	0:13	MAIN SUPPLY FAILURE
21	31-May-2021	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	22:30	22:35	0:05	LOAD CHANGE OVER
22	31-May-2021	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	NO STATION AFFECTED	18:59	20:52	1:53	LINE FAULT
23	31-May-2021	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	NO STATION AFFECTED	18:59	20:52	1:53	LINE FAULT
24	31-May-2021	BENGALURU	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	18:37	23:59	5:22	LINE FAULT
25	31-May-2021	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	12:44	12:54	0:10	LINE FAULT
26	31-May-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	11:24	11:33	0:09	LINE FAULT
27	31-May-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	11:24	11:37	0:12	LINE FAULT
28	31-May-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	14:12	14:38	0:25	LINE FAULT
29	31-May-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTURU	5:26	5:33	0:06	LINE FAULT
30	31-May-2021	BENGALURU	66	HV1	AGALKOTE	11:15	11:55	0:40	LINE CLEAR AVAILED
31	31-May-2021	GULBARGA	400	RTPS-MEHBUBNAGAR	MEHBUBNAGAR_400	2:55(16.05.2021)			LINE OPEN, LINE FAULT
32	31-May-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:04(15.05.2021)	13:48(31.05.2021)	375:44HRS	LINE CHARGED
33	31-May-2021	GULBARGA	220	HALBARGA-HUMNABAD1,2	HALBARGA_220	16:38	16:55	0:17	LINE FAULT
34	31-May-2021	GULBARGA	220	HV1	KUSHTAGI_220	12:14	12:38	0:24	TRANSFORMER FAULT
35	31-May-2021	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	14:09	19:34	5:25	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
36	31-May-2021	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	16:45	19:29	2:44	LINE FAULT
37	31-May-2021	GULBARGA	220	HUMNABAD-KAPNOOR2	KAPNOOR_220	16:43	17:14	0:31	LINE FAULT
38	31-May-2021	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAWATH_110,VALKAMDINNI_110(IDLE)	10:13(31.05.2021)			LINE OPEN,LINE CLEAR AVAILED
39	31-May-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	10:13(31.05.2021)			LINE OPEN,LINE CLEAR AVAILED
40	31-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,D EVANGAON_110,RENUKA_IPP,AFZ ALPUR_110,KARAJAGI_110	16:20(30.05.2021)	00:48(31.05.2021)	08:28HRS	LINE CHARGED
41	31-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YEDRAMI_110,MORATAGI_110	23:52(30.05.2021)	00:38(31.05.2021)	00:46HRS	LINE CHARGED
42	31-May-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	3:05	3:19	0:14	LINE FAULT
43	31-May-2021	GULBARGA	110	HV2	SANKLAPUR_110	10:00	10:15	0:15	TRANSFORMER FAULT
44	31-May-2021	GULBARGA	110	HV2	HATTI_110	5:28	5:32	0:04	TRANSFORMER FAULT
45	31-May-2021	GULBARGA	110	MYLAR-GUTTAL	MYLAR_110	12:50	13:00	0:10	MAIN SUPPLY FAILURE
46	31-May-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110,GANGAVATHI_110,VE NKATAGIRI_110	11:03	11:50	0:47	LINE CLEAR AVAILED
47	31-May-2021	GULBARGA	110	MALLAT-BYAGWATH2	VALKAMDINNI,MADLAPUR_110,M ANVI_110	19:42	19:52	0:10	LINE FAULT
48	31-May-2021	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	21:37(29.05.2021)	17:43(31.05.2021)	44:06HRS	LINE CHARGED
49	31-May-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	23:45	23:58	0:13	LINE FAULT
50	31-May-2021	GULBARGA	110	MYLAR-GUTAL1	MYLAR_110	0:50	1:41	0:51	LINE CLEAR AVAILED
51	31-May-2021	GULBARGA	110	MYLAR-GUTAL1	MYLAR_110	11:05	11:40	0:35	LINE CLEAR AVAILED
52	31-May-2021	GULBARGA	110	HV2	SANKLAPUR_110	17:15	17:50	0:35	LINE CLEAR AVAILED
53	31-May-2021	GULBARGA	110	NALWAR-CLNSLR	NALWAR_110	10:09	10:27	0:18	LINE FAULT
54	31-May-2021	GULBARGA	110	HV2	BISLAHALLI_110	9:58	10:07	0:09	TRANSFORMER FAULT
55	31-May-2021	GULBARGA	110	HV3	DEODURGA_110	10:21	10:51	0:30	LINE CLEAR AVAILED
56	31-May-2021	GULBARGA	110	GULBARGAWEST-GULBARGASOUTH	GULBARGASOUTH_110	21:20	21:30	0:10	MAIN SUPPLY FAILURE
57	31-May-2021	GULBARGA	110	HV2	HATTI_110	5:29	5:32	0:03	TRANSFORMER FAULT
58	31-May-2021	GULBARGA	110	HALBARGA-HALLIKHED	HALLIKHED_110	16:12	16:15	0:03	LINE FAULT
59	31-May-2021	GULBARGA	110	HUMNABAD-HUMNABAD2	HUMNABAD_220	12:36	12:44	0:08	LINE FAULT
60	31-May-2021	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	16:43	17:30	0:47	LINE FAULT
61	31-May-2021	GULBARGA	66	BADALADAKU-KUDLIGI	KUDLIGI_66	13:50	16:30	2:40	NFBC ISSUED
62	31-May-2021	GULBARGA	66	KUDLIGI-HANASI	HANASI_66	13:50	16:30	2:40	LINE CLEAR AVAILED
63	31-May-2021	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_110	17:23(31.5.2021)			LINE OPEN, LINE FAULT
64	31-May-2021	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	19:36	19:49	0:13	LINE FAULT
65	31-May-2021	HASSAN	110	HV1	BANTWALA_110	10:19	12:15	1:56	LINE CLEAR AVAILED
66	31-May-2021	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	18:15	18:21	0:06	HAND TRIPPED
67	31-May-2021	HASSAN	66	HV2	KANDLI_66	14:05	14:10	0:05	HAND TRIPPED
68	31-May-2021	HASSAN	66	KIADB HARAMESWARNAGAR	KIADB_66	14:00	14:30	0:30	HAND TRIPPED
69	31-May-2021	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	11:31	16:42	5:11	LINE CLEAR AVAILED
70	31-May-2021	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	11:31	16:42	5:11	LINE CLEAR AVAILED
71	31-May-2021	HASSAN	66	SBELAG-SNTBCHL	SHRAVANABELAGOLA_66	11:23	13:26	2:03	LINE CLEAR AVAILED
72	31-May-2021	MYSURU	66	KUSHALANAGARA 220-HARANGI	NO STATIONS EFFECTED	10:25	17:54	7:29	LINE CLEAR AVAILED
73	31-May-2021	MYSURU	66	PARINAMIPURA-TALAKADU	CHANDALLI_66, THALAKADU_66	12:46	12:51	0:05	LINE FAULT
74	31-May-2021	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	9:56	12:37	2:41	LINE CLEAR AVAILED
75	31-May-2021	MYSURU	66	SFC SIVA-PPCL	NO STATIONS EFFECTED	10:37	15:51	5:14	LINE CLEAR AVAILED
76	31-May-2021	MYSURU	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	14:03	14:09	0:06	LINE FAULT
77	31-May-2021	MYSURU	220	KADAKOLA-KOZHIIKODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
78	31-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN,LINE CLEAR AVAILED
79	31-May-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	14:51 (29.05.2021)	19:04(31.05.2021)	50:00HRS	LINE CHARGED
80	31-May-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	14:51 (29.05.2021)	19:06(31.5.2021)	50:00HRS	LINE CHARGED
81	31-May-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA	KOLALA_66, URDIGERE_66	10:50	11:54	1:03	LINE CLEAR AVAILED
82	31-May-2021	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,YEDAVANI_66	6:54	7:09	0:15	LINE FAULT
83	31-May-2021	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	16:42	16:44	0:01	HAND TRIPPED
84	31-May-2021	TUMKUR	66	TR-1	BALENAHALLI_66	15:00	16:46	1:45	LINE CLEAR AVAILED
85	31-May-2021	TUMKUR	66	BENKIKERE-NALLUR66	BENKIKERE_66	10:38	11:31	0:52	LINE CLEAR AVAILED
86	31-May-2021	TUMKUR	66	BENKIKERE-NALLUR66	BENKIKERE_66	18:06	18:48	0:41	LINE CLEAR AVAILED
87	31-May-2021	TUMKUR	66	TR-1	BENKIKERE_66	11:29	14:15	2:45	LINE CLEAR AVAILED
88	31-May-2021	TUMKUR	66	TR-2	BENKIKERE_66	11:29	13:49	2:20	LINE CLEAR AVAILED
89	31-May-2021	TUMKUR	66	TR-1	CHANNAGIRI_66	8:06	8:17	0:11	TRANSFORMER FAULT
90	31-May-2021	TUMKUR	66	TR-1	CHANNAGIRI_66	8:34	8:46	0:11	TRANSFORMER FAULT
91	31-May-2021	TUMKUR	66	TR-1	DEVARAHALLI_66	11:24	11:43	0:18	MAIN SUPPLY FAILURE
92	31-May-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALI	SASUVEHALI_66,CHANNAGIRI_66	2:49	2:52	0:02	LINE FAULT
93	31-May-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAG UNDA_66	14:14	15:06	0:51	LINE CLEAR AVAILED
94	31-May-2021	TUMKUR	66	TR-2	HOSAKERE_66	9:27	9:55	0:27	TRANSFORMER FAULT
95	31-May-2021	TUMKUR	66	TR-1	PAVAGADA_220	15:01	15:06	0:04	TRANSFORMER FAULT
96	31-May-2021	TUMKUR	66	PAVAGADA_220-PAVGD1	PAVAGADA_220	18:13	18:16	0:02	LINE FAULT
97	31-May-2021	TUMKUR	66	URDIGERE-ANTHRASANAHALLI	URDIGERE_66	11:09	13:17	2:07	LINE CLEAR AVAILED