

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 20.08.2019 TO 26.08.2019

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
1	20-Aug-19	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	0:00	13:37	13:37	LINE CLEAR AVAILED
2	20-Aug-19	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	1:18	8:34	7:16	LINE FAULT
3	20-Aug-19	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	10:20	11:44	1:24	LINE FAULT
4	20-Aug-19	BAGALKOT	220	NAGJHARI1-HUBLI	HUBLI_220	10:17	17:24	7:07	LINE CLEAR AVAILED
5	20-Aug-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	13:33	23:59	10:26	LINE FAULT
6	20-Aug-19	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	16:01	23:59	7:58	LINE FAULT
7	20-Aug-19	BAGALKOT	220	SHARAVATHY1-SIRSI	SIRSI_220	0:00	16:21	16:21	LINE CLEAR AVAILED
8	20-Aug-19	BAGALKOT	220	NARENDRA-BELGAUM2	NARENDRA_220	12:29	17:20	4:51	LINE FAULT
9	20-Aug-19	BAGALKOT	110	NAREGAL-RON	RON_110	1:18	1:58	0:40	LINE FAULT
10	20-Aug-19	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	1:18	1:47	0:29	LINE FAULT
11	20-Aug-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	0:00	8:17	8:17	LINE CLEAR AVAILED
12	20-Aug-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	0:00	8:17	8:17	LINE CLEAR AVAILED
13	20-Aug-19	BAGALKOT	220	MK HUBLI-NARENDRA1	MK HUBLI_220	11:58	23:59	12:01	LINE CLEAR AVAILED
14	20-Aug-19	BAGALKOT	110	110/11KV, HV2	HATTARGI_110	13:35	14:07	0:32	LINE CLEAR AVAILED
15	20-Aug-19	BAGALKOT	110	RON1&2-GAJENDRAGAD	GAJENDRAGAD_110	1:18	13:19	12:01	LINE FAULT
16	20-Aug-19	BAGALKOT	110	110/11KV, HV2	BIDNAL_220	11:41	16:15	4:34	LINE CLEAR AVAILED
17	20-Aug-19	BAGALKOT	110	110/11KV, HV2	ANANDNAGAR_110	12:20	12:54	0:34	LINE CLEAR AVAILED
18	20-Aug-19	BAGALKOT	110	110/11KV, HV1	ANANDNAGAR_110	13:04	13:36	0:32	LINE CLEAR AVAILED
19	20-Aug-19	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	10:21	10:31	0:10	LINE FAULT
20	20-Aug-19	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	10:21	10:31	0:10	LINE FAULT
21	20-Aug-19	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	12:28	12:41	0:13	LINE FAULT
22	20-Aug-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	12:28	12:41	0:13	LINE FAULT
23	20-Aug-19	BENGALURU	66	HV1	GOWRIBIDANUR 220	8:33	8:50	0:17	TRANSFORMER FAULT
24	20-Aug-19	BENGALURU	66	HOSKOTE 220 - VIDYANAGARA	GRINDWELL (EHT)	6:19	7:16	0:57	LINE FAULT
25	20-Aug-19	BENGALURU	66	HOSKOTE 220 - VIDYANAGARA	GRINDWELL (EHT)	12:40	14:05	1:25	LINE CLEAR AVAILED
26	20-Aug-19	BENGALURU	66	HV1	HOSKOTE 220	12:25	13:15	0:50	LINE CLEAR AVAILED
27	20-Aug-19	BENGALURU	66	HV2	NANGLI	14:40	15:55	1:15	LINE CLEAR AVAILED
28	20-Aug-19	BENGALURU	66	SOMENAHALLI - GOWRIBIDANUR 220	SOMENAHALLI	11:35	11:50	0:15	LOAD CHANGEOVER
29	20-Aug-19	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI	17:40	17:45	0:05	LOAD CHANGEOVER
30	20-Aug-19	BENGALURU	66	DODDABALLAPURA 220 - DEVANAHALLI 1 & 2	DEVANAHALLI, KUNDANA	11:02	16:05	5:03	LINE CLEAR AVAILED
31	20-Aug-19	BENGALURU	66	DODDABALLAPURA 220 - D CROSS	D CROSS	10:43	10:49	0:06	LOAD CHANGEOVER
32	20-Aug-19	BENGALURU	66	DODDABALLAPURA 220 - D CROSS	D CROSS	16:07	16:09	0:02	LOAD CHANGEOVER
33	20-Aug-19	BENGALURU	66	DODDABALLAPURA 220 - DG 1	AIR (EHT)	11:01	11:15	0:14	LOAD CHANGEOVER
34	20-Aug-19	BENGALURU	66	DODDABALLAPURA 220 - DG 1	AIR (EHT)	12:39	13:35	0:56	LINE CLEAR AVAILED
35	20-Aug-19	BENGALURU	66	BEGUR 220 - BIAL 1	BIAL (EHT)	16:01	16:08	0:07	LINE CLEAR AVAILED
36	20-Aug-19	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	9:52	10:20	0:28	LINE FAULT
37	20-Aug-19	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	17:08	17:11	0:03	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
38	20-Aug-19	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	9:52	10:20	0:28	LINE FAULT
39	20-Aug-19	BENGALURU	66	HV2	BOODIGERE	9:52	10:20	0:28	TRANSFORMER FAULT
40	20-Aug-19	BENGALURU	66	HV2	BOODIGERE	14:00	14:05	0:05	LOAD CHANGEOVER
41	20-Aug-19	BENGALURU	66	LV1	DODDABALLAPURA 220	11:08	16:04	4:56	LINE CLEAR AVAILED
42	20-Aug-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	21:22	21:47	0:24	MAIN SUPPLY FAILURE
43	20-Aug-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	21:22	21:49	0:27	MAIN SUPPLY FAILURE
44	20-Aug-19	BENGALURU	220	HV3	SUBRAMANYAPURA 220	21:22	21:41	0:18	TRANSFORMER FAULT
45	20-Aug-19	BENGALURU	66	LV3	SUBRAMANYAPURA 220	21:22	21:41	0:18	TRANSFORMER FAULT
46	20-Aug-19	BENGALURU	66	HV2	REMCO	21:22	21:35	0:12	MAIN SUPPLY FAILURE
47	20-Aug-19	BENGALURU	66	KADUGODI - EPIP 220	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	15:00	15:30	0:30	LINE CLEAR AVAILED
48	20-Aug-19	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110,KONKAL_110	1:22	1:31	0:09	LINE FAULT
49	20-Aug-19	GULBARGA	110	HALBURGA-CHIDRI1	KAMTHANA_110,HABSIKOTE_110	19:02	19:10	0:08	LINE FAULT
50	20-Aug-19	GULBARGA	110	HV1	DHADESUGUR_110	12:30	12:50	0:20	LINE CLEAR AVAILED
51	20-Aug-19	GULBARGA	110	HV2	DHADESUGUR_110	12:50	13:10	0:20	LINE CLEAR AVAILED
52	20-Aug-19	GULBARGA	110	HV1	DHADESUGUR_110	22:32	22:57	0:25	TRANSFORMER FAULT
53	20-Aug-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	18:37	18:37	LINE CLEAR AVAILED
54	20-Aug-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	19:15	23:59	4:44	LINE CLEAR AVAILED
55	20-Aug-19	HASSAN	220	GERSOPA-STRP1	GERSOPA	10:06	18:51	8:45	LINE CLEAR AVAILED
56	20-Aug-19	HASSAN	110	HV1	GURUPUR	10:30	14:32	4:02	LINE CLEAR AVAILED
57	20-Aug-19	HASSAN	110	GURUPUR-KAVOOR	GURUPUR	10:30	14:32	4:02	LINE CLEAR AVAILED
58	20-Aug-19	HASSAN	110	HV4	MRSMSG_220	16:54	17:27	0:33	TRANSFORMER FAULT
59	20-Aug-19	HASSAN	66	LV4	MRSMSG_220	16:54	17:28	0:34	TRANSFORMER FAULT
60	20-Aug-19	HASSAN	66	HV1	HARIHAR	15:15	17:52	2:37	LINE CLEAR AVAILED
61	20-Aug-19	HASSAN	66	HARIHAR-KADUVINKOTE	HARIHAR	15:15	17:52	2:37	LINE CLEAR AVAILED
62	20-Aug-19	MYSORE	66	HV2	BOMMALAPURA_66	8:10	8:18	0:08	TRANSFORMER FAULT
63	20-Aug-19	MYSORE	66	HV2	MADIKERI_66	8:21	9:23	1:01	LINE CLEAR AVAILED
64	20-Aug-19	TUMKUR	400	GUTTUR 400KV- KAIGA	GUTUR_400	1:38	9:59	8:20	LINE CLEAR AVAILED
65	20-Aug-19	TUMKUR	220	TR-1(HV SIDE)	HONNALLI_220	12:15	13:47	1:31	LINE CLEAR AVAILED
66	20-Aug-19	TUMKUR	220	TR-2(HV SIDE)	KBCROSS_220	17:03	19:31	2:28	LINE CLEAR AVAILED
67	20-Aug-19	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR_IPP_66	AZURE POWER SOLAR_IPP_66	11:56	16:01	4:04	LINE CLEAR AVAILED
68	20-Aug-19	TUMKUR	220	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	11:38	15:54	4:16	LINE FAULT
69	20-Aug-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	10:00	10:14	0:14	TRANSFORMER FAULT
70	20-Aug-19	TUMKUR	220	HIRIYUR220-MADHUGIRI	HIRIYUR_220	11:58	12:59	1:01	LINE CLEAR AVAILED
71	20-Aug-19	TUMKUR	220	HIRIYUR 220kv- PGCIL	HIRIYUR_220	12:59	15:43	2:44	LINE CLEAR AVAILED
72	20-Aug-19	TUMKUR	110	TR-1	TURUVEKERE_110	16:56	17:06	0:10	LINE CLEAR AVAILED
73	20-Aug-19	TUMKUR	110	TR-2	TURUVEKERE_110	16:56	17:05	0:09	LINE CLEAR AVAILED
74	20-Aug-19	TUMKUR	110	TURUVEKERE110-KBCROSS	TURUVEKERE_110	16:55	17:05	0:09	LINE CLEAR AVAILED
75	20-Aug-19	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	17:02	19:33	2:30	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
76	20-Aug-19	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	15:01	16:35	1:34	LINE CLEAR AVAILED
77	20-Aug-19	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	12:57	13:05	0:07	LINE CLEAR AVAILED
78	20-Aug-19	TUMKUR	66	TR-2	GULIGENAHALLI_66	14:41	15:01	0:19	LINE CLEAR AVAILED
79	20-Aug-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	12:11	12:19	0:08	LINE FAULT
80	20-Aug-19	TUMKUR	66	TR-1(LV SIDE)	HONNALLI_220	12:14	13:48	1:34	LINE CLEAR AVAILED
81	20-Aug-19	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	23:40	23:42	0:02	MAIN SUPPLY FAILURE
82	20-Aug-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	14:21	16:53	2:32	LINE CLEAR AVAILED
83	20-Aug-19	TUMKUR	66	TR-1	YNHOSKOTE_66	11:10	13:23	2:12	LINE CLEAR AVAILED
84	20-Aug-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	12:31	18:05	5:33	MAIN SUPPLY FAILURE
85	20-Aug-19	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	10:31	11:35	1:03	MAIN SUPPLY FAILURE
86	20-Aug-19	TUMKUR	66	RANGANATHAPURA-HIRIYUR	RANGENAHALLI_66	12:31	18:05	5:33	MAIN SUPPLY FAILURE
87	20-Aug-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:06	10:20	0:14	HAND TRIPPED
88	20-Aug-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	11:25	16:47	5:22	LINE CLEAR AVAILED
89	20-Aug-19	TUMKUR	220	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	21:46	23:40	1:53	LINE CLEAR AVAILED
90	20-Aug-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	11:25	12:11	0:46	HAND TRIPPED
91	20-Aug-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	15:43	16:35	0:51	HAND TRIPPED
92	20-Aug-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	23:25	23:38	0:12	HAND TRIPPED
93	20-Aug-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	10:04	16:47	6:42	LINE CLEAR AVAILED
94	20-Aug-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	22:01	23:42	1:41	LINE CLEAR AVAILED
95	20-Aug-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	10:04	16:47	6:42	LINE CLEAR AVAILED
96	20-Aug-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	22:01	23:42	1:40	LINE CLEAR AVAILED
97	20-Aug-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	10:05	13:30	3:24	LINE CLEAR AVAILED
98	20-Aug-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	15:43	16:16	0:33	HAND TRIPPED
99	20-Aug-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	21:51	23:38	1:46	LINE CLEAR AVAILED
100	21-Aug-19	BAGALKOT	110	110/11KV, HV1	BYADAGI_110	11:15	11:40	0:25	LINE CLEAR AVAILED
101	21-Aug-19	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	20:05	20:10	0:05	LINE FAULT
102	21-Aug-19	BAGALKOT	220	LINGASUR2-BAGEWADI	BAGEWADI_220	11:00	11:35	0:35	LINE FAULT
103	21-Aug-19	BAGALKOT	220	BIJAPUR-INDI2	BIJAPUR_220	10:35	16:55	6:20	LINE CLEAR AVAILED
104	21-Aug-19	BAGALKOT	110	GADAG-LAXMESHWAR1&2	LAXMESHWAR_110	10:03	17:55	7:52	LINE CLEAR AVAILED
105	21-Aug-19	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA2	GHATAPRABHA_110	17:00	17:30	0:30	LINE FAULT
106	21-Aug-19	BAGALKOT	110	HAVERI220-TILUVALLI	TILUVALLI_110	16:11	16:36	0:25	HAND TRIPPED
107	21-Aug-19	BAGALKOT	110	LAXMESHWAR-BELLATTI	BELLATTI_110	10:32	17:58	7:26	LINE CLEAR AVAILED
108	21-Aug-19	BAGALKOT	110	MAMDAPUR(B)-TODALBAGI	TODALBAGI_110, SAVALGI_110	12:25	13:35	1:10	LINE CLEAR AVAILED
109	21-Aug-19	BAGALKOT	110	MKHUBLI220-KITTUR	KITTUR_110	11:32	11:56	0:24	LINE CLEAR AVAILED
110	21-Aug-19	BAGALKOT	110	110/11KV, HV3	MUDALGI_110	15:08	16:00	0:52	TRANSFORMER FAULT
111	21-Aug-19	BAGALKOT	110	SATTI SUGARS-PG HUNSHYAL	PG HUNSHYAL_110	9:38	11:45	2:07	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
112	21-Aug-19	BAGALKOT	110	SOUNDATTI220-UDIKERI	UDIKERI_110	20:55	21:32	0:37	HAND TRIPPED
113	21-Aug-19	BAGALKOT	110	110/11KV, HV1	YELPARHATTI_110	14:00	14:20	0:20	LINE CLEAR AVAILED
114	21-Aug-19	BAGALKOT	220	NAGJHARI2-HUBLI	HUBLI_220	10:07	16:27	6:20	LINE CLEAR AVAILED
115	21-Aug-19	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	7:35	7:38	0:03	LOAD CHANGEOVER
116	21-Aug-19	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	10:05	10:14	0:09	LOAD CHANGEOVER
117	21-Aug-19	BENGALURU	66	HV2	ISRO LAYOUT	6:16	7:32	1:15	TRANSFORMER FAULT
118	21-Aug-19	BENGALURU	66	HV2	KADUBISANAHALLI	13:25	14:26	1:00	TRANSFORMER FAULT
119	21-Aug-19	BENGALURU	66	HV1	MELEHALLI	10:14	10:16	0:02	LINE CLEAR AVAILED
120	21-Aug-19	BENGALURU	66	HV1	MELEHALLI	11:23	12:36	1:13	LINE CLEAR AVAILED
121	21-Aug-19	BENGALURU	66	HV2	POTTERY ROAD	13:06	13:12	0:06	LINE CLEAR AVAILED
122	21-Aug-19	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 2	BAGEPALLI	12:30	14:35	2:05	LINE CLEAR AVAILED
123	21-Aug-19	BENGALURU	66	HV1	CHAKAVELU	8:51	9:25	0:34	LINE CLEAR AVAILED
124	21-Aug-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	18:41	18:52	0:11	LINE FAULT
125	21-Aug-19	BENGALURU	66	HV1	GOWRIBIDANUR 220	12:50	13:05	0:15	TRANSFORMER FAULT
126	21-Aug-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	11:07	14:29	3:22	LINE CLEAR AVAILED
127	21-Aug-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	11:08	14:29	3:21	LINE CLEAR AVAILED
128	21-Aug-19	BENGALURU	66	HV1	HOSKOTE 220	11:45	12:05	0:20	LINE CLEAR AVAILED
129	21-Aug-19	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	11:00	16:45	5:45	LINE CLEAR AVAILED
130	21-Aug-19	BENGALURU	66	HV2	MAASTHI	13:00	13:22	0:22	TRANSFORMER FAULT
131	21-Aug-19	BENGALURU	66	HV2	NANGLI	15:45	16:17	0:32	LINE CLEAR AVAILED
132	21-Aug-19	BENGALURU	66	HV3	MANYATA TECH PARK 220	17:13	18:30	1:17	LOAD CHANGEOVER
133	21-Aug-19	BENGALURU	66	MANYATA TECH PARK 220 - MANYATA TECH PARK 66	MANYATA TECH PARK 66	17:13	17:18	0:05	LOAD CHANGEOVER
134	21-Aug-19	BENGALURU	66	MANYATA TECH PARK 220 - HENNUR CROSS	HENNUR CROSS	17:13	17:18	0:05	LOAD CHANGEOVER
135	21-Aug-19	GULBARGA	220	RAICHUR-JURALA1&2	RAICHUR_220	10:45	18:36	7:51	LINE CLEAR AVAILED
136	21-Aug-19	GULBARGA	110	HV2	BETAGERA_110	10:27	12:10	1:43	LINE CLEAR AVAILED
137	21-Aug-19	GULBARGA	110	HV1	ITTAGI_220	11:25	11:55	0:30	LINE CLEAR AVAILED
138	21-Aug-19	GULBARGA	110	HV1	ITTAGI_220	11:25	12:05	0:40	TRANSFORMER FAULT
139	21-Aug-19	GULBARGA	110	HV2	ITTAGI_220	11:25	12:50	1:25	TRANSFORMER FAULT
140	21-Aug-19	GULBARGA	110	KUSTAGI-SUZLON1	KUSTAGI_220	13:00	14:00	1:00	LINE FAULT
141	21-Aug-19	GULBARGA	110	KUSTAGI-SUZLON1	KUSTAGI_220	14:05	14:37	0:32	LINE FAULT
142	21-Aug-19	GULBARGA	110	SHAHPUR-WARDHASLR_IPP	SHAHPUR_220	20:15	22:32	2:17	LINE FAULT
143	21-Aug-19	GULBARGA	110	SIDHANOOR-TURVIHAL	TURVIHAL_110	0:32	0:55	0:23	LINE FAULT
144	21-Aug-19	GULBARGA	110	SEDAM-RTPS2	SEDAM_220	19:20	19:44	0:24	LINE FAULT
145	21-Aug-19	GULBARGA	110	SHAHPUR-WARDHASLR_IPP	SHAHPUR_220	11:19	12:00	0:41	LINE FAULT
146	21-Aug-19	GULBARGA	66	ITTAGI-CLNMAX1_IPP	ITTAGI_220	10:18	10:23	0:05	HAND TRIPPED
147	21-Aug-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	12:02	12:02	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
148	21-Aug-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	11:17	14:58	3:41	LINE CLEAR AVAILED
149	21-Aug-19	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	9:47	19:24	9:37	LINE CLEAR AVAILED
150	21-Aug-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	11:08	14:53	3:45	LINE CLEAR AVAILED
151	21-Aug-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	11:16	14:58	3:42	LINE CLEAR AVAILED
152	21-Aug-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	0:00	18:46	18:46	LINE CLEAR AVAILED
153	21-Aug-19	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	9:20	9:47	0:27	LINE CLEAR AVAILED
154	21-Aug-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	11:08	14:53	3:45	LINE CLEAR AVAILED
155	21-Aug-19	HASSAN	110	HV4	MRSMSG_220	9:04	15:05	6:01	LINE CLEAR AVAILED
156	21-Aug-19	HASSAN	110	HV5	PUTTUR_220	11:58	13:41	1:43	LINE CLEAR AVAILED
157	21-Aug-19	HASSAN	110	HV3	BAIKAMPADI_110	16:11	17:11	1:00	TRANSFORMER FAULT
158	21-Aug-19	HASSAN	110	GURUPURA-KAVOOR	GURUPURA_110	15:55	23:59	8:04	LINE CLEAR AVAILED
159	21-Aug-19	HASSAN	110	HV3	KONAJE_110	11:37	14:00	2:23	LINE CLEAR AVAILED
160	21-Aug-19	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	15:50	15:56	0:06	HAND TRIPPED
161	21-Aug-19	HASSAN	110	HV1	NAVUNDA-110	13:41	14:42	1:01	LINE CLEAR AVAILED
162	21-Aug-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	10:05	10:33	0:28	LINE FAULT
163	21-Aug-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	14:55	15:39	0:44	LINE CLEAR AVAILED
164	21-Aug-19	HASSAN	66	LV4	MRSMSG_220	9:04	15:05	6:01	LINE CLEAR AVAILED
165	21-Aug-19	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	14:31	16:24	1:53	LINE FAULT
166	21-Aug-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	11:25	13:47	2:22	LINE CLEAR AVAILED
167	21-Aug-19	HASSAN	66	HV1	CHIKMAGALUR_66	16:06	16:20	0:14	HAND TRIPPED
168	21-Aug-19	HASSAN	66	HV1	HANGARANAHALLY_66	12:16	13:10	0:54	LINE CLEAR AVAILED
169	21-Aug-19	HASSAN	66	HASSN220-HN PURA	HOLEHONNUR_220	6:15	6:31	0:16	LINE FAULT
170	21-Aug-19	HASSAN	66	HV2	HOLEHONNUR_66	12:27	12:54	0:27	LINE CLEAR AVAILED
171	21-Aug-19	HASSAN	66	HV1	HOLEHONNUR_66	16:49	17:03	0:14	LINE CLEAR AVAILED
172	21-Aug-19	HASSAN	66	HV2	HOLEHONNUR_66	16:49	17:03	0:14	LINE CLEAR AVAILED
173	21-Aug-19	HASSAN	66	HV2	RAMNATHPURA_66	11:25	11:33	0:08	HAND TRIPPED
174	21-Aug-19	MYSORE	66	HV2	DEVANOORNGUDU_66	0:02	0:08	0:05	TRANSFORMER FAULT
175	21-Aug-19	MYSORE	66	HV2	HAMPAPURA_66	16:29	17:28	0:58	TRANSFORMER FAULT
176	21-Aug-19	MYSORE	66	JYOTHINAGARA-VAJAMANGALA	HAMPAPURA_66	15:19	19:28	4:08	NFBC ISSUED
177	21-Aug-19	MYSORE	66	HV2	KRPET_66	12:31	14:17	1:46	LINE CLEAR AVAILED
178	21-Aug-19	MYSORE	66	HV1	KRPET_66	10:25	11:45	1:20	LINE CLEAR AVAILED
179	21-Aug-19	MYSORE	66	HV3	KRPET_66	11:40	13:10	1:30	LINE CLEAR AVAILED
180	21-Aug-19	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	BOGADHI MANDYA_66, GUDDENAHALLI_66, G MALLIGERE_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	9:35	9:47	0:12	LINE FAULT
181	21-Aug-19	MYSORE	66	KUSHALNAGARA 220-BYLUKUPPE	BYLUKUPPE_66	16:01	16:19	0:18	LINE FAULT
182	21-Aug-19	MYSORE	66	KUSHALNAGARA 220-PERIYAPATNA-1	PERIYAPATNA_66, PONNAMPET_66, VIRAJPET_66	16:01	16:19	0:18	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
183	21-Aug-19	MYSORE	66	HV1	SINDHUVALI_66	10:28	17:17	6:48	LINE CLEAR AVAILED
184	21-Aug-19	MYSORE	66	HV2	SINDHUVALI_66	10:30	17:17	6:47	LINE CLEAR AVAILED
185	21-Aug-19	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66, ADICHUNCHANAGIRI_66, BASARALU_66, BGNAGARA_66, HARADANAHALLI(JAK)_66, KESLAGERE_66, VADKEPURA_66	2:21	2:30	0:09	LINE FAULT
186	21-Aug-19	MYSORE	66	VAJMANGALA-BANNUR	BANNUR_66, KIRUGAVALU_66, MALIYURU_66	8:28	8:42	0:14	LINE FAULT
187	21-Aug-19	MYSORE	220	HV1	VAJAMANGALA_220	10:32	18:38	8:05	LINE CLEAR AVAILED
188	21-Aug-19	MYSORE	220	HV2	VAJAMANGALA_220	10:32	18:49	8:16	LINE CLEAR AVAILED
189	21-Aug-19	MYSORE	66	HV1	VAJAMANGALA_220	15:05	18:51	3:45	LINE CLEAR AVAILED
190	21-Aug-19	MYSORE	66	HV2	VAJAMANGALA_220	15:25	18:35	3:09	LINE CLEAR AVAILED
191	21-Aug-19	MYSORE	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66, MARADIHUNDI_66	10:09	19:26	9:16	LINE CLEAR AVAILED
192	21-Aug-19	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	15:26	19:01	3:35	LINE CLEAR AVAILED
193	21-Aug-19	TUMKUR	220	TR-2(HV SIDE)	DAVANGERE_SRS_220	11:41	14:54	3:13	LINE CLEAR AVAILED
194	21-Aug-19	TUMKUR	220	GUTUR 66-DAVANGERE SRS-1	GUTUR_66	15:29	19:03	3:34	LINE CLEAR AVAILED
195	21-Aug-19	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR_IPP_66	AZURE POWER SOLAR_IPP_66	11:00	11:01	0:01	HAND TRIPPED
196	21-Aug-19	TUMKUR	110	TR-1	BIDARE_110	12:52	14:50	1:57	LINE CLEAR AVAILED
197	21-Aug-19	TUMKUR	110	BIDARE- NITTUR	BIDARE_110	12:52	14:50	1:57	LINE CLEAR AVAILED
198	21-Aug-19	TUMKUR	110	TR-1	SHETYKERE_110	12:07	13:10	1:02	LINE CLEAR AVAILED
199	21-Aug-19	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	15:19	15:32	0:13	LINE FAULT
200	21-Aug-19	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66	17:33	17:56	0:22	LINE FAULT
201	21-Aug-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:18	12:45	1:27	LINE CLEAR AVAILED
202	21-Aug-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	9:50	10:43	0:53	LOAD CHANGEOVER
203	21-Aug-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	13:34	14:55	1:20	LOAD CHANGEOVER
204	21-Aug-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	9:50	10:47	0:57	LOAD CHANGEOVER
205	21-Aug-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	13:34	13:35	0:01	LOAD CHANGEOVER
206	21-Aug-19	TUMKUR	66	TR-1(HV SIDE)	DAVANGERE_SRS_220	9:50	10:29	0:39	LINE CLEAR AVAILED
207	21-Aug-19	TUMKUR	66	TR-1(HV SIDE)	DAVANGERE_SRS_220	14:02	15:01	0:58	LINE CLEAR AVAILED
208	21-Aug-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:56	12:30	1:33	LOAD CHANGEOVER
209	21-Aug-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	13:09	14:54	1:45	LOAD CHANGEOVER
210	21-Aug-19	TUMKUR	66	TR-1	HALURAMESHWARA_66	13:03	14:31	1:27	LINE CLEAR AVAILED
211	21-Aug-19	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66, BAGUR_66, NEELAGUNDA_66	11:21	12:21	0:59	LINE CLEAR AVAILED
212	21-Aug-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	11:47	11:55	0:08	HAND TRIPPED
213	21-Aug-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	13:13	13:22	0:09	HAND TRIPPED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
214	21-Aug-19	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR_IPP_66	BPCLSOLAR_IPP_66	5:54	6:02	0:08	LINE FAULT
215	21-Aug-19	TUMKUR	66	TR-1	KORA_66	6:20	6:52	0:32	TRANSFORMER FAULT
216	21-Aug-19	TUMKUR	66	TR-2	KUNIGAL_66	0:00	0:36	0:35	TRANSFORMER FAULT
217	21-Aug-19	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	12:56	12:57	0:01	MAIN SUPPLY FAILURE
218	21-Aug-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	11:30	11:42	0:11	MAIN SUPPLY FAILURE
219	21-Aug-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	11:30	11:42	0:11	MAIN SUPPLY FAILURE
220	21-Aug-19	TUMKUR	66	TR-2	TELAGI_66	15:59	17:36	1:36	LINE CLEAR AVAILED
221	21-Aug-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:43	10:59	0:16	HAND TRIPPED
222	21-Aug-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:18	13:02	2:43	LINE CLEAR AVAILED
223	21-Aug-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	11:04	12:53	1:49	LINE CLEAR AVAILED
224	21-Aug-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	10:21	13:03	2:42	LINE CLEAR AVAILED
225	21-Aug-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	10:21	13:04	2:43	LINE CLEAR AVAILED
226	21-Aug-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	8:18	8:32	0:13	HAND TRIPPED
227	21-Aug-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	10:17	13:59	3:42	LINE CLEAR AVAILED
228	22-Aug-19	BAGALKOT	220	NAGAJHARI 1&2-AMBEWADI	AMBEWADI_220	15:45	15:59	0:14	LINE FAULT
229	22-Aug-19	BAGALKOT	110	110/11KV,HV1	BEDI_110	10:55	12:15	1:20	LINE CLEAR AVAILED
230	22-Aug-19	BAGALKOT	110	110/11KV,HV-2	BEDI_110	16:00	16:20	0:20	LINE CLEAR AVAILED
231	22-Aug-19	BAGALKOT	110	110/33KV,HV 4	BYADAGI_110	12:50	13:20	0:30	LINE CLEAR AVAILED
232	22-Aug-19	BAGALKOT	110	BIDNAL-NAVALGUND-GOPANAKOPPA	GOPANAKOPPA_110	15:51	19:14	3:23	LINE FAULT
233	22-Aug-19	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	6:32	6:43	0:11	LOAD CURTAILMENT
234	22-Aug-19	BAGALKOT	110	SOVERIGEN-TERDAL	TERDAL_110	10:40	10:50	0:10	HAND TRIPPED
235	22-Aug-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	10:52	14:54	4:02	LINE CLEAR AVAILED
236	22-Aug-19	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	15:44	23:59	8:15	LINE FAULT
237	22-Aug-19	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_110	10:54	15:40	4:46	LINE CLEAR AVAILED
238	22-Aug-19	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	10:54	17:02	6:08	LINE CLEAR AVAILED
239	22-Aug-19	BAGALKOT	110	110/11KV, HV1	SIRSI_110	10:03	17:01	6:58	LINE CLEAR AVAILED
240	22-Aug-19	BAGALKOT	110	SIRSI110-SIDDAPUR	SIDDAPUR_110	10:55	15:40	4:45	LINE CLEAR AVAILED
241	22-Aug-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	10:55	16:58	6:03	LINE CLEAR AVAILED
242	22-Aug-19	BAGALKOT	110	SIRSI-KUMTA1&2	SIRSI_110	9:50	16:50	7:00	LINE CLEAR AVAILED
243	22-Aug-19	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	10:07	16:40	6:33	LINE CLEAR AVAILED
244	22-Aug-19	BAGALKOT	110	110/11KV, HV1	TILUVALI_110	12:55	19:25	6:30	LINE CLEAR AVAILED
245	22-Aug-19	BAGALKOT	110	110/11KV, HV3	TILUVALI_110	12:00	12:57	0:57	TRANSFORMER FAULT
246	22-Aug-19	BAGALKOT	110	HAVERI220-TILUVALI	TILUVALI_110	12:00	12:57	0:57	LINE CLEAR AVAILED
247	22-Aug-19	BAGALKOT	110	110/11KV, HV1	SANKESHWAR_110	11:15	12:55	1:40	LINE CLEAR AVAILED
248	22-Aug-19	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	14:10	14:15	0:05	LINE CLEAR AVAILED
249	22-Aug-19	BAGALKOT	110	110/33KV, HV3	SANKESHWAR_110, HEBBAL_33, KANAGAL_33	12:54	14:03	1:09	LINE CLEAR AVAILED
250	22-Aug-19	BAGALKOT	110	110/11KV, HV1	HIREKERUR_110	10:01	17:05	7:04	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
251	22-Aug-19	BAGALKOT	110	110/11KV, HV3	HIREKERUR_110	10:30	17:20	6:50	LINE CLEAR AVAILED
252	22-Aug-19	BAGALKOT	110	110/33KV, HV2	HIREKERUR_110, CHIKKERUR_33, KODARI_33	10:07	18:23	8:16	LINE CLEAR AVAILED
253	22-Aug-19	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, AMINGAD_33, KARADI_33	10:03	14:48	4:45	LINE CLEAR AVAILED
254	22-Aug-19	BAGALKOT	66	66/33KV, HV4	HARIHAR-HOSPET_66, MUDENUR_33	6:32	6:45	0:13	LOAD CURTAILMENT
255	22-Aug-19	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 2	PATHPALYA, THIMAMPALLI, SOMANATHAPURA	9:55	10:08	0:12	LOAD CHANGEOVER
256	22-Aug-19	BENGALURU	66	HV2	CHANDAPURA	21:48	21:55	0:07	TRANSFORMER FAULT
257	22-Aug-19	BENGALURU	66	HV1	DODDABELAVANGALA	12:52	18:15	5:22	LINE CLEAR AVAILED
258	22-Aug-19	BENGALURU	66	HV2	DODDABELAVANGALA	12:52	18:15	5:22	LINE CLEAR AVAILED
259	22-Aug-19	BENGALURU	66	DB PURA 220 - DG2	DODDABELAVANGALA, GUNDAMGERE	13:00	17:03	4:02	LINE CLEAR AVAILED
260	22-Aug-19	BENGALURU	66	HV1	GOWRIBIDANUR 220	16:05	18:08	2:03	LINE CLEAR AVAILED
261	22-Aug-19	BENGALURU	66	GOWRIBIDANUR 220 - DB 2	TONDEBHAVI	17:10	17:20	0:10	LINE FAULT
262	22-Aug-19	BENGALURU	66	HONNIGANAHALLI - HALAGUR	HALAGUR	11:30	12:42	1:12	LINE CLEAR AVAILED
263	22-Aug-19	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	13:01	15:28	2:26	LINE CLEAR AVAILED
264	22-Aug-19	BENGALURU	66	JIGANI 66 - BG ROAD	JIGANI 66	13:01	15:28	2:26	LINE CLEAR AVAILED
265	22-Aug-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	6:43	7:33	0:49	LOAD CURTAILMENT
266	22-Aug-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 2	AMARIYOTHI, BOSCH (EHT)	15:23	16:13	0:50	LINE FAULT
267	22-Aug-19	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	13:41	13:47	0:06	LOAD CHANGEOVER
268	22-Aug-19	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	10:05	10:18	0:13	LOAD CHANGEOVER
269	22-Aug-19	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	13:42	13:50	0:08	LOAD CHANGEOVER
270	22-Aug-19	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	14:44	14:49	0:05	LOAD CHANGEOVER
271	22-Aug-19	BENGALURU	66	KHODAYS 220 - SOUTH CITY	SOUTH CITY	13:41	13:48	0:07	LOAD CHANGEOVER
272	22-Aug-19	BENGALURU	66	HV1	AMARIYOTHI	11:20	11:36	0:16	LOAD CHANGEOVER
273	22-Aug-19	BENGALURU	66	HV1	AMARIYOTHI	12:50	12:56	0:05	LOAD CHANGEOVER
274	22-Aug-19	BENGALURU	66	HV1	BTM 4TH PHASE	13:40	13:50	0:10	MAIN SUPPLY FAILURE
275	22-Aug-19	BENGALURU	66	HV1	BTM 4TH PHASE	14:37	14:43	0:06	MAIN SUPPLY FAILURE
276	22-Aug-19	BENGALURU	66	HV2	BTM 4TH PHASE	13:40	13:50	0:10	MAIN SUPPLY FAILURE
277	22-Aug-19	BENGALURU	66	HV2	BTM 4TH PHASE	14:37	14:43	0:06	MAIN SUPPLY FAILURE
278	22-Aug-19	BENGALURU	220	HV2	HSR LAYOUT 220	15:23	16:00	0:37	TRANSFORMER FAULT
279	22-Aug-19	BENGALURU	66	HV1	KHODAYS 220	13:32	13:35	0:03	LOAD CHANGEOVER
280	22-Aug-19	BENGALURU	66	HV2	KHODAYS 220	13:41	13:46	0:05	LOAD CHANGEOVER
281	22-Aug-19	BENGALURU	66	HV1	KHODAYS 220	10:05	10:18	0:13	LOAD CHANGEOVER
282	22-Aug-19	BENGALURU	66	HV2	KHODAYS 220	10:05	10:18	0:13	LOAD CHANGEOVER
283	22-Aug-19	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	5:23	16:43	11:20	LINE FAULT
284	22-Aug-19	GULBARGA	220	HV1,HV2	LINGASUGUR_220	19:10	19:20	0:10	TRANSFORMER FAULT
285	22-Aug-19	GULBARGA	220	HV1,LV1	SHAHPUR_220	13:17	13:21	0:04	TRANSFORMER FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
286	22-Aug-19	GULBARGA	220	HV1,LV1	SHAHPUR_220	14:13	14:21	0:08	TRANSFORMER FAULT
287	22-Aug-19	GULBARGA	110	HV2	ALAND_110	6:30	6:40	0:10	LOAD CURTAILMENT
288	22-Aug-19	GULBARGA	110	SHAHPUR-WARDHASLR_IPP	SHAHPUR_220	12:11	12:17	0:06	LINE CLEAR AVAILED
289	22-Aug-19	GULBARGA	110	LV2	KUSTAGI_220	8:56	9:10	0:14	TRANSFORMER FAULT
290	22-Aug-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	13:14	13:20	0:06	LINE FAULT
291	22-Aug-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	13:34	13:40	0:06	LINE FAULT
292	22-Aug-19	GULBARGA	110	KOLHAR-HALBARGA	KOLHAR_110	10:55	12:00	1:05	LINE FAULT
293	22-Aug-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	10:55	11:05	0:10	LINE FAULT
294	22-Aug-19	GULBARGA	110	HV1	DHADESUGUR_110	6:35	6:45	0:10	TRANSFORMER FAULT
295	22-Aug-19	GULBARGA	110	LINGASUGUR-MUDGAL	MUDAGAL_110	19:10	20:32	1:22	LINE FAULT
296	22-Aug-19	GULBARGA	66	KOTTUR-SUZLON1	KOTTUR_66	16:03	16:40	0:37	LINE CLEAR AVAILED
297	22-Aug-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	2:13	23:59	21:46	LINE CLEAR AVAILED
298	22-Aug-19	HASSAN	220	KADUR-SHIMOGA	KADUR_220	9:12	17:08	7:56	LINE CLEAR AVAILED
299	22-Aug-19	HASSAN	220	HV2	KAVOOR_220	9:50	17:22	7:32	LINE CLEAR AVAILED
300	22-Aug-19	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	9:12	17:09	7:57	LINE CLEAR AVAILED
301	22-Aug-19	HASSAN	220	HV1	HASSAN_220	12:07	12:57	0:50	LINE CLEAR AVAILED
302	22-Aug-19	HASSAN	110	LV2	KAVOOR_220	9:50	17:22	7:32	LINE CLEAR AVAILED
303	22-Aug-19	HASSAN	110	HV1	KAVOOR_220	10:59	17:52	6:53	LINE CLEAR AVAILED
304	22-Aug-19	HASSAN	110	MRSSHM-MPM	MRSMSG_220	9:53	16:28	6:35	LINE FAULT
305	22-Aug-19	HASSAN	110	HV1	BIRUR_110	6:32	6:48	0:16	TRANSFORMER FAULT
306	22-Aug-19	HASSAN	110	HV3	PUTTUR_220	11:52	12:52	1:00	LINE CLEAR AVAILED
307	22-Aug-19	HASSAN	110	HV1	SALATHUR_110	12:26	12:48	0:22	LINE CLEAR AVAILED
308	22-Aug-19	HASSAN	66	BHADRA- LINGADAHALLI	bhadra_gen	3:34	3:43	0:09	LINE FAULT
309	22-Aug-19	HASSAN	66	HASSN220-R R NAGAR	HASSAN_220	4:21	4:35	0:14	LINE FAULT
310	22-Aug-19	HASSAN	66	HASSN220-ARAKALGUD	HASSAN_220	12:07	12:57	0:50	LINE CLEAR AVAILED
311	22-Aug-19	HASSAN	66	HASSN220-CHIKAMAGLUR2	HASSAN_220	12:07	12:57	0:50	LINE CLEAR AVAILED
312	22-Aug-19	HASSAN	66	HASSN220-HN PURA	HASSAN_220	12:07	12:57	0:50	LINE CLEAR AVAILED
313	22-Aug-19	HASSAN	66	LV1	HASSAN_220	12:07	12:57	0:50	LINE CLEAR AVAILED
314	22-Aug-19	HASSAN	66	HASSN220-MALLALI	HASSAN_220	12:07	12:57	0:50	LINE CLEAR AVAILED
315	22-Aug-19	HASSAN	66	HASSN220-R R NAGAR	HASSAN_220	12:07	12:57	0:50	LINE CLEAR AVAILED
316	22-Aug-19	HASSAN	66	HASSN220-SKPURA	HASSAN_220	12:07	12:57	0:50	LINE CLEAR AVAILED
317	22-Aug-19	HASSAN	66	KIADBHA-RAMESWARNAGAR	KIADB_66	4:22	4:41	0:19	MAIN SUPPLY FAILURE
318	22-Aug-19	HASSAN	66	KIADBHA-RAMESWARNAGAR	KIADB_66	5:05	9:14	4:09	MAIN SUPPLY FAILURE
319	22-Aug-19	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	4:20	4:40	0:20	MAIN SUPPLY FAILURE
320	22-Aug-19	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	8:00	9:15	1:15	MAIN SUPPLY FAILURE
321	22-Aug-19	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	12:05	13:01	0:56	MAIN SUPPLY FAILURE
322	22-Aug-19	HASSAN	66	HV1	BELUR_66	10:30	17:50	7:20	LINE CLEAR AVAILED
323	22-Aug-19	HASSAN	66	GENDEHA-HASSAN	GENDEHALLI_66	10:15	18:18	8:03	LINE CLEAR AVAILED
324	22-Aug-19	HASSAN	66	HV1	GENDEHALLI_66	10:15	18:18	8:03	LINE CLEAR AVAILED
325	22-Aug-19	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	10:15	18:18	8:03	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
326	22-Aug-19	HASSAN	66	HV1	KALASAPURA_66	11:20	11:41	0:21	LINE CLEAR AVAILED
327	22-Aug-19	MYSORE	66	HV2	CHANDAKAVADI_66	8:22	9:08	0:46	TRANSFORMER FAULT
328	22-Aug-19	MYSORE	66	HV2	CHANDAKAVADI_66	13:19	14:12	0:52	LINE CLEAR AVAILED
329	22-Aug-19	MYSORE	66	HALAGURU-HONAGANAHALLI	HALAGUR_66	11:20	12:45	1:25	LINE CLEAR AVAILED
330	22-Aug-19	MYSORE	66	HV1	KIKKERI_66	11:39	12:27	0:48	LINE CLEAR AVAILED
331	22-Aug-19	MYSORE	66	KUNTHUR-DR PETE	JANNUR_66 MUGUR_66 SANTHEMARAHALLI_66 TNARASIPURA_66 THAYURU_66	13:03	13:11	0:08	LINE FAULT
332	22-Aug-19	MYSORE	66	KUSHALNAGARA 220-BYLUKUPPE	BYLUKUPPE_66	10:42	12:13	1:30	LINE CLEAR AVAILED
333	22-Aug-19	MYSORE	66	HV1	MADIKERI_66	11:09	12:46	1:36	LINE CLEAR AVAILED
334	22-Aug-19	MYSORE	66	HV1	SANTHESARAGUR_66	13:40	15:10	1:30	LINE CLEAR AVAILED
335	22-Aug-19	MYSORE	66	HV2	SANTHESARAGUR_66	15:11	16:02	0:51	LINE CLEAR AVAILED
336	22-Aug-19	TUMKUR	400	TR-2	GUTUR_400	19:35	21:02	1:27	TRANSFORMER FAULT
337	22-Aug-19	TUMKUR	220	TR-1	NEELAGUNDA_220	12:09	12:40	0:31	MAIN SUPPLY FAILURE
338	22-Aug-19	TUMKUR	220	TR-2	NEELAGUNDA_220	12:05	12:38	0:33	MAIN SUPPLY FAILURE
339	22-Aug-19	TUMKUR	110	TR-1	BIDARE_110	16:33	17:20	0:46	LINE CLEAR AVAILED
340	22-Aug-19	TUMKUR	110	BIDARE- NITTUR	BIDARE_110	16:33	17:19	0:45	LINE CLEAR AVAILED
341	22-Aug-19	TUMKUR	110	TR-2	HULIYAR_110	12:34	13:19	0:44	LINE CLEAR AVAILED
342	22-Aug-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	14:22	17:39	3:16	LINE FAULT
343	22-Aug-19	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	10:30	17:59	7:29	LINE CLEAR AVAILED
344	22-Aug-19	TUMKUR	66	CHITRADURGA 220kv-CHITRADURGA2	CHITRADURGA_220	10:06	16:32	6:26	LINE CLEAR AVAILED
345	22-Aug-19	TUMKUR	66	CHITRADURGA 220kv-CHITRADURGA 1	CHITRADURGA_220	10:07	16:32	6:24	LINE CLEAR AVAILED
346	22-Aug-19	TUMKUR	66	CHITRADURGA 66kv- PANDARAHALLI 2	PANDARAHALLI_66	9:59	18:07	8:08	LINE CLEAR AVAILED
347	22-Aug-19	TUMKUR	66	CHITRADURGA 66kv- MEGMICON 1	MEGMICON 1_IPP_66	16:40	16:43	0:02	LINE CLEAR AVAILED
348	22-Aug-19	TUMKUR	66	CHITRADURGA 66kv- MEGMICON 2	MEGMICON 1_IPP_66	16:40	16:43	0:02	LINE CLEAR AVAILED
349	22-Aug-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	14:33	14:39	0:06	LOAD CHANGEOVER
350	22-Aug-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	12:30	12:36	0:05	HAND TRIPPED
351	22-Aug-19	TUMKUR	66	TR-2	IDHALLY_66	12:59	13:26	0:26	LINE CLEAR AVAILED
352	22-Aug-19	TUMKUR	66	TR-1	KUNIGAL_66	6:50	14:03	7:13	TRANSFORMER FAULT
353	22-Aug-19	TUMKUR	66	NEELAGUNDA 220kv-HARAPPANAHALLI-1	HARAPPANAHALLI_66	12:02	12:47	0:44	MAIN SUPPLY FAILURE
354	22-Aug-19	TUMKUR	66	NEELAGUNDA 220kv-HARAPPANAHALLI-1	HARAPPANAHALLI_66	16:38	17:06	0:28	HAND TRIPPED
355	22-Aug-19	TUMKUR	66	NEELAGUNDA 220kv-HULUVAGALU	HALUVAGALU_66	12:02	12:48	0:45	MAIN SUPPLY FAILURE

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
356	22-Aug-19	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	16:37	17:06	0:28	HAND TRIPPED
357	22-Aug-19	TUMKUR	66	TR-1(LV SIDE)	NEELAGUNDA_220	12:05	12:42	0:37	MAIN SUPPLY FAILURE
358	22-Aug-19	TUMKUR	66	TR-2(LV SIDE)	NEELAGUNDA_220	12:05	12:42	0:37	MAIN SUPPLY FAILURE
359	22-Aug-19	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,HARAPPANAHALLI_66,HALUVAGALU_66,TELAGI_66	12:02	12:50	0:48	MAIN SUPPLY FAILURE
360	22-Aug-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	12:03	12:50	0:47	MAIN SUPPLY FAILURE
361	22-Aug-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	16:37	17:06	0:28	HAND TRIPPED
362	22-Aug-19	TUMKUR	66	RAMPURA66-ABLETEC(SSHTY)_IPP_66	ABLETEC(SSHTY)_IPP_66	18:41	19:31	0:49	LINE CLEAR AVAILED
363	23-Aug-19	BAGALKOT	110	110/11KV, HV1	DAVLESHWAR_110	10:35	12:26	1:51	LINE CLEAR AVAILED
364	23-Aug-19	BAGALKOT	110	110/11KV, HV2	DAVLESHWAR_110	12:26	14:00	1:34	LINE CLEAR AVAILED
365	23-Aug-19	BAGALKOT	110	110/11KV, HV4	MK HUBLI_110	19:35	23:59	4:24	TRANSFORMER FAULT
366	23-Aug-19	BAGALKOT	110	110/11KV, HV2	AREMALLAPUR_110	14:15	16:00	1:45	LINE CLEAR AVAILED
367	23-Aug-19	BAGALKOT	110	MK HUBLI220-KHANAPUR	KHANAPUR_110	16:50	17:10	0:20	LINE FAULT
368	23-Aug-19	BAGALKOT	220	MK HUBLI220-NARENDRA1	MK HUBLI_220	0:00	14:39	14:39	LINE CLEAR AVAILED
369	23-Aug-19	BENGALURU	66	MANDIKALLU - GOWRIBIDANUR 220	MANDIKALLU, PERESANDRA, SOMENAHALLI	9:50	9:57	0:07	LOAD CHANGEOVER
370	23-Aug-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	MANDIKALLU, PERESANDRA, SOMENAHALLI	18:00	18:03	0:03	LINE CLEAR AVAILED
371	23-Aug-19	BENGALURU	66	ADUGODI HSR LAYOUT	ADUGODI, BOSCH (EHT)	12:39	12:47	0:08	LINE CLEAR AVAILED
372	23-Aug-19	GULBARGA	400	BTPS-RTPS	RTPS_400	1:30	16:26	14:56	LINE FAULT
373	23-Aug-19	GULBARGA	110	HV2	BEVOOR_110	6:55	7:00	0:05	TRANSFORMER FAULT
374	23-Aug-19	GULBARGA	110	SHAHPUR-KBJNL	SHAHPUR_220	7:36	8:28	0:52	LINE CLEAR AVAILED
375	23-Aug-19	GULBARGA	110	SHAHPUR-SHAHPUR1	SHAHPUR_110	3:47	23:59	20:12	LINE FAULT
376	23-Aug-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	10:18	10:22	0:04	LINE FAULT
377	23-Aug-19	GULBARGA	66	ITTAGI-RNWSLR1	ITTAGI_220	9:30	9:35	0:05	LINE CLEAR AVAILED
378	23-Aug-19	GULBARGA	66	ITTAGI-CLNSLR2_IPP	ITTAGI_220	9:30	9:44	0:14	LINE CLEAR AVAILED
379	23-Aug-19	GULBARGA	66	ITTAGI-RNWSLR2_IPP	ITTAGI_220	11:35	11:45	0:10	LINE CLEAR AVAILED
380	23-Aug-19	GULBARGA	66	ITTAGI-RNWSLR1_IPP	ITTAGI_220	14:25	14:38	0:13	LINE CLEAR AVAILED
381	23-Aug-19	GULBARGA	66	KOGALI-ATRSOLAR_IPP	KOGALI_66	9:45	10:00	0:15	LINE CLEAR AVAILED
382	23-Aug-19	GULBARGA	66	KOGALI-ATRSOLAR_IPP	KOGALI_66	14:40	14:55	0:15	LINE CLEAR AVAILED
383	23-Aug-19	GULBARGA	66	ITTAGI-RNWSLR1_IPP	ITTAGI_220	16:00	16:05	0:05	LINE CLEAR AVAILED
384	23-Aug-19	HASSAN	220	MRSSHM-KADUR	MRSMG_220	9:57	15:55	5:58	LINE CLEAR AVAILED
385	23-Aug-19	HASSAN	110	HV1	KAVOOR-220	10:05	14:16	4:11	LINE CLEAR AVAILED
386	23-Aug-19	HASSAN	110	HV3	PUTTUR_220	9:49	12:24	2:35	LINE CLEAR AVAILED
387	23-Aug-19	HASSAN	110	HV3	PUTTUR_110	15:00	17:07	2:07	LINE CLEAR AVAILED
388	23-Aug-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	10:57	11:00	0:03	HAND TRIPPED
389	23-Aug-19	HASSAN	66	HNPR2-MYSORE1	HOLENARASIPURA_220	11:25	13:00	1:35	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
390	23-Aug-19	HASSAN	66	HNPR2-HAASSAN2	HOLENARASIPURA_220	11:40	11:55	0:15	HAND TRIPPED
391	23-Aug-19	HASSAN	66	HNPURA-IDLE	HNPUA_66	10:50	13:00	2:10	NFBC ISSUED
392	23-Aug-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPUA_66	13:30	13:40	0:10	LINE FAULT
393	23-Aug-19	MYSORE	66	HV1	CHANDAKAVADI_66	11:45	12:55	1:10	LINE CLEAR AVAILED
394	23-Aug-19	MYSORE	66	HV2	CHANDAKAVADI_66	13:13	13:43	0:29	LINE CLEAR AVAILED
395	23-Aug-19	MYSORE	66	HV1	K_HONNALGERE_66	18:12	18:31	0:19	MAIN SUPPLY FAILURE
396	23-Aug-19	MYSORE	66	HV2	K_HONNALGERE_66	18:12	18:31	0:19	MAIN SUPPLY FAILURE
397	23-Aug-19	MYSORE	66	HV1	KIADBMANDYA_66	12:29	12:33	0:04	TRANSFORMER FAULT
398	23-Aug-19	MYSORE	66	HV2	KMDODDI_66	21:56	22:12	0:16	TRANSFORMER FAULT
399	23-Aug-19	MYSORE	220	HV1	KRPET_220	12:29	13:11	0:41	LINE CLEAR AVAILED
400	23-Aug-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	5:44	5:52	0:08	LINE FAULT
401	23-Aug-19	MYSORE	66	HV5	SFCSHIVA_66	11:45	12:20	0:35	MAIN SUPPLY FAILURE
402	23-Aug-19	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	2:29	8:45	6:15	LINE CLEAR AVAILED
403	23-Aug-19	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	9:20	9:21	0:00	HAND TRIPPED
404	23-Aug-19	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	12:41	12:51	0:09	HAND TRIPPED
405	23-Aug-19	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	14:44	19:35	4:51	LINE FAULT
406	23-Aug-19	TUMKUR	220	TR-2(HV SIDE)	KBCROSS_220	3:15	7:13	3:57	TRANSFORMER FAULT
407	23-Aug-19	TUMKUR	110	DODDAGUNI- SAMPIGE	SAMPIGE_110	13:47	13:49	0:02	LINE CLEAR AVAILED
408	23-Aug-19	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	3:15	7:13	3:57	TRANSFORMER FAULT
409	23-Aug-19	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	11:10	11:17	0:07	HAND TRIPPED
410	23-Aug-19	TUMKUR	110	TR-2(HV SIDE)	MAYASANDRA_110	9:42	10:14	0:31	TRANSFORMER FAULT
411	23-Aug-19	TUMKUR	110	TR-2(HV SIDE)	MAYASANDRA_110	12:44	12:57	0:13	LINE CLEAR AVAILED
412	23-Aug-19	TUMKUR	66	TR-2	BELLAVI_66	9:14	10:28	1:14	LINE CLEAR AVAILED
413	23-Aug-19	TUMKUR	66	CHITRADURGA 66kv- PANDARAHALLI 2	PANDARAHALLI_66	14:58	17:00	2:01	LINE FAULT
414	23-Aug-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	15:05	15:30	0:25	LINE FAULT
415	23-Aug-19	TUMKUR	66	TR-2	HARAPPANAHALLI_66	16:42	17:16	0:34	LINE CLEAR AVAILED
416	23-Aug-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	15:17	15:20	0:02	HAND TRIPPED
417	23-Aug-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	17:26	18:25	0:59	LINE CLEAR AVAILED
418	23-Aug-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	17:27	18:28	1:00	LINE CLEAR AVAILED
419	23-Aug-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	17:27	18:28	1:00	LINE CLEAR AVAILED
420	23-Aug-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	10:48	18:23	7:35	LINE CLEAR AVAILED
421	23-Aug-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	11:09	11:38	0:29	LINE FAULT
422	23-Aug-19	TUMKUR	66	TR-2	TELAGI_66	12:47	13:36	0:48	LINE CLEAR AVAILED
423	23-Aug-19	TUMKUR	66	TELAGI- VESTAS IPP	VESTAS_IPP_66	17:33	17:41	0:07	HAND TRIPPED
424	24-Aug-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	15:32	16:07	0:35	LINE CLEAR AVAILED
425	24-Aug-19	BAGALKOT	110	110/11KV, HV4	BAILHONGAL_110	17:38	17:42	0:04	LINE CLEAR AVAILED
426	24-Aug-19	BAGALKOT	220	BAGALKOT-GADAG1	BAGALKOT_220	17:40	23:59	6:19	LINE CLEAR AVAILED
427	24-Aug-19	BAGALKOT	110	110/11KV, HV2	KANABARGI LAYOUT_110	11:30	12:47	1:17	LINE CLEAR AVAILED
428	24-Aug-19	BAGALKOT	110	110/11KV, HV1	KANABARGI LAYOUT_110	11:30	12:15	0:45	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
429	24-Aug-19	BAGALKOT	110	110/33KV, HV3	KANABARGI LAYOUT_110, SUZLON_33, KAKTI_33	13:00	13:30	0:30	LINE CLEAR AVAILED
430	24-Aug-19	BAGALKOT	110	110/11KV, HV4	MK HUBLI_110	0:00	17:51	17:51	LINE CLEAR AVAILED
431	24-Aug-19	BAGALKOT	110	110/11KV,HV1	UTTUR_110	11:17	12:37	1:20	LINE CLEAR AVAILED
432	24-Aug-19	BAGALKOT	110	110/33KV,HV2	UTTUR_110,VANTAGODI_33KV,YADVAD_33KV	12:51	13:12	0:21	LINE CLEAR AVAILED
433	24-Aug-19	BAGALKOT	110	110/33KV,HV1	SOUDATTI_110,UDIKERI_33KV,CHULAKI_33KV,SUZLON_33KV	10:00	16:01	6:01	LINE CLEAR AVAILED
434	24-Aug-19	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	16:04	17:15	1:11	LINE CLEAR AVAILED
435	24-Aug-19	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	19:18	21:26	2:08	TRANSFORMER FAULT
436	24-Aug-19	BAGALKOT	110	110/33KV,HV3	SANKESHWAR_110,KANAGAL_33KV,HEBBAL_33KV	8:22	8:40	0:18	TRANSFORMER FAULT
437	24-Aug-19	BAGALKOT	110	SHARAVATHI2-SIRSI	SIRSI_220	0:00	17:36	17:36	LINE CLEAR AVAILED
438	24-Aug-19	BENGALURU	220	HV2	MITTEMARI 220	1:42	2:15	0:33	TRANSFORMER FAULT
439	24-Aug-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	MANDIKALLU, PERESANDRA, SOMENAHALLI	1:42	2:15	0:33	MAIN SUPPLY FAILURE
440	24-Aug-19	BENGALURU	66	SURYANAGAR - YARANDANAHALLI 220	SURYANAGAR	9:24	19:34	10:10	LINE CLEAR AVAILED
441	24-Aug-19	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220	9:20	10:19	0:59	LINE FAULT
442	24-Aug-19	BENGALURU	220	MALUR 220 - SOMANAHALLI 1	SARJAPURA 220	9:20	10:19	0:59	MAIN SUPPLY FAILURE
443	24-Aug-19	BENGALURU	220	MALUR 220 - HOODY 220	SARJAPURA 220	12:28	12:29	0:01	LOAD CHANGEOVER
444	24-Aug-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	9:20	10:33	1:13	MAIN SUPPLY FAILURE
445	24-Aug-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	9:20	10:52	1:32	MAIN SUPPLY FAILURE
446	24-Aug-19	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	9:20	10:26	1:06	MAIN SUPPLY FAILURE
447	24-Aug-19	BENGALURU	66	HV1	SARJAPURA 220	9:20	10:22	1:02	MAIN SUPPLY FAILURE
448	24-Aug-19	BENGALURU	66	HV2	SARJAPURA 220	9:20	10:22	1:02	MAIN SUPPLY FAILURE
449	24-Aug-19	BENGALURU	220	JIGANI 220 - SOMANAHALLI 220	JIGANI 220	16:45	19:28	2:43	LINE FAULT
450	24-Aug-19	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	16:45	19:28	2:43	MAIN SUPPLY FAILURE
451	24-Aug-19	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	13:35	14:04	0:29	LINE FAULT
452	24-Aug-19	BENGALURU	66	HV1	YERANDANAHALLI 220	10:05	10:35	0:30	LOAD CHANGEOVER
453	24-Aug-19	BENGALURU	66	HV2	YERANDANAHALLI 221	10:05	10:35	0:30	LOAD CHANGEOVER
454	24-Aug-19	BENGALURU	66	HV3	YERANDANAHALLI 222	10:05	10:35	0:30	LOAD CHANGEOVER
455	24-Aug-19	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	8:59	9:06	0:07	LOAD CHANGEOVER
456	24-Aug-19	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI 1		16:35	16:45	0:10	LOAD CHANGEOVER
457	24-Aug-19	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	16:45	17:20	0:35	MAIN SUPPLY FAILURE
458	24-Aug-19	BENGALURU	66	BOMMASANDRA I/A - YERANDANAHALLI 220	BOMMASANDRA I/A	10:10	10:25	0:15	MAIN SUPPLY FAILURE

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
459	24-Aug-19	BENGALURU	66	BOMMASANDRA I/A - YERANDANAHALLI 220	BOMMASANDRA I/A	13:35	14:05	0:30	MAIN SUPPLY FAILURE
460	24-Aug-19	BENGALURU	66	BOMMASANDRA I/A - YERANDANAHALLI 220	BOMMASANDRA I/A	16:45	19:33	2:48	MAIN SUPPLY FAILURE
461	24-Aug-19	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	10:35	17:49	7:14	LINE CLEAR AVAILED
462	24-Aug-19	BENGALURU	220	SOMANAHALLI 220 - YARANDANAHALLI 220	YARANDANAHALLI 220	13:36	13:59	0:23	LINE FAULT
463	24-Aug-19	BENGALURU	220	SOMANAHALLI 220 - YARANDANAHALLI 220	YARANDANAHALLI 220	16:45	17:38	0:53	LINE FAULT
464	24-Aug-19	BENGALURU	220	YARANDANAHALLI 220 - SOMANAHALLI 220	YERANDANAHALLI 220	13:36	14:03	0:27	LINE FAULT
465	24-Aug-19	BENGALURU	220	YARANDANAHALLI 220 - SOMANAHALLI 220	YERANDANAHALLI 220	17:54	19:28	1:33	LINE CLEAR AVAILED
466	24-Aug-19	BENGALURU	66	ATTIBELE - YERANDANAHALLI 1	ATTIBELE	13:35	14:06	0:31	MAIN SUPPLY FAILURE
467	24-Aug-19	BENGALURU	66	ATTIBELE - YERANDANAHALLI 1	ATTIBELE	16:45	19:32	2:47	MAIN SUPPLY FAILURE
468	24-Aug-19	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	9:20	10:00	0:40	MAIN SUPPLY FAILURE
469	24-Aug-19	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	9:20	10:00	0:40	MAIN SUPPLY FAILURE
470	24-Aug-19	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	9:20	10:00	0:40	MAIN SUPPLY FAILURE
471	24-Aug-19	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	12:35	12:55	0:20	LOAD CHANGEOVER
472	24-Aug-19	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	12:35	12:55	0:20	LOAD CHANGEOVER
473	24-Aug-19	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	12:35	12:55	0:20	LOAD CHANGEOVER
474	24-Aug-19	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHICKSUGUR_110,SHAKTHI NAGAR_110,SURANA_IPP	0:00	16:36	16:36	LINE CLEAR AVAILED
475	24-Aug-19	GULBARGA	110	SHAHPUR-SHAHPUR1	SHAHPUR_110	0:00	12:03	12:03	LINE FAULT
476	24-Aug-19	GULBARGA	110	RAICHUR-SHAHPUR2	GABBUR_110,DEODURGA_110	5:05	5:16	0:11	LINE FAULT
477	24-Aug-19	GULBARGA	110	RAICHUR-SHAHPUR1,2	GOOGLE_110,DEO DURGA_110,GABBUR_110	15:36	16:32	0:56	LINE CLEAR AVAILED
478	24-Aug-19	GULBARGA	110	RAICHUR-SHAHPUR2	GABBUR_110,DEODURGA_110	16:02	16:22	0:20	LINE CLEAR AVAILED
479	24-Aug-19	GULBARGA	110	HV2	SHORAPUR_110	19:17	19:31	0:14	TRANSFORMER FAULT
480	24-Aug-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	9:09	10:19	1:10	LINE FAULT
481	24-Aug-19	GULBARGA	110	HUMNABAD-DUBALGUNDI	DUBBALGUNDI_110	16:08	16:18	0:10	LINE FAULT
482	24-Aug-19	GULBARGA	66	KOGALI-ASTROSLR_IPP	KOGALI_66	10:28	10:38	0:10	LINE CLEAR AVAILED
483	24-Aug-19	GULBARGA	66	HV2	CHORNOOR_66	8:09	9:30	1:21	LINE CLEAR AVAILED
484	24-Aug-19	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	13:41	17:21	3:40	NFBC ISSUED
485	24-Aug-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	12:52	13:23	0:31	LINE FAULT
486	24-Aug-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	12:52	13:05	0:13	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
487	24-Aug-19	HASSAN	66	HNPURA-MYSORE1	HNPURA_66	3:30	3:45	0:15	MAIN SUPPLY FAILURE
488	24-Aug-19	HASSAN	66	MRSSHM-DVG1	MRSMG_220	9:13	9:23	0:10	LINE FAULT
489	24-Aug-19	MYSORE	66	HV1	DATTAGALLY_66	11:31	11:42	0:10	TRANSFORMER FAULT
490	24-Aug-19	MYSORE	66	KUSHALNAGARA 220-BETTADAPURA	BETTADHAPURA_66, CHUNCHUNKATTE_66, KITTUR_66, RAVANDUR_66	18:32	18:40	0:08	LINE FAULT
491	24-Aug-19	MYSORE	66	HV1	SUTTUR_66	8:47	10:22	1:35	LINE CLEAR AVAILED
492	24-Aug-19	MYSORE	66	HV2	SUTTUR_66	10:22	12:43	2:20	LINE CLEAR AVAILED
493	25-Aug-19	BAGALKOT	220	BAGALKOT-GADAG1	BAGALKOT_220	0:00	15:05	15:05	LINE CLEAR AVAILED
494	25-Aug-19	BAGALKOT	220	GADAG-BAGALKOT2	GADAG_220	11:08	15:07	3:59	LINE CLEAR AVAILED
495	25-Aug-19	BAGALKOT	220	HARTI1&2-GADAG	GADAG_220	12:01	15:15	3:14	LINE CLEAR AVAILED
496	25-Aug-19	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	10:10	10:29	0:19	LOAD CHANGEOVER
497	25-Aug-19	BENGALURU	66	JIGANI 66 - BG ROAD	JIGANI 66	14:00	14:05	0:05	LOAD CHANGEOVER
498	25-Aug-19	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI 1		10:55	11:03	0:08	LOAD CHANGEOVER
499	25-Aug-19	BENGALURU	66	BOMMASANDRA I/A - YERANDANAHALLI 220	BOMMASANDRA I/A	14:12	14:38	0:26	MAIN SUPPLY FAILURE
500	25-Aug-19	BENGALURU	66	BOMMASANDRA I/A - ELECTRONIC CITY	BOMMASANDRA I/A	15:39	15:45	0:06	LOAD CHANGEOVER
501	25-Aug-19	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_110, CORE GREEN SUGUR_IPP	5:21	5:40	0:19	LINE FAULT
502	25-Aug-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	9:55	10:05	0:10	LINE FAULT
503	25-Aug-19	GULBARGA	110	HV3	SHORAPUR_110	11:12	11:19	0:07	TRANSFORMER FAULT
504	25-Aug-19	GULBARGA	66	HV1	KOGALI_66	16:35	16:45	0:10	TRANSFORMER FAULT
505	25-Aug-19	HASSAN	220	MRSSHM-VARAH13	MRSMG_220	11:11	11:26	0:15	LINE FAULT
506	25-Aug-19	HASSAN	110	PUTTUR-PUTTUR	PUTTUR_220	8:00	15:49	7:49	LINE CLEAR AVAILED
507	25-Aug-19	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	8:00	15:49	7:49	LINE CLEAR AVAILED
508	25-Aug-19	HASSAN	66	MRSSHM-DVG2	MRSMG_220	9:38	9:46	0:08	LINE FAULT
509	25-Aug-19	MYSORE	66	CR NAGARA-KOLLEGALA	KOLLEGALA_66	10:29	16:52	6:23	NFBC ISSUED
510	25-Aug-19	MYSORE	66	KADAKOLA-NANJANGUDU 1	NANJANGUDU_66	10:04	17:32	7:27	NFBC ISSUED
511	25-Aug-19	MYSORE	66	MADHUVANHALLI-KOLLEGALA 1	KOLLEGALA_66	10:42	16:39	5:57	NFBC ISSUED
512	25-Aug-19	MYSORE	66	PANDAVAPURA-TUBINAKERE	DODDABYADARAHALLI_66, PANDAVAPURA_66	3:54	4:14	0:20	LINE FAULT
513	25-Aug-19	MYSORE	66	HV2	SUTTUR_66	16:15	16:24	0:09	HAND TRIPPED
514	25-Aug-19	MYSORE	66	HV1	SUTTUR_66	16:15	16:24	0:09	HAND TRIPPED
515	25-Aug-19	MYSORE	66	HV1	SUTTUR_66	13:50	14:40	0:50	LINE CLEAR AVAILED
516	25-Aug-19	MYSORE	66	HV2	SUTTUR_66	13:50	14:40	0:50	LINE CLEAR AVAILED
517	25-Aug-19	MYSORE	66	THANDYA-NANJUNGUDU	NANJANGUDU_66	10:04	17:34	7:30	NFBC ISSUED
518	25-Aug-19	MYSORE	66	MUGUR-JANNUR	JANNUR_66	6:28	6:33	0:05	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
519	26-Aug-19	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	11:37	13:59	2:22	LINE CLEAR AVAILED
520	26-Aug-19	BAGALKOT	220	BIJAPUR-INDI2	BIJAPUR_220	12:47	16:51	4:04	LINE CLEAR AVAILED
521	26-Aug-19	BAGALKOT	110	110/33KV, HV4	LAKMANHALLI_110, ALNAVAR_33	21:02	21:10	0:08	TRANSFORMER FAULT
522	26-Aug-19	BAGALKOT	220	MK HUBLI-NARENDRA2	MK HUBLI_220	11:49	18:43	6:54	LINE CLEAR AVAILED
523	26-Aug-19	BAGALKOT	220	220/110KV, HV3&LV3	MAHALINGAPUR_220, HIDIKAL_110, ITANAL_110	7:10	7:25	0:15	TRANSFORMER FAULT
524	26-Aug-19	BAGALKOT	220	220/110KV, HV3&LV3	MAHALINGAPUR_220, HIDIKAL_110, ITANAL_110	7:35	7:50	0:15	TRANSFORMER FAULT
525	26-Aug-19	BAGALKOT	110	MAHALINGAPUR-RABKAVI	RABKAVI_110	6:05	6:30	0:25	LINE FAULT
526	26-Aug-19	BAGALKOT	110	MAHALINGAPUR-RABKAVI	RABKAVI_110	6:35	7:15	0:40	LINE CLEAR AVAILED
527	26-Aug-19	BAGALKOT	110	SATTI SUGARS-PG HUNSHYAL	PG HUNSHYAL_110	11:09	12:28	1:19	LINE CLEAR AVAILED
528	26-Aug-19	BAGALKOT	110	110/11KV, HV1	SAIDAPUR_110	16:55	16:59	0:04	TRANSFORMER FAULT
529	26-Aug-19	BAGALKOT	110	MAMDAPUR(B)-SHIRBUR	SHIRBUR_110	15:34	15:35	0:01	HAND TRIPPED
530	26-Aug-19	BENGALURU	66	CHIKKABALLAPURA I/A - CHIKKABALLAPURA URBAN	CHIKKABALLAPURA URBAN	10:15	10:40	0:24	LINE FAULT
531	26-Aug-19	BENGALURU	66	HV1	KEMBODI	16:30	16:52	0:22	LINE CLEAR AVAILED
532	26-Aug-19	BENGALURU	66	HV1	KYALANUR	11:15	11:20	0:05	TRANSFORMER FAULT
533	26-Aug-19	BENGALURU	66	HV2	MAASTHI	12:02	13:25	1:22	LINE CLEAR AVAILED
534	26-Aug-19	BENGALURU	66	MANDIKALLU - GOWRIBIDANUR 220	MANDIKALLU, PERESANDRA, SOMENAHALLI	10:05	10:22	0:17	LOAD CHANGEOVER
535	26-Aug-19	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	MANDIKALLU, PERESANDRA, SOMENAHALLI	18:03	18:15	0:12	LOAD CHANGEOVER
536	26-Aug-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	MANDIKALLU, PERESANDRA, SOMENAHALLI	15:19	15:21	0:02	LOAD CHANGEOVER
537	26-Aug-19	BENGALURU	220	HV1	MITTEMARI 220	19:40	23:59	4:19	TRANSFORMER FAULT
538	26-Aug-19	BENGALURU	220	HV2	MITTEMARI 220	19:42	23:59	4:17	TRANSFORMER FAULT
539	26-Aug-19	BENGALURU	66	HENNUR CROSS - MANYATA TECH PARK 220	HENNUR CROSS	16:51	16:56	0:05	LOAD CHANGEOVER
540	26-Aug-19	BENGALURU	66	ANJANAPURA - KHODAYS 220	ANJANAPURA	15:32	17:45	2:12	LINE CLEAR AVAILED
541	26-Aug-19	GULBARGA	220	HV1	RAICHUR_220	12:16	13:10	0:54	LINE CLEAR AVAILED
542	26-Aug-19	GULBARGA	110	HV2	KUSTAGI_220	9:37	9:50	0:13	TRANSFORMER FAULT
543	26-Aug-19	GULBARGA	110	PDHALLI-JANAKI_IPP	JANAKI_IPP	10:45	12:53	2:08	LINE CLEAR AVAILED
544	26-Aug-19	GULBARGA	110	HUMNABAD220-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	12:10	11:18	11:42	LINE FAULT
545	26-Aug-19	GULBARGA	110	HUMNABAD220-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	12:30	12:40	0:10	LINE FAULT
546	26-Aug-19	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	16:59	17:05	0:06	LINE FAULT
547	26-Aug-19	GULBARGA	110	BETAGERA-KSHVCMNT_SLR_IPP	BETAGERA_110	18:40	21:30	2:50	LINE CLEAR AVAILED
548	26-Aug-19	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHICKSUGUR_110,SHAKTHI NAGAR_110,SURANA_IPP	22:40	22:50	0:10	LINE FAULT
549	26-Aug-19	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHICKSUGUR_110,SHAKTHI NAGAR_110,SURANA_IPP	23:06	23:15	0:09	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
550	26-Aug-19	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHICKSUGUR_110,SHAKTHI NAGAR_110,SURANA_IPP	12:05	23:59	11:54	LINE CLEAR AVAILED
551	26-Aug-19	GULBARGA	66	CHORNOOR-KUDLIGI	CHORNOOR_66	12:10	12:40	0:30	LINE CLEAR AVAILED
552	26-Aug-19	HASSAN	400	HASSAN40-UPCL1	HASSAN_400	21:55	23:59	2:04	LINE CLEAR AVAILED
553	26-Aug-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:55	23:59	2:04	LINE CLEAR AVAILED
554	26-Aug-19	HASSAN	220	MRSSHM-VARAHI3	MRSMSG_220	9:27	18:37	9:10	LINE CLEAR AVAILED
555	26-Aug-19	HASSAN	220	VARAHI-SHMG3	varahi_gen	9:25	19:01	9:36	NFBC ISSUED
556	26-Aug-19	HASSAN	66	HV1	ALDUR_66	12:00	23:59	11:59	LINE CLEAR AVAILED
557	26-Aug-19	MYSORE	66	HV1	ELAVALA_66	11:14	15:42	4:28	LINE CLEAR AVAILED
558	26-Aug-19	MYSORE	66	KUSHALANAGRA 220-BETTADAPURA	BETTADHAPURA_66, CHUNCHUNKATTE_66, KITTUR_66, RAVANDUR_66	23:04	23:13	0:08	LINE FAULT
559	26-Aug-19	MYSORE	66	HV1	PGPALYA_66	13:21	15:22	2:00	LINE CLEAR AVAILED