

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 28.04.2020 TO 04.05.2020

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	28-Apr-20	BAGALKOT	66	DAVANAGERE-HARIHAR HOSPET	HARIHAR HOSPET_66	21:25	23:59	2:34	LINE CLEAR AVAILED
2	28-Apr-20	BAGALKOT	66	HONNALLI-HARIHAR HOSPET	HARIHAR HOSPET_66	13:35	21:25	7:50	MAIN SUPPLY FAILURE
3	28-Apr-20	BAGALKOT	110	110/11KV,HV 1	ANKOLA_110	5:45	5:49	0:04	TRANSFORMER FAULT
4	28-Apr-20	BAGALKOT	110	110/11KV,HV 1	HIDIKAL_110	11:55	12:30	0:35	LINE CLEAR AVAILED
5	28-Apr-20	BAGALKOT	110	110/11KV,HV 1	KHANAPUR_110	16:23	23:59	7:36	TRANSFORMER FAULT
6	28-Apr-20	BAGALKOT	110	110/11KV,HV 2	KHANAPUR_110	15:30	16:10	0:40	TRANSFORMER FAULT
7	28-Apr-20	BAGALKOT	110	110/11KV,HV1	YELAPARATTI_110	11:47	12:04	0:17	LINE CLEAR AVAILED
8	28-Apr-20	BAGALKOT	110	110/11KV,HV1	SIRSI_110	16:50	17:26	0:36	LINE CLEAR AVAILED
9	28-Apr-20	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	9:25	9:40	0:15	TRANSFORMER FAULT
10	28-Apr-20	BAGALKOT	110	110/33KV,HV2	HUNAGUND_110,AMINAGAD_33,KARADI_33,MYTRA SOLAR_33	10:14	10:19	0:05	TRANSFORMER FAULT
11	28-Apr-20	BAGALKOT	110	110/33KV,HV3	ZALKI_110,NEVARAGI_33,DHULKHED_33,HAL ASANGHI_33	13:05	13:08	0:03	TRANSFORMER FAULT
12	28-Apr-20	BAGALKOT	110	110/33KV,HV3	ZALKI_110,NEVARAGI_33,DHULKHED_33,HAL ASANGHI_33	13:43	13:48	0:05	TRANSFORMER FAULT
13	28-Apr-20	BAGALKOT	110	110/33KV,HV3	ZALKI_110,NEVARAGI_33,DHULKHED_33,HAL ASANGHI_33	14:05	14:15	0:10	TRANSFORMER FAULT
14	28-Apr-20	BAGALKOT	110	110/33KV,HV3	ZALKI_110,NEVARAGI_33,DHULKHED_33,HAL ASANGHI_33	22:17	22:25	0:08	TRANSFORMER FAULT
15	28-Apr-20	BAGALKOT	110	110/33KV,HV4	HIDIKAL_110ALAGAWADI_33	20:37	20:45	0:08	TRANSFORMER FAULT
16	28-Apr-20	BAGALKOT	110	AMBEWADI-NK2	KAVALWAD_110	19:59	20:02	0:03	HAND TRIPPED
17	28-Apr-20	BAGALKOT	110	ANKOLA-KUMATA (L2)	KUMATA,HONNAVAR& MURDESHWAR_110	19:22	23:59	4:37	LINE FAULT
18	28-Apr-20	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	5:24	5:30	0:06	LINE FAULT
19	28-Apr-20	BAGALKOT	110	ESALE-1(SIRSI220)-SIRSI	SIRSI_110	17:06	18:10	1:04	LINE CLEAR AVAILED
20	28-Apr-20	BAGALKOT	110	ESALE-2(SIRSI220)-SIRSI	SIRSI_110	17:06	17:21	0:15	LINE CLEAR AVAILED
21	28-Apr-20	BAGALKOT	110	GADAG220-DAMBAL2	DAMBAL_110	11:14	14:32	3:18	LINE CLEAR AVAILED
22	28-Apr-20	BAGALKOT	110	GADAG220-SHIRAHATTI	SHIRAHATTI_110	11:27	13:16	1:49	LINE CLEAR AVAILED
23	28-Apr-20	BAGALKOT	110	ITNAL-HIDIKAL	HIDIKAL_110	8:27(27.4.20)	19:22	34:54 hrs	LINE CLEAR AVAILED
24	28-Apr-20	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	13:14	13:43	0:29	LINE FAULT
25	28-Apr-20	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	14:53	17:56	3:03	LINE FAULT
26	28-Apr-20	BAGALKOT	110	MAMADAPUR-BABALESHWAR	BABALESHWAR_110	1:30	7:11	5:41	LINE FAULT
27	28-Apr-20	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	14:50	14:54	0:04	LINE CLEAR AVAILED
28	28-Apr-20	BAGALKOT	110	VAJRAMATTI220-MANTUR 1	MANTUR-110,MAREGUDDI_110,MUNDUGANUR_110,G ANI_33,GALAGALI_33	22:45	23:18	0:33	LINE FAULT
29	28-Apr-20	BAGALKOT	220	220/110KV, HV3&LV3	MAHALINGAPUR_220, HIDIKAL_110, ITANAL_110	13:14	13:41	0:27	TRANSFORMER FAULT
30	28-Apr-20	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	14:34	17:46	3:12	LINE CLEAR AVAILED
31	28-Apr-20	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	13:19	17:44	4:25	LINE FAULT
32	28-Apr-20	BAGALKOT	220	CHIKKODI-KUDUCHI2	CHIKKODI_220	14:16	14:32	0:16	HAND TRIPPED
33	28-Apr-20	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	7:22	7:27	0:05	LOAD CHANGE OVER
34	28-Apr-20	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU	21:05	21:17	0:12	LINE FAULT
35	28-Apr-20	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU	23:52	23:59	0:06	LINE FAULT
36	28-Apr-20	BENGALURU	66	GANJIGUNTE - CHINTAMANI 1	NO STATION AFFECTED	21:05	21:18	0:13	LINE FAULT
37	28-Apr-20	BENGALURU	66	GANJIGUNTE - CHINTAMANI 1	NO STATION AFFECTED	23:52	23:59	0:06	LINE FAULT
38	28-Apr-20	BENGALURU	66	HV1	MEI LAYOUT	9:17	9:19	0:02	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
39	28-Apr-20	BENGALURU	66	HV1	RMV	7:12	7:15	0:03	LINE CLEAR AVAILED
40	28-Apr-20	BENGALURU	66	HV1	SIR MV LAYOUT	11:37	12:50	1:13	TRANSFORMER FAULT
41	28-Apr-20	BENGALURU	66	HV1	DEVANAHALLI	7:35	7:40	0:05	TRANSFORMER FAULT
42	28-Apr-20	BENGALURU	66	HV2	MEI LAYOUT	10:42	10:45	0:03	LINE CLEAR AVAILED
43	28-Apr-20	BENGALURU	66	HV2	RMV	9:34	9:38	0:04	LINE CLEAR AVAILED
44	28-Apr-20	BENGALURU	66	HV2	ATTUR YELAHANKA	10:58	12:20	1:21	LINE CLEAR AVAILED
45	28-Apr-20	BENGALURU	66	HV2	THAYALUR	17:59	18:04	0:05	TRANSFORMER FAULT
46	28-Apr-20	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KUMBALAGODU,CHANDRAPPA CIRCLE	12:38	13:05	0:27	LINE FAULT
47	28-Apr-20	BENGALURU	66	KENGERI SATELLITE TOWN - SIR M V LAYOUR	KENGERI SATELLITE TOWN,KUMBALAGODU,CHANDRAPPA CIRCLE	12:38	12:51	0:13	LINE FAULT
48	28-Apr-20	BENGALURU	66	KENGERI SATELLITE TOWN - SIR M V LAYOUR	KENGERI SATELLITE TOWN	14:13	14:18	0:05	LINE FAULT
49	28-Apr-20	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	12:00	12:06	0:05	LINE FAULT
50	28-Apr-20	BENGALURU	66	KUMBALAGODU - KENGERI SATELLITE TOWN	KUMBALAGODU,CHANDRAPPA CIRCLE	14:13	14:45	0:32	MAIN SUPPLY FAILURE
51	28-Apr-20	BENGALURU	66	SIR MV LAYOUT - KENGERI SATELLITE TOWN	KENGERI SATELLITE TOWN,KUMBALAGODU,CHANDRAPPA CIRCLE	12:38	12:51	0:13	LINE FAULT
52	28-Apr-20	BENGALURU	66	SIR MV LAYOUT - KENGERI SATELLITE TOWN	KENGERI SATELLITE TOWN	14:13	14:18	0:05	LINE FAULT
53	28-Apr-20	BENGALURU	220	BEGUR 220 - HOODY 220	BEGUR 220	13:23	15:14	1:51	LINE FAULT
54	28-Apr-20	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	14:40	14:48	0:08	LINE FAULT
55	28-Apr-20	GULBARGA	110	HV2	DEODURGA_110	17:35	17:55	0:20	TRANSFORMER FAULT
56	28-Apr-20	GULBARGA	110	HV2	SHAHPUR_220	17:39	17:46	0:07	TRANSFORMER FAULT
57	28-Apr-20	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110, MANVI_110	20:14	20:27	0:13	LINE FAULT
58	28-Apr-20	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHABAD_220	17:15(17.4.20)			LINE FAULT
59	28-Apr-20	GULBARGA	220	KAPNOOR-SHAHPUR	SHAHPUR_220	17:15(17.4.20)			LINE FAULT
60	28-Apr-20	GULBARGA	220	LINGAPUR-ARESSSTEELS_IPP	ARESS STEELS_IPP	13:43	14:17	0:34	LINE CLEAR AVAILED
61	28-Apr-20	GULBARGA	220	LINGAPUR-GDHALLI1,2	GDHALLI_220	10:07	17:35	7:28	NFBC ISSUED
62	28-Apr-20	HASSAN	66	GANGUR-HASSAN	GANGUR_66	13:10	16:35	3:25	MAIN SUPPLY FAILURE
63	28-Apr-20	HASSAN	66	HAGARE-HASSAN	HAGARE_66	13:10	16:50	3:40	MAIN SUPPLY FAILURE
64	28-Apr-20	HASSAN	66	HV1	SAKLESH PURA_66	11:02	11:15	0:13	TRANSFORMER FAULT
65	28-Apr-20	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	9:00	19:01	10:01	LINE CLEAR AVAILED
66	28-Apr-20	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	9:00	19:01	10:01	LINE CLEAR AVAILED
67	28-Apr-20	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	15:04	16:57	1:53	LINE CLEAR AVAILED
68	28-Apr-20	HASSAN	110	AESK2-GANDASI	ARASIKERE_220	14:37	15:31	0:54	LINE FAULT
69	28-Apr-20	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	14:37	15:26	0:49	LINE FAULT
70	28-Apr-20	HASSAN	110	ARSK2-GERUMARA	ARASIKERE_220	14:37	15:27	0:50	LINE FAULT
71	28-Apr-20	HASSAN	110	HV1	ARASIKERE_220	14:37	15:37	1:00	TRANSFORMER FAULT
72	28-Apr-20	HASSAN	110	HV1	BRAHMAVARA_110	9:36	17:30	7:54	LINE CLEAR AVAILED
73	28-Apr-20	HASSAN	110	HV2	BRAHMAVARA_110	9:36	15:54	6:18	LINE CLEAR AVAILED
74	28-Apr-20	HASSAN	110	LV2	KEMAR-220	11:43	12:35	0:52	LINE CLEAR AVAILED
75	28-Apr-20	HASSAN	110	LV3	KEMAR-220	10:35	11:40	1:05	LINE CLEAR AVAILED
76	28-Apr-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	9:40	15:55	6:15	LINE CLEAR AVAILED
77	28-Apr-20	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	10:33	13:25	2:52	LINE CLEAR AVAILED
78	28-Apr-20	HASSAN	220	ARSK2-HSN	ARASIKERE_220	14:37	16:04	1:27	LINE CLEAR AVAILED
79	28-Apr-20	HASSAN	220	ARSK2-SMG	ARASIKERE_220	14:37	15:23	0:46	LINE FAULT
80	28-Apr-20	HASSAN	220	HV2	KEMAR-220	11:43	12:35	0:52	LINE CLEAR AVAILED
81	28-Apr-20	HASSAN	220	HV3	KEMAR-220	10:35	11:40	1:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
82	28-Apr-20	HASSAN	220	KEMAR-Kavoor1	KEMAR-220	10:20	12:21	2:01	LINE CLEAR AVAILED
83	28-Apr-20	HASSAN	220	KEMAR-Varahi1	KEMAR-220	9:54	12:17	2:23	NFBC ISSUED
84	28-Apr-20	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	14:37	15:23	0:46	LINE FAULT
85	28-Apr-20	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	10:20	12:21	2:01	NFBC ISSUED
86	28-Apr-20	HASSAN	220	VARAHI-KEMAR1	varahi_gen	9:55	12:15	2:20	LINE CLEAR AVAILED
87	28-Apr-20	MYSORE	66	CR NAGARA-YALANDUR	YELANDUR_66	6:27	6:31	0:03	LINE FAULT
88	28-Apr-20	MYSORE	66	K R PETE	HV1	13:12	13:55	0:43	LINE CLEAR AVAILED
89	28-Apr-20	MYSORE	66	KUSHALNAGARA 220-MYSORE-2	NO STATIONS	12:26	14:01	1:35	LINE CLEAR AVAILED
90	28-Apr-20	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	10:02	10:12	0:10	LINE FAULT
91	28-Apr-20	MYSORE	66	TUBINKERE-KOZIKODE	NO STATIONS	21:05	21:50	0:45	LINE FAULT
92	28-Apr-20	MYSORE	66	TUBINKERE-NAGAMANGALA 2	SHIVALLY_66	23:06	23:16	0:09	LINE FAULT
93	28-Apr-20	MYSORE	66	VAJMANGALA-DEVNOOR(MYS)	DEVANOORMYS_66RAJEEVNAGARA_66	16:55	17:05	0:09	LINE FAULT
94	28-Apr-20	MYSORE	220	KADAKOLA-KOZIKODE	NO STATIONS	15:26	15:48	0:22	LINE FAULT
95	28-Apr-20	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:23	10:37	0:13	LINE FAULT
96	28-Apr-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:51	15:01	0:10	LINE FAULT
97	28-Apr-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	10:50	11:01	0:11	LINE FAULT
98	28-Apr-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	12:34	17:07	4:33	LINE CLEAR AVAILED
99	28-Apr-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	11:38	11:48	0:10	LINE CLEAR AVAILED
100	28-Apr-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	12:26	17:08	4:41	LINE CLEAR AVAILED
101	28-Apr-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	23:21	23:29	0:07	LINE FAULT
102	28-Apr-20	TUMKUR	66	TR-1	BAGUR_TMK_66	8:55	12:11	3:16	LINE CLEAR AVAILED
103	28-Apr-20	TUMKUR	66	TR-1	GOWRASAMUDRA_66	10:32	13:03	2:31	LINE CLEAR AVAILED
104	28-Apr-20	TUMKUR	66	TR-2	BAGUR_TMK_66	8:55	12:11	3:16	LINE CLEAR AVAILED
105	28-Apr-20	TUMKUR	66	TR-2	DAVANGERE_SRS_220	12:22	12:25	0:02	LINE CLEAR AVAILED
106	28-Apr-20	TUMKUR	66	TR-3	HARIYABBE_66	11:12	11:20	0:08	TRANSFORMER FAULT
107	28-Apr-20	TUMKUR	110	DODDAGUNI- NITTUR	DODDAGUNI_110	14:37	17:01	2:23	MAIN SUPPLY FAILURE
108	28-Apr-20	TUMKUR	110	NITTUR 220kV- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	16:29	16:56	0:27	LINE CLEAR AVAILED
109	28-Apr-20	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	15:06	15:16	0:09	LINE FAULT
110	28-Apr-20	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	15:06	15:08	0:02	LINE CLEAR AVAILED
111	28-Apr-20	TUMKUR	110	SAMPIGE- DODDAGUNI	DODDAGUNI_110,AMMASANDRA_110,SAMPI GE_110	14:37	16:59	2:21	LINE FAULT
112	28-Apr-20	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	12:30	12:38	0:08	TRANSFORMER FAULT
113	28-Apr-20	TUMKUR	110	TR-2	KADEHALLI_110	16:43	17:06	0:22	LINE CLEAR AVAILED
114	28-Apr-20	TUMKUR	220	HIRIYUR220-MADHUGIRI	HIRIYUR_220	13:19	14:53	1:34	LINE CLEAR AVAILED
115	28-Apr-20	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	15:06	15:59	0:52	LINE CLEAR AVAILED
116	28-Apr-20	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	13:28	15:06	1:37	LINE FAULT
117	29-Apr-20	BAGALKOT	110	110/11KV, HV1	AMBEWADI_220	19:47	20:37	0:50	LINE CLEAR AVAILED
118	29-Apr-20	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	11:12	18:35	7:23	LINE CLEAR AVAILED
119	29-Apr-20	BAGALKOT	110	110/11KV,HV1	GOPPANAKOPPA_110	11:18	11:29	0:11	LINE CLEAR AVAILED
120	29-Apr-20	BAGALKOT	110	110/11KV,HV1,HV2	HANGAL_110	12:20	13:50	1:30	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
121	29-Apr-20	BAGALKOT	110	110/11KV,HV4	KANABARGI LAYOUT_110,KAKATI_33,SUZLON_33	11:23	16:02	4:39	LINE CLEAR AVAILED
122	29-Apr-20	BAGALKOT	110	110/11KV2	NIDAGUNDI_110	11:34	11:44	0:10	TRANSFORMER FAULT
123	29-Apr-20	BAGALKOT	110	110/33K,HV1	HANGAL_110,PALA_33	12:19	13:55	1:36	LINE CLEAR AVAILED
124	29-Apr-20	BAGALKOT	110	110/33K,HV2,HV3	HANGAL_110,BOMMANNALLI_33,BELAGALPE TE_33,LAXMIPUR_33,AKKIALUR_33	12:19	14:18	1:59	LINE CLEAR AVAILED
125	29-Apr-20	BAGALKOT	110	110/33KV,HV3	MAMADAPUR_110,,LINGALLI_33,DEVAR GENNUR-33	5:33	23:59	18:26	TRANSFORMER FAULT
126	29-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	13:05	13:09	0:04	TRANSFORMER FAULT
127	29-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	13:24	13:30	0:06	TRANSFORMER FAULT
128	29-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	14:23	14:34	0:11	TRANSFORMER FAULT
129	29-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	19:29	19:35	0:06	TRANSFORMER FAULT
130	29-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	23:27	23:30	0:03	TRANSFORMER FAULT
131	29-Apr-20	BAGALKOT	110	BAGEWADI-MAMADAPUR1	BAGEWADI_220	0:09	0:31	0:22	LINE FAULT
132	29-Apr-20	BAGALKOT	110	BAGEWADI-MAMADAPUR1	BAGEWADI_220	0:09	0:31	0:22	LINE FAULT
133	29-Apr-20	BAGALKOT	110	GADAG220-SAMBAPUR ROAD(DAMBAL1)	SAMBAPUR ROAD_110	8:12	14:01	5:49	LINE CLEAR AVAILED
134	29-Apr-20	BAGALKOT	110	GOPPANAKOPPA-NARGUND	NARGUND_110	17:23	21:52	4:29	LINE FAULT
135	29-Apr-20	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	13:36	13:49	0:13	HAND TRIPPED
136	29-Apr-20	BAGALKOT	110	ITNAL-HIDIKAL	HIDIKAL_110	10:58	16:34	5:36	LINE CLEAR AVAILED
137	29-Apr-20	BAGALKOT	110	JOG 2-SIRSI110	SIRSI_110	13:6(26.4.20)	15:07	25.69 hrs	LINE CLEAR AVAILED
138	29-Apr-20	BAGALKOT	110	KUDUCHI-SHIRAGUPPI	SHIRAGUPPI_110	5:35	6:25	0:50	LINE FAULT
139	29-Apr-20	BAGALKOT	110	MAHALINGAPUR-TERADAL	TERADAL_110	17:00	23:59	6:59	LINE FAULT
140	29-Apr-20	BAGALKOT	110	NARENDRA-KUD DHARWAD1	KUD DHARWAD_110	19:24	19:39	0:15	LINE FAULT
141	29-Apr-20	BAGALKOT	220	220/110KV,HV1,LV1	KUDUCHI_220	5:35	5:50	0:15	TRANSFORMER FAULT
142	29-Apr-20	BAGALKOT	220	BAGEWADI-BALUTI	BAGEWADI_220	15:50	16:05	0:15	LINE FAULT
143	29-Apr-20	BAGALKOT	220	GADAG-HARTI1	GADAG_220	11:10(26.4.20)	10:53	23.02 hrs	LINE CLEAR AVAILED
144	29-Apr-20	BAGALKOT	220	GADAG-HARTI1	GADAG_220	10:53	23:59	13:06	LINE CLEAR AVAILED
145	29-Apr-20	BAGALKOT	220	GADAG-HARTI2	GADAG_220	10:53	23:59	13:06	LINE CLEAR AVAILED
146	29-Apr-20	BAGALKOT	220	LINGASUR1-BAGEWADI	BAGEWADI_220	10:55	16:25	5:30	LINE CLEAR AVAILED
147	29-Apr-20	BAGALKOT	220	SHARAVATY1-SIRSI	SIRSI_220	10:57	13:07	2:10	LINE CLEAR AVAILED
148	29-Apr-20	BAGALKOT	220	SHARAVATY2-SIRSI	SIRSI_220	13:20	14:22	1:02	LINE CLEAR AVAILED
149	29-Apr-20	BAGALKOT	220	SRS HUBLI-SIRSI 1&2	SRS HUBLI_220	9:37	13:20	3:43	NFBC ISSUED
150	29-Apr-20	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR, NELAMANGALA 66	19:40	19:50	0:10	MAIN SUPPLY FAILURE
151	29-Apr-20	BENGALURU	66	BAIRAKUR - KEMBODI	BAIRAKUR	3:25	20:40	17:15	MAIN SUPPLY FAILURE
152	29-Apr-20	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	NO STATION AFFECTED	3:12	9:25	6:13	LINE FAULT
153	29-Apr-20	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	12:13	12:28	0:15	LOAD CHANGE OVER
154	29-Apr-20	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	13:41	13:45	0:03	LOAD CHANGE OVER
155	29-Apr-20	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	12:14	12:28	0:14	LOAD CHANGE OVER
156	29-Apr-20	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	13:41	13:45	0:03	LOAD CHANGE OVER
157	29-Apr-20	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	12:14	13:47	1:33	MAIN SUPPLY FAILURE
158	29-Apr-20	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	12:14	12:28	0:13	LOAD CHANGE OVER
159	29-Apr-20	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	13:41	13:44	0:02	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
160	29-Apr-20	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	11:12	11:44	0:32	LINE FAULT
161	29-Apr-20	BENGALURU	66	GANJIGUNTE - CHINTAMANI 1	NO STATION AFFECTED	3:12	9:30	6:18	LINE FAULT
162	29-Apr-20	BENGALURU	66	HV1	THIMAMPALLI	2:30	3:25	0:55	TRANSFORMER FAULT
163	29-Apr-20	BENGALURU	66	HV1	SIDDLAGHATTA	3:55	4:30	0:35	TRANSFORMER FAULT
164	29-Apr-20	BENGALURU	66	HV1	DEVARBISANAHALLI	17:38	23:59	6:20	LINE CLEAR AVAILED
165	29-Apr-20	BENGALURU	66	HV1	CB PURA I/A	4:14	10:40	6:25	TRANSFORMER FAULT
166	29-Apr-20	BENGALURU	66	HV1	CB PURA I/A	14:50	15:31	0:40	LINE CLEAR AVAILED
167	29-Apr-20	BENGALURU	66	HV1	DEVANAHALLI	4:07	4:15	0:08	TRANSFORMER FAULT
168	29-Apr-20	BENGALURU	66	HV1	DEVANAHALLI	16:58	17:08	0:10	TRANSFORMER FAULT
169	29-Apr-20	BENGALURU	66	HV1	KIADB DB PURA 220	7:10	7:30	0:20	TRANSFORMER FAULT
170	29-Apr-20	BENGALURU	66	HV2	KANAKAPURA 66	12:15	12:20	0:04	LINE CLEAR AVAILED
171	29-Apr-20	BENGALURU	66	HV2	CB PURA URBAN	12:22	13:00	0:37	LINE CLEAR AVAILED
172	29-Apr-20	BENGALURU	66	KADUGODI - EPIP 220	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	11:12	12:46	1:34	LINE FAULT
173	29-Apr-20	BENGALURU	66	KADUGODI - EPIP 220	ARMY WELFARE ORGANIZATION	11:12	12:46	1:34	LINE FAULT
174	29-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	3:25	3:47	0:21	LINE FAULT
175	29-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	3:47	3:49	0:01	LINE FAULT
176	29-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	3:49	3:57	0:08	LINE FAULT
177	29-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	3:57	9:05	5:07	LINE FAULT
178	29-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	9:05	10:12	1:07	LINE FAULT
179	29-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	10:12	10:32	0:19	LINE FAULT
180	29-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	10:38	11:20	0:41	LINE CLEAR AVAILED
181	29-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	11:32	11:46	0:13	LINE CLEAR AVAILED
182	29-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	14:54	15:48	0:54	LINE CLEAR AVAILED
183	29-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	15:48	18:45	2:56	LINE FAULT
184	29-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	18:50	20:00	1:10	LINE CLEAR AVAILED
185	29-Apr-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	10:26	11:39	1:12	LINE CLEAR AVAILED
186	29-Apr-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:04	15:56	0:51	LINE CLEAR AVAILED
187	29-Apr-20	BENGALURU	66	KYALNUR - VEMGAL	KYALNUR	16:50	17:05	0:15	LINE CLEAR AVAILED
188	29-Apr-20	BENGALURU	66	NANGLI - KEMBODI	NANGALI	3:25	20:30	17:04	MAIN SUPPLY FAILURE
189	29-Apr-20	BENGALURU	66	PATHPALYA - SOMANATHPURA	SOMANATHPURA, THIMAMPALLI	1:34	1:39	0:05	LINE FAULT
190	29-Apr-20	BENGALURU	66	SIDDLAGHATTA - CHINTAMANI 220	SIDDLAGHATTA	8:45	9:30	0:45	LINE CLEAR AVAILED
191	29-Apr-20	BENGALURU	220	HV2	YELAHANKA 220	5:20	5:39	0:19	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
192	29-Apr-20	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110, KONKAL_110	2:20	2:30	0:10	LINE FAULT
193	29-Apr-20	GULBARGA	110	HANUMASAGAR-KUSTAGI	HANUMASAGAR_110, HIREGONNAGAR_110, HANUMANAL_110	11:20	11:45	0:25	MAIN SUPPLY FAILURE
194	29-Apr-20	GULBARGA	110	HANUMASAGAR-KUSTAGI	HANUMASAGAR_110, HIREGONNAGAR_110, HANUMANAL_110	12:00	12:25	0:25	MAIN SUPPLY FAILURE
195	29-Apr-20	GULBARGA	110	HV1	GURUMITAKAL_110, KONKAL_110	0:10	0:20	0:10	TRANSFORMER FAULT
196	29-Apr-20	GULBARGA	110	HV1	GURUMITAKAL_110	11:20	12:05	0:45	TRANSFORMER FAULT
197	29-Apr-20	GULBARGA	110	HV1	HANUMASAGAR_110	20:00	20:40	0:40	TRANSFORMER FAULT
198	29-Apr-20	GULBARGA	110	HV1	HATTI_110	8:58	20:10	11:12	LINE CLEAR AVAILED
199	29-Apr-20	GULBARGA	110	HV2	YELBURGA_110	18:55	19:25	0:30	TRANSFORMER FAULT
200	29-Apr-20	GULBARGA	110	KUDITINI-BELLARY(ALIPUR)	KUDITINI_110, TORANGALLU_110	3:05	3:10	0:05	LINE FAULT
201	29-Apr-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	20:53	23:59	3:06	LINE FAULT
202	29-Apr-20	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGWAT_110	20:10	20:20	0:10	LINE FAULT
203	29-Apr-20	GULBARGA	110	SHAHPUR220-SHAHBAD1	SHAHPUR_110	5:01	10:20	5:19	LINE FAULT
204	29-Apr-20	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	11:20	11:50	0:30	MAIN SUPPLY FAILURE
205	29-Apr-20	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	12:00	12:35	0:35	MAIN SUPPLY FAILURE
206	29-Apr-20	GULBARGA	220	HV1	KUSTAGI_220	11:20	11:30	0:10	TRANSFORMER FAULT
207	29-Apr-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.20)			LINE FAULT
208	29-Apr-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.20)			LINE FAULT
209	29-Apr-20	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	11:59	12:21	0:22	LINE FAULT
210	29-Apr-20	GULBARGA	220	MALLAT-LINGASUGUR_220	LINGASUGUR_220	12:00	13:45	1:45	LINE FAULT
211	29-Apr-20	GULBARGA	400	BTPS-HIRIYUR1	HIRIYUR_400	12:00	23:59	11:59	NFBC ISSUED
212	29-Apr-20	HASSAN	66	HASSN22-HSN66	HASSAN_220	10:34	12:47	2:13	LINE CLEAR AVAILED
213	29-Apr-20	HASSAN	66	HV2	SINGAPURA_66	10:44	13:07	2:23	LINE CLEAR AVAILED
214	29-Apr-20	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	10:00	17:59	7:59	LINE CLEAR AVAILED
215	29-Apr-20	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	10:00	17:59	7:59	LINE CLEAR AVAILED
216	29-Apr-20	HASSAN	66	UDDURKO-NITTUR2	UDDURKOPLU_66	11:36	13:13	1:37	LINE CLEAR AVAILED
217	29-Apr-20	HASSAN	66	UDDURKO-NITTUR1	UDDURKOPLU_66	11:01	11:36	0:35	LINE CLEAR AVAILED
218	29-Apr-20	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	10:19	12:55	2:36	NFBC ISSUED
219	29-Apr-20	HASSAN	110	HV2	BHADRAVATHI_110	11:25	12:49	1:24	LINE CLEAR AVAILED
220	29-Apr-20	HASSAN	110	HV2	MOODABIDRE_110	10:55	11:26	0:31	LINE CLEAR AVAILED
221	29-Apr-20	HASSAN	110	HV4	BAIKAMPADI_110	0:11	5:34	5:23	TRANSFORMER FAULT
222	29-Apr-20	HASSAN	110	JOG-NK2	mghejog_gen	14:15	15:21	1:06	LINE CLEAR AVAILED
223	29-Apr-20	HASSAN	110	KADUR-YGTI	KADUR_220	10:08	12:10	2:02	LINE CLEAR AVAILED
224	29-Apr-20	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	0:11	0:29	0:18	LINE FAULT
225	29-Apr-20	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:19	12:55	2:36	LINE CLEAR AVAILED
226	29-Apr-20	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	10:23	12:57	2:34	LINE CLEAR AVAILED
227	29-Apr-20	HASSAN	110	MRSSHM-GAJNUR	MRS MG_220	9:51	9:52	0:01	HAND TRIPPED
228	29-Apr-20	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	10:57	13:07	2:10	NFBC ISSUED
229	29-Apr-20	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	13:20	14:23	1:03	NFBC ISSUED
230	29-Apr-20	HASSAN	220	VARAHI-SHMG3	varahi_gen	9:47	9:53	0:06	LINE FAULT
231	29-Apr-20	MYSORE	66	CHAMARAJANAGARA-DR PET 2	NO STATIONS	7:14	8:15	1:01	LINE CLEAR AVAILED
232	29-Apr-20	MYSORE	66	CHAMARAJANAGARA-DR PET 2	NO STATIONS	8:21	8:30	0:09	HAND TRIPPED
233	29-Apr-20	MYSORE	66	CHAMARAJANAGARA-DR PET 2	NO STATIONS	16:45	16:56	0:11	LINE FAULT
234	29-Apr-20	MYSORE	66	CHAMARAJANAGARA-DR PET 2	NO STATIONS	17:52	17:55	0:03	LINE FAULT
235	29-Apr-20	MYSORE	66	HANNUR-COWDALLI	BANDALLI_66, RAMAPURA_MYS_66 & MARTAHALLI_66	5:51	5:55	0:03	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
236	29-Apr-20	MYSORE	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS	5:51	5:55	0:03	LINE FAULT
237	29-Apr-20	MYSORE	66	HV1	JAKKANAHALLY_66	19:22	19:39	0:17	TRANSFORMER FAULT
238	29-Apr-20	MYSORE	66	HV1	GAVADAGERE_66	18:00	18:10	0:10	LINE CLEAR AVAILED
239	29-Apr-20	MYSORE	66	HV2	COWDALLI_66	6:03	6:08	0:04	TRANSFORMER FAULT
240	29-Apr-20	MYSORE	66	HV2	COWDALLI_66	7:22	7:23	0:01	TRANSFORMER FAULT
241	29-Apr-20	MYSORE	66	HV2	DEVANOORNGUDU_66	2:46	2:52	0:05	TRANSFORMER FAULT
242	29-Apr-20	MYSORE	66	HV2	DEVANOORNGUDU_66	10:00	10:25	0:25	TRANSFORMER FAULT
243	29-Apr-20	MYSORE	66	HV2	DEVANOORNGUDU_66	10:18	11:00	0:41	LINE CLEAR AVAILED
244	29-Apr-20	MYSORE	66	HV2	ANEGOLAL_66	13:50	16:45	2:55	LINE CLEAR AVAILED
245	29-Apr-20	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	0:26	0:34	0:07	LINE FAULT
246	29-Apr-20	MYSORE	66	MADIKERI-SUNTIKOPPA	NO STATIONS	6:57	7:18	0:21	LINE FAULT
247	29-Apr-20	MYSORE	220	HV1	MADHUVANAHALLI_220	0:26	0:33	0:07	TRANSFORMER FAULT
248	29-Apr-20	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	13:09	13:14	0:05	MAIN SUPPLY FAILURE
249	29-Apr-20	TUMKUR	66	BHAKTHARA HALLI -ANCHEPALYA	BHAKTHARAHALLI_66	15:27	16:14	0:46	LINE CLEAR AVAILED
250	29-Apr-20	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	13:35	13:37	0:02	MAIN SUPPLY FAILURE
251	29-Apr-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:06	6:14	0:07	LINE FAULT
252	29-Apr-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	12:56	13:04	0:07	LINE FAULT
253	29-Apr-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	14:35	14:54	0:18	LINE FAULT
254	29-Apr-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	14:23	14:33	0:09	LINE FAULT
255	29-Apr-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	8:26	8:47	0:21	LINE FAULT
256	29-Apr-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	10:39	12:12	1:33	LINE CLEAR AVAILED
257	29-Apr-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	14:07	14:55	0:48	LINE FAULT
258	29-Apr-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	10:39	12:12	1:32	LINE CLEAR AVAILED
259	29-Apr-20	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	9:49	9:51	0:01	HAND TRIPPED
260	29-Apr-20	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	16:59	17:06	0:07	LINE FAULT
261	29-Apr-20	TUMKUR	66	PAVAGADA-NAGALAMADIKE	NAGALMADIKE_66	9:27	10:10	0:43	HAND TRIPPED
262	29-Apr-20	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	15:27	16:14	0:46	LINE CLEAR AVAILED
263	29-Apr-20	TUMKUR	66	TR-1	KALAMARANAHALLI_66	11:07	11:40	0:32	LINE CLEAR AVAILED
264	29-Apr-20	TUMKUR	66	TR-1	LINGADAHALLI_TMK2_66	0:09	0:28	0:18	TRANSFORMER FAULT
265	29-Apr-20	TUMKUR	66	TR-1	MADHUGIRI_66	5:24	5:29	0:04	TRANSFORMER FAULT
266	29-Apr-20	TUMKUR	66	TR-1	TUMKUR_66	14:55	15:35	0:39	TRANSFORMER FAULT
267	29-Apr-20	TUMKUR	66	TR-2	KOLALA_66	15:22	15:44	0:22	LINE CLEAR AVAILED
268	29-Apr-20	TUMKUR	66	TR-2	SHYLAPURA_66	2:35	3:27	0:51	TRANSFORMER FAULT
269	29-Apr-20	TUMKUR	66	TR-2	SHYLAPURA_66	7:41	9:06	1:25	TRANSFORMER FAULT
270	29-Apr-20	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	15:09	15:49	0:40	LINE CLEAR AVAILED
271	29-Apr-20	TUMKUR	110	TR-2	NITTUR_220	10:18	11:02	0:43	TRANSFORMER FAULT
272	29-Apr-20	TUMKUR	110	TR-2	SAMPIGE_110	13:17	14:54	1:36	LINE CLEAR AVAILED
273	29-Apr-20	TUMKUR	220	HONNALLI 220kV- SUZLON1	SUZLON_IPP_66	16:05	17:12	1:07	LINE CLEAR AVAILED
274	29-Apr-20	TUMKUR	220	HONNALLI 220kV- SUZLON2	SUZLON_IPP_66	13:08	14:20	1:12	LINE CLEAR AVAILED
275	29-Apr-20	TUMKUR	220	PAVAGADA-MADHUGIRI1	PAVAGADA_66	6:01	6:49	0:48	LINE FAULT
276	29-Apr-20	TUMKUR	220	TR-1(HV SIDE)	KBCROSS_220	15:09	15:48	0:38	LINE CLEAR AVAILED
277	30-Apr-20	BAGALKOT	110	110/11KV, HV1	GULEDGUDDA_110	11:17	11:43	0:26	LINE CLEAR AVAILED
278	30-Apr-20	BAGALKOT	110	110/11KV, HV1	GULEDGUDDA_110	15:59	17:14	1:15	LINE CLEAR AVAILED
279	30-Apr-20	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	18:46	19:13	0:27	TRANSFORMER FAULT
280	30-Apr-20	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	21:06	21:14	0:08	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
281	30-Apr-20	BAGALKOT	110	110/11KV,HV 1	KHANAPUR_110	16:23(28.4.20)	15:06	22.96 hrs	LINE CLEAR AVAILED
282	30-Apr-20	BAGALKOT	110	110/11KV,HV 2	KHANAPUR_110	15:11	15:48	0:37	HAND TRIPPED
283	30-Apr-20	BAGALKOT	110	110/11KV,HV2	SHIROL_110	15:16	15:24	0:08	TRANSFORMER FAULT
284	30-Apr-20	BAGALKOT	110	110/11KV,HV2	MUDDEBIHAL_110	18:03	18:10	0:07	TRANSFORMER FAULT
285	30-Apr-20	BAGALKOT	110	110/33KV,HV3	MAMADAPUR_110,,LINGADALLI_33,DEVAR GENNUR-33	5:33			TRANSFORMER FAULT
286	30-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	0:04	0:08	0:04	TRANSFORMER FAULT
287	30-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	1:08	1:32	0:24	TRANSFORMER FAULT
288	30-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	1:59	20:05	18:06	TRANSFORMER FAULT
289	30-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	12:23	12:37	0:14	TRANSFORMER FAULT
290	30-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	15:05	15:18	0:13	TRANSFORMER FAULT
291	30-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	21:17	21:26	0:09	TRANSFORMER FAULT
292	30-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	21:34	21:48	0:14	TRANSFORMER FAULT
293	30-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	21:52	21:57	0:05	TRANSFORMER FAULT
294	30-Apr-20	BAGALKOT	110	AMBEWADI-NK1(HALYAL)	HALIYAL_110	9:14	15:16	6:02	LINE CLEAR AVAILED
295	30-Apr-20	BAGALKOT	110	AMBEWADI-NK1(HALYAL)	HALIYAL_110	18:21	19:36	1:15	LINE FAULT
296	30-Apr-20	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	KAVALWAD_110	18:28			LINE FAULT
297	30-Apr-20	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	KAVALWAD_110	8:57	15:16	6:19	LINE CLEAR AVAILED
298	30-Apr-20	BAGALKOT	110	BELGAUM220-ANKALGI	ANKALGI_110, HUDLI_110, ISLAMPUR_110	16:06	16:46	0:40	LINE FAULT
299	30-Apr-20	BAGALKOT	110	BELGAUM220-UCHAGOAN	UCHAGOAN_110, UDYAMBAG_110	16:06	17:02	0:56	LINE FAULT
300	30-Apr-20	BAGALKOT	110	CHIKKODI220-SNKESHWAR	SANKESHWAR_110, HUKKERI_110	23:40	23:59	0:19	LINE CLEAR AVAILED
301	30-Apr-20	BAGALKOT	110	GADAG220-BETAGERI	BETAGERI_110	8:37	13:17	4:40	LINE CLEAR AVAILED
302	30-Apr-20	BAGALKOT	110	GAJENDRAGAD-KUSHTAGI	GAJENDRAGAD_110	18:01(27.4.20)	8:37	14:37	LINE CLEAR AVAILED
303	30-Apr-20	BAGALKOT	110	MAHALINGAPUR-TERADAL	TERADAL_110	17:0(29.4.20)	15:53	22:53	LINE CLEAR AVAILED
304	30-Apr-20	BAGALKOT	110	MAMADAPUR(B)-SHIRBUR	SHIRBUR_110	17:07	17:23	0:16	HAND TRIPPED
305	30-Apr-20	BAGALKOT	110	RON -GAJENDRAGAD1&2	GAJENDRAGAD_110	13:24	16:20	2:56	LINE CLEAR AVAILED
306	30-Apr-20	BAGALKOT	220	220/110KV,HV3,LV3	MAHALINGAPUR_220,ITNAL_110,DAVALESHW AR_110,HIDIKAL_110	17:20	17:55	0:35	TRANSFORMER FAULT
307	30-Apr-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	9:16			LINE FAULT
308	30-Apr-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	19:30(18.1.20)	9:10		LINE CLEAR AVAILED
309	30-Apr-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI2	BAGALKOT_220	23:39(18.2.20)	8:41		LINE CLEAR AVAILED
310	30-Apr-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI2	BAGALKOT_220	11:00	23:59	12:59	LINE CLEAR AVAILED
311	30-Apr-20	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	19:09	23:59	4:50	LINE CLEAR AVAILED
312	30-Apr-20	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	18:41			LINE FAULT
313	30-Apr-20	BAGALKOT	220	NAGJHARI1-HUBLI	HUBLI_220	18:07	18:57	0:50	LINE FAULT
314	30-Apr-20	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	17:27	21:30	4:03	LINE FAULT
315	30-Apr-20	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	19:05			LINE FAULT
316	30-Apr-20	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	15:05	15:08	0:03	LOAD CHANGE OVER
317	30-Apr-20	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	9:57	10:03	0:06	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
318	30-Apr-20	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	12:14	12:20	0:06	LOAD CHANGE OVER
319	30-Apr-20	BENGALURU	66	ATTUR YELAHANKA - DG 4	ATTUR YELAHANKA	14:00	14:04	0:04	LOAD CHANGE OVER
320	30-Apr-20	BENGALURU	66	BAIRAKUR - KOLAR 220	BAIRAKUR	1:27	12:53	11:25	MAIN SUPPLY FAILURE
321	30-Apr-20	BENGALURU	66	BAIRAKUR - KOLAR 220	BAIRAKUR	15:33	17:00	1:26	MAIN SUPPLY FAILURE
322	30-Apr-20	BENGALURU	66	GOWRIBIDANUR 220 - AFTL(SOLAR)EHT	NO STATION AFFECTED	11:06	11:34	0:28	LINE FAULT
323	30-Apr-20	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSUR RAMAPURA	11:06	11:33	0:27	MAIN SUPPLY FAILURE
324	30-Apr-20	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI	11:06	18:22	7:16	LINE FAULT
325	30-Apr-20	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	11:06	11:33	0:27	MAIN SUPPLY FAILURE
326	30-Apr-20	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	17:55	18:00	0:05	LOAD CHANGE OVER
327	30-Apr-20	BENGALURU	66	HBR LAYOUT - MANYATHA 220	HBR LAYOUT	19:32	19:37	0:05	LOAD CHANGE OVER
328	30-Apr-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	17:06	18:00	0:54	MAIN SUPPLY FAILURE
329	30-Apr-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	17:06	17:15	0:08	MAIN SUPPLY FAILURE
330	30-Apr-20	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	17:06	18:00	0:54	MAIN SUPPLY FAILURE
331	30-Apr-20	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	17:06	18:00	0:54	MAIN SUPPLY FAILURE
332	30-Apr-20	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	17:06	18:00	0:54	MAIN SUPPLY FAILURE
333	30-Apr-20	BENGALURU	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR	12:45	13:00	0:14	LINE CLEAR AVAILED
334	30-Apr-20	BENGALURU	66	HV1	BRIGADE METROPOLIS	14:07	14:43	0:36	LINE CLEAR AVAILED
335	30-Apr-20	BENGALURU	66	HV1	NELAKADRANAHALLI	12:05	12:10	0:05	LINE CLEAR AVAILED
336	30-Apr-20	BENGALURU	66	HV1	HOODY 220	11:34	11:37	0:03	LINE CLEAR AVAILED
337	30-Apr-20	BENGALURU	66	HV1	HOSPALYA CIRCLE	18:29	18:40	0:10	TRANSFORMER FAULT
338	30-Apr-20	BENGALURU	66	HV1	YEDUMADU	13:02	13:05	0:02	LINE CLEAR AVAILED
339	30-Apr-20	BENGALURU	66	HV1	MANYATHA 220	12:35	12:41	0:06	LOAD CHANGE OVER
340	30-Apr-20	BENGALURU	66	HV1	GOWRIBIDANUR 220	8:05	9:33	1:28	TRANSFORMER FAULT
341	30-Apr-20	BENGALURU	66	HV2	VIJAYANAGARA	20:23	20:32	0:09	LOAD CHANGE OVER
342	30-Apr-20	BENGALURU	66	HV2	IISc	7:48	7:53	0:05	LINE CLEAR AVAILED
343	30-Apr-20	BENGALURU	66	HV2	KADUGODI	12:57	13:57	1:00	LINE CLEAR AVAILED
344	30-Apr-20	BENGALURU	66	HV2	NELAKADRANAHALLI	10:40	10:55	0:15	LINE CLEAR AVAILED
345	30-Apr-20	BENGALURU	66	HV2	KIADB DB PURA 220	11:58	12:14	0:15	TRANSFORMER FAULT
346	30-Apr-20	BENGALURU	66	HV2	SOMAYAJJANAHALLI	12:21	12:48	0:26	LINE CLEAR AVAILED
347	30-Apr-20	BENGALURU	66	HV2	YEDUMADU	11:37	11:42	0:04	LINE CLEAR AVAILED
348	30-Apr-20	BENGALURU	66	HV2	GOWRIBIDANUR 220	8:05	8:50	0:45	TRANSFORMER FAULT
349	30-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	0:26	0:40	0:13	LINE FAULT
350	30-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	0:40	0:52	0:12	LINE FAULT
351	30-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	0:52	3:31	2:39	LINE FAULT
352	30-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	3:31	5:37	2:05	LINE FAULT
353	30-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	5:37	7:22	1:45	LINE CLEAR AVAILED
354	30-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	7:22	8:58	1:35	LINE FAULT
355	30-Apr-20	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	11:28	12:26	0:57	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
356	30-Apr-20	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	10:40	10:53	0:13	MAIN SUPPLY FAILURE
357	30-Apr-20	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	10:40	10:55	0:15	MAIN SUPPLY FAILURE
358	30-Apr-20	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	10:40	10:54	0:14	MAIN SUPPLY FAILURE
359	30-Apr-20	BENGALURU	66	KHODAYS 220 - SOUTH CITY	SOUTH CITY	10:40	10:57	0:17	MAIN SUPPLY FAILURE
360	30-Apr-20	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	1:39	1:56	0:16	LINE FAULT
361	30-Apr-20	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	15:12	15:18	0:06	LINE FAULT
362	30-Apr-20	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	15:23	16:52	1:29	LINE CLEAR AVAILED
363	30-Apr-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	16:15	16:53	0:37	LINE CLEAR AVAILED
364	30-Apr-20	BENGALURU	66	MANYATHA 220 - MANYATHA 66	MANYATHA 66	12:35	12:41	0:06	LOAD CHANGE OVER
365	30-Apr-20	BENGALURU	66	MANYATHA TECH PARK 220 - SHOBHA CITY(EHT)	SHOBHA CITY(EHT)	12:31	12:46	0:15	LOAD CHANGE OVER
366	30-Apr-20	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	10:40	10:44	0:04	MAIN SUPPLY FAILURE
367	30-Apr-20	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT),R R NAGAR	10:40	10:44	0:04	MAIN SUPPLY FAILURE
368	30-Apr-20	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	10:40	10:44	0:04	MAIN SUPPLY FAILURE
369	30-Apr-20	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	10:40	10:44	0:04	MAIN SUPPLY FAILURE
370	30-Apr-20	BENGALURU	66	SUBRAMANYAPURA 220 - SOMANAHALLI 1	SUBRAMANYAPURA 66, ISKON	10:40	10:44	0:04	MAIN SUPPLY FAILURE
371	30-Apr-20	BENGALURU	66	SURYANAGAR - ANEKAL	NO STATION AFFECTED	18:27	18:46	0:18	LINE FAULT
372	30-Apr-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	HOSKOTE 220, DEVANAHALLI HARDWARE PARK 220	17:06	18:00	0:54	LINE CLEAR AVAILED
373	30-Apr-20	BENGALURU	220	HV1	MANYATHA TECH PARK	12:31	12:46	0:15	LOAD CHANGE OVER
374	30-Apr-20	BENGALURU	220	HV3	GOWRIBIDANUR 220	11:06	11:30	0:24	TRANSFORMER FAULT
375	30-Apr-20	BENGALURU	220	KHODAYS 220- SOMANAHALLI 220	KHODYAS 220, SUBRAMANYAPURA 220	10:40	10:52	0:12	LINE CLEAR AVAILED
376	30-Apr-20	GULBARGA	110	GULBARGAUNIVERSITY-GULBAGASOUTH	GULUNI_110	20:10	20:35	0:25	MAIN SUPPLY FAILURE
377	30-Apr-20	GULBARGA	110	HV1	HATTI_110	8:12	11:12	3:00	LINE CLEAR AVAILED
378	30-Apr-20	GULBARGA	110	HV2	HATTI_110	7:34	12:02	4:28	LINE CLEAR AVAILED
379	30-Apr-20	GULBARGA	110	HV2	HATTI_110	21:35	21:40	0:05	TRANSFORMER FAULT
380	30-Apr-20	GULBARGA	110	HV2	MANVI_110	12:38	12:48	0:10	TRANSFORMER FAULT
381	30-Apr-20	GULBARGA	110	KAPNOOR-GULBARGAWEST	GULBARGAWEST_110,GULBARGASOUTH_110	20:09	23:59	3:50	LINE FAULT
382	30-Apr-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	23:53(29.4.20)	0:05	0:12	LINE FAULT
383	30-Apr-20	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110, HUNSAGI_110, ASKI_110	19:43	19:49	0:06	LINE FAULT
384	30-Apr-20	GULBARGA	220	HV2	SEDAM_220	18:16	19:00	0:44	HAND TRIPPED
385	30-Apr-20	GULBARGA	220	KAPNOOR-SHAHABAD	NO STATION AFFECTED	17:15			LINE FAULT
386	30-Apr-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15			LINE FAULT
387	30-Apr-20	GULBARGA	220	SHAHPUR-SHAHABAD	SHAHABAD_220	11:36	13:01	1:25	LINE FAULT
388	30-Apr-20	GULBARGA	400	BTPS-HIRIYUR1	HIRIYUR_400	12:00(29.4.20)	18:08	30:08 hrs	LINE CLEAR AVAILED
389	30-Apr-20	HASSAN	66	HV2	HOLEHONNUR_66	11:34	13:08	1:34	LINE CLEAR AVAILED
390	30-Apr-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	15:36	15:59	0:23	LINE FAULT
391	30-Apr-20	HASSAN	66	LV1	MRSMSG_220	13:44	13:58	0:14	TRANSFORMER FAULT
392	30-Apr-20	HASSAN	66	LV2	MRSMSG_220	13:44	13:57	0:13	TRANSFORMER FAULT
393	30-Apr-20	HASSAN	66	LV3	MRSMSG_220	13:44	13:57	0:13	TRANSFORMER FAULT
394	30-Apr-20	HASSAN	66	LV4	MRSMSG_220	13:43	13:57	0:14	TRANSFORMER FAULT
395	30-Apr-20	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	13:44	13:58	0:14	LINE FAULT
396	30-Apr-20	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	13:44	13:58	0:14	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
397	30-Apr-20	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	13:40	14:16	0:36	LINE FAULT
398	30-Apr-20	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	13:40	13:58	0:18	LINE FAULT
399	30-Apr-20	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:45	18:24	9:39	LINE CLEAR AVAILED
400	30-Apr-20	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	8:45	18:25	9:40	LINE CLEAR AVAILED
401	30-Apr-20	HASSAN	110	ANANDA-SHIMOGA	ANANDPURA_110	13:40	14:14	0:34	LINE FAULT
402	30-Apr-20	HASSAN	110	ESSUR-BELIGAVI	ESSUR_110	15:15	16:12	0:57	LINE CLEAR AVAILED
403	30-Apr-20	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	13:58	14:05	0:07	LINE FAULT
404	30-Apr-20	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	16:00	16:40	0:40	MAIN SUPPLY FAILURE
405	30-Apr-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	16:00	17:08	1:08	MAIN SUPPLY FAILURE
406	30-Apr-20	HASSAN	110	GURUVA-SLPWR	GURUVAYANAKERE_110	16:01	16:45	0:44	MAIN SUPPLY FAILURE
407	30-Apr-20	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	10:19	13:02	2:43	LINE CLEAR AVAILED
408	30-Apr-20	HASSAN	110	HV1	MRSMSG_220	13:44	13:57	0:13	TRANSFORMER FAULT
409	30-Apr-20	HASSAN	110	HV2	MRSMSG_220	13:44	13:57	0:13	TRANSFORMER FAULT
410	30-Apr-20	HASSAN	110	HV3	MRSMSG_220	13:44	13:57	0:13	TRANSFORMER FAULT
411	30-Apr-20	HASSAN	110	HV4	MRSMSG_220	13:44	13:56	0:12	TRANSFORMER FAULT
412	30-Apr-20	HASSAN	110	HV5	MRSMSG_220	13:43	13:51	0:08	TRANSFORMER FAULT
413	30-Apr-20	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	16:00	16:40	0:40	LINE FAULT
414	30-Apr-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	16:00	17:07	1:07	LINE FAULT
415	30-Apr-20	HASSAN	110	LV1	MRSMSG_220	13:40	13:52	0:12	TRANSFORMER FAULT
416	30-Apr-20	HASSAN	110	LV2	MRSMSG_220	13:40	13:51	0:11	TRANSFORMER FAULT
417	30-Apr-20	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	13:43	14:02	0:19	LINE FAULT
418	30-Apr-20	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	13:43	14:03	0:20	LINE FAULT
419	30-Apr-20	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	13:43	13:54	0:11	LINE FAULT
420	30-Apr-20	HASSAN	110	MRSSHM-MPM	MRSMSG_220	13:43	13:55	0:12	LINE FAULT
421	30-Apr-20	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	13:40	13:55	0:15	LINE FAULT
422	30-Apr-20	HASSAN	110	MRSSHM-SS1	MRSMSG_220	13:43	13:56	0:13	LINE FAULT
423	30-Apr-20	HASSAN	110	MRSSHM-SS2	MRSMSG_220	13:43	13:56	0:13	LINE FAULT
424	30-Apr-20	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	17:18	17:38	0:20	LINE FAULT
425	30-Apr-20	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	17:24	17:52	0:28	LINE FAULT
426	30-Apr-20	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	14:58	16:15	1:17	LINE CLEAR AVAILED
427	30-Apr-20	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	18:38			LINE FAULT
428	30-Apr-20	HASSAN	110	VGAJNUR	MRSMSG_220	16:04	18:44	2:40	LINE FAULT
429	30-Apr-20	HASSAN	220	HASSAN4-SHIMOGA1	SHANTHIGRAMA_400	15:59	19:36	3:37	LINE FAULT
430	30-Apr-20	HASSAN	220	HV1	MRSMSG_220	13:40	13:50	0:10	TRANSFORMER FAULT
431	30-Apr-20	HASSAN	220	HV2	MRSMSG_220	13:40	13:50	0:10	TRANSFORMER FAULT
432	30-Apr-20	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	11:00	12:41	1:41	LINE CLEAR AVAILED
433	30-Apr-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	9:22	23:59	14:37	NFBC ISSUED
434	30-Apr-20	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	13:40	13:47	0:07	LINE FAULT
435	30-Apr-20	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	13:40	13:48	0:08	LINE FAULT
436	30-Apr-20	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	13:40	13:59	0:19	LINE FAULT
437	30-Apr-20	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	13:40	13:48	0:08	LINE FAULT
438	30-Apr-20	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	15:59	19:36	3:37	LINE FAULT
439	30-Apr-20	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	13:40	13:48	0:08	LINE FAULT
440	30-Apr-20	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	13:40	13:48	0:08	LINE FAULT
441	30-Apr-20	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	13:40	13:59	0:19	LINE FAULT
442	30-Apr-20	HASSAN	220	MRSSHM-VARAH11	MRSMSG_220	13:40	13:48	0:08	LINE FAULT
443	30-Apr-20	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	13:15	17:49	4:34	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
444	30-Apr-20	HASSAN	220	MRSSHM-VARAH13	MRSMG_220	13:38	18:47	5:09	LINE FAULT
445	30-Apr-20	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	19:49			LINE FAULT
446	30-Apr-20	HASSAN	220	VARAHI-KEMAR1	varahi_gen	9:21	23:59	14:38	LINE CLEAR AVAILED
447	30-Apr-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	12:36	12:52	0:16	LINE FAULT
448	30-Apr-20	HASSAN	220	VARAHI-KEMAR3	varahi_gen	12:36	12:46	0:10	LINE FAULT
449	30-Apr-20	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	12:36	12:45	0:09	LINE FAULT
450	30-Apr-20	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	12:36	12:45	0:09	LINE FAULT
451	30-Apr-20	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	13:16	17:51	4:35	LINE CLEAR AVAILED
452	30-Apr-20	HASSAN	220	VARAHI-SHMG3	varahi_gen	12:36	12:45	0:09	LINE FAULT
453	30-Apr-20	HASSAN	220	VARAHI-SHMG3	varahi_gen	13:38	18:48	5:10	LINE FAULT
454	30-Apr-20	MYSORE	66	CR NAGARA-YALANDUR	YELANDUR_66	6:43	6:50	0:06	LINE CLEAR AVAILED
455	30-Apr-20	MYSORE	66	DODDARAYAPETE-CR NAGARA 1	NO STATIONS	11:42	17:47	6:05	LINE FAULT
456	30-Apr-20	MYSORE	66	HANNUR-AMP SOLAR	NO STATIONS	1:13	1:18	0:05	LINE CLEAR AVAILED
457	30-Apr-20	MYSORE	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS	1:13	1:17	0:04	LINE CLEAR AVAILED
458	30-Apr-20	MYSORE	66	HV1	BANNUR_66	12:35	14:01	1:26	TRANSFORMER FAULT
459	30-Apr-20	MYSORE	66	HV1	BANNUR_66	14:12	15:04	0:51	TRANSFORMER FAULT
460	30-Apr-20	MYSORE	66	HV1	HANNUR_66	10:44	12:11	1:26	TRANSFORMER FAULT
461	30-Apr-20	MYSORE	66	HV2	RKNAGARA_66	11:03	11:29	0:25	TRANSFORMER FAULT
462	30-Apr-20	MYSORE	66	KOLLEGALA-SATHEGALA	NO STATIONS	6:10	6:15	0:04	LINE CLEAR AVAILED
463	30-Apr-20	MYSORE	66	MEGHALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 TNARASIPURA_66 VYASRAJPURA_66	6:38	6:46	0:08	LINE CLEAR AVAILED
464	30-Apr-20	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	10:53	10:59	0:05	LINE CLEAR AVAILED
465	30-Apr-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	13:07	13:15	0:07	LINE FAULT
466	30-Apr-20	TUMKUR	66	HEGGERE- MALLASANDRA	MALLASANDRA_66	15:57	16:37	0:40	LINE FAULT
467	30-Apr-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	10:50	10:58	0:07	LINE FAULT
468	30-Apr-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:25	11:41	0:16	LINE FAULT
469	30-Apr-20	TUMKUR	66	NEELAGUNDA- TELAGI	PUNABHAGHATTA_66,HARAPPANAHALLI_66, HALUVAGALU_66,TELAGI_66	1:50	2:01	0:10	LINE FAULT
470	30-Apr-20	TUMKUR	66	TR-1	UCHCHANGIDURGA_66	11:04	13:12	2:07	LINE CLEAR AVAILED
471	30-Apr-20	TUMKUR	66	TR-2	CHANNAGIRI_66	12:16	12:21	0:04	TRANSFORMER FAULT
472	30-Apr-20	TUMKUR	66	TR-2	HALUVAGALU_66	15:57	16:12	0:14	TRANSFORMER FAULT
473	30-Apr-20	TUMKUR	66	TR-2	HONNUDIKE_66	17:55	18:21	0:26	LINE CLEAR AVAILED
474	30-Apr-20	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	17:02	17:07	0:04	LINE CLEAR AVAILED
475	1-May-20	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	16:14	18:02	1:48	LINE CLEAR AVAILED
476	1-May-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	13:30	13:33	0:03	TRANSFORMER FAULT
477	1-May-20	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	KAVALWAD_110	18:28(30.4.20)	18:25	23:56 hrs	LINE CLEAR AVAILED
478	1-May-20	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	KAVALWAD_110	18:28(30.4.20)	18:25	23:56 hrs	LINE CLEAR AVAILED
479	1-May-20	BAGALKOT	110	CHIKKODI220-SNKESHWAR	SANKESHWAR_110, HUKKERI_110	23:40(30.4.20)	0:19	0:39	LINE CLEAR AVAILED
480	1-May-20	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	7:45	20:30	12:45	LINE CLEAR AVAILED
481	1-May-20	BAGALKOT	110	HATTARGI-HUKKERI	HATTARGI_110	21:38	23:59	2:21	LINE CLEAR AVAILED
482	1-May-20	BAGALKOT	110	HIDIKAL-ITANAL	HIDIKAL_110	13:46	19:15	5:29	LINE CLEAR AVAILED
483	1-May-20	BAGALKOT	110	NARENDRA-KUD DHARWAD	KUD DHARWAD_110	13:41	17:13	3:32	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
484	1-May-20	BAGALKOT	110	TARIHAL-TADASINAKOPPA	TADASINAKOPPA_110	13:15	13:27	0:12	HAND TRIPPED
485	1-May-20	BAGALKOT	110	TARIHAL-TADASINAKOPPA	TADASINAKOPPA_110	17:28	17:31	0:03	HAND TRIPPED
486	1-May-20	BAGALKOT	220	BALLIGAVI(SHIROLKOPPA)-RANEENNUR	RANEENNUR_220	9:34	23:59	14:25	LINE CLEAR AVAILED
487	1-May-20	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	19:09(30.4.20)	9:34	13:05	LINE CLEAR AVAILED
488	1-May-20	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	18:41(30.4.20)	14:18	19:36	LINE CLEAR AVAILED
489	1-May-20	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	18:41(30.4.20)	14:18	19:36	LINE CLEAR AVAILED
490	1-May-20	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	19:05(30.4.20)	14:20	18:29	LINE CLEAR AVAILED
491	1-May-20	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	19:05(30.4.20)	14:20	18:29	LINE CLEAR AVAILED
492	1-May-20	BENGALURU	66	ALUR - NEMMANGALA 66	ALUR	18:48	18:55	0:07	LOAD CHANGE OVER
493	1-May-20	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	7:09	7:47	0:38	HAND TRIPPED
494	1-May-20	BENGALURU	66	HV1	RAJANUKUNTE	13:25	13:49	0:24	TRANSFORMER FAULT
495	1-May-20	BENGALURU	66	HV2	DEVARABISANAHALLI	16:41	17:05	0:24	LINE CLEAR AVAILED
496	1-May-20	BENGALURU	66	HV2	BAGEPALLI	17:13	17:29	0:16	LINE CLEAR AVAILED
497	1-May-20	BENGALURU	66	HV2	NG HULKUR	18:45	19:02	0:17	TRANSFORMER FAULT
498	1-May-20	BENGALURU	66	HV2	WEL CAST STEEL	11:54	12:17	0:22	LINE CLEAR AVAILED
499	1-May-20	BENGALURU	66	KORAMANGALA 220 - AUSTIN TOWN	NO STATION AFFECTED	7:16	7:51	0:35	LINE FAULT
500	1-May-20	BENGALURU	66	KUMBALAGODU -SOMANAHALLI 220	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	10:40	10:45	0:05	LOAD CHANGE OVER
501	1-May-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	17:21	17:37	0:15	LINE FAULT
502	1-May-20	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	17:17	17:19	0:02	LOAD CHANGE OVER
503	1-May-20	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	18:54	18:56	0:01	LOAD CHANGE OVER
504	1-May-20	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	14:40	16:11	1:31	LINE CLEAR AVAILED
505	1-May-20	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	14:40	16:11	1:31	LINE CLEAR AVAILED
506	1-May-20	BENGALURU	66	NRS 220 - NANDINI LAYOUT	NO STATION AFFECTED	14:40	16:11	1:31	LINE CLEAR AVAILED
507	1-May-20	BENGALURU	66	NRS 220 - SRS 2	NO STATION AFFECTED	14:40	16:11	1:31	LINE CLEAR AVAILED
508	1-May-20	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1 & 2	TELECOM LAYOUT	14:40	16:11	1:31	LINE CLEAR AVAILED
509	1-May-20	BENGALURU	66	NRS 220 - VIJAY NGR MY2	VIJAYANAGARA	14:40	16:11	1:31	LINE CLEAR AVAILED
510	1-May-20	BENGALURU	66	SRS PEENYA 220 - DG2	MALUR, NEMMANGALA, BIEC	17:15	17:27	0:12	LINE FAULT
511	1-May-20	BENGALURU	66	SRS PEENYA 220 - DG2	NO STATION AFFECTED	17:27	18:40	1:13	LINE FAULT
512	1-May-20	BENGALURU	220	HV1	NRS 220	14:40	16:11	1:31	LINE CLEAR AVAILED
513	1-May-20	BENGALURU	220	HV2	NRS 220	14:40	16:11	1:31	LINE CLEAR AVAILED
514	1-May-20	GULBARGA	66	HV2	TAMBRAHALLI_66	10:05	11:40	1:35	TRANSFORMER FAULT
515	1-May-20	GULBARGA	110	HV1, HV2	GULBARGASOUTH_110	20:25	21:40	1:15	TRANSFORMER FAULT
516	1-May-20	GULBARGA	110	HV2	MANVI_110	11:23	13:04	1:41	LINE CLEAR AVAILED
517	1-May-20	GULBARGA	110	HV2	DEODURGA_110	18:15	18:40	0:25	TRANSFORMER FAULT
518	1-May-20	GULBARGA	110	HV3	SHORAPUR_110	19:45	19:50	0:05	TRANSFORMER FAULT
519	1-May-20	GULBARGA	110	HV4	SHORAPUR_110	18:48	18:53	0:05	TRANSFORMER FAULT
520	1-May-20	GULBARGA	110	KAPNOOR-GULBARGAWEST	GULBARGAWEST_110,GULBARGASOUTH_110	20:09	2:45	6:45	LINE FAULT
521	1-May-20	GULBARGA	110	MALLAT-BYAGAWAT2	MANVI_110, MADALAPUR_110	11:36	12:52	1:16	LINE CLEAR AVAILED
522	1-May-20	GULBARGA	110	SINDHANOOR220-RAICHUR1	SINDHANOOR_110	18:35	23:59	5:24	LINE FAULT
523	1-May-20	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPUR_110	16:05	16:15	0:10	LINE CLEAR AVAILED
524	1-May-20	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPUR_110	23:54	23:59	0:05	LINE FAULT
525	1-May-20	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	12:30	12:50	0:20	MAIN SUPPLY FAILURE
526	1-May-20	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	13:25	14:02	0:37	MAIN SUPPLY FAILURE
527	1-May-20	GULBARGA	220	HV1	KUSTAGI_220	11:30	12:05	0:35	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
528	1-May-20	GULBARGA	220	HV1	KUSTAGI_220	12:20	12:45	0:25	TRANSFORMER FAULT
529	1-May-20	GULBARGA	220	HV1	KUSTAGI_220	13:15	13:45	0:30	TRANSFORMER FAULT
530	1-May-20	GULBARGA	220	HV1	SIDHANOOR_220	18:35	19:05	0:30	TRANSFORMER FAULT
531	1-May-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15			LINE FAULT
532	1-May-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15			LINE FAULT
533	1-May-20	GULBARGA	220	RAICHUR-JURALA1	LINE IDLE	22:55	23:59	1:04	LINE FAULT
534	1-May-20	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:40	14:20	2:40	LINE CLEAR AVAILED
535	1-May-20	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	11:37	14:13	2:36	LINE CLEAR AVAILED
536	1-May-20	HASSAN	66	HV2	UDAYAPURA_66	21:12	21:37	0:25	LINE CLEAR AVAILED
537	1-May-20	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGARA_66	11:08	11:16	0:08	LINE FAULT
538	1-May-20	HASSAN	110	ANANDA-SHIMOGA	ANANDPURA_110	12:29	13:15	0:46	LINE CLEAR AVAILED
539	1-May-20	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	16:59	17:32	0:33	MAIN SUPPLY FAILURE
540	1-May-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	16:59	17:47	0:48	MAIN SUPPLY FAILURE
541	1-May-20	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	17:00	19:27	2:27	MAIN SUPPLY FAILURE
542	1-May-20	HASSAN	110	HV1	KEMAR_220	1:56	13:18	11:22	TRANSFORMER FAULT
543	1-May-20	HASSAN	110	HV1	SHIVAPURA_110	17:33	18:16	0:43	LINE CLEAR AVAILED
544	1-May-20	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	16:58	17:32	0:34	LINE FAULT
545	1-May-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	16:58	17:46	0:48	LINE FAULT
546	1-May-20	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	17:42	19:09	1:27	LINE FAULT
547	1-May-20	HASSAN	110	MRSSHM-SS2	MRSMSG_220	12:29	13:14	0:45	LINE CLEAR AVAILED
548	1-May-20	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	18:38	12:55	18:14	LINE FAULT
549	1-May-20	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	19:46	19:49	0:03	LINE FAULT
550	1-May-20	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	19:46	19:49	0:03	LINE FAULT
551	1-May-20	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	19:49	14:20	18:03	LINE FAULT
552	1-May-20	MYSORE	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS	18:52	19:09	0:17	LINE FAULT
553	1-May-20	MYSORE	66	DK MAIDANA-KADAKOLA	DKMAIDANA_66	18:52	19:10	0:18	LINE FAULT
554	1-May-20	MYSORE	66	HOOTAGALLI-HEBBAL	HEBBAL_66 METAGALLY_66 SRIRANGAPATNA_66	11:47	23:59	12:11	LINE FAULT
555	1-May-20	MYSORE	66	HOOTAGALLI-RBI	NO STATIONS	11:47	23:59	12:11	LINE FAULT
556	1-May-20	MYSORE	66	HV2	BETTADHAPURA_66	17:39	18:03	0:23	LINE CLEAR AVAILED
557	1-May-20	MYSORE	66	HV2	HOOTAGALLY_220	11:47	13:45	1:57	TRANSFORMER FAULT
558	1-May-20	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66,	23:39	23:44	0:04	LINE FAULT
559	1-May-20	MYSORE	66	MEGHALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 TNARASIPURA_66 VYASRAJPURA_66	5:58	6:08	0:09	LINE FAULT
560	1-May-20	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	6:27	6:32	0:05	LINE FAULT
561	1-May-20	MYSORE	66	VAJMANGALA-MEGHALAPURA	NO STATIONS	11:41	11:46	0:05	LINE FAULT
562	1-May-20	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	6:41	7:01	0:20	LINE FAULT
563	1-May-20	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	12:06	12:12	0:06	LINE FAULT
564	1-May-20	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	12:21	12:41	0:20	HAND TRIPPED
565	1-May-20	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	15:01	16:03	1:01	LINE CLEAR AVAILED
566	1-May-20	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	12:21	12:41	0:20	HAND TRIPPED
567	1-May-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:41	14:54	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
568	1-May-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:21	12:41	0:20	HAND TRIPPED
569	1-May-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	17:29	17:36	0:06	LINE FAULT
570	1-May-20	TUMKUR	66	HIREGUNTANUR- CHITRADURGA	HIREGUNTANUR_66	9:47	9:49	0:02	LINE CLEAR AVAILED
571	1-May-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	12:00	12:07	0:07	LINE FAULT
572	1-May-20	TUMKUR	66	TR-2	HALUVAGALU_66	2:17	2:21	0:03	TRANSFORMER FAULT
573	1-May-20	TUMKUR	66	TR-2	HIREGUNTANUR_66	9:30	9:51	0:21	LINE CLEAR AVAILED
574	1-May-20	TUMKUR	110	DODDAGUNI- SAMPIGE	SAMPIGE_110	10:59	12:11	1:11	LINE CLEAR AVAILED
575	1-May-20	TUMKUR	110	NITTUR 220KV- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	11:03	12:06	1:03	LINE CLEAR AVAILED
576	2-May-20	BAGALKOT	110	110/11KV, HV1	SIRSI_220	10:43	16:25	5:42	LINE CLEAR AVAILED
577	2-May-20	BAGALKOT	110	110/11KV, HV2	MUDDEBIHAL_110	17:48	17:55	0:06	TRANSFORMER FAULT
578	2-May-20	BAGALKOT	110	110/11KV, HV2	MRUTHYUNJAY NAGAR_110	16:11	16:21	0:10	TRANSFORMER FAULT
579	2-May-20	BAGALKOT	110	110/11KV,HV1	BABALESHWAR_110	15:09	16:09	1:00	LINE CLEAR AVAILED
580	2-May-20	BAGALKOT	110	110/33KV,HV 2	ANKOLA_110&SEA BIRD_33,MASTIKATTA_33	19:07	19:45	0:38	TRANSFORMER FAULT
581	2-May-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	1:11	11:15	0:04	TRANSFORMER FAULT
582	2-May-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	14:41	14:44	0:04	TRANSFORMER FAULT
583	2-May-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	21:09	21:15	0:06	TRANSFORMER FAULT
584	2-May-20	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	KAVALWAD_110	16:36	16:43	0:06	HAND TRIPPED
585	2-May-20	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	KAVALWAD_110	18:08	18:20	0:13	LINE FAULT
586	2-May-20	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110, HUKKERI_110	11:46(30.4.20)	12:56	36.3 hrs	LINE CLEAR AVAILED
587	2-May-20	BAGALKOT	110	HATTARAGI-HUKKERI	HATTARAGI_110	21:38(1.5.20)	7:25	9:47 hrs	LINE CLEAR AVAILED
588	2-May-20	BAGALKOT	110	HUBLI-KADANKOPPA	KADANKOPPA_110	16:56	20:15	3:20	LINE FAULT
589	2-May-20	BAGALKOT	110	HUBLI-KALGHATAGI	KALGHATAGI_110	16:20	20:30	4:11	LINE FAULT
590	2-May-20	BAGALKOT	110	KN SOLAR-MUDDEBIHAL	MUDDEBIHAL_110	16:16			LINE CLEAR AVAILED
591	2-May-20	BAGALKOT	110	MAHALINGAPUR- TERDAL	TERDAL_110	2:48	3:04	0:15	LINE FAULT
592	2-May-20	BAGALKOT	110	SHIVASAGAR SUGARS- SALAHALLI	SALAHALLI_110	20:24			LINE CLEAR AVAILED
593	2-May-20	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_110	10:36	18:56	8:19	LINE CLEAR AVAILED
594	2-May-20	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	10:41	18:54	8:14	LINE CLEAR AVAILED
595	2-May-20	BAGALKOT	110	UMMACHAGI-SIRSI	UMMACHAGI_110	10:27	20:08	9:42	LINE CLEAR AVAILED
596	2-May-20	BAGALKOT	220	220/110KV,HV1&LV1	SIRSI_220	11:35	18:29	6:54	LINE CLEAR AVAILED
597	2-May-20	BAGALKOT	220	BIDNAL-HAVERI	BIDNAL_220	10:54	14:01	3:06	NFBC ISSUED
598	2-May-20	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	16:59	23:33	6:33	LINE FAULT
599	2-May-20	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	15:47	18:06	2:19	LINE FAULT
600	2-May-20	BAGALKOT	220	HAVERI-BIDNAL	HAVERI_220	10:54	13:59	3:04	LINE CLEAR AVAILED
601	2-May-20	BAGALKOT	220	HAVERI-NARENDRA	HAVERI_220	16:45			LINE FAULT
602	2-May-20	BAGALKOT	220	HAVERI-NARENDRA	HAVERI_220	11:30	13:27	1:57	LINE CLEAR AVAILED
603	2-May-20	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	10:30	17:51	7:21	LINE CLEAR AVAILED
604	2-May-20	BENGALURU	66	HV2	SUBRAMANYAPURA 66	21:28	21:59	0:30	TRANSFORMER FAULT
605	2-May-20	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	11:03	14:30	3:27	MAIN SUPPLY FAILURE
606	2-May-20	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	7:37	7:48	0:11	LINE FAULT
607	2-May-20	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	NO STATION AFFECTED	7:37	13:08	5:31	LINE FAULT
608	2-May-20	GULBARGA	66	HV2	HAGARIBOMMANAHALLI_66	23:30			TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
609	2-May-20	GULBARGA	110	HV1	SHAHAPUR_220	19:59	20:06	0:07	TRANSFORMER FAULT
610	2-May-20	GULBARGA	110	HV1	SHAHAPUR_220	21:28	21:35	0:07	TRANSFORMER FAULT
611	2-May-20	GULBARGA	110	HV3	BEVOOR_110	23:55			TRANSFORMER FAULT
612	2-May-20	GULBARGA	110	SHAHBAD-BAGEWADI1	MANDEWAL_110,MORATGI_110,DEVANGOAN_110,AFZALPUR_110, KARAJGI_110	14:20	14:38	0:18	LINE FAULT
613	2-May-20	GULBARGA	110	SHAHBAD-BAGEWADI1	MANDEWAL_110,MORATGI_110,DEVANGOAN_110,AFZALPUR_110, KARAJGI_110	16:03	16:19	0:16	LINE FAULT
614	2-May-20	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110, HUNSAGI_110, ASKI_110	15:23	15:34	0:11	LINE FAULT
615	2-May-20	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110	18:53	19:02	0:09	LINE FAULT
616	2-May-20	GULBARGA	110	SHAHPUR-YADGIR	YADGIR110	17:15	17:28	0:13	LINE FAULT
617	2-May-20	GULBARGA	110	SINDHANOOR220-RAICHUR1	SINDHANOOR_110	18:35(1.5.20)	12:00	17.24 hrs	LINE FAULT
618	2-May-20	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPUR_110	23:54(1.5.20)	0:04	0:04	LINE FAULT
619	2-May-20	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SIDHANOOR_220	1:22	1:32	0:10	LINE FAULT
620	2-May-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.20)			LINE FAULT
621	2-May-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.20)			LINE FAULT
622	2-May-20	GULBARGA	220	RAICHUR-JURALA1	LINE IDLE	22:55(1.5.20)	9:53	10:57 hrs	LINE FAULT
623	2-May-20	HASSAN	66	HASSN22-ARKD2	HASSAN_220	2:35	3:15	0:40	LINE CLEAR AVAILED
624	2-May-20	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	20:01	21:13	1:12	MAIN SUPPLY FAILURE
625	2-May-20	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	20:01	21:01	1:00	MAIN SUPPLY FAILURE
626	2-May-20	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	20:01	21:32	1:31	MAIN SUPPLY FAILURE
627	2-May-20	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	21:32			LINE CLEAR AVAILED
628	2-May-20	HASSAN	110	HV1	KONAJE_110	9:56	9:59	0:03	TRANSFORMER FAULT
629	2-May-20	HASSAN	110	HV2	KONAJE_110	9:56	9:59	0:03	TRANSFORMER FAULT
630	2-May-20	HASSAN	110	HV3	GURUVAYANAKERE_110	21:18	22:42	1:24	TRANSFORMER FAULT
631	2-May-20	HASSAN	110	HV3	KONAJE_110	9:56	9:59	0:03	TRANSFORMER FAULT
632	2-May-20	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	19:59	20:57	0:58	LINE CLEAR AVAILED
633	2-May-20	HASSAN	110	KEMAR-Manipal1	KEMAR_220	19:53	21:05	1:12	LINE CLEAR AVAILED
634	2-May-20	HASSAN	110	KEMAR-Manipal2	KEMAR_220	19:53	21:05	1:12	LINE CLEAR AVAILED
635	2-May-20	HASSAN	110	MADHUV-HIRIYADKA	MADHUVANA_110	20:00			LINE CLEAR AVAILED
636	2-May-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	19:54	21:08	1:14	MAIN SUPPLY FAILURE
637	2-May-20	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	19:54	21:00	1:06	MAIN SUPPLY FAILURE
638	2-May-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	19:54	21:06	1:12	LINE CLEAR AVAILED
639	2-May-20	HASSAN	110	MANIPAL-KEMAR2	MANIPAL_110	19:54	21:06	1:12	MAIN SUPPLY FAILURE
640	2-May-20	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	9:54	12:02	2:08	LINE CLEAR AVAILED
641	2-May-20	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	9:59	12:23	2:24	LINE CLEAR AVAILED
642	2-May-20	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	12:29	14:17	1:48	LINE CLEAR AVAILED
643	2-May-20	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	15:51	16:35	0:44	LINE CLEAR AVAILED
644	2-May-20	MYSORE	66	HEBBANI-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66	18:45	19:02	0:17	LINE FAULT
645	2-May-20	MYSORE	66	HEBBANI-VADKEPURA	VADKEPURA_66	18:45	19:06	0:21	LINE FAULT
646	2-May-20	MYSORE	66	HOOTAGALLY-RBI	NO STATIONS	11:46	16:02	4:16	LINE FAULT
647	2-May-20	MYSORE	66	HOOTAGALLY-VIKRANTH	NO STATIONS	11:46	15:40	3:54	LINE FAULT
648	2-May-20	MYSORE	66	HV1	GAMANAHALLY_66	9:58	11:21	1:23	TRANSFORMER FAULT
649	2-May-20	MYSORE	66	HV1	KOPPA_66	10:25	11:45	1:20	LINE CLEAR AVAILED
650	2-May-20	MYSORE	66	HV1	KIRUGAVALU_66	10:50	12:45	1:55	LINE CLEAR AVAILED
651	2-May-20	MYSORE	66	HV1	ARAKERE_66	13:45	14:05	0:20	TRANSFORMER FAULT
652	2-May-20	MYSORE	66	HV4	SFCSHIVA_66	8:55	9:05	0:10	HAND TRIPPED
653	2-May-20	MYSORE	66	HV4	SFCSHIVA_66	9:47	11:55	2:07	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
654	2-May-20	MYSORE	66	HV5	SFCSHIVA_66	21:59	13:15	15:15	LINE CLEAR AVAILED
655	2-May-20	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66 HAMPAPURA(K)_66 HDKOTE_66 JAIPUR_66	6:23	6:28	0:04	LINE FAULT
656	2-May-20	MYSORE	66	MADHUVANAHALLI-KOLLEGALA 1	NO STATIONS	5:27	5:32	0:05	LINE FAULT
657	2-May-20	MYSORE	66	SATHEGALA-HEBBANI	NO STATIONS	0:07	0:30	0:23	LINE FAULT
658	2-May-20	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 TARIPURA_66 GAMANAHALLY_66	9:47	9:53	0:06	LINE FAULT
659	2-May-20	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 TARIPURA_66 GAMANAHALLY_66	9:57	10:03	0:06	LINE FAULT
660	2-May-20	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 TARIPURA_66 GAMANAHALLY_66	11:19	11:24	0:04	LINE FAULT
661	2-May-20	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	15:45	17:35	1:49	LINE CLEAR AVAILED
662	2-May-20	TUMKUR	66	HANAGAL- THALLAK	HANAGAL_66	16:06	16:12	0:05	LINE FAULT
663	2-May-20	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	16:06	16:32	0:25	LINE FAULT
664	2-May-20	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66	11:01	11:10	0:08	LINE FAULT
665	2-May-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	14:40	14:51	0:10	LINE FAULT
666	2-May-20	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	12:53	13:18	0:24	LINE CLEAR AVAILED
667	2-May-20	TUMKUR	66	TR-1	CHITRADURGA_66	18:39	19:06	0:27	TRANSFORMER FAULT
668	2-May-20	TUMKUR	66	TR-1	PANDARAHALLI_66	22:13	22:30	0:17	HAND TRIPPED
669	2-May-20	TUMKUR	66	TR-1	PANDARAHALLI_66	20:11	21:10	0:58	HAND TRIPPED
670	2-May-20	TUMKUR	66	TR-1	LINGADAHALLI-TMK2_66	9:26	10:05	0:39	LINE CLEAR AVAILED
671	2-May-20	TUMKUR	66	TR-2	HARIYABBE_66	13:07	14:24	1:17	LINE CLEAR AVAILED
672	2-May-20	TUMKUR	66	TR-2	MATHOD_66	16:04	16:13	0:09	TRANSFORMER FAULT
673	2-May-20	TUMKUR	66	TR-2	MATHOD_66	16:32	16:35	0:03	TRANSFORMER FAULT
674	2-May-20	TUMKUR	220	NITTUR 220kv- ARASIKERE	NITTUR_220	14:46	18:11	3:24	LINE CLEAR AVAILED
675	2-May-20	TUMKUR	220	NITTUR 220kv- NELAMANGALA	NITTUR_220	18:13	18:24	0:11	LINE FAULT
676	2-May-20	TUMKUR	220	THALLAK 220kv- HIREMALLANAHOLE 2	THALLAKK_220	17:30	20:22	2:51	LINE FAULT
677	3-May-20	BAGALKOT	110	110/11KV, HV1	NAVANAGAR(H)_110	7:54	8:06	0:13	LINE CLEAR AVAILED
678	3-May-20	BAGALKOT	110	110/11KV, HV2	ITANAL_110	15:26	15:36	0:09	TRANSFORMER FAULT
679	3-May-20	BAGALKOT	110	110/11KV,HV4	GHATAPRABHA_110	14:46	14:48	0:02	TRANSFORMER FAULT
680	3-May-20	BAGALKOT	110	110/33KV,HV 2	ANKOLA_110&SEA BIRD_33,MASTIKATTA_33	18:49	19:18	0:29	TRANSFORMER FAULT
681	3-May-20	BAGALKOT	110	110/33KV,HV3	MAMADAPUR_110,,LINGADALLI_33,DEVAR GENNUR_33	5:33			TRANSFORMER FAULT
682	3-May-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	13:12	13:18	0:06	TRANSFORMER FAULT
683	3-May-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	13:39	13:45	0:06	TRANSFORMER FAULT
684	3-May-20	BAGALKOT	110	110/33KV,HV4	ZALAKI_110&33KV HALASANGI,DHULAKHED,NEVARAGI	21:54	21:58	0:03	TRANSFORMER FAULT
685	3-May-20	BAGALKOT	110	AMBEWADI-NK2 (KAVALWADA)	KAVALWAD_110	14:37	14:42	0:04	HAND TRIPPED
686	3-May-20	BAGALKOT	110	ANKOLA-KUMATA 2	KUMATA_110	17:53	22:30	4:36	LINE FAULT
687	3-May-20	BAGALKOT	110	BELLATTI-ENERCON 2	BELLATTI_110	12:29	13:48	1:18	LINE CLEAR AVAILED
688	3-May-20	BAGALKOT	110	GHATAPRABHA-PG HUNSHYAL	PG HUNSHYAL_110	2:35	3:49	1:14	LINE FAULT
689	3-May-20	BAGALKOT	110	GMNAVAR-SALAHALLI	SALAHALLI_110	10:27	14:55	4:27	LINE CLEAR AVAILED
690	3-May-20	BAGALKOT	110	GOPANAKOPPA-NARAGUND	GOPANAKOPPA_110	19:07			LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
691	3-May-20	BAGALKOT	110	KN SOLAR-MUDDEBIHAL	MUDDEBIHAL_110	16:17(2.5.20)	15:36	22:78 hrs	LINE CLEAR AVAILED
692	3-May-20	BAGALKOT	110	PG HUNSHYAL-MUDALGI	MUDALGI_110, NAGNUR_110	3:49	3:51	0:00	HAND TRIPPED
693	3-May-20	BAGALKOT	110	SATTI SUGARS- PG HUNSHYAL	PG HUNSHYAL_110	3:49	13:32	9:42	LINE CLEAR AVAILED
694	3-May-20	BAGALKOT	110	SHIVASAGAR SUGARS- SALAHALLI	SALAHALLI_110	20:24(2.5.20)	13:03	16:38 hrs	LINE CLEAR AVAILED
695	3-May-20	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	12:33	13:30	0:57	LINE FAULT
696	3-May-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	9:15			LINE FAULT
697	3-May-20	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	18:56			LINE FAULT
698	3-May-20	BAGALKOT	220	BIDNAL-HARTI 2	BIDNAL_220	19:00			LINE FAULT
699	3-May-20	BAGALKOT	220	GADAG-HARTHI 1	GADAG_220	10:53(29.4.20)	19:43	104.5 hrs	LINE CLEAR AVAILED
700	3-May-20	BAGALKOT	220	GADAG-HARTHI 2	GADAG_220	10:53(29.4.20)	20:01	105.07 hrs	LINE CLEAR AVAILED
701	3-May-20	BAGALKOT	220	GADAG-LINGAPUR2(DHONI2)	GADAG_220	18:49			LINE FAULT
702	3-May-20	BAGALKOT	220	HAVERI-BYADAGI	BYADAGI_110	19:47			LINE FAULT
703	3-May-20	BAGALKOT	220	HAVERI-NARENDRA	HAVERI_220	16:46(2.5.20)	0:13	7:26 hrs	LINE CLEAR AVAILED
704	3-May-20	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	15:13	21:13	6:00	LINE FAULT
705	3-May-20	BAGALKOT	220	SHARAVATHY1-SIRSI	SIRSI_220	15:54			LINE CLEAR AVAILED
706	3-May-20	BAGALKOT	220	SHARAVATHY2-SIRSI	SIRSI_220	15:18			LINE FAULT
707	3-May-20	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	11:45(22.4.20)	15:54	268 hrs	LINE CLEAR AVAILED
708	3-May-20	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	11:46(22.4.20)	15:54	268 hrs	LINE CLEAR AVAILED
709	3-May-20	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	21:36	21:40	0:04	LOAD CHANGE OVER
710	3-May-20	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	11:03	11:17	0:14	MAIN SUPPLY FAILURE
711	3-May-20	BENGALURU	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	18:39	18:44	0:05	LINE FAULT
712	3-May-20	BENGALURU	66	HOODY 220 - MANYATHA TECH PARK 220	NO STATION AFFECTED	13:35	16:09	2:34	LINE FAULT
713	3-May-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	14:20	15:00	0:40	LINE FAULT
714	3-May-20	BENGALURU	66	HV1	RR NAGAR	11:03	11:17	0:14	MAIN SUPPLY FAILURE
715	3-May-20	BENGALURU	66	HV1	RR NAGAR	23:04	23:06	0:02	LOAD CHANGE OVER
716	3-May-20	BENGALURU	66	HV1	SIR MV LAYOUT	5:15	10:46	5:31	TRANSFORMER FAULT
717	3-May-20	BENGALURU	66	HV1	KYLANUR	15:30	15:39	0:09	TRANSFORMER FAULT
718	3-May-20	BENGALURU	66	HV1	KYLANUR	18:18	18:29	0:11	TRANSFORMER FAULT
719	3-May-20	BENGALURU	66	HV2	RR NAGAR	11:03	11:18	0:14	MAIN SUPPLY FAILURE
720	3-May-20	BENGALURU	66	HV2	RR NAGAR	23:03	23:06	0:03	LOAD CHANGE OVER
721	3-May-20	BENGALURU	66	HV2	JANGAMAKOTE	17:45	18:17	0:32	LINE CLEAR AVAILED
722	3-May-20	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	11:35	11:55	0:20	LINE CLEAR AVAILED
723	3-May-20	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	7:35	8:30	0:55	LINE FAULT
724	3-May-20	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	14:49	14:58	0:09	LINE FAULT
725	3-May-20	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, SOMAYAJANAHALLI	22:33	22:43	0:10	LINE FAULT
726	3-May-20	BENGALURU	66	LV3	SUBRAMANYAPURA 220	21:25	21:29	0:03	LINE CLEAR AVAILED
727	3-May-20	BENGALURU	66	LV3	SUBRAMANYAPURA 220	11:03	11:51	0:47	TRANSFORMER FAULT
728	3-May-20	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	10:47	10:50	0:02	LOAD CHANGE OVER
729	3-May-20	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	12:42	12:44	0:02	LOAD CHANGE OVER
730	3-May-20	BENGALURU	66	SIDLAGATTA - CHINTAMANI 220	SIDLAGATTA, MELUR	14:11	14:24	0:12	LINE CLEAR AVAILED
731	3-May-20	BENGALURU	66	SOLDEVANAHALLI - SRS PEENYA 220	SOLDEVANAHALLI	12:36	12:40	0:04	LOAD CHANGE OVER
732	3-May-20	BENGALURU	66	SOLDEVANAHALLI - YELAHANKA 220	SOLDEVANAHALLI	10:53	10:58	0:05	LOAD CHANGE OVER
733	3-May-20	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	20:50	20:54	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
734	3-May-20	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	17:08	17:33	0:25	LINE FAULT
735	3-May-20	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	21:40	22:03	0:23	LINE FAULT
736	3-May-20	BENGALURU	220	HV3	SUBRAMANYAPURA 220	11:03	11:49	0:46	TRANSFORMER FAULT
737	3-May-20	GULBARGA	66	HAGARIBOMMANAHALLI-ITTAGI	HAGARIBOMMANAHALLI_66, UPANAYAKANAHALLI_66	23:00	23:05	0:05	MAIN SUPPLY FAILURE
738	3-May-20	GULBARGA	66	HV2	HAGARIBOMMANAHALLI_66	23.30(2.5.20)	7:10	7:39	TRANSFORMER FAULT
739	3-May-20	GULBARGA	66	HV2	HAGARIBOMMANAHALLI_66	10:44	18:20	7:36	LINE CLEAR AVAILED
740	3-May-20	GULBARGA	66	ITTAGI-HAGARIBOMMANAHALLI	HAGARIBOMMANAHALLI_66, UPANAYAKANAHALLI_66	18:00	18:06	0:06	HAND TRIPPED
741	3-May-20	GULBARGA	66	ITTAGI-HAGARIBOMMANAHALLI	HAGARIBOMMANAHALLI_66, UPANAYAKANAHALLI_66	22:58	23:02	0:04	LINE FAULT
742	3-May-20	GULBARGA	66	ITTAGI-SUZLON1_IPP	ITTAGI_220	6:12	6:22	0:10	LINE FAULT
743	3-May-20	GULBARGA	110	HV2	MADIYAL_110	9:20	9:25	0:05	TRANSFORMER FAULT
744	3-May-20	GULBARGA	110	HV3	BEVOOR_110	23:55(2.5.20)	0:15	4:48	TRANSFORMER FAULT
745	3-May-20	GULBARGA	110	HV3	BEVOOR_110	14:53	15:08	0:15	TRANSFORMER FAULT
746	3-May-20	GULBARGA	110	HV3	BEVOOR_110	15:15	15:30	0:15	TRANSFORMER FAULT
747	3-May-20	GULBARGA	110	SHAHBAD-BAGEWADI1	MANDEWAL_110,MORATGI_110,DEVANGOAN_110,AFZALPUR_110, KARAJGI_110	13:24	13:29	0:05	LINE FAULT
748	3-May-20	GULBARGA	110	SHAHBAD-BAGEWADI1	MANDEWAL_110,MORATGI_110,DEVANGOAN_110,AFZALPUR_110, KARAJGI_110	13:50	14:04	0:14	LINE FAULT
749	3-May-20	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110	3:22	3:31	0:09	LINE FAULT
750	3-May-20	GULBARGA	220	HV2	SEDAM_220	18:36	21:12	2:36	TRANSFORMER FAULT
751	3-May-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.20)			LINE FAULT
752	3-May-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.20)			LINE FAULT
753	3-May-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	18:23	20:00	1:37	LINE FAULT
754	3-May-20	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	20:10	20:28	0:18	LINE CLEAR AVAILED
755	3-May-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	17:41	17:55	0:14	LINE CLEAR AVAILED
756	3-May-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	17:57	18:37	0:40	LINE CLEAR AVAILED
757	3-May-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	19:34	20:05	0:31	LINE CLEAR AVAILED
758	3-May-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	20:13	20:37	0:24	LINE CLEAR AVAILED
759	3-May-20	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	14:52	15:07	0:15	LINE CLEAR AVAILED
760	3-May-20	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	21:32(2.5.20)	2:06	4:33	LINE FAULT
761	3-May-20	HASSAN	110	HV1	ESSUR_110	15:38	16:09	0:31	TRANSFORMER FAULT
762	3-May-20	HASSAN	110	HV1	KAVOOR_220	9:40	13:33	3:53	TRANSFORMER FAULT
763	3-May-20	HASSAN	110	HV2	ARASIKERE_110	10:54	12:50	1:56	LINE CLEAR AVAILED
764	3-May-20	HASSAN	110	HV2	ARASIKERE_110	12:48	15:28	2:40	LINE CLEAR AVAILED
765	3-May-20	HASSAN	110	HV2	KEMAR_220	18:15	18:30	0:15	LINE CLEAR AVAILED
766	3-May-20	HASSAN	110	MADHUV-HIRIYADKA	MADHUVANA_110	20:00(2.5.20)	2:10	6:10	LINE FAULT
767	3-May-20	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	18:06	18:45	0:39	LINE CLEAR AVAILED
768	3-May-20	HASSAN	110	MRSSHM-BADRAVATY3	MRSMSG_220	9:16	12:16	3:00	LINE FAULT
769	3-May-20	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	18:21	18:42	0:21	LINE CLEAR AVAILED
770	3-May-20	HASSAN	110	NANDIKU-ISTRIL	NANDIKUR_110	20:06	21:39	1:33	LINE CLEAR AVAILED
771	3-May-20	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	20:06	20:55	0:49	LINE CLEAR AVAILED
772	3-May-20	HASSAN	110	SHIVPU-BIRUR	SHIVPURA_110	18:07	18:38	0:31	LINE CLEAR AVAILED
773	3-May-20	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	17:42	18:38	0:56	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
774	3-May-20	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	3:15			LINE CLEAR AVAILED
775	3-May-20	HASSAN	220	VARAHI-SHMG3	varahi_gen	17:42	18:37	0:55	LINE CLEAR AVAILED
776	3-May-20	MYSORE	66	HV1	K_HONNALGERE_66	20:49	20:56	0:06	HAND TRIPPED
777	3-May-20	MYSORE	66	HV2	K_HONNALGERE_66	20:49	20:56	0:06	HAND TRIPPED
778	3-May-20	MYSORE	66	KADAKOLA-SARGUR 1	DOORA_66 HULLAHALLI_66 HURA_66 CHANDRAVADI_66 ANTHARSANTHE_66 HAMPAPURA(K)_66 HDKOTE_66 JAIPUR_66 SANTHESARAGUR_66	12:28	12:31	0:02	LINE FAULT
779	3-May-20	MYSORE	66	KADAKOLA-SARGUR 2	DOORA_66 HULLAHALLI_66 HURA_66 CHANDRAVADI_66 ANTHARSANTHE_66 HAMPAPURA(K)_66 HDKOTE_66 JAIPUR_66 SANTHESARAGUR_66	12:28	12:31	0:02	LINE FAULT
780	3-May-20	MYSORE	66	KADAKOLA-SARGUR 2	DOORA_66 HULLAHALLI_66 HURA_66 CHANDRAVADI_66	22:09	22:12	0:03	LINE FAULT
781	3-May-20	MYSORE	66	KALAMANDIR-MYSORE SOUTH	NO STATIONS	22:56	23:31	0:35	LINE FAULT
782	3-May-20	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 SOMANAHALLI_66	17:08	17:17	0:09	LINE FAULT
783	3-May-20	MYSORE	66	KM DODDI-MANDYA	KIADBMANDYA_66 MADDUR_66 SOMANAHALLI_66	21:41	21:54	0:13	LINE FAULT
784	3-May-20	MYSORE	66	MADHUVANALLI-KUNTHUR	NO STATIONS	7:48	7:53	0:04	LINE FAULT
785	3-May-20	MYSORE	66	MADHUVANALLI-MAMBALLI	MAMBALLI_66	4:26	4:31	0:05	LINE FAULT
786	3-May-20	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	0:55	1:01	0:05	LINE FAULT
787	3-May-20	MYSORE	66	VAJAMANGALA-JYOTHINAGARA	JYOTHINAGARA_66 DKMAIDANA_66	22:43	22:59	0:16	LINE FAULT
788	3-May-20	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	16:26	16:40	0:14	LINE FAULT
789	3-May-20	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	5:26	10:15	4:48	LINE CLEAR AVAILED
790	3-May-20	TUMKUR	66	TR-1	HANAGAL_66	8:12	9:19	1:07	LINE CLEAR AVAILED
791	3-May-20	TUMKUR	66	TR-1	KUNDUR_66	17:19	17:49	0:30	LINE CLEAR AVAILED
792	3-May-20	TUMKUR	66	TR-1	PANDARAHALLI_66	12:24	12:33	0:09	HAND TRIPPED
793	3-May-20	TUMKUR	66	TR-1	MATHOD_66	11:00	18:25	7:24	LINE CLEAR AVAILED
794	3-May-20	TUMKUR	66	TR-1	LINGADAHALLI_TMK2_66	17:23	19:12	1:49	TRANSFORMER FAULT
795	3-May-20	TUMKUR	66	TR-2	MELKOTE_66	17:14	17:44	0:29	TRANSFORMER FAULT
796	3-May-20	TUMKUR	66	TR-2	MATHOD_66	11:07	11:22	0:15	LINE CLEAR AVAILED
797	4-May-20	BAGALKOT	110	110/11KV, HV2	SHIROL_110	17:26	17:35	0:09	TRANSFORMER FAULT
798	4-May-20	BAGALKOT	110	110/11KV, HV4	MK HUBLI_110	10:15	11:23	1:08	LINE CLEAR AVAILED
799	4-May-20	BAGALKOT	110	110/11KV,HV1	ANAND NAGAR_110	18:59	19:08	0:09	TRANSFORMER FAULT
800	4-May-20	BAGALKOT	110	110/11KV,HV2	AIGALI_110	16:20	16:39	0:19	TRANSFORMER FAULT
801	4-May-20	BAGALKOT	110	110/11KV,HV2	AIGALI_110	18:20	19:19	0:59	TRANSFORMER FAULT
802	4-May-20	BAGALKOT	110	110/11KV,HV2	MAMADAPUR_110	19:08	19:11	0:03	HAND TRIPPED
803	4-May-20	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)	9:27	9:32	0:05	TRANSFORMER FAULT
804	4-May-20	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DHULKED_33, HALSANGI_33	11:18	11:22	0:04	TRANSFORMER FAULT
805	4-May-20	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DHULKED_33, HALSANGI_33	16:28	16:33	0:05	TRANSFORMER FAULT
806	4-May-20	BAGALKOT	110	110/33KV,HV3	MAMADAPUR_110	5:33			TRANSFORMER FAULT
807	4-May-20	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	14:09	14:21	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
808	4-May-20	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR_110	14:09	14:21	0:12	LINE FAULT
809	4-May-20	BAGALKOT	110	GOPPANAKOPPA-NARGUND	GOPPANAKOPPA_110	19:08(3.5.20)	12:19	17:19	LINE CLEAR AVAILED
810	4-May-20	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	19:47(3.5.20)	7:17	11:29	LINE CLEAR AVAILED
811	4-May-20	BAGALKOT	110	JAMKHANDI-SHIROL	SHIROL_110	17:35			LINE CLEAR AVAILED
812	4-May-20	BAGALKOT	110	MAMADPUR-BABALESHWAR	MAMADAPUR_110	14:23	14:33	0:10	LINE FAULT
813	4-May-20	BAGALKOT	110	MANTUR-SHIROL	SHIROL_110	7:44(25.4.20)	17:35	225:05 hrs	LINE CLEAR AVAILED
814	4-May-20	BAGALKOT	110	MKHUBLI220-MK HUBLI	MK HUBLI_110	11:34	15:20	3:46	LINE CLEAR AVAILED
815	4-May-20	BAGALKOT	110	NARENDRA1-BELUR	BELUR_110	10:33	15:05	4:32	LINE CLEAR AVAILED
816	4-May-20	BAGALKOT	110	NARENDRA2-BELUR	BELUR_110	15:09	15:11	0:02	HAND TRIPPED
817	4-May-20	BAGALKOT	110	NARENDRA-BELUR1	BELUR_110	16:23			LINE CLEAR AVAILED
818	4-May-20	BAGALKOT	110	SANKESHWAR-HUKKERI	SANKESHWAR_110	0:54			LINE CLEAR AVAILED
819	4-May-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	9:15			LINE FAULT
820	4-May-20	BAGALKOT	220	BELLIGAVI(SHIROLKOPPA)- RANEBENNUR	RANEBENNUR_220	9:03			LINE CLEAR AVAILED
821	4-May-20	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	18:56			LINE FAULT
822	4-May-20	BAGALKOT	220	BIDNAL-HARTI 2	BIDNAL_220	19:0(3.5.20)	10:15	15:15	LINE CLEAR AVAILED
823	4-May-20	BAGALKOT	220	GADAG -HARTI 1&2	GADAG_220	10:50			LINE CLEAR AVAILED
824	4-May-20	BAGALKOT	220	GADAG-LINGAPUR2(DHONI2)	GADAG_220	18:49			LINE FAULT
825	4-May-20	BAGALKOT	220	GUTTUR-RANEBENNUR	RANEBENNUR_220	16:32(3.5.20)	9:03	16:57	LINE CLEAR AVAILED
826	4-May-20	BAGALKOT	220	HAVERI-GUTTUR1	HAVERI_220	14:19	16:10	1:51	LINE FAULT
827	4-May-20	BAGALKOT	220	SHARAVATHY2-SIRSI	SIRSI_220	15:18(3.5.20)	11:40	20:21	LINE CLEAR AVAILED
828	4-May-20	BENGALURU	66	ANEKAL - ATTIBELE	ATTIBELE	10:55	11:02	0:07	LINE CLEAR AVAILED
829	4-May-20	BENGALURU	66	HV1	JAYANAGARA	13:05	13:08	0:02	LINE CLEAR AVAILED
830	4-May-20	BENGALURU	66	HV1	EDC 220	12:20	12:22	0:02	LINE CLEAR AVAILED
831	4-May-20	BENGALURU	66	HV2	RMV	13:10	13:14	0:03	LINE CLEAR AVAILED
832	4-May-20	BENGALURU	66	HV2	SRIGANDADA KAVALU	8:23	8:37	0:14	TRANSFORMER FAULT
833	4-May-20	BENGALURU	66	KODIGEHALLI - TAVAREKERE	TAVAREKERE	12:33	13:24	0:51	LINE CLEAR AVAILED
834	4-May-20	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:01	13:47	1:46	LINE CLEAR AVAILED
835	4-May-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	13:55	13:59	0:04	LINE FAULT
836	4-May-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	12:01	13:47	1:46	LINE CLEAR AVAILED
837	4-May-20	BENGALURU	220	NELAMANGALA 400 - KB CROSS 220	NO STATION AFFECTED	16:43	21:30	4:47	LINE FAULT
838	4-May-20	GULBARGA	110	HANUMASAGAR-KUSTAGI	HANUMASAGAR-KUSTAGI	16:36	17:26	0:50	MAIN SUPPLY FAILURE
839	4-May-20	GULBARGA	110	HV2	SHAHAPUR_220	10:15	10:55	0:40	TRANSFORMER FAULT
840	4-May-20	GULBARGA	110	HV2	HANUMANAL_110	17:15	17:30	0:15	TRANSFORMER FAULT
841	4-May-20	GULBARGA	110	HV2	HATTI_110	15:04	15:10	0:06	TRANSFORMER FAULT
842	4-May-20	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110	3:15	3:24	0:09	LINE FAULT
843	4-May-20	GULBARGA	110	SINDHANOOR220-MUNIRABAD1	KARATAGI_110, SRNAGAR_110, GANGAVATHI_110, VENKATGIRI_110	12:38	12:53	0:15	LINE FAULT
844	4-May-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.20)			LINE FAULT
845	4-May-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.20)			LINE FAULT
846	4-May-20	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	16:39	17:02	0:23	LINE FAULT
847	4-May-20	GULBARGA	220	LINGAPUR-AARESS STEELS_IPP	AARESS STEELS_IPP	10:28	15:30	5:02	LINE CLEAR AVAILED
848	4-May-20	GULBARGA	400	JSWVL-BTPS	JSWVL_400	3:50	16:58	13:08	LINE FAULT
849	4-May-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	17:45			LINE CLEAR AVAILED
850	4-May-20	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	17:45	21:20	3:35	MAIN SUPPLY FAILURE
851	4-May-20	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	17:45	18:17	0:32	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
852	4-May-20	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	18:17	19:59	1:42	LINE CLEAR AVAILED
853	4-May-20	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	19:59			LINE CLEAR AVAILED
854	4-May-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	9:21	13:18	3:57	LINE FAULT
855	4-May-20	HASSAN	110	HV2	KADUR_220	16:30	18:56	2:26	TRANSFORMER FAULT
856	4-May-20	HASSAN	110	KADUR-AJAMPURA	KADUR_220	16:30	18:56	2:26	LINE FAULT
857	4-May-20	HASSAN	110	KADUR-NERELEKERE	KADUR_220	16:30	18:56	2:26	LINE FAULT
858	4-May-20	HASSAN	110	KADUR-NGNHL	KADUR_220	16:30	18:56	2:26	LINE FAULT
859	4-May-20	HASSAN	110	KADUR-TNGL	KADUR_220	16:30	18:56	2:26	LINE FAULT
860	4-May-20	HASSAN	110	KADUR-YGTI	KADUR_220	16:30	18:56	2:26	LINE FAULT
861	4-May-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	9:21	13:18	3:57	LINE FAULT
862	4-May-20	HASSAN	110	LV1	KADUR_220	16:30	18:56	2:26	TRANSFORMER FAULT
863	4-May-20	HASSAN	110	LV2	KADUR_220	16:30	18:56	2:26	TRANSFORMER FAULT
864	4-May-20	HASSAN	110	MANIAPAL-HIRIYADKA	MANIPAL_110	13:04	13:29	0:25	LINE FAULT
865	4-May-20	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	18:03	20:59	2:56	LINE CLEAR AVAILED
866	4-May-20	HASSAN	110	NANDIKU-ISTRIL	NANDIKUR_110	10:00	12:36	2:36	LINE FAULT
867	4-May-20	HASSAN	110	SHIVAPU-BIRUR	SHIVPURA_110	11:40	12:13	0:33	LINE FAULT
868	4-May-20	HASSAN	220	HV1	KADUR_220	16:30	18:56	2:26	TRANSFORMER FAULT
869	4-May-20	HASSAN	220	HV2	KADUR_220	16:30	18:56	2:26	TRANSFORMER FAULT
870	4-May-20	HASSAN	220	KADUR-DABUSET	KADUR_220	16:30	18:56	2:26	LINE CLEAR AVAILED
871	4-May-20	HASSAN	220	KADUR-SHIMOGA	KADUR_220	16:30	18:56	2:26	LINE CLEAR AVAILED
872	4-May-20	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	17:37	18:40	1:03	LINE CLEAR AVAILED
873	4-May-20	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	18:30	21:32	3:02	LINE FAULT
874	4-May-20	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	3:15(3.5.20)			LINE CLEAR AVAILED
875	4-May-20	HASSAN	220	VARAH1-SHMG3	varahi_gen	18:34	21:32	2:58	LINE FAULT
876	4-May-20	MYSORE	66	HV2	DEVANOORNGUDU_66	20:49	20:54	0:05	TRANSFORMER FAULT
877	4-May-20	MYSORE	66	HV2	DEVANOORNGUDU_66	21:24	21:40	0:15	TRANSFORMER FAULT
878	4-May-20	MYSORE	66	HV2	KIADBMANDYA_66	17:01	18:59	1:58	LINE CLEAR AVAILED
879	4-May-20	MYSORE	66	HV2	SFCSHIVA_66	15:15	15:55	0:39	LINE CLEAR AVAILED
880	4-May-20	MYSORE	66	MADHUVANAHALLY-KUNTHUR	NO STATIONS	6:27	6:32	0:05	LINE FAULT
881	4-May-20	MYSORE	66	METAGALLY-VIKRANTH	NO STATIONS	9:30	10:25	0:55	LINE CLEAR AVAILED
882	4-May-20	MYSORE	66	METAGALLY-VIKRANTH	NO STATIONS	17:49	17:52	0:02	HAND TRIPPED
883	4-May-20	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	5:13	11:12	5:59	LINE CLEAR AVAILED
884	4-May-20	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	3:56	4:06	0:09	LINE FAULT
885	4-May-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	12:48	13:00	0:12	LINE FAULT
886	4-May-20	TUMKUR	66	HONNALLI 220KV- NALLUR	NALLUR_66	10:23	10:34	0:11	LINE FAULT
887	4-May-20	TUMKUR	66	HONNALLI 220KV- NALLUR	NALLUR_66	16:43	17:14	0:31	LINE FAULT
888	4-May-20	TUMKUR	66	TR-1	CHALLAKERE_66	17:21	17:31	0:10	TRANSFORMER FAULT
889	4-May-20	TUMKUR	66	TR-1	CHANNAGIRI_66	9:15	9:27	0:11	TRANSFORMER FAULT
890	4-May-20	TUMKUR	110	NITTUR 220KV- KADABA	KADABA_110	17:55	18:08	0:13	HAND TRIPPED
891	4-May-20	TUMKUR	110	NITTUR 220KV- KALLUR	KALLUR_110	17:55	18:08	0:13	HAND TRIPPED
892	4-May-20	TUMKUR	220	GUTTUR 400KV- HAVERI 1	GUTUR_400	14:19	16:11	1:51	LINE FAULT
893	4-May-20	TUMKUR	220	NITTUR 220KV- NELAMANGALA	NITTUR_220	17:54	22:05	4:10	LINE FAULT
894	4-May-20	TUMKUR	400	GUTTUR 400KV- KAIGA 2	GUTUR_400	9:45	15:26	5:41	LINE CLEAR AVAILED