

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 08.02.2022 TO 14.02.2022

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	8-Feb-2022	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)	16:35 (08.02.2022)	8382:24hrs	LINE CHARGED
2	8-Feb-2022	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
3	8-Feb-2022	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
4	8-Feb-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
5	8-Feb-2022	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
6	8-Feb-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
7	8-Feb-2022	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)			LOAD CURTAILMENT
8	8-Feb-2022	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)			LOAD CURTAILMENT
9	8-Feb-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN,LINE FAULT
10	8-Feb-2022	BAGALKOT	110	110/11KV,HV2	BABALESHWAR_110	9:05 (07.02.2022)	19:27 (08.02.2022)	34:22hrs	TRANSFORMER CHARGED
11	8-Feb-2022	BAGALKOT	110	110/11KV,HV1&2	ANKALI_110	10:00	16:47	6:47	LINE CLEAR AVAILED
12	8-Feb-2022	BAGALKOT	110	110/11KV,HV2	BEDI_110	11:30	13:50	2:20	LINE CLEAR AVAILED
13	8-Feb-2022	BAGALKOT	110	110/11KV,HV1	GOKAK_110	15:49	17:04	1:15	LINE CLEAR AVAILED
14	8-Feb-2022	BAGALKOT	110	110/11KV,HV1	HIREKERUR_110	15:16	17:56	2:40	LINE CLEAR AVAILED
15	8-Feb-2022	BAGALKOT	110	INDI-HIREMASALI	HIREMASALI_110	19:24	19:33	0:09	LINE FAULT
16	8-Feb-2022	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110 &ALNAVAR,VIDYAGIRI_33& RAYAPUR_33	21:08	21:29	0:21	TRANSFORMER FAULT
17	8-Feb-2022	BAGALKOT	110	110/11KV,HV1	MANTUR(G)	13:00	13:11	0:11	TRANSFORMER FAULT
18	8-Feb-2022	BAGALKOT	110	110/11KV,HV1	MANTUR(G)	13:00	13:15	0:15	TRANSFORMER FAULT
19	8-Feb-2022	BAGALKOT	110	110/11KV,HV1&2	NAVANAGAR(B)_110	9:03	9:26	0:23	LINE CLEAR AVAILED
20	8-Feb-2022	BAGALKOT	110	110/33KV,HV2	SAVALAGI_110 &HIREPADASALGI LIS,KALABILAGI&TUNGAL_33	10:24	17:20	6:56	LINE CLEAR AVAILED
21	8-Feb-2022	BAGALKOT	110	UTTUR-JAMBAGI	JAMBAGI_110	6:38	7:01	0:23	LINE FAULT
22	8-Feb-2022	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	11:37	13:05	1:28	LINE CLEAR AVAILED
23	8-Feb-2022	BAGALKOT	220	HUBLI-NARENDRA1	STATION NOT AFFECTED HUBLI_220	11:11	15:24	4:13	LINE CLEAR AVAILED
24	8-Feb-2022	BAGALKOT	110	CHIKODI220-ANKALI	ANKALI_110	10:25	13:16	2:51	LINE CLEAR AVAILED
25	8-Feb-2022	BAGALKOT	110	AMBEWADI220- NK-1 (KAWALWADA)	STATION NOT AFFECTED AMBEWADI_220	10:25 (04.02.2022)			LINE OPEN,LINE CLEAR AVAILED
26	8-Feb-2022	BAGALKOT	110	AMBEWADI220- NK-2 (HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	10:28 (04.02.2022)			LINE OPEN,LINE CLEAR AVAILED
27	8-Feb-2022	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 1	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)	16:35 (08.02.2022)	8382:24hrs	LINE CHARGED
28	8-Feb-2022	BAGALKOT	110	110/11KV,HV3	UDYAMBAG_110	9:35	13:20	3:45	TRANSFORMER FAULT
29	8-Feb-2022	BAGALKOT	110	110/33KV,HV4	UDYAMBAG_110, RM1_33,RM2_33	11:00	17:00	6:00	LINE CLEAR AVAILED
30	8-Feb-2022	BAGALKOT	110	MUNDARAGI-SINGATALUR	MUNDARGI_110,SINGATALUR _110	20:10	22:00	1:50	LINE CLEAR AVAILED
31	8-Feb-2022	BAGALKOT	110	MK HUBLI-BIDI	MK HUBLI_220	13:33	13:41	0:08	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
32	8-Feb-2022	BAGALKOT	110	110/33KV,HV3	ANKALI_110 NANDIKURALI_33	10:25	16:45	6:20	LINE CLEAR AVAILED
33	8-Feb-2022	BAGALKOT	110	110/33KV,HV4	ANKALI_110 KOTAWADI_33,SHIRAGUPPI_33	10:25	16:45	6:20	LINE CLEAR AVAILED
34	8-Feb-2022	BAGALKOT	110	INDI-DEVAR HIPPARAGI	DEVAR HIPPARAGI_110,ATHARGA_110, HIREMASALI_110	19:25	19:32	0:07	LINE FAULT
35	8-Feb-2022	BAGALKOT	110	SHIRAGUPPI-VAJRAMATTI	SHIRAGUPPI_110	6:45	6:50	0:05	LINE FAULT
36	8-Feb-2022	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110,GIRISAGAR_110, OLAMATTI_110,BISNAL_110	6:45	7:05	0:20	LINE FAULT
37	8-Feb-2022	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	10:18	10:35	0:17	MAIN SUPPLY FAILURE
38	8-Feb-2022	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	12:51	12:56	0:05	LOAD CHANGE OVER
39	8-Feb-2022	BENGALURU	66	NRS 220 - REMCO MYS 1	VIJAYANAGARA	7:31	8:03	0:32	LINE FAULT
40	8-Feb-2022	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	9:10	9:16	0:06	LOAD CHANGE OVER
41	8-Feb-2022	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	15:45	15:50	0:05	LOAD CHANGE OVER
42	8-Feb-2022	BENGALURU	66	SRS PEENYA 220 - NRS 1	NANDINI LAYOUT	10:18	10:35	0:17	LINE FAULT
43	8-Feb-2022	BENGALURU	66	HV1	VIJAYANAGARA	10:00	16:37	6:37	LINE CLEAR AVAILED
44	8-Feb-2022	BENGALURU	66	HV2	VIJAYANAGARA	10:00	16:39	6:39	LINE CLEAR AVAILED
45	8-Feb-2022	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	14:08	14:12	0:04	LOAD CHANGE OVER
46	8-Feb-2022	BENGALURU	66	HBR LAYOUT - HEBBALA 220	HBR LAYOUT	16:01	16:04	0:03	LOAD CHANGE OVER
47	8-Feb-2022	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	6:05	6:13	0:07	LINE FAULT
48	8-Feb-2022	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	6:56	7:06	0:09	LINE FAULT
49	8-Feb-2022	BENGALURU	66	HV1	MALLASANDRA	10:50	11:05	0:14	LINE CLEAR AVAILED
50	8-Feb-2022	BENGALURU	66	HV2	MAASTI	11:56	12:03	0:07	TRANSFORMER FAULT
51	8-Feb-2022	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPETE	7:52	8:09	0:17	LOAD CURTAILMENT
52	8-Feb-2022	BENGALURU	66	HV1	KGF	8:14	9:01	0:46	LINE CLEAR AVAILED
53	8-Feb-2022	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	HBR LAYOUT, BELL CERAMICS (EHT)	14:09	15:44	1:34	LINE CLEAR AVAILED
54	8-Feb-2022	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	10:50	11:10	0:20	LINE FAULT
55	8-Feb-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	17:05	17:52	0:46	LINE CLEAR AVAILED
56	8-Feb-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	NO STATION AFFECTED	15:42	16:58	1:16	LINE CLEAR AVAILED
57	8-Feb-2022	BENGALURU	66	HV2	DEVANAHALLI 66	15:34	18:29	2:54	LINE CLEAR AVAILED
58	8-Feb-2022	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN,LINE FAULT
59	8-Feb-2022	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN,LINE FAULT
60	8-Feb-2022	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	23:41:00(07/02/2022)	00:04(08/02/2022)	0:22hrs	LINE CHARGED
61	8-Feb-2022	GULBARGA	110	YAPALDINI-VADAVATTI	YAPALDINI_110	9:20	10:00	0:40	MAIN SUPPLY FAILURE
62	8-Feb-2022	GULBARGA	110	YEREGERA-RAICHUR	YEREGERA_110	9:20	9:58	0:38	MAIN SUPPLY FAILURE
63	8-Feb-2022	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	1:01	1:16	0:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
64	8-Feb-2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110,M ANVI_110	1:11	1:21	0:10	LINE FAULT
65	8-Feb-2022	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	1:36	1:46	0:10	LINE FAULT
66	8-Feb-2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110,M ANVI_110	4:34	4:44	0:10	LINE FAULT
67	8-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,GAUBBUR_110	7:38	7:50	0:12	LINE CLEAR AVAILED
68	8-Feb-2022	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	6:25	7:45	1:20	LINE CLEAR AVAILED
69	8-Feb-2022	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATI_1 10	9:23	10:00	0:37	LINE CLEAR AVAILED
70	8-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,GAUBBUR_110	19:05	19:14	0:09	LINE CLEAR AVAILED
71	8-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR1	GAUBBUR_110	19:05	19:14	0:09	LINE FAULT
72	8-Feb-2022	GULBARGA	110	SINDHANOOR-NIRLOTI_IPP	SINDHANOOR_220	17:37	17:47	0:10	LINE FAULT
73	8-Feb-2022	GULBARGA	110	JAWALGERA-ADAVI AMARESHWAR	ADAVI AMARESHWAR_110	16:55	17:05	0:10	LINE CLEAR AVAILED
74	8-Feb-2022	GULBARGA	110	YAPALDINNI-VADAVATI	YAPALDINNI_110	9:20	10:00	0:08	MAIN SUPPLY FAILURE
75	8-Feb-2022	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	10:58	11:12	0:08	LINE FAULT
76	8-Feb-2022	GULBARGA	110	YEREGERA-RAICHUR	YEREGERA_110	9:20	9:58	0:08	MAIN SUPPLY FAILURE
77	8-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	7:35	19:18	11:43	LINE CLEAR AVAILED
78	8-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	7:35	19:18	11:43	LINE CLEAR AVAILED
79	8-Feb-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:23 (07.02.2022)	10:36 (08.02.2022)	13:13 HRS	LINE CHARGED
80	8-Feb-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_ 110,SDAIDHAPUR_110,SANAT HI_IPP,CORE GREEN SUGAR_IPP	6:07	6:12	0:05	LINE FAULT
81	8-Feb-2022	GULBARGA	66	ITTAGI-HIREHADGALI2	HIREHADGALI_66,GIRIYAPUR_ 66,MAGALA_66,SOVENHALLI_ 66,TUNGA BHADRA_IPP	11:55	12:30	0:35	LINE CLEAR AVAILED
82	8-Feb-2022	GULBARGA	66	NEELAGUNDA-HALAVAGALU	HALAVAGALU_66	2:29	2:39	0:10	LINE FAULT
83	8-Feb-2022	HASSAN	110	JOG110-AMBTR2	JOG_110	13:08 (26.01.2022)			LINE OPEN,LINE FAULT
84	8-Feb-2022	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN,LINE CLEAR AVAILED
85	8-Feb-2022	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN,LINE CLEAR AVAILED
86	8-Feb-2022	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:30(9.01.2022)			LINE OPEN,LINE CLEAR AVAILED
87	8-Feb-2022	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	10:13(08.02.2022)			MAIN SUPPLY FAILURE
88	8-Feb-2022	HASSAN	220	HGUNJE-KMR2	HRGGUNJE_220	10:49	14:29	3:40	NFBC ISSUED
89	8-Feb-2022	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	10:13	11:11	0:58	LINE CLEAR AVAILED
90	8-Feb-2022	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	0:09	11:11	11:02	LINE FAULT
91	8-Feb-2022	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	15:49	16:30	0:41	HAND TRIPPED
92	8-Feb-2022	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	0:09	10:52	10:43	LINE FAULT
93	8-Feb-2022	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	15:44	16:19	0:35	LINE CLEAR AVAILED
94	8-Feb-2022	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	0:09	0:30	0:21	MAIN SUPPLY FAILURE
95	8-Feb-2022	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	0:35	0:49	0:14	HAND TRIPPED
96	8-Feb-2022	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	0:51	0:58	0:07	HAND TRIPPED
97	8-Feb-2022	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	5:01	5:05	0:04	HAND TRIPPED
98	8-Feb-2022	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	6:01	6:05	0:04	HAND TRIPPED
99	8-Feb-2022	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	6:22	6:29	0:07	HAND TRIPPED
100	8-Feb-2022	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	15:40	15:56	0:16	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
101	8-Feb-2022	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	0:09	0:20	0:11	MAIN SUPPLY FAILURE
102	8-Feb-2022	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	0:09	0:22	0:13	MAIN SUPPLY FAILURE
103	8-Feb-2022	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	0:09	0:32	0:23	MAIN SUPPLY FAILURE
104	8-Feb-2022	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	15:46	16:24	0:38	MAIN SUPPLY FAILURE
105	8-Feb-2022	HASSAN	110	HV2	HALADY_110	9:45	15:42	5:57	LINE CLEAR AVAIED
106	8-Feb-2022	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_66	9:02	9:09	0:07	LINE FAULT
107	8-Feb-2022	HASSAN	110	HV2	GERUMARA_110	16:55	17:16	0:21	TRANSFORMER FAULT
108	8-Feb-2022	HASSAN	110	HV1	GURUPURA_110	10:33	16:48	6:15	LINE CLEAR AVAIED
109	8-Feb-2022	HASSAN	110	HV2	HOSANGADI_110	20:41	21:58	1:17	TRANSFORMER FAULT
110	8-Feb-2022	HASSAN	110	HV2	HOSANGADI_110	23:07	23:57	0:50	TRANSFORMER FAULT
111	8-Feb-2022	HASSAN	110	KADUR-YGTI	KADUR_220	9:20	KAD05	0:45	HAND TRIPPED
112	8-Feb-2022	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	12:43	16:50	4:07	NFBC ISSUED
113	8-Feb-2022	HASSAN	220	KEMAR-HEGUNJE	KEMAR_220	10:48	14:29	3:41	LINE CLEAR AVAIED
114	8-Feb-2022	HASSAN	110	HV2	KEMAR_220	15:02	17:40	2:38	LINE CLEAR AVAIED
115	8-Feb-2022	HASSAN	110	KEMAR-Manipal1	KEMAR_220	10:13	12:30	2:17	LINE CLEAR AVAIED
116	8-Feb-2022	HASSAN	110	KEMAR-Manipal2	KEMAR_220	10:15	12:30	2:15	LINE CLEAR AVAIED
117	8-Feb-2022	HASSAN	110	HV2	KUNDAPURA_110	11:42	12:46	1:04	LINE CLEAR AVAIED
118	8-Feb-2022	HASSAN	110	HV3	MANIPAL_110	12:30	13:10	0:40	LINE CLEAR AVAIED
119	8-Feb-2022	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	10:13	12:35	2:22	NFBC ISSUED
120	8-Feb-2022	HASSAN	110	HV1	MOODABIDRE_110	10:00	13:00	3:00	LINE CLEAR AVAIED
121	8-Feb-2022	HASSAN	110	HV1	MOODABIDRE_110	15:15	16:30	1:15	LINE CLEAR AVAIED
122	8-Feb-2022	HASSAN	110	HV2	MOODABIDRE_110	13:10	15:11	2:01	LINE CLEAR AVAIED
123	8-Feb-2022	HASSAN	110	HV2	MRSMTG_220	10:51	12:49	1:58	LINE CLEAR AVAIED
124	8-Feb-2022	HASSAN	110	HV2	BRAHMAVARA_110	14:40	15:05	0:25	TRANSFORMER FAULT
125	8-Feb-2022	HASSAN	66	HV1	HALLYMYSORE_66	16:55	17:13	0:18	TRANSFORMER FAULT
126	8-Feb-2022	HASSAN	66	HV1	HANGARAHALLI_66	16:55	17:05	0:10	TRANSFORMER FAULT
127	8-Feb-2022	HASSAN	66	HV1	HARIHARAPURA_66	10:00	14:57	4:57	MAIN SUPPLY FAILURE
128	8-Feb-2022	HASSAN	66	HARIHAR-KADUVINKOTE	HARIHARAPURA_66	10:00	14:57	4:57	MAIN SUPPLY FAILURE
129	8-Feb-2022	HASSAN	66	HV2	HIRESAVE_66	12:56	13:00	0:04	TRANSFORMER FAULT
130	8-Feb-2022	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	10:18	14:45	4:27	LINE CLEAR AVAIED
131	8-Feb-2022	HASSAN	66	HV2	HOLALUR_66	10:15	11:01	0:46	LINE CLEAR AVAIED
132	8-Feb-2022	HASSAN	66	HV2	MAGGE_66	12:01	12:09	0:08	LINE CLEAR AVAIED
133	8-Feb-2022	HASSAN	66	MNJUPR-L1	MANJUNATHPURA_66	19:22	19:24	0:02	HAND TRIPPED
134	8-Feb-2022	MYSURU	66	HV1	ADDIHALLI_66	16:13	16:19	0:06	MAIN SUPPLY FAILURE
135	8-Feb-2022	MYSURU	66	HV2	ADDIHALLI_66	16:13	16:19	0:06	MAIN SUPPLY FAILURE
136	8-Feb-2022	MYSURU	66	HV1	ADDIHALLI_66	19:10	19:16	0:06	MAIN SUPPLY FAILURE
137	8-Feb-2022	MYSURU	66	HV2	ADDIHALLI_66	19:10	19:16	0:06	MAIN SUPPLY FAILURE
138	8-Feb-2022	MYSURU	66	HV2	AKKIHEBBAL_66	16:54	17:04	0:09	LOAD CURTAILMENT
139	8-Feb-2022	MYSURU	66	HV1	BESAGARAHALLI_66	16:54	17:05	0:10	LOAD CURTAILMENT
140	8-Feb-2022	MYSURU	66	HV2	BOOKANAKERE_66	16:55	16:59	0:04	LOAD CURTAILMENT
141	8-Feb-2022	MYSURU	66	HV1	DODDINADUVADI_66	16:54	17:03	0:08	LOAD CURTAILMENT
142	8-Feb-2022	MYSURU	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	4:35	4:40	0:04	LINE FAULT
143	8-Feb-2022	MYSURU	66	HV2	GVGUDI_66	16:54	17:11	0:17	LOAD CURTAILMENT
144	8-Feb-2022	MYSURU	66	HANNUR-KOTHANURU	NO STATIONS EFFECTED	3:25	3:30	0:05	LINE FAULT
145	8-Feb-2022	MYSURU	66	HANNUR-KOTHANURU	NO STATIONS EFFECTED	5:54	6:04	0:10	LINE FAULT
146	8-Feb-2022	MYSURU	66	HV2	HDKOTE_66	16:55	17:07	0:12	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
147	8-Feb-2022	MYSURU	66	HV1	HARIYALDAMMATemple_66	16:10	16:13	0:03	MAIN SUPPLY FAILURE
148	8-Feb-2022	MYSURU	66	HV1	HARIYALDAMMATemple_66	19:10	19:25	0:15	MAIN SUPPLY FAILURE
149	8-Feb-2022	MYSURU	66	HV2	JAIPUR_66	16:55	17:14	0:18	LOAD CURTAILMENT
150	8-Feb-2022	MYSURU	66	KR PETE 220-CR PATNA	NO STATIONS EFFECTED	15:26(8.2.22)			LINE OPEN,LINE CLEAR AVAILED
151	8-Feb-2022	MYSURU	66	KR PETE 220-SB HALLI	NO STATIONS EFFECTED	16:22	18:52	2:30	LINE CLEAR AVAILED
152	8-Feb-2022	MYSURU	66	HV1	MADHUVANAHALLI_220	10:20	12:02	1:42	LINE CLEAR AVAILED
153	8-Feb-2022	MYSURU	66	HV2	MADHUVANAHALLI_220	12:17	13:52	1:34	LINE CLEAR AVAILED
154	8-Feb-2022	MYSURU	220	HV1	MADHUVANAHALLI_220	10:32	15:42	5:10	LINE CLEAR AVAILED
155	8-Feb-2022	MYSURU	220	HV2	MADHUVANAHALLI_220	15:47	18:30	2:42	LINE CLEAR AVAILED
156	8-Feb-2022	MYSURU	66	HV1	SANTHEBACHALLI_66	16:11	16:17	0:06	MAIN SUPPLY FAILURE
157	8-Feb-2022	MYSURU	66	HV2	SANTHEBACHALLI_66	16:11	16:17	0:06	MAIN SUPPLY FAILURE
158	8-Feb-2022	MYSURU	66	HV1	SANTHEBACHALLI_66	19:11	19:18	0:07	MAIN SUPPLY FAILURE
159	8-Feb-2022	MYSURU	66	HV2	SANTHEBACHALLI_66	19:11	19:18	0:07	MAIN SUPPLY FAILURE
160	8-Feb-2022	MYSURU	66	HV5	SFCSHIVA_66	14:41			TRANSFORMER OPEN, LINE CLEAR AVAILED
161	8-Feb-2022	MYSURU	66	HV1	YELANDUR_66	16:54	17:10	0:15	LOAD CURTAILMENT
162	8-Feb-2022	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)			LINE OPEN,LINE CLEAR AVAILED
163	8-Feb-2022	MYSURU	66	TN PURA-THAYUR	NO STATIONS EFFECTED	11:57:36 (13/1/2022)			LINE OPEN,LINE CLEAR AVAILED
164	8-Feb-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
165	8-Feb-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
166	8-Feb-2022	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	12:54:48 (18.01.2022)			LINE OPEN,LINE CLEAR AVAILED
167	8-Feb-2022	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	11:37	13:05	1:28	LINE CLEAR AVAILED
168	8-Feb-2022	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	11:33	14:03	2:29	LINE CLEAR AVAILED
169	8-Feb-2022	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	12:20	13:25	1:05	LINE CLEAR AVAILED
170	8-Feb-2022	TUMKUR	110	CHIKKANAYAKANAHALLI- HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL_110	15:16	15:27	0:10	LINE FAULT
171	8-Feb-2022	TUMKUR	110	TR-1	KALLUR_110	1:42	2:37	0:55	TRANSFORMER FAULT
172	8-Feb-2022	TUMKUR	110	TR-1	KBCROSS_220	15:24	15:47	0:23	LINE CLEAR AVAILED
173	8-Feb-2022	TUMKUR	110	TR-1	MAYASANDRA_110	11:05	11:17	0:12	TRANSFORMER FAULT
174	8-Feb-2022	TUMKUR	110	NITTUR 220-KADABA	KADABA_110	9:42	10:29	0:47	LOAD CURTAILMENT
175	8-Feb-2022	TUMKUR	110	NITTUR 220-K G TEMPLE	KGTEMPLE_110	10:30	11:15	0:45	LOAD CURTAILMENT
176	8-Feb-2022	TUMKUR	110	NITTUR 220-KALLUR	KALLUR_110	11:19	11:58	0:39	LOAD CURTAILMENT
177	8-Feb-2022	TUMKUR	110	NITTUR 220-SOMLAPURA110	SOMLAPURA_110	9:40	10:31	0:51	LOAD CURTAILMENT
178	8-Feb-2022	TUMKUR	110	TR-2	SHETYKERE_110	18:16	18:39	0:23	LINE CLEAR AVAILED
179	8-Feb-2022	TUMKUR	66	ANCHEPALYA 220kv- HEBBUR_66	HEBBUR_66,THIMMASANDRA_66,HONNENAHALLI_66	9:18	9:26	0:07	LOAD CURTAILMENT
180	8-Feb-2022	TUMKUR	66	BEVINAHALLI- AFTL SOLAR IPP_66	AFTL SOLAR_IPP_66	7:12	8:13	1:01	LINE FAULT
181	8-Feb-2022	TUMKUR	66	TR-2	BHARAMAGIRI_66	8:00	8:05	0:05	TRANSFORMER FAULT
182	8-Feb-2022	TUMKUR	66	TR-2	BHARAMAGIRI_66	11:00	11:45	0:45	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
183	8-Feb-2022	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 1	CHITRADURGA_66 OLD MUSS,PANDARAHALLI_66,CHI TRAHALLI_66,HDPURA_66,HO LALKERE_66,RAMGIRI_66	7:42	8:29	0:47	LOAD CURTAILMENT
184	8-Feb-2022	TUMKUR	66	TR-1	PAVAGADA_66	14:25	14:27	0:02	TRANSFORMER FAULT
185	8-Feb-2022	TUMKUR	66	TR-2	PAVAGADA_66	14:02	14:31	0:28	TRANSFORMER FAULT
186	8-Feb-2022	TUMKUR	66	PAVAGADA66-MADHUGIRI	PAVAGADA_66	14:04	14:26	0:22	LINE FAULT
187	8-Feb-2022	TUMKUR	66	PAVAGADA220-MEDIGESHI66	MEDIGESHI_66,I D HALLI_66,HOSKERE_66	14:45	14:51	0:05	LINE FAULT
188	8-Feb-2022	TUMKUR	66	TR-1	HALURAMESHWARA_66	15:15	16:08	0:52	LINE CLEAR AVAILED
189	8-Feb-2022	TUMKUR	66	TR-2	HALURAMESHWARA_66	15:16	16:08	0:52	LINE CLEAR AVAILED
190	8-Feb-2022	TUMKUR	66	H D PURA- SUZLON_IPP_66	SUZLON_IPP_66	10:18	11:44	1:25	LINE CLEAR AVAILED
191	8-Feb-2022	TUMKUR	66	H D PURA- MMCLWINDMILL	MMCLWINDMILL_IPP_66	10:18	11:44	1:25	LINE CLEAR AVAILED
192	8-Feb-2022	TUMKUR	66	TR-1	HIRIYUR_66	14:09	14:23	0:14	TRANSFORMER FAULT
193	8-Feb-2022	TUMKUR	66	HONNALLI 220kV- KUNDUR66	KUNDUR_66,MALEBENNUR_66, DEVARABELKERE_66	12:41	13:14	0:32	HAND TRIPPED
194	8-Feb-2022	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:41	10:48	0:06	LINE FAULT
195	8-Feb-2022	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEE LAGUNDA_66	17:08	17:24	0:16	LINE FAULT
196	8-Feb-2022	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:11	15:31	6:20	LINE CLEAR AVAILED
197	8-Feb-2022	TUMKUR	66	TR-1	LINGADHALLI_66	10:10	10:36	0:26	TRANSFORMER FAULT
198	8-Feb-2022	TUMKUR	66	TR-2	MALEBENNUR_66	13:16	15:03	1:47	LINE CLEAR AVAILED
199	8-Feb-2022	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	9:32	11:17	1:45	LINE CLEAR AVAILED
200	8-Feb-2022	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	11:47	12:07	0:19	LINE FAULT
201	8-Feb-2022	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	13:01	16:04	3:03	LINE CLEAR AVAILED
202	8-Feb-2022	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	16:32	16:40	0:08	LINE FAULT
203	8-Feb-2022	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	17:01	17:07	0:06	LINE FAULT
204	8-Feb-2022	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	18:32	19:04	0:31	LINE FAULT
205	8-Feb-2022	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA	KOLALA_66, URDIGERE_66	9:17	9:40	0:22	LOAD CURTAILMENT
206	8-Feb-2022	TUMKUR	66	MADHUGIRI 220kV- MEDIGESHI 1	MEDIGESHI_66,I D HALLI_66,KODIGENAHALLI_66 ,HOSKERE_66	11:14	11:33	0:18	LINE FAULT
207	9-Feb-2022	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
208	9-Feb-2022	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)	9:05 (09.02.2022)	8416:48HRS	LINE CHARGED
209	9-Feb-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
210	9-Feb-2022	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
211	9-Feb-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
212	9-Feb-2022	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)	10:33 (09.02.2022)	334:44HRS	LOAD CURTAILMENT
213	9-Feb-2022	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	11:49 (26.01.2022)	10:33 (09.02.2022)	334:44HRS	LOAD CURTAILMENT
214	9-Feb-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN,LINE FAULT
215	9-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED ANKALI_110	12:30	13:04	0:34	LINE CLEAR AVAILED
216	9-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED BABALESHWAR_110	12:45	16:32	3:47	LINE CLEAR AVAILED
217	9-Feb-2022	BAGALKOT	110	BIDNAL220-GADAG ROAD	STATION NOT AFFECTED BIDNAL_220	8:59	10:05	1:06	LINE CLEAR AVAILED
218	9-Feb-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED DEVANAGAON_110	9:33	9:45	0:12	TRANSFORMER FAULT
219	9-Feb-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED DEVANAGAON_110	13:27	13:35	0:08	TRANSFORMER FAULT
220	9-Feb-2022	BAGALKOT	110	GADAG ROAD-GOPANAKOPPA	GADAG ROAD_110	8:59	10:14	1:15	LINE CLEAR AVAILED
221	9-Feb-2022	BAGALKOT	110	GADAG ROAD-BIDNAL220	STATIO NOT AFFECTED GADAG ROAD_110	10:15	10:16	0:01	HAND TRIPPED
222	9-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED HIDIKAL DAM_110	12:14	13:19	1:05	LINE CLEAR AVAILED
223	9-Feb-2022	BAGALKOT	110	JAMAKHANDI- MAHALINGAPUR220	JAMAKHANDI_110	10:10	18:43	8:33	LINE CLEAR AVAILED
224	9-Feb-2022	BAGALKOT	110	KADANAKOPPA-HUBLI220	STATION NOT AFFECTED KADANAKOPPA_110	18:48	22:27	3:39	LINE FAULT
225	9-Feb-2022	BAGALKOT	110	M R NAGAR-NARENDAR220-2	M R NAGAR_110	10:19	10:20	0:01	HAND TRIPPED
226	9-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUNDAGOD_110	10:14	14:17	4:03	LINE CLEAR AVAILED
227	9-Feb-2022	BAGALKOT	110	NARAGUND-BPCL	BPCL IPP_110 NARAGUND_110	1:27	6:45	5:18	LINE FAULT
228	9-Feb-2022	BAGALKOT	110	NAVALAGI-JAMAKHANDI	JAMAKHANDI_110	18:20	18:37	0:17	LINE CLEAR AVAILED
229	9-Feb-2022	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	9:41	9:58	0:17	HAND TRIPPED
230	9-Feb-2022	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	10:21	10:55	0:34	LINE FAULT
231	9-Feb-2022	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	10:55	12:15	1:20	LINE FAULT
232	9-Feb-2022	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	14:18	21:17	6:59	LINE FAULT
233	9-Feb-2022	BAGALKOT	110	SHIROL-JAMAKHANDI	STATION NOT AFFECTED SHIROL_110	10:10	13:00	2:50	LINE CLEAR AVAILED
234	9-Feb-2022	BAGALKOT	110	110/11KV,HV1,HV2	STATION NOT AFFECTED SHIROL_110	14:00	14:05	0:05	HAND TRIPPED
235	9-Feb-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	10:33	10:58	0:25	HAND TRIPPED
236	9-Feb-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
237	9-Feb-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	10:33	10:58	0:25	HAND TRIPPED
238	9-Feb-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
239	9-Feb-2022	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	10:58	22:24	11:26	LINE CLEAR AVAILED
240	9-Feb-2022	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	10:58	22:24	11:26	LINE CLEAR AVAILED
241	9-Feb-2022	BAGALKOT	220	AMBEWADI-NAGJHARI2	STATION NOT AFFECTED AMBEWDI_220	16:25 (09.02.2022)			LINE OPEN,LINE FAULT
242	9-Feb-2022	BAGALKOT	110	HUBLI-KADANKOPPA	STATION NOT AFFECTED HUBLI_220	18:48	22:03	3:15	LINE FAULT
243	9-Feb-2022	BAGALKOT	220	MAHALINGAPUR-ATHANI	STATION NOT AFFECTED ATHANI_220	6:25	7:19	0:54	LINE FAULT
244	9-Feb-2022	BAGALKOT	110	AMBEWADI220- NK-1 (KAWALWADA)	STATION NOT AFFECTED AMBEWADI_220	10:25 (04.02.2022)			LINE OPEN,LINE CLEAR AVAILED
245	9-Feb-2022	BAGALKOT	110	AMBEWADI220- NK-2 (HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	10:28 (04.02.2022)			LINE OPEN,LINE CLEAR AVAILED
246	9-Feb-2022	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI1	STATION NOT AFFECTED MAHALINGAPUR_220	9:40	9:55	0:15	HAND TRIPPED
247	9-Feb-2022	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI2	STATION NOT AFFECTED MAHALINGAPUR_220	9:40	9:56	0:16	HAND TRIPPED
248	9-Feb-2022	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI1	STATION NOT AFFECTED MAHALINGAPUR_220	11:15	11:45	0:30	HAND TRIPPED
249	9-Feb-2022	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI1	STATION NOT AFFECTED MAHALINGAPUR_220	13:00	13:18	0:18	LINE FAULT
250	9-Feb-2022	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI1	STATION NOT AFFECTED MAHALINGAPUR_220	13:43	14:21	0:38	LINE FAULT
251	9-Feb-2022	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI1	STATION NOT AFFECTED MAHALINGAPUR_220	14:34	21:10	6:36	LINE FAULT
252	9-Feb-2022	BENGALURU	66	CESSNA - HSR LAYOUT 220	CESSNA, EXORA	12:05	12:10	0:05	LOAD CHANGE OVER
253	9-Feb-2022	BENGALURU	66	CESSNA - HAL 220	CESSNA, EXORA	14:35	14:40	0:05	LOAD CHANGE OVER
254	9-Feb-2022	BENGALURU	66	EXORA - HSR LAYOUT 220	EXORA	8:04	8:15	0:11	MAIN SUPPLY FAILURE
255	9-Feb-2022	BENGALURU	66	HV1	GLOBAL TECH PARK	9:45	9:50	0:05	LINE CLEAR AVAILED
256	9-Feb-2022	BENGALURU	220	HV3	HSR LAYOUT 220	8:04	11:30	3:26	LINE CLEAR AVAILED
257	9-Feb-2022	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	JAKKASANDRA	8:04	8:36	0:32	LINE CLEAR AVAILED
258	9-Feb-2022	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI	8:04	8:24	0:20	LINE CLEAR AVAILED
259	9-Feb-2022	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	8:04	8:15	0:11	LINE CLEAR AVAILED
260	9-Feb-2022	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	8:04	8:15	0:11	LINE CLEAR AVAILED
261	9-Feb-2022	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS WOOD	ST. JOHNS WOOD	8:04	8:38	0:34	LINE CLEAR AVAILED
262	9-Feb-2022	BENGALURU	66	HV1	HSR LAYOUT 220	8:04	8:15	0:11	LINE CLEAR AVAILED
263	9-Feb-2022	BENGALURU	66	HV2	HSR LAYOUT 220	8:04	8:15	0:11	LINE CLEAR AVAILED
264	9-Feb-2022	BENGALURU	66	SHOBHA APARTMENT - HSR LAYOUT 220	SHOBHA APARTMENT	12:14	12:40	0:26	MAIN SUPPLY FAILURE
265	9-Feb-2022	BENGALURU	66	SHOBHA APARTMENT - DEVARABISANAHALLI	SHOBHA APARTMENT	14:24	14:35	0:11	LOAD CHANGE OVER
266	9-Feb-2022	BENGALURU	66	HV2	NAGANATHPURA 220	12:07	12:10	0:03	LINE CLEAR AVAILED
267	9-Feb-2022	BENGALURU	66	HV2	NAGANATHPURA 220	16:28	16:30	0:02	LOAD CHANGE OVER
268	9-Feb-2022	BENGALURU	66	HV2	NRS 220	15:46	15:54	0:08	LINE CLEAR AVAILED
269	9-Feb-2022	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	11:10	15:20	4:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
270	9-Feb-2022	BENGALURU	66	ST.JOHN WOOD - HSR LAYOUT 220	ST.JOHN WOOD	8:43	8:48	0:05	LOAD CHANGE OVER
271	9-Feb-2022	BENGALURU	66	ST.JOHN WOOD - ADUGODI	ST.JOHN WOOD	11:40	11:45	0:05	LOAD CHANGE OVER
272	9-Feb-2022	BENGALURU	66	HV1	TEKAL	13:25	16:11	2:46	LINE CLEAR AVAILED
273	9-Feb-2022	BENGALURU	66	HV2	TEKAL	11:20	13:18	1:58	LINE CLEAR AVAILED
274	9-Feb-2022	BENGALURU	66	HV2	MAASTHI	14:15	14:25	0:10	TRANSFORMER FAULT
275	9-Feb-2022	BENGALURU	66	HV2	KODIHALLI CHINTAMANI	17:03	17:48	0:44	LINE CLEAR AVAILED
276	9-Feb-2022	BENGALURU	66	HV2	GUDIBANDE	16:07	16:40	0:32	LINE CLEAR AVAILED
277	9-Feb-2022	BENGALURU	66	HV1	GANJIGUNTE	10:24	16:11	5:46	LINE CLEAR AVAILED
278	9-Feb-2022	BENGALURU	66	HV1	GANJIGUNTE	16:56	17:35	0:39	LINE CLEAR AVAILED
279	9-Feb-2022	BENGALURU	66	HV1	DODDABELAVANGALA	15:53	16:00	0:07	TRANSFORMER FAULT
280	9-Feb-2022	BENGALURU	66	HV2	BANGARPET	17:20	18:15	0:55	TRANSFORMER FAULT
281	9-Feb-2022	BENGALURU	66	HV2	SRINIVASAPURA	17:45	17:50	0:05	LINE CLEAR AVAILED
282	9-Feb-2022	BENGALURU	66	SRINIVASAPURA - CHINTAMANI 220	SRINIVASAPURA	20:00	20:05	0:05	MAIN SUPPLY FAILURE
283	9-Feb-2022	BENGALURU	66	MARALWADI - KANAKPURA 220	MARALWADI, GODURU	15:58	16:02	0:04	LINE FAULT
284	9-Feb-2022	BENGALURU	66	PALLICHERLU - CHINTAMNI 220	PALLICHERLU	18:35	18:40	0:05	MAIN SUPPLY FAILURE
285	9-Feb-2022	BENGALURU	66	TUBUGERE - DB PURA 220	TUBUGERE	16:14	17:27	1:12	LINE CLEAR AVAILED
286	9-Feb-2022	BENGALURU	66	PALLICHERLU - ACME SOLAR(IPP)	NO STATION AFFECTED	18:35	18:50	0:15	LINE CLEAR AVAILED
287	9-Feb-2022	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	12:08	12:25	0:17	LINE CLEAR AVAILED
288	9-Feb-2022	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	11:58	12:07	0:09	LINE CLEAR AVAILED
289	9-Feb-2022	BENGALURU	220	DABUSPET 220 - KADUR 220	DABUSPET 220	11:39	17:15	5:36	LOAD CURTAILMENT
290	9-Feb-2022	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	17:51	17:53	0:02	LINE CLEAR AVAILED
291	9-Feb-2022	BENGALURU	66	HV1	MUDIYANUR	16:25	16:45	0:20	TRANSFORMER FAULT
292	9-Feb-2022	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	10:38	10:58	0:20	LINE FAULT
293	9-Feb-2022	BENGALURU	66	TADIGOLU - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	7:45	7:58	0:13	LINE FAULT
294	9-Feb-2022	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN,LINE FAULT
295	9-Feb-2022	BENGALURU	220	KOTIPURA 220 - TUBINAKERE 220	NO STATION AFFECTED	18:15(09/02/2022)			LINE OPEN,LINE FAULT
296	9-Feb-2022	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN,LINE FAULT
297	9-Feb-2022	GULBARGA	220	HV2	RAICHUR_220	9:19	9:35	0:16	LINE CLEAR AVAILED
298	9-Feb-2022	GULBARGA	220	HV2	RAICHUR_220	12:50	13:04	0:14	LINE CLEAR AVAILED
299	9-Feb-2022	GULBARGA	220	HV1&HV2	SINDHANOOR_220	9:39	9:55	0:16	TRANSFORMER FAULT
300	9-Feb-2022	GULBARGA	220	HV1	SHAHAPUR_220	11:22	11:31	0:09	LINE CLEAR AVAILED
301	9-Feb-2022	GULBARGA	220	HV2	SHAHAPUR_220	11:41	17:44	6:03	LINE CLEAR AVAILED
302	9-Feb-2022	GULBARGA	220	HV1	HUMNABAD_220	10:19	16:09	5:50	LINE CLEAR AVAILED
303	9-Feb-2022	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	11:40	16:51	5:11	LINE CLEAR AVAILED
304	9-Feb-2022	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	10:50	11:01	0:11	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
305	9-Feb-2022	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	11:08	11:14	0:06	LINE CLEAR AVAILED
306	9-Feb-2022	GULBARGA	220	SHAHAPUR-LINGASUGUR	LINGASUGUR_220	11:17	11:21	0:04	LINE CLEAR AVAILED
307	9-Feb-2022	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	23:05	23:22	0:17	LINE FAULT
308	9-Feb-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
309	9-Feb-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:11 (08.02.2022)			LINE OPEN,LINE CLEAR AVAILED
310	9-Feb-2022	GULBARGA	110	KUSTAGI-KANAKGIRI	KANAKGIRI_110,GANADAL_11 0,NAVALI_110	10:30(09.2.22)			LINE OPEN,LINE CLEAR AVAILED
311	9-Feb-2022	GULBARGA	110	KUSTAGI-TAWERGERE	TAWERGERE_110	10:45(09.2.22)			LINE OPEN,LINE CLEAR AVAILED
312	9-Feb-2022	GULBARGA	110	KUSTAGI-KUSTAGI SOLAR_IPP	KUSTAGI SOLAR_IPP	10:50(09.2.22)			LINE OPEN,LINE CLEAR AVAILED
313	9-Feb-2022	GULBARGA	110	HV2	SREERAMANAGAR_110	7:15	7:45	0:08	TRANSFORMER FAULT
314	9-Feb-2022	GULBARGA	110	HV1	SINDHANOOR_220	9:25	9:35	0:10	TRANSFORMER FAULT
315	9-Feb-2022	GULBARGA	110	HV1	SINDHANOOR_220	12:20	13:05	0:45	TRANSFORMER FAULT
316	9-Feb-2022	GULBARGA	110	HV2	YAPALDINI_110	10:10	18:10	8:00	LINE CLEAR AVAILED
317	9-Feb-2022	GULBARGA	110	HV2	HANUMANAL_110	17:20	17:50	0:30	LINE CLEAR AVAILED
318	9-Feb-2022	GULBARGA	110	GANDHINAGAR-SINDHANOOR	GANDHINAGAR_110,TURVIHA L_110	9:36	9:52	0:08	MAIN SUPPLY FAILURE
319	9-Feb-2022	GULBARGA	110	HUMNABAD-MANEIKHELLI	MANAIKHELLI_110	1:20	1:27	0:07	LINE FAULT
320	9-Feb-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_ 110,SDAIDHAPUR_110,SANAT HI_IPP,CORE GREEN SUGAR_IPP	4:47	4:52	0:05	LINE FAULT
321	9-Feb-2022	GULBARGA	110	SREERAMANAGAR-SINDHANOOR	SREERAMANAGAR_110	9:35	9:55	0:08	MAIN SUPPLY FAILURE
322	9-Feb-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERDONA_110,SRNAGAR_110 ,MALLAPURA_110	7:35	7:45	2:08	LINE FAULT
323	9-Feb-2022	GULBARGA	110	HUMNABAD-MANNAEKHELI	MANNAEKHELI_110	1:20	1:27	0:07	LINE FAULT
324	9-Feb-2022	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLAR Y NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JAN AKI_IPP,BASAI STEELS	2:52	2:59	0:08	LINE FAULT
325	9-Feb-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERDONA_110,SRNAGAR_110 ,MALLAPURA_110	0:25	0:35	0:10	LINE FAULT
326	9-Feb-2022	GULBARGA	110	SINDHANOOR-NIRLOTI_IPP	SINDHANOOR_220	1:26	1:36	0:10	LINE FAULT
327	9-Feb-2022	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGU R_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	9:25	9:37	0:12	LINE FAULT
328	9-Feb-2022	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGU R_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	9:39	10:22	0:43	LINE FAULT
329	9-Feb-2022	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGU R_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	12:20	13:10	0:50	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
330	9-Feb-2022	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	4:40	4:50	0:10	LINE FAULT
331	9-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	2:25	2:30	0:05	LINE FAULT
332	9-Feb-2022	GULBARGA	110	KUSTAGI-KANAKAGIRI	KANAKAGIRI_110,GANADAL_110	10:30	13:50	3:20	LINE CLEAR AVAILED
333	9-Feb-2022	GULBARGA	110	KUSTAGI-TAWARAGERA	TAWARAGERA_110	12:26	13:00	0:34	LINE CLEAR AVAILED
334	9-Feb-2022	GULBARGA	110	KUSTAGI-LINGASUGUR	KUSTAGI_220	12:15	14:00	1:45	LINE FAULT
335	9-Feb-2022	GULBARGA	110	KUSTAGI-KUSTAGI SOLAR_IPP	KUSTAGI_220	11:00	19:35	8:35	LINE CLEAR AVAILED
336	9-Feb-2022	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	2:52	3:08	0:16	MAIN SUPPLY FAILURE
337	9-Feb-2022	GULBARGA	110	GURMITKAL-GMSHWIND	GURMITKAL_110	10:15	17:30	7:15	LINE CLEAR AVAILED
338	9-Feb-2022	GULBARGA	110	YERADONA-SINDANOOR	YEREDONA_110	0:20	0:30	0:10	MAIN SUPPLY FAILURE
339	9-Feb-2022	GULBARGA	110	YERADONA-SINDANOOR	YEREDONA_110	9:40	9:55	0:15	MAIN SUPPLY FAILURE
340	9-Feb-2022	GULBARGA	110	TAVERGERA-KUSHTAGI	TAVERGERA_110	10:40	12:45	2:05	MAIN SUPPLY FAILURE
341	9-Feb-2022	GULBARGA	110	ADVAMERESHWAR-SINDANOOR	ADVAMERESHWAR_110	9:30	9:55	0:25	MAIN SUPPLY FAILURE
342	9-Feb-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_110,CORE GREEN SUGARS IPP	4:47	4:52	0:05	LINE FAULT
343	9-Feb-2022	GULBARGA	66	BANVEKAL-BADALADUKU	BANVEKAL_66	11:20	11:40	0:20	MAIN SUPPLY FAILURE
344	9-Feb-2022	HASSAN	110	JOG110-AMBTR2	JOG_110	13:08 (26.01.2022)			LINE OPEN,LINE FAULT
345	9-Feb-2022	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN,LINE CLEAR AVAILED
346	9-Feb-2022	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN,LINE CLEAR AVAILED
347	9-Feb-2022	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:30(9.01.2022)			LINE OPEN,LINE CLEAR AVAILED
348	9-Feb-2022	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	10:13(08.02.2022)			MAIN SUPPLY FAILURE
349	9-Feb-2022	HASSAN	220	KADUR-SHIMOGA	KADUR_220	17:18	17:40	0:22	HAND TRIPPED
350	9-Feb-2022	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	17:18	17:39	0:21	LINE CLEAR AVAILED
351	9-Feb-2022	HASSAN	110	HV5	MRSMSG_220	16:15	17:21	1:06	LINE CLEAR AVAILED
352	9-Feb-2022	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	9:38	14:44	5:06	LINE CLEAR AVAILED
353	9-Feb-2022	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:05	11:50	0:45	LINE CLEAR AVAILED
354	9-Feb-2022	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	17:00	17:39	0:39	LINE CLEAR AVAILED
355	9-Feb-2022	HASSAN	110	HV2	ANAVATTI_110	11:59	13:19	1:20	LINE CLEAR AVAILED
356	9-Feb-2022	HASSAN	110	BARANG-ANVATTI	BARANGI_110	17:18	17:30	0:12	LINE CLEAR AVAILED
357	9-Feb-2022	HASSAN	110	BARANG-SHR220	BARANGI_110	11:54	17:18	5:24	NFBC ISSUED
358	9-Feb-2022	HASSAN	110	HV2	HOSANGADI_110	10:51	11:06	0:15	TRANSFORMER FAULT
359	9-Feb-2022	HASSAN	110	HV2	HOSANGADI_110	11:10	16:24	5:14	LINE CLEAR AVAILED
360	9-Feb-2022	HASSAN	110	HV2	KONAJE_110	9:59	13:25	3:26	LINE CLEAR AVAILED
361	9-Feb-2022	HASSAN	110	HV3	KONAJE_110	10:00	13:24	3:24	LINE CLEAR AVAILED
362	9-Feb-2022	HASSAN	110	HV	PUTTUR_110	10:39	13:17	2:38	LINE CLEAR AVAILED
363	9-Feb-2022	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_110	11:05	17:15	6:10	LINE CLEAR AVAILED
364	9-Feb-2022	HASSAN	66	AREHALI-SAKLESPUR	AREHALLI_66	8:50	17:02	8:12	MAIN SUPPLY FAILURE
365	9-Feb-2022	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLI_66	12:49	13:16	0:27	HAND TRIPPED
366	9-Feb-2022	HASSAN	66	HV1	HALEBEEDU_66	8:10	8:15	0:05	MAIN SUPPLY FAILURE
367	9-Feb-2022	HASSAN	66	HV1	HANUBAL_66	16:00	17:02	1:02	MAIN SUPPLY FAILURE
368	9-Feb-2022	HASSAN	66	HANUBAL-SAKLESPUR	HANUBAL_66	8:50	10:38	1:48	NFBC ISSUED
369	9-Feb-2022	HASSAN	66	HANUBAL-SAKLESPUR	HANUBAL_66	16:00	17:02	1:02	NFBC ISSUED
370	9-Feb-2022	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	10:30	10:40	0:10	LINE FAULT
371	9-Feb-2022	HASSAN	66	MNJUPR-L1 CB	MANJUNATHPURA_66	9:24	9:25	0:01	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
372	9-Feb-2022	HASSAN	66	MNJUPR-L1 CB	MANJUNATHPURA_66	12:40	12:41	0:01	HAND TRIPPED
373	9-Feb-2022	HASSAN	66	SAKALE-HANBAL	SAKALESHPURA_66	8:47	10:35	1:48	LINE CLEAR AVAILED
374	9-Feb-2022	HASSAN	66	SAKALE-HANBAL	SAKALESHPURA_66	16:00	17:00	1:00	LINE CLEAR AVAILED
375	9-Feb-2022	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	5:30	9:44	4:14	MAIN SUPPLY FAILURE
376	9-Feb-2022	HASSAN	66	CHANNAR-MALLALI	CHANNNARAYAPATNA_66	5:38	8:35	2:57	LINE FAULT
377	9-Feb-2022	HASSAN	66	CHANNAR-UDAYAPURA	CHANNNARAYAPATNA_66	5:38	8:35	2:57	LINE FAULT
378	9-Feb-2022	MYSURU	66	HV1	ADDIHALLI_66	7:12	7:18	0:06	HAND TRIPPED
379	9-Feb-2022	MYSURU	66	HV2	ADDIHALLI_66	7:12	7:19	0:06	HAND TRIPPED
380	9-Feb-2022	MYSURU	66	HV1	ADDIHALLI_66	10:26	10:29	0:03	HAND TRIPPED
381	9-Feb-2022	MYSURU	66	HV2	ADDIHALLI_66	10:26	10:29	0:03	HAND TRIPPED
382	9-Feb-2022	MYSURU	66	HV1	ADDIHALLI_66	11:33	11:36	0:02	MAIN SUPPLY FAILURE
383	9-Feb-2022	MYSURU	66	HV2	ADDIHALLI_66	11:33	11:35	0:02	MAIN SUPPLY FAILURE
384	9-Feb-2022	MYSURU	66	HV1	BANNUR_66	14:31	14:39	0:07	TRANSFORMER FAULT
385	9-Feb-2022	MYSURU	66	HV1	BHARGI_66	10:25	10:40	0:15	TRANSFORMER FAULT
386	9-Feb-2022	MYSURU	66	HV1	DEVANOORMYS_66	14:09	14:50	0:40	LINE CLEAR AVAILED
387	9-Feb-2022	MYSURU	66	HV1	HARIYALDAMMATemple_66	12:40	12:45	0:05	MAIN SUPPLY FAILURE
388	9-Feb-2022	MYSURU	220	KADAKOLA -BASTIPURA 1	NO STATIONS EFFECTED	11:15	14:10	2:55	LINE CLEAR AVAILED
389	9-Feb-2022	MYSURU	220	KADAKOLA -BASTIPURA2	NO STATIONS EFFECTED	15:19	18:07	2:47	LINE CLEAR AVAILED
390	9-Feb-2022	MYSURU	220	KADAKOLA -CR NAGARA 1	NO STATIONS EFFECTED	12:49	14:12	1:22	LINE CLEAR AVAILED
391	9-Feb-2022	MYSURU	66	HV1	KADKOTHANAHALLI_66	13:05	13:20	0:15	MAIN SUPPLY FAILURE
392	9-Feb-2022	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	14:16(9.2.22)			LINE OPEN,LINE CLEAR AVAILED
393	9-Feb-2022	MYSURU	66	HV1	KOLLEGALA_66	10:05	14:36	4:31	LINE CLEAR AVAILED
394	9-Feb-2022	MYSURU	66	HV2	KOLLEGALA_66	14:40	16:24	1:44	LINE CLEAR AVAILED
395	9-Feb-2022	MYSURU	66	KR PETE 220-CR PATNA	NO STATIONS EFFECTED	14:05	15:11	1:06	LINE CLEAR AVAILED
396	9-Feb-2022	MYSURU	66	KR PETE 220-SANTHEBACHALLI-1	NO STATIONS EFFECTED	8:34	11:31	2:57	LINE CLEAR AVAILED
397	9-Feb-2022	MYSURU	220	HV1	KUSHALNAGARA_220, BILIKERE_66 BHERYA_66 DMG_HALLI_66 GVGUDI_66 MIRLE_66 KR NAGARA_66, KAMPALAPURA_66, BETTADHAPURA_66, CHUNCHUNKATTE_66, KITTUR_66, RAVANDUR_66, BYLUKUPPE_66, PERIYAPATNA_66, PONNAMPET_66, VIRAJPET_66, HANAGODU_66, KHBCOLONY_66	13:39	13:54	0:14	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
398	9-Feb-2022	MYSURU	220	HV2	KUSHALNAGARA_220, BILIKERE_66 BHERYA_66 DMG_HALLI_66 GVGUDI_66 MIRLE_66 KRNAGARA_66, KAMPALAPURA_66, BETTADHAPURA_66, CHUNCHUNKATTE_66, KITTUR_66, RAVANDUR_66, BYLUKUPPE_66, PERIYAPATNA_66, PONNAMPET_66, VIRAJPET_66, HANAGODU_66, KHBCOLONY_66	13:40	13:54	0:14	TRANSFORMER FAULT
399	9-Feb-2022	MYSURU	66	HV1	SANTHEBACHALLI_66	10:40	10:45	0:05	TRANSFORMER FAULT
400	9-Feb-2022	MYSURU	66	HV1	SANTHEBACHALLI_66	11:45	11:50	0:05	TRANSFORMER FAULT
401	9-Feb-2022	MYSURU	66	SB HALLI -ADHANI	NO STATIONS EFFECTED	7:10	9:33	2:22	LINE CLEAR AVAILED
402	9-Feb-2022	MYSURU	66	SB HALLI -ADDIHALLI	ADDIHALLI_66	7:10	9:33	2:22	LINE CLEAR AVAILED
403	9-Feb-2022	MYSURU	66	SB HALLI -HARIYALDAMMA TEMPLE	HARIYALDAMMATEMPLE_66	7:10	9:33	2:22	LINE CLEAR AVAILED
404	9-Feb-2022	MYSURU	66	SB HALLI -HARIYALDAMMA TEMPLE	NO STATIONS EFFECTED	11:33	12:40	1:06	LINE CLEAR AVAILED
405	9-Feb-2022	MYSURU	66	SB HALLI -HUYGONAHALLI-1	SANTHEBACHALLI_66	7:10	11:32	4:21	LINE CLEAR AVAILED
406	9-Feb-2022	MYSURU	66	SB HALLI -HUYGONAHALLI-2	NO STATIONS EFFECTED	15:00	15:40	0:40	NFBC ISSUED
407	9-Feb-2022	MYSURU	66	HV5	SFCSHIVA_66	15:53(9.2.22)			TRANSFORMER OPEN, LINE CLEAR AVAILED
408	9-Feb-2022	MYSURU	66	HV2	SHIVALLY_66	16:00	16:34	0:33	LINE CLEAR AVAILED
409	9-Feb-2022	MYSURU	66	HV1	YERALLI HAND POST_66	8:55	9:10	0:15	TRANSFORMER FAULT
410	9-Feb-2022	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)			LINE OPEN,LINE CLEAR AVAILED
411	9-Feb-2022	MYSURU	66	TN PURA-THAYUR	NO STATIONS EFFECTED	11:57:36 (13/1/2022)			LINE OPEN,LINE CLEAR AVAILED
412	9-Feb-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
413	9-Feb-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
414	9-Feb-2022	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	12:54:48 (18.01.2022)	9:38	644:43HRs	LINE CHARGED
415	9-Feb-2022	MYSURU	66	HV5	SFCSHIVA_66	14:41:17 (08.02.2022)	6:50	16:08 HRs	TRANSFORMER CHARGED
416	9-Feb-2022	MYSURU	66	KR PETE 220-CR PATNA	NO STATIONS EFFECTED	15:26:34 (08.02.2022)	12:55	21:29 HRs	LINE CHARGED
417	9-Feb-2022	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI 66	17:33	18:49	1:16	TRANSFORMER FAULT
418	9-Feb-2022	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	14:03	14:43	0:40	LINE CLEAR AVAILED
419	9-Feb-2022	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	14:03	14:43	0:39	LINE CLEAR AVAILED
420	9-Feb-2022	TUMKUR	220	TR-1	KIADB V N PURA_220	11:17	11:18	0:01	HAND TRIPPED
421	9-Feb-2022	TUMKUR	220	TR-1	KIADB V N PURA_220	11:30	11:35	0:05	HAND TRIPPED
422	9-Feb-2022	TUMKUR	220	TR-2	KIADB V N PURA_220	11:17	11:18	0:01	HAND TRIPPED
423	9-Feb-2022	TUMKUR	220	KIADB V N PURA220- MADHUGIRI220	MADHUGIRI_220	12:06	12:16	0:10	HAND TRIPPED
424	9-Feb-2022	TUMKUR	220	KIADB V N PURA220-PGCIL V N PURA	KIADB V N PURA_220	12:21	12:24	0:03	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
425	9-Feb-2022	TUMKUR	66	ANTHRASANAHALI 220KV-KOLALA	KOLALA_66, URDIGERE_66	17:29	18:18	0:49	LOAD CURTAILMENT
426	9-Feb-2022	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALI 66	17:33	18:49	1:16	TRANSFORMER FAULT
427	9-Feb-2022	TUMKUR	66	ANTHRASANAHALI 220KV-BELLAVI	BELLAVI_66,MALLASANDRA_66, HEGGERE_66, DODDASARANGI_66	15:08	15:16	0:08	LINE FAULT
428	9-Feb-2022	TUMKUR	66	ANTHRASANAHALI 220KV-BELLAVI	BELLAVI_66,MALLASANDRA_66, HEGGERE_66, DODDASARANGI_66	17:34	18:53	1:19	LINE CLEAR AVAILED
429	9-Feb-2022	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	10:14	11:10	0:55	LINE CLEAR AVAILED
430	9-Feb-2022	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	14:02	14:44	0:41	LINE CLEAR AVAILED
431	9-Feb-2022	TUMKUR	66	CHITRADURGA 220kv-PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	9:55	17:16	7:21	LINE CLEAR AVAILED
432	9-Feb-2022	TUMKUR	66	TR-1	CITRADURGA_66	14:09	14:46	0:37	MAIN SUPPLY FAILURE
433	9-Feb-2022	TUMKUR	66	TR-1	DEVARAHALLI_66	19:48	19:57	0:08	TRANSFORMER FAULT
434	9-Feb-2022	TUMKUR	66	CHITRADURGA 220kv-CHITRADURGA 1	CHITRADURGA_220	14:14	14:29	0:14	LINE FAULT
435	9-Feb-2022	TUMKUR	66	CHITRADURGA 220kv-CHITRADURGA 1	CHITRADURGA_220	16:20	16:43	0:23	LINE FAULT
436	9-Feb-2022	TUMKUR	66	CHITRADURGA 220kv-CHITRADURGA 1	CHITRADURGA_220	17:16	17:37	0:21	LINE FAULT
437	9-Feb-2022	TUMKUR	66	HANAGAL-THALLAK 1	HANAGAL_66	16:59	18:10	1:10	LINE CLEAR AVAILED
438	9-Feb-2022	TUMKUR	66	HARIYABBE-PD KOTE	HARIYABBE_66	15:17	17:54	2:36	LINE CLEAR AVAILED
439	9-Feb-2022	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEE LAGUNDA_66	2:17	2:23	0:06	LINE FAULT
440	9-Feb-2022	TUMKUR	66	TR-1(LV SIDE)	KIADB V N PURA_220	12:43	12:46	0:03	HAND TRIPPED
441	9-Feb-2022	TUMKUR	66	TR-2	KIADB V N PURA_220	13:23	13:32	0:09	HAND TRIPPED
442	9-Feb-2022	TUMKUR	66	TR-2	KIADB V N PURA_220	14:53	19:47	4:54	LINE CLEAR AVAILED
443	9-Feb-2022	TUMKUR	66	KIADB V N PURA220-TMTP_6	TMTP_66	12:56	13:00	0:04	HAND TRIPPED
444	9-Feb-2022	TUMKUR	66	PAVAGADA220-MEDEGESHI66	MEDIGESHI_66,I D HALLI_66,HOSKERE_66	9:50	10:35	0:45	LINE FAULT
445	9-Feb-2022	TUMKUR	66	PAVAGADA220-MEDEGESHI66	MEDIGESHI_66,I D HALLI_66,HOSKERE_66	9:10	9:15	0:05	LINE FAULT
446	9-Feb-2022	TUMKUR	66	PAVAGADA220-NAGALAMADIKE66	PAVAGADA_220	18:03	18:10	0:07	LINE FAULT
447	9-Feb-2022	TUMKUR	66	PAVAGADA220-SHYLAPURA_66	SHYLAPURA_66	18:03	18:10	0:06	LINE FAULT
448	9-Feb-2022	TUMKUR	66	PAVAGADA220-YNHOSAKOTE	YNHOSAKOTE_66	18:03	18:10	0:06	LINE FAULT
449	9-Feb-2022	TUMKUR	66	TR-2	RAMAPURA_66	8:01	8:07	0:05	TRANSFORMER FAULT
450	9-Feb-2022	TUMKUR	66	TR-2	SANIKERE_66	13:39	13:43	0:03	TRANSFORMER FAULT
451	9-Feb-2022	TUMKUR	66	TR-2	HIRIYUR_66	10:12	18:20	8:08	LINE CLEAR AVAILED
452	9-Feb-2022	TUMKUR	66	TR-1	KADAJJI_66	18:25	18:30	0:05	HAND TRIPPED
453	9-Feb-2022	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:03	13:30	1:27	LINE CLEAR AVAILED
454	9-Feb-2022	TUMKUR	66	MELKOTE-BADIHALLI	MELKOTE_66	17:40	18:43	1:02	LOAD CURTAILMENT
455	9-Feb-2022	TUMKUR	66	MIDIGESHI-MADHUGIRI_220KV	MEDIGESHI_66	10:40	11:37	0:57	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
456	9-Feb-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	9:05	9:15	0:10	LINE FAULT
457	9-Feb-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	12:08	12:17	0:09	LINE FAULT
458	9-Feb-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	17:00	17:11	0:10	LINE FAULT
459	9-Feb-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	18:10	18:19	0:09	LINE FAULT
460	9-Feb-2022	TUMKUR	66	PDKOTE-HARIYABBE	PDKOTE_66	15:16	17:53	2:37	LINE CLEAR AVAILED
461	9-Feb-2022	TUMKUR	66	TR-1	PDKOTE_66	15:16	17:54	2:38	LINE CLEAR AVAILED
462	10-Feb-2022	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
463	10-Feb-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
464	10-Feb-2022	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
465	10-Feb-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
466	10-Feb-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN,LINE FAULT
467	10-Feb-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
468	10-Feb-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
469	10-Feb-2022	BAGALKOT	220	AMBEWADI-NAGJHARI2	STATION NOT AFFECTED AMBEWDI_220	16:25 (09.02.2022)	16:14 (10.02.2022)	23:49HRS	LINE CHARGED
470	10-Feb-2022	BAGALKOT	110	110/33KV,HV2	ANKOLA_110	8:32	8:39	0:07	TRANSFORMER FAULT
471	10-Feb-2022	BAGALKOT	110	110/11KV,HV2	CHANDKAVATE_110	16:10	16:50	0:40	HAND TRIPPED
472	10-Feb-2022	BAGALKOT	110	GAJENDRAGAD-RON 1&2	GAJENDRAGAD_110	15:33	15:51	0:18	HAND TRIPPED
473	10-Feb-2022	BAGALKOT	110	110/33KV,HV2	GULEDGUDD_110 & SHIRUR&KAMATAGI_33	16:33	17:12	0:39	HAND TRIPPED
474	10-Feb-2022	BAGALKOT	110	110/11KV,HV1	GUTTAL_110	11:02	11:15	0:13	TRANSFORMER FAULT
475	10-Feb-2022	BAGALKOT	110	110/11KV,HV1	GUTTAL_110	11:31	11:40	0:09	TRANSFORMER FAULT
476	10-Feb-2022	BAGALKOT	110	110/11KV,HV1	GUTTAL_110	12:08	12:15	0:07	TRANSFORMER FAULT
477	10-Feb-2022	BAGALKOT	110	110/11KV,HV2	HANAGAL_110	10:58	13:50	2:52	LINE CLEAR AVAILED
478	10-Feb-2022	BAGALKOT	110	YELPARHATTI-KUDACHI220	YELPARHATTI_110	10:14	14:13	3:59	LINE CLEAR AVAILED
479	10-Feb-2022	BAGALKOT	110	110/11KV, HV1	YELPARHATTI_110	10:14	14:15	4:01	LINE CLEAR AVAILED
480	10-Feb-2022	BAGALKOT	110	110/11KV, HV2	YELPARHATTI_110	10:14	14:15	4:01	LINE CLEAR AVAILED
481	10-Feb-2022	BAGALKOT	110	110/11KV, HV1	UAS DHARWAD_110	10:15	18:20	8:05	LINE CLEAR AVAILED
482	10-Feb-2022	BAGALKOT	110	110/11KV, HV2	UAS DHARWAD_110	10:15	18:20	8:05	LINE CLEAR AVAILED
483	10-Feb-2022	BAGALKOT	110	UAS DHARWAD-MR NAGAR	UAS DHARWAD_110	10:36	17:45	7:09	LINE CLEAR AVAILED
484	10-Feb-2022	BAGALKOT	110	UAS DHARWAD- NARENDRA220	UAS DHARWAD_110	11:17	17:30	6:13	LINE CLEAR AVAILED
485	10-Feb-2022	BAGALKOT	110	110/33KV, HV2	KALABILAGI_33, HIREPADASALAGI LIS_33 & TUNGAL LIS_33 STATION NOT AFFECTED SAVALAGI_110	10:30	12:24	1:54	LINE CLEAR AVAILED
486	10-Feb-2022	BAGALKOT	110	NANADI-DODDANNAVAR SOLAR	DODDANNAVAR SOLAR IPP_110 NANADI_110	10:20	12:34	2:14	LINE CLEAR AVAILED
487	10-Feb-2022	BAGALKOT	110	NANADI-CHIKKODI220	NANADI_110	10:32	12:35	2:03	LINE CLEAR AVAILED
488	10-Feb-2022	BAGALKOT	110	110/11KV, HV1	NANADI_110	10:37	16:54	6:17	LINE CLEAR AVAILED
489	10-Feb-2022	BAGALKOT	110	110/11KV, HV2	NANADI_110	10:37	17:01	6:24	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
490	10-Feb-2022	BAGALKOT	110	MR NAGAR-UAS DHARWAD (NARENDRA2)	UAS DHARWAD_110	10:35	18:20	7:45	NFBC ISSUED
491	10-Feb-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KUD DHARWAD_110	10:39	12:40	2:01	LINE CLEAR AVAILED
492	10-Feb-2022	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	11:48	13:13	1:25	LINE CLEAR AVAILED
493	10-Feb-2022	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	6:08	12:36	6:28	LINE CLEAR AVAILED
494	10-Feb-2022	BAGALKOT	110	RANEBENNUR- RATTIHALLI(TUMMINAKATTI)	TUMMINAKATTI_110	6:56	6:58	0:02	HAND TRIPPED
495	10-Feb-2022	BAGALKOT	110	RANEBENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEBENNUR_220	12:22 (10.02.2022)			LINE OPEN,LINE CLEAR AVAILED
496	10-Feb-2022	BAGALKOT	110	CHIKKODI-BHOJ(NANADI)	NANADI_110	10:27	12:10	1:43	LINE CLEAR AVAILED
497	10-Feb-2022	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	11:42	11:50	0:08	LINE FAULT
498	10-Feb-2022	BAGALKOT	110	SOUDATTI- NARGUND(RAMADURGA1)	STATION NOT AFFECTED SOUNDATTI_220	18:58	19:06	0:08	LINE FAULT
499	10-Feb-2022	BAGALKOT	220	BIJAPUR-VAISHALI1	STATION NOT AFFECTED BIJAPUR_220	10:25	17:13	6:48	LINE CLEAR AVAILED
500	10-Feb-2022	BAGALKOT	220	BIJAPUR-VAISHALI2	STATION NOT AFFECTED BIJAPUR_220	11:04	17:13	6:09	LINE CLEAR AVAILED
501	10-Feb-2022	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	2:43	8:24	5:41	LINE FAULT
502	10-Feb-2022	BAGALKOT	110	HAVERI-HANAGAL(TILUVALI)	HAVERI_220	11:10	13:27	2:17	LINE CLEAR AVAILED
503	10-Feb-2022	BAGALKOT	110	AMBEWADI220- NK-1 (KAWALWADA)	STATION NOT AFFECTED AMBEWADI_220	10:25 (04.02.2022)	17:17 (10.02.2022)	150:52HRS	LINE CHARGED
504	10-Feb-2022	BAGALKOT	110	AMBEWADI220- NK-2 (HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	10:28 (04.02.2022)	17:18 (10.02.2022)	150:50HRS	LINE CHARGED
505	10-Feb-2022	BAGALKOT	220	AMBEWADI-NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	12:33	16:16	3:43	LINE CLEAR AVAILED
506	10-Feb-2022	BAGALKOT	110	RAMDURGA-SAUDATTI1	STATION NOT AFFECTED RAMADURGA_110	18:30	19:05	0:35	LINE FAULT
507	10-Feb-2022	BAGALKOT	110	ATHANI220-BALIGERI	BALIGERI_110	12:14	12:23	0:09	LINE FAULT
508	10-Feb-2022	BENGALURU	66	HV1	AMAR JYOTHI	12:12	12:19	0:07	LINE CLEAR AVAILED
509	10-Feb-2022	BENGALURU	66	HV2	GLOBAL TECH PARK	9:17	9:20	0:03	LINE CLEAR AVAILED
510	10-Feb-2022	BENGALURU	66	ITI 220 - NGEF	NGEF, NGEF(EHT)	10:13	17:11	6:58	LINE CLEAR AVAILED
511	10-Feb-2022	BENGALURU	66	PRIMAL - VIKAS TECH PARK 220	PRIMAL	11:01	12:55	1:54	LINE CLEAR AVAILED
512	10-Feb-2022	BENGALURU	66	HV1	PRIMAL	12:56	13:01	0:05	LINE CLEAR AVAILED
513	10-Feb-2022	BENGALURU	66	HV2	PRIMAL	15:10	15:15	0:05	LINE CLEAR AVAILED
514	10-Feb-2022	BENGALURU	66	RAJANUKUTE - YELAHANKA 220	RAJANUKUNTE	16:35	16:45	0:10	MAIN SUPPLY FAILURE
515	10-Feb-2022	BENGALURU	66	YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	10:10	16:57	6:47	LINE CLEAR AVAILED
516	10-Feb-2022	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	11:11	11:17	0:06	LOAD CHANGE OVER
517	10-Feb-2022	BENGALURU	66	L R BANDE - HBR LAYOUT	L R BANDE	12:44	12:51	0:07	LOAD CHANGE OVER
518	10-Feb-2022	BENGALURU	66	HV2	ATTUR YELAHANKA	15:12	15:15	0:03	LINE CLEAR AVAILED
519	10-Feb-2022	BENGALURU	66	HV2	ATTUR YELAHANKA	15:30	15:32	0:02	LOAD CHANGE OVER
520	10-Feb-2022	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	18:32	18:42	0:10	LINE FAULT
521	10-Feb-2022	BENGALURU	66	HV2	GOWRIBIDANUR 220	16:28	16:38	0:10	LINE CLEAR AVAILED
522	10-Feb-2022	BENGALURU	220	HV2	DB PURA 220	10:00	16:00	6:00	LINE CLEAR AVAILED
523	10-Feb-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA	10:00	16:38	6:38	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
524	10-Feb-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	10:00	16:07	6:07	LINE CLEAR AVAILED
525	10-Feb-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	10:00	17:25	7:25	LINE CLEAR AVAILED
526	10-Feb-2022	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	16:33	16:45	0:11	LINE FAULT
527	10-Feb-2022	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTURU	GUNDLU KOTTURU	4:55	5:09	0:13	LINE FAULT
528	10-Feb-2022	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	3:07	3:26	0:19	LINE FAULT
529	10-Feb-2022	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	5:53	6:01	0:08	LINE FAULT
530	10-Feb-2022	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	6:37	6:52	0:14	LINE FAULT
531	10-Feb-2022	BENGALURU	220	DABUSPET 220 - KADUR 220	DABUSPET 220	11:44	18:59	7:15	LOAD CURTAILMENT
532	10-Feb-2022	BENGALURU	66	HV2	YEDUMADU	11:30	11:35	0:05	LINE CLEAR AVAILED
533	10-Feb-2022	BENGALURU	66	HV2	THAYALUR	9:13	9:27	0:13	TRANSFORMER FAULT
534	10-Feb-2022	BENGALURU	66	HV1	THAYALUR	4:10	4:20	0:10	TRANSFORMER FAULT
535	10-Feb-2022	BENGALURU	66	HV1	SM MANGALA	16:54	18:10	1:15	LINE CLEAR AVAILED
536	10-Feb-2022	BENGALURU	66	HV2	SM MANGALA	16:54	17:18	0:24	LINE CLEAR AVAILED
537	10-Feb-2022	BENGALURU	66	HV2	MAASTHI	10:10	10:25	0:14	TRANSFORMER FAULT
538	10-Feb-2022	BENGALURU	66	HV2	KEMBODI	14:15	14:30	0:15	LINE CLEAR AVAILED
539	10-Feb-2022	BENGALURU	220	KOTIPURA 220 - TUBINAKERE 220	NO STATION AFFECTED	18:15(09/02/2022)	11:31(10/02/2022)	17:16HRS	LINE CHARGED
540	10-Feb-2022	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN,LINE FAULT
541	10-Feb-2022	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN,LINE FAULT
542	10-Feb-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
543	10-Feb-2022	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	2:26	2:41	0:15	LINE FAULT
544	10-Feb-2022	GULBARGA	220	KUDLIGI-HM HOLI_1&2	KUDALIGI_220	10:45	16:35	5:50	LINE CLEAR AVAILED
545	10-Feb-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	23:58(10.2.2022)			LINE OPEN,LINE FAULT
546	10-Feb-2022	GULBARGA	220	HV1	SINDHANOOR_220	9:05	9:15	0:10	TRANSFORMER FAULT
547	10-Feb-2022	GULBARGA	220	HV1	SINDHANOOR_220	11:37	12:57	1:20	LINE CLEAR AVAILED
548	10-Feb-2022	GULBARGA	220	LINGAPUR-GUDHALLI1	LINGAPUR_220	9:46	18:34	8:48	LINE CLEAR AVAILED
549	10-Feb-2022	GULBARGA	220	KAPNOOR-HUMNABAD2	KAPNOOR_220	17:05	21:20	4:15	LINE CLEAR AVAILED
550	10-Feb-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
551	10-Feb-2022	GULBARGA	110	SEDAM-ULTRATECH	SEDAM_220	9:15	17:16	8:01	LINE CLEAR AVAILED
552	10-Feb-2022	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	9:46	9:55	0:09	MAIN SUPPLY FAILURE
553	10-Feb-2022	GULBARGA	110	GABBUR-RAICHUR	GABBUR_110	8:25	8:40	0:15	MAIN SUPPLY FAILURE
554	10-Feb-2022	GULBARGA	110	HV1	KAMALANAGAR_110	9:02	9:16	0:14	TRANSFORMER FAULT
555	10-Feb-2022	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMERESHWAR_110	3:10	3:16	0:08	MAIN SUPPLY FAILURE
556	10-Feb-2022	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMERESHWAR_110	20:20	20:39	0:08	MAIN SUPPLY FAILURE
557	10-Feb-2022	GULBARGA	110	BAYYAPUR-MUDAGAL	BAYYAPURA_110	13:25	14:05	0:08	MAIN SUPPLY FAILURE
558	10-Feb-2022	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,MUDDAPURA_11 0	2:57	3:06	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
559	10-Feb-2022	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,MUDDAPURA_110	4:47	4:55	0:08	LINE FAULT
560	10-Feb-2022	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,MUDDAPURA_110	21:20	21:31	0:11	LINE FAULT
561	10-Feb-2022	GULBARGA	110	YERADONA-SINDHANOOR	YERADONA_110,BENUR_110	9:05	9:20	0:15	MAIN SUPPLY FAILURE
562	10-Feb-2022	GULBARGA	110	YERADONA-BENUR	BENUR_110	0:50	0:55	0:05	LINE FAULT
563	10-Feb-2022	GULBARGA	110	JAWALGERA-SINDHANOOR	JAWALGERA_110	9:05	9:15	0:10	MAIN SUPPLY FAILURE
564	10-Feb-2022	GULBARGA	110	JAWALGERA-SINDHANOOR	JAWALGERA_110	16:30	17:25	0:55	MAIN SUPPLY FAILURE
565	10-Feb-2022	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	11:15	12:55	1:40	MAIN SUPPLY FAILURE
566	10-Feb-2022	GULBARGA	110	GABBUR-RAICHUR	GABBUR_110	8:25	8:40	0:15	MAIN SUPPLY FAILURE
567	10-Feb-2022	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	13:27	14:00	0:33	MAIN SUPPLY FAILURE
568	10-Feb-2022	GULBARGA	110	HV2	MATAMARI_110	1:20	1:25	0:05	TRANSFORMER FAULT
569	10-Feb-2022	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	7:25	8:32	1:07	LOAD CURTAILMENT
570	10-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,GABBUR_110	8:24	8:40	0:16	LINE CLEAR AVAILED
571	10-Feb-2022	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	6:04	6:14	0:10	LINE FAULT
572	10-Feb-2022	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	1:45	1:53	0:08	LINE FAULT
573	10-Feb-2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110,MANVI_110	20:30	20:40	0:10	LINE FAULT
574	10-Feb-2022	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDI NNI_110	23:06	23:16	0:10	LINE FAULT
575	10-Feb-2022	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	19:18	19:28	0:10	LINE FAULT
576	10-Feb-2022	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_220	3:10	3:44	0:34	LOAD CURTAILMENT
577	10-Feb-2022	GULBARGA	110	LV1	HALBARGA_220	10:30	16:06	5:36	LINE CLEAR AVAILED
578	10-Feb-2022	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	14:25	14:32	0:07	LINE FAULT
579	10-Feb-2022	GULBARGA	110	KAPNOOR-GULBARGA WEST 1&2	GULBARGA WEST_110,GULBARGA SOUTH_110	9:45	17:13	7:28	LINE CLEAR AVAILED
580	10-Feb-2022	GULBARGA	110	KAPNOOR-GULBARGA NORTH1,2	GULBARGA NORTH_110,GULBARGA SOUTH_110,GULBARGA UNIVERSITY_110	10:00	10:11	0:11	LINE FAULT
581	10-Feb-2022	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARGUTTI_110	12:41	17:18	4:37	LINE CLEAR AVAILED
582	10-Feb-2022	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	9:30	17:18	7:48	LINE CLEAR AVAILED
583	10-Feb-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAISAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	5:30	5:34	0:04	LINE FAULT
584	10-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR1,2	DEODURGA_110	5:50	5:54	0:04	LINE FAULT
585	10-Feb-2022	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	6:17	6:41	0:24	LINE CLEAR AVAILED
586	10-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	8:29	20:08	11:39	LINE CLEAR AVAILED
587	10-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	8:29(10.8.22)			LINE OPEN,LINE CLEAR AVAILED
588	10-Feb-2022	GULBARGA	66	NEELAGUNDA-HP HALLI_1	HP HALLI_66	19:04(10.02.2022)	00:10(11.02.2022)	04:56HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
589	10-Feb-2022	GULBARGA	66	KUDLIGI-KUDLIGI_66	KUDLIGI_66,HANSI_66	9:30	10:20	0:50	CB OPENED OUT FOR TAKING BACK FEEDING FROM 66KV MUSS KUDLING . THE ARRENGING POWER SUPPLY TO 66KV DOWN STRAMS DUE TO 220KV SAID QUTRALY MAINTAINCE WORK CARRY OUT AT 220KV MUSS KUDLIGI.MEAN WHILE ALL 66KV LINES ARE INTERRUPTED AND CHARGED AT 10:25HRS.STATION LOAD EFFECTED
590	10-Feb-2022	GULBARGA	66	LV1	KUDALIGI_220	10:10	10:20	0:10	LINE CLEAR AVAILED
591	10-Feb-2022	GULBARGA	66	KUDLIGI-KUDLIGI_66	KUDLIGI_66,HANSI_66	16:40	17:20	0:40	LINE CLEAR AVAILED
592	10-Feb-2022	GULBARGA	66	HANASI-BADALADUKU	HANASI_66	9:35	9:50	0:15	MAIN SUPPLY FAILURE
593	10-Feb-2022	GULBARGA	66	HANASI-BADALADUKU	HANASI_66	17:10	17:20	0:10	MAIN SUPPLY FAILURE
594	10-Feb-2022	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:30(9.01.2022)	11:19(10.02.2022)	25:48 hrs	LINE CHARGED
595	10-Feb-2022	HASSAN	110	JOG110-AMBTR2	JOG_110	13:08 (26.01.2022)			LINE OPEN,LINE FAULT
596	10-Feb-2022	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN,LINE CLEAR AVAILED
597	10-Feb-2022	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN,LINE CLEAR AVAILED
598	10-Feb-2022	HASSAN	110	SAGARA-SS2	SAGARA_110	18:05(10.02.2022)			LINE OPEN,LINE FAULT
599	10-Feb-2022	HASSAN	220	KADUR-DABUSET	KADUR_220	13:33	19:42	6:09	LINE FAULT
600	10-Feb-2022	HASSAN	110	HV1	PUTTUR_110	10:38	18:29	7:51	LINE CLEAR AVAILED
601	10-Feb-2022	HASSAN	110	HV2	PUTTUR_110	10:39	18:29	7:50	LINE CLEAR AVAILED
602	10-Feb-2022	HASSAN	110	HV1	ANANDAPURA_110	18:11	19:49	1:38	LINE CLEAR AVAILED
603	10-Feb-2022	HASSAN	110	HV2	ANANDAPURA_110	11:00	11:25	0:25	TRANSFORMER FAULT
604	10-Feb-2022	HASSAN	110	HV2	ANANDAPURA_110	18:11	20:04	1:53	LINE CLEAR AVAILED
605	10-Feb-2022	HASSAN	110	ANANDA-SHIMOGA	ANANDAPURA_110	18:11	19:48	1:37	LINE CLEAR AVAILED
606	10-Feb-2022	HASSAN	110	HV2	ANAVATTI_110	11:51	12:29	0:38	HAND TRIPPED
607	10-Feb-2022	HASSAN	110	HV1	BARANGI_110	15:47	16:33	0:46	LINE CLEAR AVAILED
608	10-Feb-2022	HASSAN	110	HV2	BARANGI_110	14:01	14:27	0:26	LINE CLEAR AVAILED
609	10-Feb-2022	HASSAN	110	HV2	BARANGI_110	17:54	19:56	2:02	TRANSFORMER FAULT
610	10-Feb-2022	HASSAN	110	HV2	KITTADAHALLI_110	17:00	19:52	2:52	LINE CLEAR AVAILED
611	10-Feb-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	12:19	12:57	0:38	LINE CLEAR AVAILED
612	10-Feb-2022	HASSAN	110	MRSSHM-SS2	MRSMSG_220	18:04	19:48	1:44	LINE FAULT
613	10-Feb-2022	HASSAN	220	HV2	MSEZ_220	9:57	15:38	5:41	LINE CLEAR AVAILED
614	10-Feb-2022	HASSAN	110	HV1	NANDIKUR_110	12:33	13:32	0:59	LINE CLEAR AVAILED
615	10-Feb-2022	HASSAN	110	HV2	NANDIKUR_110	10:10	12:30	2:20	LINE CLEAR AVAILED
616	10-Feb-2022	HASSAN	110	NANDIKU-SUZLON	NANDIKUR_110	13:20	14:24	1:04	LINE CLEAR AVAILED
617	10-Feb-2022	HASSAN	110	NANDIKU-ISTRLL	NANDIKUR_110	11:47	14:34	2:47	LINE CLEAR AVAILED
618	10-Feb-2022	HASSAN	110	NANDIKU-BELMAN	NANDIKUR_110	14:08	14:16	0:08	HAND TRIPPED
619	10-Feb-2022	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	14:08	14:16	0:08	HAND TRIPPED
620	10-Feb-2022	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	14:08	14:16	0:08	HAND TRIPPED
621	10-Feb-2022	HASSAN	110	PUTTUR-PUTTUR11	PUTTUR_220	7:59	18:23	10:24	LINE CLEAR AVAILED
622	10-Feb-2022	HASSAN	110	SAGARA-SORABA	SAGARA_110	18:05	19:10	1:05	LINE CLEAR AVAILED
623	10-Feb-2022	HASSAN	66	HASSN22-MALLALI	HASSN_220	17:14	17:18	0:04	HAND TRIPPED
624	10-Feb-2022	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYAPATNA_220	13:25	13:30	0:05	HAND TRIPPED
625	10-Feb-2022	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYAPATNA_220	15:57	16:00	0:03	HAND TRIPPED
626	10-Feb-2022	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	10:41	13:36	2:55	LINE CLEAR AVAILED
627	10-Feb-2022	HASSAN	66	DIDDAHA-HOOTGALLI	DODDAHALLI_66	15:30	15:46	0:16	LINE CLEAR AVAILED
628	10-Feb-2022	HASSAN	66	HV1	DODDAHALLI_66	15:47	16:10	0:23	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
629	10-Feb-2022	HASSAN	66	MATTNAV-DIDGTHL	MATTANAVILE_66	16:12	17:04	0:52	LINE CLEAR AVAILED
630	10-Feb-2022	MYSURU	66	HV1	BETTADHAPURA_66	17:00	18:20	1:19	LINE CLEAR AVAILED
631	10-Feb-2022	MYSURU	66	HV1	BGPURA_66	7:45	9:26	1:41	LINE CLEAR AVAILED
632	10-Feb-2022	MYSURU	66	HV2	BILIKERE_66	16:07	16:15	0:07	TRANSFORMER FAULT
633	10-Feb-2022	MYSURU	66	HV1	COWDALLI_66	14:12	14:25	0:13	TRANSFORMER FAULT
634	10-Feb-2022	MYSURU	220	HV1	CRNAGAR_220	10:54	15:00	4:06	LINE CLEAR AVAILED
635	10-Feb-2022	MYSURU	220	HV2	CRNAGAR_220	15:06	17:44	2:37	LINE CLEAR AVAILED
636	10-Feb-2022	MYSURU	66	HV1	CRNAGAR_220	12:50	14:54	2:04	LINE CLEAR AVAILED
637	10-Feb-2022	MYSURU	66	HV1	DEVANOORNGUDU_66	14:50	16:08	1:17	LINE CLEAR AVAILED
638	10-Feb-2022	MYSURU	66	HV1	GUNDULPET_66	17:30	19:00	1:30	LINE CLEAR AVAILED
639	10-Feb-2022	MYSURU	220	KADAKOLA-BEGUR 2	NO STATIONS EFFECTED	10:14	11:59	1:44	LINE CLEAR AVAILED
640	10-Feb-2022	MYSURU	66	KADAKOLA-SARAGURU 2	DOORA_66 HURA_66 HULLAHALLI_66	14:15	15:19	1:04	NFBC ISSUED
641	10-Feb-2022	MYSURU	66	HV1	KAGGERE HAMPAPURA_66	15:30	15:45	0:15	MAIN SUPPLY FAILURE
642	10-Feb-2022	MYSURU	66	HV1	KIKKERI_66	16:01	17:13	1:11	LINE CLEAR AVAILED
643	10-Feb-2022	MYSURU	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	15:50	15:54	0:04	LINE FAULT
644	10-Feb-2022	MYSURU	66	KR PETE 220- MADESHWARAPURA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 MADESWARAPURA_66 NAGAMANGALA_66	16:00	16:06	0:05	LINE FAULT
645	10-Feb-2022	MYSURU	66	HV1	MADDUR_66	12:12	16:12	4:00	LINE CLEAR AVAILED
646	10-Feb-2022	MYSURU	66	HV1	MADIKERI_66	10:31	15:24	4:53	LINE CLEAR AVAILED
647	10-Feb-2022	MYSURU	66	HV5	SFCSHIVA_66	20:10			TRANSFORMER OPEN, LINE CLEAR AVAILED
648	10-Feb-2022	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)			LINE OPEN,LINE CLEAR AVAILED
649	10-Feb-2022	MYSURU	66	TN PURA-THAYUR	NO STATIONS EFFECTED	11:57:36 (13/1/2022)			LINE OPEN,LINE CLEAR AVAILED
650	10-Feb-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
651	10-Feb-2022	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16(8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
652	10-Feb-2022	MYSURU	66	HV5	SFCSHIVA_66	15:53:19 (09/02/2022)	14:41:42	22:48HRs	TRANSFORMER CHARGED
653	10-Feb-2022	TUMKUR	220	TR-1	HONNALLI_66	11:25	15:04	3:38	LINE CLEAR AVAILED
654	10-Feb-2022	TUMKUR	220	KDBVNP- MADHUGIRI220	KDBVNO_220	12:18	12:20	0:01	HAND TRIPPED
655	10-Feb-2022	TUMKUR	220	TR-2	KDBVNO_220	12:29	12:32	0:03	HAND TRIPPED
656	10-Feb-2022	TUMKUR	110	TR-1	HANDANKERE_110	14:17	14:24	0:07	LINE CLEAR AVAILED
657	10-Feb-2022	TUMKUR	110	TR-2	HANDANKERE_110	13:30	14:30	1:00	LINE CLEAR AVAILED
658	10-Feb-2022	TUMKUR	110	TR-2	HANDANKERE_110	15:35	18:05	2:30	LINE CLEAR AVAILED
659	10-Feb-2022	TUMKUR	110	CHIKKANAYAKANAHALLI- HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	14:17	14:24	0:07	LOAD CURTAILMENT
660	10-Feb-2022	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	11:52	12:27	0:34	LINE FAULT
661	10-Feb-2022	TUMKUR	66	ANTHRASANAHALLI 220KV- BELLAVI	BELLAVI_66	11:29	11:53	0:24	LINE FAULT
662	10-Feb-2022	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	12:24	12:28	0:03	LINE FAULT
663	10-Feb-2022	TUMKUR	66	CHITRADURGA 220kV- CHITRADURGA2	CHITRADURGA_220	12:31	13:27	0:55	LINE CLEAR AVAILED
664	10-Feb-2022	TUMKUR	66	TR-1	HIRIYUR_66	10:07	16:32	6:25	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
665	10-Feb-2022	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	16:26	16:28	0:02	LOAD CURTAILMENT
666	10-Feb-2022	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	15:26	16:28	1:02	LOAD CURTAILMENT
667	10-Feb-2022	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	15:26	16:26	1:00	LOAD CURTAILMENT
668	10-Feb-2022	TUMKUR	66	TR-1	HONNALLI_220	11:14	11:22	0:08	LOAD CURTAILMENT
669	10-Feb-2022	TUMKUR	66	TR-1	HONNALLI_220	15:06	15:14	0:08	LOAD CURTAILMENT
670	10-Feb-2022	TUMKUR	66	TR-2	HONNALLI_220	11:14	15:19	4:05	LINE CLEAR AVAILED
671	10-Feb-2022	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	11:14	11:44	0:30	LOAD CURTAILMENT
672	10-Feb-2022	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:06	15:19	0:13	LOAD CURTAILMENT
673	10-Feb-2022	TUMKUR	66	TR-1(LV SIDE)	HONNALLI_220	11:25	15:05	3:39	LINE CLEAR AVAILED
674	10-Feb-2022	TUMKUR	66	TR-1(LV SIDE)	HONNALLI_220	15:13	15:14	0:01	LOAD CURTAILMENT
675	10-Feb-2022	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	11:14	11:24	0:09	LOAD CURTAILMENT
676	10-Feb-2022	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	15:06	15:19	0:12	LOAD CURTAILMENT
677	10-Feb-2022	TUMKUR	66	TR-1	KDBVNO_220	12:49	12:50	0:01	HAND TRIPPED
678	10-Feb-2022	TUMKUR	66	TR-2	KDBVNO_220	13:47	19:20	5:32	LINE CLEAR AVAILED
679	10-Feb-2022	TUMKUR	66	TR-2	KORA_66	9:42	10:04	0:22	TRANSFORMER FAULT
680	10-Feb-2022	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:14	12:29	3:14	NFBC ISSUED
681	10-Feb-2022	TUMKUR	66	TR-1	LINGADHALLI_66	12:23	12:46	0:22	LINE CLEAR AVAILED
682	10-Feb-2022	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	6:15	6:19	0:04	LINE FAULT
683	10-Feb-2022	TUMKUR	66	TR-1	NAGASAMUDRA_66	11:20	12:51	1:31	LINE CLEAR AVAILED
684	10-Feb-2022	TUMKUR	66	TR-2	PATTNAYAKANAHALLI_66	12:02	12:12	0:09	TRANSFORMER FAULT
685	10-Feb-2022	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	15:04	15:15	0:10	HAND TRIPPED
686	10-Feb-2022	TUMKUR	66	PAVAGADA220-MIDIGESHI	MIDIGESHI_66	13:04	13:14	0:09	LINE FAULT
687	10-Feb-2022	TUMKUR	66	SANIKERE- HIRIYUR	SANIKERE_66	12:46	16:35	3:48	LINE CLEAR AVAILED
688	10-Feb-2022	TUMKUR	66	TR-2	SIRA_66	13:25	13:43	0:18	TRANSFORMER FAULT
689	11-Feb-2022	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
690	11-Feb-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
691	11-Feb-2022	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
692	11-Feb-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
693	11-Feb-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN,LINE FAULT
694	11-Feb-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
695	11-Feb-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
696	11-Feb-2022	BAGALKOT	110	RANEENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	12:22 (10.02.2022)			LINE OPEN,LINE CLEAR AVAILED
697	11-Feb-2022	BAGALKOT	110	110/11KV,HV2	HANAGAL_110	14:03	17:48	3:45	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
698	11-Feb-2022	BAGALKOT	220	220/110KV,HV2 & LV2	KUDACHI_220	14:49	15:43	0:54	LINE CLEAR AVAILED
699	11-Feb-2022	BAGALKOT	110	KUDACHI-AINAPUR	AINAPUR_110	10:34	12:37	2:03	LINE CLEAR AVAILED
700	11-Feb-2022	BAGALKOT	110	UDIKERI-NOKAR SOLAR(SOUDATTI)	UDIKERI_110	8:15	8:55	0:40	LINE CLEAR AVAILED
701	11-Feb-2022	BAGALKOT	110	UDIKERI-NOKAR SOLAR(SOUDATTI)	UDIKERI_110	9:32	10:08	0:36	LINE FAULT
702	11-Feb-2022	BAGALKOT	110	110/33KV, HV4	HALASANGI_33, NEVARGI_33 & DULAKHED_33 STATION NOT AFFECTED ZALKI_110	10:52	10:56	0:04	TRANSFORMER FAULT
703	11-Feb-2022	BAGALKOT	110	YELLAMMANAWADI-ALBAL	ALBAL_110	5:06	5:18	0:12	LINE FAULT
704	11-Feb-2022	BAGALKOT	220	CHIKODI-BELGAUM1	STATION NOT AFFECTED CHIKODI_220	10:34	13:07	2:33	LINE CLEAR AVAILED
705	11-Feb-2022	BAGALKOT	220	HUBLI-NAGJHARI3	STATION NOT AFFECTED HUBLI_220	17:20 (11.02.2022)			LINE OPEN,LINE FAULT
706	11-Feb-2022	BAGALKOT	220	BELGAVI-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:37	13:07	2:30	NFBC ISSUED
707	11-Feb-2022	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	5:07	5:16	0:09	LINE FAULT
708	11-Feb-2022	BAGALKOT	110	MUNDARAGI-SINGATALUR	SINGATALUR_110	3:50	4:15	0:25	MAIN SUPPLY FAILURE
709	11-Feb-2022	BAGALKOT	110	MUNDARAGI-SINGATALUR	SINGATALUR_110	6:30	8:55	2:25	MAIN SUPPLY FAILURE
710	11-Feb-2022	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)	15:56 (12.02.2022)	8469:57HRS	LINE CHARGED
711	11-Feb-2022	BENGALURU	66	BRIGADE MEADOWS - SHOBHA FOREST	SHOBHA FOREST	8:30	8:54	0:24	LINE FAULT
712	11-Feb-2022	BENGALURU	66	HV2	ELECTRONIC CITY PH-2 SEC-2	15:39	15:45	0:06	TRANSFORMER FAULT
713	11-Feb-2022	BENGALURU	66	HV2	HANUMANTHNAGARA	1:40	2:05	0:25	TRANSFORMER FAULT
714	11-Feb-2022	BENGALURU	66	HV2	HOODY 220	13:35	14:42	1:07	LINE CLEAR AVAILED
715	11-Feb-2022	BENGALURU	66	HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTHINIKETHAN	14:47	15:37	0:50	LINE CLEAR AVAILED
716	11-Feb-2022	BENGALURU	220	HV2	HOODY 220	18:38	19:11	0:33	TRANSFORMER FAULT
717	11-Feb-2022	BENGALURU	66	HOODY 220 - BAGHMANE WORLD TECH PARK 2	NO STATION AFFECTED	18:38	20:56	2:18	LINE FAULT
718	11-Feb-2022	BENGALURU	66	HV1	TK HALLI 220	12:25	12:30	0:05	TRANSFORMER FAULT
719	11-Feb-2022	BENGALURU	66	HV1	TK HALLI 220	13:11	13:17	0:06	TRANSFORMER FAULT
720	11-Feb-2022	BENGALURU	66	HV2	TK HALLI 220	17:57	18:08	0:11	TRANSFORMER FAULT
721	11-Feb-2022	BENGALURU	66	HV1	YEDUMADU	10:59	11:05	0:05	LINE CLEAR AVAILED
722	11-Feb-2022	BENGALURU	66	HV2	YEDUMADU	13:21	13:25	0:03	LINE CLEAR AVAILED
723	11-Feb-2022	BENGALURU	66	HV1	DODDABELAVANGALA	16:05	16:10	0:04	LINE CLEAR AVAILED
724	11-Feb-2022	BENGALURU	220	DABUSPET 220 - KADUR 220	DABUSPET 220	9:03	15:49	6:46	LOAD CURTAILMENT
725	11-Feb-2022	BENGALURU	66	CHIKKABALLAPURA I/A - DB PURA 2	NO STATION AFFECTED	7:34	7:44	0:09	LINE FAULT
726	11-Feb-2022	BENGALURU	66	GUNDAMGERE- GOWRIBIDANUR 220	GUNDAMGERE	11:30	11:40	0:10	LOAD CHANGE OVER
727	11-Feb-2022	BENGALURU	66	GUNDAMGERE- DB PURA 220	GUNDAMGERE	16:25	16:35	0:10	LOAD CHANGE OVER
728	11-Feb-2022	BENGALURU	66	HV1	GOWRIBIDANUR 220	10:45	10:50	0:05	TRANSFORMER FAULT
729	11-Feb-2022	BENGALURU	66	HV1	GOWRIBIDANUR 220	13:54	14:08	0:14	TRANSFORMER FAULT
730	11-Feb-2022	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	18:45	18:55	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
731	11-Feb-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	7:35	7:41	0:06	LINE FAULT
732	11-Feb-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:00	11:06	0:06	LINE CLEAR AVAILED
733	11-Feb-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	11:00	11:06	0:06	LINE CLEAR AVAILED
734	11-Feb-2022	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	16:10	16:28	0:18	MAIN SUPPLY FAILURE
735	11-Feb-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	16:10	16:28	0:18	MAIN SUPPLY FAILURE
736	11-Feb-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	16:10	16:28	0:18	MAIN SUPPLY FAILURE
737	11-Feb-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	16:10	16:28	0:18	MAIN SUPPLY FAILURE
738	11-Feb-2022	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	16:10	16:28	0:18	MAIN SUPPLY FAILURE
739	11-Feb-2022	BENGALURU	220	LV1	DB PURA 220	16:16	17:52	1:36	LINE CLEAR AVAILED
740	11-Feb-2022	BENGALURU	220	HV1	DB PURA 220	16:16	17:48	1:32	LINE CLEAR AVAILED
741	11-Feb-2022	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	17:25	17:35	0:10	LINE CLEAR AVAILED
742	11-Feb-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	17:25	18:03	0:38	LINE CLEAR AVAILED
743	11-Feb-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	17:25	17:56	0:31	LINE CLEAR AVAILED
744	11-Feb-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	17:25	17:56	0:31	LINE CLEAR AVAILED
745	11-Feb-2022	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	17:25	17:58	0:33	LINE CLEAR AVAILED
746	11-Feb-2022	BENGALURU	66	HV2	MANCHENAHALLI	13:32	13:37	0:04	TRANSFORMER FAULT
747	11-Feb-2022	BENGALURU	66	HV2	MANCHENAHALLI	13:47	14:12	0:25	TRANSFORMER FAULT
748	11-Feb-2022	BENGALURU	66	HV2	MANCHENAHALLI	15:23	15:27	0:04	TRANSFORMER FAULT
749	11-Feb-2022	BENGALURU	66	SRS PEENYA 220 - BYDRAHALLI	BYDRAHALLI, SRIGANDA KAVALU, KODIGEHALI	23:40(11/02/2022)			LINE OPEN,LINE FAULT
750	11-Feb-2022	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN,LINE FAULT
751	11-Feb-2022	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN,LINE FAULT
752	11-Feb-2022	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	9:46(11-2-2022)			LINE OPEN,LINE FAULT
753	11-Feb-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	23:58(10.2.2022)			LINE OPEN,LINE FAULT
754	11-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,GABBUR_110,D EODURGA_110	08:30(11.02.20222)			LINE OPEN,LINE CLEAR AVAILED
755	11-Feb-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
756	11-Feb-2022	GULBARGA	110	SEDAM-ULTRATECH	SEDAM_220	8:40			LINE OPEN,LINE CLEAR AVAILED
757	11-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	8:29			LINE OPEN,LINE CLEAR AVAILED
758	11-Feb-2022	GULBARGA	400	BTPSG-RTPS	RTPS_400	7:50	12:01	4:11	LINE FAULT
759	11-Feb-2022	GULBARGA	400	RTPS-RAICHUR1	RTPS_400	6:42	11:29	4:47	LINE FAULT
760	11-Feb-2022	GULBARGA	400	RTPS-MEHEBUB NAGR	MEHEBUB NAGR_400	12:51	18:19	5:28	LINE CLEAR AVAILED
761	11-Feb-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
762	11-Feb-2022	GULBARGA	220	SHAHAPUR-LINGASUGUR	LINGASUGUR_220	13:49 (11.02.2022)			LINE OPEN,LINE FAULT
763	11-Feb-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	23:58(10.2.2022)	18:00 (11.02.2022)	18:02 HRS	LINE CHARGED
764	11-Feb-2022	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	11:44	14:26	2:42	LINE CLEAR AVAILED
765	11-Feb-2022	GULBARGA	220	HV2	SHAHAPUR_220	12:01	14:17	2:16	LINE CLEAR AVAILED
766	11-Feb-2022	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	14:28	14:32	0:04	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
767	11-Feb-2022	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	14:46	14:50	0:04	LINE CLEAR AVAILED
768	11-Feb-2022	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	14:51	14:56	0:05	LINE CLEAR AVAILED
769	11-Feb-2022	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	14:58	15:04	0:06	LINE CLEAR AVAILED
770	11-Feb-2022	GULBARGA	220	HV1	SHAHAPUR_220	15:30	15:42	0:12	LINE CLEAR AVAILED
771	11-Feb-2022	GULBARGA	220	HV2	SHAHAPUR_220	15:36	15:42	0:06	TRANSFORMER FAULT
772	11-Feb-2022	GULBARGA	220	SHAHAPUR-RAICHUR1	DEODURGA_110	8:17	9:36	1:19	LINE CLEAR AVAILED
773	11-Feb-2022	GULBARGA	220	SINDHANOOR-SULEKAL(GANGAVATHI)	SINDHANOOR_220	5:40	5:52	0:12	LINE FAULT
774	11-Feb-2022	GULBARGA	220	HV1	SINDHANOOR_220	5:40	5:54	0:14	TRANSFORMER FAULT
775	11-Feb-2022	GULBARGA	220	HV2	SINDHANOOR_220	5:40	7:02	1:22	TRANSFORMER FAULT
776	11-Feb-2022	GULBARGA	220	HV2	SINDHANOOR_220	13:35	14:15	0:40	LINE CLEAR AVAILED
777	11-Feb-2022	GULBARGA	220	HV2	SINDHANOOR_220	16:10	16:20	0:10	LINE CLEAR AVAILED
778	11-Feb-2022	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	9:30	11:55	2:25	LINE CLEAR AVAILED
779	11-Feb-2022	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	12:30	14:51	2:21	LINE CLEAR AVAILED
780	11-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	8:29 (10.02.2022)			LINE OPEN,LINE CLEAR AVAILED
781	11-Feb-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:28 (10.02.2022)			LINE OPEN,LINE CLEAR AVAILED
782	11-Feb-2022	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	23:28(11.02.2022)			LINE OPEN,LINE FAULT
783	11-Feb-2022	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,MUDDAPURA_110	3:23	3:28	0:05	LINE FAULT
784	11-Feb-2022	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,MUDDAPURA_110	5:35	6:10	0:35	LINE FAULT
785	11-Feb-2022	GULBARGA	110	GANDHINAGAR-SINDHANOOR	GANDHINAGAR_110,TURVIHA L_110	5:37	6:04	0:27	MAIN SUPPLY FAILURE
786	11-Feb-2022	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	5:40	6:01	0:21	MAIN SUPPLY FAILURE
787	11-Feb-2022	GULBARGA	110	GANDHINAGAR-SINDHANOOR	GANDHINAGAR_110,TURVIHA L_110	5:37	6:04	0:27	MAIN SUPPLY FAILURE
788	11-Feb-2022	GULBARGA	110	GANDHINAGAR-SINDHANOOR	GANDHINAGAR_110,TURVIHA L_110	13:10	14:22	1:12	MAIN SUPPLY FAILURE
789	11-Feb-2022	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	14:55	15:00	0:05	LINE FAULT
790	11-Feb-2022	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	3:12	3:22	0:10	LINE FAULT
791	11-Feb-2022	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	12:52	14:20	1:28	LINE CLEAR AVAILED
792	11-Feb-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	12:52	14:20	1:28	LINE CLEAR AVAILED
793	11-Feb-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERDONA_110,SRNAGAR_110 ,MALLAPURA_110,JAWALGER A_110	12:52	14:20	1:28	LINE CLEAR AVAILED
794	11-Feb-2022	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110,MUDDAP UR_110,MASKI_110,VALAKA MADINNI_110	12:52	14:20	1:28	LINE CLEAR AVAILED
795	11-Feb-2022	GULBARGA	110	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110,,VALAKAM ADINNI_110,	12:52	14:20	1:28	LINE CLEAR AVAILED
796	11-Feb-2022	GULBARGA	110	SINDHANOOR-ADVIAMARESHWARA	ADAVIAMARESHWARA_110,M ANVI_110	12:52	14:20	1:28	LINE CLEAR AVAILED
797	11-Feb-2022	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110,GANDHINAG AR_110	12:52	14:20	1:28	LINE CLEAR AVAILED
798	11-Feb-2022	GULBARGA	110	HV1	JAWALGERA_110	15:45	16:40	0:55	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
799	11-Feb-2022	GULBARGA	110	HV1	YEREGERA_110	12:20	15:30	3:10	LINE CLEAR AVAILED
800	11-Feb-2022	GULBARGA	110	HV1	GULBARGAWEST_110	10:10	10:15	0:05	TRANSFORMER FAULT
801	11-Feb-2022	GULBARGA	110	KAVITAL-MALLAT	KAVITAL_110	23:00	23:25	0:25	MAIN SUPPLY FAILURE
802	11-Feb-2022	GULBARGA	110	HALBARGA-HUMNABAD	HUMNABAD_110	13:45	13:53	0:08	LINE FAULT
803	11-Feb-2022	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	16:42	19:42	3:00	LINE CLEAR AVAILED
804	11-Feb-2022	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGUTTI_110	16:42	19:43	3:01	LINE CLEAR AVAILED
805	11-Feb-2022	GULBARGA	110	LV1	HUMNABAD_220	10:30	15:45	5:15	LINE CLEAR AVAILED
806	11-Feb-2022	GULBARGA	110	SEDAM-ULTRATECH	SEDAM_220	8:40	18:14	9:34	LINE CLEAR AVAILED
807	11-Feb-2022	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORWAR TEMPLE_110	9:38	9:43	0:05	LINE FAULT
808	11-Feb-2022	GULBARGA	66	MAGALA-HIREHADAGALLI	MAGALA_66	15:34	15:47	0:13	LINE FAULT
809	11-Feb-2022	GULBARGA	66	NEELAGUNDA-PUNABGHATTA	PUNABGHATTA_66,UCHANGI DURGA_66	10:36	10:46	0:10	LINE FAULT
810	11-Feb-2022	GULBARGA	66	ITTAGI-BOMMANHALLI	BOMMANHALLI_66	10:58	14:15	3:17	LINE CLEAR AVAILED
811	11-Feb-2022	HASSAN	110	SAGARA-SS2	SAGARA_110	18:05(10.02.2022)			LINE OPEN,LINE FAULT
812	11-Feb-2022	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)	11:59(11.02.2022)	1248:23HRS	LINE CHARGED
813	11-Feb-2022	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)	11:45(11.02.2022)	1248:31HRS	LINE CHARGED
814	11-Feb-2022	HASSAN	110	LPH-MGHE 2	lph_gen	14:46(21.12.2021)	14:46(11.02.2022)	1248:00HRS	LINE CHARGED
815	11-Feb-2022	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	15:53	16:08	0:15	HAND TRIPPED
816	11-Feb-2022	HASSAN	220	KADUR-SHIMOGA	KADUR_220	15:51	16:04	0:13	HAND TRIPPED
817	11-Feb-2022	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	15:53	16:06	0:13	HAND TRIPPED
818	11-Feb-2022	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	15:53	16:04	0:11	HAND TRIPPED
819	11-Feb-2022	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:49	16:28	4:39	LINE CLEAR AVAILED
820	11-Feb-2022	HASSAN	220	HV2	MSEZ_220	9:43	15:15	5:32	LINE CLEAR AVAILED
821	11-Feb-2022	HASSAN	110	HV2	HALADY_110	11:48	13:12	1:24	LINE CLEAR AVAILED
822	11-Feb-2022	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	9:17	16:41	7:24	NFBC ISSUED
823	11-Feb-2022	HASSAN	110	JOG110-LPH	JOG_110	12:15	12:20	0:05	HAND TRIPPED
824	11-Feb-2022	HASSAN	110	KADUR-NERELEKERE	KADUR_220	15:53	16:07	0:14	HAND TRIPPED
825	11-Feb-2022	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	9:16	16:41	7:25	LINE CLEAR AVAILED
826	11-Feb-2022	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	15:37	16:21	0:44	LINE CLEAR AVAILED
827	11-Feb-2022	HASSAN	110	HV1	SHIVPURA_110	11:06	11:15	0:09	HAND TRIPPED
828	11-Feb-2022	HASSAN	66	HV2	BALEHONNUR_66	15:54	16:30	0:36	LINE CLEAR AVAILED
829	11-Feb-2022	MYSURU	66	COWDALLI-AJJIPURA	COWDALLI_66 MARTAHALLI_66	10:00	17:50	7:50	LINE CLEAR AVAILED
830	11-Feb-2022	MYSURU	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	10:12	18:22	8:09	NFBC ISSUED
831	11-Feb-2022	MYSURU	66	HV1	GUNDULPET_66	10:17	18:24	8:06	LINE CLEAR AVAILED
832	11-Feb-2022	MYSURU	66	GUNDLUPETE-HANGLA	BHARGI_66 HANGLA_66	10:25	15:10	4:45	NFBC ISSUED
833	11-Feb-2022	MYSURU	66	HV2	GUNDULPET_66	10:00	18:30	8:30	LINE CLEAR AVAILED
834	11-Feb-2022	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	16:33	19:18	2:44	LINE FAULT
835	11-Feb-2022	MYSURU	66	HV1	KHBCOLONY_66	16:07	17:28	1:20	LINE CLEAR AVAILED
836	11-Feb-2022	MYSURU	66	KUSHALNAGARA-MYSORE	MIRLE_66	6:20	6:26	0:06	LINE FAULT
837	11-Feb-2022	MYSURU	66	MADHUVANAHALLI-HANNUR1	AJJIPURA_66 BANDAHALLI_66 RAMAPURA_MYS_66 HANNUR_66	14:47	16:06	1:19	NFBC ISSUED
838	11-Feb-2022	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	14:47	16:06	1:19	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
839	11-Feb-2022	MYSURU	66	HANNUR-KOTTANUR	NO STATIONS EFFECTED	14:20	16:00	1:40	NFBC ISSUED
840	11-Feb-2022	MYSURU	66	HV2	MALAVALLI_66	13:08	13:29	0:20	TRANSFORMER FAULT
841	11-Feb-2022	MYSURU	66	HV1	MANDYA_66	10:57	12:40	1:43	LINE CLEAR AVAILED
842	11-Feb-2022	MYSURU	66	HV2	MYSORESOUTH_66	16:28	17:05	0:37	LINE CLEAR AVAILED
843	11-Feb-2022	MYSURU	66	SFC SIVA-ATRIA	NO STATIONS EFFECTED	9:25	12:40	3:15	LINE CLEAR AVAILED
844	11-Feb-2022	MYSURU	66	TUBINKERE-NAGAMANGALA 2	HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66SHIVALLY_66 BASARALU_66KESLAGERE_66	4:05	4:14	0:08	LINE FAULT
845	11-Feb-2022	MYSURU	66	VAJMANGALA-HEBBANI	NO STATIONS EFFECTED	6:40	6:50	0:10	LINE FAULT
846	11-Feb-2022	MYSURU	66	PERIYAPATNA-HANGODU	PONNAMPET_66VIRAJPET_66 HANAGODU_66	11:54:18 (11.2.2022)			LINE OPEN,LINE FAULT
847	11-Feb-2022	MYSURU	66	HV5	SFCSHIVA_66	20:10(11.2.22)			TRANSFORMER OPEN, LINE CLEAR AVAILED
848	11-Feb-2022	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)			LINE OPEN,LINE CLEAR AVAILED
849	11-Feb-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
850	11-Feb-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
851	11-Feb-2022	TUMKUR	400	SYSLOH	GUTTUR 400	11:05	15:12	4:07	LINE CLEAR AVAILED
852	11-Feb-2022	TUMKUR	400	GUTTUR-1	GUTTUR 400	11:32	17:15	5:43	LINE FAULT
853	11-Feb-2022	TUMKUR	400	GUTTUR-2	GUTTUR 400	16:46	17:25	0:39	LINE FAULT
854	11-Feb-2022	TUMKUR	220	THALLAK 220KV- CHALLAKERE1	THALLAK_220	6:43	7:05	0:22	LINE FAULT
855	11-Feb-2022	TUMKUR	220	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	7:01	18:55	11:54	LINE FAULT
856	11-Feb-2022	TUMKUR	220	ANCHEPALYA 66KV-HEBBUR66	ANCHEPALYA_220	9:24	9:34	0:10	LINE FAULT
857	11-Feb-2022	TUMKUR	220	DAVANGERE SRS- CHITRADURGA2	CHITRADURGA_220	10:44	14:45	4:01	LINE CLEAR AVAILED
858	11-Feb-2022	TUMKUR	66	TR2	BHARAMAGIRI_66	14:30	14:35	0:05	TRANSFORMER FAULT
859	11-Feb-2022	TUMKUR	66	MADHUGIRI 220KV- MEDIGESHI 2	NAGALAMADIKE_66	8:10	9:10	1:00	LINE CLEAR AVAILED
860	11-Feb-2022	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA	URDIGERE_66	15:10	17:40	2:30	LINE CLEAR AVAILED
861	11-Feb-2022	TUMKUR	66	TR1	SIRA_66	12:45	13:00	0:15	TRANSFORMER FAULT
862	11-Feb-2022	TUMKUR	66	TR1	KADDAJI	11:05	11:15	0:10	TRANSFORMER FAULT
863	11-Feb-2022	TUMKUR	66	TR1	KADDAJI	11:15	11:35	0:20	LINE CLEAR AVAILED
864	11-Feb-2022	TUMKUR	66	HIRIYUR220-BEVINAHALLI66	JAVAGONDANAHALLI_66	12:30	12:40	0:10	LINE FAULT
865	11-Feb-2022	TUMKUR	66	HIRIYUR220-BEVINAHALLI66	JAVAGONDANAHALLI_66	14:05	14:10	0:05	LINE FAULT
866	11-Feb-2022	TUMKUR	66	TR1	BHAKTARAHALLI	13:00	13:05	0:05	TRANSFORMER FAULT
867	11-Feb-2022	TUMKUR	66	ANCHEPALYA 220kv- KUNIGAL66	THIPPUR_66	17:50	18:00	0:10	LINE FAULT
868	11-Feb-2022	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	SANIKERE_66	10:30	10:35	0:05	LINE CLEAR AVAILED
869	11-Feb-2022	TUMKUR	66	TR1	SANIKERE_66	8:50	9:15	0:25	LINE CLEAR AVAILED
870	11-Feb-2022	TUMKUR	66	TR1	SANIKERE_66	10:40	12:55	2:15	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
871	11-Feb-2022	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	17:00	17:50	0:50	MAIN SUPPLY FAILURE
872	11-Feb-2022	TUMKUR	66	TR1	HOLLAKRE_66	10:00	10:05	0:05	TRANSFORMER FAULT
873	11-Feb-2022	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	12:00	12:05	0:05	HAND TRIPPED
874	11-Feb-2022	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	12:55	12:56	0:01	HAND TRIPPED
875	11-Feb-2022	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	13:25	13:40	0:15	MAIN SUPPLY FAILURE
876	11-Feb-2022	TUMKUR	66	TR-2	PATTNAYAKANAHALLI_66	11:25	12:05	0:40	TRANSFORMER FAULT
877	12-Feb-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
878	12-Feb-2022	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
879	12-Feb-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
880	12-Feb-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN,LINE FAULT
881	12-Feb-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
882	12-Feb-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
883	12-Feb-2022	BAGALKOT	110	RANEENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	12:22 (10.02.2022)			LINE OPEN,LINE CLEAR AVAILED
884	12-Feb-2022	BAGALKOT	220	HUBLI-NAGJHARI3	STATION NOT AFFECTED HUBLI_220	17:20 (11.02.2022)			LINE OPEN,LINE FAULT
885	12-Feb-2022	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	6:30	6:48	0:18	LINE FAULT
886	12-Feb-2022	BAGALKOT	220	BIDNAL-SOUNDATTI	BIDNAL_220	13:46	17:39	3:53	LINE FAULT
887	12-Feb-2022	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110	14:05	14:23	0:18	TRANSFORMER FAULT
888	12-Feb-2022	BAGALKOT	110	110/11KV,HV1	HANAGAL_110	10:08	15:05	4:57	LINE CLEAR AVAILED
889	12-Feb-2022	BAGALKOT	110	110/11KV,HV3	HANAGAL_110	18:25	18:47	0:22	LINE CLEAR AVAILED
890	12-Feb-2022	BAGALKOT	110	110/11KV, HV1	YARAGATTI_110	18:19	18:26	0:07	HAND TRIPPED
891	12-Feb-2022	BAGALKOT	110	110/11KV, HV2	YARAGATTI_110	18:19	18:27	0:08	HAND TRIPPED
892	12-Feb-2022	BAGALKOT	110	UTTUR- RANNABELAGALI(MAHALINGAP UR)	UTTUR_110	16:53	17:44	0:51	LINE FAULT
893	12-Feb-2022	BAGALKOT	110	SUARNASOUDHA-MACHE	MACHE_110	4:13	4:46	0:33	LINE FAULT
894	12-Feb-2022	BAGALKOT	110	110/11KV, HV1 (HV4)	STATION NOT AFFECTED SADALAGA_110	10:14	18:44	8:30	LINE CLEAR AVAILED
895	12-Feb-2022	BAGALKOT	110	110/33KV, HV3	BHOJ_33 STATION NOT AFFECTED SADALAGA_110	10:18	19:34	9:16	LINE CLEAR AVAILED
896	12-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SADALAGA_110	10:18	19:34	9:16	LINE CLEAR AVAILED
897	12-Feb-2022	BAGALKOT	110	SADALAGA-CHIKKODI220	SADALAGA_110	18:12	18:41	0:29	LINE CLEAR AVAILED
898	12-Feb-2022	BAGALKOT	110	SADALAGA-VPPL IPP	VPPL IPP_110 SADALAGA_110	18:14	18:42	0:28	LINE CLEAR AVAILED
899	12-Feb-2022	BAGALKOT	110	SADALAGA-BORGAON	BORGAON_110	18:15	18:42	0:27	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
900	12-Feb-2022	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	SOUDATTI_220	16:50	18:54	2:04	LINE CLEAR AVAILED
901	12-Feb-2022	BAGALKOT	220	BIDNAL-SOUDATTI	SOUDATTI_220	14:11	17:43	3:32	LINE FAULT
902	12-Feb-2022	BAGALKOT	220	220/110KV,HV1,LV1,LV2	SOUDATTI_220	17:16	17:44	0:28	MAIN SUPPLY FAILURE
903	12-Feb-2022	BAGALKOT	110	110/11KV,HV1	SOUDATTI_220	16:53	17:52	0:59	HAND TRIPPED
904	12-Feb-2022	BAGALKOT	110	SOUDATTI-BENAKATTI	BENAKATTI_110	16:50	18:08	1:18	LINE CLEAR AVAILED
905	12-Feb-2022	BAGALKOT	110	SOUDATTI-MUNAVALLI	MUNAVALLI_110	16:53	18:19	1:26	LINE FAULT
906	12-Feb-2022	BAGALKOT	110	SOUDATTI220-SAUDATTI	SOUDATTI_110	17:17	17:54	0:37	HAND TRIPPED
907	12-Feb-2022	BAGALKOT	110	SOUDATTI-RAMADURGA	RAMADURGA_110	16:53	18:03	1:10	LINE FAULT
908	12-Feb-2022	BAGALKOT	110	SOUDATTI-MMCL	SOUNDATTI_220	16:50	17:56	1:06	LINE CLEAR AVAILED
909	12-Feb-2022	BAGALKOT	110	SOUDATTI-YARAGATTI	YARAGATTI_110	16:50	18:14	1:24	LINE CLEAR AVAILED
910	12-Feb-2022	BAGALKOT	110	MK HUBLI-KHANAPUR	KHANAPUR_110	10:02	17:42	7:40	LINE CLEAR AVAILED
911	12-Feb-2022	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	16:16	16:28	0:12	LINE FAULT
912	12-Feb-2022	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	16:28 (12.02.2022)			LINE OPEN,LINE FAULT
913	12-Feb-2022	BAGALKOT	220	AMBEWADI-NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	20:27 (12.02.2022)			LINE OPEN,LINE FAULT
914	12-Feb-2022	BAGALKOT	220	AMBEWADI-NAGJHARI2	STATION NOT AFFECTED AMBEWADI_220	20:27	21:54	1:27	LINE FAULT
915	12-Feb-2022	BAGALKOT	220	MAHALINGAPUR-ATHANI	STATION NOT AFFECTED ATHANI_220	16:53	17:45	0:52	LINE FAULT
916	12-Feb-2022	BAGALKOT	110	SOUDATTI-UDAKERI	UDAKERI_110	16:50	17:58	1:08	LINE CLEAR AVAILED
917	12-Feb-2022	BAGALKOT	110	SOUDATTI-KATAKOL	KATAKOL_110	16:50	18:15	1:25	LINE CLEAR AVAILED
918	12-Feb-2022	BAGALKOT	110	NARENDRA-MR NAGAR	MRUTHYUNJAYANAGAR_110	10:10	14:09	3:59	LINE CLEAR AVAILED
919	12-Feb-2022	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	17:16	18:01	0:45	LINE FAULT
920	12-Feb-2022	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	7:24	7:31	0:07	LINE FAULT
921	12-Feb-2022	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	DODDALAHALLI	8:30	9:01	0:31	LINE FAULT
922	12-Feb-2022	BENGALURU	66	LR BANDE - HBR LAYOUT	LR BANDE	8:14	8:16	0:02	LOAD CHANGE OVER
923	12-Feb-2022	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTURU	GUNDLU KOTTURU	22:19	22:32	0:12	LINE FAULT
924	12-Feb-2022	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTURU	GUNDLU KOTTURU	22:32	22:36	0:03	LINE FAULT
925	12-Feb-2022	BENGALURU	66	SOMENAHALLI - AFTL (IPP)	NO STATION AFFECTED	9:25	9:30	0:05	LINE FAULT
926	12-Feb-2022	BENGALURU	66	SOMENAHALLI - AFTL (IPP)	NO STATION AFFECTED	9:35	9:40	0:05	LINE FAULT
927	12-Feb-2022	BENGALURU	66	SOMENAHALLI - AFTL (IPP)	NO STATION AFFECTED	9:45	10:25	0:40	LINE FAULT
928	12-Feb-2022	BENGALURU	66	SOMENAHALLI - AFTL (IPP)	NO STATION AFFECTED	10:31	10:36	0:04	LINE FAULT
929	12-Feb-2022	BENGALURU	66	SOMENAHALLI - AFTL (IPP)	NO STATION AFFECTED	11:07	11:09	0:01	LINE FAULT
930	12-Feb-2022	BENGALURU	66	SOMENAHALLI - AFTL (IPP)	NO STATION AFFECTED	11:31	11:34	0:02	LINE FAULT
931	12-Feb-2022	BENGALURU	66	SOMENAHALLI - AFTL (IPP)	NO STATION AFFECTED	12:05	12:10	0:05	LINE FAULT
932	12-Feb-2022	BENGALURU	220	DABUSPET 220 - KADUR 220	DABUSPET 220	9:09	15:21	6:12	LOAD CURTAILMENT
933	12-Feb-2022	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	7:28	7:36	0:07	LINE FAULT
934	12-Feb-2022	BENGALURU	66	GUNDAMGERE- GOWRIBIDANUR 220	GUNDAMGERE	10:13	10:29	0:16	LOAD CHANGE OVER
935	12-Feb-2022	BENGALURU	66	GUNDAMGERE- DB PURA 220	GUNDAMGERE	12:45	13:00	0:15	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
936	12-Feb-2022	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	10:08	10:50	0:42	LINE FAULT
937	12-Feb-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	12:44	12:52	0:08	MAIN SUPPLY FAILURE
938	12-Feb-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	12:44	12:53	0:09	MAIN SUPPLY FAILURE
939	12-Feb-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	12:44	12:53	0:09	MAIN SUPPLY FAILURE
940	12-Feb-2022	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	12:44	12:52	0:08	MAIN SUPPLY FAILURE
941	12-Feb-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA	14:30	14:41	0:11	LINE CLEAR AVAILED
942	12-Feb-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	14:30	14:41	0:11	LINE CLEAR AVAILED
943	12-Feb-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	14:30	14:41	0:11	LINE CLEAR AVAILED
944	12-Feb-2022	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	14:30	14:41	0:11	LINE CLEAR AVAILED
945	12-Feb-2022	BENGALURU	220	LV1	DB PURA 220	12:45	14:40	1:55	LINE CLEAR AVAILED
946	12-Feb-2022	BENGALURU	220	HV1	DB PURA 220	12:45	14:36	1:51	LINE CLEAR AVAILED
947	12-Feb-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA	16:24	16:29	0:05	LINE CLEAR AVAILED
948	12-Feb-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA	18:20	18:24	0:04	LINE CLEAR AVAILED
949	12-Feb-2022	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	9:46(11-2-2022)			LINE OPEN,LINE FAULT
950	12-Feb-2022	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN,LINE FAULT
951	12-Feb-2022	BENGALURU	66	SRS PEENYA 220 - BYDRAHALLI	BYDRAHALLI, SRIGANDA KAVALU, KODIGEHALI	23:40(11/02/2022)	1:05(12/02/2022)	01:25:00HRS	LINE CHARGED
952	12-Feb-2022	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN,LINE FAULT
953	12-Feb-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
954	12-Feb-2022	GULBARGA	220	SHAHAPUR-LINGASUGUR	LINGASUGUR_220	13:49 (11.02.2022)	13:50 (12.02.2022)	24:01 HRS	LINE CHARGED
955	12-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,GABBUR_110,D EODURGA_110	08:30(11.02.20222)			LINE OPEN,LINE CLEAR AVAILED
956	12-Feb-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
957	12-Feb-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	23:07 (12.02.2022)			LINE OPEN,LINE CLEAR AVAILED
958	12-Feb-2022	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	7:25	8:00	0:35	LOAD CURTAILMENT
959	12-Feb-2022	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	4:36	4:45	0:09	LINE FAULT
960	12-Feb-2022	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	23:28(11.02.2022)	00:55(12.02.2022)	01:27HRS	LINE CHARGED
961	12-Feb-2022	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	18:30	18:45	0:15	LINE FAULT
962	12-Feb-2022	GULBARGA	110	YERADONA-BENUR	BENUR_110	13:00	13:10	0:10	LINE FAULT
963	12-Feb-2022	GULBARGA	110	HV2	YEREGERA_110	9:35	18:00	8:25	LINE CLEAR AVAILED
964	12-Feb-2022	GULBARGA	110	HV1	YEREGERA_110	18:05	18:48	0:43	LINE CLEAR AVAILED
965	12-Feb-2022	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARGUTTI_110	12:06	12:25	0:19	LINE CLEAR AVAILED
966	12-Feb-2022	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARGUTTI_110	13:16	13:30	0:14	LINE CLEAR AVAILED
967	12-Feb-2022	GULBARGA	110	HV2	KUSTAGI_220	16:55	17:05	0:10	TRANSFORMER FAULT
968	12-Feb-2022	GULBARGA	110	HV2	KUSTAGI_220	17:08	17:27	0:19	TRANSFORMER FAULT
969	12-Feb-2022	GULBARGA	110	HV2	KUSTAGI_220	17:43	17:50	0:07	TRANSFORMER FAULT
970	12-Feb-2022	GULBARGA	110	HV2	KUSTAGI_220	18:54	19:36	0:42	TRANSFORMER FAULT
971	12-Feb-2022	GULBARGA	110	HV2	KUSTAGI_220	19:37	19:44	0:07	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
972	12-Feb-2022	GULBARGA	110	LV1	HUMNABAD_220	9:45	16:10	6:25	LINE CLEAR AVAILED
973	12-Feb-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAISAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	2:02	2:08	0:06	LINE FAULT
974	12-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	6:10	6:44	0:34	LINE FAULT
975	12-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	6:10	6:42	0:32	LINE FAULT
976	12-Feb-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:28 (10.02.2022)	9:11 (12.02.2022)	35:43 HRS	LINE CHARGED
977	12-Feb-2022	GULBARGA	66	PUNABGHATA-NEELAGUNDA	PUNABGHATA_66,UCHCHANGIDURGA_66	7:00	7:05	0:05	HAND TRIPPED
978	12-Feb-2022	GULBARGA	66	PUNABGHATA-UCHCHANGIDURGA	UCHCHANGIDURGA_66	6:45	7:20	0:35	LINE FAULT
979	12-Feb-2022	GULBARGA	66	HV1	GUDEKOTE_66	7:00	9:00	2:00	LINE CLEAR AVAILED
980	12-Feb-2022	GULBARGA	66	UCHCHANGIDURGA-NEELAGUNDA	UCHCHANGIDURGA_66,BILCHOD_66	6:45	7:20	0:35	MAIN SUPPLY FAILURE
981	12-Feb-2022	GULBARGA	66	NEELAGUNDA-PUNABGHATTA	PUNABGHATTA_66,UCHANGIDURGA_66	9:15	9:25	0:10	LINE CLEAR AVAILED
982	12-Feb-2022	HASSAN	110	JOG110-AMBTR2	JOG_110	13:08 (26.01.2022)			LINE OPEN,LINE FAULT
983	12-Feb-2022	HASSAN	110	SAGARA-SS2	SAGARA_110	18:05(10.02.2022)	20:20(12.02.2022)	50:15HRS	LINE CHARGED
984	12-Feb-2022	HASSAN	110	JOG-JLT4	mghejog_gen	16:25(12.02.2022)			LINE OPEN,LINE FAULT
985	12-Feb-2022	HASSAN	110	LPH-MGHE 2	lph_gen	16:25(12.02.2022)			LINE OPEN,LINE FAULT
986	12-Feb-2022	HASSAN	66	HV2	BELUR_66	22:19(12.02.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
987	12-Feb-2022	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	10:25	15:45	5:20	LINE CLEAR AVAILED
988	12-Feb-2022	HASSAN	66	MRSSHM-DVG2	MRSMG_220	14:44	14:52	0:08	LINE FAULT
989	12-Feb-2022	HASSAN	110	HV1	ANANDPURA_110	13:45	15:58	2:13	TRANSFORMER FAULT
990	12-Feb-2022	HASSAN	66	HASSN22-CRP1	HASSAN_220	6:34	6:51	0:17	LINE FAULT
991	12-Feb-2022	HASSAN	66	MATTNAV-DIDGTHL	MATTNAVILE_66	10:38	10:52	0:14	LINE FAULT
992	12-Feb-2022	MYSURU	66	HV1	BANANGADI_66	3:11	3:17	0:05	TRANSFORMER FAULT
993	12-Feb-2022	MYSURU	66	HV1	BANANGADI_66	3:25	3:34	0:09	HAND TRIPPED
994	12-Feb-2022	MYSURU	66	HV2	BILIKERE_66	12:36	12:42	0:06	TRANSFORMER FAULT
995	12-Feb-2022	MYSURU	66	HV2	BILIKERE_66	14:26	14:47	0:20	TRANSFORMER FAULT
996	12-Feb-2022	MYSURU	66	HV1	DEVANOORNGUDU_66	13:28	13:33	0:05	TRANSFORMER FAULT
997	12-Feb-2022	MYSURU	66	JAKKANAHALLI-NAGAMANGLA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 NAGAMANGALA_66	6:08	6:14	0:05	LINE FAULT
998	12-Feb-2022	MYSURU	220	HV1	MADHUVANAHALLI_220	9:06	9:12	0:06	TRANSFORMER FAULT
999	12-Feb-2022	MYSURU	220	HV2	MADHUVANAHALLI_220	9:06	9:12	0:06	TRANSFORMER FAULT
1000	12-Feb-2022	MYSURU	66	MADHUVANAHALLI 220-KOLLEGALA1	KOLLEGALA_66 SATHEGALA_66	16:53	17:01	0:07	LINE FAULT
1001	12-Feb-2022	MYSURU	66	SATHEGALA-BPCL	NO STATIONS EFFECTED	15:29	19:19	3:50	LINE CLEAR AVAILED
1002	12-Feb-2022	MYSURU	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	17:34	19:20	1:45	LINE CLEAR AVAILED
1003	12-Feb-2022	MYSURU	66	PERIYAPATNA-HANGODU	PONNAMPET_66VIRAJPET_66 HANAGODU_66	11:54:18 (11.2.2022)	00:03:00 (12.02.2022)	0:09HRS	LINE CHARGED
1004	12-Feb-2022	MYSURU	66	HV5	SFCSHIVA_66	20:10(11.2.22)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1005	12-Feb-2022	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)			LINE OPEN,LINE CLEAR AVAILED
1006	12-Feb-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
1007	12-Feb-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1008	12-Feb-2022	TUMKUR	400	TR2	GUTTUR 400	18:53	22:20	3:27	TRANSFORMER FAULT
1009	12-Feb-2022	TUMKUR	400	GUTTUR -2	GUTTUR 400	18:53(12.2.22)			LINE OPEN,LINE FAULT
1010	12-Feb-2022	TUMKUR	220	TR1	THALLAK_220	6:43	7:01	0:18	TRANSFORMER FAULT
1011	12-Feb-2022	TUMKUR	220	TR2	THALLAK_220	6:43	7:18	0:35	TRANSFORMER FAULT
1012	12-Feb-2022	TUMKUR	220	PN HALLI	SIRA 220	6:23	6:36	0:13	LINE FAULT
1013	12-Feb-2022	TUMKUR	220	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	7:33	7:59	0:26	LINE FAULT
1014	12-Feb-2022	TUMKUR	220	ANCHEPALYA 66kv- ANCHEPALYA 1	ANCHEPALYA_220	14:04	14:13	0:09	LINE FAULT
1015	12-Feb-2022	TUMKUR	66	HIRIYUR220-BEVINAHALLI66	JAVAGONDANAHALLI_66	6:40	6:45	0:05	LINE FAULT
1016	12-Feb-2022	TUMKUR	66	ANCHEPALYA 220kv- KUNIGAL66	THIPPUR_66	14:05	14:10	0:05	MAIN SUPPLY FAILURE
1017	12-Feb-2022	TUMKUR	66	BALENAHALLI-CHALKERE66	BALENAHALLI_66	10:10	17:35	7:25	LINE CLEAR AVAILED
1018	12-Feb-2022	TUMKUR	66	TR2	SANIKERE_66	13:10	13:20	0:10	TRANSFORMER FAULT
1019	12-Feb-2022	TUMKUR	66	TR1	SANIKERE_66	19:00	19:05	0:05	TRANSFORMER FAULT
1020	12-Feb-2022	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	15:55	16:02	0:07	MAIN SUPPLY FAILURE
1021	12-Feb-2022	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	16:05	16:14	0:09	HAND TRIPPED
1022	12-Feb-2022	TUMKUR	66	TR-1	HIRESHALLI_66	3:02	3:28	0:26	TRANSFORMER FAULT
1023	12-Feb-2022	TUMKUR	66	TR-1	HIRESHALLI_66	11:23	14:07	2:44	TRANSFORMER FAULT
1024	12-Feb-2022	TUMKUR	66	TR-1	HIRESHALLI_66	14:09	18:42	4:33	TRANSFORMER FAULT
1025	12-Feb-2022	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	3:25	3:35	0:10	LINE FAULT
1026	13-Feb-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
1027	13-Feb-2022	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
1028	13-Feb-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1029	13-Feb-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN,LINE FAULT
1030	13-Feb-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1031	13-Feb-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1032	13-Feb-2022	BAGALKOT	110	RANEBENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEBENNUR_220	12:22 (10.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1033	13-Feb-2022	BAGALKOT	220	HUBLI-NAGJHARI3	STATION NOT AFFECTED HUBLI_220	17:20 (11.02.2022)	16:56 (13.02.2022)	47:36HRS	LINE CHARGED
1034	13-Feb-2022	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	16:28 (12.02.2022)			LINE OPEN,LINE FAULT
1035	13-Feb-2022	BAGALKOT	220	AMBEWADI-NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	20:27 (12.02.2022)			LINE OPEN,LINE FAULT
1036	13-Feb-2022	BAGALKOT	220	BIDNAL-NAGJHARI2	BIDNAL_220	10:57	15:36	4:39	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1037	13-Feb-2022	BAGALKOT	110	110/33KV, HV4	HALASANGI_33, NEVARGI_33 & DULAKHED_33 STATION NOT AFFECTED ZALKI_110	13:34	13:39	0:05	TRANSFORMER FAULT
1038	13-Feb-2022	BAGALKOT	110	110/11KV, HV2 (HV3)	STATION NOT AFFECTED SOUDATTI_110	9:36	12:26	2:50	LINE CLEAR AVAILED
1039	13-Feb-2022	BAGALKOT	110	110/33KV, HV3 (HV1)	UDAKERI_33, CHULAKI_33, SPINNING MILL_33, SUZALON_33 & HV4(5MVA)_33 STATION NOT AFFECTED SOUDATTI_110	15:03	19:15	4:12	LINE CLEAR AVAILED
1040	13-Feb-2022	BAGALKOT	110	ATHANI220-ATHANI110	ATHANI_110	10:56	10:59	0:03	HAND TRIPPED
1041	13-Feb-2022	BAGALKOT	220	AMBEWADI- PONDA1	STATION NOT AFFECTED AMBEWADI_220	13:43	14:15	0:32	LINE FAULT
1042	13-Feb-2022	BAGALKOT	110	110/11KV,HV3	BIJAPUR_110	17:23	17:53	0:30	TRANSFORMER FAULT
1043	13-Feb-2022	BAGALKOT	110	GHATAPRABHA-GOKAK	GOKAK_110	18:45	19:00	0:15	LINE FAULT
1044	13-Feb-2022	BAGALKOT	110	BELGAUM220- VADAGOAN	VADAGOAN_110	9:05	16:50	7:45	LINE CLEAR AVAILED
1045	13-Feb-2022	BAGALKOT	110	BELGAUM220-BELGAUM	BELGAUM_110	12:05	15:00	2:55	LINE CLEAR AVAILED
1046	13-Feb-2022	BENGALURU	66	HV1	KODIGEHALLI	14:20	14:25	0:05	LINE CLEAR AVAILED
1047	13-Feb-2022	BENGALURU	66	HV1	KODIGEHALLI	15:20	15:30	0:10	LOAD CHANGE OVER
1048	13-Feb-2022	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	13:21	13:35	0:14	MAIN SUPPLY FAILURE
1049	13-Feb-2022	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	13:21	13:35	0:14	LINE CLEAR AVAILED
1050	13-Feb-2022	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	13:21	13:35	0:14	LINE CLEAR AVAILED
1051	13-Feb-2022	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	13:21	13:35	0:14	LINE CLEAR AVAILED
1052	13-Feb-2022	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	13:21	13:35	0:14	LINE CLEAR AVAILED
1053	13-Feb-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	10:07	10:13	0:06	LINE CLEAR AVAILED
1054	13-Feb-2022	BENGALURU	66	HV3	YARANDANAHALLI 220	8:59	9:06	0:07	TRANSFORMER FAULT
1055	13-Feb-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	18:10	18:13	0:03	LINE CLEAR AVAILED
1056	13-Feb-2022	BENGALURU	66	YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	18:15	18:25	0:10	LINE CLEAR AVAILED
1057	13-Feb-2022	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	3:12	3:20	0:08	LINE FAULT
1058	13-Feb-2022	BENGALURU	220	MALUR 220 - SOMANHALLI 2	SARJAPURA 220, VIKAS TECH PARK 220	13:24	13:39	0:15	LINE FAULT
1059	13-Feb-2022	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	13:24	13:44	0:20	MAIN SUPPLY FAILURE
1060	13-Feb-2022	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	13:24	13:43	0:19	MAIN SUPPLY FAILURE
1061	13-Feb-2022	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	13:24	13:45	0:21	MAIN SUPPLY FAILURE
1062	13-Feb-2022	BENGALURU	220	HV1	SARJAPURA 220	13:24	13:45	0:21	MAIN SUPPLY FAILURE
1063	13-Feb-2022	BENGALURU	220	HV2	SARJAPURA 220	13:24	13:45	0:21	MAIN SUPPLY FAILURE
1064	13-Feb-2022	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	7:25	7:30	0:05	LOAD CHANGE OVER
1065	13-Feb-2022	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	18:20	18:25	0:05	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1066	13-Feb-2022	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	10:28	14:22	3:54	LINE CLEAR AVAILED
1067	13-Feb-2022	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR	10:57	14:34	3:37	LINE CLEAR AVAILED
1068	13-Feb-2022	BENGALURU	66	GUNDAMGERE- GOWRIBIDANUR 220	GUNDAMGERE	8:31	8:40	0:09	LOAD CHANGE OVER
1069	13-Feb-2022	BENGALURU	66	GUNDAMGERE- DB PURA 220	GUNDAMGERE	16:00	16:05	0:05	LOAD CHANGE OVER
1070	13-Feb-2022	BENGALURU	66	HV1	GOWRIBIDANUR 220	18:42	18:50	0:08	TRANSFORMER FAULT
1071	13-Feb-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	5:08	5:18	0:10	LINE FAULT
1072	13-Feb-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	20:51	21:00	0:09	LINE FAULT
1073	13-Feb-2022	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	9:46(11-2-2022)			LINE OPEN,LINE FAULT
1074	13-Feb-2022	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN,LINE FAULT
1075	13-Feb-2022	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN,LINE FAULT
1076	13-Feb-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
1077	13-Feb-2022	GULBARGA	220	HV1	NEELAGUNDA_220	12:16	12:30	0:14	TRANSFORMER FAULT
1078	13-Feb-2022	GULBARGA	220	HV1	NEELAGUNDA_220	12:31	12:58	0:27	TRANSFORMER FAULT
1079	13-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,GABBUR_110,D EODURGA_110	08:30(11.02.20222)			LINE OPEN,LINE CLEAR AVAILED
1080	13-Feb-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1081	13-Feb-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:49 (13.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1082	13-Feb-2022	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	6:33	6:43	0:10	LINE FAULT
1083	13-Feb-2022	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVA THI_110,DR NAGAR_110,KARATAGI_110	18:08	18:21	0:13	LINE FAULT
1084	13-Feb-2022	GULBARGA	110	LV1	HUMNABAD_220	10:21	15:59	5:38	LINE CLEAR AVAILED
1085	13-Feb-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	23:07 (12.02.2022)	8:02 (13.02.2022)	8:55 HRS	LINE CHARGED
1086	13-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	21:58	22:11	0:13	LINE FAULT
1087	13-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	21:58	22:11	0:13	LINE FAULT
1088	13-Feb-2022	GULBARGA	66	NEELAGUNDA-PUNABGHATTA	PUNABGHATTA_66,UCHANGI DURGA_66	18:19	18:29	0:10	LINE FAULT
1089	13-Feb-2022	GULBARGA	66	NEELAGUNDA-PUNABGHATTA	PUNABGHATTA_66,UCHANGI DURGA_66	12:54	13:04	0:10	LINE CLEAR AVAILED
1090	13-Feb-2022	GULBARGA	66	NEELAGUNDA-HALAVAGALU	HALAVAGALU_66	12:16	13:03	0:47	LINE FAULT
1091	13-Feb-2022	GULBARGA	66	HANASI-ITTAGGI	HANASI_66	10:05	18:35	8:30	LINE CLEAR AVAILED
1092	13-Feb-2022	GULBARGA	66	CHOWDAPUR-AFZALPUR	CHOWDAPUR_110	21:50	22:15	0:25	LINE FAULT
1093	13-Feb-2022	GULBARGA	66	PUNABGHATA- UCHCHANGIDURGA	UCHCHANGIDURGA_66,BILCH OD_66	8:05	8:10	0:05	LINE FAULT
1094	13-Feb-2022	GULBARGA	66	HV1	PUNABGHATA_66	9:10	9:15	0:05	TRANSFORMER FAULT
1095	13-Feb-2022	GULBARGA	66	PUNABGHATA-NEELAGUNDA	PUNABGHATA_66,UCHCHANG IDURGA_66	12:15	13:15	1:00	MAIN SUPPLY FAILURE
1096	13-Feb-2022	GULBARGA	66	HV1	PUNABGHATA_66	18:30	18:35	0:05	TRANSFORMER FAULT
1097	13-Feb-2022	GULBARGA	66	PUNABGHATA- UCHCHANGIDURGA	UCHCHANGIDURGA_66	8:05	8:10	0:05	LINE FAULT
1098	13-Feb-2022	HASSAN	110	JOG110-AMBTR2	JOG_110	13:08 (26.01.2022)			LINE OPEN,LINE FAULT
1099	13-Feb-2022	HASSAN	110	JOG-JLT4	mghejog_gen	16:25(12.02.2022)	11:28(13.02.2022)	19:03HRS	LINE CHARGED
1100	13-Feb-2022	HASSAN	110	LPH-MGHE 2	lph_gen	16:25(12.02.2022)	11:25(13.02.2022)	18:00HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1101	13-Feb-2022	HASSAN	66	HV2	BELUR_66	22:19(12.02.2022)	12:32(13.02.2022)	14:03HRS	TRANSFORMER CHARGED
1102	13-Feb-2022	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:32(13.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1103	13-Feb-2022	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	9:32	10:35	1:03	LINE CLEAR AVAILED
1104	13-Feb-2022	HASSAN	110	HV2	HALADY_110	8:59	9:15	0:16	LINE CLEAR AVAILED
1105	13-Feb-2022	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	8:20	8:50	0:30	HAND TRIPPED
1106	13-Feb-2022	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	15:30	15:50	0:20	HAND TRIPPED
1107	13-Feb-2022	HASSAN	110	HV3	BAIKAMPADY_110	12:31	13:23	0:52	LINE CLEAR AVAILED
1108	13-Feb-2022	HASSAN	110	BARANG-ANVATTI	BARANGI_110	15:43	15:47	0:04	HAND TRIPPED
1109	13-Feb-2022	HASSAN	110	BARANG-SHR220	BARANGI_110	8:20	8:50	0:30	MAIN SUPPLY FAILURE
1110	13-Feb-2022	HASSAN	110	JOG-JLT3	mghejog_gen	11:20	11:34	0:14	LINE FAULT
1111	13-Feb-2022	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	8:22	15:39	7:17	LINE CLEAR AVAILED
1112	13-Feb-2022	HASSAN	66	HASSN22-CRP2	HASSAN_220	18:48	19:11	0:23	LINE CLEAR AVAILED
1113	13-Feb-2022	HASSAN	66	HV1	HIRISAVE_66	9:20	9:22	0:02	TRANSFORMER FAULT
1114	13-Feb-2022	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	14:13	14:23	0:10	LINE FAULT
1115	13-Feb-2022	HASSAN	66	KIADB H-HASAN I\C	KIADB_66	18:48	19:11	0:23	MAIN SUPPLY FAILURE
1116	13-Feb-2022	MYSURU	66	HV5	SFCSHIVA_66	20:10(11.2.22)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1117	13-Feb-2022	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)			LINE OPEN,LINE CLEAR AVAILED
1118	13-Feb-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
1119	13-Feb-2022	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1120	13-Feb-2022	MYSURU	66	C R NAGARA-D R PETE 1	DODDARAYAPET_66	9:09	14:31	5:22	LINE CLEAR AVAILED
1121	13-Feb-2022	MYSURU	66	C R NAGARA-D R PETE 2	DODDARAYAPET_66	9:09	14:31	5:22	LINE CLEAR AVAILED
1122	13-Feb-2022	MYSURU	66	MADHUVANAHALLY- KOLLEGALA	KOLLEGALA_66	10:27	14:56	4:29	NFBC ISSUED
1123	13-Feb-2022	MYSURU	220	MADHUVANAHALLY-WARDA SOLAR	NO STATIONS EFFECTED	18:48	19:08	0:20	LINE FAULT
1124	13-Feb-2022	MYSURU	66	HEBBANI-SATHEGALA	NO STATIONS EFFECTED	18:53	19:07	0:14	LINE FAULT
1125	13-Feb-2022	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI _66 SHIVALLY_66	4:13	4:19	0:06	LINE FAULT
1126	13-Feb-2022	MYSURU	66	KASALAGERE-BASARALU	BASARALU_66	1:30	1:45	0:15	LINE FAULT
1127	13-Feb-2022	MYSURU	66	HEBBANI-MEGAHALAPURA	CHIDRAVALLI_66 CHANDALLI_66 BGPURA_66 THUMBLA_66	7:05	7:28	0:23	LINE FAULT
1128	13-Feb-2022	MYSURU	66	HV1	KUNTHUR_66	10:00	14:50	4:50	LINE CLEAR AVAILED
1129	13-Feb-2022	MYSURU	66	HV2	KUNTHUR_66	10:00	15:30	5:30	LINE CLEAR AVAILED
1130	13-Feb-2022	TUMKUR	400	GUTTUR -2	GUTTUR 400	18:53(12.2.22)			LINE OPEN,LINE FAULT
1131	13-Feb-2022	TUMKUR	220	PN HALLI	SIRA 220	11:16	11:26	0:10	LINE FAULT
1132	13-Feb-2022	TUMKUR	66	TR2	BHARAMAGIRI_66	16:40	16:45	0:05	TRANSFORMER FAULT
1133	13-Feb-2022	TUMKUR	66	TR1	BILCHODU_66	6:45	7:25	0:40	TRANSFORMER FAULT
1134	13-Feb-2022	TUMKUR	66	UCHANGIDURGA- PALLAGATTE	BILCHODU_66	6:45	7:20	0:35	MAIN SUPPLY FAILURE
1135	13-Feb-2022	TUMKUR	66	UCHANGIDURGA- PALLAGATTE	BILCHODU_66	9:15	9:25	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1136	13-Feb-2022	TUMKUR	66	MATHOD- HOSADURGA	NEERAGUNDA	3:10	3:15	0:05	LINE FAULT
1137	13-Feb-2022	TUMKUR	66	MATHOD- HOSADURGA	NEERAGUNDA	7:55	8:00	0:05	LINE FAULT
1138	14-Feb-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
1139	14-Feb-2022	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
1140	14-Feb-2022	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1141	14-Feb-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN,LINE FAULT
1142	14-Feb-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1143	14-Feb-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1144	14-Feb-2022	BAGALKOT	110	RANEBENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEBENNUR_220	12:22 (10.02.2022)	7:30 (14.02.2022)	91:08HRS	LINE CHARGED
1145	14-Feb-2022	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	16:28 (12.02.2022)			LINE OPEN,LINE FAULT
1146	14-Feb-2022	BAGALKOT	220	AMBEWADI-NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	20:27 (12.02.2022)	15:06 (14.02.2022)	42:39HRS	LINE CHARGED
1147	14-Feb-2022	BAGALKOT	110	AMBEWADI-HALIYAL(NK-1)	STATION NOT AFFECTED AMBEWADI_220	8:16 (14.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1148	14-Feb-2022	BAGALKOT	110	AMBEWADI-KAVALWADA(NK-2)	STATION NOT AFFECTED AMBEWADI_220	8:16 (14.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1149	14-Feb-2022	BAGALKOT	110	AINAPUR- ATHANI SUGARS	STATION NOT AFFECTED AINAPUR_110	6:50	7:00	0:10	LINE FAULT
1150	14-Feb-2022	BAGALKOT	110	110/11KV, HV1	ANKOLA_110	9:13	9:16	0:03	HAND TRIPPED
1151	14-Feb-2022	BAGALKOT	110	110/11KV, HV1	BENAKATTI_110	14:08	16:00	1:52	LINE CLEAR AVAILED
1152	14-Feb-2022	BAGALKOT	110	RANEBENNUR220- BYADAGI	STATION NOT AFFECTED BYADAGI_110	7:40	18:42	11:02	LINE CLEAR AVAILED
1153	14-Feb-2022	BAGALKOT	110	110/11KV, HV1	CHANDKAVATTI_110	11:24	12:40	1:16	LINE CLEAR AVAILED
1154	14-Feb-2022	BAGALKOT	110	110/11KV,HV3	HANGAL_110	18:50	19:10	0:20	HAND TRIPPED
1155	14-Feb-2022	BAGALKOT	110	HAVERI220- BYADAGI	STATION NOT AFFECTED HAVERI_220	18:45	19:51	1:06	LINE CLEAR AVAILED
1156	14-Feb-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	14:06	14:10	0:04	TRANSFORMER FAULT
1157	14-Feb-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	14:14	14:20	0:06	TRANSFORMER FAULT
1158	14-Feb-2022	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	14:31	14:35	0:04	TRANSFORMER FAULT
1159	14-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TILUVALLI_110	15:58	21:15	5:17	TRANSFORMER FAULT
1160	14-Feb-2022	BAGALKOT	110	110/11KV, HV1 (HV2)	STATION NOT AFFECTED MUNAVALLI_110	9:07	12:15	3:08	LINE CLEAR AVAILED
1161	14-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUNAVALLI_110	11:55	15:45	3:50	LINE CLEAR AVAILED
1162	14-Feb-2022	BAGALKOT	110	110/33KV, HV3	HULIKATTI & MUNAVALLI_33, MALLUR_33 STATION NOT AFFECTED MUNAVALLI_110	15:30	18:53	3:23	LINE CLEAR AVAILED
1163	14-Feb-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KUDACHI_220	16:31	17:29	0:58	LINE CLEAR AVAILED
1164	14-Feb-2022	BAGALKOT	220	AMBEWADI-NAGJHARI2	STATION NOT AFFECTED AMBEWADI_220	10:44	15:06	4:22	LINE CLEAR AVAILED
1165	14-Feb-2022	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:29	12:39	2:10	LINE CLEAR AVAILED
1166	14-Feb-2022	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:30	12:39	2:09	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1167	14-Feb-2022	BAGALKOT	220	220/110KV,HV2,LV2	BIJAPUR_220	14:35	15:12	0:37	HAND TRIPPED
1168	14-Feb-2022	BAGALKOT	220	HUBLI-NARENDRA1	STATION NOT AFFECTED HUBLI_220	15:06	18:31	3:25	LINE CLEAR AVAILED
1169	14-Feb-2022	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA2	HIDIKAL_110,ISLAMPUR_110, HATTARAGI_110	17:07	17:53	0:46	LINE FAULT
1170	14-Feb-2022	BAGALKOT	110	KIRUVATTI-UMUCHAGI	KIRUVATTI_110	13:00	13:20	0:20	LINE CLEAR AVAILED
1171	14-Feb-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED JAMAKHANDI_110	16:31	17:29	0:58	LINE CLEAR AVAILED
1172	14-Feb-2022	BAGALKOT	110	RANEENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1173	14-Feb-2022	BAGALKOT	110	RANEENNUR-BYADAGI	STATION NOT AFFECTED RANEENNUR_220	7:14	7:20	0:06	LINE FAULT
1174	14-Feb-2022	BAGALKOT	110	RANEENNUR-BYADAGI	STATION NOT AFFECTED RANEENNUR_220	7:23	18:24	11:01	LINE CLEAR AVAILED
1175	14-Feb-2022	BAGALKOT	110	110/33KV, HV2	LAXMESHVAR_110	14:20	14:50	0:30	LINE CLEAR AVAILED
1176	14-Feb-2022	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	14:15	14:30	0:15	TRANSFORMER FAULT
1177	14-Feb-2022	BAGALKOT	220	NARENDRA- HUBLI1	STATION NOT AFFECTED NARENDRA_220	15:56	18:30	2:34	LINE CLEAR AVAILED
1178	14-Feb-2022	BENGALURU	66	HV1	SHOBHA APARTMENT	17:34	18:04	0:30	LOAD CHANGE OVER
1179	14-Feb-2022	BENGALURU	66	HV2	SHOBHA APARTMENT	9:02	9:06	0:04	LINE CLEAR AVAILED
1180	14-Feb-2022	BENGALURU	66	HV2	SHOBHA APARTMENT	17:35	18:03	0:28	LOAD CHANGE OVER
1181	14-Feb-2022	BENGALURU	220	HV1	YARANDANAHALLI 220	13:54	14:23	0:29	TRANSFORMER FAULT
1182	14-Feb-2022	BENGALURU	220	HV1	YARANDANAHALLI 220	14:38	14:53	0:15	TRANSFORMER FAULT
1183	14-Feb-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	13:54	14:23	0:29	LINE CLEAR AVAILED
1184	14-Feb-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	14:38	14:53	0:15	LINE CLEAR AVAILED
1185	14-Feb-2022	BENGALURU	66	HV1	S M MANGALA	7:30	8:58	1:28	LINE CLEAR AVAILED
1186	14-Feb-2022	BENGALURU	66	HV2	S M MANGALA	7:30	8:58	1:28	LINE CLEAR AVAILED
1187	14-Feb-2022	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	18:58	19:15	0:17	LINE FAULT
1188	14-Feb-2022	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	14:50	14:55	0:05	LOAD CHANGE OVER
1189	14-Feb-2022	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	14:50	15:00	0:10	LOAD CHANGE OVER
1190	14-Feb-2022	BENGALURU	66	HV1	AGALAKOTE	12:00	12:25	0:24	LINE CLEAR AVAILED
1191	14-Feb-2022	BENGALURU	66	HV3	CB PURA I/A	9:15	9:25	0:10	TRANSFORMER FAULT
1192	14-Feb-2022	BENGALURU	220	HV1	DB PURA 220	15:31	19:26	3:54	LINE CLEAR AVAILED
1193	14-Feb-2022	BENGALURU	220	LV1	DB PURA 220	15:31	19:26	3:54	LINE CLEAR AVAILED
1194	14-Feb-2022	BENGALURU	66	HV1 CB	HUKUNDA	10:21	10:30	0:08	TRANSFORMER FAULT
1195	14-Feb-2022	BENGALURU	66	HV2	KANAKAPURA 66	11:10	18:25	7:15	LINE CLEAR AVAILED
1196	14-Feb-2022	BENGALURU	66	HV1	KOLAR 220	10:57	11:45	0:47	LINE CLEAR AVAILED
1197	14-Feb-2022	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	9:21	16:31	7:10	LOAD CURTAILMENT
1198	14-Feb-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	15:30	15:39	0:08	LINE CLEAR AVAILED
1199	14-Feb-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	19:21	19:33	0:12	LINE CLEAR AVAILED
1200	14-Feb-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	15:30	15:39	0:08	LINE CLEAR AVAILED
1201	14-Feb-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	19:21	19:33	0:12	LINE CLEAR AVAILED
1202	14-Feb-2022	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	15:25	15:28	0:03	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1203	14-Feb-2022	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	6:23	6:28	0:04	LINE CLEAR AVAILED
1204	14-Feb-2022	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	15:31	15:38	0:06	LINE CLEAR AVAILED
1205	14-Feb-2022	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	19:22	19:32	0:10	LINE CLEAR AVAILED
1206	14-Feb-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	15:31	15:37	0:06	LINE CLEAR AVAILED
1207	14-Feb-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	19:21	19:32	0:11	LINE CLEAR AVAILED
1208	14-Feb-2022	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI	14:45	14:49	0:04	LINE CLEAR AVAILED
1209	14-Feb-2022	BENGALURU	66	HV1	BANGARPETE	18:47	19:24	0:36	TRANSFORMER FAULT
1210	14-Feb-2022	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	9:46(11-2-2022)			LINE OPEN,LINE FAULT
1211	14-Feb-2022	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN,LINE FAULT
1212	14-Feb-2022	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN,LINE FAULT
1213	14-Feb-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
1214	14-Feb-2022	GULBARGA	220	HV2	SHAHAPUR_220	12:24	15:25	3:01	LINE CLEAR AVAILED
1215	14-Feb-2022	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	5:46	5:56	0:10	LINE FAULT
1216	14-Feb-2022	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	18:14	18:38	0:24	LINE FAULT
1217	14-Feb-2022	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	18:14	18:43	0:29	LINE FAULT
1218	14-Feb-2022	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	21:29	21:45	0:16	LINE FAULT
1219	14-Feb-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1220	14-Feb-2022	GULBARGA	110	LV1	HUMNABAD_220	9:58	16:09	6:11	LINE CLEAR AVAILED
1221	14-Feb-2022	GULBARGA	110	HV1	MANVI_110	12:11	13:32	1:21	LINE CLEAR AVAILED
1222	14-Feb-2022	GULBARGA	110	HV1	ALIPUR_220	17:16	17:38	0:22	TRANSFORMER FAULT
1223	14-Feb-2022	GULBARGA	110	HV1	ALIPUR_220	17:38	18:25	0:47	LINE CLEAR AVAILED
1224	14-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GOOGLE_110,GABBUR_110,D EODURGA_110	08:30(11.02.20222)	10:45(14.02.2022)	74:15HRS	LINE CHARGED
1225	14-Feb-2022	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	3:00	3:10	0:10	MAIN SUPPLY FAILURE
1226	14-Feb-2022	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	4:45	5:00	0:15	MAIN SUPPLY FAILURE
1227	14-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	4:48	4:59	0:11	LINE FAULT
1228	14-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	4:48	4:59	0:11	LINE FAULT
1229	14-Feb-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:49 (13.02.2022)	7:17 (14.02.2022)	10:28 HRS	LINE CHARGED
1230	14-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	9:10	9:19	0:09	LINE CLEAR AVAILED
1231	14-Feb-2022	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	9:10	9:19	0:09	LINE CLEAR AVAILED
1232	14-Feb-2022	GULBARGA	110	MUNIRABAD-KOPPAL	KIRLOSHKAR_IPP,HARE KRISHNA_IPP, STATR METALIC_IPP	18:52	19:14	0:22	LINE FAULT
1233	14-Feb-2022	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDI NNI_110	4:42	4:52	0:10	LINE FAULT
1234	14-Feb-2022	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDI NNI_110	4:56	5:08	0:12	LINE FAULT
1235	14-Feb-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	11:28	14:20	2:52	LINE CLEAR AVAILED
1236	14-Feb-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERDONA_110,SRNAGAR_110 ,MALLAPURA_110,JAWALGER A_110	19:28	19:38	0:10	LINE FAULT
1237	14-Feb-2022	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	23:48	23:58	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1238	14-Feb-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	16:25	16:38	0:35	LINE CLEAR AVAILED
1239	14-Feb-2022	GULBARGA	110	MUDDAPUR-MASKI	MUDDAPURA_110	8:15	8:30	0:15	MAIN SUPPLY FAILURE
1240	14-Feb-2022	GULBARGA	110	YAKATPUR-HALBARGA	YAKATPUR_110	0:50	1:25	0:35	MAIN SUPPLY FAILURE
1241	14-Feb-2022	GULBARGA	110	BYGWAT-ACMBSLR	BYGWAT_110	5:10	5:20	0:10	LINE FAULT
1242	14-Feb-2022	GULBARGA	110	GABBUR-SHAHPUR	GABBUR_110	5:04	6:30	1:26	MAIN SUPPLY FAILURE
1243	14-Feb-2022	GULBARGA	110	GABBUR-DEODURGA	GABBUR_110	10:50	11:55	1:05	NFBC ISSUED
1244	14-Feb-2022	GULBARGA	110	NALWAR-SHAHPUR	NALWAR_110	4:50	6:30	1:40	MAIN SUPPLY FAILURE
1245	14-Feb-2022	GULBARGA	110	HV2	NALWAR_110	12:50	14:20	1:30	LINE CLEAR AVAILED
1246	14-Feb-2022	GULBARGA	110	YAPALDINI-VADAVATTI	YAPALDINI_110	12:40	14:30	1:50	MAIN SUPPLY FAILURE
1247	14-Feb-2022	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGA ON_110,KAMALNAGAR_110	17:43	17:58	0:15	LINE FAULT
1248	14-Feb-2022	GULBARGA	66	HV2	ITTAGI_220	23:42 (14.02.2022)			TRANSFORMER OPEN,TRANSFORMER FAULT
1249	14-Feb-2022	GULBARGA	66	HV2	TELGI_66	14:45	14:50	0:05	TRANSFORMER FAULT
1250	14-Feb-2022	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJ HALLI_66, HOSAHALLI_66	6:35	8:45	0:35	LINE CLEAR AVAILED
1251	14-Feb-2022	GULBARGA	66	ITTAGI-HIREHADGALI2	HIREHADGALI_66,GIRIYAPUR_66,MAGALA_66,SOVENHALLI_66,TUNGA BHADRA_IPP	12:09	12:19	0:10	LINE FAULT
1252	14-Feb-2022	GULBARGA	66	ITTAGI-HIREHADGALI2	HIREHADGALI_66,GIRIYAPUR_66,MAGALA_66,SOVENHALLI_66,TUNGA BHADRA_IPP	22:58	23:04	0:06	LINE FAULT
1253	14-Feb-2022	GULBARGA	66	NEELAGUNDA-PUNABGHATTA	PUNABGHATTA_66,UCHANGI DURGA_66	9:23	9:29	0:06	LINE FAULT
1254	14-Feb-2022	HASSAN	110	JOG110-AMBTR2	JOG_110	13:08 (26.01.2022)			LINE OPEN,LINE CLEAR AVAILED
1255	14-Feb-2022	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:32(13.02.2022)			LINE OPEN,LINE CLEAR AVAILED
1256	14-Feb-2022	HASSAN	220	HV1	ARSIKERE_220	14:56	15:24	0:28	HAND TRIPPED
1257	14-Feb-2022	HASSAN	220	ARSK2-SHMG	ARSIKERE_220	14:56	16:50	1:54	LINE FAULT
1258	14-Feb-2022	HASSAN	220	HV1	KADUR_220	15:00	15:02	0:02	TRANSFORMER FAULT
1259	14-Feb-2022	HASSAN	220	HV2	KADUR_220	15:00	15:02	0:02	TRANSFORMER FAULT
1260	14-Feb-2022	HASSAN	110	KADUR-AJAMPURA	KADUR_220	15:00	15:04	0:04	MAIN SUPPLY FAILURE
1261	14-Feb-2022	HASSAN	110	LV1	KADUR_220	15:00	15:02	0:02	MAIN SUPPLY FAILURE
1262	14-Feb-2022	HASSAN	110	LV2	KADUR_220	15:00	15:02	0:02	MAIN SUPPLY FAILURE
1263	14-Feb-2022	HASSAN	110	KADUR-NERELEKERE	KADUR_220	15:00	15:04	0:04	MAIN SUPPLY FAILURE
1264	14-Feb-2022	HASSAN	110	KADUR-NGNHL	KADUR_220	15:00	15:04	0:04	MAIN SUPPLY FAILURE
1265	14-Feb-2022	HASSAN	110	KADUR-TNGL	KADUR_220	15:00	15:04	0:04	MAIN SUPPLY FAILURE
1266	14-Feb-2022	HASSAN	110	KADUR-YGTI	KADUR_220	15:00	15:04	0:04	MAIN SUPPLY FAILURE
1267	14-Feb-2022	HASSAN	220	MRSSHM-HASSAN	MRSSHM	14:56	16:42	1:46	LINE FAULT
1268	14-Feb-2022	HASSAN	220	MRSSHM-SHARAVATHY4	MRSSHM	13:31	16:10	2:39	LINE FAULT
1269	14-Feb-2022	HASSAN	220	MRSSHM-SHARAVATHY4	MRSSHM	13:42	14:11	0:29	HAND TRIPPED
1270	14-Feb-2022	HASSAN	66	MRSSHM-DVG2	MRSSHM	16:32	16:38	0:06	LINE FAULT
1271	14-Feb-2022	HASSAN	220	HV1	MSEZ_220	10:10	15:00	4:50	LINE CLEAR AVAILED
1272	14-Feb-2022	HASSAN	220	HV1	MSEZ_220	10:10	15:00	4:50	LINE CLEAR AVAILED
1273	14-Feb-2022	HASSAN	220	SHRAVTY-SHIMOGA4	SHARAVATHY_GEN	13:31	16:10	2:39	LINE FAULT
1274	14-Feb-2022	HASSAN	220	SHRAVTY-SHIMOGA4	SHARAVATHY_GEN	13:42	14:11	0:29	HAND TRIPPED
1275	14-Feb-2022	HASSAN	110	ARSK2-GANDASI	ARSIKERE_220	14:56	15:28	0:32	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1276	14-Feb-2022	HASSAN	110	ARSK2-GERUMARA	ARSIKERE_220	14:56	15:28	0:32	MAIN SUPPLY FAILURE
1277	14-Feb-2022	HASSAN	110	LV1	ARSIKERE_220	14:56	15:28	0:32	MAIN SUPPLY FAILURE
1278	14-Feb-2022	HASSAN	110	HV1	KEMAR_220	10:43	16:03	5:20	LINE CLEAR AVAILED
1279	14-Feb-2022	HASSAN	66	BANDISH-ADANI	BANDISHETTIHALLI_66	19:17	19:24	0:07	LINE FAULT
1280	14-Feb-2022	HASSAN	66	HV1	DODDAHALLI_66	16:13	17:41	1:28	LINE CLEAR AVAILED
1281	14-Feb-2022	HASSAN	66	HV1	HIREMANGALORE_66	10:00	16:35	6:35	LINE CLEAR AVAILED
1282	14-Feb-2022	HASSAN	66	HV2	HIREMANGALORE_66	10:00	16:35	6:35	LINE CLEAR AVAILED
1283	14-Feb-2022	HASSAN	66	MATTNAV-DIDGTHL	MATTANAVILE_66	14:02	14:14	0:12	LINE FAULT
1284	14-Feb-2022	MYSURU	66	KHB STATION-BILIKERE	KHBCOLONY_66	13:16	13:21	0:04	HAND TRIPPED
1285	14-Feb-2022	MYSURU	66	KIRUGAVALU-MALIYUR	NO STATIONS EFFECTED	15:25	15:31	0:06	LINE FAULT
1286	14-Feb-2022	MYSURU	66	MADHUVANAHALLI- LOKKANAHALLI	LOKKANAHALLI_66 PG PALYA_66	5:57	6:06	0:09	LINE FAULT
1287	14-Feb-2022	MYSURU	220	HEBBANI-MADHUVANAHALLI 1	NO STATIONS EFFECTED	10:26	11:01	0:35	LINE CLEAR AVAILED
1288	14-Feb-2022	MYSURU	220	HEBBANI-MADHUVANAHALLI 2	NO STATIONS EFFECTED	11:44	12:50	1:06	LINE CLEAR AVAILED
1289	14-Feb-2022	MYSURU	66	HV1	KADABALLY_66	14:00	14:15	0:15	MAIN SUPPLY FAILURE
1290	14-Feb-2022	MYSURU	66	HV2	THUMBLA_66	12:40	17:05	4:25	LINE CLEAR AVAILED
1291	14-Feb-2022	MYSURU	66	VYASARAJAPURA- GARGESHWARI	VYASRAJPURA_66	10:54	11:50	0:56	LINE CLEAR AVAILED
1292	14-Feb-2022	MYSURU	66	HV1	SOMANAHALLI_66	16:04	16:14	0:10	TRANSFORMER FAULT
1293	14-Feb-2022	MYSURU	66	HV2	HOSURGATE_66	13:40	13:45	0:05	TRANSFORMER FAULT
1294	14-Feb-2022	MYSURU	66	HV1	CHINAKURALI_66	12:30	12:50	0:20	LINE CLEAR AVAILED
1295	14-Feb-2022	MYSURU	66	HV2	CHINAKURALI_66	12:30	12:50	0:20	LINE CLEAR AVAILED
1296	14-Feb-2022	MYSURU	66	HV5	SFCSHIVA_66	20:10:00 (10.2.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1297	14-Feb-2022	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)			LINE OPEN,LINE CLEAR AVAILED
1298	14-Feb-2022	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN,LINE CLEAR AVAILED
1299	14-Feb-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1300	14-Feb-2022	TUMKUR	400	GUTTUR 400	GUTTUR 400	8:57	16:25	7:28	LINE CLEAR AVAILED
1301	14-Feb-2022	TUMKUR	220	AVAREGERE 66kV-DAVANGERE SRS	DAVANAGERE_220	7:40	7:50	0:10	LINE FAULT
1302	14-Feb-2022	TUMKUR	220	AVAREGERE 66kV-DAVANGERE SRS	DAVANAGERE_220	7:50	10:53	3:03	LINE FAULT
1303	14-Feb-2022	TUMKUR	220	AVAREGERE 66kV-DAVANGERE SRS	DAVANAGERE_220	12:08	12:20	0:12	LINE FAULT
1304	14-Feb-2022	TUMKUR	220	DAVANGERE SRS- CHITRADURGA2	DAVANAGERE_220	13:03	13:16	0:13	LINE FAULT
1305	14-Feb-2022	TUMKUR	220	DAVANGERE SRS- CHITRADURGA2	DAVANAGERE_220	16:34	16:44	0:10	LINE FAULT
1306	14-Feb-2022	TUMKUR	220	HONNALLI 220KV- NYAMATHI	HONNALLI 220KV	9:50	10:13	0:23	LINE FAULT
1307	14-Feb-2022	TUMKUR	220	DODDAGUNI- NITTUR	DODDAGUNI_110	11:59	13:02	1:03	LINE CLEAR AVAILED
1308	14-Feb-2022	TUMKUR	110	KB CROSS 220kv- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110	14:40	15:15	0:35	LINE CLEAR AVAILED
1309	14-Feb-2022	TUMKUR	110	HULIYAR110-C N HALLI	CHIKKANAYAKANAHALLI_110	13:30	15:25	1:55	LINE CLEAR AVAILED
1310	14-Feb-2022	TUMKUR	66	TR1	CHIKKABANAGERE_66	11:41	11:54	0:13	HAND TRIPPED
1311	14-Feb-2022	TUMKUR	66	TR1	MEDIGESHI_66	11:55	13:35	1:40	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1312	14-Feb-2022	TUMKUR	66	MADHUGIRI 220kV- MEDIGESHI 1	MEDIGESHI_66	12:20	13:30	1:10	LINE CLEAR AVAILED
1313	14-Feb-2022	TUMKUR	66	MEDIGESHI- CLEAN SOLAR PVT LTD IPP_66	MEDIGESHI_66	12:35	13:30	0:55	LINE CLEAR AVAILED
1314	14-Feb-2022	TUMKUR	66	MIDIGESHI-PAVAGADA220	MEDIGESHI_66	12:35	13:30	0:55	LINE CLEAR AVAILED
1315	14-Feb-2022	TUMKUR	66	PAVAGADA220-MEDEGESHI66	MEDIGESHI_66	12:35	13:30	0:55	LINE CLEAR AVAILED
1316	14-Feb-2022	TUMKUR	66	TR1	THIPPUR_66	8:25	8:35	0:10	TRANSFORMER FAULT
1317	14-Feb-2022	TUMKUR	66	TR2	LINGADHALLI_66	15:05	15:10	0:05	TRANSFORMER FAULT
1318	14-Feb-2022	TUMKUR	66	TR2	HANAGAL_66	16:00	17:20	1:20	LINE CLEAR AVAILED