

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 30.07.2019 TO 05.08.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
1	30-Jul-19	BAGALKOT	110	110/33KV,HV3	BAGEWADI_220,MUTTAGI_33,M ANAGULI_33	7:00	18:45	11:45	TRANSFORMER FAULT
2	30-Jul-19	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	0:00	0:17	0:17	LINE CLEAR AVAILED
3	30-Jul-19	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	2:12	2:22	0:10	LINE FAULT
4	30-Jul-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	1:05	7:30	6:25	LINE CLEAR AVAILED
5	30-Jul-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	20:34	23:59	3:25	LINE CLEAR AVAILED
6	30-Jul-19	BAGALKOT	110	HUBLI-RAMANAKOPPA	RAMANAKOPPA_110 & MUNDAGOD_110	3:32	15:31	11:59	LINE FAULT
7	30-Jul-19	BAGALKOT	220	220/110KV,HV3	HUBLI_220	3:32	4:07	0:35	TRANSFORMER FAULT
8	30-Jul-19	BAGALKOT	110	RANEENNUR- TUMMINKATTI(RATTIHALLI)	TUMMINAKATTI_110	23:43	23:59	0:16	LINE FAULT
9	30-Jul-19	BAGALKOT	220	220/110KV,HV1	MK HUBLI_220	3:47	9:11	5:24	TRANSFORMER FAULT
10	30-Jul-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	3:21	9:27	6:06	LINE CLEAR AVAILED
11	30-Jul-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	3:10	6:41	3:31	LINE CLEAR AVAILED
12	30-Jul-19	BAGALKOT	110	GSML1-MAHALINGAPUR	MAHALINGAPUR_220	0:10	2:30	2:20	LINE CLEAR AVAILED
13	30-Jul-19	BAGALKOT	220	110/33KV,HV2	MAHALINGAPUR_220, HALLUR_33KV,MALALI_33KV	5:30	12:45	7:15	TRANSFORMER FAULT
14	30-Jul-19	BAGALKOT	220	KUDUCHI-MAHALINGAPUR	KUDUCHI_220	7:40	8:25	0:45	LINE FAULT
15	30-Jul-19	BAGALKOT	110	KUDUCHI220-KUDUCHI	KUDUCHI_110	15:20	15:45	0:25	HAND TRIPPED
16	30-Jul-19	BAGALKOT	110	110/33KV,HV1	MAHALINGAPUR_220,DEMPODAI RY_33KV,JAGADAL_33KV	8:30	8:35	0:05	HAND TRIPPED
17	30-Jul-19	BAGALKOT	110	INDI220-ZALKI 1&2	ZALKI_110	17:25	18:45	1:20	LINE CLEAR AVAILED
18	30-Jul-19	BAGALKOT	110	INDI220-DEVAR HIPPARGI	DEVAR HIPPARGI_110	6:07	6:11	0:04	LINE FAULT
19	30-Jul-19	BAGALKOT	110	110/33KV,HV1	MAHALINGAPUR_220,DEMPODAI RY_33KV,JAGADAL_33KV	12:45	13:00	0:15	HAND TRIPPED
20	30-Jul-19	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	11:42	11:51	0:09	LINE FAULT
21	30-Jul-19	BENGALURU	66	SADLI - JULUPALYA	JULUPALYA	9:45	9:55	0:10	LOAD CHANGEVER
22	30-Jul-19	BENGALURU	66	MITTEMARI 220 - SADLI	JULUPALYA	20:10	20:20	0:10	LOAD CHANGEVER
23	30-Jul-19	BENGALURU	66	SOMENAHALLI - CHINTAMANI 220	SOMENAHALLI	9:50	9:56	0:06	LOAD CHANGEVER
24	30-Jul-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI	20:11	20:20	0:09	LOAD CHANGEVER
25	30-Jul-19	BENGALURU	66	GOWRIBIDANUR 220 - DB 2	THONDEBHAVI, MANCHENAHALLI	8:10	8:45	0:35	LINE CLEAR AVAILED
26	30-Jul-19	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	3:20	10:01	6:41	LINE FAULT
27	30-Jul-19	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	1:30	1:35	0:05	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
28	30-Jul-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	2:34	2:40	0:06	LINE FAULT
29	30-Jul-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110	2:14	2:23	0:09	LINE FAULT
30	30-Jul-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARAGUTTI_110	3:04	3:13	0:09	LINE FAULT
31	30-Jul-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110	6:21	6:25	0:04	LINE FAULT
32	30-Jul-19	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	5:20	5:27	0:07	LINE FAULT
33	30-Jul-19	GULBARGA	110	HV2	SHAHPUR_220	2:00	2:44	0:44	TRANSFORMER FAULT
34	30-Jul-19	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	5:20	5:27	0:07	LINE FAULT
35	30-Jul-19	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110	0:38	0:51	0:13	LINE FAULT
36	30-Jul-19	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110	20:20	20:26	0:06	LINE FAULT
37	30-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:40	23:59	0:19	HAND TRIPPED
38	30-Jul-19	HASSAN	66	HV1	HIRESAVE_66	14:40	15:40	1:00	MAIN SUPPLY FAILURE
39	30-Jul-19	HASSAN	66	HNPR2-HASS3	HNPURA_220	12:05	13:40	1:35	LINE FAULT
40	30-Jul-19	HASSAN	66	HV1	JUTTANAHALLY_66	14:40	15:40	1:00	MAIN SUPPLY FAILURE
41	30-Jul-19	MYSORE	66	KR PETE 220-MAHADESHWARA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	3:05	3:15	0:10	LINE FAULT
42	30-Jul-19	MYSORE	66	KR PETE 220-MAHADESHWARA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	4:08	7:50	3:42	LINE CLEAR AVAILED
43	30-Jul-19	MYSORE	66	KR PETE 220-MAHADESHWARA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	14:30	14:35	0:05	LINE FAULT
44	30-Jul-19	MYSORE	66	KR PETE 220-MAHADESHWARA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	15:00	15:05	0:05	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
45	30-Jul-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 KESLAGERE_66	6:22	6:30	0:08	LINE FAULT
46	30-Jul-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 KESLAGERE_66	6:39	6:45	0:06	LINE FAULT
47	31-Jul-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	5:57	6:08	0:11	LINE FAULT
48	31-Jul-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	6:12	8:41	2:29	LINE FAULT
49	31-Jul-19	BAGALKOT	110	110/11KV,HV1	BILAGI_110	12:35	18:10	5:35	LINE CLEAR AVAILED
50	31-Jul-19	BAGALKOT	220	PONDA1&2-AMBEWADI	AMBEWADI_220	11:04	13:47	2:43	LINE CLEAR AVAILED
51	31-Jul-19	BAGALKOT	110	BELGUAM220-BELGUAM	BELGUAM_110	15:41	23:59	8:18	LINE CLEAR AVAILED
52	31-Jul-19	BAGALKOT	220	NARENDRA1-BELGAUM	BELGUAM_220	0:31	7:52	7:21	LINE CLEAR AVAILED
53	31-Jul-19	BAGALKOT	220	BELGUAM220-CHIKKODI2	BELGUAM_220	0:00	7:38	7:38	LINE CLEAR AVAILED
54	31-Jul-19	BAGALKOT	220	NARENDRA1-BELGAUM	BELGUAM_220	21:06	23:59	2:53	LINE CLEAR AVAILED
55	31-Jul-19	BAGALKOT	220	BELGUAM220-CHIKKODI2	BELGUAM_220	18:02	23:59	5:57	LINE CLEAR AVAILED
56	31-Jul-19	BAGALKOT	110	110/11KV,HV4	GHATAPRABHA_110	12:04	13:07	1:03	LINE CLEAR AVAILED
57	31-Jul-19	BAGALKOT	110	110/11KV,HV2	ITANAL_110	20:27	20:43	0:16	TRANSFORMER FAULT
58	31-Jul-19	BAGALKOT	110	110/33KV,HV1	KUMTA_110,MAREKAL_33KV,ANK OLA_33KV	10:46	13:35	2:49	LINE CLEAR AVAILED
59	31-Jul-19	BAGALKOT	110	GSML1-MAHALINGAPUR	MAHALINGAPUR_220	17:40	21:02	3:22	LINE CLEAR AVAILED
60	31-Jul-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	0:06	9:32	9:26	LINE CLEAR AVAILED
61	31-Jul-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	23:27	23:59	0:32	HAND TRIPPED
62	31-Jul-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	23:24	23:59	0:35	HAND TRIPPED
63	31-Jul-19	BAGALKOT	220	VAISHALI1-BIJAPUR	BIJAPUR_220	14:45	16:23	1:38	LINE CLEAR AVAILED
64	31-Jul-19	BAGALKOT	220	VAISHALI2-BIJAPUR	BIJAPUR_220	14:45	16:00	1:15	LINE CLEAR AVAILED
65	31-Jul-19	BAGALKOT	220	BIJAPUR-INDI1	BIJAPUR_220	15:37	16:00	0:23	LINE CLEAR AVAILED
66	31-Jul-19	BAGALKOT	110	ENERCON-BIJAPUR	BIJAPUR_220	14:47	16:00	1:13	LINE CLEAR AVAILED
67	31-Jul-19	BAGALKOT	110	BIJAPUR220-BIJAPURCITY	BIJAPUR CITY_110	6:48	14:54	8:06	LINE FAULT
68	31-Jul-19	BAGALKOT	220	BAGEWADI-BIJAPUR2	BAGEWADI_220	14:00	14:56	0:56	HAND TRIPPED
69	31-Jul-19	BAGALKOT	220	BAGEWADI-BIJAPUR1	BAGEWADI_220	14:00	14:39	0:39	HAND TRIPPED
70	31-Jul-19	BAGALKOT	110	110/33KV,HV3	ZALKI_110,HORTI_33KV	22:24	22:32	0:08	TRANSFORMER FAULT
71	31-Jul-19	BAGALKOT	110	110/11KV,HV2	YELPHARATTI_110	15:19	15:24	0:05	TRANSFORMER FAULT
72	31-Jul-19	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	2:43	14:20	11:37	LINE CLEAR AVAILED
73	31-Jul-19	BAGALKOT	110	JAMKHANDI SUGAR-TODALBAGI	TODALBAGI_110	9:01	13:58	4:57	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
74	31-Jul-19	BAGALKOT	110	110/11KV,HV1	TARIHAL_110	15:00	17:25	2:25	LINE CLEAR AVAILED
75	31-Jul-19	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110	6:13	6:17	0:04	LINE FAULT
76	31-Jul-19	BAGALKOT	110	VAJRAMATTI220-SHIRAGUPPI	SHIRAGUPPI_110	6:05	6:10	0:05	LINE FAULT
77	31-Jul-19	BAGALKOT	110	RANEENNUR-TUNMMINAKATTI(RATTIHALLI)	TUMMINAKATTI_110	0:00	8:44	8:44	LINE CLEAR AVAILED
78	31-Jul-19	BAGALKOT	110	RANEENNUR-TUNMMINAKATTI(RATTIHALLI)	TUMMINAKATTI_110	12:12	12:39	0:27	HAND TRIPPED
79	31-Jul-19	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)_-RANEENNUR	RANEENNUR_220	18:26	23:59	5:33	LINE CLEAR AVAILED
80	31-Jul-19	BAGALKOT	110	SPV-MUKARTHIHAL	MUKARTHIHAL_110	12:14	12:38	0:24	LOAD CURTAILMENT
81	31-Jul-19	BENGALURU	66	HV2	NRS 220	14:16	14:20	0:03	MAIN SUPPLY FAILURE
82	31-Jul-19	BENGALURU	66	HV2	NRS 220	14:16	15:16	1:00	LOAD CHANGEOVER
83	31-Jul-19	BENGALURU	66	VR DODDI - SOMANAHALLI 220	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	7:31	7:37	0:06	LINE FAULT
84	31-Jul-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	11:42	11:53	0:10	LOAD CHANGEOVER
85	31-Jul-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	13:36	13:43	0:07	LOAD CHANGEOVER
86	31-Jul-19	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	15:09	15:13	0:04	LOAD CHANGEOVER
87	31-Jul-19	BENGALURU	66	SADLI - JULUPALYA	JULUPALYA	9:45	10:00	0:15	LOAD CHANGEOVER
88	31-Jul-19	BENGALURU	66	MITTEMARI 220 - JULUPALYA	JULUPALYA	18:00	18:18	0:18	LOAD CHANGEOVER
89	31-Jul-19	BENGALURU	66	SOMENAHALLI - CHINTAMANI 220	SOMENAHALLI	9:45	10:15	0:30	LOAD CHANGEOVER
90	31-Jul-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI	18:05	18:15	0:10	LOAD CHANGEOVER
91	31-Jul-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	14:54	14:57	0:03	LINE FAULT
92	31-Jul-19	BENGALURU	66	HV1	DABUSPET 220	6:43	8:03	1:19	TRANSFORMER FAULT
93	31-Jul-19	GULBARGA	220	HUMNABAD-SEDAM1,2	HUMNABAD_220	11:47	11:59	0:12	LINE FAULT
94	31-Jul-19	GULBARGA	220	SEDAM-CLANMAX_IPP	SEDAM_220	11:20	11:37	0:17	LINE CLEAR AVAILED
95	31-Jul-19	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	11:45	12:10	0:25	LINE FAULT
96	31-Jul-19	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	12:55	18:55	6:00	LINE CLEAR AVAILED
97	31-Jul-19	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	19:35	23:59	4:24	LINE CLEAR AVAILED
98	31-Jul-19	GULBARGA	110	SINDHANOOR220-RAICHUR1	VALKAMDINNI_110	5:33	5:44	0:11	LINE FAULT
99	31-Jul-19	GULBARGA	110	KAPNOOR220-HUMNABAD2	ALAND_110,KADAGANCHI_110	1:11	1:23	0:12	LINE FAULT
100	31-Jul-19	GULBARGA	110	MASKI-RENEWSOLAR	MASKI_110	9:48	10:07	0:19	LINE FAULT
101	31-Jul-19	GULBARGA	110	HV2	SHORAPUR_110	11:40	11:55	0:15	TRANSFORMER FAULT
102	31-Jul-19	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	KOLHAR_110	14:05	14:21	0:16	LINE CLEAR AVAILED
103	31-Jul-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	20:05	20:11	0:06	LINE FAULT
104	31-Jul-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	20:18	20:33	0:15	LINE FAULT
105	31-Jul-19	GULBARGA	66	KOTTUR-ITTAGI	KOTTUR_66	10:45	10:58	0:13	MAIN SUPPLY FAILURE
106	31-Jul-19	GULBARGA	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	8:50	9:03	0:13	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
107	31-Jul-19	GULBARGA	66	LV1, LV2	ITTAGI_220	10:45	10:50	0:05	LINE FAULT
108	31-Jul-19	GULBARGA	66	ITTAGI-CLNMAX1	ITTAGI_220	13:22	13:27	0:05	LINE CLEAR AVAILED
109	31-Jul-19	GULBARGA	66	ITTAGI-BENNEHALLI	BENNEHALI_66, KOTTUR_66, UJJA NI_66	15:42	15:46	0:04	LINE CLEAR AVAILED
110	31-Jul-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	6:38	6:38	LINE CLEAR AVAILED
111	31-Jul-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	18:00	19:16	1:16	LINE CLEAR AVAILED
112	31-Jul-19	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	6:59	12:55	5:56	LINE CLEAR AVAILED
113	31-Jul-19	HASSAN	220	HV1	SHIRALKOPPA_220	12:06	18:05	5:59	LINE CLEAR AVAILED
114	31-Jul-19	HASSAN	220	HV2	SHIRALKOPPA_220	12:05	18:05	6:00	LINE CLEAR AVAILED
115	31-Jul-19	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	12:11	18:25	6:14	LINE CLEAR AVAILED
116	31-Jul-19	HASSAN	110	HV2	AJJAMPURA_110	10:58	11:44	0:46	LINE CLEAR AVAILED
117	31-Jul-19	HASSAN	110	HV2	ESSUR_110	15:17	16:02	0:45	LINE CLEAR AVAILED
118	31-Jul-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	12:11	18:25	6:14	LINE CLEAR AVAILED
119	31-Jul-19	HASSAN	110	LV1	SHIRALKOPPA_220	12:06	18:05	5:59	LINE CLEAR AVAILED
120	31-Jul-19	HASSAN	110	LV2	SHIRALKOPPA_220	12:06	18:05	5:59	LINE CLEAR AVAILED
121	31-Jul-19	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:11	18:25	6:14	LINE CLEAR AVAILED
122	31-Jul-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	12:11	18:25	6:14	LINE CLEAR AVAILED
123	31-Jul-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	12:11	18:25	6:14	LINE CLEAR AVAILED
124	31-Jul-19	HASSAN	110	TOGARSI-BALIGAVI	TOGARSI_110	12:05	13:05	1:00	MAIN SUPPLY FAILURE
125	31-Jul-19	HASSAN	110	TOGARSI-BALIGAVI	TOGARSI_110	18:05	18:25	0:20	MAIN SUPPLY FAILURE
126	31-Jul-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	14:46	14:50	0:04	LINE CLEAR AVAILED
127	31-Jul-19	HASSAN	66	HV2	CHIKMAGALUR_66	11:19	11:43	0:24	LINE CLEAR AVAILED
128	31-Jul-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	11:30	11:35	0:05	HAND TRIPPED
129	31-Jul-19	HASSAN	66	HV2	HOLALUR_66	16:05	17:08	1:03	LINE CLEAR AVAILED
130	31-Jul-19	MYSORE	66	HV2	HARVEY-	17:57	18:14	0:16	HAND TRIPPED
131	31-Jul-19	MYSORE	220	HV1	KUSHALANAGARA 220-	16:09	16:39	0:30	LINE CLEAR AVAILED
132	31-Jul-19	MYSORE	66	KUSHALANAGARA 220-RAMANTHAPURA 1	LUR SIDDAPURA & KANAGAL	16:06	16:45	0:38	HAND TRIPPED
133	31-Jul-19	MYSORE	66	HV2	MADDUR-	10:04	10:28	0:24	LINE CLEAR AVAILED
134	31-Jul-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PG PALYA	10:16	10:22	0:05	LINE FAULT
135	31-Jul-19	MYSORE	66	HV1	MADIKERI-	14:52	15:00	0:08	HAND TRIPPED
136	31-Jul-19	TUMKUR	110	TR-1	GUNGURMALE_110	12:44	17:04	4:20	LINE CLEAR AVAILED
137	31-Jul-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	23:16	23:31	0:14	HAND TRIPPED
138	31-Jul-19	TUMKUR	66	HIRIYUR 220kv- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	12:30	12:40	0:09	HAND TRIPPED
139	31-Jul-19	TUMKUR	66	HIRIYUR 220kv- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	22:31	23:28	0:57	HAND TRIPPED
140	31-Jul-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	23:16	23:31	0:15	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
141	1-Aug-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:00	8:27	8:27	LINE CLEAR AVAILED
142	1-Aug-19	BAGALKOT	220	NARENDRA 1-BELGAUM	BELGAUM_220	0:00	8:26	8:26	LINE CLEAR AVAILED
143	1-Aug-19	BAGALKOT	110	110/11KV,HV1	BILAGI_110	12:40	13:40	1:00	LINE CLEAR AVAILED
144	1-Aug-19	BAGALKOT	110	110/11KV,HV2	BILAGI_110	12:40	13:45	1:05	LINE CLEAR AVAILED
145	1-Aug-19	BAGALKOT	110	CHIKKODI20-SANKESHAWARA	SANKESHAWARA_110	13:12	13:47	0:35	LINE FAULT
146	1-Aug-19	BAGALKOT	110	110/11KV,HV1	GULEDAGUDDA_110	6:03	6:15	0:12	TRANSFORMER FAULT
147	1-Aug-19	BAGALKOT	110	110/11KV,HV2	KALAGATAGI_110	15:02	15:07	0:05	TRANSFORMER FAULT
148	1-Aug-19	BAGALKOT	110	KUDUCHI220-KUDUCHI	KUDUCHI_110	15:10	15:59	0:49	HAND TRIPPED
149	1-Aug-19	BAGALKOT	110	SIRSI220-SIRSI 1	SIRSI_110	12:15	12:35	0:20	HAND TRIPPED
150	1-Aug-19	BAGALKOT	110	SIRSI220-SIRSI 2	SIRSI_110	12:10	12:15	0:05	HAND TRIPPED
151	1-Aug-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	0:00	9:34	9:34	LINE CLEAR AVAILED
152	1-Aug-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	0:00	6:26	6:26	LINE CLEAR AVAILED
153	1-Aug-19	BAGALKOT	220	220/110KV,HV1	MK HUBLI_220	1:05	9:20	8:15	TRANSFORMER FAULT
154	1-Aug-19	BENGALURU	66	SADLI - JULUPALYA	JULUPALYA	11:40	12:35	0:55	LINE CLEAR AVAILED
155	1-Aug-19	BENGALURU	66	SOMENAHALLI - CHINTAMANI 220	SOMENAHALLI	11:00	11:05	0:05	LOAD CHANGEOVER
156	1-Aug-19	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	7:52	7:56	0:04	LINE FAULT
157	1-Aug-19	BENGALURU	66	GANJIGUNTE - DIBBURAHALLI	DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	10:20	10:30	0:10	LINE FAULT
158	1-Aug-19	BENGALURU	66	GANJIGUNTE - DIBBURAHALLI	DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	10:30	10:33	0:03	LINE FAULT
159	1-Aug-19	BENGALURU	66	GANJIGUNTE - DIBBURAHALLI	DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	10:33	11:00	0:27	LINE FAULT
160	1-Aug-19	BENGALURU	66	GANJIGUNTE - DIBBURAHALLI	DIBBURAHALLI, SADALI, SOMENAHALLI	11:40	12:37	0:57	LINE CLEAR AVAILED
161	1-Aug-19	GULBARGA	110	KAPNOOR220-HUMNABAD2	ALAND_110,KADAGANCHI_110	16:03	16:08	0:05	LINE CLEAR AVAILED
162	1-Aug-19	GULBARGA	110	KAPNOOR220-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	16:03	16:10	0:07	LINE FAULT
163	1-Aug-19	GULBARGA	110	KAPNOOR220-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	11:15	11:20	0:05	LINE FAULT
164	1-Aug-19	GULBARGA	110	KAPNOOR220-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	11:30	11:40	0:10	LINE FAULT
165	1-Aug-19	GULBARGA	110	SHAHPUR220-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_110, CORE GREEN SUGUR_IPP	1:10	1:30	0:20	LINE CLEAR AVAILED
166	1-Aug-19	GULBARGA	110	SHAHPUR220-WARDHASOLAR_IPP	SHAHPUR_220	1:10	2:08	0:58	LINE CLEAR AVAILED
167	1-Aug-19	GULBARGA	110	SHAHPUR220-SHAHPUR2	SHAHPUR_110	15:16	15:50	0:34	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
168	1-Aug-19	GULBARGA	110	SHAHPUR220-SHAHAPUR1	SHAHPUR_110	15:38	15:50	0:12	LINE CLEAR AVAILED
169	1-Aug-19	GULBARGA	110	SEDAM-ULTRA TECH CEMENTS	SEDAM_220	19:37	23:59	4:22	LINE CLEAR AVAILED
170	1-Aug-19	GULBARGA	110	HUMNABAD-MARAGUTTI	MAHAGOAN_110,MARGUTTI_110	20:54	21:32	0:38	LINE FAULT
171	1-Aug-19	GULBARGA	110	HUMNABAD-MARAGUTTI	MAHAGOAN_110,MARGUTTI_110	22:06	22:32	0:26	LINE FAULT
172	1-Aug-19	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SRERAMNAGAR_110, GANGAVATHI_110,VENKATAGIRI_110	10:30	10:40	0:10	LINE FAULT
173	1-Aug-19	GULBARGA	110	SINDHANOOR-SIRIGUPPA	TEKKALAKOTE_110,DHADESUGUR_110, SIRIGUPPA_110,NSL_SUGUR_IPP	22:25	22:40	0:15	LINE FAULT
174	1-Aug-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	16:37	23:59	7:22	LINE CLEAR AVAILED
175	1-Aug-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	8:12	8:12	LINE CLEAR AVAILED
176	1-Aug-19	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	10:17	13:08	2:51	LINE CLEAR AVAILED
177	1-Aug-19	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	10:15	13:20	3:05	LINE CLEAR AVAILED
178	1-Aug-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	9:50	10:10	0:20	LINE FAULT
179	1-Aug-19	MYSORE	66	HV1	BEGUR_66	12:05	13:15	1:10	LINE CLEAR AVAILED
180	1-Aug-19	MYSORE	66	HV2	BEGUR_66	13:12	14:25	1:13	LINE CLEAR AVAILED
181	1-Aug-19	MYSORE	66	KUSHALNAGARA 220-MYSORE-1	KRNAGARA_66, BHERYA_66, MIRLE_66, BILIKERE_66, GVGUDI_66, DMG_HALLI_66	5:45	5:57	0:11	LINE FAULT
182	1-Aug-19	MYSORE	66	KUSHALNAGARA 220-BETTADHAPURA	BETTADHAPURA_66, CHUNCHUNKATTE_66, KITTUR_66, RAVANDUR_66	5:45	5:57	0:11	LINE FAULT
183	1-Aug-19	MYSORE	220	HV1	MADHUVANAHALLI_220	16:25	16:57	0:31	LINE CLEAR AVAILED
184	1-Aug-19	MYSORE	220	HV2	MADHUVANAHALLI_220	14:54	16:21	1:26	LINE CLEAR AVAILED
185	1-Aug-19	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	5:27	5:42	0:15	LINE FAULT
186	1-Aug-19	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	13:01	13:08	0:07	LINE CLEAR AVAILED
187	1-Aug-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	16:38	16:50	0:11	HAND TRIPPED
188	1-Aug-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	16:38	16:50	0:11	HAND TRIPPED
189	1-Aug-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	16:38	16:50	0:12	HAND TRIPPED
190	1-Aug-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:38	16:50	0:11	HAND TRIPPED
191	1-Aug-19	TUMKUR	66	TR-2	NAYAKANAHATTI_66	11:09	16:56	5:46	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
192	2-Aug-19	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	7:48	10:48	3:00	TRANSFORMER FAULT
193	2-Aug-19	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	10:58	11:02	0:04	TRANSFORMER FAULT
194	2-Aug-19	BAGALKOT	66	66/33KV,HV4	HARIHAR-HOSPET_66KV,AREMALLAPUR_33KV	10:10	10:16	0:06	TRANSFORMER FAULT
195	2-Aug-19	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	16:02	16:11	0:09	HAND TRIPPED
196	2-Aug-19	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	12:08	12:33	0:25	HAND TRIPPED
197	2-Aug-19	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	0:18	23:59	23:41	LINE FAULT
198	2-Aug-19	BAGALKOT	220	BIJAPUR-INDI 1	BIJAPUR_220	12:28	12:41	0:13	HAND TRIPPED
199	2-Aug-19	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	12:31	13:08	0:36	LINE CLEAR AVAILED
200	2-Aug-19	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	12:31	14:01	1:29	LINE CLEAR AVAILED
201	2-Aug-19	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	14:10	14:15	0:05	LOAD CHANGEOVER
202	2-Aug-19	BENGALURU	66	HV2	MAASTHI	5:55	6:02	0:06	TRANSFORMER FAULT
203	2-Aug-19	BENGALURU	66	VG DODDI - ANCHEPALYA 220	VG DODDI	9:35	13:35	4:00	LINE CLEAR AVAILED
204	2-Aug-19	BENGALURU	66	WELCAST - SRS PEENYA 220	WELCAST	10:45	10:55	0:10	LOAD CHANGEOVER
205	2-Aug-19	BENGALURU	66	WELCAST - ABBIGERE	WELCAST	17:50	18:00	0:10	LOAD CHANGEOVER
206	2-Aug-19	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	12:19	12:36	0:16	LINE CLEAR AVAILED
207	2-Aug-19	BENGALURU	66	HV2	NRS 220	15:53	16:00	0:06	LOAD CHANGEOVER
208	2-Aug-19	BENGALURU	66	HV2	NRS 220	10:46	10:51	0:05	LOAD CHANGEOVER
209	2-Aug-19	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, BIEC, NELAMANGALA 66	10:32	10:46	0:14	LOAD CURTAILMENT
210	2-Aug-19	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	3:50	4:12	0:22	LINE FAULT
211	2-Aug-19	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	14:03	16:33	2:30	LINE CLEAR AVAILED
212	2-Aug-19	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	0:00	16:34	16:34	LINE CLEAR AVAILED
213	2-Aug-19	GULBARGA	220	LINGAPUR-DHONI_IPP	LINGAPUR_220	8:35	19:58	11:23	LINE CLEAR AVAILED
214	2-Aug-19	GULBARGA	220	LINGAPUR-ARRERS_IPP	LINGAPUR_220	9:02	9:41	0:39	LINE CLEAR AVAILED
215	2-Aug-19	GULBARGA	110	KAPNOOR220-MADIYAL	MADIYAL_110, NSLSUGARS_IPP, CHOWDAPUR_110	5:49	7:59	2:10	LINE FAULT
216	2-Aug-19	GULBARGA	110	SEDAM-ULTRA TECH CEMENTS	ULTRA TECH CEMENTS_IPP	0:00	17:00	17:00	LINE CLEAR AVAILED
217	2-Aug-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	10:35	19:15	8:40	LINE CLEAR AVAILED
218	2-Aug-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	23:45	23:59	0:14	LINE FAULT
219	2-Aug-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110, NSLSUGARS_IPP, CHOWDAPUR_110	6:00	6:10	0:10	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
220	2-Aug-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:42	23:59	1:17	LINE CLEAR AVAILED
221	2-Aug-19	HASSAN	220	HASSN220-Shomoga	HASSAN_220	3:22	3:30	0:08	HAND TRIPPED
222	2-Aug-19	HASSAN	220	HV3	KEMAR_220	12:19	12:32	0:13	HAND TRIPPED
223	2-Aug-19	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	8:56	23:59	15:03	LINE CLEAR AVAILED
224	2-Aug-19	HASSAN	110	LV3	KEMAR_220	12:22	12:32	0:10	HAND TRIPPED
225	2-Aug-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	2:17	2:28	0:11	LINE FAULT
226	2-Aug-19	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	10:20	12:33	2:13	LINE CLEAR AVAILED
227	2-Aug-19	HASSAN	110	NANDIKU-KEMAR2	NANDIKU_110	2:17	2:28	0:11	LINE FAULT
228	2-Aug-19	HASSAN	110	HV1	SAGARA_110	12:10	12:15	0:05	HAND TRIPPED
229	2-Aug-19	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	17:09	18:16	1:07	LINE CLEAR AVAILED
230	2-Aug-19	MYSORE	66	HOOTAGALLI-BOGADHI	BOGADHI_66, KALAMANDIRA_66	16:43	16:45	0:01	LINE CLEAR AVAILED
231	2-Aug-19	MYSORE	66	HOOTAGALLI-BOGADHI	BOGADHI_66, KALAMANDIRA_66	16:55	17:04	0:08	LINE FAULT
232	2-Aug-19	MYSORE	220	HV3	HOOTAGALLY_220	16:55	17:52	0:57	LINE CLEAR AVAILED
233	2-Aug-19	MYSORE	66	HV1	K_HONNALGERE_66	11:45	13:16	1:31	LINE CLEAR AVAILED
234	2-Aug-19	MYSORE	66	HV2	K_HONNALGERE_66	14:29	15:42	1:13	LINE CLEAR AVAILED
235	2-Aug-19	MYSORE	66	HV1	MALAVALLI_66	13:20	13:53	0:33	TRANSFORMER FAULT
236	2-Aug-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	11:12	11:43	0:31	LINE CLEAR AVAILED
237	2-Aug-19	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	16:03	17:01	0:57	LINE CLEAR AVAILED
238	2-Aug-19	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	16:02	17:01	0:59	HAND TRIPPED
239	2-Aug-19	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	14:35	17:07	2:31	LINE CLEAR AVAILED
240	2-Aug-19	TUMKUR	110	TR-1	HUNSEGHATTA_110	11:36	16:46	5:10	LINE CLEAR AVAILED
241	2-Aug-19	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	11:31	16:48	5:16	LINE CLEAR AVAILED
242	2-Aug-19	TUMKUR	110	TR-1	SHETYKERE_110	12:44	13:35	0:50	LINE CLEAR AVAILED
243	2-Aug-19	TUMKUR	110	TR-2	SHETYKERE_110	13:21	13:57	0:36	LINE CLEAR AVAILED
244	2-Aug-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	12:22	12:39	0:17	HAND TRIPPED
245	2-Aug-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:26	12:40	0:13	HAND TRIPPED
246	2-Aug-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:30	13:23	0:53	HAND TRIPPED
247	2-Aug-19	TUMKUR	66	TR-1	HIREGUNTANUR_66	15:38	16:01	0:22	LINE CLEAR AVAILED
248	2-Aug-19	TUMKUR	66	TR-1	KUNIGAL_66	14:24	14:30	0:05	TRANSFORMER FAULT
249	2-Aug-19	TUMKUR	66	TR-1	PANDARAHALLI_66	13:14	13:17	0:02	HAND TRIPPED
250	2-Aug-19	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	9:41	9:49	0:08	LINE FAULT
251	3-Aug-19	BAGALKOT	220	NAGJHARI1&2-AMBEWADI	AMBEWADI_220	14:47	15:30	0:43	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
252	3-Aug-19	BAGALKOT	110	GADAG220-BETAGERI	BETAGERI_110	20:37	20:55	0:18	LINE FAULT
253	3-Aug-19	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	20:40	21:00	0:20	HAND TRIPPED
254	3-Aug-19	BAGALKOT	220	NAGJHARI 2-BIDNAL	BIDNAL_220	14:47	17:46	2:59	LINE FAULT
255	3-Aug-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	1:37	7:20	5:43	LINE CLEAR AVAILED
256	3-Aug-19	BAGALKOT	220	BELGAUM-NARENDRA1	BELGAUM_220	1:47	7:04	5:17	LINE CLEAR AVAILED
257	3-Aug-19	BAGALKOT	220	220/110KV,HV2,LV2	BELGAUM_220	1:42	2:10	0:28	HAND TRIPPED
258	3-Aug-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	18:05	23:59	5:54	LINE CLEAR AVAILED
259	3-Aug-19	BAGALKOT	110	110/33KV,HV2	GAJENDRAGHAD_110,WIND1&2_33KV	10:27	10:50	0:23	TRANSFORMER FAULT
260	3-Aug-19	BAGALKOT	110	110/33KV,HV2	GAJENDRAGHAD_110,WIND1&2_33KV	20:39	21:00	0:21	TRANSFORMER FAULT
261	3-Aug-19	BAGALKOT	110	RON1&2-GAJENDRAGHAD	GAJENDRAGHAD_110	20:40	21:25	0:45	MAIN SUPPLY FAILURE
262	3-Aug-19	BAGALKOT	220	KADRA2-KARWAR	KARWAR_220	19:25	20:31	1:06	LINE FAULT
263	3-Aug-19	BAGALKOT	110	KARWAR220-BINAGA	BINAGA_110	19:25	23:59	4:34	LINE FAULT
264	3-Aug-19	BAGALKOT	110	KARWAR220-KUMTA	KUMTA_110	16:05	17:35	1:30	LINE CLEAR AVAILED
265	3-Aug-19	BAGALKOT	110	110/11KV, HV1&HV2	TILUVALI_110	22:53	23:59	1:06	TRANSFORMER FAULT
266	3-Aug-19	BAGALKOT	110	110/33KV, HV3	TILUVALI_110, KALKERI_33, SHESHGIRI_33, KNL_33	22:53	23:59	1:06	TRANSFORMER FAULT
267	3-Aug-19	BAGALKOT	110	SOUDATTI220-SOUDATTI1&2	SOUDATTI_110	9:25	10:29	1:04	LINE CLEAR AVAILED
268	3-Aug-19	BAGALKOT	110	110/11KV,HV2	PG HUNSHYAL_110	13:09	13:50	0:41	LINE CLEAR AVAILED
269	3-Aug-19	BAGALKOT	110	110/11KV,HV1	PG HUNSHYAL_110	12:00	13:00	1:00	LINE CLEAR AVAILED
270	3-Aug-19	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110,ALNAVAR_33KV	23:10	23:13	0:03	TRANSFORMER FAULT
271	3-Aug-19	BAGALKOT	110	BAGEWADI-MATTIHAL	MATTIHAL_110	15:35	15:55	0:20	LINE CLEAR AVAILED
272	3-Aug-19	BAGALKOT	110	110/11KV,HV2	MATTIHAL_110	15:35	15:55	0:20	LINE CLEAR AVAILED
273	3-Aug-19	BAGALKOT	110	110/11KV,HV1	MATTIHAL_110	15:35	15:55	0:20	LINE CLEAR AVAILED
274	3-Aug-19	BAGALKOT	110	110/33KV,HV1	MATTIHAL_110,NTPC_33KV,KARJOL_33KV.KOLAR_33KV	15:35	15:55	0:20	LINE CLEAR AVAILED
275	3-Aug-19	BENGALURU	66	HV1	SIDLAGHATTA	10:23	14:10	3:46	LINE CLEAR AVAILED
276	3-Aug-19	BENGALURU	66	HV1	VG DODDI	9:39	13:13	3:34	LINE CLEAR AVAILED
277	3-Aug-19	BENGALURU	66	HV1	WELCAST	11:00	11:22	0:22	LINE CLEAR AVAILED
278	3-Aug-19	BENGALURU	66	GOLF LINKS - ADUGODI 1	GOLF LINKS	12:40	12:45	0:05	LOAD CHANGEOVER
279	3-Aug-19	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	9:28	9:34	0:06	LINE FAULT
280	3-Aug-19	BENGALURU	66	HV2	AMARJYOTHI	9:24	9:40	0:16	LOAD CHANGEOVER
281	3-Aug-19	BENGALURU	66	HV2	AMARJYOTHI	9:25	9:39	0:14	LOAD CHANGEOVER
282	3-Aug-19	BENGALURU	66	HV2	A STATION 66	10:35	14:00	3:24	LINE CLEAR AVAILED
283	3-Aug-19	BENGALURU	66	HV1	GOLF LINKS	7:30	7:35	0:05	LINE CLEAR AVAILED
284	3-Aug-19	BENGALURU	66	HV1	GOLF LINKS	12:30	12:35	0:05	LINE CLEAR AVAILED
285	3-Aug-19	BENGALURU	66	HV1	HAL 220	9:31	9:36	0:04	LOAD CHANGEOVER
286	3-Aug-19	BENGALURU	66	HV2	HAL 220	9:25	9:30	0:05	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
287	3-Aug-19	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	14:30	14:40	0:10	LINE CLEAR AVAILED
288	3-Aug-19	BENGALURU	66	HV2	PRESTIGE SHANTINIKETHAN	12:30	12:35	0:05	LINE CLEAR AVAILED
289	3-Aug-19	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	4:03	4:06	0:03	LINE FAULT
290	3-Aug-19	GULBARGA	110	SINDHANOOR220-MUNIRABAD1	KARATAGI_110,SRERAMNAGAR_110, GANGAVATHI_110,VENKATAGIRI_110	11:40	13:40	2:00	LINE CLEAR AVAILED
291	3-Aug-19	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	SINDHANOOR_110 , MASKI_110,MUDDAPURA_110	3:10	3:30	0:20	LINE FAULT
292	3-Aug-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	6:30	6:59	0:29	LINE FAULT
293	3-Aug-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110, NSLSUGARS_IPP, CHOWDAPUR_110	5:58	6:10	0:12	LINE FAULT
294	3-Aug-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	0:00	11:40	11:40	LINE FAULT
295	3-Aug-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	4:20	4:30	0:10	LINE FAULT
296	3-Aug-19	GULBARGA	110	YELBURGA-PARAMPOOJYA_IPP	YELBURGA_110	15:25	15:32	0:07	LINE FAULT
297	3-Aug-19	HASSAN	400	TALGU-NELAMANGALA#2	TALAGUPPA_400	0:00	7:09	7:09	LINE CLEAR AVAILED
298	3-Aug-19	HASSAN	400	TALGU-NELAMANGALA#2	TALAGUPPA_400	21:49	23:59	2:10	LINE CLEAR AVAILED
299	3-Aug-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	12:28	13:10	0:42	LINE CLEAR AVAILED
300	3-Aug-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	9:18	19:14	9:56	LINE CLEAR AVAILED
301	3-Aug-19	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	0:00	14:44	14:44	LINE CLEAR AVAILED
302	3-Aug-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	12:28	13:10	0:42	NFBC ISSUED
303	3-Aug-19	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	11:22	13:44	2:22	LINE CLEAR AVAILED
304	3-Aug-19	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	10:48	12:37	1:49	LINE CLEAR AVAILED
305	3-Aug-19	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	9:53	10:00	0:07	LINE CLEAR AVAILED
306	3-Aug-19	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	14:02	17:47	3:45	LINE CLEAR AVAILED
307	3-Aug-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	9:53	10:00	0:07	LINE CLEAR AVAILED
308	3-Aug-19	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	15:00	15:15	0:15	LINE FAULT
309	3-Aug-19	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	9:52	10:00	0:08	LINE CLEAR AVAILED
310	3-Aug-19	MYSORE	66	HV2	HAMPAPURA_66	11:24	11:30	0:05	TRANSFORMER FAULT
311	3-Aug-19	MYSORE	66	HV2	HAMPAPURA_66	15:13	15:23	0:10	TRANSFORMER FAULT
312	3-Aug-19	MYSORE	66	HV2	HAMPAPURA_66	15:36	16:12	0:36	TRANSFORMER FAULT
313	3-Aug-19	MYSORE	66	HOOTAGALLI-BOGADHI	BOGADHI_66, KALAMANDIRA_66	9:31	9:32	0:01	HAND TRIPPED
314	3-Aug-19	MYSORE	66	HOOTAGALLI-DATAGALLI	DATTAGALLY_66	9:45	9:46	0:01	HAND TRIPPED
315	3-Aug-19	MYSORE	66	HV1	HOOTAGALLY_220	9:38	9:40	0:02	HAND TRIPPED
316	3-Aug-19	MYSORE	220	HV1	HOOTAGALLY_220	10:50	0:00	13:09	LINE CLEAR AVAILED
317	3-Aug-19	MYSORE	66	HV2	HOOTAGALLY_220	9:38	9:41	0:02	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
318	3-Aug-19	MYSORE	66	KADAKOLA-SARAGUR 1	JAIPUR_66, HDKOTE_66, HAMPAPURA(K)_66, ANTHARSANTHE_66	6:16	6:22	0:05	LINE FAULT
319	3-Aug-19	MYSORE	66	HV1	KUNTHUR_66	11:27	12:49	1:22	LINE CLEAR AVAILED
320	3-Aug-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	11:57	13:31	1:33	NFBC ISSUED
321	3-Aug-19	TUMKUR	110	TURUVEKERE_110	TURUVEKERE_110	9:11	9:22	0:11	MAIN SUPPLY FAILURE
322	3-Aug-19	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	0:30	0:45	0:15	LINE FAULT
323	3-Aug-19	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	11:48	13:48	2:00	LINE CLEAR AVAILED
324	3-Aug-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	11:06	12:45	1:38	LINE CLEAR AVAILED
325	3-Aug-19	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	13:47	14:06	0:18	LINE FAULT
326	3-Aug-19	TUMKUR	66	KUNDUR- RSOLAR	RSOLAR_IPP_66	13:47	14:06	0:18	LINE FAULT
327	3-Aug-19	TUMKUR	66	TR-2	SANIKERE_66	8:24	9:12	0:47	LINE CLEAR AVAILED
328	3-Aug-19	TUMKUR	66	TR-2	THALLAKK_220	7:32	9:39	2:06	LINE CLEAR AVAILED
329	3-Aug-19	TUMKUR	66	NEELAGUNDA- GUTTUR	NEELAGUNDA_220	15:54	16:35	0:40	LINE FAULT
330	4-Aug-19	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	13:44	14:44	1:00	LINE FAULT
331	4-Aug-19	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	13:45	14:46	1:01	LINE FAULT
332	4-Aug-19	BAGALKOT	110	GADAG220-BETAGERI	BETAGERI_110	7:30	7:40	0:10	LINE FAULT
333	4-Aug-19	BAGALKOT	110	BIJAPUR220-BIJAPUR CITY	BIJAPUR CITY_110	19:03	19:10	0:07	LINE FAULT
334	4-Aug-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:00	7:49	7:49	LINE CLEAR AVAILED
335	4-Aug-19	BAGALKOT	220	220/110KV,LV2	BELGAUM_220	13:05	14:20	1:15	LINE CLEAR AVAILED
336	4-Aug-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	16:50	23:59	7:09	LINE CLEAR AVAILED
337	4-Aug-19	BAGALKOT	110	110/33KV,HV2	GAJENDRAGHAD_110,WIND1&2_33KV	13:30	13:40	0:10	TRANSFORMER FAULT
338	4-Aug-19	BAGALKOT	110	RON1&2-GAJENDRAGHAD	GAJENDRAGHAD_110	7:30	7:55	0:25	MAIN SUPPLY FAILURE
339	4-Aug-19	BAGALKOT	110	KARWAR220-BINAGA	BINAGA_110	0:00	11:25	11:25	LINE CLEAR AVAILED
340	4-Aug-19	BAGALKOT	110	KARWAR220-BINAGA	BINAGA_110	12:00	12:35	0:35	LINE CLEAR AVAILED
341	4-Aug-19	BAGALKOT	110	KARWAR220-BINAGA	BINAGA_110	14:18	15:50	1:32	LINE CLEAR AVAILED
342	4-Aug-19	BAGALKOT	110	110/11KV, HV1&HV2	TILUVALI_110	0:00	2:50	2:50	LINE CLEAR AVAILED
343	4-Aug-19	BAGALKOT	110	110/33KV, HV3	TILUVALI_110, KALKERI_33, SHESHGIRI_33, KNL_33	0:00	2:50	2:50	LINE CLEAR AVAILED
344	4-Aug-19	BAGALKOT	110	SOUDATTI220-RAMDURGA1	RAMDURGA_110	6:21	6:50	0:29	LINE FAULT
345	4-Aug-19	BAGALKOT	110	SOUDATTI220-RAMDURGA2	RAMDURGA_110	6:21	6:55	0:34	LINE FAULT
346	4-Aug-19	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	18:18	23:59	5:41	LINE FAULT
347	4-Aug-19	BAGALKOT	220	220/110KV,HV1,LV1	SIRSI_220	18:18	19:34	1:16	TRANSFORMER FAULT
348	4-Aug-19	BAGALKOT	220	220/110KV,LV1	SIRSI_220	8:05	8:13	0:08	TRANSFORMER FAULT
349	4-Aug-19	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	14:10	20:14	6:04	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
350	4-Aug-19	BAGALKOT	110	SIRSI-SIRSI1	SIRSI_110	8:05	8:14	0:09	LINE FAULT
351	4-Aug-19	BAGALKOT	110	SIRSI-SIRSI1	SIRSI_110	18:18	19:00	0:42	LINE FAULT
352	4-Aug-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	7:58	20:30	12:32	LINE FAULT
353	4-Aug-19	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	10:50	19:48	8:58	LINE FAULT
354	4-Aug-19	BAGALKOT	110	110/11KV,HV2	KULIGOD_110	15:20	15:54	0:34	LINE CLEAR AVAILED
355	4-Aug-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, AMARJYOTHI, BOSCH (EHT)	23:28	23:43	0:15	LINE FAULT
356	4-Aug-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI, AMARJYOTHI, BOSCH (EHT)	23:28	23:43	0:15	LINE FAULT
357	4-Aug-19	BENGALURU	220	HV2	HSR LAYOUT 220	23:28	23:38	0:10	TRANSFORMER FAULT
358	4-Aug-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	23:28	23:38	0:10	MAIN SUPPLY FAILURE
359	4-Aug-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	9:15	10:59	1:44	LINE CLEAR AVAILED
360	4-Aug-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	17:29	18:34	1:05	LINE CLEAR AVAILED
361	4-Aug-19	BENGALURU	66	ABBIGERE - ATTUR YELAHANKA	ABBIGERE	8:20	8:24	0:04	LOAD CHANGEOVER
362	4-Aug-19	BENGALURU	66	ABBIGERE - WELCAST	ABBIGERE	11:40	11:48	0:08	LOAD CHANGEOVER
363	4-Aug-19	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA	9:20	9:45	0:25	LOAD CHANGEOVER
364	4-Aug-19	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	10:15	10:25	0:10	LOAD CHANGEOVER
365	4-Aug-19	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	18:25	18:30	0:05	LOAD CHANGEOVER
366	4-Aug-19	BENGALURU	66	NARASAPURA - KOLAR 220	NARASAPURA	9:40	18:40	9:00	LINE CLEAR AVAILED
367	4-Aug-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:00	18:44	8:44	LINE CLEAR AVAILED
368	4-Aug-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	9:50	18:18	8:28	LINE CLEAR AVAILED
369	4-Aug-19	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	10:20	18:55	8:35	LINE CLEAR AVAILED
370	4-Aug-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR, SM MANGALA	9:50	18:02	8:12	LINE CLEAR AVAILED
371	4-Aug-19	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	9:02	18:10	9:08	LINE CLEAR AVAILED
372	4-Aug-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL	9:55	18:00	8:05	LINE CLEAR AVAILED
373	4-Aug-19	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	10:20	19:08	8:48	LINE CLEAR AVAILED
374	4-Aug-19	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	10:20	17:28	7:08	LINE CLEAR AVAILED
375	4-Aug-19	BENGALURU	66	HV1	KOLAR 220	10:05	17:37	7:32	LINE CLEAR AVAILED
376	4-Aug-19	BENGALURU	66	HV2	KOLAR 220	10:05	18:38	8:33	LINE CLEAR AVAILED
377	4-Aug-19	BENGALURU	220	KOLAR 220 - RAILWAYS 1 & 2	RAILWAYS (EHT)	10:20	17:31	7:11	LINE CLEAR AVAILED
378	4-Aug-19	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	10:15	10:30	0:15	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
379	4-Aug-19	BENGALURU	220	MALUR 220 - SARJAPURA 220	VIKAS TECH PARK 220, SARJAPURA 220	10:15	10:34	0:19	MAIN SUPPLY FAILURE
380	4-Aug-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	10:15	10:33	0:18	MAIN SUPPLY FAILURE
381	4-Aug-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	10:15	10:33	0:18	MAIN SUPPLY FAILURE
382	4-Aug-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, LAKKUR, DEVANGONDHI	10:15	10:33	0:18	MAIN SUPPLY FAILURE
383	4-Aug-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	10:15	10:31	0:16	MAIN SUPPLY FAILURE
384	4-Aug-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	10:15	10:33	0:18	MAIN SUPPLY FAILURE
385	4-Aug-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	10:15	10:33	0:18	MAIN SUPPLY FAILURE
386	4-Aug-19	BENGALURU	220	MALUR 220 - HOODY 220	MALUR 220	17:30	17:45	0:15	LOAD CHANGEOVER
387	4-Aug-19	BENGALURU	220	MALUR 220 - SARJAPURA 220	VIKAS TECH PARK 220, SARJAPURA 220	17:30	18:05	0:35	MAIN SUPPLY FAILURE
388	4-Aug-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	17:22	17:56	0:34	MAIN SUPPLY FAILURE
389	4-Aug-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	17:22	17:58	0:36	MAIN SUPPLY FAILURE
390	4-Aug-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, LAKKUR, DEVANGONDHI	17:22	18:00	0:38	MAIN SUPPLY FAILURE
391	4-Aug-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	17:22	17:51	0:29	MAIN SUPPLY FAILURE
392	4-Aug-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	17:22	17:59	0:37	MAIN SUPPLY FAILURE
393	4-Aug-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	17:22	17:55	0:33	MAIN SUPPLY FAILURE
394	4-Aug-19	BENGALURU	66	KYALNUR - VEMGAL	KYALNUR	9:40	18:00	8:20	LINE CLEAR AVAILED
395	4-Aug-19	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	14:45	15:02	0:17	LOAD CHANGEOVER
396	4-Aug-19	BENGALURU	66	MANYATHA TECH PARK 66 - MANYATHA TECH PARK 220	MANYATHA TECH PARK 66	9:00	18:45	9:45	LINE CLEAR AVAILED
397	4-Aug-19	BENGALURU	220	MANYATHA TECH PARK 220 - YELAHANKA 220	MANYATHA TECH PARK 220	12:10	18:00	5:50	LINE CLEAR AVAILED
398	4-Aug-19	BENGALURU	66	HV1	MANYATHA TECH PARK 220	12:10	18:00	5:50	MAIN SUPPLY FAILURE
399	4-Aug-19	BENGALURU	66	HV2	MANYATHA TECH PARK 220	12:10	18:00	5:50	MAIN SUPPLY FAILURE
400	4-Aug-19	BENGALURU	66	HV3	MANYATHA TECH PARK 220	12:10	18:00	5:50	LINE CLEAR AVAILED
401	4-Aug-19	BENGALURU	66	HV4	MANYATHA TECH PARK 220	12:10	18:00	5:50	MAIN SUPPLY FAILURE
402	4-Aug-19	BENGALURU	66	SARAKKI - SUBRAMANYAPURA 2	SARAKKI	9:30	9:50	0:20	LOAD CHANGEOVER
403	4-Aug-19	BENGALURU	66	SARAKKI - JAYADEVA	SARAKKI	14:38	14:45	0:07	LOAD CHANGEOVER
404	4-Aug-19	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	16:50	17:05	0:15	LOAD CHANGEOVER
405	4-Aug-19	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	18:45	18:55	0:10	LOAD CHANGEOVER
406	4-Aug-19	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	9:36	9:41	0:05	LOAD CHANGEOVER
407	4-Aug-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	1:13	1:28	0:15	LINE FAULT
408	4-Aug-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	4:54	5:12	0:18	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
409	4-Aug-19	HASSAN	110	HV2	HALADY_110	6:38	6:45	0:07	TRANSFORMER FAULT
410	4-Aug-19	HASSAN	110	HV4	BAIKAMPADI_110	10:31	11:37	1:06	LINE CLEAR AVAILED
411	4-Aug-19	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	19:03	20:51	1:48	LINE FAULT
412	4-Aug-19	HASSAN	110	HV2	KULASHEKARA_110	11:03	12:11	1:08	LINE CLEAR AVAILED
413	4-Aug-19	HASSAN	110	HV4	MANIPAL_110	11:40	11:46	0:06	HAND TRIPPED
414	4-Aug-19	HASSAN	110	MRASHM-MYSORE	MRSMSG_220	20:05	20:08	0:03	HAND TRIPPED
415	4-Aug-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	23:20	23:32	0:12	LINE FAULT
416	4-Aug-19	MYSORE	66	HV2	BOOKANAKERE_66	23:08	23:18	0:10	TRANSFORMER FAULT
417	4-Aug-19	MYSORE	66	HV2	KMDODDI_66	17:59	18:09	0:09	TRANSFORMER FAULT
418	4-Aug-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66, MARADIHUNDI_66	9:18	9:53	0:35	LINE FAULT
419	4-Aug-19	TUMKUR	66	TR-2	BUKKAPATNA_66	3:44	3:45	0:00	MAIN SUPPLY FAILURE
420	4-Aug-19	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	3:10	3:17	0:06	LINE FAULT
421	4-Aug-19	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	3:10	3:38	0:28	LINE FAULT
422	4-Aug-19	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	3:10	3:38	0:27	MAIN SUPPLY FAILURE
423	5-Aug-19	BAGALKOT	110	110/11KV, HV1	BILAGI_110	22:05	22:07	0:02	TRANSFORMER FAULT
424	5-Aug-19	BAGALKOT	110	110/33KV, HV2	CHIKKODI_110, KERUR_33, KARACHAGI_33	22:53	23:17	0:24	TRANSFORMER FAULT
425	5-Aug-19	BAGALKOT	110	110/11KV, HV1	SIRSI_110	7:15	7:30	0:15	TRANSFORMER FAULT
426	5-Aug-19	BAGALKOT	110	110/11KV, HV1	SIRSI_110	22:01	22:50	0:49	TRANSFORMER FAULT
427	5-Aug-19	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	0:00	15:20	15:20	LINE CLEAR AVAILED
428	5-Aug-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	21:26	23:59	2:33	LINE FAULT
429	5-Aug-19	BAGALKOT	220	BIJAPUR-INDI1	BIJAPUR_220	15:20	16:50	1:30	LINE CLEAR AVAILED
430	5-Aug-19	BAGALKOT	220	BIJAPUR-INDI1	BIJAPUR_220	16:55	17:05	0:10	LINE CLEAR AVAILED
431	5-Aug-19	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	19:13	19:35	0:22	HAND TRIPPED
432	5-Aug-19	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	13:40	15:10	1:30	LINE CLEAR AVAILED
433	5-Aug-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, AMARJYOTHI, BOSCH (EHT)	23:28	23:43	0:15	LINE FAULT
434	5-Aug-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI, AMARJYOTHI, BOSCH (EHT)	23:28	23:43	0:15	LINE FAULT
435	5-Aug-19	BENGALURU	220	HV2	HSR LAYOUT 220	23:28	23:38	0:10	TRANSFORMER FAULT
436	5-Aug-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	23:28	23:38	0:10	MAIN SUPPLY FAILURE
437	5-Aug-19	BENGALURU	220	DB PURA 220 - BEGUR 220	BEGUR 220	15:31	15:57	0:26	LINE FAULT
438	5-Aug-19	BENGALURU	220	BEGUR 220 - DB PURA 220	BEGUR 220	15:31	15:33	0:02	LINE FAULT
439	5-Aug-19	BENGALURU	220	BEGUR 220 - HOSKOTE 220	HOSKOTE 220	15:31	15:49	0:18	MAIN SUPPLY FAILURE
440	5-Aug-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	15:31	15:51	0:20	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
441	5-Aug-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	15:29	15:54	0:24	LINE FAULT
442	5-Aug-19	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	15:31	15:53	0:22	MAIN SUPPLY FAILURE
443	5-Aug-19	BENGALURU	66	HOSKOTE 220 - PILAGUMPA	PILAGUMPA	15:31	15:51	0:20	MAIN SUPPLY FAILURE
444	5-Aug-19	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	15:31	15:52	0:21	MAIN SUPPLY FAILURE
445	5-Aug-19	BENGALURU	66	HV1	HOSKOTE 220	15:31	15:49	0:18	MAIN SUPPLY FAILURE
446	5-Aug-19	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	15:31	15:37	0:06	MAIN SUPPLY FAILURE
447	5-Aug-19	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	15:31	15:37	0:06	MAIN SUPPLY FAILURE
448	5-Aug-19	BENGALURU	66	BEGUR 220 - BIAL 1 (EHT)	BIAL (EHT)	15:31	15:37	0:06	MAIN SUPPLY FAILURE
449	5-Aug-19	BENGALURU	66	BEGUR 220 - BIAL 2 (EHT)	BIAL (EHT)	15:31	15:37	0:06	MAIN SUPPLY FAILURE
450	5-Aug-19	BENGALURU	66	HV1	BEGUR 220	15:31	15:49	0:18	MAIN SUPPLY FAILURE
451	5-Aug-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	19:02	19:08	0:05	LINE FAULT
452	5-Aug-19	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, AMARJYOTHI, BOSCH (EHT)	9:50	9:59	0:09	LOAD CHANGEOVER
453	5-Aug-19	BENGALURU	66	ADUGODI - HSR LAYOUT	ADUGODI, AMARJYOTHI, BOSCH (EHT)	13:28	13:34	0:06	LOAD CHANGEOVER
454	5-Aug-19	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, AMARJYOTHI, BOSCH (EHT)	15:28	15:37	0:09	LOAD CHANGEOVER
455	5-Aug-19	BENGALURU	66	HV1	AMARJYOTHI	0:43	2:15	1:32	MAIN SUPPLY FAILURE
456	5-Aug-19	BENGALURU	66	HV1	AMARJYOTHI	10:27	10:28	0:01	LOAD CHANGEOVER
457	5-Aug-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	13:49	14:05	0:16	LOAD CHANGEOVER
458	5-Aug-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	17:21	17:31	0:10	LOAD CHANGEOVER
459	5-Aug-19	BENGALURU	66	ADUGODI - HAL 1	AMARJYOTHI	0:50	1:53	1:03	LINE FAULT
460	5-Aug-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI, BOSCH (EHT)	10:13	10:13	0:00	LINE FAULT
461	5-Aug-19	BENGALURU	220	HV2	HSR LAYOUT 220	1:08	1:11	0:02	TRANSFORMER FAULT
462	5-Aug-19	GULBARGA	220	RTPS-LINGSUGUR3	LINGASUGUR_220	12:50	23:59	11:09	LINE FAULT
463	5-Aug-19	GULBARGA	220	RTPS-SHAHAPUR2	SHAHAPUR_220	14:10	23:59	9:49	LINE FAULT
464	5-Aug-19	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	10:35	10:55	0:20	LINE FAULT
465	5-Aug-19	GULBARGA	110	HV2	CHITAGUPPA_110	16:26	17:00	0:34	TRANSFORMER FAULT
466	5-Aug-19	GULBARGA	110	HATTI-GAMESHA_IPP	HATTI_110	10:10	10:20	0:10	LINE CLEAR AVAILED
467	5-Aug-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	9:26	9:26	LINE CLEAR AVAILED
468	5-Aug-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	20:09	20:43	0:34	LINE FAULT
469	5-Aug-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	19:48	20:00	0:12	LINE FAULT
470	5-Aug-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	16:05	16:34	0:29	LINE FAULT
471	5-Aug-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	16:40	23:59	7:19	LINE CLEAR AVAILED
472	5-Aug-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	19:50	19:59	0:09	HAND TRIPPED
473	5-Aug-19	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	16:25	16:50	0:25	LINE FAULT
474	5-Aug-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	9:25	11:45	2:20	LINE FAULT
475	5-Aug-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	20:09	20:43	0:34	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
476	5-Aug-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	16:04	16:27	0:23	LINE FAULT
477	5-Aug-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	19:48	23:59	4:11	LINE FAULT
478	5-Aug-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	16:04	16:27	0:23	LINE FAULT
479	5-Aug-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	21:33	21:53	0:20	LINE FAULT
480	5-Aug-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	16:06	16:34	0:28	LINE FAULT
481	5-Aug-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	16:34	23:59	7:25	LINE FAULT
482	5-Aug-19	HASSAN	220	VARAHI-SHMG3	varahi_gen	9:25	11:45	2:20	LINE FAULT
483	5-Aug-19	HASSAN	110	HV2	PUTTUR_110	18:20	18:47	0:27	TRANSFORMER FAULT
484	5-Aug-19	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	6:29	7:05	0:36	MAIN SUPPLY FAILURE
485	5-Aug-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	9:26	9:37	0:11	LINE FAULT
486	5-Aug-19	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	6:33	6:54	0:21	LINE FAULT
487	5-Aug-19	HASSAN	110	KAVOOR-AMR	KAVOOR_220	6:29	8:10	1:41	LINE FAULT
488	5-Aug-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	6:30	7:08	0:38	MAIN SUPPLY FAILURE
489	5-Aug-19	HASSAN	110	HV2	KULASHEKARA_110	9:51	11:12	1:21	LINE CLEAR AVAILED
490	5-Aug-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	19:50	21:12	1:22	LINE CLEAR AVAILED
491	5-Aug-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	22:47	22:57	0:10	HAND TRIPPED
492	5-Aug-19	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	19:56	22:56	3:00	LINE CLEAR AVAILED
493	5-Aug-19	HASSAN	110	HV1	MANIPAL_110	12:18	12:32	0:14	HAND TRIPPED
494	5-Aug-19	HASSAN	110	HV1	MANIPAL_110	20:25	20:34	0:09	HAND TRIPPED
495	5-Aug-19	HASSAN	110	HV3	MANIPAL_110	20:25	20:34	0:09	HAND TRIPPED
496	5-Aug-19	HASSAN	110	HV4	MANIPAL_110	20:25	20:34	0:09	HAND TRIPPED
497	5-Aug-19	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	19:34	20:31	0:57	HAND TRIPPED
498	5-Aug-19	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	22:48	22:52	0:04	HAND TRIPPED
499	5-Aug-19	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	19:49	22:32	2:43	LINE CLEAR AVAILED
500	5-Aug-19	HASSAN	110	MAQNIPAL-NITTUR	MANIPAL_110	22:03	22:11	0:08	HAND TRIPPED
501	5-Aug-19	HASSAN	110	HV1	SORABA_110	17:09	23:59	6:50	TRANSFORMER FAULT
502	5-Aug-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:43	16:51	0:08	LINE FAULT
503	5-Aug-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	0:53	0:59	0:06	LINE FAULT
504	5-Aug-19	HASSAN	66	HV2	RAMPURA_66	13:45	13:58	0:13	TRANSFORMER FAULT
505	5-Aug-19	HASSAN	66	HV2	RAMPURA_66	14:27	15:01	0:34	LINE CLEAR AVAILED
506	5-Aug-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	3:21	3:34	0:13	LINE FAULT
507	5-Aug-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	3:44	4:18	0:34	LINE FAULT
508	5-Aug-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	15:17	16:14	0:57	LINE CLEAR AVAILED
509	5-Aug-19	MYSORE	66	BILIKERE-GV GUDI	GVGUDI_66	19:14	19:19	0:05	LINE FAULT
510	5-Aug-19	MYSORE	66	HV2	GUNDULPET_66	16:55	17:54	0:58	LINE CLEAR AVAILED
511	5-Aug-19	MYSORE	66	HV1	JAKKANAHALLY_66	12:08	15:14	3:05	LINE CLEAR AVAILED
512	5-Aug-19	MYSORE	66	HV2	JAKKANAHALLY_66	13:54	14:32	0:38	LINE CLEAR AVAILED
513	5-Aug-19	MYSORE	66	HV2	JAKKANAHALLY_66	15:19	17:30	2:10	LINE CLEAR AVAILED
514	5-Aug-19	MYSORE	66	HV1	K_HONNALGERE_66	10:30	10:46	0:15	HAND TRIPPED
515	5-Aug-19	MYSORE	66	HV2	K_HONNALGERE_66	10:30	10:46	0:15	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
516	5-Aug-19	MYSORE	66	HV1	KRNAGARA_66	9:52	10:04	0:12	TRANSFORMER FAULT
517	5-Aug-19	MYSORE	66	PANDAVAPURA-TUBINAKERE	DODDABYADARAHALLI_66, PANDAVAPURA_66	10:52	11:07	0:15	LINE FAULT
518	5-Aug-19	MYSORE	66	HV1	RAVANDUR_66	16:24	17:10	0:45	LINE CLEAR AVAILED
519	5-Aug-19	TUMKUR	220	NEELAGUNDA- ITTAGI	NEELAGUNDA_220	12:56	18:36	5:39	LINE CLEAR AVAILED
520	5-Aug-19	TUMKUR	110	TR-1	TURUVEKERE_110	10:08	12:02	1:54	MAIN SUPPLY FAILURE
521	5-Aug-19	TUMKUR	66	TR-2	BADAVANAHALLI_66	18:21	18:31	0:09	TRANSFORMER FAULT
522	5-Aug-19	TUMKUR	66	TR-2	BADAVANAHALLI_66	19:15	19:24	0:08	TRANSFORMER FAULT
523	5-Aug-19	TUMKUR	66	TR-2	BADAVANAHALLI_66	20:23	20:30	0:07	TRANSFORMER FAULT
524	5-Aug-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	17:54	17:59	0:05	HAND TRIPPED
525	5-Aug-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	16:39	16:51	0:11	LINE FAULT
526	5-Aug-19	TUMKUR	66	TR-1	PULAMG_66	13:19	13:28	0:09	TRANSFORMER FAULT
527	5-Aug-19	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:37	12:40	2:02	LINE FAULT