

400/220/110/66 kV TRANSMISSION OUTAGES FROM :12.10.21 to 18.10.21

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	12-Oct-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
2	12-Oct-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
3	12-Oct-21	BAGALKOT	110	110/11KV, HV1	MUDDEBIHAL_110	9:05	9:12	0:07	TRANSFORMER FAULT
4	12-Oct-21	BAGALKOT	110	110/11KV, HV1	MUDDEBIHAL_110	10:50	10:59	0:09	TRANSFORMER FAULT
5	12-Oct-21	BAGALKOT	110	110/11KV, HV1	KONNUR_110	17:30	17:40	0:10	MAIN SUPPLY FAILURE
6	12-Oct-21	BAGALKOT	110	110/11KV, HV1	NARAGUND_110	6:35	7:15	0:40	MAIN SUPPLY FAILURE
7	12-Oct-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SHIRGAON_110	18:45	20:20	1:35	TRANSFORMER FAULT
8	12-Oct-21	BAGALKOT	110	110/11KV, HV2	NARAGUND_110	17:30	17:40	0:10	MAIN SUPPLY FAILURE
9	12-Oct-21	BAGALKOT	110	110/11KV,HV1	BELLATTI_110	23:38	23:43	0:05	TRANSFORMER FAULT
10	12-Oct-21	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED NIDAGUNDI_110	11:40	12:40	1:00	HAND TRIPPED
11	12-Oct-21	BAGALKOT	110	110/11KV,HV1	AMBEWADI	15:30	16:15	0:45	TRANSFORMER FAULT
12	12-Oct-21	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED NIDAGUNDI_110	13:25	14:35	1:10	HAND TRIPPED
13	12-Oct-21	BAGALKOT	110	110/11KV,HV2	CHIKKODI_110	16:35	18:00	1:25	MAIN SUPPLY FAILURE
14	12-Oct-21	BAGALKOT	110	110/33KV, HV2	KONNUR_110	6:35	7:15	0:40	MAIN SUPPLY FAILURE
15	12-Oct-21	BAGALKOT	110	110/33KV, HV3	KONNUR_110	6:35	7:15	0:40	MAIN SUPPLY FAILURE
16	12-Oct-21	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED CHIKKODI_110 , KHAROSHI_33 & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
17	12-Oct-21	BAGALKOT	110	220/110KV, LV1	MKHUBLI_220	12:31 (12.10.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
18	12-Oct-21	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	11:23	12:31	1:08	HAND TRIPPED
19	12-Oct-21	BAGALKOT	110	BAGALKOT220- LOKAPUR	LOKAPUR_110	15:46	19:30	3:44	LINE FAULT
20	12-Oct-21	BAGALKOT	110	BAGALKOT220- RAMDURGA	RAMDURGA_110	17:21	19:05	1:44	HAND TRIPPED
21	12-Oct-21	BAGALKOT	110	BAGEWADI-MAMADAPUR 1	MAMADAPUR_110	2:10	2:34	0:24	LINE FAULT
22	12-Oct-21	BAGALKOT	110	BAGEWADI-MAMADAPUR2	BAGEWADI_220	2:10	2:30	0:20	MAIN SUPPLY FAILURE
23	12-Oct-21	BAGALKOT	110	BIDNAL- NARAGUND	NARAGUND_110	6:35	7:15	0:40	MAIN SUPPLY FAILURE
24	12-Oct-21	BAGALKOT	110	BIDNAL-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	15:25 (11.10.2021)	14:45 (12.10.2021)	23:20hrs	LINE CHARGED
25	12-Oct-21	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA	GHATAPRABHA_110KV ,HIDIKAL DAM_110	10:30	12:54	2:24	LINE CLEAR AVAILED
26	12-Oct-21	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA 2	GHATAPRABHA_110	10:30	12:53	2:23	LINE CLEAR AVAILED
27	12-Oct-21	BAGALKOT	110	GHATAPRAGHA-SORYODAYA SOLAR	GHATAPRAGHA_220	2:00	2:20	0:20	LINE FAULT
28	12-Oct-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
29	12-Oct-21	BAGALKOT	110	GUTTAL-RANEENNUR	STATION NOT AFFECTED RANEENNUR_110	21:38	22:08	0:30	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
30	12-Oct-21	BAGALKOT	110	GUTTAL-RANEENNUR	STATION NOT AFFECTED RANEENNUR_110	22:08	22:30	0:22	LINE FAULT
31	12-Oct-21	BAGALKOT	110	INDI-LACHYAL	INDI_220	6:20	6:30	0:10	LINE FAULT
32	12-Oct-21	BAGALKOT	110	INDI-ZALKI2	INDI_220	6:20	6:30	0:10	LINE FAULT
33	12-Oct-21	BAGALKOT	110	MKHUBLI220- KHANAPUR	KHANAPUR_110	8:00	8:17	0:17	LINE FAULT
34	12-Oct-21	BAGALKOT	110	NAVALGUND- KONNUR	KONNUR_110	6:35	17:40	11:05	MAIN SUPPLY FAILURE
35	12-Oct-21	BAGALKOT	110	SALAHALLI- G HOSKOTE	G HOSKOTE_110	15:50	16:30	0:40	MAIN SUPPLY FAILURE
36	12-Oct-21	BAGALKOT	110	SALAHALLI- G HOSKOTE	G HOSKOTE_110	20:25	20:35	0:10	MAIN SUPPLY FAILURE
37	12-Oct-21	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_220	13:57 (29.09.2021)	10:10 (12.10.2021)	20:13hrs	LINE CHARGED
38	12-Oct-21	BAGALKOT	110	TODALBAGI-JAMAKHANDI SUGARS	JAMAKHANDI SUGARS_110 STATION NOT AFFECTED TODALBAGI_110	6:50	7:00	0:10	LINE FAULT
39	12-Oct-21	BAGALKOT	110	UMMACHAGI - KIRVATTI	UMMACHAGI_110	8:45	0:00	15:15	LINE CLEAR AVAILED
40	12-Oct-21	BAGALKOT	220	220/110KV, HV1	MKHUBLI_220	15:17	16:09	0:52	LINE CLEAR AVAILED
41	12-Oct-21	BAGALKOT	220	220/110KV,HV1	SIRSI_220	10:10	13:07	2:57	LINE CLEAR AVAILED
42	12-Oct-21	BAGALKOT	220	HAVERI-GUTTURI	HAVERI_220	10:54	12:02	1:08	LINE CLEAR AVAILED
43	12-Oct-21	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	3:22 (07.10.2021)			LINE OPEN:LINE FAULT
44	12-Oct-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
45	12-Oct-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
46	12-Oct-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
47	12-Oct-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
48	12-Oct-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
49	12-Oct-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
50	12-Oct-21	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	19:10	19:15	0:05	LOAD CHANGEVER
51	12-Oct-21	BENGALURU	66	CHANDAPURA - YARANDANAHALLI	CHANDAPURA	19:25	19:35	0:10	LOAD CHANGEVER
52	12-Oct-21	BENGALURU	66	DOMMASANDRA - EPIP 220	DOMMASANDRA	19:10	19:15	0:05	LOAD CHANGEVER
53	12-Oct-21	BENGALURU	66	EPIP 220 - DIVYASHREE TECH PARK	DIVYASHREE TECH PARK, KACHMARANAHALLI	10:44	11:10	0:26	LINE FAULT
54	12-Oct-21	BENGALURU	66	HV1	ISRO LAYOUT	5:25	5:32	0:07	LINE CLEAR AVAILED
55	12-Oct-21	BENGALURU	66	HV1	NIMHANS 220	11:38	12:05	0:27	TRANSFORMER FAULT
56	12-Oct-21	BENGALURU	66	HV1	POTTERY ROAD	10:15	10:35	0:20	TRANSFORMER FAULT
57	12-Oct-21	BENGALURU	66	HV1	POTTERY ROAD	13:34	13:40	0:06	TRANSFORMER FAULT
58	12-Oct-21	BENGALURU	66	HV1	GANJIGUNTE	19:20	19:50	0:30	TRANSFORMER FAULT
59	12-Oct-21	BENGALURU	66	HV1	GANJIGUNTE	22:50	23:25	0:35	TRANSFORMER FAULT
60	12-Oct-21	BENGALURU	66	HV1	SARJAPURA 220	10:28	19:10	8:42	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
61	12-Oct-21	BENGALURU	66	HV1	HOSKOTE 66	12:35	12:50	0:15	LINE CLEAR AVAILED
62	12-Oct-21	BENGALURU	66	HV1	MITTEMARI 220	3:42	4:26	0:44	MAIN SUPPLY FAILURE
63	12-Oct-21	BENGALURU	66	HV1	KOLAR 220	21:16	22:55	1:39	MAIN SUPPLY FAILURE
64	12-Oct-21	BENGALURU	66	HV1	ANDERSONPET	21:35	22:20	0:45	TRANSFORMER FAULT
65	12-Oct-21	BENGALURU	66	HV2	SARJAPURA 220	10:28	20:35	10:07	MAIN SUPPLY FAILURE
66	12-Oct-21	BENGALURU	66	HV2	KANAKPURA 66	12:20:00	13:18	0:58	TRANSFORMER FAULT
67	12-Oct-21	BENGALURU	66	HV2	NELMANGALA 66	13:37	14:06	0:29	LINE CLEAR AVAILED
68	12-Oct-21	BENGALURU	66	HV2	THAYALUR	8:10	8:15	0:05	LINE CLEAR AVAILED
69	12-Oct-21	BENGALURU	66	HV2	KANAKPURA 66	13:18(12-10-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
70	12-Oct-21	BENGALURU	66	HV3	HOSKOTE 66	12:55	13:00	0:05	TRANSFORMER FAULT
71	12-Oct-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	21:39	21:55	0:16	LINE FAULT
72	12-Oct-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	21:16	22:55	1:39	MAIN SUPPLY FAILURE
73	12-Oct-21	BENGALURU	66	KOLAR 220 - PGCIL	SM MANGALA, SUGUTUR	21:16	22:55	1:39	MAIN SUPPLY FAILURE
74	12-Oct-21	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO (EHT), MALLASANDRA, DALASNUR, YELDUR	21:16	22:55	1:39	MAIN SUPPLY FAILURE
75	12-Oct-21	BENGALURU	66	KOLAR 220 - THAYALUR	TAMAKA	21:16	22:55	1:39	MAIN SUPPLY FAILURE
76	12-Oct-21	BENGALURU	66	KOLAR 220 - VEMGAL	KYALNUR, VEMGAL, TALAGUNDA	21:16	22:55	1:39	MAIN SUPPLY FAILURE
77	12-Oct-21	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	14:20	14:55	0:35	LINE FAULT
78	12-Oct-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	3:42	4:26	0:44	MAIN SUPPLY FAILURE
79	12-Oct-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	3:42	4:26	0:44	MAIN SUPPLY FAILURE
80	12-Oct-21	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	3:42	4:29	0:47	MAIN SUPPLY FAILURE
81	12-Oct-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	3:42	4:29	0:47	MAIN SUPPLY FAILURE
82	12-Oct-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	3:42	4:29	0:47	MAIN SUPPLY FAILURE
83	12-Oct-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	3:42	4:29	0:47	MAIN SUPPLY FAILURE
84	12-Oct-21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	3:42	4:26	0:44	MAIN SUPPLY FAILURE
85	12-Oct-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	10:28	11:25	0:57	MAIN SUPPLY FAILURE
86	12-Oct-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	10:28	11:15	0:47	MAIN SUPPLY FAILURE
87	12-Oct-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:28	12:55	2:27	MAIN SUPPLY FAILURE
88	12-Oct-21	BENGALURU	220	HV1	SARJAPURA 220	10:28	19:10	8:42	MAIN SUPPLY FAILURE
89	12-Oct-21	BENGALURU	220	HV1	MITTEMARI 220	3:42	4:26	0:44	LINE CLEAR AVAILED
90	12-Oct-21	BENGALURU	220	HV2	SARJAPURA 220	10:28	18:58	8:30	MAIN SUPPLY FAILURE
91	12-Oct-21	BENGALURU	220	HV2	MITTEMARI 220	3:42	4:31	0:49	LINE CLEAR AVAILED
92	12-Oct-21	BENGALURU	220	LV3	KOLAR 220	21:16	22:50	1:34	TRANSFORMER FAULT
93	12-Oct-21	BENGALURU	220	MALUR 220 - SOMANAHALLI 1	SARJAPURA 220, VIKAS TECH PARK 220	10:29	10:49	0:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
94	12-Oct-21	BENGALURU	220	MALUR 220 - SOMANAHALLI 1	SARJAPURA 220, VIKAS TECH PARK 220	10:49	18:41	7:52	LINE FAULT
95	12-Oct-21	GULBARGA	66	HV1	BENNEHALI_66	8:15	8:20	0:05	LINE CLEAR AVAILED
96	12-Oct-21	GULBARGA	66	HV1	BENNEHALI_66	7:20	8:15	0:55	LINE CLEAR AVAILED
97	12-Oct-21	GULBARGA	66	HV2	TELALI_66	9:30	9:50	0:20	LINE CLEAR AVAILED
98	12-Oct-21	GULBARGA	66	HV3	TELALI_66	9:30	10:45	1:15	LINE CLEAR AVAILED
99	12-Oct-21	GULBARGA	66	HV3	KUDLIGI_220	16:00	16:20	0:20	TRANSFORMER FAULT
100	12-Oct-21	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINAHADAGALI_66	6:12	6:35	0:23	LINE FAULT
101	12-Oct-21	GULBARGA	66	KUDLIGI-HANASI	HANASI_66	20:25	20:40	0:15	MAIN SUPPLY FAILURE
102	12-Oct-21	GULBARGA	66	KUDLIGI-HANASI	HANASI_66	22:50	23:10	0:20	MAIN SUPPLY FAILURE
103	12-Oct-21	GULBARGA	66	MUNIRABAD-MSDLNE	HANASI_66	10:30	10:45	0:15	LINE FAULT
104	12-Oct-21	GULBARGA	66	UCHHANGIDURGA-BILCHOD	BILCHOD_66	17:40	18:05	0:25	LINE FAULT
105	12-Oct-21	GULBARGA	110	BELLAYSOUTH-HALAKUNDI	BELLARYSOUTH_110	13:00(08.10.2021)	16:10(12.10.2021)	99:10HRS	LINE CHARGED
106	12-Oct-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAO N_110,DIGGI_110	6:56	6:59	0:03	MAIN SUPPLY FAILURE
107	12-Oct-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAO N_110,DIGGI_110	22:48	22:57	0:09	MAIN SUPPLY FAILURE
108	12-Oct-21	GULBARGA	110	HUMNABAD-MANEIKHELI	MANEIKHELI_110	10:51	15:23	4:32	LINE CLEAR AVAILED
109	12-Oct-21	GULBARGA	110	HV1	JEEWARGI_110	7:00	7:40	0:40	TRANSFORMER FAULT
110	12-Oct-21	GULBARGA	110	HV3	SHAHAPUR_220	20:28 (12.10.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
111	12-Oct-21	GULBARGA	110	HV4	SHAHAPUR_220	20:28 (12.10.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
112	12-Oct-21	GULBARGA	110	JANAWADA-SANTAPUR	SANTHAPUR_110	6:50	6:57	0:07	LINE FAULT
113	12-Oct-21	GULBARGA	110	JEEWARGI-SHAHABAD	JEEWARGI_110	7:35	11:05	3:30	NFBC ISSUED
114	12-Oct-21	GULBARGA	110	KUSHTAGI-BEVOOR	BEVOOR_110	4:20	5:15	0:55	MAIN SUPPLY FAILURE
115	12-Oct-21	GULBARGA	110	KUSHTAGI-BEVOOR	BEVOOR_110	5:15	6:45	1:30	MAIN SUPPLY FAILURE
116	12-Oct-21	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	5:27	5:37	0:10	LINE FAULT
117	12-Oct-21	GULBARGA	110	MADIYAL-KAPNOOR	MADIYAL_110,NSLSUGAR_FACTORY,CHOWDAPUR_110	6:00	6:04	0:04	LINE FAULT
118	12-Oct-21	GULBARGA	110	MANGALORE-BEVOOR	MANGALORE_110	4:15	7:20	3:05	MAIN SUPPLY FAILURE
119	12-Oct-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	22:15(11.10.2021)	08:10(12.10.2021)	10:55HRS	LINE CHARGED
120	12-Oct-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	21:05(12.10.2021)			LINE OPEN:LINE FAULT
121	12-Oct-21	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	2:32	2:40	0:08	LINE FAULT
122	12-Oct-21	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,AZALPUR_110,KARAJAGI_110	3:20	3:28	0:08	LINE FAULT
123	12-Oct-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	11:30	11:35	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
124	12-Oct-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
125	12-Oct-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
126	12-Oct-21	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARAGI_110	8:05	10:55	2:50	LINE CLEAR AVAILED
127	12-Oct-21	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	9:40	10:35	0:55	LINE CLEAR AVAILED
128	12-Oct-21	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	19:08	19:16	0:08	LINE FAULT
129	12-Oct-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	1:55	2:01	0:06	LINE FAULT
130	12-Oct-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	2:08	2:20	0:12	LINE FAULT
131	12-Oct-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	13:00(08.10.2021)			LINE OPEN:LINE CLEAR AVAILED
132	12-Oct-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	0:58	1:07	0:09	LINE FAULT
133	12-Oct-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:47	22:08	0:21	LINE FAULT
134	12-Oct-21	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110	19:30(11/10/2021)	10:40(12/10/2021)	15:10 HRS	LINE CHARGED
135	12-Oct-21	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110	9:05	9:15	0:10	MAIN SUPPLY FAILURE
136	12-Oct-21	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110,SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	11:25	11:35	0:10	LINE FAULT
137	12-Oct-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
138	12-Oct-21	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	22:34(11.10.2021)	11:53(12.10.2021)	13:19HRS	LINE CHARGED
139	12-Oct-21	GULBARGA	220	SHAHAPUR-RTPS2	RTPS_220	23:27	23:50	0:23	LINE FAULT
140	12-Oct-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	23:55 (12.10.2021)			LINE OPEN:LINE FAULT
141	12-Oct-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:59(11.10.2021)	7:22(12.10.2021)	8:23HRS	LINE CHARGED
142	12-Oct-21	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	16:05	16:45	0:40	LINE CLEAR AVAILED
143	12-Oct-21	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	16:05	16:45	0:40	LINE CLEAR AVAILED
144	12-Oct-21	HASSAN	66	HIREMAN-CHIKAMANGALUR	HIREMAGALUR_66	13:35	17:39	4:04	LINE CLEAR AVAILED
145	12-Oct-21	HASSAN	66	HIREMAN-CKM220	HIREMAGALUR_66	13:36	15:01	1:25	LINE CLEAR AVAILED
146	12-Oct-21	HASSAN	66	HIREMAN-RDL	HIREMAGALUR_66	13:08	15:06	1:58	LINE CLEAR AVAILED
147	12-Oct-21	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	16:10	19:30	3:20	LINE CLEAR AVAILED
148	12-Oct-21	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	15:45	15:50	0:05	LINE FAULT
149	12-Oct-21	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	6:15	6:21	0:06	LINE FAULT
150	12-Oct-21	HASSAN	66	HV1	AREHALLI_66	11:38	13:18	1:40	LINE CLEAR AVAILED
151	12-Oct-21	HASSAN	66	HV1	BALLUPETE_66	14:02	14:11	0:09	LINE CLEAR AVAILED
152	12-Oct-21	HASSAN	66	HV1	CHIKMAGALUR_66	13:35	18:46	5:11	LINE CLEAR AVAILED
153	12-Oct-21	HASSAN	66	HV1	HIREMAGALUR_66	13:05	15:03	1:58	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
154	12-Oct-21	HASSAN	66	HV1	MOSALEHOSAHALLI_66	16:17	17:08	0:51	HAND TRIPPED
155	12-Oct-21	HASSAN	66	HV1	NAGARTHI_66	16:19	17:11	0:52	LINE CLEAR AVAILED
156	12-Oct-21	HASSAN	66	HV2	CHIKMAGALUR_66	12:18	18:46	6:28	LINE CLEAR AVAILED
157	12-Oct-21	HASSAN	66	HV2	HALLYMYSORE_66	6:15	6:33	0:18	TRANSFORMER FAULT
158	12-Oct-21	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	15:56	17:10	1:14	MAIN SUPPLY FAILURE
159	12-Oct-21	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	9:06	9:12	0:06	LINE FAULT
160	12-Oct-21	HASSAN	110	ANANDA-SHIMOGA	ANANDPURA_110	12:10	14:19	2:09	LINE FAULT
161	12-Oct-21	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	10:30	17:33	7:03	NFBC ISSUED
162	12-Oct-21	HASSAN	110	HGUNJE-HALADY	HEGGUNJE_220	10:40	10:46	0:06	LINE FAULT
163	12-Oct-21	HASSAN	110	HGUNJE-HIRIYADKA	HEGGUNJE_220	10:40	10:45	0:05	LINE FAULT
164	12-Oct-21	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	10:41	10:47	0:06	MAIN SUPPLY FAILURE
165	12-Oct-21	HASSAN	110	HV1	ARASIKERE_110	10:30	17:33	7:03	LINE CLEAR AVAILED
166	12-Oct-21	HASSAN	110	HV1	HEGGUNJE_220	11:11	11:16	0:05	TRANSFORMER FAULT
167	12-Oct-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
168	12-Oct-21	HASSAN	110	HV2	ANAVATTI_110	23:39	23:56	0:17	TRANSFORMER FAULT
169	12-Oct-21	HASSAN	110	HV2	ARASIKERE_110	10:30	17:50	7:20	LINE CLEAR AVAILED
170	12-Oct-21	HASSAN	110	LV1	PUTTUR_220	9:22	11:59	2:37	LINE CLEAR AVAILED
171	12-Oct-21	HASSAN	110	MRSSHM-SS2	MRSMSG_220	12:10	14:19	2:09	LINE FAULT
172	12-Oct-21	HASSAN	110	NERALA-TEREKERE	NERALAKERE_110	13:35	18:48	5:13	LINE FAULT
173	12-Oct-21	HASSAN	220	HV1	PUTTUR_220	9:22	11:58	2:36	LINE CLEAR AVAILED
174	12-Oct-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
175	12-Oct-21	MYSURU	66	BG NAGAR-NAGMAGALA	ADDIHALLI_66 HARADANAHALLI(JAK)	12:16	12:40	0:23	HAND TRIPPED
176	12-Oct-21	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN:LINE CLEAR AVAILED
177	12-Oct-21	MYSURU	66	DB HALLI-TUBINKERE	DODDABYADARAHALLI_66	10:42	18:31	7:49	HAND TRIPPED
178	12-Oct-21	MYSURU	66	HUNSUR-HOOTGALLI	NO STATIONS EFFECTED	14:31	14:45	0:13	LINE FAULT
179	12-Oct-21	MYSURU	66	HV1	ANEGOLAL_66	11:31	11:43	22:44	TRANSFORMER FAULT
180	12-Oct-21	MYSURU	66	HV1	GVGUDI_66	7:46	18:49	11:03	LINE CLEAR AVAILED
181	12-Oct-21	MYSURU	66	HV1	PERIYAPATNA_66	12:29	13:21	0:52	LINE CLEAR AVAILED
182	12-Oct-21	MYSURU	66	HV2	DEVANOORNGUDU_66	11:03	14:45	3:41	LINE CLEAR AVAILED
183	12-Oct-21	MYSURU	66	HV2	JAKKANAHALLY_66	10:09	16:30	6:20	LINE CLEAR AVAILED
184	12-Oct-21	MYSURU	66	KHONALAGERE-IGLOOR	K_HONNALGERE_66	8:39	8:45	0:06	HAND TRIPPED
185	12-Oct-21	MYSURU	66	KR PETE 220-SANTEBACHALLI	SANTHEBACHALLI_66 HARADANAHALLI(JAK)_66	14:01	14:06	0:05	LINE FAULT
186	12-Oct-21	MYSURU	66	KR PETE 220-SANTEBACHALLI	SANTHEBACHALLI_66 HARADANAHALLI(JAK)_66	16:24	16:45	0:21	LINE FAULT
187	12-Oct-21	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
188	12-Oct-21	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:40(5.10.21)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
189	12-Oct-21	MYSURU	66	SANTEBACHALLI-KR PETE	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 SANTHEBACHALLI_66 HARADANAHALLI(JAK)_66	11:05	11:20	0:15	LINE FAULT
190	12-Oct-21	MYSURU	66	SFC SHIVA-HEBBANI	NO STATIONS EFFECTED	17:50	18:05	0:15	LINE FAULT
191	12-Oct-21	MYSURU	66	SFC SHIVA-PGL	NO STATIONS EFFECTED	17:50	18:00	0:10	LINE FAULT
192	12-Oct-21	MYSURU	66	SHANIVARSANTE-YESSLUR	NO STATIONS EFFECTED	10:22	10:41	0:18	LINE FAULT
193	12-Oct-21	MYSURU	66	TUBINKERE-NAGAMGALA1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	15:22	15:28	0:06	LINE FAULT
194	12-Oct-21	MYSURU	66	TUBINKERE-NAGAMGALA1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	16:25	16:40	0:15	HAND TRIPPED
195	12-Oct-21	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
196	12-Oct-21	MYSURU	220	KADAKOLA-BEGURU1	NO STATIONS EFFECTED	8:44	14:53	6:09	LINE CLEAR AVAILED
197	12-Oct-21	TUMKUR	66	HANAGAL-THALLAK2	HANAGAL_66	13:52	14:02	0:10	LINE FAULT
198	12-Oct-21	TUMKUR	66	HANAGAL-THALLAK2	HANAGAL_66	13:50	15:10	1:20	LINE FAULT
199	12-Oct-21	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	9:55	10:30	0:35	LINE FAULT
200	12-Oct-21	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	10:41	10:54	0:12	LINE FAULT
201	12-Oct-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	14:33	14:40	0:06	LINE FAULT
202	12-Oct-21	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	9:12	9:19	0:06	LINE FAULT
203	12-Oct-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	10:20	10:30	0:09	LINE FAULT
204	12-Oct-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	12:13	12:33	0:20	LINE FAULT
205	12-Oct-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	10:08	10:17	0:09	MAIN SUPPLY FAILURE
206	12-Oct-21	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	10:25	10:27	0:01	MAIN SUPPLY FAILURE
207	12-Oct-21	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	4:54	5:17	0:23	LINE FAULT
208	12-Oct-21	TUMKUR	66	PKOTE66-HIRIYUR_66	PD KOTE_66	9:55	10:05	0:10	MAIN SUPPLY FAILURE
209	12-Oct-21	TUMKUR	66	PKOTE66-HIRIYUR_66	PD KOTE_66	9:55	10:05	0:10	MAIN SUPPLY FAILURE
210	12-Oct-21	TUMKUR	66	PKOTE-AZURE SOLAR	PKOTE_66	10:06	10:34	0:28	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
211	12-Oct-21	TUMKUR	66	PDKOTE-AZURE SOLAR	PDKOTE_66	10:41	11:02	0:20	MAIN SUPPLY FAILURE
212	12-Oct-21	TUMKUR	66	PDKOTE-AZURE SOLAR	PDKOTE_66	10:06	10:34	0:28	MAIN SUPPLY FAILURE
213	12-Oct-21	TUMKUR	66	PDKOTE-AZURE SOLAR	PDKOTE_66	10:41	11:02	0:20	MAIN SUPPLY FAILURE
214	12-Oct-21	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	10:05	10:32	0:26	MAIN SUPPLY FAILURE
215	12-Oct-21	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	10:41	10:57	0:15	MAIN SUPPLY FAILURE
216	12-Oct-21	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	10:05	10:32	0:26	MAIN SUPPLY FAILURE
217	12-Oct-21	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	10:41	10:57	0:15	MAIN SUPPLY FAILURE
218	12-Oct-21	TUMKUR	66	PDKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	10:05	10:30	0:24	MAIN SUPPLY FAILURE
219	12-Oct-21	TUMKUR	66	PDKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	10:41	11:12	0:30	MAIN SUPPLY FAILURE
220	12-Oct-21	TUMKUR	66	PDKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	10:05	10:30	0:24	MAIN SUPPLY FAILURE
221	12-Oct-21	TUMKUR	66	PDKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	10:41	11:12	0:30	MAIN SUPPLY FAILURE
222	12-Oct-21	TUMKUR	66	TR-2	ANTHRASANAHALLI-220	9:39	13:02	3:23	HAND TRIPPED
223	12-Oct-21	TUMKUR	66	TR-2	HINDASGHATTA_66	11:10	11:48	0:38	TRANSFORMER FAULT
224	12-Oct-21	TUMKUR	66	TR-2	HINDASGHATTA_66	13:42	15:56	2:13	TRANSFORMER FAULT
225	12-Oct-21	TUMKUR	66	YEDIYUR- BG NAGARA66	BGNAGARA_66	11:44	12:35	0:50	HAND TRIPPED
226	12-Oct-21	TUMKUR	66	YEDIYUR- BG NAGARA66	BGNAGARA_66	11:44	12:35	0:50	HAND TRIPPED
227	12-Oct-21	TUMKUR	110	SAMPIGE_110	TR-1	12:00	14:39	2:39	LINE CLEAR AVAILED
228	12-Oct-21	TUMKUR	110	SAMPIGE_110	TR-2	12:00	14:40	2:39	LINE CLEAR AVAILED
229	12-Oct-21	TUMKUR	110	TANDAGA_66	TR-1	14:50	15:45	0:55	LINE CLEAR AVAILED
230	12-Oct-21	TUMKUR	110	TR-2	AMMASANDRA_110	10:35	16:50	6:14	LINE CLEAR AVAILED
231	12-Oct-21	TUMKUR	110	TR-2	BANDIHALLI_110	11:58	12:26	0:27	LINE CLEAR AVAILED
232	12-Oct-21	TUMKUR	110	TR-3	GUBBI_110	15:53	22:19	6:25	LINE CLEAR AVAILED
233	12-Oct-21	TUMKUR	220	TR-2	KIADB V N PURA_220	15:56	22:47	6:51	TRANSFORMER FAULT
234	13-Oct-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
235	13-Oct-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
236	13-Oct-21	BAGALKOT	110	110/11KV, HV1	UDAKERI_110	17:15	18:00	0:45	HAND TRIPPED
237	13-Oct-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NANADI_110	10:17	17:09	6:52	LINE CLEAR AVAILED
238	13-Oct-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KANABARGI_110	17:04	17:55	0:51	LINE CLEAR AVAILED
239	13-Oct-21	BAGALKOT	110	110/11KV, HV2	ANKALI_110	11:20	12:30	1:10	LINE CLEAR AVAILED
240	13-Oct-21	BAGALKOT	110	110/11KV, HV2	MRUTYUNJAYNAGAR_110	11:15	11:20	0:05	TRANSFORMER FAULT
241	13-Oct-21	BAGALKOT	110	110/11KV, HV3	ANKALI_110	12:55	14:00	1:05	LINE CLEAR AVAILED
242	13-Oct-21	BAGALKOT	110	110/11KV,HV1	ARGA_110	9:36	10:41	1:05	HAND TRIPPED
243	13-Oct-21	BAGALKOT	110	110/33KV, HV2(HV3)	HALLUR_33, MASUR_33 RATTIHALLI_110	19:00	19:57	0:57	TRANSFORMER FAULT
244	13-Oct-21	BAGALKOT	110	110/33KV, HV3	RAMDURG_110	12:03	15:30	3:27	LINE CLEAR AVAILED
245	13-Oct-21	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED CHIKKODI_110 , KHAROSHI_33 & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
246	13-Oct-21	BAGALKOT	110	220/110KV, LV1	MKHUBLI_220	12:31 (12.10.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
247	13-Oct-21	BAGALKOT	110	ATHANI220-BALIGERI	BALIGERI_110	5:55	6:07	0:12	LINE FAULT
248	13-Oct-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AWAIED
249	13-Oct-21	BAGALKOT	110	RAMANAKOPPA- MUNDAGOD(SAVANUR)	MUNDAGOD_110	5:58	6:11	0:13	LINE FAULT
250	13-Oct-21	BAGALKOT	110	RATTIHALLI-RANEENNUR220	RATTIHALLI_110	19:00	20:10	1:10	LINE FAULT
251	13-Oct-21	BAGALKOT	110	SHIROL-MANTUR	SHIROL_110	12:00	13:25	1:25	LINE CLEAR AWAIED
252	13-Oct-21	BAGALKOT	110	YADAWAD-ISRA SOLAR (ISEL)	ISRA SOLAR_110 STATION NOT AFFECTED YADAWAD_110	18:15	22:27	4:12	LINE CLEAR AWAIED
253	13-Oct-21	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	3:22 (07.10.2021)			LINE OPEN:LINE FAULT
254	13-Oct-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AWAIED
255	13-Oct-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
256	13-Oct-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN:LINE CLEAR AWAIED
257	13-Oct-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN:LINE CLEAR AWAIED
258	13-Oct-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
259	13-Oct-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AWAIED
260	13-Oct-21	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI	13:02	13:08	0:06	LOAD CHANGEOVER
261	13-Oct-21	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	15:11	15:13	0:02	LOAD CHANGEOVER
262	13-Oct-21	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	11:47	11:49	0:02	LOAD CHANGEOVER
263	13-Oct-21	BENGALURU	66	BEGUR 220 - VIDYANAGAR	VIDYANAGAR, HENNUR CROSS	12:46	12:57	0:11	LINE CLEAR AWAIED
264	13-Oct-21	BENGALURU	66	CHANDAPURA - YARANDANAHALLI	CHANDAPURA	11:21	11:28	0:07	LOAD CHANGEOVER
265	13-Oct-21	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	12:45	12:50	0:05	LINE CLEAR AWAIED
266	13-Oct-21	BENGALURU	66	HV1	GANJIGUNTE	12:45	12:55	0:10	LINE CLEAR AWAIED
267	13-Oct-21	BENGALURU	66	HV1	GANJIGUNTE	14:05	14:15	0:10	LINE CLEAR AWAIED
268	13-Oct-21	BENGALURU	66	HV2	AMAR JYOTHI	9:14	9:18	0:04	LINE CLEAR AWAIED
269	13-Oct-21	BENGALURU	66	HV2	ITI 220	13:35	13:52	0:17	TRANSFORMER FAULT
270	13-Oct-21	BENGALURU	66	HV2	SARJAPURA 220	10:33	11:20	0:47	MAIN SUPPLY FAILURE
271	13-Oct-21	BENGALURU	66	HV2	KANAKPURA 66	13:18(12-10-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
272	13-Oct-21	BENGALURU	66	JAYADEVA - ADUGODI	NO STATION AFFECTED	6:52	14:48	7:56	LINE FAULT
273	13-Oct-21	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	6:52	6:57	0:05	LINE FAULT
274	13-Oct-21	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	10:43	10:47	0:04	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
275	13-Oct-21	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	12:23	12:26	0:03	LOAD CHANGEOVER
276	13-Oct-21	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	10:43	10:47	0:04	LOAD CHANGEOVER
277	13-Oct-21	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	12:23	12:26	0:03	LOAD CHANGEOVER
278	13-Oct-21	BENGALURU	66	KOLAR 220 - THAYALUR	TAMAKA	6:16	6:23	0:07	LINE FAULT
279	13-Oct-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	10:30	10:40	0:10	MAIN SUPPLY FAILURE
280	13-Oct-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:30	11:20	0:50	MAIN SUPPLY FAILURE
281	13-Oct-21	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	BAIRKURU, NANGLI	22:09	22:25	0:16	LINE FAULT
282	13-Oct-21	BENGALURU	66	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	14:55	15:14	0:19	LINE FAULT
283	13-Oct-21	BENGALURU	220	HV1	SARJAPURA 220	10:34	11:18	0:44	LINE CLEAR AVAILED
284	13-Oct-21	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 1	NO STATION AFFECTED	0:10	7:08	6:58	MAIN SUPPLY FAILURE
285	13-Oct-21	GULBARGA	66	HV1	TELAGI_66	14:35	14:40	0:05	LINE CLEAR AVAILED
286	13-Oct-21	GULBARGA	66	HV2	TELAGI_66	14:10	14:20	0:10	TRANSFORMER FAULT
287	13-Oct-21	GULBARGA	66	HV2	TELAGI_66	12:20	12:40	0:20	TRANSFORMER FAULT
288	13-Oct-21	GULBARGA	66	HV3	KUDLIGI_220	11:30	11:40	0:10	TRANSFORMER FAULT
289	13-Oct-21	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	5:55	6:05	0:10	LINE FAULT
290	13-Oct-21	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,UPANAYAKA NAHALLI_66,HAGARIBOMMAN AHALLI_66,RR STEELS_IPP	10:06	13:09	3:03	LINE CLEAR AVAILED
291	13-Oct-21	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,UPANAYAKA NAHALLI_66,HAGARIBOMMAN AHALLI_66,RR STEELS_IPP	10:06(13.10.21)			LINE OPEN:LINE CLEAR AVAILED
292	13-Oct-21	GULBARGA	66	NEELAGUNDA-TELIGI	TELIGI_110	16:54	17:08	0:14	LINE FAULT
293	13-Oct-21	GULBARGA	110	CHINCHOLI-MANEKHALI	MANEKHALI_110	15:55	16:13	0:18	LINE FAULT
294	13-Oct-21	GULBARGA	110	CHITGUPPA-HUMNABAD	CHITGUPPA_110	8:40	8:45	0:05	MAIN SUPPLY FAILURE
295	13-Oct-21	GULBARGA	110	HV3	SHAHAPUR_220	20:28 (12.10.2021)	4:16 (13.10.2021)	7:48 HRS	TRANSFORMER CHARGED
296	13-Oct-21	GULBARGA	110	HV3	SHAHAPUR_220	20:28 (12.10.2021)	4:16 (13.10.2021)	7:48 HRS	TRANSFORMER CHARGED
297	13-Oct-21	GULBARGA	110	HV3	SHAHAPUR_220	13:55	18:26	4:31	LINE CLEAR AVAILED
298	13-Oct-21	GULBARGA	110	HV3	KEREHALI_110	11:05	11:15	0:10	TRANSFORMER FAULT
299	13-Oct-21	GULBARGA	110	HV4	SHAHAPUR_220	20:28 (12.10.2021)	1:10 (13.10.2021)	4:42 HRS	TRANSFORMER CHARGED
300	13-Oct-21	GULBARGA	110	HV4	SHAHAPUR_220	1:58	3:07	1:09	LINE CLEAR AVAILED
301	13-Oct-21	GULBARGA	110	JAWALGERA-SINDHNOOR	JAWALGERA_110	12:25	12:30	0:05	MAIN SUPPLY FAILURE
302	13-Oct-21	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	5:30	5:35	0:05	MAIN SUPPLY FAILURE
303	13-Oct-21	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	6:00	6:05	0:05	MAIN SUPPLY FAILURE
304	13-Oct-21	GULBARGA	110	MALLAT-MADLAPUR	ADVIAMARESHAWAR_110	0:26	0:31	0:05	LINE FAULT
305	13-Oct-21	GULBARGA	110	MALLAT-MADLAPUR	ADVIAMARESHAWAR_110	2:33	2:38	0:05	LINE FAULT
306	13-Oct-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	9:56	10:04	0:08	LINE FAULT
307	13-Oct-21	GULBARGA	110	MASKI-SINDHNOOR	MASKI_110	3:37	3:46	0:09	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
308	13-Oct-21	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	3:28	3:33	0:05	LINE FAULT
309	13-Oct-21	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVAT HI_110,DR NAGAR_110,KARATAGI_110	0:34	1:23	0:49	LINE FAULT
310	13-Oct-21	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	5:00	5:10	0:10	LINE FAULT
311	13-Oct-21	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	18:55	19:04	0:09	LINE FAULT
312	13-Oct-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	21:05(12.10.2021)	07:40(13.10.2021)	10:35HRS	LINE CHARGED
313	13-Oct-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
314	13-Oct-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
315	13-Oct-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	17:55	19:04	1:09	LINE CLEAR AVAILED
316	13-Oct-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	13:00(08.10.2021)			LINE OPEN:LINE CLEAR AVAILED
317	13-Oct-21	GULBARGA	110	SHAHAPUR-VARDA SLOAR_IPP	SHAHAPUR_220	19:12	23:52	4:40	LINE CLEAR AVAILED
318	13-Oct-21	GULBARGA	110	SINDHANOOR-ADVIAMRESHWARA	ADAVIAMARESHWARA_110	12:23	12:33	0:10	LINE FAULT
319	13-Oct-21	GULBARGA	110	STAR METALLIC-SINDHANOOR	SINDHANOOR_220	0:33	0:44	0:11	LINE FAULT
320	13-Oct-21	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	5:36	5:48	0:12	LINE FAULT
321	13-Oct-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
322	13-Oct-21	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	20:48	21:10	0:22	LINE FAULT
323	13-Oct-21	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	21:44	22:45	1:01	LINE FAULT
324	13-Oct-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	23:55 (12.10.2021)	6:10 (13.10.2021)	6:15 HRS	LINE CHARGED
325	13-Oct-21	HASSAN	66	HV1	HIEMANGALUR_66	16:45	18:05	1:20	TRANSFORMER FAULT
326	13-Oct-21	HASSAN	66	HV1	MALALI_66	13:00	15:10	2:10	LINE CLEAR AVAILED
327	13-Oct-21	HASSAN	66	HV1	MOSALEHOSAHALLI_66	10:15	10:25	0:10	HAND TRIPPED
328	13-Oct-21	HASSAN	66	TAVAREC-IDLE	TAVARECHATNAHALLI_66	9:25	9:35	0:10	LINE FAULT
329	13-Oct-21	HASSAN	110	HOSUR-BALIGAVI	HOSUR_110	20:10	20:15	0:05	LINE FAULT
330	13-Oct-21	HASSAN	110	HV1	NITTUR_110	4:02	9:23	5:21	TRANSFORMER FAULT
331	13-Oct-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
332	13-Oct-21	HASSAN	110	LV1	ARASIKERE_220	11:43	15:37	3:54	TRANSFORMER FAULT
333	13-Oct-21	HASSAN	110	LV1	ARASIKERE_220	18:47	20:10	1:23	TRANSFORMER FAULT
334	13-Oct-21	HASSAN	220	HV1	ARASIKERE_220	18:47	20:10	1:23	TRANSFORMER FAULT
335	13-Oct-21	HASSAN	220	HV1	ARASIKERE_220	11:43	15:37	3:54	TRANSFORMER FAULT
336	13-Oct-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
337	13-Oct-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:25	17:07	3:42	NFBC ISSUED
338	13-Oct-21	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
339	13-Oct-21	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	11:40	11:46	0:06	LINE FAULT
340	13-Oct-21	MYSURU	66	HV1	GVGUDI_66	10:35	11:30	0:55	LINE CLEAR AVAILED
341	13-Oct-21	MYSURU	66	HV1	GVGUDI_66	10:35	11:30	0:55	LINE CLEAR AVAILED
342	13-Oct-21	MYSURU	66	HV2	DEVANORNGUDU_66	7:26	7:36	22:44	TRANSFORMER FAULT
343	13-Oct-21	MYSURU	66	HV2	DEVANORNGUDU_66	7:26	7:36	0:09	TRANSFORMER FAULT
344	13-Oct-21	MYSURU	66	KIRUGAVALU-MALIYUR	NO STATIONS EFFECTED	7:16	7:24	0:08	LINE FAULT
345	13-Oct-21	MYSURU	66	KIRUGAVALU-MALIYUR	NO STATIONS EFFECTED	7:16	7:24	0:08	LINE FAULT
346	13-Oct-21	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
347	13-Oct-21	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:40(5.10.21)			LINE OPEN:LINE CLEAR AVAILED
348	13-Oct-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	BGNAGARA_66, ADICHUNCHANAGIRI_66,VADE RALLI_66,ADDIHALLI_66 & HARADANAHALLI(JAK)_66	21:37	18:49	2:47	HAND TRIPPED
349	13-Oct-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66	21:37:24(13.10.2021)			LINE OPEN:LINE CLEAR AVAILED
350	13-Oct-21	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
351	13-Oct-21	TUMKUR	66	DAVANGERE SRS- AVAREGERE66	AVAREGERE_66,MELLEKATTE_6 6,KADAJJI_66	6:42	6:53	0:10	LINE FAULT
352	13-Oct-21	TUMKUR	66	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	6:42	6:53	0:10	LINE FAULT
353	13-Oct-21	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	17:44	18:10	0:25	LINE FAULT
354	13-Oct-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	15:12	15:28	0:16	HAND TRIPPED
355	13-Oct-21	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	11:29	11:38	0:09	LINE FAULT
356	13-Oct-21	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	12:18	13:26	1:08	LINE FAULT
357	13-Oct-21	TUMKUR	66	HONNALLI 220kv- KUNDUR66	KUNDUR,_66,MALEBENNUR_66 ,DEVARABELKERE_66	15:31	15:38	0:07	LINE FAULT
358	13-Oct-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI _66	5:56	6:04	0:08	LINE FAULT
359	13-Oct-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI _66	10:44	10:54	0:10	LINE FAULT
360	13-Oct-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI _66	13:22	14:22	1:00	LINE FAULT
361	13-Oct-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:08	11:10	0:01	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
362	13-Oct-21	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	18:10	18:43	0:32	LINE FAULT
363	13-Oct-21	TUMKUR	66	PAVAGADA220-NAGALAMADIKE66	PAVAGADA_220	6:33	6:43	0:10	LINE FAULT
364	13-Oct-21	TUMKUR	66	TR-1	PAVAGADA_66	22:32	22:42	0:10	TRANSFORMER FAULT
365	13-Oct-21	TUMKUR	220	PAVAGADA220-MADHUGIRI 1	PAVAGADA_220	19:21	20:55	1:34	LINE FAULT
366	13-Oct-21	TUMKUR	220	THALLAK 220kV- HRLMN2	THALLAK_220	12:25	20:46	8:21	LINE CLEAR AVAILED
367	13-Oct-21	TUMKUR	220	TR-1(HV SIDE)	PAVAGADA_220	19:21	19:31	0:10	TRANSFORMER FAULT
368	13-Oct-21	TUMKUR	220	TR-2 (HV SIDE)	PAVAGADA_220	19:21	19:38	0:16	TRANSFORMER FAULT
369	14-Oct-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
370	14-Oct-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
371	14-Oct-21	BAGALKOT	110	110/11KV, HV1	SHIRAGUPPI_110	10:35	10:40	0:05	TRANSFORMER FAULT
372	14-Oct-21	BAGALKOT	110	110/11KV, HV1	KATARAKI_110	8:55	9:45	0:50	LINE CLEAR AVAILED
373	14-Oct-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KUD DHARWAD_110	16:57	17:04	0:07	TRANSFORMER FAULT
374	14-Oct-21	BAGALKOT	110	110/11KV,HV2	ALMEL_110	9:42	9:47	0:05	TRANSFORMER FAULT
375	14-Oct-21	BAGALKOT	110	110/11KV,HV2	ALMEL_110	9:58	10:09	0:11	TRANSFORMER FAULT
376	14-Oct-21	BAGALKOT	110	110/11KV,HV2	THORVI_110	7:22	7:29	0:07	TRANSFORMER FAULT
377	14-Oct-21	BAGALKOT	110	110/11KV,HV4	HIDIKAL_110	12:17	12:41	0:24	HAND TRIPPED
378	14-Oct-21	BAGALKOT	110	110/33KV, HV3	HORTI_33 STATION NOT AFFECTED ZALKI_110	11:29	12:01	0:32	HAND TRIPPED
379	14-Oct-21	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED CHIKKODI_110 , KHAROSHI_33 & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
380	14-Oct-21	BAGALKOT	110	220/110KV, LV1	MKHUBLI_220	12:31 (12.10.2021)	11:30 (14.10.2021)	46:59 hrs	TRANSFORMER CHARGED
381	14-Oct-21	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED MKHUBLI_220	16:15 (14.10.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
382	14-Oct-21	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MKHUBLI_220	11:35	16:12	4:37	HAND TRIPPED
383	14-Oct-21	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	6:06	6:26	0:20	LINE FAULT
384	14-Oct-21	BAGALKOT	110	CHANDAKAVTE-ALMEL	CHANDAKAVATE_110	4:45	4:50	0:05	LINE FAULT
385	14-Oct-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
386	14-Oct-21	BAGALKOT	110	INDI220-ZALKI2	STATION NOT EFFECTED INDI_220	10:24	10:28	0:04	LINE FAULT
387	14-Oct-21	BAGALKOT	110	KERUR-BADAMI	BADAMI_110 KERUR_110	6:06	6:32	0:26	LINE FAULT
388	14-Oct-21	BAGALKOT	110	RANEENNUR220-HIREKERUR	HIREKERUR_110	13:50	14:02	0:12	LINE FAULT
389	14-Oct-21	BAGALKOT	220	220/110KV, HV1 & LV1	KARWAR_220	12:10	19:10	7:00	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
390	14-Oct-21	BAGALKOT	220	HAVERI220-KNNL	HAVERI_220	0:20	0:34	0:14	HAND TRIPPED
391	14-Oct-21	BAGALKOT	220	KADRA -KARWAR 1	STATION NOT EFFECTED KARWAR_220	12:37	14:05	1:28	LINE CLEAR AVAILED
392	14-Oct-21	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	3:22 (07.10.2021)			LINE OPEN:LINE FAULT
393	14-Oct-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
394	14-Oct-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
395	14-Oct-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
396	14-Oct-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
397	14-Oct-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
398	14-Oct-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
399	14-Oct-21	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	4:33	4:46	0:13	LINE FAULT
400	14-Oct-21	BENGALURU	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	5:59	6:10	0:11	LINE FAULT
401	14-Oct-21	BENGALURU	66	HEBBALA 220 - BANASAWADI	BANASAWADI	1:38	1:51	0:13	LINE FAULT
402	14-Oct-21	BENGALURU	66	HEBBALA 220 - BANASAWADI	BANASAWADI	11:55	12:04	0:09	LINE FAULT
403	14-Oct-21	BENGALURU	66	HV1	ELECTRONIC CITY	8:01	8:10	0:09	TRANSFORMER FAULT
404	14-Oct-21	BENGALURU	66	HV1	BANASAWADI	12:35	13:03	0:28	MAIN SUPPLY FAILURE
405	14-Oct-21	BENGALURU	66	HV1	CHINTAMANI 66	14:44	15:13	0:29	TRANSFORMER FAULT
406	14-Oct-21	BENGALURU	66	HV1	CHINTAMANI 66	15:29	16:12	0:43	LINE CLEAR AVAILED
407	14-Oct-21	BENGALURU	66	HV2	BANASAWADI	12:35	13:03	0:28	MAIN SUPPLY FAILURE
408	14-Oct-21	BENGALURU	66	HV2	ARMY WELFARE	1:15	1:20	0:05	LINE CLEAR AVAILED
409	14-Oct-21	BENGALURU	66	HV2	THAYALUR	18:30	19:00	0:30	LINE CLEAR AVAILED
410	14-Oct-21	BENGALURU	66	HV2	KANAKPURA 66	13:18(12-10-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
411	14-Oct-21	BENGALURU	66	HV3	BANASAWADI	12:35	13:03	0:28	MAIN SUPPLY FAILURE
412	14-Oct-21	BENGALURU	66	HV5	NRS 220	18:11(14/10/2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
413	14-Oct-21	BENGALURU	66	ITI 220 - BANASAWADI	BANASAWADI	12:35	13:03	0:28	LINE FAULT
414	14-Oct-21	BENGALURU	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD	4:30	4:45	0:15	LOAD CHANGEOVER
415	14-Oct-21	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	10:15	10:29	0:14	LINE FAULT
416	14-Oct-21	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	ISKON, SUBRAMANYAPURA 66	14:09	14:38	0:29	LOAD CHANGEOVER
417	14-Oct-21	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	ISKON, SUBRAMANYAPURA 66	17:37	17:47	0:10	LOAD CHANGEOVER
418	14-Oct-21	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 1	NO STATION AFFECTED	0:31	7:20	6:49	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
419	14-Oct-21	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 1	NO STATION AFFECTED	21:23(14-10-2021)			MAIN SUPPLY FAILURE
420	14-Oct-21	GULBARGA	66	HV1	PUNAB GHATA_66	18:50	18:55	0:05	TRANSFORMER FAULT
421	14-Oct-21	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP	5:55	6:05	0:10	LINE FAULT
422	14-Oct-21	GULBARGA	66	KUDLIGI-HANASI	HANASI_66	5:50	6:50	1:00	MAIN SUPPLY FAILURE
423	14-Oct-21	GULBARGA	66	NEELAGUNDA-PUNAMGHATTA	PUNAMGHATTA_66	17:07	17:15	0:08	LINE FAULT
424	14-Oct-21	GULBARGA	66	TELIGI-NEELAGUNDA	TELIGI_66	6:15	6:35	0:20	MAIN SUPPLY FAILURE
425	14-Oct-21	GULBARGA	110	CHINCHOLI-MANEKHALI	MANEKHALI_110	16:20	16:25	0:05	LINE FAULT
426	14-Oct-21	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	21:10	21:20	0:10	LINE FAULT
427	14-Oct-21	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	11:00	11:10	0:10	MAIN SUPPLY FAILURE
428	14-Oct-21	GULBARGA	110	HV1	GANDHINAGAR_110	8:00	8:20	0:20	LINE CLEAR AVAILED
429	14-Oct-21	GULBARGA	110	HV1	KADAGANCHUI_110	11:30	11:45	0:15	TRANSFORMER FAULT
430	14-Oct-21	GULBARGA	110	HV2	MANVI_110	11:33	11:36	0:03	TRANSFORMER FAULT
431	14-Oct-21	GULBARGA	110	MALLAT-GALAG	GALAG_110	2:40	2:50	0:10	MAIN SUPPLY FAILURE
432	14-Oct-21	GULBARGA	110	MASKI-SINDHNOOR	MASKI_110	2:40	2:57	0:17	LINE FAULT
433	14-Oct-21	GULBARGA	110	MYLAR-MUNIRABAD	MYLAR_110	13:50	14:20	0:30	LINE CLEAR AVAILED
434	14-Oct-21	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	18:11	18:30	0:19	LINE FAULT
435	14-Oct-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	22:20(14.10.2021)			LINE OPEN:LINE FAULT
436	14-Oct-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
437	14-Oct-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
438	14-Oct-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	4:25	4:31	0:06	LINE FAULT
439	14-Oct-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	13:00(08.10.2021)			LINE OPEN:LINE CLEAR AVAILED
440	14-Oct-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	5:46	5:49	0:03	LINE FAULT
441	14-Oct-21	GULBARGA	220	HV1	KUDLIGI_220	5:50	6:40	0:50	TRANSFORMER FAULT
442	14-Oct-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
443	14-Oct-21	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	2:05	4:54	2:49	LINE FAULT
444	14-Oct-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
445	14-Oct-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
446	14-Oct-21	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN:LINE CLEAR AVAILED
447	14-Oct-21	MYSURU	66	HV2	KADAKOLA_66	4:39	4:46	22:44	TRANSFORMER FAULT
448	14-Oct-21	MYSURU	66	HV2	MALAVALLI_66	10:55	18:49	7:54	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
449	14-Oct-21	MYSURU	66	KR PETE 220-SB HALLI	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 SANTHEBACHALLI_66	7:37	7:42	0:04	LINE FAULT
450	14-Oct-21	MYSURU	66	KUSHALNAGARA 220-MYSORE-1	MIRLE_66	15:50	15:53	0:03	LINE FAULT
451	14-Oct-21	MYSURU	66	KUSHALNAGARA 220-PERIYAPATNA-1	NO STATIONS EFFECTED	9:26	18:31	9:05	LINE FAULT
452	14-Oct-21	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
453	14-Oct-21	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42(15.10.21)			LINE OPEN:LINE CLEAR AVAILED
454	14-Oct-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66	21:37:24 (13.10.2021)			LINE OPEN:LINE CLEAR AVAILED
455	14-Oct-21	MYSURU	66	VAJMANGALA-KADAKOLA1	MARADIHUNDI_66 AYRALLI_66	18:15	18:24	0:09	LINE FAULT
456	14-Oct-21	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
457	14-Oct-21	TUMKUR	66	BRAHMASANDRA- SIRA	BRAHMASANDRA_66	11:06	11:15	0:09	LINE FAULT
458	14-Oct-21	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES IPP_66	GOLDEN HATCHERIES_IPP_66	8:55	9:25	0:30	MAIN SUPPLY FAILURE
459	14-Oct-21	TUMKUR	66	DAVANGERE SRS- AVAREGERE66	AVAREGERE_66,MELLEKATTE_6 6,KADAJJI_66	6:11	6:21	0:09	LINE FAULT
460	14-Oct-21	TUMKUR	66	DAVANGERE SRS- AVAREGERE66	AVAREGERE_66,MELLEKATTE_6 6,KADAJJI_66	11:11	12:30	1:19	LINE FAULT
461	14-Oct-21	TUMKUR	66	DAVANGERE SRS- CHITRADURGA2	CHITRADURGA_220	6:11	6:21	0:09	LINE FAULT
462	14-Oct-21	TUMKUR	66	DAVANGERE SRS- CHITRADURGA2	CHITRADURGA_220	11:11	12:30	1:19	LINE FAULT
463	14-Oct-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:37	12:51	0:13	LINE FAULT
464	14-Oct-21	TUMKUR	66	GULIGENAHALLI- SIRA	GULIGENAHALLI_66	7:28	7:37	0:09	LINE FAULT
465	14-Oct-21	TUMKUR	66	HONNALLI 220KV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	15:15	15:24	0:09	LINE FAULT
466	14-Oct-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	13:29	13:39	0:09	LINE FAULT
467	14-Oct-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	13:29	15:26	1:57	LINE FAULT
468	14-Oct-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:06	12:07	0:01	LINE FAULT
469	14-Oct-21	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	6:08	6:20	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
470	14-Oct-21	TUMKUR	66	MEDIGESHI- CLEAN SOLAR PVT LTD IPP_66	CLEAN SOLAR PVT LTD _IPP_66	18:05	18:52	0:47	HAND TRIPPED
471	14-Oct-21	TUMKUR	220	JAGLUR_400-KODLIGI 2	JAGALUR_400	5:50	6:49	0:58	LINE FAULT
472	15-Oct-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
473	15-Oct-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
474	15-Oct-21	BAGALKOT	110	110/11KV, HV1	RON_110	11:40	12:40	1:00	TRANSFORMER FAULT
475	15-Oct-21	BAGALKOT	110	110/11KV,HV2	ALMEL_110	15:26	15:36	0:10	HAND TRIPPED
476	15-Oct-21	BAGALKOT	110	110/11KV,HV4	HIDIKAL_110	12:11	12:29	0:18	HAND TRIPPED
477	15-Oct-21	BAGALKOT	110	110/11KV,HV4	HIDIKAL_110	17:13	17:35	0:22	HAND TRIPPED
478	15-Oct-21	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED CHIKKODI_110 , KHAROSHI_33 & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
479	15-Oct-21	BAGALKOT	110	110/33KV,HV2	GULEGDUDD_110	12:36	12:48	0:12	TRANSFORMER FAULT
480	15-Oct-21	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED MKHUBLI_220	16:15 (14.10.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
481	15-Oct-21	BAGALKOT	110	AMBEWAADI220-SUPA2	AMBEWADI_220	6:55	12:45	5:50	LINE FAULT
482	15-Oct-21	BAGALKOT	110	BAGEWADI220-RONIHAL	RONIHAL_110	11:05	13:10	2:05	MAIN SUPPLY FAILURE
483	15-Oct-21	BAGALKOT	110	BAGEWADI220-RONIHAL	RONIHAL_110	13:30	13:55	0:25	MAIN SUPPLY FAILURE
484	15-Oct-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	11:04	13:09	2:05	LINE CLEAR AVAILED
485	15-Oct-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	13:31	13:56	0:25	LINE CLEAR AVAILED
486	15-Oct-21	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	11:06	12:43	1:37	LINE CLEAR AVAILED
487	15-Oct-21	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	13:32	13:56	0:24	LINE CLEAR AVAILED
488	15-Oct-21	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	11:08	11:22	0:14	LINE CLEAR AVAILED
489	15-Oct-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
490	15-Oct-21	BAGALKOT	110	HAVERI220-KNNL	HAVERI_220	6:24	7:43	1:19	LINE FAULT
491	15-Oct-21	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	8:51	9:11	0:20	LINE FAULT
492	15-Oct-21	BAGALKOT	110	HAVERI220-TILUVALI	TILUVALLI_110	8:38	8:48	0:10	HAND TRIPPED
493	15-Oct-21	BAGALKOT	110	HAVERI220-TILUVALLI	TILUVALLI_110	6:03	7:53	1:50	LINE FAULT
494	15-Oct-21	BAGALKOT	220	220/110KV, HV1	MK HUBLI_220	11:04	12:23	1:19	LINE CLEAR AVAILED
495	15-Oct-21	BAGALKOT	220	220/110KV, LV2	MK HUBLI_220	23:53 (15.10.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
496	15-Oct-21	BAGALKOT	220	DHONI-GADAG2	DHONI_400	12:26	12:43	0:17	LINE FAULT
497	15-Oct-21	BAGALKOT	220	DHONI-GADAG2	DHONI_400	14:06	18:59	4:53	LINE FAULT
498	15-Oct-21	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	3:22 (07.10.2021)			LINE OPEN:LINE FAULT
499	15-Oct-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
500	15-Oct-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
501	15-Oct-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI 220	17:40 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
502	15-Oct-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI 220	17:47 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
503	15-Oct-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
504	15-Oct-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
505	15-Oct-21	BENGALURU	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE, SOUDELA,DLF	14:15	14:20	0:05	LINE CLEAR AVAILED
506	15-Oct-21	BENGALURU	66	C STATION - HEBBALA 220	C STATION	14:32	14:48	0:16	MAIN SUPPLY FAILURE
507	15-Oct-21	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALIC CROSS, YENNIGADALE, CHELUR, CHAKAVELU	19:23	19:26	0:03	LINE FAULT
508	15-Oct-21	BENGALURU	66	DIVYASHREE TECH PARK - KACHAMARANAHALLI	KACHAMARANAHALLI	18:56	19:35	0:39	LINE FAULT
509	15-Oct-21	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	5:40	5:50	0:10	LINE FAULT
510	15-Oct-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	HBR LAYOUT, BELL CERAMICS (EHT)	8:21	8:32	0:11	LINE FAULT
511	15-Oct-21	BENGALURU	66	HV1	BANASAWADI	14:29	14:37	0:08	MAIN SUPPLY FAILURE
512	15-Oct-21	BENGALURU	66	HV1	TK HALLI 220	12:12	12:24	0:12	TRANSFORMER FAULT
513	15-Oct-21	BENGALURU	66	HV1	KOLAR 220	15:10	15:25	0:15	MAIN SUPPLY FAILURE
514	15-Oct-21	BENGALURU	66	HV2	KANAKPURA 66	13:18(12-10-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
515	15-Oct-21	BENGALURU	66	HV3	BANASAWADI	14:29	14:37	0:08	MAIN SUPPLY FAILURE
516	15-Oct-21	BENGALURU	66	HV5	NRS 220	18:11(14/10/2021)	17:20(15/10/2021)	24:09HRS	TRANSFORMER CHARGED
517	15-Oct-21	BENGALURU	66	IISc - HEBBALA 220	IISc	14:29	14:40	0:11	MAIN SUPPLY FAILURE
518	15-Oct-21	BENGALURU	66	KFG - KYASAMBALLI	KYASAMBALLI, ANDERSONPET	17:15	17:40	0:25	LINE FAULT
519	15-Oct-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	15:10	15:25	0:15	MAIN SUPPLY FAILURE
520	15-Oct-21	BENGALURU	66	KOLAR 220 - PGCIL	SM MANGALA, SUGUTUR	15:10	15:25	0:15	MAIN SUPPLY FAILURE
521	15-Oct-21	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO (EHT), MALLASANDRA, DALASNUR, YELDUR	15:10	15:25	0:15	MAIN SUPPLY FAILURE
522	15-Oct-21	BENGALURU	66	KOLAR 220 - THAYALUR	TAMAKA	15:10	15:25	0:15	MAIN SUPPLY FAILURE
523	15-Oct-21	BENGALURU	66	KOLAR 220 - VEMGAL	KYALNUR, VEMGAL, TALAGUNDA	15:10	15:25	0:15	MAIN SUPPLY FAILURE
524	15-Oct-21	BENGALURU	66	L R BANDE - HBR LAYOUT	L R BANDE	17:58	18:00	0:02	LOAD CHANGE OVER
525	15-Oct-21	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	14:30	14:42	0:12	MAIN SUPPLY FAILURE
526	15-Oct-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	12:03	12:17	0:14	MAIN SUPPLY FAILURE
527	15-Oct-21	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	12:03	12:17	0:14	MAIN SUPPLY FAILURE
528	15-Oct-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	12:03	12:17	0:14	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
529	15-Oct-21	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, BEML (EHT), KYASAMBALLI	12:03	12:17	0:14	MAIN SUPPLY FAILURE
530	15-Oct-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	12:03	12:17	0:14	MAIN SUPPLY FAILURE
531	15-Oct-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	12:03	12:17	0:14	MAIN SUPPLY FAILURE
532	15-Oct-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	12:03	12:17	0:14	MAIN SUPPLY FAILURE
533	15-Oct-21	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, STAR PANEL (EHT)	12:03	12:17	0:14	MAIN SUPPLY FAILURE
534	15-Oct-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	20:21	21:09	0:48	LINE FAULT
535	15-Oct-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	10:29	17:23	6:54	MAIN SUPPLY FAILURE
536	15-Oct-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	10:29	17:23	6:54	MAIN SUPPLY FAILURE
537	15-Oct-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	18:06	18:58	0:52	LINE FAULT
538	15-Oct-21	BENGALURU	220	HV1	YARANDANAHALLI 220	18:06	18:58	0:52	TRANSFORMER FAULT
539	15-Oct-21	BENGALURU	220	HV1	MALUR 220	12:03	12:17	0:14	MAIN SUPPLY FAILURE
540	15-Oct-21	BENGALURU	220	HV1	HEBBALA 220	14:29:00(15/10/2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
541	15-Oct-21	BENGALURU	220	HV2	HEBBALA 220	14:29	17:46	3:17	TRANSFORMER FAULT
542	15-Oct-21	BENGALURU	220	HV2	MALUR 220	12:03	12:17	0:14	MAIN SUPPLY FAILURE
543	15-Oct-21	BENGALURU	220	HV3	KOLAR 220	15:10	15:25	0:15	TRANSFORMER FAULT
544	15-Oct-21	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	12:03	12:14	0:11	LINE FAULT
545	15-Oct-21	BENGALURU	220	LV3	KOLAR 220	15:10	15:25	0:15	TRANSFORMER FAULT
546	15-Oct-21	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 1	NO STATION AFFECTED	21:23(14-10-2021)	8:10(15-10-2021)	10:37	MAIN SUPPLY FAILURE
547	15-Oct-21	GULBARGA	66	HV3	KUDLIGI_220	16:15	16:25	0:10	TRANSFORMER FAULT
548	15-Oct-21	GULBARGA	66	KUDLIGI-HANASI	HANASI_66	1:10	2:05	0:55	MAIN SUPPLY FAILURE
549	15-Oct-21	GULBARGA	110	BELLARYNORTH-BISILAHALLI	BISILAHALLI_110	1:25	16:03	14:38	MAIN SUPPLY FAILURE
550	15-Oct-21	GULBARGA	110	CHINCHOLI-RENEWSOLAR_IPP	CHINCHOLI_110	18:27	23:01	4:34	LINE CLEAR AVAILED
551	15-Oct-21	GULBARGA	110	HALBARGA-CHIDRI 1	CHRIDRI_110,KAMTHANA_110, HASIKOTE_110	16:38	16:43	0:05	LINE FAULT
552	15-Oct-21	GULBARGA	110	HV2	DEODURGA_110	16:28	16:33	0:05	TRANSFORMER FAULT
553	15-Oct-21	GULBARGA	110	HV2	CHINCHOLI_110	21:36	22:14	0:38	TRANSFORMER FAULT
554	15-Oct-21	GULBARGA	110	HV4	SHAHAPUR_220	9:40	9:57	0:17	LINE CLEAR AVAILED
555	15-Oct-21	GULBARGA	110	MASKI-SINDHNOOR	MASKI_110	22:22	22:26	0:04	LINE FAULT
556	15-Oct-21	GULBARGA	110	NALWAR-CLEANSLR	NALWAR_110	6:00	6:10	0:10	LINE FAULT
557	15-Oct-21	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110,JANAKI STEELA_IPP,BASAI_IPP	7:30	16:04	8:34	LINE CLEAR AVAILED
558	15-Oct-21	GULBARGA	110	RAICHUR-GOOGLE	GOOGLE_110	3:40	3:50	0:10	MAIN SUPPLY FAILURE
559	15-Oct-21	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	4:35	4:49	0:14	LINE FAULT
560	15-Oct-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	22:20(14.10.2021)	08:10(15.10.2021)	10:00HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
561	15-Oct-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	17:49	18:21	0:32	LINE FAULT
562	15-Oct-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	20:29(15.10.2021)			LINE OPEN:LINE FAULT
563	15-Oct-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
564	15-Oct-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
565	15-Oct-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_11 0,WADAGERA_110,SANNATHI_I PP,COREGREENSUGARS_IPP	6:01	6:10	0:09	LINE FAULT
566	15-Oct-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	13:00(08.10.2021)			LINE OPEN:LINE CLEAR AVAILED
567	15-Oct-21	GULBARGA	110	SHAHBAD-NALWAR	NALWAR_110	5:35	5:40	0:05	MAIN SUPPLY FAILURE
568	15-Oct-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
569	15-Oct-21	HASSAN	66	BALLUPE-SAKLESHPUR	BALLUPETE_66	17:19	17:45	0:26	LINE FAULT
570	15-Oct-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	13:00	13:20	0:20	LINE FAULT
571	15-Oct-21	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALI_66	20:32(15.10.2021)			LINE OPEN:LINE FAULT
572	15-Oct-21	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALI_66	19:30	20:32	1:02	MAIN SUPPLY FAILURE
573	15-Oct-21	HASSAN	66	HASSN22-SKPURA	HASSAN_220	17:19	18:18	0:59	LINE FAULT
574	15-Oct-21	HASSAN	66	HASSN22-SUZLON	HASSAN_220	15:01	15:18	0:17	LINE FAULT
575	15-Oct-21	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	17:01	18:45	1:44	LINE FAULT
576	15-Oct-21	HASSAN	66	HV1	BELUR_66	19:30	20:32	1:02	MAIN SUPPLY FAILURE
577	15-Oct-21	HASSAN	66	HV1	HNPURA_66	13:40	14:28	0:48	LINE CLEAR AVAILED
578	15-Oct-21	HASSAN	66	HV1	MAGGE_66	17:19	17:46	0:27	MAIN SUPPLY FAILURE
579	15-Oct-21	HASSAN	66	HV2	HNPURA_66	13:40	14:28	0:48	LINE CLEAR AVAILED
580	15-Oct-21	HASSAN	66	HV2	MAGGE_66	17:19	17:46	0:27	MAIN SUPPLY FAILURE
581	15-Oct-21	HASSAN	66	KANDLI-HASSAN	KANDLI_66	17:18	18:24	1:06	LINE FAULT
582	15-Oct-21	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	17:18	18:13	0:55	LINE FAULT
583	15-Oct-21	HASSAN	66	SAKALE-IPCL2	SAKLESHPUR_66	22:10(15.10.2021)			LINE OPEN:LINE CLEAR AVAILED
584	15-Oct-21	HASSAN	66	SAKALE-IPCL2	SAKLESHPUR_66	11:45	12:00	0:15	LINE FAULT
585	15-Oct-21	HASSAN	66	SAKALE-IPCL2	SAKLESHPUR_66	13:10	13:20	0:10	HAND TRIPPED
586	15-Oct-21	HASSAN	66	TAVAREC-IDLE	TAVARECHATNAHALLI_66	14:20	14:30	0:10	LINE FAULT
587	15-Oct-21	HASSAN	66	UDDURKO-NITTUR1	UDDURKOPLU_66	17:00	19:40	2:40	MAIN SUPPLY FAILURE
588	15-Oct-21	HASSAN	66	UDDURKO-NITTUR2	UDDURKOPLU_66	17:00(15.10.2021)			MAIN SUPPLY FAILURE
589	15-Oct-21	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPLU_66	15:01	15:18	0:17	LINE FAULT
590	15-Oct-21	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPLU_66	17:00	17:55	0:55	MAIN SUPPLY FAILURE
591	15-Oct-21	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPLU_66	18:48	18:57	0:09	LINE FAULT
592	15-Oct-21	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPLU_66	17:00	17:55	0:55	MAIN SUPPLY FAILURE
593	15-Oct-21	HASSAN	66	UDDURKO-UDDUR	UDDURKOPLU_66	17:00	22:20	5:20	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
594	15-Oct-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
595	15-Oct-21	HASSAN	110	HV2	ANAVATTI_110	6:54	7:00	0:06	TRANSFORMER FAULT
596	15-Oct-21	HASSAN	110	HV2	ANAVATTI_110	19:15	19:45	0:30	TRANSFORMER FAULT
597	15-Oct-21	HASSAN	110	JOG110-MGHE	JOG_110	15:00	15:35	0:35	LINE FAULT
598	15-Oct-21	HASSAN	110	JOG-JLT4	mghejog_gen	15:00(15.10.2021)			LINE OPEN:LINE FAULT
599	15-Oct-21	HASSAN	110	LPH-MGHE 2	lph_gen	15:00(15.10.2021)			LINE OPEN:LINE FAULT
600	15-Oct-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	12:06	12:41	0:35	LINE FAULT
601	15-Oct-21	HASSAN	220	ARSK2-NITTUR	ARASIKERE_220	14:50	15:35	0:45	LINE FAULT
602	15-Oct-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
603	15-Oct-21	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN:LINE CLEAR AVAILED
604	15-Oct-21	MYSURU	66	HV2	AKKIHBBAL_66	21:43	22:30	22:44	TRANSFORMER FAULT
605	15-Oct-21	MYSURU	66	HV2	SB HALLI_66	15:14	18:49	3:35	TRANSFORMER FAULT
606	15-Oct-21	MYSURU	66	KABHALLY-CLEANSOLAR	NO STATIONS EFFECTED	3:58	5:07	1:08	LINE FAULT
607	15-Oct-21	MYSURU	66	KUSHALNAGARA-MYSORE-1	MIRLE_66	8:28	18:31	10:03	LINE FAULT
608	15-Oct-21	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
609	15-Oct-21	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42(15.10.21)			LINE OPEN:LINE CLEAR AVAILED
610	15-Oct-21	MYSURU	66	SFC SIVA-HEBBANI-6	NO STATIONS EFFECTED	20:25	20:40	0:15	LINE FAULT
611	15-Oct-21	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	20:27	20:38	0:10	LINE FAULT
612	15-Oct-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66	21:37:24 (13.10.2021)			LINE OPEN:LINE CLEAR AVAILED
613	15-Oct-21	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
614	15-Oct-21	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	12:38	19:28	6:49	LINE FAULT
615	15-Oct-21	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66,KADAJJI_66, MELEKATTE_66	5:42	5:55	0:12	LINE FAULT
616	15-Oct-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	5:42	5:55	0:12	LINE FAULT
617	15-Oct-21	TUMKUR	66	HARIYABBE-PD KOTE	HARIYABBE_66	19:56	20:00	0:03	HAND TRIPPED
618	15-Oct-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	9:54	10:00	0:06	LINE FAULT
619	15-Oct-21	TUMKUR	66	NAYAKANAHATTI66- HIREMALLANHOLE66	NAYAKANHATTI_66, HIREMALLANAHOLE_66	18:27	18:41	0:14	LINE FAULT
620	15-Oct-21	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	19:54	20:32	0:37	MAIN SUPPLY FAILURE
621	15-Oct-21	TUMKUR	66	PD KOTE66-AZURE POWER _IPP_66	AZURE POWER _IPP_66	19:54	20:32	0:37	MAIN SUPPLY FAILURE
622	15-Oct-21	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	19:54	20:41	0:46	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
623	15-Oct-21	TUMKUR	66	PKOTE66-HIRIYUR_66	PD KOTE_66	19:52	19:58	0:05	MAIN SUPPLY FAILURE
624	15-Oct-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	10:16	10:35	0:19	LINE FAULT
625	15-Oct-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	18:10	19:14	1:04	LINE FAULT
626	15-Oct-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	10:16	10:35	0:19	LINE FAULT
627	15-Oct-21	TUMKUR	220	NITTUR 220-ARASIKERE	NITTUR_220	14:50	15:31	0:41	LINE FAULT
628	15-Oct-21	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	10:57	11:48	0:51	LINE FAULT
629	16-Oct-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVALIED
630	16-Oct-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVALIED
631	16-Oct-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED YELPHARATTI_110	17:22 (16.10.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
632	16-Oct-21	BAGALKOT	110	110/11KV, HV1(HV2)	STATION NOT AFFECTED MUDDEBIHAL_110	11:46	12:13	0:27	TRANSFORMER FAULT
633	16-Oct-21	BAGALKOT	110	110/11KV,HV1	MALGHAN(B)	15:06	15:12	0:06	TRANSFORMER FAULT
634	16-Oct-21	BAGALKOT	110	110/11KV,HV2	ALAMEL_110	9:12	11:00	1:48	LINE CLEAR AVALIED
635	16-Oct-21	BAGALKOT	110	110/11KV,HV2	ALAMEL_110	14:59	15:09	0:10	LINE CLEAR AVALIED
636	16-Oct-21	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED CHIKKODI_110 , KHAROSHI_33 & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
637	16-Oct-21	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED MKHUBLI_220	16:15 (14.10.2021)	13:36 (16.10.2021)	21:21 hrs	TRANSFORMER CHARGED
638	16-Oct-21	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	13:40	13:53	0:13	HAND TRIPPED
639	16-Oct-21	BAGALKOT	110	GHATAPRABHA220- MANTUR (MUDALGI)	MANTUR_110	0:48	1:00	0:12	LINE FAULT
640	16-Oct-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVALIED
641	16-Oct-21	BAGALKOT	110	INDI220- ZALKI1	ZALKI_110	0:02	0:08	0:06	LINE FAULT
642	16-Oct-21	BAGALKOT	110	INDI220- ZALKI2	ZALKI_110	18:15	18:40	0:25	LINE FAULT
643	16-Oct-21	BAGALKOT	110	MANTUR(G)-TUNGABHADRA SOLAR	MANTUR(G)_110	0:48	6:24	5:36	LINE FAULT
644	16-Oct-21	BAGALKOT	110	MUNDARGI-VIJAYA SUGARS	VIJAYA SUGARS_110 STATION NOT AFFECTED MUNDARGI_110	6:07	7:25	1:18	LINE FAULT
645	16-Oct-21	BAGALKOT	110	RANEBENNUR-GUTTAL	RANEBENNUR_220	17:01	17:07	0:06	MAIN SUPPLY FAILURE
646	16-Oct-21	BAGALKOT	110	RANEBENNUR-GUTTAL	RANEBENNUR_220	19:16	19:22	0:06	MAIN SUPPLY FAILURE
647	16-Oct-21	BAGALKOT	110	RANEBENNUR-HIREKERUR	RANEBENNUR_220	17:01	17:07	0:06	MAIN SUPPLY FAILURE
648	16-Oct-21	BAGALKOT	110	RANEBENNUR-HIREKERUR	RANEBENNUR_220	19:16	19:22	0:06	MAIN SUPPLY FAILURE
649	16-Oct-21	BAGALKOT	110	RANEBENNUR-HIREKERUR	RANEBENNUR_220	11:54	12:09	0:15	MAIN SUPPLY FAILURE
650	16-Oct-21	BAGALKOT	110	RANEBENNUR-HONNATTI	RANEBENNUR_220	17:01	17:07	0:06	MAIN SUPPLY FAILURE
651	16-Oct-21	BAGALKOT	110	RANEBENNUR-HONNATTI	RANEBENNUR_220	19:16	19:22	0:06	MAIN SUPPLY FAILURE
652	16-Oct-21	BAGALKOT	110	RANEBENNUR-HONNATTI	RANEBENNUR_220	11:54	12:09	0:15	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
653	16-Oct-21	BAGALKOT	110	RANEENNUR-TUMMINAKATTI	RANEENNUR_220	17:01	17:07	0:06	MAIN SUPPLY FAILURE
654	16-Oct-21	BAGALKOT	110	RANEENNUR-TUMMINAKATTI	RANEENNUR_220	19:16	19:22	0:06	MAIN SUPPLY FAILURE
655	16-Oct-21	BAGALKOT	110	RANEENNUR-TUMMINAKATTI	RANEENNUR_220	11:54	12:09	0:15	MAIN SUPPLY FAILURE
656	16-Oct-21	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	13:43	13:50	0:07	LINE FAULT
657	16-Oct-21	BAGALKOT	110	TAKKALAKI-KN SOLAR	KN SOLAR_110 STATION NOT AFFECTED TAKKALAKI_110	12:02	12:04	0:02	HAND TRIPPED
658	16-Oct-21	BAGALKOT	110	TAKKALAKI-WARDA SOLAR	WARDA SOLAR_110 STATION NOT AFFECTED TAKKALAKI_110	10:40	10:48	0:08	HAND TRIPPED
659	16-Oct-21	BAGALKOT	110	TAKKALAKI-WARDA SOLAR	WARDA SOLAR_110 STATION NOT AFFECTED TAKKALAKI_110	12:02	12:04	0:02	HAND TRIPPED
660	16-Oct-21	BAGALKOT	220	220/110KV, HV1	NARENDRA_220	22:52	23:01	0:09	TRANSFORMER FAULT
661	16-Oct-21	BAGALKOT	220	220/110KV, HV1	MK HUBLI_220	12:23	13:35	1:12	LINE CLEAR AVOIDED
662	16-Oct-21	BAGALKOT	220	AMBEWADI- PONDA1	AMBEWADI_220	0:23	0:55	0:32	LINE FAULT
663	16-Oct-21	BAGALKOT	220	BIDNAL- NAGJHARI2	BIDNAL_220	11:40	12:07	0:27	LINE FAULT
664	16-Oct-21	BAGALKOT	220	GADAG- DHONI2	GADAG_220	11:11	13:09	1:58	LINE CLEAR AVOIDED
665	16-Oct-21	BAGALKOT	220	GUTTUR1- HAVERI	HAVERI_220	15:56	18:05	2:09	LINE CLEAR AVOIDED
666	16-Oct-21	BAGALKOT	220	GUTTUR2- HAVERI	HAVERI_220	13:43	18:05	4:22	LINE FAULT
667	16-Oct-21	BAGALKOT	220	GUTTUR2- HAVERI	HAVERI_220	5:47	13:15	4:22	LINE FAULT
668	16-Oct-21	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	11:31	15:40	4:09	LINE CLEAR AVOIDED
669	16-Oct-21	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	3:22 (07.10.2021)			LINE OPEN:LINE FAULT
670	16-Oct-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
671	16-Oct-21	BAGALKOT	220	NAGJHARI1-HUBLI	HUBLI_220	11:44	12:21	0:37	LINE FAULT
672	16-Oct-21	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	11:32	15:40	4:08	LINE FAULT
673	16-Oct-21	BAGALKOT	220	NARENDRA- HUBLI2	NARENDRA_220	15:16	15:30	0:14	LINE FAULT
674	16-Oct-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
675	16-Oct-21	BAGALKOT	220	RANEENNUR-BELLIGAVI	RANEENNUR_220	17:01	17:29	0:28	MAIN SUPPLY FAILURE
676	16-Oct-21	BAGALKOT	220	RANEENNUR-BELLIGAVI	RANEENNUR_220	19:16	19:34	0:20	MAIN SUPPLY FAILURE
677	16-Oct-21	BAGALKOT	220	RANEENNUR-BELLIGAVI	RANEENNUR_220	11:54	12:09	0:15	MAIN SUPPLY FAILURE
678	16-Oct-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN:LINE CLEAR AVOIDED
679	16-Oct-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN:LINE CLEAR AVOIDED
680	16-Oct-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
681	16-Oct-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
682	16-Oct-21	BENGALURU	66	ADUGODI - HSR LAYOUT 220	ADUGODI	13:09	13:14	0:05	LOAD CHANGEOVER
683	16-Oct-21	BENGALURU	66	BANASAWADI - ITI 220	BANASAWADI	7:39	7:43	0:04	LOAD CHANGEOVER
684	16-Oct-21	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	19:53	20:13	0:19	LINE FAULT
685	16-Oct-21	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	20:13	21:05	0:51	LINE FAULT
686	16-Oct-21	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NO STATION AFFECTED	22:30	22:33	0:02	LINE CLEAR AVAILED
687	16-Oct-21	BENGALURU	66	DABUSPET 220 - SK STEEL (EHT)	SK STEEL (EHT)	14:01	15:49	1:48	LINE FAULT
688	16-Oct-21	BENGALURU	66	DABUSPET 220 - SK STEEL (EHT)	SK STEEL (EHT)	15:52	18:29	2:37	LINE FAULT
689	16-Oct-21	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	12:17	13:47	1:30	LINE FAULT
690	16-Oct-21	BENGALURU	66	HV1	ABBIGERE	13:50	14:02	0:12	LINE CLEAR AVAILED
691	16-Oct-21	BENGALURU	66	HV1	HEBBALA 220	2:04	4:37	2:33	LINE CLEAR AVAILED
692	16-Oct-21	BENGALURU	66	HV1	KADUBISANAHALLI	11:25	11:30	0:05	LINE CLEAR AVAILED
693	16-Oct-21	BENGALURU	66	HV1	RMV	14:47	14:53	0:06	LOAD CHANGEOVER
694	16-Oct-21	BENGALURU	66	HV1	RMV	16:08	16:12	0:04	LOAD CHANGEOVER
695	16-Oct-21	BENGALURU	66	HV2	ABBIGERE	13:12	13:22	0:10	LINE CLEAR AVAILED
696	16-Oct-21	BENGALURU	66	HV2	BTM 4TH PHASE	13:05	13:15	0:10	LINE CLEAR AVAILED
697	16-Oct-21	BENGALURU	66	HV2	HAL 220	10:39	10:43	0:04	LINE CLEAR AVAILED
698	16-Oct-21	BENGALURU	66	HV2	HEBBALA 220	2:04	4:41	2:37	LINE CLEAR AVAILED
699	16-Oct-21	BENGALURU	66	HV2	RMV	13:30	13:40	0:10	LOAD CHANGEOVER
700	16-Oct-21	BENGALURU	66	HV2	KANAKPURA 66	13:18(12-10-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
701	16-Oct-21	BENGALURU	66	HV3	HEBBALA 220		4:41	2:37	LINE CLEAR AVAILED
702	16-Oct-21	BENGALURU	66	KGF - KYASAMBALLI	DODDAKARI, KYASAMBALLI, ANDERSONPET	17:28	17:43	0:14	LINE FAULT
703	16-Oct-21	BENGALURU	66	L R BANDE - HBR LAYOUT	L R BANDE	4:50	4:54	0:04	LOAD CHANGEOVER
704	16-Oct-21	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	2:01	2:12	0:11	MAIN SUPPLY FAILURE
705	16-Oct-21	BENGALURU	66	MANYATHA TECH PARK 220 - HOSKOTE 1	MANYATHATECH PARK 66	13:01	13:22	0:21	LINE CLEAR AVAILED
706	16-Oct-21	BENGALURU	66	MANYATHA TECH PARK 220 - HOSKOTE 2	SHOBHA CITY	13:01	13:22	0:21	LINE CLEAR AVAILED
707	16-Oct-21	BENGALURU	66	MANYATHA TECH PARK 220 - PEENYA 2	SAHAKARINAGAR	13:01	13:22	0:21	LINE CLEAR AVAILED
708	16-Oct-21	BENGALURU	66	NELAMANGALA 66 - PEENYA 220	NELAMANGALA 66	22:28	22:33	0:05	LOAD CHANGEOVER
709	16-Oct-21	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66, ISKON	20:39	20:58	0:19	LOAD CHANGEOVER
710	16-Oct-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	17:20	17:36	0:16	LINE FAULT
711	16-Oct-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	17:38	18:03	0:25	LINE FAULT
712	16-Oct-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	17:33	17:50	0:17	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
713	16-Oct-21	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	NO STATION AFFECTED	17:15	18:17	1:02	LINE FAULT
714	16-Oct-21	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	NO STATION AFFECTED	22:52(16-10-2021)			MAIN SUPPLY FAILURE
715	16-Oct-21	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	17:52(16-10-2021)			MAIN SUPPLY FAILURE
716	16-Oct-21	BENGALURU	220	HEBBALA 220 - MANYATHA TECH PARK 220	HEBBALA 220	2:04	4:35	2:31	LINE CLEAR AVAILED
717	16-Oct-21	BENGALURU	220	HOODY 220 - MANYATHA TECH PARK 220	MANYATHA TECH PARK 220	13:01	13:21	0:20	LINE FAULT
718	16-Oct-21	BENGALURU	220	HV1	HEBBALA 220	14:29:00(15/10/2021)	4:37(16/10/2021)	14:08 hrs	TRANSFORMER CHARGED
719	16-Oct-21	BENGALURU	220	HV2	HEBBALA 220	2:04	7:30	5:26	TRANSFORMER FAULT
720	16-Oct-21	BENGALURU	220	MANYATHA TECH PARK 220 - HOODY 220	MANYATHA TECH PARK 220	13:01	13:21	0:20	LINE FAULT
721	16-Oct-21	BENGALURU	220	MANYATHA TECH PARK 220 - ITI 220	MANYATHA TECH PARK 220	13:01	13:21	0:20	LINE FAULT
722	16-Oct-21	GULBARGA	66	BENNEHALLI-ITTAGGI	BENNEHALLI_66,KOTTUR_66,UJ JANI_66	16:00	16:20	0:20	MAIN SUPPLY FAILURE
723	16-Oct-21	GULBARGA	66	HALAVAGALU-NEELAGUNDA	HALAVAGALU_66	6:10	6:30	0:20	MAIN SUPPLY FAILURE
724	16-Oct-21	GULBARGA	66	HV1	HARAPANAHALLI_66	20:40	20:50	0:10	TRANSFORMER FAULT
725	16-Oct-21	GULBARGA	66	KOTTUR-BENNEHALLI	KOTTUR_66,UJJAINI_66	4:25	4:30	0:05	LINE FAULT
726	16-Oct-21	GULBARGA	66	PUNABGHATA-NEELAGUNDA	PUNABGHATA_66	6:10	6:35	0:25	LINE FAULT
727	16-Oct-21	GULBARGA	66	TELAGI-NEELAGUNDA	TELAGI_66	6:15	6:35	0:20	MAIN SUPPLY FAILURE
728	16-Oct-21	GULBARGA	66	UCHCHANGIDURGA-NEELAGUNDA	UCHCHANGIDURGA_66	6:00	6:30	0:30	MAIN SUPPLY FAILURE
729	16-Oct-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAO N_110,DIGGI_110	22:24	22:30	0:06	MAIN SUPPLY FAILURE
730	16-Oct-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAO N_110,DIGGI_110	23:54	0:00	0:06	MAIN SUPPLY FAILURE
731	16-Oct-21	GULBARGA	110	HATTI-GAMESHAWIND_IPP	HATTI_110	14:52	15:21	0:29	LINE FAULT
732	16-Oct-21	GULBARGA	110	HV1	HATTI_110	14:55	15:09	0:14	LINE CLEAR AVAILED
733	16-Oct-21	GULBARGA	110	HV1	CHORNOOR_66	13:30	14:05	0:35	LINE CLEAR AVAILED
734	16-Oct-21	GULBARGA	110	HV1	MATAMARI_110	11:20	12:00	0:40	LINE CLEAR AVAILED
735	16-Oct-21	GULBARGA	110	HV2	BISLAHALLI_110	11:30	11:45	0:15	TRANSFORMER FAULT
736	16-Oct-21	GULBARGA	110	HV2	CHORNOOR_66	11:05	13:30	2:25	LINE CLEAR AVAILED
737	16-Oct-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	2:25	2:35	0:10	LINE FAULT
738	16-Oct-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	2:25	2:35	0:10	LINE FAULT
739	16-Oct-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	22:35	22:40	0:05	LINE FAULT
740	16-Oct-21	GULBARGA	110	KUSTAGI-KUSTAGI SOLAR_IPP	KUSTAGI_220	17:56	19:56	2:00	LINE CLEAR AVAILED
741	16-Oct-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	2:37	2:47	0:10	LINE FAULT
742	16-Oct-21	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDIN NI_110	18:56	19:08	0:12	LINE FAULT
743	16-Oct-21	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDIN NI_110	20:15	20:25	0:10	LINE FAULT
744	16-Oct-21	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDIN NI_110	23:38	23:45	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
745	16-Oct-21	GULBARGA	110	MALLAT-GALAG	GALAG_110	5:20	5:30	0:10	MAIN SUPPLY FAILURE
746	16-Oct-21	GULBARGA	110	MYLAR-GUTLA	MYLAR_110	11:53	12:09	0:16	MAIN SUPPLY FAILURE
747	16-Oct-21	GULBARGA	110	MYLAR-GUTLA	MYLAR_110	14:01	14:10	0:09	MAIN SUPPLY FAILURE
748	16-Oct-21	GULBARGA	110	MYLAR-GUTLA	MYLAR_110	17:01	17:07	0:06	MAIN SUPPLY FAILURE
749	16-Oct-21	GULBARGA	110	MYLAR-GUTLA	MYLAR_110	19:16	19:23	0:07	MAIN SUPPLY FAILURE
750	16-Oct-21	GULBARGA	110	RAICHUR-GOOGLE	GOOGLE_110	23:50	0:00	0:10	MAIN SUPPLY FAILURE
751	16-Oct-21	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	23:50	23:58	0:08	LINE FAULT
752	16-Oct-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	20:29(15.10.2021)	07:53(16.10.2021)	11:24HRS	LINE CHARGED
753	16-Oct-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	23:12(16.10.2021)			LINE OPEN:LINE FAULT
754	16-Oct-21	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	20:44	20:47	0:03	LINE FAULT
755	16-Oct-21	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORAWAR TEMPLE_110	16:28	16:33	0:05	LINE FAULT
756	16-Oct-21	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	22:03	23:08	1:05	LINE FAULT
757	16-Oct-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
758	16-Oct-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
759	16-Oct-21	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	18:00	18:06	0:06	LINE FAULT
760	16-Oct-21	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	22:10	22:18	0:08	LINE FAULT
761	16-Oct-21	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	22:10	22:17	0:07	LINE FAULT
762	16-Oct-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	13:00(08.10.2021)			LINE OPEN:LINE CLEAR AVAILED
763	16-Oct-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	20:16	20:22	0:06	LINE FAULT
764	16-Oct-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	23:03	23:09	0:06	LINE FAULT
765	16-Oct-21	GULBARGA	220	HV1	SINDHANOOR_220	10:50	14:00	3:10	LINE CLEAR AVAILED
766	16-Oct-21	GULBARGA	220	HV1	SINDHANOOR_220	13:47	13:57	0:10	TRANSFORMER FAULT
767	16-Oct-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
768	16-Oct-21	GULBARGA	220	HV2	NEELAGUNDA_220	6:10	6:25	0:15	TRANSFORMER FAULT
769	16-Oct-21	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	18:53	19:12	0:19	LINE FAULT
770	16-Oct-21	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	18:54	18:57	0:03	LINE FAULT
771	16-Oct-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	1:45	7:20	5:35	LINE CLEAR AVAILED
772	16-Oct-21	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	20:32(15.10.2021)	10:53(16.10.2021)	14:20 hrs	LINE CHARGED
773	16-Oct-21	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	17:57	19:12	1:15	MAIN SUPPLY FAILURE
774	16-Oct-21	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	19:44	20:31	0:47	MAIN SUPPLY FAILURE
775	16-Oct-21	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	17:42	17:44	0:02	HAND TRIPPED
776	16-Oct-21	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	18:41	18:46	0:05	HAND TRIPPED
777	16-Oct-21	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	19:39	19:42	0:03	HAND TRIPPED
778	16-Oct-21	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	20:41	20:44	0:03	HAND TRIPPED
779	16-Oct-21	HASSAN	66	HASSN22-SKPURA	HASSAN_220	17:55	20:26	2:31	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
780	16-Oct-21	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	18:50	19:39	0:49	MAIN SUPPLY FAILURE
781	16-Oct-21	HASSAN	66	HV1	GORUR_66	18:19	18:54	0:35	MAIN SUPPLY FAILURE
782	16-Oct-21	HASSAN	66	HV1	GORUR_66	19:48	20:46	0:58	MAIN SUPPLY FAILURE
783	16-Oct-21	HASSAN	66	HV1	HNPURA_66	13:04	15:45	2:41	LINE CLEAR AVAILED
784	16-Oct-21	HASSAN	66	HV1	MAGGE_66	17:59	20:29	2:30	MAIN SUPPLY FAILURE
785	16-Oct-21	HASSAN	66	HV1	YESLUR_66	19:08	20:32	1:24	MAIN SUPPLY FAILURE
786	16-Oct-21	HASSAN	66	HV2	HNPURA_66	13:15	15:45	2:30	LINE CLEAR AVAILED
787	16-Oct-21	HASSAN	66	HV2	MAGGE_66	17:59	20:29	2:30	MAIN SUPPLY FAILURE
788	16-Oct-21	HASSAN	66	LV1	HASSAN_220	17:58	18:40	0:42	LINE CLEAR AVAILED
789	16-Oct-21	HASSAN	66	LV1	HASSAN_220	19:45	20:22	0:37	LINE CLEAR AVAILED
790	16-Oct-21	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	17:30	17:50	0:20	LINE FAULT
791	16-Oct-21	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	22:10(15.10.2021)	2:10(16.10.2021)	3:59 hrs	LINE CHARGED
792	16-Oct-21	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	17:30	20:30	3:00	LINE FAULT
793	16-Oct-21	HASSAN	66	UDDURKO-NITTUR1	UDDURKOPLU_66	15:05	20:40	5:35	LINE CLEAR AVAILED
794	16-Oct-21	HASSAN	66	UDDURKO-NITTUR2	UDDURKOPLU_66	17:00(15.10.2021)			MAIN SUPPLY FAILURE
795	16-Oct-21	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	11:48	16:00	4:12	LINE FAULT
796	16-Oct-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	18:46	19:45	0:59	LINE FAULT
797	16-Oct-21	HASSAN	110	HV1	BAIKAMPADI_110	20:50(16.10.2021)			MAIN SUPPLY FAILURE
798	16-Oct-21	HASSAN	110	HV1	KADUR_220	13:37	13:46	0:09	HAND TRIPPED
799	16-Oct-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
800	16-Oct-21	HASSAN	110	HV2	BAIKAMPADI_110	20:50(16.10.2021)			MAIN SUPPLY FAILURE
801	16-Oct-21	HASSAN	110	HV2	KONAJE_110	19:54	21:29	1:35	MAIN SUPPLY FAILURE
802	16-Oct-21	HASSAN	110	HV2	VITTAL_110	20:55	21:34	0:39	MAIN SUPPLY FAILURE
803	16-Oct-21	HASSAN	110	HV3	BAIKAMPADI_110	20:50(16.10.2021)			MAIN SUPPLY FAILURE
804	16-Oct-21	HASSAN	110	HV4	BAIKAMPADI_110	20:50(16.10.2021)			MAIN SUPPLY FAILURE
805	16-Oct-21	HASSAN	110	JOG-JLT4	mghejog_gen	15:00(15.10.2021)			LINE OPEN:LINE FAULT
806	16-Oct-21	HASSAN	110	KAVOOR-AMR	KAVOOR_220	20:10	21:25	1:15	LINE FAULT
807	16-Oct-21	HASSAN	110	KAVOOR-AMR	KAVOOR_220	22:37	23:48	1:11	LINE FAULT
808	16-Oct-21	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	20:47(16.10.2021)			LINE OPEN:LINE FAULT
809	16-Oct-21	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	19:50	21:21	1:31	LINE FAULT
810	16-Oct-21	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	19:56	21:23	1:27	LINE FAULT
811	16-Oct-21	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	18:46	19:46	1:00	LINE FAULT
812	16-Oct-21	HASSAN	110	KONJE-MANJESWARG	KONAJE_110	19:55	21:49	1:54	MAIN SUPPLY FAILURE
813	16-Oct-21	HASSAN	110	KSHRLKP-ITTADAHALLI	SHIRALKOPPA_220	12:30	12:59	0:29	MAIN SUPPLY FAILURE
814	16-Oct-21	HASSAN	110	KSHRLKP-ITTADAHALLI	SHIRALKOPPA_220	13:04	14:21	1:17	MAIN SUPPLY FAILURE
815	16-Oct-21	HASSAN	110	KSHRLKP-ITTADAHALLI	SHIRALKOPPA_220	17:07	17:34	0:27	MAIN SUPPLY FAILURE
816	16-Oct-21	HASSAN	110	KSHRLKP-ITTADAHALLI	SHIRALKOPPA_220	19:15	19:36	0:21	MAIN SUPPLY FAILURE
817	16-Oct-21	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	19:54	21:20	1:26	MAIN SUPPLY FAILURE
818	16-Oct-21	HASSAN	110	LPH-MGHE 2	lph_gen	15:00(15.10.2021)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
819	16-Oct-21	HASSAN	110	LV1	SHIRALKOPPA_220	13:50	15:21	1:31	MAIN SUPPLY FAILURE
820	16-Oct-21	HASSAN	110	LV2	KAVOOR_220	19:55	20:22	0:27	TRANSFORMER FAULT
821	16-Oct-21	HASSAN	110	LV2	SHIRALKOPPA_220	14:01	15:23	1:22	MAIN SUPPLY FAILURE
822	16-Oct-21	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	20:55	21:33	0:38	LINE FAULT
823	16-Oct-21	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	20:33	22:42	2:09	LINE FAULT
824	16-Oct-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	12:30	12:59	0:29	MAIN SUPPLY FAILURE
825	16-Oct-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	13:04	14:21	1:17	MAIN SUPPLY FAILURE
826	16-Oct-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	17:07	17:38	0:31	MAIN SUPPLY FAILURE
827	16-Oct-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	19:15	19:38	0:23	MAIN SUPPLY FAILURE
828	16-Oct-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:30	12:58	0:28	MAIN SUPPLY FAILURE
829	16-Oct-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	13:04	14:14	1:10	MAIN SUPPLY FAILURE
830	16-Oct-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	17:07	17:33	0:26	MAIN SUPPLY FAILURE
831	16-Oct-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	19:15	19:35	0:20	MAIN SUPPLY FAILURE
832	16-Oct-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	12:30	13:00	0:30	MAIN SUPPLY FAILURE
833	16-Oct-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	13:04	14:16	1:12	MAIN SUPPLY FAILURE
834	16-Oct-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	17:07	17:37	0:30	MAIN SUPPLY FAILURE
835	16-Oct-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	19:15	19:37	0:22	MAIN SUPPLY FAILURE
836	16-Oct-21	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	12:30	15:06	2:36	MAIN SUPPLY FAILURE
837	16-Oct-21	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	16:53	17:38	0:45	MAIN SUPPLY FAILURE
838	16-Oct-21	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	19:15	19:38	0:23	MAIN SUPPLY FAILURE
839	16-Oct-21	HASSAN	110	SORABA-SHR220	SORABA_110	12:35	16:00	3:25	MAIN SUPPLY FAILURE
840	16-Oct-21	HASSAN	110	VITTAL-PUTR_SLTUR	VITTAL_110	20:55	21:35	0:40	MAIN SUPPLY FAILURE
841	16-Oct-21	HASSAN	220	HV1	HASSAN_220	17:58	18:40	0:42	LINE CLEAR AVAILED
842	16-Oct-21	HASSAN	220	HV1	HASSAN_220	19:45	20:22	0:37	LINE CLEAR AVAILED
843	16-Oct-21	HASSAN	220	HV1	SHIRALKOPPA_220	13:50	15:21	1:31	MAIN SUPPLY FAILURE
844	16-Oct-21	HASSAN	220	HV2	HASSAN_220	18:51	19:34	0:43	LINE CLEAR AVAILED
845	16-Oct-21	HASSAN	220	HV2	KAVOOR_220	19:55	20:20	0:25	TRANSFORMER FAULT
846	16-Oct-21	HASSAN	220	HV2	SHIRALKOPPA_220	14:01	15:23	1:22	MAIN SUPPLY FAILURE
847	16-Oct-21	HASSAN	220	MRSSHM-VARAH13	MRSMG_220	12:34	13:02	0:28	LINE FAULT
848	16-Oct-21	HASSAN	220	SHRAVTY-SHIMOGA 2	sharavathy_gen	17:01	18:08	1:07	LINE FAULT
849	16-Oct-21	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	17:01	18:14	1:13	LINE FAULT
850	16-Oct-21	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	19:16	19:35	0:19	LINE FAULT
851	16-Oct-21	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	12:30	18:47	6:17	LINE FAULT
852	16-Oct-21	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	17:16	18:47	1:31	LINE FAULT
853	16-Oct-21	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	19:15	20:09	0:54	LINE FAULT
854	16-Oct-21	HASSAN	220	SHRAVTY-TALAGUPPA1	sharavathy_gen	17:01	18:16	1:15	LINE FAULT
855	16-Oct-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	12:30	15:00	2:30	LINE FAULT
856	16-Oct-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	17:16	18:47	1:31	LINE FAULT
857	16-Oct-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	19:15	20:09	0:54	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
858	16-Oct-21	HASSAN	220	VARAHI-SHMG3	varahi_gen	12:34	13:02	0:28	LINE FAULT
859	16-Oct-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
860	16-Oct-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:12	15:03	2:51	NFBC ISSUED
861	16-Oct-21	MYSORE	66	BG NAGAR-NAGMAGALA	BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	11:03	11:15	0:11	LINE FAULT
862	16-Oct-21	MYSORE	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN:LINE CLEAR AVAILED
863	16-Oct-21	MYSORE	66	HV1	CHANDAKAVADI_66	18:22	18:49	0:26	TRANSFORMER FAULT
864	16-Oct-21	MYSORE	66	HV1	MADDUR_66	17:33	18:28	0:54	HAND TRIPPED
865	16-Oct-21	MYSORE	66	HV2	AKKIEBBAL_66	19:43	20:08	0:24	TRANSFORMER FAULT
866	16-Oct-21	MYSORE	66	HV2	MADDUR_66	17:33	18:28	0:55	HAND TRIPPED
867	16-Oct-21	MYSORE	66	KABALLI-CLEAN SOLAR	NO STATIONS EFFECTED	6:23	18:31	12:08	LINE FAULT
868	16-Oct-21	MYSORE	66	MADHUVANALLI-KUNTUR	NO STATIONS EFFECTED	13:44	13:50	0:05	LINE FAULT
869	16-Oct-21	MYSORE	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
870	16-Oct-21	MYSORE	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42(5.10.21)			LINE OPEN:LINE CLEAR AVAILED
871	16-Oct-21	MYSORE	66	TUBINKERE-NAGAMANGALA 1	BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66	21:37:24 (13.10.2021)			LINE OPEN:LINE CLEAR AVAILED
872	16-Oct-21	MYSORE	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
873	16-Oct-21	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66,KADAJJI_66, MELEKATTE_66	3:38	3:49	0:10	LINE FAULT
874	16-Oct-21	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	13:58	14:14	0:15	LINE FAULT
875	16-Oct-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	3:38	3:51	0:12	LINE FAULT
876	16-Oct-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	5:30	5:39	0:09	LINE FAULT
877	16-Oct-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:58	14:13	0:14	LINE FAULT
878	16-Oct-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	10:17	10:24	0:06	LINE FAULT
879	16-Oct-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	8:53	8:57	0:04	LINE FAULT
880	16-Oct-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:35	11:36	0:01	LINE FAULT
881	16-Oct-21	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI66	MADHUGIRI_66, BADAVANAHALLI_66	10:39	11:29	0:50	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
882	16-Oct-21	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE66	NAYAKANHATTI_66, HIREMALLANAHOLE_66	13:29	17:42	4:12	NFBC ISSUED
883	16-Oct-21	TUMKUR	66	TR-1	MELKOTE_66	14:20	17:56	3:36	LINE CLEAR AVAILED
884	16-Oct-21	TUMKUR	66	TR-2	HULIYURDURGA_66	11:45	14:03	2:18	LINE CLEAR AVAILED
885	16-Oct-21	TUMKUR	66	TR-2	RAMPURA_66	8:22	8:50	0:28	LINE CLEAR AVAILED
886	16-Oct-21	TUMKUR	66	TR-2	RAMPURA_66	11:06	12:20	1:13	LINE CLEAR AVAILED
887	16-Oct-21	TUMKUR	66	TURUVANUR66-JAGALUR	TURUVANUR_66	0:58	1:08	0:10	LINE FAULT
888	16-Oct-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	13:41	13:58	0:17	LINE FAULT
889	16-Oct-21	TUMKUR	220	JAGALIR_400-THALLAK-1	THALLAK_220	16:56	17:50	0:54	LINE CLEAR AVAILED
890	16-Oct-21	TUMKUR	220	THALLAK 220kV- HRLMN2	THALLAK_220	16:38	17:58	1:20	LINE CLEAR AVAILED
891	16-Oct-21	TUMKUR	220	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	17:59	18:40	0:40	LINE CLEAR AVAILED
892	17-Oct-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
893	17-Oct-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
894	17-Oct-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED YELPHARATTI_110	17:22 (16.10.2021)	17:07 (17.10.2021)	23:45 hrs	TRANSFORMER CHARGED
895	17-Oct-21	BAGALKOT	110	110/11KV, HV1	TIKOTA_110	11:13	11:16	0:03	TRANSFORMER FAULT
896	17-Oct-21	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	11:13	11:23	0:10	TRANSFORMER FAULT
897	17-Oct-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TIKOTA_110	15:04	15:06	0:02	TRANSFORMER FAULT
898	17-Oct-21	BAGALKOT	110	110/11KV,HV1&2	KULAGERI CROSS_110	11:29	12:16	0:47	LINE CLEAR AVAILED
899	17-Oct-21	BAGALKOT	110	110/33KV, HV3	SHIGAON_33, AMBUJA INDUSTRIES_33 & KPCLSOLAR_33 STATION NOT AFFECTED SHIGAON_110	17:24	17:33	0:09	TRANSFORMER FAULT
900	17-Oct-21	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED CHIKKODI_110 , KHAROSHI_33 & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
901	17-Oct-21	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110 &ALNAVAR_33	16:13	17:27	1:14	LINE CLEAR AVAILED
902	17-Oct-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
903	17-Oct-21	BAGALKOT	110	HAVERI220- HANGAL(TILUVALLI)	TILUVALLI_110	5:24	5:44	0:20	LINE FAULT
904	17-Oct-21	BAGALKOT	110	HIREBEVANUR-RODAGI	RODAGI_110	12:14	12:59	0:45	LINE CLEAR AVAILED
905	17-Oct-21	BAGALKOT	110	HUNGUND-KUDALSANGAM	KUDALSANGAM_110	4:40	4:46	0:06	LINE FAULT
906	17-Oct-21	BAGALKOT	110	INDI220- ZALKI1	ZALKI_110	0:02	0:08	0:06	LINE FAULT
907	17-Oct-21	BAGALKOT	110	INDI220- ZALKI2	ZALKI_110	18:15	18:40	0:25	LINE FAULT
908	17-Oct-21	BAGALKOT	110	KADANAKOPPA-KAVALWAD	KADANAKOPPA_110	14:04 (17.10.2021)			LINE OPEN:LINE CLEAR AVAILED
909	17-Oct-21	BAGALKOT	110	KIADB BIJAPUR-BHUTANAL	BHUTANAL_110	11:04	11:09	0:05	LINE FAULT
910	17-Oct-21	BAGALKOT	110	KIADB BIJAPUR-BHUTANAL	BHUTANAL_110	11:37	11:39	0:02	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
911	17-Oct-21	BAGALKOT	110	KIADB BIJAPUR-BHUTANAL	BHUTANAL_110	12:02	12:05	0:03	LINE FAULT
912	17-Oct-21	BAGALKOT	110	KIADB BIJAPUR-BHUTANAL	BHUTANAL_110	12:23	12:25	0:02	LINE FAULT
913	17-Oct-21	BAGALKOT	110	MKHUBLI220- HIREBAGEWADI	HIREBAGEWADI_110	10:26	16:05	7:45	LINE CLEAR AVAILED
914	17-Oct-21	BAGALKOT	110	RANEENNUR-GUTTAL	RANEENNUR_220	17:01	17:07	0:06	MAIN SUPPLY FAILURE
915	17-Oct-21	BAGALKOT	110	RANEENNUR-GUTTAL	RANEENNUR_220	19:16	19:22	0:06	MAIN SUPPLY FAILURE
916	17-Oct-21	BAGALKOT	110	RANEENNUR-HIREKERUR	RANEENNUR_220	17:01	17:07	0:06	MAIN SUPPLY FAILURE
917	17-Oct-21	BAGALKOT	110	RANEENNUR-HIREKERUR	RANEENNUR_220	19:16	19:22	0:06	MAIN SUPPLY FAILURE
918	17-Oct-21	BAGALKOT	110	RANEENNUR-HIREKERUR	RANEENNUR_220	11:54	12:09	0:15	MAIN SUPPLY FAILURE
919	17-Oct-21	BAGALKOT	110	RANEENNUR-HONNATTI	RANEENNUR_220	17:01	17:07	0:06	MAIN SUPPLY FAILURE
920	17-Oct-21	BAGALKOT	110	RANEENNUR-HONNATTI	RANEENNUR_220	19:16	19:22	0:06	MAIN SUPPLY FAILURE
921	17-Oct-21	BAGALKOT	110	RANEENNUR-HONNATTI	RANEENNUR_220	11:54	12:09	0:15	MAIN SUPPLY FAILURE
922	17-Oct-21	BAGALKOT	110	RANEENNUR-TUMMINAKATTI	RANEENNUR_220	17:01	17:07	0:06	MAIN SUPPLY FAILURE
923	17-Oct-21	BAGALKOT	110	RANEENNUR-TUMMINAKATTI	RANEENNUR_220	19:16	19:22	0:06	MAIN SUPPLY FAILURE
924	17-Oct-21	BAGALKOT	110	RANEENNUR-TUMMINAKATTI	RANEENNUR_220	11:54	12:09	0:15	MAIN SUPPLY FAILURE
925	17-Oct-21	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	6:20	6:25	0:05	LINE FAULT
926	17-Oct-21	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	6:38	6:46	0:08	LINE FAULT
927	17-Oct-21	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	6:46	6:50	0:04	LINE FAULT
928	17-Oct-21	BAGALKOT	110	TAKKALAKI-KN SOLAR	KN SOLAR_110 STATION NOT AFFECTED TAKKALAKI_110	11:06	11:09	0:03	HAND TRIPPED
929	17-Oct-21	BAGALKOT	110	TAKKALAKI-KN SOLAR	KN SOLAR_110 STATION NOT AFFECTED TAKKALAKI_110	11:38	11:41	0:03	HAND TRIPPED
930	17-Oct-21	BAGALKOT	110	TAKKALAKI-WARDA SOLAR	WARDA SOLAR_110 STATION NOT AFFECTED TAKKALAKI_110	11:05	11:09	0:04	HAND TRIPPED
931	17-Oct-21	BAGALKOT	110	TAKKALAKI-WARDA SOLAR	WARDA SOLAR_110 STATION NOT AFFECTED TAKKALAKI_110	11:38	11:49	0:11	HAND TRIPPED
932	17-Oct-21	BAGALKOT	110	TAKKALAKI-WARDA SOLAR	WARDA SOLAR_110 STATION NOT AFFECTED TAKKALAKI_110	12:04	12:09	0:05	HAND TRIPPED
933	17-Oct-21	BAGALKOT	110	TAKKALAKI-WARDA SOLAR	WARDA SOLAR_110 STATION NOT AFFECTED TAKKALAKI_110	12:24	12:29	0:05	HAND TRIPPED
934	17-Oct-21	BAGALKOT	220	220/110KV, LV2	MK HUBLI_220	13:40	13:53	0:13	HAND TRIPPED
935	17-Oct-21	BAGALKOT	220	AMBEWADI- NAGJHARI2	AMBEWADI_220	10:12	10:31	0:19	LINE FAULT
936	17-Oct-21	BAGALKOT	220	GHATAPRABHA- NARENDRA2	GHATAPRABHA_220	5:48	7:27	1:39	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
937	17-Oct-21	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	3:22 (07.10.2021)			LINE OPEN:LINE FAULT
938	17-Oct-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
939	17-Oct-21	BAGALKOT	220	NARENDRA- KANABARGI1(BELGAUM)	NARENDRA_220	11:00	17:14	6:14	LINE CLEAR AVAILED
940	17-Oct-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
941	17-Oct-21	BAGALKOT	220	RANEENNUR-BELLIGAVI	RANEENNUR_220	17:01	17:29	0:28	MAIN SUPPLY FAILURE
942	17-Oct-21	BAGALKOT	220	RANEENNUR-BELLIGAVI	RANEENNUR_220	19:16	19:34	0:20	MAIN SUPPLY FAILURE
943	17-Oct-21	BAGALKOT	220	RANEENNUR-BELLIGAVI	RANEENNUR_220	11:54	12:09	0:15	MAIN SUPPLY FAILURE
944	17-Oct-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
945	17-Oct-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
946	17-Oct-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
947	17-Oct-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
948	17-Oct-21	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA	5:33	5:42	0:09	LINE FAULT
949	17-Oct-21	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA	12:48	12:57	0:08	LINE FAULT
950	17-Oct-21	BENGALURU	66	HV1	CHAKAVELU	10:16	10:45	0:28	LINE CLEAR AVAILED
951	17-Oct-21	BENGALURU	66	HV2	VIJAYANAGARA	13:06	13:13	0:07	LOAD CHANGEOVER
952	17-Oct-21	BENGALURU	66	HV2	VIJAYANAGARA	16:27	16:35	0:08	LOAD CHANGEOVER
953	17-Oct-21	BENGALURU	66	HV2	KIADB DB PURA 220	3:52(17-10-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
954	17-Oct-21	BENGALURU	66	HV2	KANAKPURA 66	13:18(12-10-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
955	17-Oct-21	BENGALURU	66	IISc - NRS 220	IISc	13:10	13:15	0:05	LOAD CHANGEOVER
956	17-Oct-21	BENGALURU	66	JIGANI 220 - JIGANI 66	JIAGNI 66, JIGANI LINK ROAD	7:35	7:45	0:10	MAIN SUPPLY FAILURE
957	17-Oct-21	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	14:02	16:08	2:06	LINE CLEAR AVAILED
958	17-Oct-21	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM ALYOUT	14:02	16:08	2:06	LINE CLEAR AVAILED
959	17-Oct-21	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66, ISKON	11:15	11:23	0:08	LOAD CHANGEOVER
960	17-Oct-21	BENGALURU	66	TK HALLI 220 - BWSSB 4 (EHT)	BWSSB 4 (EHT)	22:06	22:34	0:28	LINE FAULT
961	17-Oct-21	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	NO STATION AFFECTED	22:56(17-10-2021)			MAIN SUPPLY FAILURE
962	17-Oct-21	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	NO STATION AFFECTED	22:52(16-10-2021)	8:33(17-10-2021)	9:40 hrs	LINE CHARGED
963	17-Oct-21	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 1	NO STATION AFFECTED	7:41	12:50	5:09	LINE CLEAR AVAILED
964	17-Oct-21	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	17:52(16-10-2021)	15:05(17-10-2021)	21:12 hrs	LINE CHARGED
965	17-Oct-21	BENGALURU	220	HV2	JIGANI 220	7:35	7:45	0:10	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
966	17-Oct-21	GULBARGA	66	HALAVAGALU-NEELAGUNDA	HALAVAGALU_66	16:00	16:40	0:40	MAIN SUPPLY FAILURE
967	17-Oct-21	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,UPANAYAKA NAHALLI_66,HAGARIBOMMAN AHALLI_66,RR STEELS_IPP	6:35	6:47	0:12	LINE FAULT
968	17-Oct-21	GULBARGA	66	PUNABGHATA-NEELAGUNDA	PUNABGHATA_66	16:00	16:40	0:40	LINE FAULT
969	17-Oct-21	GULBARGA	66	TAMBRAHALLI-ITTAGGI	TAMBRAHALLI_66	16:00	16:20	0:20	MAIN SUPPLY FAILURE
970	17-Oct-21	GULBARGA	66	TELAGI-NEELAGUNDA	TELAGI_66	16:00	16:35	0:35	MAIN SUPPLY FAILURE
971	17-Oct-21	GULBARGA	66	UCHCHANGIDURGA-NEELAGUNDA	UCHCHANGIDURGA_66	16:00	16:45	0:45	MAIN SUPPLY FAILURE
972	17-Oct-21	GULBARGA	110	BISILAHALLI-ALIPUR	BISILAHALLI_110	12:40	16:30	3:50	MAIN SUPPLY FAILURE
973	17-Oct-21	GULBARGA	110	BISILAHALLI-ALIPUR	BISILAHALLI_110	17:39	17:44	0:05	MAIN SUPPLY FAILURE
974	17-Oct-21	GULBARGA	110	CHINCHOLI-RENEWOLAR_IPP	CHINCHOLI_110	18:50	22:38	3:48	LINE FAULT
975	17-Oct-21	GULBARGA	110	DUBALGUNDI-HUMNABAD	BUBALGUNDI_110	4:40	17:40	13:00	MAIN SUPPLY FAILURE
976	17-Oct-21	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110,LADHA_110,MGSS K_IPP,BHALKI SUGAR_IPP	4:39	17:38	12:59	LINE FAULT
977	17-Oct-21	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	21:05	21:15	0:10	MAIN SUPPLY FAILURE
978	17-Oct-21	GULBARGA	110	HV1	NALWAR_110	9:15	10:20	1:05	TRANSFORMER FAULT
979	17-Oct-21	GULBARGA	110	HV2	NALWAR_110	9:15	10:20	1:05	LINE CLEAR AVAILED
980	17-Oct-21	GULBARGA	110	HV3	CHINCHOLI_110	20:46	20:57	0:11	TRANSFORMER FAULT
981	17-Oct-21	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	5:55	6:02	0:07	MAIN SUPPLY FAILURE
982	17-Oct-21	GULBARGA	110	JAWALEGRA-SINDHNOOR	JAWALGERA_110	22:25	22:35	0:10	MAIN SUPPLY FAILURE
983	17-Oct-21	GULBARGA	110	JAWALEGRA-SINDHNOOR	JAWALGERA_110	23:25	23:35	0:10	MAIN SUPPLY FAILURE
984	17-Oct-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	0:00	0:05	0:05	LINE FAULT
985	17-Oct-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	0:55	1:00	0:05	LINE FAULT
986	17-Oct-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	2:10	2:20	0:10	LINE FAULT
987	17-Oct-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	3:11	3:18	0:07	LINE FAULT
988	17-Oct-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	5:27	5:36	0:09	LINE FAULT
989	17-Oct-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	5:58	6:23	0:25	LINE FAULT
990	17-Oct-21	GULBARGA	110	KEREHALI-MUNIRABAD	KEREHALI_110	9:50	11:55	2:05	MAIN SUPPLY FAILURE
991	17-Oct-21	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDIN NI_110	1:45	1:55	0:10	LINE FAULT
992	17-Oct-21	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDIN NI_110	8:34	8:48	0:14	LINE FAULT
993	17-Oct-21	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDIN NI_110	18:53	19:03	0:10	LINE FAULT
994	17-Oct-21	GULBARGA	110	MALLAT-BYAGAWATH1(IDLE LINE)	BYAGAWATH_110,VALKAMDIN NI_110	3:04	4:04	1:00	LINE FAULT
995	17-Oct-21	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	2:23	2:33	0:10	LINE FAULT
996	17-Oct-21	GULBARGA	110	MASKI-SINDANOOR	MASKI_110	22:30	22:36	0:06	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
997	17-Oct-21	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVAT HI_110,DR NAGAR_110,KARATAGI_110	9:50	11:19	1:29	LINE CLEAR AVAILED
998	17-Oct-21	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,K EREHALLI_110,MALLAPUR_110	9:50	11:47	1:57	LINE CLEAR AVAILED
999	17-Oct-21	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	18:00	18:05	0:05	LINE FAULT
1000	17-Oct-21	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	18:00	18:05	0:05	MAIN SUPPLY FAILURE
1001	17-Oct-21	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	12:43	16:30	3:47	MAIN SUPPLY FAILURE
1002	17-Oct-21	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	17:40	17:44	0:04	MAIN SUPPLY FAILURE
1003	17-Oct-21	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110	6:01	6:11	0:10	LINE FAULT
1004	17-Oct-21	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	18:49	19:07	0:18	LINE FAULT
1005	17-Oct-21	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	18:49	19:07	0:18	LINE FAULT
1006	17-Oct-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	23:12(16.10.2021)	07:09(17.10.2021)	07:57HRS	LINE CHARGED
1007	17-Oct-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	20:31	20:46	0:15	LINE FAULT
1008	17-Oct-21	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	20:51	20:57	0:06	LINE FAULT
1009	17-Oct-21	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	4:45	11:26	6:41	MAIN SUPPLY FAILURE
1010	17-Oct-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNSAG I_110	21:09	21:12	0:03	LINE FAULT
1011	17-Oct-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	13:00(08.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1012	17-Oct-21	GULBARGA	110	SINDHANOOR-ADVIAMARESHWARA	ADAVIAMARESHWARA_110	22:28	22:38	0:10	LINE FAULT
1013	17-Oct-21	GULBARGA	110	SINDHANOOR-ADVIAMARESHWARA	ADAVIAMARESHWARA_110	23:28	23:38	0:10	LINE FAULT
1014	17-Oct-21	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	23:21	23:31	0:10	LINE FAULT
1015	17-Oct-21	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110,GANDHINAGAR_110	10:00	10:10	0:10	LINE FAULT
1016	17-Oct-21	GULBARGA	110	VALKAMDINNI-MALLAT	VALKAMDINNI_110	23:50	23:55	0:05	MAIN SUPPLY FAILURE
1017	17-Oct-21	GULBARGA	110	YERADONA-SINDHANOOR	YERADONA_110	13:50	14:00	0:10	MAIN SUPPLY FAILURE
1018	17-Oct-21	GULBARGA	220	HV1	HUMNABAD_220	4:39	6:08	1:29	TRANSFORMER FAULT
1019	17-Oct-21	GULBARGA	220	HV1	ITTAGI_220	16:00	16:10	0:10	TRANSFORMER FAULT
1020	17-Oct-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1021	17-Oct-21	GULBARGA	220	HV2	ITTAGI_220	16:00	16:15	0:15	TRANSFORMER FAULT
1022	17-Oct-21	GULBARGA	220	ITTAGI-HARKANAL_IPP	ITTAGI_220	22:05(17.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1023	17-Oct-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	2:27	2:47	0:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1024	17-Oct-21	HASSAN	66	HV1	AREHALLI_HSN_66	9:54	11:26	1:32	LINE CLEAR AVAILED
1025	17-Oct-21	HASSAN	66	HV1	YESLUR_66	12:50	14:07	1:17	LINE CLEAR AVAILED
1026	17-Oct-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	7:23	7:35	0:12	LINE FAULT
1027	17-Oct-21	HASSAN	66	MRSSHM-HOLUR	MRS MG_220	12:21	14:55	2:34	LINE CLEAR AVAILED
1028	17-Oct-21	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	10:00	10:10	0:10	LINE FAULT
1029	17-Oct-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATHNAHALLI_66	10:58	15:00	4:02	HAND TRIPPED
1030	17-Oct-21	HASSAN	66	UDDURKO-NITTUR2	UDDURKOPLU_66	17:00(15.10.2021)	20:40(17.10.2021)	27:39 hrs	LINE CHARGED
1031	17-Oct-21	HASSAN	110	HOSUR-BALIGAVI	HOSUR_110	18:58	19:09	0:11	LINE FAULT
1032	17-Oct-21	HASSAN	110	HV1	BAIKAMPADI_110	20:50(16.10.2021)	10:45(17.10.2021)	13:54 hrs	TRANSFORMER CHARGED
1033	17-Oct-21	HASSAN	110	HV1	KULASHEKARA_110	11:41	12:05	0:24	LINE CLEAR AVAILED
1034	17-Oct-21	HASSAN	110	HV1	KULASHEKARA_110	15:20	16:59	1:39	LINE CLEAR AVAILED
1035	17-Oct-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1036	17-Oct-21	HASSAN	110	HV2	BAIKAMPADI_110	20:50(16.10.2021)	10:45(17.10.2021)	13:54 hrs	TRANSFORMER CHARGED
1037	17-Oct-21	HASSAN	110	HV2	KADUR_220	10:14	11:15	1:01	TRANSFORMER FAULT
1038	17-Oct-21	HASSAN	110	HV3	BAIKAMPADI_110	20:50(16.10.2021)	10:45(17.10.2021)	13:54 hrs	TRANSFORMER CHARGED
1039	17-Oct-21	HASSAN	110	HV4	BAIKAMPADI_110	20:50(16.10.2021)	10:45(17.10.2021)	13:54 hrs	TRANSFORMER CHARGED
1040	17-Oct-21	HASSAN	110	JOG-JLT4	mghejog_gen	15:00(15.10.2021)			LINE OPEN:LINE FAULT
1041	17-Oct-21	HASSAN	110	KADUR-TNGL	KADUR_220	10:14	11:15	1:01	LINE FAULT
1042	17-Oct-21	HASSAN	110	KADUR-YGTI	KADUR_220	10:14	11:15	1:01	LINE FAULT
1043	17-Oct-21	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	20:47(16.10.2021)	10:45(17.10.2021)	13:57 hrs	LINE CHARGED
1044	17-Oct-21	HASSAN	110	LPH-MGHE 2	lph_gen	15:00(15.10.2021)			LINE OPEN:LINE FAULT
1045	17-Oct-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	9:38	10:13	0:35	LINE FAULT
1046	17-Oct-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	10:35	10:50	0:15	LINE FAULT
1047	17-Oct-21	HASSAN	220	ARSK2-HSN	ARASIKERE_220	12:21	13:03	0:42	LINE FAULT
1048	17-Oct-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
1049	17-Oct-21	MYSORE	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN:LINE CLEAR AVAILED
1050	17-Oct-21	MYSORE	66	HV1	CHANDAKAVADI_66	2:07	2:41	0:33	TRANSFORMER FAULT
1051	17-Oct-21	MYSORE	66	HV1	CHANDAKAVADI_66	2:59	9:57	6:58	TRANSFORMER FAULT
1052	17-Oct-21	MYSORE	66	HV1	CHANDAKAVADI_66	10:04	11:26	1:21	TRANSFORMER FAULT
1053	17-Oct-21	MYSORE	66	HV1	CHANDAKAVADI_66	12:01	18:31	6:30	HAND TRIPPED
1054	17-Oct-21	MYSORE	66	HV1	DATTAGALLY_66	10:51	18:49	7:58	HAND TRIPPED
1055	17-Oct-21	MYSORE	66	HV1	DATTAGALLY_66	11:25	12:10	0:45	LINE CLEAR AVAILED
1056	17-Oct-21	MYSORE	66	HV1	DATTAGALLY_66	16:23	16:49	0:25	LINE CLEAR AVAILED
1057	17-Oct-21	MYSORE	66	HV1	HANAGODU_66	4:01	4:11	0:10	LINE CLEAR AVAILED
1058	17-Oct-21	MYSORE	66	HV1	HANNUR_66	11:05	12:55	1:49	LINE CLEAR AVAILED
1059	17-Oct-21	MYSORE	66	HV1	JAIPUR_66	8:59	9:34	0:34	LINE CLEAR AVAILED
1060	17-Oct-21	MYSORE	66	HV2	KOLLEGALA_66	11:12	12:52	1:39	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1061	17-Oct-21	MYSORE	66	JAKKANALLY-NAGAMANGLA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66	17:08	17:15	0:06	LINE FAULT
1062	17-Oct-21	MYSORE	66	KADAKOLA-SARGUR2	DOORA_66 HULLAHALLI_66 HURA_66	2:13	2:18	0:05	LINE FAULT
1063	17-Oct-21	MYSORE	66	KIRUGAVALU-MALIYUR	NO STATIONS EFFECTED	6:03	6:13	0:09	LINE FAULT
1064	17-Oct-21	MYSORE	66	KUSHALANAGARA-RAMANTHAPURA1	KANAGAL_66 ALUR SIDDAPUR_66 CB HALLI_66 RUDRAPATNA_66	0:28	0:35	0:06	LINE FAULT
1065	17-Oct-21	MYSORE	66	KUSHALANAGARA-RAMANTHAPURA1	KANAGAL_66 ALUR SIDDAPUR_66 CB HALLI_66 RUDRAPATNA_66	5:47	5:56	0:08	LINE FAULT
1066	17-Oct-21	MYSORE	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1067	17-Oct-21	MYSORE	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42(5.10.21)			LINE OPEN:LINE CLEAR AVAILED
1068	17-Oct-21	MYSORE	66	SHIVALLI-HV1	SHIVALLI_66	17:39	18:26	0:47	LINE FAULT
1069	17-Oct-21	MYSORE	66	TUBINKERE-NAGAMANGALA 1	BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66	21:37:24 (13.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1070	17-Oct-21	MYSORE	66	VAJMANGALA-MEGHALAPURA	NO STATIONS EFFECTED	9:47	10:02	0:15	LINE FAULT
1071	17-Oct-21	MYSORE	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1072	17-Oct-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	7:35	7:55	0:20	LINE FAULT
1073	17-Oct-21	TUMKUR	66	DAVANGERE SRS- AVAREGERE66	AVAREGERE_66,MELLEKATTE_6 6,KADAJJI_66	10:57	11:12	0:15	LINE CLEAR AVAILED
1074	17-Oct-21	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	12:12	12:21	0:08	LINE FAULT
1075	17-Oct-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:40	12:05	0:24	LINE FAULT
1076	17-Oct-21	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 1	KORATAGERE_66,HOLAVINAHALLI_66	15:44	17:25	1:41	LINE FAULT
1077	17-Oct-21	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	15:45	16:58	1:12	LINE FAULT
1078	17-Oct-21	TUMKUR	66	MATHOD- PANCHANAHALLI	GARAGA_66,PANCHANAHALLI_66	23:36	23:45	0:08	LINE FAULT
1079	17-Oct-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	12:09	12:48	0:38	HAND TRIPPED
1080	17-Oct-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	12:09	12:48	0:38	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1081	17-Oct-21	TUMKUR	66	SIRA66-KALAMBELLA66	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	20:57	21:39	0:41	LINE FAULT
1082	17-Oct-21	TUMKUR	66	SIRA66-MADHUGIRI220	SIRA_66	20:57	21:06	0:09	LINE FAULT
1083	17-Oct-21	TUMKUR	66	TR-1	TIMMANAHALLI_110	18:00	18:12	0:11	TRANSFORMER FAULT
1084	17-Oct-21	TUMKUR	66	TR-2	RAMPURA_66	11:47	14:45	2:57	LINE CLEAR AVAILED
1085	17-Oct-21	TUMKUR	110	TR-1	KALLUR_110	10:35	10:52	0:16	TRANSFORMER FAULT
1086	17-Oct-21	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	17:15	22:04	4:48	LINE CLEAR AVAILED
1087	17-Oct-21	TUMKUR	220	NITTUR 220-ARASIKERE	NITTUR_220	12:21	12:59	0:37	LINE FAULT
1088	18-Oct-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1089	18-Oct-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
1090	18-Oct-21	BAGALKOT	110	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI_110	21:10	21:20	0:10	LINE FAULT
1091	18-Oct-21	BAGALKOT	110	110/11KV, HV3	SADALAGA_110	12:15	20:10	7:55	LINE CLEAR AVAILED
1092	18-Oct-21	BAGALKOT	110	110/11KV, HV4	SADALAGA_110	12:51	13:00	0:09	HAND TRIPPED
1093	18-Oct-21	BAGALKOT	110	110/11KV,HV1	BAGALKOT_220	9:20	11:22	2:02	TRANSFORMER FAULT
1094	18-Oct-21	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	4:28	4:36	0:08	TRANSFORMER FAULT
1095	18-Oct-21	BAGALKOT	110	110/11KV,HV1	HALAKI_110	9:45	16:50	7:05	TRANSFORMER FAULT
1096	18-Oct-21	BAGALKOT	110	110/11KV,HV2	MALGHAN_110	10:02	10:16	0:14	TRANSFORMER FAULT
1097	18-Oct-21	BAGALKOT	110	110/11KV,HV2	MANTUR_110	6:50	6:55	0:05	TRANSFORMER FAULT
1098	18-Oct-21	BAGALKOT	110	110/11KV,HV3	SANKESHWAR_110	17:55	18:05	0:10	HAND TRIPPED
1099	18-Oct-21	BAGALKOT	110	110/11KV,HV4	HIDIKAL_110	16:15	18:30	2:15	TRANSFORMER FAULT
1100	18-Oct-21	BAGALKOT	110	110/11KV,HV4	KERUR_110	16:35	17:10	0:35	TRANSFORMER FAULT
1101	18-Oct-21	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED CHIKKODI_110 , KHAROSHI_33 & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1102	18-Oct-21	BAGALKOT	110	110/33KV,HV3	ZALKI_110,HORTI_33	13:34	13:40	0:06	HAND TRIPPED
1103	18-Oct-21	BAGALKOT	110	AGADAG-ANNIGERI	ANNIGERI_110	10:42	13:58	3:16	LINE CLEAR AVAILED
1104	18-Oct-21	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	15:50	15:52	0:02	LINE FAULT
1105	18-Oct-21	BAGALKOT	110	AMBEWADI- SUPA1	AMBEWADI_220	15:49	16:41	0:52	HAND TRIPPED
1106	18-Oct-21	BAGALKOT	110	AMBEWADI- SUPA2	AMBEWADI_220	15:50	16:43	0:53	HAND TRIPPED
1107	18-Oct-21	BAGALKOT	110	BAGALKOT-NAVANAGAR 1	NAVANAGAR_110	13:27	14:11	0:44	LINE CLEAR AVAILED
1108	18-Oct-21	BAGALKOT	110	BAGALKOT-NAVANAGAR 2	NAVANAGAR_110	13:01	13:36	0:35	LINE FAULT
1109	18-Oct-21	BAGALKOT	110	BAGALKOT-NAVANAGAR 2	NAVANAGAR_110	13:36	14:12	0:36	LINE CLEAR AVAILED
1110	18-Oct-21	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	10:18	10:38	0:20	NFBC ISSUED
1111	18-Oct-21	BAGALKOT	110	BIDNAL-KONNUR	KONNUR_110	23:35 (18.10.2021)			MAIN SUPPLY FAILURE
1112	18-Oct-21	BAGALKOT	110	BIDNAL-NARGUND	NARGUND_110	23:35 (18.10.2021)			MAIN SUPPLY FAILURE
1113	18-Oct-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
1114	18-Oct-21	BAGALKOT	110	KADANAKOPPA-KAVALWAD	KADANAKOPPA_110	14:04 (17.10.2021)	8:36 (18.10.2021)	18:32 hrs	LINE CHARGED
1115	18-Oct-21	BAGALKOT	110	KADANAKOPPA-KAVALWAD	KADANAKOPPA_110	18:19	18:55	0:36	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1116	18-Oct-21	BAGALKOT	110	KARWAR220-BINAGA(SOLARIS)	KARWAR_220	5:52	8:10	2:18	LINE FAULT
1117	18-Oct-21	BAGALKOT	110	NARENDRA 1&2-MRUTYNJAYA NAGAR	MRUTYUNJAYA NAGAR_110	4:20	13:20	9:00	HAND TRIPPED
1118	18-Oct-21	BAGALKOT	110	NARENDRA-BELUR1	NARENDRA_220	15:55	16:36	0:41	HAND TRIPPED
1119	18-Oct-21	BAGALKOT	110	NARENDRA-BELUR2	NARENDRA_220	16:37	17:02	0:25	HAND TRIPPED
1120	18-Oct-21	BAGALKOT	110	NAVALGUND- KONNUR	KONNUR_110	23:35 (18.10.2021)			LINE OPEN:LINE FAULT
1121	18-Oct-21	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110	9:56	18:28	8:32	NFBC ISSUED
1122	18-Oct-21	BAGALKOT	110	RANEENNUR-HIREKERUR	HIREKERUR_110	10:00	18:35	8:35	HAND TRIPPED
1123	18-Oct-21	BAGALKOT	220	220/110KV, HV1&LV1	KUDACHI_220	10:35	20:27	9:52	LINE CLEAR AVAILED
1124	18-Oct-21	BAGALKOT	220	220/110KV,HV2,LV2	HUBLI_220	14:49	20:55	6:06	LINE CLEAR AVAILED
1125	18-Oct-21	BAGALKOT	220	ATHANI-KUDUCHI	ATHANI_220	11:37	12:46	1:09	NFBC ISSUED
1126	18-Oct-21	BAGALKOT	220	BIDNAL-HUBLI3	BIDNAL_220	10:46	19:18	8:32	NFBC ISSUED
1127	18-Oct-21	BAGALKOT	220	HUBLI-BIDNAL2	HUBLI_220	10:46	19:18	8:32	LINE CLEAR AVAILED
1128	18-Oct-21	BAGALKOT	220	HUBLI-NAGJHARI1	HUBLI_220	10:08	15:14	5:06	LINE CLEAR AVAILED
1129	18-Oct-21	BAGALKOT	220	HUBLI-NAGJHARI2	HUBLI_220	10:08	15:16	5:08	LINE CLEAR AVAILED
1130	18-Oct-21	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	11:03	16:01	4:58	HAND TRIPPED
1131	18-Oct-21	BAGALKOT	220	KUDACHI- ATHANI	KUDACHI_220	11:37	12:47	1:10	LINE CLEAR AVAILED
1132	18-Oct-21	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	3:22 (07.10.2021)			LINE OPEN:LINE FAULT
1133	18-Oct-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1134	18-Oct-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
1135	18-Oct-21	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	11:03	16:01	4:58	HAND TRIPPED
1136	18-Oct-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1137	18-Oct-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1138	18-Oct-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
1139	18-Oct-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1140	18-Oct-21	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA	13:32	14:15	0:43	LINE CLEAR AVAILED
1141	18-Oct-21	BENGALURU	66	HEBBALA 220 - BANASAWADI	BANASAWADI	12:26	12:30	0:04	LINE CLEAR AVAILED
1142	18-Oct-21	BENGALURU	66	HV1	BANASAWADI	13:21	13:25	0:04	LOAD CHANGE OVER
1143	18-Oct-21	BENGALURU	66	HV1	RMZ	9:48	9:55	0:07	LINE CLEAR AVAILED
1144	18-Oct-21	BENGALURU	66	HV2	REMCO	15:55	16:46	0:51	LINE CLEAR AVAILED
1145	18-Oct-21	BENGALURU	66	HV2	RMZ	13:10	13:18	0:08	LINE CLEAR AVAILED
1146	18-Oct-21	BENGALURU	66	HV2	MELUR	13:02	15:57	2:55	LINE CLEAR AVAILED
1147	18-Oct-21	BENGALURU	66	HV2	SARJAPURA 220	12:56	13:00	0:04	MAIN SUPPLY FAILURE
1148	18-Oct-21	BENGALURU	66	HV2	KIADB DB PURA 220	3:52(17-10-2021)	12:38(18-10-2021)	8:45 hrs	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1149	18-Oct-21	BENGALURU	66	HV2	KANAKPURA 66	13:18(12-10-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1150	18-Oct-21	BENGALURU	66	HV3	ELECTRONIC CITY	11:11	11:26	0:15	TRANSFORMER FAULT
1151	18-Oct-21	BENGALURU	66	HV3	BANASAWADI	13:21	13:25	0:04	LOAD CHANGEOVER
1152	18-Oct-21	BENGALURU	66	HV3	SARAKKI	14:55	15:42	0:47	TRANSFORMER FAULT
1153	18-Oct-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	6:22	6:53	0:31	LINE FAULT
1154	18-Oct-21	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	10:02	10:17	0:15	MAIN SUPPLY FAILURE
1155	18-Oct-21	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	12:42	13:01	0:19	LOAD CHANGEOVER
1156	18-Oct-21	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	17:57	18:09	0:12	LOAD CHANGEOVER
1157	18-Oct-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	10:02	10:17	0:15	MAIN SUPPLY FAILURE
1158	18-Oct-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	12:42	13:01	0:19	LOAD CHANGEOVER
1159	18-Oct-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	17:57	18:12	0:15	LOAD CHANGEOVER
1160	18-Oct-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	10:02	10:17	0:15	MAIN SUPPLY FAILURE
1161	18-Oct-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	12:42	13:01	0:19	LOAD CHANGEOVER
1162	18-Oct-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	17:57	18:12	0:15	LOAD CHANGEOVER
1163	18-Oct-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	15:49	16:39	0:50	LINE CLEAR AVAILED
1164	18-Oct-21	BENGALURU	66	SARJAPURA - CHANDAPURA	CHANDAPURA	12:56	13:00	0:04	MAIN SUPPLY FAILURE
1165	18-Oct-21	BENGALURU	66	SARJAPURA - DOMMASANDRA	DOMMASANDRA	12:56	13:00	0:04	MAIN SUPPLY FAILURE
1166	18-Oct-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	11:44	12:37	0:53	LINE CLEAR AVAILED
1167	18-Oct-21	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	NO STATION AFFECTED	22:56(17-10-2021)	7:33(18-10-2021)	8:36 hrs	LINE CHARGED
1168	18-Oct-21	BENGALURU	220	HV1	MALUR 220	10:20	12:33	2:13	LINE CLEAR AVAILED
1169	18-Oct-21	BENGALURU	220	HV1	SARJAPURA 220	12:56(18-10-2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1170	18-Oct-21	GULBARGA	66	HV3	TELADI_66	11:00	11:20	0:20	LINE CLEAR AVAILED
1171	18-Oct-21	GULBARGA	66	HV3 AND HV4	ITTAGI_220	11:30	16:30	5:00	LINE CLEAR AVAILED
1172	18-Oct-21	GULBARGA	66	ITTAGI-HUVINAHADAGALLI	HUVINAHADAGALI_66,HOLAGU NDI_110	10:25	15:25	5:00	LINE CLEAR AVAILED
1173	18-Oct-21	GULBARGA	66	KUDLIGI-BANVIKAL	BANVIKAL_66	13:05	13:10	0:05	LINE CLEAR AVAILED
1174	18-Oct-21	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,UPANAYAKA NAHALLI_66,HAGARIBOMMAN AHALLI_66,RR STEELS_IPP	6:33	6:41	0:08	LINE FAULT
1175	18-Oct-21	GULBARGA	66	TELADI-YARAGUNTA	YARAGUNTA_66	12:00	16:40	4:40	LINE CLEAR AVAILED
1176	18-Oct-21	GULBARGA	66	UCHCHANGIDURGA-BILACHOD	BILCHOD_66	23:10	23:20	0:10	LINE FAULT
1177	18-Oct-21	GULBARGA	110	ALIPUR-BELLARY NORTH1	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANA KI_IPP,BASAI STEELA	19:00	19:12	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1178	18-Oct-21	GULBARGA	110	BEVOOR-KUSHTAGI	BEVVOR_110	12:35	12:40	0:05	MAIN SUPPLY FAILURE
1179	18-Oct-21	GULBARGA	110	BEVOOR-KUSHTAGI	BEVVOR_110	11:45	12:35	0:50	MAIN SUPPLY FAILURE
1180	18-Oct-21	GULBARGA	110	HV2	GULBARGAUNIVERSITY_110	13:15	13:40	0:25	LINE CLEAR AVAILED
1181	18-Oct-21	GULBARGA	110	HV2	MANVI_110	11:52	13:20	1:28	LINE CLEAR AVAILED
1182	18-Oct-21	GULBARGA	110	HV2	GHATTARGA_110	17:00	17:15	0:15	TRANSFORMER FAULT
1183	18-Oct-21	GULBARGA	110	HV3	HATTI_110	3:02	3:15	0:13	TRANSFORMER FAULT
1184	18-Oct-21	GULBARGA	110	JAWALEGRA-SINDHNOOR	JAWALGERA_110	1:30	1:50	0:20	MAIN SUPPLY FAILURE
1185	18-Oct-21	GULBARGA	110	KUSTAGI-BEVOOR	BEVOOR_110,MAGALORE_110	11:50	12:36	0:46	LINE CLEAR AVAILED
1186	18-Oct-21	GULBARGA	110	MANGALORE-BEVOOR	MANGALORE_110	11:45	12:45	1:00	MAIN SUPPLY FAILURE
1187	18-Oct-21	GULBARGA	110	METRI-ALIPUR	METRI_110	19:00	19:10	0:10	MAIN SUPPLY FAILURE
1188	18-Oct-21	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVAT HI_110,DR NAGAR_110,KARATAGI_110	10:24	10:39	0:15	LINE FAULT
1189	18-Oct-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	21:20(18.10.2021)			LINE OPEN:LINE FAULT
1190	18-Oct-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	3:40	7:28	3:48	LINE FAULT
1191	18-Oct-21	GULBARGA	110	RAICHUR-SINDHANOOR2	SINDHANOOR_110	11:02	12:31	1:29	LINE FAULT
1192	18-Oct-21	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	11:20	11:24	0:04	LINE FAULT
1193	18-Oct-21	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	11:30	11:34	0:04	LINE FAULT
1194	18-Oct-21	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	11:35	12:07	0:32	LINE FAULT
1195	18-Oct-21	GULBARGA	110	SEDAM-VASAVADATTA_IPP	SEDAM_220	9:29	16:03	6:34	LINE CLEAR AVAILED
1196	18-Oct-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
1197	18-Oct-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
1198	18-Oct-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	13:00(08.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1199	18-Oct-21	GULBARGA	110	SINDHANOOR-ADVIAMARESHWARA	ADAVIAMARESHWARA_110	1:30	1:40	0:10	LINE FAULT
1200	18-Oct-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,Y ERDONA_110,SRNAGAR_110,M ALLAPURA_110	16:35	16:45	0:10	LINE FAULT
1201	18-Oct-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,Y ERDONA_110,SRNAGAR_110,M ALLAPURA_110	16:59	17:59	1:00	LINE FAULT
1202	18-Oct-21	GULBARGA	110	SIRIGERICROSS-KURUGOD	KURUGOD_110	16:45	17:25	0:40	LINE CLEAR AVAILED
1203	18-Oct-21	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	16:35	16:45	0:10	MAIN SUPPLY FAILURE
1204	18-Oct-21	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	17:00	18:00	1:00	MAIN SUPPLY FAILURE
1205	18-Oct-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1206	18-Oct-21	GULBARGA	220	ITTAGI-HARKANAL_IPP	ITTAGI_220	22:05(17.10.2021)	10:55(18.10.2021)	12:50HRS	LINE CHARGED
1207	18-Oct-21	GULBARGA	220	MALLA-RTPS	RTPS_220	6:07	6:30	0:23	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1208	18-Oct-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	01:01(18.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1209	18-Oct-21	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	5:13	5:24	0:11	LINE FAULT
1210	18-Oct-21	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	13:10	16:14	3:04	NFBC ISSUED
1211	18-Oct-21	HASSAN	66	GORUR-ARAKALGUD	GORUR_66	15:59	16:36	0:37	MAIN SUPPLY FAILURE
1212	18-Oct-21	HASSAN	66	HV1	MAGGE_66	12:20	16:24	4:04	MAIN SUPPLY FAILURE
1213	18-Oct-21	HASSAN	66	HV1	RAMPURA_66	11:27	17:14	5:47	LINE CLEAR AVAILED
1214	18-Oct-21	HASSAN	66	HV1	YESLUR_66	12:05	14:20	2:15	LINE CLEAR AVAILED
1215	18-Oct-21	HASSAN	66	HV2	ARAKALGUD_66	12:19	12:30	0:11	LINE CLEAR AVAILED
1216	18-Oct-21	HASSAN	66	HV2	MAGGE_66	12:20	16:37	4:17	MAIN SUPPLY FAILURE
1217	18-Oct-21	HASSAN	66	KANDLI-HASSAN	KANDLI_66	11:59	16:12	4:13	NFBC ISSUED
1218	18-Oct-21	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	11:59	16:22	4:23	NFBC ISSUED
1219	18-Oct-21	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	12:12	13:47	1:35	LINE FAULT
1220	18-Oct-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	12:15	13:55	1:40	NFBC ISSUED
1221	18-Oct-21	HASSAN	110	HULICA-MRS SK	HULICAL_110	15:22	17:00	1:38	LINE FAULT
1222	18-Oct-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1223	18-Oct-21	HASSAN	110	HV2	BHADRAVATHI_110	11:33	12:07	0:34	LINE CLEAR AVAILED
1224	18-Oct-21	HASSAN	110	HV6	BAIKAMPADY_110	11:32	13:16	1:44	LINE CLEAR AVAILED
1225	18-Oct-21	HASSAN	110	JOG-JLT4	mghejog_gen	15:00(15.10.2021)	11:18(18.10.2021)	68:18hrs	LINE CHARGED
1226	18-Oct-21	HASSAN	110	LPH-MGHE 2	lph_gen	15:00(15.10.2021)	11:24(18.10.2021)	68:24hrs	LINE CHARGED
1227	18-Oct-21	HASSAN	110	LV1	PUTTUR_220	9:30	16:07	6:37	LINE CLEAR AVAILED
1228	18-Oct-21	HASSAN	220	HV1	PUTTUR_220	9:30	15:33	6:03	LINE CLEAR AVAILED
1229	18-Oct-21	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	9:32	12:07	2:35	LINE CLEAR AVAILED
1230	18-Oct-21	HASSAN	220	KEMAR-Varahi2	KEMAR_220	14:03	15:06	1:03	LINE FAULT
1231	18-Oct-21	HASSAN	220	MRSSHM-DAVANGERE	MRSMG_220	12:50	14:32	1:42	LINE CLEAR AVAILED
1232	18-Oct-21	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	9:35	12:08	2:33	NFBC ISSUED
1233	18-Oct-21	HASSAN	220	SHRAVITY-TALAGUPPA 3	sharavathy_gen	10:22	11:55	1:33	LINE CLEAR AVAILED
1234	18-Oct-21	HASSAN	220	TALAGU-SGS3	TALAGUPPA_400	10:22	11:55	1:33	LINE CLEAR AVAILED
1235	18-Oct-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	14:03	14:28	0:25	LINE FAULT
1236	18-Oct-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	14:04	15:55	1:51	LINE FAULT
1237	18-Oct-21	HASSAN	400	TALAGU-HSN400	TALAGUPPA_400	9:31(18.10.2021)			LINE OPEN:LINE FAULT
1238	18-Oct-21	HASSAN	400	TALAGU-HSN400	TALAGUPPA_400	13:45(21.09.2021)	9:27(18.10.2021)	643:42hrs	LINE CHARGED
1239	18-Oct-21	MYSORE	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN:LINE CLEAR AVAILED
1240	18-Oct-21	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	15:43	15:49	0:06	LINE FAULT
1241	18-Oct-21	MYSORE	66	HV1	CHANDAKAVADI_66	9:05	16:33	7:27	LINE CLEAR AVAILED
1242	18-Oct-21	MYSORE	66	HV1	HANAGODU_66	13:55	18:31	4:36	LINE CLEAR AVAILED
1243	18-Oct-21	MYSORE	66	HV2	AKKIEBBAL_66	10:53	11:00	0:06	HAND TRIPPED
1244	18-Oct-21	MYSORE	66	HV2	HANAGODU_66	12:19	18:49	6:30	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1245	18-Oct-21	MYSORE	66	KOLLEGALA-PARINAMIPURA	PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	18:10	18:17	0:06	LINE FAULT
1246	18-Oct-21	MYSORE	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1247	18-Oct-21	MYSORE	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42(5.10.21)			LINE OPEN:LINE CLEAR AVAILED
1248	18-Oct-21	MYSORE	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	21:37:24 (13.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1249	18-Oct-21	MYSORE	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1250	18-Oct-21	MYSORE	220	KADAKOLA-BASTIPURA2	NO STATIONS EFFECTED	10:16	18:51	8:35	NFBC ISSUED
1251	18-Oct-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:03	9:18	0:15	LINE FAULT
1252	18-Oct-21	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	9:03	9:19	0:16	LINE FAULT
1253	18-Oct-21	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	6:03	6:18	0:15	MAIN SUPPLY FAILURE
1254	18-Oct-21	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	9:33	9:43	0:10	HAND TRIPPED
1255	18-Oct-21	TUMKUR	66	HIRIYUR220kv-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	9:33	9:43	0:10	LINE FAULT
1256	18-Oct-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	0:27	0:34	0:07	LINE FAULT
1257	18-Oct-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	4:13	4:21	0:08	LINE FAULT
1258	18-Oct-21	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	6:23	6:29	0:05	LINE FAULT
1259	18-Oct-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	PANDRAHALLI2	0:27	0:34	0:07	LINE FAULT
1260	18-Oct-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	PANDRAHALLI2	4:13	4:21	0:08	LINE FAULT
1261	18-Oct-21	TUMKUR	66	HONNALLI 220kv- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	14:08	14:18	0:10	LINE FAULT
1262	18-Oct-21	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	14:16	14:22	0:05	HAND TRIPPED
1263	18-Oct-21	TUMKUR	66	JAVAGONDANAHALLI- HIRIYUR	JAVAGONDANAHALLI_66	10:45	11:05	0:20	MAIN SUPPLY FAILURE
1264	18-Oct-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	JAVAGONDANAHALLI_66	10:13	10:21	0:08	LINE FAULT
1265	18-Oct-21	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 1	KORATAGERE_66	13:46	15:21	1:35	LOAD CHANGEOVER
1266	18-Oct-21	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI	4:20	4:34	0:14	LINE FAULT
1267	18-Oct-21	TUMKUR	66	PAVAGADA 220kv- YN HOSAKETE	PAVAGADA_220	19:41	21:53	2:12	LINE CLEAR AVAILED
1268	18-Oct-21	TUMKUR	66	PKOTE-AZURE SOLAR	PKOTE_66	6:03	6:27	0:24	MAIN SUPPLY FAILURE
1269	18-Oct-21	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	6:03	6:29	0:26	MAIN SUPPLY FAILURE
1270	18-Oct-21	TUMKUR	66	PKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	6:03	6:36	0:33	MAIN SUPPLY FAILURE
1271	18-Oct-21	TUMKUR	66	SHYLAPURA- MADHUGIRI	YNHOSKOTE_66, MANGALWADA_66,LINGDHALL I_66	17:23	21:56	4:32	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1272	18-Oct-21	TUMKUR	66	TR-1	BUKKAPATNA_66	16:03	16:17	0:14	LINE CLEAR AVAILED
1273	18-Oct-21	TUMKUR	66	TR-1	BUKKAPATNA_66	18:21	18:37	0:16	LINE CLEAR AVAILED
1274	18-Oct-21	TUMKUR	66	TR-1	MAVINAKATTE_66	11:21	11:24	0:02	LINE CLEAR AVAILED
1275	18-Oct-21	TUMKUR	66	TR-1	SANIKERE_66	17:40	18:40	1:00	LINE CLEAR AVAILED
1276	18-Oct-21	TUMKUR	66	TR-1	SANTHEMAVATHURU_66	17:40	17:46	0:06	TRANSFORMER FAULT
1277	18-Oct-21	TUMKUR	66	TR-2	ANTHARASANAHALLI_220	15:21	18:02	2:40	LINE CLEAR AVAILED
1278	18-Oct-21	TUMKUR	66	TR-2	GULIGENAHALLI_66	13:20	13:49	0:29	LINE CLEAR AVAILED
1279	18-Oct-21	TUMKUR	66	TR-2	KORA_66	14:41	15:09	0:27	TRANSFORMER FAULT
1280	18-Oct-21	TUMKUR	66	TR-2	MAVINAKATTE_66	0:08	0:19	0:11	TRANSFORMER FAULT
1281	18-Oct-21	TUMKUR	66	TR-2	MAVINAKATTE_66	13:45	15:52	2:07	LINE CLEAR AVAILED
1282	18-Oct-21	TUMKUR	110	TR-1	TANDAGA_110	13:19	14:08	0:48	LINE CLEAR AVAILED
1283	18-Oct-21	TUMKUR	110	TR-2	BANDIHALLI_110	12:03	12:16	0:13	LINE CLEAR AVAILED
1284	18-Oct-21	TUMKUR	110	TR-2	DODDAGUNI_110	14:45	17:05	2:20	LINE CLEAR AVAILED
1285	18-Oct-21	TUMKUR	220	THALLAK 220kv - BARC 1	BARC 1	12:52	13:45	0:53	LINE FAULT

[illegible]

#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	66
#####	GULBARGA	66
#####	GULBARGA	66
#####	GULBARGA	66
#####	HASSAN	400
#####	HASSAN	110
#####	HASSAN	110
#####	HASSAN	110
#####	HASSAN	110
#####	HASSAN	110
#####	HASSAN	110
#####	HASSAN	110
#####	HASSAN	66
#####	HASSAN	66
#####	HASSAN	66
#####	HASSAN	66
#####	MYSURU	66
#####	MYSURU	66
#####	MYSURU	66
#####	MYSURU	66
#####	MYSURU	66
#####	MYSURU	66
#####	MYSURU	66
#####	MYSURU	66
#####	TUMKUR	220
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	BAGALKOT	220
#####	BAGALKOT	220
#####	BAGALKOT	110
#####	BAGALKOT	220

#####	BAGALKOT	110
#####	BAGALKOT	110
#####	BAGALKOT	110
#####	BAGALKOT	110
#####	BAGALKOT	110
#####	BENGALURU	66
#####	BENGALURU	66
#####	BENGALURU	66
#####	BENGALURU	66
#####	BENGALURU	66
#####	BENGALURU	66
#####	BENGALURU	66
#####	GULBARGA	220
#####	GULBARGA	220
#####	GULBARGA	220
#####	GULBARGA	220
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	66
#####	GULBARGA	66
#####	GULBARGA	66
#####	GULBARGA	66
#####	GULBARGA	66
#####	HASSAN	400
#####	HASSAN	220
#####	HASSAN	220
#####	HASSAN	110
#####	HASSAN	110
#####	HASSAN	110
#####	HASSAN	110
#####	HASSAN	66
#####	HASSAN	66
#####	MYSURU	66
#####	MYSURU	66
#####	MYSURU	66
#####	MYSURU	66
#####	TUMKUR	220

[illegible]

#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	66
#####	GULBARGA	66
#####	GULBARGA	66
#####	HASSAN	400
#####	MYSURU	66
#####	MYSURU	66
#####	MYSURU	66
#####	MYSURU	66
#####	MYSURU	66
#####	TUMKUR	220
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	BAGALKOT	220
#####	BAGALKOT	220
#####	BAGALKOT	110
#####	BAGALKOT	220
#####	BAGALKOT	110
#####	BAGALKOT	220
#####	BAGALKOT	220
#####	BAGALKOT	110
#####	BAGALKOT	110
#####	BAGALKOT	110
#####	BAGALKOT	110
#####	BAGALKOT	110
#####	BENGALURU	220
#####	BENGALURU	66
#####	BENGALURU	66
#####	BENGALURU	66
#####	BENGALURU	220
#####	BENGALURU	66
#####	BENGALURU	66
#####	BENGALURU	66
#####	BENGALURU	220
#####	BENGALURU	220

#####	BENGALURU	220
#####	BENGALURU	66
#####	BENGALURU	66
#####	BENGALURU	66
#####	BENGALURU	220
#####	GULBARGA	220
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	110
#####	GULBARGA	66
#####	HASSAN	400
#####	HASSAN	110
#####	HASSAN	110
#####	HASSAN	66
#####	HASSAN	220
#####	HASSAN	110
#####	HASSAN	110
#####	HASSAN	110
#####	HASSAN	66
#####	HASSAN	66
#####	HASSAN	66
#####	HASSAN	66
#####	HASSAN	66
#####	HASSAN	66
#####	HASSAN	66
#####	HASSAN	66
#####	HASSAN	66
#####	HASSAN	66
#####	HASSAN	66
#####	MYSURU	66
#####	MYSURU	66
#####	MYSURU	220
#####	MYSURU	66
#####	MYSURU	66
#####	MYSURU	66
#####	MYSURU	66
#####	TUMKUR	400
#####	TUMKUR	220
#####	TUMKUR	66
#####	TUMKUR	66

#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66
#####	TUMKUR	66

VAJRAMATT	STATION NO. 7	(23.02.2021)			LINE IS OPEN ON 23.02.2021 @16.17HRS,TRIPPED
NARENDRA-	STATION NO. 22	(30.03.2021)			CB IS OPEN ON 30.03.2021 @ 17:22,TRIPPED ON PI
110/33KV,H	STATION NO. 2	(28.09.2021)			TRANSFORER IS OPEN ON 28.09.2021 @21.32 HRS,
KUDACHI- M	STATION NO. 22	(07.10.2021)			LINE IS OPEN ON 07.10.2021 @3:22HRS, TRIPPED C
110/11KV,H	BELLATTI_11	23:38	23:43	0:05	TRIPPED ON OCR B PHASE
BAGEWADI-	MAMADAPU	2:10	2:34	0:24	TRIPPED ON DPR,Z-1,B PHASE
TODALBAGI-	JAMAKHANI	6:50	7:00	0:10	TRIPPED ON OCR & MASTER 86 RELAY.
110/11KV, H	STATION NO.	18:45	20:20	1:35	TRIPPED ON DIFFERANCIAL RELAY, DIRCTIONAL OC
GUTTAL-RAN	STATION NO.	21:38	22:08	0:30	TRIPPED ON DISTANCE PROTECTION & EFR RELAY.
GUTTAL-RAN	STATION NO.	22:08	22:30	0:22	TRIPPED ON EFR AND OCR,B-N PHASE
BAGALKOT2	LOKAPUR_1	15:46	19:30	3:44	TRIPPED ON DPR, Z-1, DIST-0.01KM
110/11KV, H	MUDDEBIHA	9:05	9:12	0:07	TRIPPED ON OCR & 86 RELAY
110/11KV, H	MUDDEBIHA	10:50	10:59	0:09	TRIPPED ON OCR & 86 RELAY
MKHUBLI22	KHANAPUR_	8:00	8:17	0:17	TRIPPED ON EFR & 86 RELAY
110/11KV,H	AMBEWADI	15:30	16:15	0:45	TRIPPED ON REFR & MTR 86
GHATAPRAG	GHATAPRAG	2:00	2:20	0:20	TRIPPED ON EFR
INDI-LACHYA	INDI_220	6:20	6:30	0:10	TRIPPED ON DPR,Z-1,B PHASE
INDI-ZALKI2	INDI_220	6:20	6:30	0:10	TRIPPED ON MTR 86
EPIP 220 - D	DIVYASHREE	10:44	11:10	0:26	EFR
KORMANGA	K & C VALLE	14:20	14:55	0:35	DIFF.PRO.RELAY, OCR
HV1	NIMHANS 2	11:38	12:05	0:27	86, OCR - 11kv F12 OCR & EFR
HV1	POTTERY RO	10:15	10:35	0:20	PRV, OSR, 86 - 11kv LV1 EFR & OCR & F3 EFR & OC
HV1	POTTERY RO	13:34	13:40	0:06	LOAD CHANGE OVER
HV1	GANJIGUNT	19:20	19:50	0:30	BACK UP OCR - 11kv LV1 EFR
HV1	GANJIGUNT	22:50	23:25	0:35	BACK UP OCR - 11kv LV1 EFR
HV3	HOSKOTE 66	12:55	13:00	0:05	OCR - 11kv LV3 OCR, F18 DOCR, EFR
HV2	KANAKPURA	12:20:00	13:18	0:58	BUCCHOLZ, 86
LV3	KOLAR 220	21:16	22:50	1:34	DIRECTIONAL OCR, EFR, 86, TRIP CIRCUIT SUPERVIS
KOLAR 220 -	BANGARPET	21:39	21:55	0:16	DPR, 86
MALUR 220	SARJAPURA	10:29	10:49	0:20	DPR
MALUR 220	SARJAPURA	10:49	18:41	7:52	DPR
HV1	ANDERSONP	21:35	22:20	0:45	DIFFERENTIAL PROTECTION RELAY, 86, EFR - 11kv I
HV2	KANAKPURA	18(12-10-2021)			TRANSFORMER OPENED TRIPPED ONBUCCHOLZ, W
HV2	KUDLIGI_21	18(12.08.2021)			TRANSFORMER IS KEPT OPEN. TRIPPED ON 86
SHAHAPUR	SEDAM_225	5 (12.10.2021)			LINE IS OPEN.CB OPENED OUT DUE TO HIGH V
SHAHAPUR	RTPS_220	23:27	23:50	0:23	TRIPPED ON DISTANCE RELAY AT DIST: 50.4 KI
HV3	SHAHAPUR	28 (12.10.2021)			TRANSFORMER IS OPEN.TRIPPED ON OCR REL
HV4	SHAHAPUR	28 (12.10.2021)			TRANSFORMER IS OPEN.HV4 IS HAND TRIPPEI
SHAHABAD	MADEWAL	3:20	3:28	0:08	TRIPPED ON EFR DISTANCE RELAY AT DIST: 44
JANAWADA	SANTHAPU	6:50	6:57	0:07	TRIPPED ON DISTANCE RELAY ,CPHASE,ZONE1
HV1	JEEWARGI	7:00	7:40	0:40	TRIPPED ON M86 RELAY
MADIYAL-K	MADIYAL_	6:00	6:04	0:04	TRIPPED ON DISTANCE RELAY AT DIST:5.247KI
MADIYAL-C	CHOWDAP	5:27	5:37	0:10	TRIPPED ON OCR
SINDHANO	TEKKALAKO	11:25	11:35	0:10	TRIPPED ON EFR,DISTANCE PROTECTION REL/
RAICHUR-S	KURDICRO	2:32	2:40	0:08	TRIPPED ON EFR C-PHASE .NO STATION LOAD
RAICHUR-S	SINDHANO	05(12.10.2021)			LINE IS OPEN.TRIPPED ON EFR .NO STATION LI

SHAHABAD	YADRAMI_	11:30	11:35	0:05	TRIPPED ON EFR ,MTR.NO STATION LOAD EFF
SHAHABAD	NALWAR_1	19:08	19:16	0:08	TRIPPED ON DISTANCE RELAY ACT, B-PHASE Z
SHAHAPUR	YADGIR_11	0:58	1:07	0:09	IDLE LINE TRIPPED ON DISTANCE RELAY AT DI
SHAHAPUR	KHANAPUR	1:55	2:01	0:06	TRIPPED ON DISTANCE RELAY AT DIST: 19.6 KI
SHAHAPUR	KHANAPUR	2:08	2:20	0:12	TRIPPED ON DISTANCE RELAY AT DIST: 9.89 KI
SHAHAPUR	YADGIR_11	21:47	22:08	0:21	IDLE LINE TRIPPED ON DISTANCE RELAY AT DI
MUNIRABA	HANASI_66	10:30	10:45	0:15	TRIPPED ON EFR ,MTR. STATION LOAD EFFECT
UCHHANGI	BILCHOD_6	17:40	18:05	0:25	TRIPPED ON DISTANCE RELAY AT DIST: 9.95 KI
ITTAGI-HU	HUVINAH	6:12	6:35	0:23	TRIPPED ON DISTANCE RELAY AT DIST: 12.94 I
HV3	KUDLIGI_2	16:00	16:20	0:20	TRIPPED ON EFR-RPHASE,ALONG WITH 11KV I
TALAGU-HS	TALAGUPPA	45(21.09.2021)			LINE OPENED, TRIPPED ON DPR, .32KM, Z1, L1-N L
ANANDA-SH	ANANDPUR	12:10	14:19	2:09	TRIPPED ON DPR, Z1, 35.8KM, A-N LOOP
HV2	ANAVATTI_1	23:39	23:56	0:17	TRIPPED ON MASTER TRIP,OCR
HGUNJE-HIR	HEGGUNJE_	10:40	10:45	0:05	TRIPPED DUE TO DC FAILURE
HGUNJE-HA	HEGGUNJE_	10:40	10:46	0:06	TRIPPED DUE TO DC FAILURE
HV1	HEGGUNJE_	11:11	11:16	0:05	TRIPPED DUE TO DC FAILURE
MRSSHM-SS	MRSMSG_22	12:10	14:19	2:09	TRIPPED ON DPR,C TO N,11.8KM,Z1
NERALA-TER	NERALAKER	13:35	18:48	5:13	TRIPPED ON DPR,,39.23KM,Z2
HV2	HALLYMYSO	6:15	6:33	0:18	TRIPPED ON 86 RELAY
HNPR2-HAS	HOLENARAS	15:45	15:50	0:05	TRIPPED ON DOCR,Z1,3.48KM
HNPR2-MYS	HOLENARAS	6:15	6:21	0:06	TRIPPED WITHOUT RELAY
UDAYAP-BA	UDAYAPURA	9:06	9:12	0:06	TRIPPED ON OCR
HV1	ANEGOLAL_	11:31	11:43	22:44	TRIPPED ON BACKUP EFR.F2,F3 & F5 FEEDERS INTE
HUNSUR-HC	NO STATION	14:31	14:45	0:13	TRIPPED ON DPR,Z-1 17.48KMS 'R' PHASE.
KR PETE 220	SANTHEBAC	14:01	14:06	0:05	TRIPPED ON DPR.
KR PETE 220	SANTHEBAC	16:24	16:45	0:21	TRIPPED ON DPR.
SHANIVARS	NO STATION	10:22	10:41	0:18	TRIPPED ON DPR..
SFC SHIVA-H	NO STATION	17:50	18:05	0:15	TRIPPED ON EFR.
SFC SHIVA-P	NO STATION	17:50	18:00	0:10	TRIPPED ON MASTER TRIP RELAY(AS PER STATION I
TUBINKERE-	ADDIHALLI_	15:22	15:28	0:06	TRIPPEDON DPR Z-3 @64.75KMS & EFR.STATIONS I
SANTEBACH	ADDIHALLI_	11:05	11:20	0:15	TRIPPED ONOCR & EFR. SANTEBACHALLI & HARIYA
TR-2	KIADB V N P	15:56	22:47	6:51	TRIPPING COIL FAULT ATTEND
HANAGAL-T	HANAGAL_6	13:52	14:02	0:10	TRIPPED ON DPR &MTR86
HANAGAL-T	HANAGAL_6	13:50	15:10	1:20	TRIPPED ON DPR &MTR86
HARIYABBE-	HARIYABBE_	9:55	10:30	0:35	TRIPPED ON OCR DUE TO OVER GENRATION
HARIYABBE-	HARIYABBE_	10:41	10:54	0:12	TRIPPED ON OCR DUE TO OVER GENRATION
TR-2	HINDASGHA	11:10	11:48	0:38	DC CHARGER FAILURE
TR-2	HINDASGHA	13:42	15:56	2:13	TRIPPED ON MTR86 DUE TO F12 BANK ARC OVER
220KV-CHA	CHALLAKER	14:33	14:40	0:06	TRIPPED ON EFR
kv- CHANNA	DEVARAHAL	9:12	9:19	0:06	TRIPPED ON DPR R-PH TO GROUND DIST 18.96KM .
I 220KV- SAS	LLI_66,CHAN	10:20	10:30	0:09	TRIPED ON DPR B-PH TO GROUND Z1 DIST 14.47KM
I 220KV- SAS	LLI_66,CHAN	12:13	12:33	0:20	TRIPPED ON DPR B-PH TO GROUND Z1 DIST 18.27K
MADHUGIRI	MEDIGESHI_	4:54	5:17	0:23	TRIPPED ON DPR DIST 11.02KM Z1 B-PH & CONTAC
VAJRAMATT	STATION NO 7	(23.02.2021)			LINE IS OPEN ON 23.02.2021 @16.17HRS,TRIPPED
NARENDRA-	STATION NO 22	(30.03.2021)			CB IS OPEN ON 30.03.2021 @ 17:22,TRIPPED ON PI
110/33KV,H	STATION NO 2	(28.09.2021)			TRANSFORER IS OPEN ON 28.09.2021 @21.32 HRS,
KUDACHI- M	STATION NO 22	(07.10.2021)			LINE IS OPEN ON 07.10.2021 @3:22HRS, TRIPPED C

110/33KV, H	HALLUR_33,	19:00	19:57	0:57	TRIPPED ON TRIP CKT SUPERVISION RELAY 1.95ABC
RATTIHALLI-	RATTIHALLI	19:00	20:10	1:10	TRIPPED ON NUMERICAL RELAY 21L FAIL, 67/67N I
RAMANAKO	MUNDAGOD	5:58	6:11	0:13	TRIPPED ON DPR, FD=20.66KM, PHASE=B, FC=151C
110/11KV, H	MRUTYUNJA	11:15	11:20	0:05	TRIPPED BUT NO RELAY OPERATED
ATHANI220-	BALIGERI_11	5:55	6:07	0:12	TRIPPED ON DPR, C-PH,Z-1,LOCATION-6KM
HV2	ITI 220	13:35	13:52	0:17	OCR, 86 - 11kv LV2 NO RELAY OPERATED, F9 EFR &
JAYADEVA -	JAYADEVA	6:52	6:57	0:05	OCR
JAYADEVA -	NO STATION	6:52	14:48	7:56	DPR
T GOLLAHAL	BAIRKURU, I	22:09	22:25	0:16	DPR
TK HALLI 22	NO STATION	14:55	15:14	0:19	NO RELAY OPERATED
KOLAR 220 -	TAMAKA	6:16	6:23	0:07	DOCR
HV2	KANAKPURA	18(12-10-2021)			TRANSFORMER OPENED TRIPPED ONBUCCHOLZ, V
HV2	KUDLIGI_22	18(12.08.2021)			TRANSFORMER IS KEPT OPEN. TRIPPED ON 86.1 &
SHAHAPUR-	SHAHAPUR_	20:48	21:10	0:22	TRIPPED ON DISTANCE RELAY AT DIST: 22.9KM ZON
SHAHAPUR-	SHAHAPUR_	21:44	22:45	1:01	TRIPPED ON DISTANCE RELAY AT DIST: 49.9KM ZON
HUMNABAD	HUMNABAD	5:36	5:48	0:12	TRIPPED ON DISTANCE RELAY AT DIST: 55.11 KM ZC
STAR METAL	SINDHANOC	0:33	0:44	0:11	TRIPPED ON OCR EFR. STATION LOAD EFFECTED
MUNIRABAD	VENKATAGI	0:34	1:23	0:49	TRIPPED ON OCR/EFR DISTANCE RELAY AT DISTAN
MUDDAPUR	MASKI_110	3:28	3:33	0:05	TRIPPED ON DISTANCE RELAY AT DIST: 2.9KM ZONI
SINDHANOC	ADAVIAMAR	12:23	12:33	0:10	TRIPPED ON OCR,DISTANCE RELAY AT DISTANCE=5
RAICHUR-SH	GOOGLE_11	5:00	5:10	0:10	TRIPPED ON DISTANCE RELAY AT DISTANCE=15.42H
RAICHUR-SH	GOOGLE_11	18:55	19:04	0:09	TRIPPED ON DISTANCE RELAY AT DISTANCE=29.76H
MALLAT-SIR	SIRWAR_110	9:56	10:04	0:08	TRIPPED ON EFR.,OCR.STATION LOAD IS EFFECTED.
MALLAT-MA	ADVIAMARE	0:26	0:31	0:05	TRIPPED ON EFR DISTANCE RELAY AT DISTANCE=17
MALLAT-MA	ADVIAMARE	2:33	2:38	0:05	TRIPPED ON EFR DISTANCE RELAY AT DISTANCE=17
HV3	KEREHALLI_	11:05	11:15	0:10	TRIPPED ON EFR
CHINCHOLI-	MANEKHALI	15:55	16:13	0:18	TRIPPED ON DIFFERENTIAL RELAY & MTR ALONG V
NEELAGUND	TELIGI_110	16:54	17:08	0:14	TRIPPED ON DISTANCE RELAY AT DISTANCE=5.469H
HV3	KUDLIGI_22	11:30	11:40	0:10	TRIPPED ON EFR ALONG WITH 11KV F3 FEEDER FAI
ITTAGI-HIRE	HIREHADAG	5:55	6:05	0:10	TRIPPED ON DISTANCE RELAY .STATION LOAD EFFE
HV2	TELIGI_66	14:10	14:20	0:10	TRIPPED ON OCR ALONG WITH 11KV FEEDER F4 .H'
HV2	TELIGI_66	12:20	12:40	0:20	TRIPPED ON OCR ALONG WITH 11KV FEEDER F4 .H'
TALAGU-HSI	TALAGUPPA	45(21.09.2021)			LINE OPENED, TRIPPED ON DPR, .32KM, Z1, L1-N LC
HV1	ARASIKERE_	18:47	20:10	1:23	TRIPPED ON PRD
HV1	ARASIKERE_	11:43	15:37	3:54	TRIPPED ON PRD
LV1	ARASIKERE_	11:43	15:37	3:54	TRIPPED ON PRD
LV1	ARASIKERE_	18:47	20:10	1:23	TRIPPED ON PRD
HOSUR-BALI	HOSUR_110	20:10	20:15	0:05	TRIPPED ON CB LOCKOUT
HV1	NITTUR_110	4:02	9:23	5:21	TRIPPED ON EFR,OCR
HV1	HIREMANGA	16:45	18:05	1:20	TRIPPED ON TRF TRIP FUNCTION OPERATEDDD REL/
TAVAREC-ID	TAVARECHA	9:25	9:35	0:10	TRIPPED ON DPR,1.35KM,Z1,C-PHASE
HV2	DEVANOOR	7:26	7:36	22:44	TRIPPED ON DC SUPERVISION RELAY. F5, F6, F7, F8
KIRUGAVAL	NO STATION	7:16	7:24	0:08	TRIPPED ON DPR.
CR NAGARA	NO STATION	11:40	11:46	0:06	TRIPPED ON DPR, Z-1 @68.9%.
HV2	DEVANOOR	7:26	7:36	0:09	TRIPPED ON DC SUPERVISION RELAY. F5, F6, F7, F8
KIRUGAVAL	NO STATION	7:16	7:24	0:08	TRIPPED ON DPR.
TR-1(HV SID	PAVAGADA_	19:21	19:31	0:10	TRIPPED ON MTR86A&B

TR-2 (HV SID	PAVAGADA	19:21	19:38	0:16	TRIPPED ON MTR86A&B
PAVAGADA2	PAVAGADA	19:21	20:55	1:34	TRIPPED ON MTR86A&B
DAVANGERE	AVAREGERE	6:42	6:53	0:10	TRIPPED ON EFR
DAVANGERE	DAVANGERE	6:42	6:53	0:10	TRIPPED ON EFR
HARIYABBE-	HARIYABBE	17:44	18:10	0:25	TRIPPED ON MTR86 HI SPEED 86 DUE TO PD KOTE
HONNALLI 2	KUNDUR,_6	15:31	15:38	0:07	TRIPPED ON MTR86&EFR
HONNALLI 2	DEVARAHAL	11:29	11:38	0:09	TRIPPED ON DPR R-PH TO GROUND DIST 2.21KM Z
HONNALLI 2	DEVARAHAL	12:18	13:26	1:08	TRIPPED ON DPR R-PH TO GROUND DIST 2.24KM Z
HONNALLI 2	SASUVEHAL	5:56	6:04	0:08	TRIPPED ON DPR R-PH TO GROUND DIST 30.34KM
HONNALLI 2	SASUVEHAL	10:44	10:54	0:10	TRIPPED ON DPR R-PH TO GROUND DIST 2.12KM Z
HONNALLI 2	SASUVEHAL	13:22	14:22	1:00	TRIPPED ON DPR B-PH TO GROUND DIST 7.13KM Z
MADHUGIRI	MEDIGESHI	18:10	18:43	0:32	TRIPPED ON B-PH Z1 DPR DIST 2.05KM 21X
TR-1	PAVAGADA	22:32	22:42	0:10	TRIPPED ON MTR86
PAVAGADA2	PAVAGADA	6:33	6:43	0:10	TRIPPED ON EFR
VAJRAMATT	STATION NO 7	(23.02.2021)			LINE IS OPEN ON 23.02.2021 @16.17HRS,TRIPPED
NARENDRA-	STATION NO 22	(30.03.2021)			CB IS OPEN ON 30.03.2021 @ 17:22,TRIPPED ON PI
110/33KV,H	STATION NO 2	(28.09.2021)			TRANSFORER IS OPEN ON 28.09.2021 @21.32 HRS,
KUDACHI- M	STATION NO 22	(07.10.2021)			LINE IS OPEN ON 07.10.2021 @3:22HRS, TRIPPED C
110/11KV,H	ALMEL_110	9:42	9:47	0:05	TRIPPED ON OCR
110/11KV,H	ALMEL_110	9:58	10:09	0:11	TRIPPED ON OCR
BAGALKOT-H	KERUR_110	6:06	6:26	0:20	TRIPPED ON DPR
110/11KV,H	THORVI_110	7:22	7:29	0:07	TRIPPED ON OCR&86
110/11KV, H	STATION NO	16:57	17:04	0:07	TRIPPED ON OCR & 86 RELAY
KERUR-BAD	BADAMI_11	6:06	6:32	0:26	TRIPPED ON EFR
CHANDAKAV	CHANDAKAV	4:45	4:50	0:05	TRIPPED ON DPR
110/11KV, H	SHIRAGUPPI	10:35	10:40	0:05	TRIPPED ON OCR
RANEENN	HIREKERUR	13:50	14:02	0:12	TRIPPE ON OCR & EFR,B PHASE DPR(Z-1,Bphase, 8
INDI220-ZAL	STATION NO	10:24	10:28	0:04	TRIPPED ON EFR
BG ROAD - J	JIGANI LINK	4:33	4:46	0:13	DPR
HV1	ELECTRONIC	8:01	8:10	0:09	86, OCR & EFR - 11kv LV1 OCR & F5 OCR & EFR
HEBBALA 22	BANASAWA	1:38	1:51	0:13	DPR
HEBBALA 22	BANASAWA	11:55	12:04	0:09	DPR
ITI 220 - BAN	BANASAWA	12:35	13:03	0:28	DPR, EFR
SOMANAH	ISKON, SUB	10:15	10:29	0:14	OCR & EFR
GOWRIBIDA	AFTL SOLAR	5:59	6:10	0:11	DPR
HV1	CHINTAMAN	14:44	15:13	0:29	DIFFERENTIAL PROTECTION RELAY - 11kv F13 EFR,
HV2	KANAKPURA	18(12-10-2021)			TRANSFORMER OPENED TRIPPED ONBUCCHOLZ, V
HV5	NRS 220	11(14/10/2021)			TRANSFORMER IS OPENED, TRIPPED ON OCR(R PH,
HV1	KUDLIGI_22	5:50	6:40	0:50	TRIPPED ON 86.1 AND 86.2 REALY. STATION LOAD
SHAHAPUR-	SHAHAPUR	2:05	4:54	2:49	TRIPPED ON DISTANCE RELAY AT DIST: 22.8KM ZO
HV2	KUDLIGI_22	18(12.08.2021)			TRANSFORMER IS KEPT OPEN. TRIPPED ON 86.1 &
RAICHUR-SH	GOOGLE_11	18:11	18:30	0:19	TRIPPED ON EFR,MTR, DISTANCE RELAY AT DISTAN
RAICHUR-SI	SINDHANOC	20(14.10.2021)			LINE IS OPEN.TRIPPED ON DISTANCE RELAY AT DIS
SHAHAPUR-	KHANAPUR	4:25	4:31	0:06	TRIPPED ON DISTANCE RELAY AT DIST: 9.07KM ZO
SHAHAPUR-	SHORAPUR	5:46	5:49	0:03	TRIPPED ON DISTANCE RELAY AT DISTANCE-15.3 KI
HUMNABAD	CHITAGUPP	21:10	21:20	0:10	TRIPPED ON EFR .STATION LOAD EFFECTED.
HV1	KADAGANCH	11:30	11:45	0:15	TRIPPED ON REFR

HV2	MANVI_110	11:33	11:36	0:03	TRIPPED ON OCR 51C ALONG WITH 11KV F4 JANEK
MASKI-SIND	MASKI_110	2:40	2:57	0:17	TRIPPED ON BACKUP EFR ALONG WITH 110KV REN
CHINCHOLI-	MANEKHALI	16:20	16:25	0:05	TRIPPED ON DIFFERENTIAL RELAY & MTR ALONG W
NEELAGUND	PUNAMGHA	17:07	17:15	0:08	TRIPPED ON EFR.NO STATION LOAD EFFECTED
ITTAGI-HIRE	HIREHADAG	5:55	6:05	0:10	TRIPPED ON BACK UP OCR,B-PHASE AND MTR REL/
HV1	PUNAB GHA	18:50	18:55	0:05	TRIPPED ON OCR,EFR . HV1 LOAD EFFECTED
TALAGU-HSI	TALAGUPPA	45(21.09.2021)			LINE OPENED, TRIPPED ON DPR, .32KM, Z1, L1-N L
HV2	KADAKOLA_	4:39	4:46	22:44	TRIPPED ON BACK UP AUXILLARY RELAY & MASTER
KR PETE 220	ADDIHALLI_	7:37	7:42	0:04	TRIPPED ON DPR.
KUSHALNAG	MIRLE_66	15:50	15:53	0:03	TRIPPED ON DPR, Z-1@ 62.6KMS
KUSHALNAG	NO STATION	9:26	18:31	9:05	TRIPPED ON DPR, Z-1@ 30.95KMS.
VAJMANGAL	MARADIHUN	18:15	18:24	0:09	TRIPPED ON DPR, Z-1@ 23.4KMS.
JAGLUR_400	JAGALUR_40	5:50	6:49	0:58	TRIPPED ON DPR DIST 20.9KM B-PH Z1 &MTR86
BRAHMASAI	BRAHMASAI	11:06	11:15	0:09	TRIPPED ON DPR DUE TO SUN WEEK FAULT
DAVANGERE	AVAREGERE	6:11	6:21	0:09	TRIPPED ON EFR
DAVANGERE	AVAREGERE	11:11	12:30	1:19	TRIPPED ON EFR
DAVANGERE	CHITRADUR	6:11	6:21	0:09	TRIPPED ON EFR
DAVANGERE	CHITRADUR	11:11	12:30	1:19	TRIPPED ON EFR
DAVANGERE	KUKKAWAD	12:37	12:51	0:13	TRIPPED ON OCR
GULIGENAH	GULIGENAH	7:28	7:37	0:09	TRIPPED ON DPR&MTR86
HONNALLI 2	BANUVALLI	15:15	15:24	0:09	TRIPPED ON DPR Z1 R-PH TO NUTRAL Z1 DIST 25.2
HONNALLI 2	SASUVEHAL	13:29	13:39	0:09	TRIPPED ON DPR Z1 B-PH TO GROUND DIST 18.81K
HONNALLI 2	SASUVEHAL	13:29	15:26	1:57	TRIPPED ON DPR Z1 B-PH TO GROUND DIST 11.20I
JAVAGONDA	JAVAGONDA	6:08	6:20	0:11	TRIPPED ON OCR
JAVAGONDA	INFOSYS-1	12:06	12:07	0:01	TRIPPED ON SPS RELAY
VAJRAMATT	STATION NO.7	(23.02.2021)			LINE IS OPEN ON 23.02.2021 @16.17HRS,TRIPPED
NARENDRA-	STATION NO.22	(30.03.2021)			CB IS OPEN ON 30.03.2021 @ 17:22,TRIPPED ON PI
110/33KV,H	STATION NO.2	(28.09.2021)			TRANSFORER IS OPEN ON 28.09.2021 @21.32 HRS,
KUDACHI- M	STATION NO.22	(07.10.2021)			LINE IS OPEN ON 07.10.2021 @3:22HRS, TRIPPED C
110/33KV,H	GULEDGUDI	12:36	12:48	0:12	TRIPPED ON OCR, B PHASE
DHONI-GAD	DHONI_400	12:26	12:43	0:17	TRIPPED ON Z-1,B-N,12.9KM,FC-4.07KA
DHONI-GAD	DHONI_400	14:06	18:59	4:53	TRIPPED ON B PHASE,Z-1,10.56KM,FC-4.482KA,
AMBEWAAD	AMBEWADI	6:55	12:45	5:50	DPR,L2-N,DIST=0.1 KM,FC==10.947 kA(Y-Ph LA flas
110/11KV, H	RON_110	11:40	12:40	1:00	TRIPPED ON EFR & OCR
HAVERI220-	TILUVALLI_1	6:03	7:53	1:50	Tripped on DOCR and EFR,FC=2.437kA,Distance=27
HAVERI220-	HAVERI_220	6:24	7:43	1:19	TRIPPEED ON DPR Zone-1,FD=8.329km,B-N,Ib=4.4
HAVERI220-	SAVANUR_1	8:51	9:11	0:20	TRIPPED ON DPR,Z-1,Ph-AB-N,FL=13.2KM,FC=3.97
HV2	HEBBALA 22	14:29	17:46	3:17	OCR
DIVYASHREE	KACHAMAR	18:56	19:35	0:39	EFR
HV1	TK HALLI 220	12:12	12:24	0:12	86, OCR
TK HALLI 220	AKKURMOL	20:21	21:09	0:48	EFR
HV1	YARANDANA	18:06	18:58	0:52	86, OCR
YARANDANA	BIOCON (EH	18:06	18:58	0:52	86, DPR
GOWRIBIDA	MANCHENA	5:40	5:50	0:10	DPR
HOSKOTE 22	HBR LAYOU	8:21	8:32	0:11	DPR
LV3	KOLAR 220	15:10	15:25	0:15	DIRECTIONAL OCR, EFR, 86
HV3	KOLAR 220	15:10	15:25	0:15	DIRECTIONAL OCR, EFR, 86, TRIP CIRCUIT SUPERVIS

KOLAR 220	MALUR 220	12:03	12:14	0:11	DPR, 86
KFG - KYASA	KYASAMBAL	17:15	17:40	0:25	DPR, OCR, EFR
CHINTAMAN	BOMMEPAL	19:23	19:26	0:03	EFR, 86
HV2	KANAKPURA	18(12-10-2021)			TRANSFORMER OPENED TRIPPED ONBUCCHOLZ, V
HV1	HEBBALA 220	00(15/10/2021)			TRANSFORMER IS OPENED, TRIPPED ON DIFF.PRO.
HV2	KUDLIGI_220	18(12.08.2021)			TRANSFORMER IS KEPT OPEN. TRIPPED ON 86.1 &
RAICHUR-SH	GOOGLE_11	4:35	4:49	0:14	TRIPPED ON DISTANCE RELAY AT DISTANCE=8.73KI
RAICHUR-SI	SINDHANOC	17:49	18:21	0:32	TRIPPED ON DISTANCE RELAY AT DISTANCE=37.75
RAICHUR-SI	SINDHANOC	29(15.10.2021)			LINE IS OPEN.TRIPPED ON DISTANCE RELAY AT DIS
HALBARGA-	CHRIDRI_11	16:38	16:43	0:05	TRIPPED ON EFR.NO STATION LOAD EFFECTED
SHAHAPUR-	KHANAPUR	6:01	6:10	0:09	TRIPPED ON DISTANCE RELAY AT DIST: 19.5KM ZON
HV2	DEODURGA	16:28	16:33	0:05	TRIPPED ON OCR YPHASE,MTR,EFR,ALONG WITH 1
MASKI-SIND	MASKI_110	22:22	22:26	0:04	TRIPPED ON BACKUP EFR
HV2	CHINCHOLI	21:36	22:14	0:38	TRIPPED ON DIFFERENTIAL RELAY RYB-PHASE & M
NALWAR-CL	NALWAR_11	6:00	6:10	0:10	TRIPPED ON DISTANCE PROTECTION RELAY DISTAN
HV3	KUDLIGI_22	16:15	16:25	0:10	TRIPPED ON EFR AND OCR ALONG WITH 11KV F3 F
TALAGU-HSI	TALAGUPPA	45(21.09.2021)			LINE OPENED, TRIPPED ON DPR, .32KM, Z1, L1-N LI
JOG-JLT4	mghejog_gen	00(15.10.2021)			TRIPPED ON DPR,B-PHASE,86A,Z1ON 15.10.2021@
LPH-MGHE 2	lph_gen	00(15.10.2021)			TRIPPED ON DPR,B-PHASE,86A,Z1ON 15.10.2021@
GENDEHA-M	GENDEHALL	32(15.10.2021)			LINE OPENED TRIPPED ON DPR,9.31KM, ON 15.10.:
ARSK2-NITT	ARASIKERE	14:50	15:35	0:45	TRIPPED ON DPR,BC-PHASE,106.9KM,Z1,
HV2	ANAVATTI_1	6:54	7:00	0:06	TRIPPED ON DIFFERENTIAL RELAY
HV2	ANAVATTI_1	19:15	19:45	0:30	TRIPPED ON OCR,Y-PHASE
JOG110-MG	JOG_110	15:00	15:35	0:35	TRIPPED ON MASTER TRIP
SHRLKP-BAR	SHIRALKOPP	12:06	12:41	0:35	TRIPPED ON DPR,L3-E LOOP,7.2 KMS
HASSN22-SK	HASSAN_22	17:19	18:18	0:59	TRIPPED ON DPR,EFR,DPR,B TO N,0.2KM
HASSN22-SU	HASSAN_22	15:01	15:18	0:17	TRIPPED ON OCR,DPR,5.1KM,A TO N,MASTER TRIP
HASSN22-UI	HASSAN_22	17:01	18:45	1:44	TRIPPED ON ,21.76,OCR,MASTER TRIP
BALLUPE-SA	BALLUPETE	17:19	17:45	0:26	TRIPPED ON DPR,37.48MTR
KANDLI-HAS	KANDLI_66	17:18	18:24	1:06	TRIPPED ON OCR
KANDLI-SAK	KANDLI_66	17:18	18:13	0:55	TRIPPED ON OCR
SAKALE-IPCL	SAKLESHPU	11:45	12:00	0:15	TRIPPED ON EFR
TAVAREC-ID	TAVARECHA	14:20	14:30	0:10	TRIPPED ON DPR,18.39KM,Z1,A-PHASE
UDDURKO-S	UDDURKOP	15:01	15:18	0:17	TRIPPED ON EFR
UDDURKO-S	UDDURKOP	18:48	18:57	0:09	TRIPPED ON EFR
CHANNAR-M	CHANNARAY	13:00	13:20	0:20	TRIPPED ON DPR,Z1,A-PHASE,16.59KM
HV2	AKKIHEBBAL	21:43	22:30	22:44	TRIPPED ON REFR & MASTER TRIP RELAY , LC TAKE
KABHALLY-C	NO STATION	3:58	5:07	1:08	TRIPPED ON DPR.
KADAKOLA-I	NO STATION	12:38	19:28	6:49	TRIPPED ON DPR (KEPT OPEN INFORM TO TLI JE) &
KUSHALNAG	MIRLE_66	8:28	18:31	10:03	TRIPPED ON DPR, Z-1@ 46.07KMS.
HV2	SB HALLI_66	15:14	18:49	3:35	TRIPPED ON OCR & EFR DUE TO F6 FEEDER FAULT.
SFC SIVA-PG	NO STATION	20:27	20:38	0:10	TRIPPED ON OCR.
SFC SIVA-HE	NO STATION	20:25	20:40	0:15	TRIPPED ON DPR.
GUTTUR 400	GUTUR_400	10:57	11:48	0:51	TRIPPED ON DPR DIST 146.1KM Z2
NITTUR 220	NITTUR_220	14:50	15:31	0:41	TRIPPED ON DPR Z1 DIST 28.29KM R-PH &MTR86
DAVANGERE	DAVANAGER	5:42	5:55	0:12	TRIPPED ON EFR
DAVANGERE	KUKKAWAD	5:42	5:55	0:12	TRIPPED ON EFR

JAVAGONDA	INFOSYS-1	9:54	10:00	0:06	TRIPPED ON SPS RELAY
NAYAKANAH	NAYAKANHA	18:27	18:41	0:14	TRIPPED ON EFR & ,OCR HI SPEED 86
RANGANATH	WELSPUN_I	10:16	10:35	0:19	TRIPPED ON EFR
RANGANATH	WELSPUN_I	18:10	19:14	1:04	TRIPPED ON DPR &EFR
RANGANATH	WELSPUN_I	10:16	10:35	0:19	TRIPPED ON EFR

ON DPR,Z-1,DIST-20.87KM,B-G,FC-3.36KA(NFBC ISSUED TO TLM STAFF FOR ATTENDING LINE MAINTANENCE WORK
DR (NOT RECORDED IN SCADA) CB PROBLEM (FAIL)AT NARENDRA END , LINE IS IDLE CHARGED AT AMBEWADI END,

ALDAMMA TEMPLE ,ADDIHALLI,HARADANAHALLI,BG NAGARA,AC GIRI & VADERALLI STATIONS INTERRUPTEDSTATIC

ON DPR,Z-1,DIST-20.87KM,B-G,FC-3.36KA(NFBC ISSUED TO TLM STAFF FOR ATTENDING LINE MAINTANENCE WORK
DR (NOT RECORDED IN SCADA) CB PROBLEM (FAIL)AT NARENDRA END , LINE IS IDLE CHARGED AT AMBEWADI END,

ON DPR,Z-1,DIST-20.87KM,B-G,FC-3.36KA(NFBC ISSUED TO TLM STAFF FOR ATTENDING LINE MAINTANENCE WORK
DR (NOT RECORDED IN SCADA) CB PROBLEM (FAIL)AT NARENDRA END , LINE IS IDLE CHARGED AT AMBEWADI END,

ON DPR,Z-1,DIST-20.87KM,B-G,FC-3.36KA(NFBC ISSUED TO TLM STAFF FOR ATTENDING LINE MAINTANENCE WORK
DR (NOT RECORDED IN SCADA) CB PROBLEM (FAIL)AT NARENDRA END , LINE IS IDLE CHARGED AT AMBEWADI END,

{)OPEN AT BOTH END, SUPPLY IS FROM BAGALKOT 220 & KUDAGI GEN (AROUND 360 INSULATOR HAS TO BE RELAPC

;)OPEN AT BOTH END, SUPPLY IS FROM BAGALKOT 220 & KUDAGI GEN (AROUND 360 INSULATOR HAS TO BE REPLACED)

;)OPEN AT BOTH END, SUPPLY IS FROM BAGALKOT 220 & KUDAGI GEN (AROUND 360 INSULATOR HAS TO BE REPLACED)

;)OPEN AT BOTH END, SUPPLY IS FROM BAGALKOT 220 & KUDAGI GEN (AROUND 360 INSULATOR HAS TO BE REPLAC

ED, TENDER INVITING WORK IS UNDER PROCESS)

ED, TENDER INVITING WORK IS UNDER PROCESS)

ED, TENDER INVITING WORK IS UNDER PROCESS)

ED, TENDER INVITING WORK IS UNDER PROCESS)