

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 04.12.2018 to 10.12.2018

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	4-Dec-18	BAGALKOT	220	220/110KV,HV1	ATHANI_220,HALIYAL LIS_110,KSSKN_110,SATTI_110,KARIMA SUTI_110,ATHANI_110,AIGALI_110,TAU SHI_110	5:58	7:05	1:07	TRANSFORMER FAULT
2	4-Dec-18	BAGALKOT	220	220/110KV,HV2,LV2	ATHANI_220	10:18	17:00	6:42	TRANSFORMER FAULT
3	4-Dec-18	BAGALKOT	110	110/11KV,HV2	BELUR_110	5:30	5:57	0:27	TRANSFORMER FAULT
4	4-Dec-18	BAGALKOT	110	110/11KV,HV2	BELUR_110	13:40	14:38	0:58	HAND TRIPPED
5	4-Dec-18	BAGALKOT	220	BELGAUM2-CHIKKODI	CHIKKOD_220	15:56	15:58	0:02	HAND TRIPPED
6	4-Dec-18	BAGALKOT	220	BELGAUM1-CHIKKODI	CHIKKODI_220	15:59	16:00	0:01	HAND TRIPPED
7	4-Dec-18	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	4:06	4:35	0:29	LINE FAULT
8	4-Dec-18	BAGALKOT	110	MAHALINGPUR220-JAMAKHANDI	JAMAKHANDI_110	0:00	6:17	6:17	HAND TRIPPED
9	4-Dec-18	BAGALKOT	110	110/11KV,HV1	KUDUCHI_220	22:21	22:28	0:07	TRANSFORMER FAULT
10	4-Dec-18	BAGALKOT	220	KUDUCHI-ATHANI	ATHANI_220	5:59	6:49	0:50	LINE FAULT
11	4-Dec-18	BAGALKOT	110	UMMACHAGI-SIRSI	SIRSI_110	0:00	13:00	13:00	LINE CLEAR AVAILED
12	4-Dec-18	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	10:23	18:01	7:38	LINE CLEAR AVAILED
13	4-Dec-18	BAGALKOT	110	ATHANI220-SATTI	SATTI_110	15:12	23:59	8:47	HAND TRIPPED
14	4-Dec-18	BAGALKOT	110	110/33KV,HV3	SANKHESHWAR_110	10:51	11:03	0:12	HAND TRIPPED
15	4-Dec-18	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	10:58	14:15	3:17	HAND TRIPPED
16	4-Dec-18	BAGALKOT	110	110/33KV,HV3	LOKAPUR_110	12:05	13:25	1:20	HAND TRIPPED
17	4-Dec-18	BAGALKOT	110	110/11KV,HV1	MURDESHWARA_110	7:33	8:07	0:34	LINE CLEAR AVAILED
18	4-Dec-18	BAGALKOT	110	110/11KV,HV1	MURDESHWARA_110	17:44	18:00	0:16	HAND TRIPPED
19	4-Dec-18	BANGALORE	66	HV1	BANGARPET	15:23	16:02	0:38	LINE CLEAR AVAILED
20	4-Dec-18	BANGALORE	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	11:12	11:27	0:14	LINE CLEAR AVAILED
21	4-Dec-18	BANGALORE	66	DALASNUR - SRINIVASPURA	YELDUR	9:35	11:00	1:25	LOAD CURTAILMENT
22	4-Dec-18	BANGALORE	66	HV2	DODDABELAVANGALA	16:02	17:14	1:12	LINE CLEAR AVAILED
23	4-Dec-18	BANGALORE	220	HOSKOTE 220 - BIAL 220	HOSKOTE 220	11:48	12:07	0:18	LINE FAULT
24	4-Dec-18	BANGALORE	220	HOSKOTE 220 - BIAL 220	HOSKOTE 220	12:07	12:25	0:17	LINE FAULT
25	4-Dec-18	BANGALORE	220	HOSKOTE 220 - BIAL 220	HOSKOTE 220	23:30	23:59	0:29	LINE FAULT
26	4-Dec-18	BANGALORE	220	HV1	HOSKOTE 220	11:16	11:27	0:10	TRANSFORMER FAULT
27	4-Dec-18	BANGALORE	220	HV1	HOSKOTE 220	11:38	12:45	1:06	TRANSFORMER FAULT
28	4-Dec-18	BANGALORE	220	HV1	HOSKOTE 220	23:30	23:59	0:29	TRANSFORMER FAULT
29	4-Dec-18	BANGALORE	220	HV2	HOSKOTE 220	11:16	11:29	0:12	TRANSFORMER FAULT
30	4-Dec-18	BANGALORE	220	HV2	HOSKOTE 220	12:24	12:36	0:11	TRANSFORMER FAULT
31	4-Dec-18	BANGALORE	220	HV2	HOSKOTE 220	23:30	23:59	0:29	TRANSFORMER FAULT
32	4-Dec-18	BANGALORE	220	BUS COUPLER	HOSKOTE 220	11:38	12:45	1:06	LINE FAULT
33	4-Dec-18	BANGALORE	220	BUS COUPLER	HOSKOTE 220	23:30	23:59	0:29	LINE FAULT
34	4-Dec-18	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	3:40	3:49	0:09	LINE FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
35	4-Dec-18	BANGALORE	66	HV1	SOMAYAJJANAHALLI	10:42	10:46	0:03	LINE CLEAR AVAILED
36	4-Dec-18	BANGALORE	66	YELAHANKA 220 - LINE 6	SOLADEVANAHALLI	7:00	7:11	0:11	LINE FAULT
37	4-Dec-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	11:16	11:29	0:12	MAIN SUPPLY FAILURE
38	4-Dec-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	11:16	11:29	0:12	MAIN SUPPLY FAILURE
39	4-Dec-18	BANGALORE	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	11:16	11:30	0:13	MAIN SUPPLY FAILURE
40	4-Dec-18	BANGALORE	66	HOSKOTE 220 - SULIBELE	SULIBELE	11:16	11:30	0:13	MAIN SUPPLY FAILURE
41	4-Dec-18	BANGALORE	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	11:16	11:30	0:13	MAIN SUPPLY FAILURE
42	4-Dec-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA	11:38	12:48	1:09	MAIN SUPPLY FAILURE
43	4-Dec-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	11:38	12:49	1:10	MAIN SUPPLY FAILURE
44	4-Dec-18	BANGALORE	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	11:38	12:51	1:12	MAIN SUPPLY FAILURE
45	4-Dec-18	BANGALORE	66	HOSKOTE 220 - SULIBELE	SULIBELE	11:38	12:56	1:17	MAIN SUPPLY FAILURE
46	4-Dec-18	BANGALORE	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	11:38	12:56	1:17	MAIN SUPPLY FAILURE
47	4-Dec-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	23:30	23:59	0:29	MAIN SUPPLY FAILURE
48	4-Dec-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	23:30	23:59	0:29	MAIN SUPPLY FAILURE
49	4-Dec-18	BANGALORE	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	23:30	23:59	0:29	MAIN SUPPLY FAILURE
50	4-Dec-18	BANGALORE	66	HOSKOTE 220 - SULIBELE	SULIBELE	23:30	23:59	0:29	MAIN SUPPLY FAILURE
51	4-Dec-18	BANGALORE	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	23:30	23:59	0:29	MAIN SUPPLY FAILURE
52	4-Dec-18	BANGALORE	66	AUSTIN TOWN - KORAMANGALA	KORAMANGALA	11:38	11:50	0:12	LOAD CHANGE OVER
53	4-Dec-18	BANGALORE	66	AUSTIN TOWN - HSR LAYOUT 220	AUSTIN TOWN	11:38	11:50	0:12	LOAD CHANGE OVER
54	4-Dec-18	BANGALORE	66	BMTc - NIMHANS	BMTc	11:42	11:47	0:04	LOAD CHANGE OVER
55	4-Dec-18	BANGALORE	66	HV1	DEVARABISANAHALLI	14:41	15:03	0:22	HAND TRIPPED
56	4-Dec-18	BANGALORE	66	HV2	DEVARABISANAHALLI	13:41	14:33	0:52	HAND TRIPPED
57	4-Dec-18	BANGALORE	66	HV1	ELECTRONIC CITY PH2 SEC1	11:02	11:37	0:34	LINE CLEAR AVAILED
58	4-Dec-18	BANGALORE	66	HV1	HANUMANTHNAGAR	4:07	4:11	0:04	LINE CLEAR AVAILED
59	4-Dec-18	BANGALORE	66	HV1	HANUMANTHNAGAR	7:41	8:33	0:51	LINE CLEAR AVAILED
60	4-Dec-18	BANGALORE	66	HV1	HANUMANTHNAGAR	11:46	13:08	1:21	LINE CLEAR AVAILED
61	4-Dec-18	BANGALORE	66	HEBBAL 220 - LR BANDE	LR BANDE	15:37	16:15	0:37	LINE FAULT
62	4-Dec-18	BANGALORE	66	HV2	HSR LAYOUT 220	14:10	14:39	0:28	LINE CLEAR AVAILED
63	4-Dec-18	BANGALORE	66	HOODY 220 - HP (EHT)	HP (EHT)	15:56	16:38	0:42	LINE CLEAR AVAILED
64	4-Dec-18	GULBARGA	220	RTPS-SHAHAPUR2	SHAHPUR_220	5:38	6:04	0:26	LINE FAULT
65	4-Dec-18	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	14:25	18:55	4:30	LINE CLEAR AVAILED
66	4-Dec-18	GULBARGA	110	HV2	BETAGERA_110	7:31	7:34	0:03	TRANSFORMER FAULT
67	4-Dec-18	GULBARGA	110	HV1	RAICHUR_220	15:15	15:19	0:04	TRANSFORMER FAULT
68	4-Dec-18	GULBARGA	110	UPNAYAKANAHALLI-MUNIRABAD	UPANAYAKANAHALLI_66	10:00	15:22	5:22	LINE CLEAR AVAILED
69	4-Dec-18	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGRAGOA_110,KAMALANAGAR_110	6:56	7:01	0:05	LINE FAULT
70	4-Dec-18	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	KAMPLI_GLB_110,MUKUNDA_110,BTPS_WATERWORKS	12:02	12:17	0:15	LINE FAULT
71	4-Dec-18	GULBARGA	110	HV1	SIRWAR_110	16:38	17:11	0:33	TRANSFORMER FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
72	4-Dec-18	GULBARGA	110	HV4	YELBURGA_110	8:16	8:32	0:16	TRANSFORMER FAULT
73	4-Dec-18	HASSAN	220	SHHASSAN40-IMOGA1	HASSAN_400	9:50	23:59	14:09	LINE CLEAR AVAILED
74	4-Dec-18	HASSAN	220	HV1	HNPURA_220	9:20	15:27	6:07	LINE CLEAR AVAILED
75	4-Dec-18	HASSAN	220	HV2	HNPURA_220	15:30	19:01	3:31	LINE CLEAR AVAILED
76	4-Dec-18	HASSAN	66	Lv1	HNPURA_220	9:20	15:27	6:07	LINE CLEAR AVAILED
77	4-Dec-18	HASSAN	66	Lv2	HNPURA_220	15:30	19:01	3:31	LINE CLEAR AVAILED
78	4-Dec-18	HASSAN	66	HNPR2-MYSOR1	HNPURA_220	13:22	13:32	0:10	LINE FAULT
79	4-Dec-18	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	9:49	23:59	14:10	LINE CLEAR AVAILED
80	4-Dec-18	HASSAN	110	HV2	GANDASI_110	22:55	23:59	1:04	TRANSFORMER FAULT
81	4-Dec-18	HASSAN	110	HV2	KONAJE_110	10:46	12:57	2:11	LINE CLEAR AVAILED
82	4-Dec-18	HASSAN	110	HV2	SHIKARIPURA_110	10:05	15:36	5:31	LINE CLEAR AVAILED
83	4-Dec-18	HASSAN	66	BHADRA-SHMGA 2	BHADRA_GEN	8:15	23:59	15:44	LINE CLEAR AVAILED
84	4-Dec-18	HASSAN	66	HV2	HIRESAVE_66	12:08	12:12	0:04	HAND TRIPPED
85	4-Dec-18	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	13:38	14:00	0:22	LINE FAULT
86	4-Dec-18	MYSORE	66	HV1	DEVANOORNGUDU_66	11:34	13:55	2:20	LINE CLEAR AVAILED
87	4-Dec-18	MYSORE	66	HV2	DEVANOORNGUDU_66	13:55	16:12	2:16	LINE CLEAR AVAILED
88	4-Dec-18	MYSORE	66	HV1	DUNDANAHALLI_66	13:28	14:34	1:06	LINE CLEAR AVAILED
89	4-Dec-18	MYSORE	66	HV2	DUNDANAHALLI_66	11:21	13:09	1:47	LINE CLEAR AVAILED
90	4-Dec-18	MYSORE	66	HV1	THALAKADU_66	18:17	18:21	0:04	MAIN SUPPLY FAILURE
91	4-Dec-18	MYSORE	66	HV2	THALAKADU_66	18:17	18:21	0:04	MAIN SUPPLY FAILURE
92	4-Dec-18	MYSORE	66	HV1	TARIPURA_66	11:01	11:17	0:15	LINE CLEAR AVAILED
93	4-Dec-18	MYSORE	66	HV1	CHUNCHUNKATTE_66	12:31	12:43	0:12	TRANSFORMER FAULT
94	4-Dec-18	MYSORE	66	HV3	KUSHALANAGARA_66	11:32	12:46	1:14	TRANSFORMER FAULT
95	4-Dec-18	MYSORE	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66 ATTIGULIPURA_66	15:38	16:00	0:21	HAND TRIPPED
96	4-Dec-18	MYSORE	66	MIRLE-HOOTAGALLY	MIRLE_66	14:38	15:42	1:04	LINE CLEAR AVAILED
97	4-Dec-18	MYSORE	66	SINDHUVALLI-KADAKOLA	SINDHUVALLI_66	10:12	16:57	6:44	LINE CLEAR AVAILED
98	4-Dec-18	MYSORE	66	SINDHUVALLI-BEGUR	SINDHUVALLI_66	10:30	17:00	6:30	LINE CLEAR AVAILED
99	4-Dec-18	MYSORE	66	FTS-BANNIMANTAPA	BANNIMANTAP_66	16:20	16:43	0:23	LINE FAULT
100	4-Dec-18	MYSORE	66	HOOTAGALLI-HUNSURU	HOSURGATE_66	21:05	21:09	0:04	LINE FAULT
101	4-Dec-18	MYSORE	66	KADAKOLA-NANJANGUDU 1	NANJANGUDU_66	16:28	16:54	0:25	LINE FAULT
102	4-Dec-18	MYSORE	66	KADAKOLA-NANJANGUDU 1	NANJANGUDU_66	16:55	19:46	2:51	LINE FAULT
103	4-Dec-18	MYSORE	66	KADAKOLA-NANJANGUDU 2	THANDYA_66	16:28	16:55	0:26	LINE FAULT
104	4-Dec-18	MYSORE	66	KADAKOLA-SARAGUR 2	DOORA_66, HURA_66, HULLAHALLI_66	8:15	8:20	0:05	LINE FAULT
105	4-Dec-18	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	BOGADHI MANDYA_66, GUDDENAHALLI_66, G MALLIGERE_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	7:49	7:53	0:04	LINE FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
106	4-Dec-18	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66, ADICHUNCHANAGIRI_66, BGNAGARA_66,HARADANAHALLI(JAK)_ 66, SHIVALLY_66 VADERALLI_66	6:44	6:58	0:14	LINE FAULT
107	4-Dec-18	TUMKUR	220	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	12:02	13:38	1:36	LINE FAULT
108	4-Dec-18	TUMKUR	220	TR-2(HV SIDE)	DAVANGERE_SRS_220	11:14	12:48	1:34	LINE CLEAR AVAILED
109	4-Dec-18	TUMKUR	110	TR-2(HV SIDE)	SAMPIGE_110	13:04	13:10	0:05	TRANSFORMER FAULT
110	4-Dec-18	TUMKUR	66	AMRUTHUR-ANCHEPALYA	AMRUTHUR_66,	17:11	17:17	0:05	HAND TRIPPED
111	4-Dec-18	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	14:33	17:16	2:42	LINE FAULT
112	4-Dec-18	TUMKUR	66	TR-3	AVAREGERE_66	16:47	17:47	1:00	LINE CLEAR AVAILED
113	4-Dec-18	TUMKUR	66	TR-1 & TR2	CHANNAGIRI_66	9:05	16:41	7:36	MAIN SUPPLY FAILURE
114	4-Dec-18	TUMKUR	66	CHANNAGIRI-LNGDHLI	CHANNAGIRI_66	9:05	16:41	7:36	MAIN SUPPLY FAILURE
115	4-Dec-18	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:12	11:24	0:11	HAND TRIPPED
116	4-Dec-18	TUMKUR	66	TR-1(HV SIDE)	DAVANGERE_SRS_220	11:12	11:23	0:11	HAND TRIPPED
117	4-Dec-18	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:28	11:33	0:05	HAND TRIPPED
118	4-Dec-18	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJHALLI_66	11:12	11:24	0:11	HAND TRIPPED
119	4-Dec-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:26	17:43	9:17	LINE FAULT
120	4-Dec-18	TUMKUR	66	DYAVARANAHALLI- CLEAN MAX SOLAR	CLEANMAXSOLAR_IPP_66	22:19	22:59	0:39	LINE FAULT
121	4-Dec-18	TUMKUR	66	TR-2	HONNALI_66	2:18	2:25	0:06	TRANSFORMER FAULT
122	4-Dec-18	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	17:40	21:32	3:51	HAND TRIPPED
123	4-Dec-18	TUMKUR	66	TR-1 & TR2	KORATAGERE_66	11:14	14:00	2:46	LINE CLEAR AVAILED
124	4-Dec-18	TUMKUR	66	KORATAGERE66-MADHUGIRI	KORATAGERE_66	11:13	14:00	2:47	LINE CLEAR AVAILED
125	4-Dec-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:07	13:23	0:16	LINE FAULT
126	4-Dec-18	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:07	13:23	0:16	LINE FAULT
127	4-Dec-18	TUMKUR	66	TR-1	LINGADAHALLI_TMK2_66	21:26	22:23	0:56	MAIN SUPPLY FAILURE
128	4-Dec-18	TUMKUR	66	TR-2	LINGADAHALLI_TMK2_66	21:49	21:53	0:04	HAND TRIPPED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
129	4-Dec-18	TUMKUR	66	LINGADAHALLI- SHYLAPURA	SHYLAPURA_66,YNHOSKOTE_66,MANGALWADA_66	21:16	21:26	0:09	HAND TRIPPED
130	4-Dec-18	TUMKUR	66	TR-1(HV SIDE)	NEELAGUNDA_220	8:01	8:08	0:06	TRANSFORMER FAULT
131	4-Dec-18	TUMKUR	66	TR-1(LV SIDE)	NEELAGUNDA_220	15:13	15:23	0:10	LINE CLEAR AVAILED
132	4-Dec-18	TUMKUR	66	TR-2(LV SIDE)	NEELAGUNDA_220	14:27	15:22	0:54	LINE CLEAR AVAILED
133	4-Dec-18	TUMKUR	66	TR-1	PAVAGADA_66	9:01	9:26	0:24	TRANSFORMER FAULT
134	4-Dec-18	TUMKUR	66	TR-1	PAVAGADA_66	9:44	10:19	0:34	TRANSFORMER FAULT
135	4-Dec-18	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR2_IPP_66	12:02	13:38	1:36	LINE FAULT
136	4-Dec-18	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	8:53	9:31	0:37	LINE FAULT
137	5-Dec-18	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	12:36	13:16	0:40	HAND TRIPPED
138	5-Dec-18	BAGALKOT	220	RAVI URJA 2-ATHANI	ATHANI_220	17:22	18:05	0:43	HAND TRIPPED
139	5-Dec-18	BAGALKOT	220	NARENDRA2-AMBEWADI	AMBEWADI_220	13:59	15:12	1:13	LINE CLEAR AVAILED
140	5-Dec-18	BAGALKOT	110	BIDNAL220-P H COMPOUND	P H COMPOUND_110	10:12	15:47	5:35	LINE CLEAR AVAILED
141	5-Dec-18	BAGALKOT	110	BELGAUM220-ANKALAGI	ANKALAGI_110	11:29	16:00	4:31	HAND TRIPPED
142	5-Dec-18	BAGALKOT	110	110/33KV,HV4	HIDIKAL_110	5:54	6:16	0:22	TRANSFORMER FAULT
143	5-Dec-18	BAGALKOT	110	110/33KV,HV1&2	JAMKHANDI_110	13:46	15:25	1:39	HAND TRIPPED
144	5-Dec-18	BAGALKOT	110	110/11KV,HV3,HV2A	JAMKHANDI_110	13:45	15:25	1:40	HAND TRIPPED
145	5-Dec-18	BAGALKOT	110	110/11KV,HV1	SUVARNA SOUDA_110	16:38	17:10	0:32	LINE CLEAR AVAILED
146	5-Dec-18	BAGALKOT	110	110/11KV,HV2	SUVARNA SOUDA_110	17:12	17:36	0:24	LINE CLEAR AVAILED
147	5-Dec-18	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	12:34	12:36	0:02	TRANSFORMER FAULT
148	5-Dec-18	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	16:27	16:32	0:05	HAND TRIPPED
149	5-Dec-18	BAGALKOT	110	ATHANI 220-SATTI	SATTI_110	0:00	12:14	12:14	HAND TRIPPED
150	5-Dec-18	BAGALKOT	110	220/110KV,LV3	MAHALINGAPUR_220,ITNAL_110,SULTANPUR_110	7:55	8:15	0:20	TRANSFORMER FAULT
151	5-Dec-18	BAGALKOT	110	MAHALINGAPUR 220-HIDIKAL	HIDIKAL_110	8:02	8:19	0:17	LINE FAULT
152	5-Dec-18	BAGALKOT	110	110/11KV,HV1	JAMBAGI_110	11:51	11:56	0:05	TRANSFORMER FAULT
153	5-Dec-18	BAGALKOT	110	110/11KV,HV1	KUDUCHI_220	22:42	22:47	0:05	TRANSFORMER FAULT
154	5-Dec-18	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	13:22	13:30	0:08	LINE FAULT
155	5-Dec-18	BAGALKOT	220	NAGJHARI1-HUBLI	HUBLI_220	10:09	13:22	3:13	HAND TRIPPED
156	5-Dec-18	BAGALKOT	110	HUBLI220-P H COMPOUND	P H COMPOUND_110	9:58	15:46	5:48	HAND TRIPPED
157	5-Dec-18	BAGALKOT	110	HUBLI220-RAMANKOPPA	RAMANKOPPA_110	22:56	23:59	1:03	LINE FAULT
158	5-Dec-18	BANGALORE	220	HOSKOTE 220 - BIAL 220	HOSKOTE 220	0:00	0:05	0:05	LINE FAULT
159	5-Dec-18	BANGALORE	220	BUS COUPLER	HOSKOTE 220	0:00	0:10	0:10	LINE FAULT
160	5-Dec-18	BANGALORE	220	HV1	HOSKOTE 220	0:00	0:15	0:15	TRANSFORMER FAULT
161	5-Dec-18	BANGALORE	220	HV2	HOSKOTE 220	0:00	0:15	0:15	TRANSFORMER FAULT
162	5-Dec-18	BANGALORE	66	HOSKOTE 220 - SULIBELE	SULIBELE	0:00	0:24	0:24	MAIN SUPPLY FAILURE
163	5-Dec-18	BANGALORE	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	0:00	0:28	0:28	MAIN SUPPLY FAILURE
164	5-Dec-18	BANGALORE	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	0:00	0:24	0:24	MAIN SUPPLY FAILURE

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
165	5-Dec-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	0:00	0:28	0:28	MAIN SUPPLY FAILURE
166	5-Dec-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	0:00	0:24	0:24	MAIN SUPPLY FAILURE
167	5-Dec-18	BANGALORE	220	HV1	HOSKOTE 220	0:50	1:45	0:55	TRANSFORMER FAULT
168	5-Dec-18	BANGALORE	220	HV2	HOSKOTE 220	0:50	1:30	0:40	TRANSFORMER FAULT
169	5-Dec-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	0:50	2:00	1:10	MAIN SUPPLY FAILURE
170	5-Dec-18	BANGALORE	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	0:50	2:00	1:10	MAIN SUPPLY FAILURE
171	5-Dec-18	BANGALORE	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	0:00	2:02	2:02	MAIN SUPPLY FAILURE
172	5-Dec-18	BANGALORE	66	HOSKOTE 220 - SULIBELE	SULIBELE	0:00	2:05	2:05	MAIN SUPPLY FAILURE
173	5-Dec-18	BANGALORE	66	HV2	DODDABELAVANGALA	11:51	12:43	0:52	LINE CLEAR AVAIED
174	5-Dec-18	BANGALORE	66	HV2	KEMBODI	11:18	12:02	0:44	LINE CLEAR AVAIED
175	5-Dec-18	BANGALORE	66	YELAHANKA 220 - LINE 3	ATTUR LAYOUT,MANYATHA TECH PARK ,ABBIGERE,ESCORTS	3:15	3:38	0:23	LINE FAULT
176	5-Dec-18	BANGALORE	66	GOWRIBIDANUR - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHPURA	9:41	19:09	9:27	LINE CLEAR AVAIED
177	5-Dec-18	BANGALORE	66	GOWRIBIDANUR - BAGEPALLI 2	BAGEPALLI , VIDHURASHWATHA , GUNDLU KOTTUR	9:41	19:09	9:27	LINE CLEAR AVAIED
178	5-Dec-18	BANGALORE	66	HEBBAL 220 - LR BANDE	LR BANDE	3:36	4:27	0:51	LINE FAULT
179	5-Dec-18	BANGALORE	66	HEBBAL 220 - BANASWADI	BANASWADI	10:45	12:25	1:40	LINE CLEAR AVAIED
180	5-Dec-18	BANGALORE	66	KADUGODI - ARMY WELFARE ORGANIZATION	ARMY WELFARE ORGANIZATION, ALUMBIC GLASS (EHT), KONDASPURA	2:28	3:00	0:32	LINE FAULT
181	5-Dec-18	BANGALORE	66	KADUGODI - EPIP 220	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	9:10	9:35	0:25	LINE FAULT
182	5-Dec-18	BANGALORE	220	HV1	KHODAYS 220	0:37	0:49	0:12	TRANSFORMER FAULT
183	5-Dec-18	BANGALORE	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	0:37	0:54	0:17	MAIN SUPPLY FAILURE
184	5-Dec-18	BANGALORE	66	KHODAYS 220 - ELITA PROMENEDE	ELITA PROMENEDE	0:37	0:56	0:19	MAIN SUPPLY FAILURE
185	5-Dec-18	BANGALORE	66	PADMANABHANAGAR - SUBRAMANYAPURA 220	PADMANABHANAGAR	7:39	7:45	0:06	LOAD CHANGE OVER
186	5-Dec-18	BANGALORE	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	14:55	15:00	0:05	LOAD CHANGE OVER
187	5-Dec-18	BANGALORE	66	SRS PEENYA 220 - DG2	ALUR, NELAMANGALA 66	4:27	4:56	0:29	LINE FAULT
188	5-Dec-18	BANGALORE	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	7:00	7:45	0:45	MAIN SUPPLY FAILURE
189	5-Dec-18	BANGALORE	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	8:43	8:48	0:05	LOAD CHANGE OVER
190	5-Dec-18	BANGALORE	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	SUBRAMANYAPURA 66	7:00	7:30	0:30	LINE FAULT
191	5-Dec-18	BANGALORE	66	T K HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	2:01	2:14	0:13	LINE FAULT
192	5-Dec-18	GULBARGA	220	HV1	LINGASUGUR_220	5:20	5:30	0:10	TRANSFORMER FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
193	5-Dec-18	GULBARGA	220	HV2	LINGASUGUR_220	5:20	5:45	0:25	TRANSFORMER FAULT
194	5-Dec-18	GULBARGA	220	LINGAPUR-GADAG2	AARESS_STEELS,HRG_STEELS	10:18	16:00	5:42	LINE CLEAR AVAILED
195	5-Dec-18	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	9:44	23:59	14:15	LINE CLEAR AVAILED
196	5-Dec-18	GULBARGA	110	ALIPUR-MUNIRABAD	KUDITINI_110,TORANGALLU_110,KURU GOD_110,AGARWAL_IPP,SHATAVAHAN A_IPP,SUZLON_IPP,KAMALAPUR_110,M ETRI_110,RBNS_FACTORY	5:23	5:38	0:15	LINE FAULT
197	5-Dec-18	GULBARGA	110	HV3	KUSTAGI_220	10:48	14:01	3:13	LINE CLEAR AVAILED
198	5-Dec-18	GULBARGA	110	RAJESHWAR-WARDHASLR	RAJESHWAR_110	17:16	17:49	0:33	LINE CLEAR AVAILED
199	5-Dec-18	GULBARGA	110	KOLHAR-NSSK	KOLHAR_110	18:40	18:47	0:07	LINE FAULT
200	5-Dec-18	GULBARGA	66	KOTTUR-BENNEHALLI	KOTTUR_66,UJJANI_66	10:40	13:58	3:18	LINE CLEAR AVAILED
201	5-Dec-18	HASSAN	400	HUPCL-ASSAN1	UPCL_GEN	0:00	19:08	19:08	LINE CLEAR AVAILED
202	5-Dec-18	HASSAN	220	ARSK2-SHMG	ARSKERE_220	10:50	14:12	3:22	LINE CLEAR AVAILED
203	5-Dec-18	HASSAN	220	MRSSHM-HASSAN	MRSMG_220	10:51	13:58	3:07	LINE CLEAR AVAILED
204	5-Dec-18	HASSAN	220	VARAHI-KEMAR2	VARAHI_GEN	8:58	23:59	15:01	LINE CLEAR AVAILED
205	5-Dec-18	HASSAN	110	HV3	BANTWALA_110	5:25	21:11	15:46	LINE CLEAR AVAILED
206	5-Dec-18	HASSAN	110	HV2	GANDASI_110	0:00	13:21	13:21	TRANSFORMER FAULT
207	5-Dec-18	HASSAN	110	HOSNGDI-VTRG2	HOSNGADI_110	9:31	12:08	2:37	LINE CLEAR AVAILED
208	5-Dec-18	HASSAN	66	HV2	KIADB_66	10:55	12:44	1:49	LINE CLEAR AVAILED
209	5-Dec-18	MYSORE	66	HV1	BGNAGARA_66	10:59	11:33	0:34	LINE CLEAR AVAILED
210	5-Dec-18	MYSORE	66	HV2	FTS_66	6:11	14:12	8:01	LINE CLEAR AVAILED
211	5-Dec-18	MYSORE	66	HV1	HOOTAGALLY_220	15:43	15:47	0:04	HAND TRIPPED
212	5-Dec-18	MYSORE	66	HV2	HOOTAGALLY_220	15:43	15:47	0:04	HAND TRIPPED
213	5-Dec-18	MYSORE	66	HV1	MEGALAPURA_66	9:34	18:17	8:43	LINE CLEAR AVAILED
214	5-Dec-18	MYSORE	66	HV2	MEGALAPURA_66	9:33	18:20	8:46	LINE CLEAR AVAILED
215	5-Dec-18	MYSORE	66	HV2	PANDAVAPURA_66	11:03	11:44	0:41	LINE CLEAR AVAILED
216	5-Dec-18	MYSORE	66	HV2	PANDAVAPURA_66	11:46	11:49	0:03	HAND TRIPPED
217	5-Dec-18	MYSORE	66	BANNIMANTAP-VIJAYANAGAR	VIJAYANAGRAMYS_66	10:12	15:39	5:27	NBFC
218	5-Dec-18	MYSORE	66	ELAVALA-HOOTAGALLI	ELAVALA_66 GAVADAGERE_66	10:31	17:42	7:11	LINE CLEAR AVAILED
219	5-Dec-18	MYSORE	66	ELAVALA-HUNSUR	ELAVALA_66 GAVADAGERE_66	10:16	17:48	7:32	LINE CLEAR AVAILED
220	5-Dec-18	MYSORE	66	HOOTAGALLI-HUNSUR	HUNSUR_66 HOSURGATE_66	15:42	15:48	0:06	HAND TRIPPED
221	5-Dec-18	MYSORE	66	HOOTAGALLI-KHB	KHBCOLONY_66 DMG_HALLI_66	15:41	15:50	0:08	HAND TRIPPED
222	5-Dec-18	MYSORE	66	SANTHE SARGUR-KADAKOLA 1	JAIPUR_66,HAMPAPURA(K)_66, ANTHARSANTHE_66 HDKOTE_66	18:14	18:21	0:07	LINE FAULT
223	5-Dec-18	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	23:22	23:40	0:18	TRANSFORMER FAULT
224	5-Dec-18	TUMKUR	110	TR-1	SHETYKERE_110	10:19	11:47	1:28	LINE CLEAR AVAILED
225	5-Dec-18	TUMKUR	66	THALLAK 220kv- NAYAKNHATTY1	NAYAKANAHATTI_66,HIREMALLANAHO LE_66	10:19	17:16	6:57	LINE CLEAR AVAILED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
226	5-Dec-18	TUMKUR	66	TR-1	BAGUR_TMK_66	8:57	9:08	0:11	TRANSFORMER FAULT
227	5-Dec-18	TUMKUR	66	TR-1	BAGUR_TMK_66	18:31	18:52	0:21	LINE CLEAR AVAILED
228	5-Dec-18	TUMKUR	66	TR-2	BAGUR_TMK_66	15:47	16:20	0:32	TRANSFORMER FAULT
229	5-Dec-18	TUMKUR	66	TR-2	BENNEHALLI_66	10:30	17:30	7:00	LINE CLEAR AVAILED
230	5-Dec-18	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	13:04	13:17	0:12	LINE FAULT
231	5-Dec-18	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	13:56	15:31	1:35	LINE CLEAR AVAILED
232	5-Dec-18	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:57	13:50	1:53	LINE CLEAR AVAILED
233	5-Dec-18	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	16:04	16:12	0:07	LINE FAULT
234	5-Dec-18	TUMKUR	66	DYAVARANAHALLI- CLEAN MAX SOLAR	CLEANMAXSOLAR_IPP_66	10:18	10:30	0:12	HAND TRIPPED
235	5-Dec-18	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	14:12	15:11	0:59	LINE CLEAR AVAILED
236	5-Dec-18	TUMKUR	66	TR-1	HANAGAL_66	13:47	14:22	0:35	LINE CLEAR AVAILED
237	5-Dec-18	TUMKUR	66	HARIHARA-DAVANGERE_HARIH	HARIHAR_66	12:04	13:43	1:39	MAIN SUPPLY FAILURE
238	5-Dec-18	TUMKUR	66	TR-2	HIREMALLANAHOLE_66	17:44	18:12	0:27	MAIN SUPPLY FAILURE
239	5-Dec-18	TUMKUR	66	TR-2	HONNALI_66	1:42	2:24	0:41	TRANSFORMER FAULT
240	5-Dec-18	TUMKUR	66	TR-2	HONNALI_66	18:16	18:25	0:08	TRANSFORMER FAULT
241	5-Dec-18	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS1_EHT_66	8:57	9:03	0:05	LINE FAULT
242	5-Dec-18	TUMKUR	66	MATHOD66-ENERCON 1	ENERCON1_IPP_66	18:14	18:26	0:12	LINE FAULT
243	5-Dec-18	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	HIREMALLANAHOLE_66	17:27	17:38	0:11	LINE CLEAR AVAILED
244	5-Dec-18	TUMKUR	66	TR-2	SHYLAPURA_66	11:12	11:17	0:04	TRANSFORMER FAULT
245	5-Dec-18	TUMKUR	66	TR-2	TAVAREKERE(H)_66	12:58	14:09	1:10	LINE CLEAR AVAILED
246	6-Dec-18	BAGALKOT	220	NARENDRA1-AMBEWADI	AMBEWADI_220	9:58	18:56	8:58	LINE FAULT
247	6-Dec-18	BAGALKOT	220	NARENDRA2-AMBEWADI	AMBEWADI_220	11:27	18:56	7:29	LINE CLEAR AVAILED
248	6-Dec-18	BAGALKOT	110	AMBEWADI220-HALIYAL	HALIYAL_110	11:49	19:09	7:20	LINE CLEAR AVAILED
249	6-Dec-18	BAGALKOT	110	AMBEWADI220-KAVALWADA	KAVALWADA_110	11:49	19:09	7:20	LINE CLEAR AVAILED
250	6-Dec-18	BAGALKOT	110	SUPA1-AMBEWADI	AMBEWADI_220	14:52	15:35	0:43	LINE FAULT
251	6-Dec-18	BAGALKOT	110	BAGEWADI220-MUDDEBIIHAL	MUDDEBIIHAL_110	22:18	22:42	0:24	LINE FAULT
252	6-Dec-18	BAGALKOT	110	110/33KV,HV3	KIADB BIJAPUR_110	12:45	13:25	0:40	HAND TRIPPED
253	6-Dec-18	BAGALKOT	110	110/11KV,HV1	GADAG ROAD_110	13:19	13:33	0:14	HAND TRIPPED
254	6-Dec-18	BAGALKOT	110	110/33KV,HV3	GOPPANKOPPA_110	14:18	14:35	0:17	HAND TRIPPED
255	6-Dec-18	BAGALKOT	110	KERUR-BADAMI	BADAMI_110	11:29	14:29	3:00	LINE CLEAR AVAILED
256	6-Dec-18	BAGALKOT	110	KERUR-BADAMI	BADAMI_110	14:30	23:59	9:29	HAND TRIPPED
257	6-Dec-18	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	11:38	23:59	12:21	LINE CLEAR AVAILED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
258	6-Dec-18	BAGALKOT	110	BAGALKOT220-KERUR	KERUR_110	11:38	13:18	1:40	LINE CLEAR AVAILED
259	6-Dec-18	BAGALKOT	110	BAGALKOT220-KERUR	KERUR_110	14:25	14:28	0:03	HAND TRIPPED
260	6-Dec-18	BAGALKOT	110	BALAJI SUGARS-MUDDEBIIHAL	MUDDEBIIHAL_110	22:45	22:46	0:01	MAIN SUPPLY FAILURE
261	6-Dec-18	BAGALKOT	110	KNM SOLAR-MUDDEBIIHAL	MUDDEBIIHAL_110	22:45	22:47	0:02	MAIN SUPPLY FAILURE
262	6-Dec-18	BAGALKOT	110	110/11KV,HV1	MURDESHWARA_110	10:31	10:46	0:15	HAND TRIPPED
263	6-Dec-18	BAGALKOT	110	110/11KV,HV1	JAMBAGI_110	18:38	19:19	0:41	HAND TRIPPED
264	6-Dec-18	BAGALKOT	110	110/11KV, HV2	UGARKHUD_110	3:23	3:29	0:06	TRANSFORMER FAULT
265	6-Dec-18	BAGALKOT	110	NAVANAGAR(H)-TARIHAL	TARIHAL_110	10:13	23:59	13:46	LINE CLEAR AVAILED
266	6-Dec-18	BAGALKOT	110	SUVARNA SOUDA-MACHE	MACHE_110	17:28	23:59	6:31	HAND TRIPPED
267	6-Dec-18	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	11:50	11:53	0:03	HAND TRIPPED
268	6-Dec-18	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	19:04	19:10	0:06	HAND TRIPPED
269	6-Dec-18	BAGALKOT	110	SAVANUR-SHIGGOAN	SHIGGOAN_110	11:24	15:50	4:26	LINE CLEAR AVAILED
270	6-Dec-18	BAGALKOT	110	110/33KV, HV2	SAVANUR_110	15:54	16:00	0:06	HAND TRIPPED
271	6-Dec-18	BAGALKOT	110	110/11KV, HV1	NAVANAGAR(H)_110	10:07	17:13	7:06	LINE CLEAR AVAILED
272	6-Dec-18	BAGALKOT	110	DHARWADBIO-NAVALGUND	NAVALGUND_110	16:26	16:32	0:06	LINE CLEAR AVAILED
273	6-Dec-18	BAGALKOT	66	66/33KV, HV4	HARIHAR HOSPET_66	7:22	8:01	0:39	LOAD CURTAILMENT
274	6-Dec-18	BAGALKOT	66	BANUVALLY-HARIHARI HOSPET	HARIHAR HOSPET_66	22:23	23:59	1:36	LINE FAULT
275	6-Dec-18	BAGALKOT	110	BIDNAL1&2-HUBLI	HUBLI_220	9:13	14:41	5:28	LINE CLEAR AVAILED
276	6-Dec-18	BAGALKOT	110	110/11KV, HV4	HUBLI_220	15:06	17:09	2:03	LINE CLEAR AVAILED
277	6-Dec-18	BAGALKOT	110	110/11KV, HV3	HUBLI_220	17:16	17:18	0:02	HAND TRIPPED
278	6-Dec-18	BAGALKOT	110	HUBLI220-RAMANKOPPA	RAMANKOPPA_110	0:00	10:47	10:47	LINE CLEAR AVAILED
279	6-Dec-18	BAGALKOT	220	220/110KV, HV3&LV3	HUBLI_220	15:58	17:52	1:54	LINE CLEAR AVAILED
280	6-Dec-18	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	12:08	12:54	0:46	LINE FAULT
281	6-Dec-18	BAGALKOT	220	NAGJHARI1-HUBLI	HUBLI_220	12:08	12:52	0:44	LINE FAULT
282	6-Dec-18	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	17:14	23:59	6:45	LINE FAULT
283	6-Dec-18	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	15:52	16:03	0:11	LINE FAULT
284	6-Dec-18	BANGALORE	66	HV2	CHIKKABALLAPURA URBAN	12:15	12:20	0:05	LOAD CHANGE OVER
285	6-Dec-18	BANGALORE	66	HV2	DODDABELAVANGALA	11:53	12:21	0:28	LINE CLEAR AVAILED
286	6-Dec-18	BANGALORE	66	HV3	KGF	12:13	15:08	2:55	LINE CLEAR AVAILED
287	6-Dec-18	BANGALORE	66	HV1	KGF	11:02	15:08	4:06	LINE CLEAR AVAILED
288	6-Dec-18	BANGALORE	66	HV2	KGF	12:24	14:37	2:13	LINE CLEAR AVAILED
289	6-Dec-18	BANGALORE	66	KGF-MALUR 1	KGF	12:25	14:40	2:15	LINE CLEAR AVAILED
290	6-Dec-18	BANGALORE	66	KGF - KAMASAMUDRA	KAMASAMUDRA	12:25	14:40	2:15	LINE CLEAR AVAILED
291	6-Dec-18	BANGALORE	66	HV3	NELAMANGALA 66	9:43	16:54	7:11	LINE CLEAR AVAILED
292	6-Dec-18	BANGALORE	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	12:15	13:51	1:35	LINE CLEAR AVAILED
293	6-Dec-18	BANGALORE	66	HEBBAL 220 - IISC	IISC	13:35	14:13	0:38	LINE CLEAR AVAILED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
294	6-Dec-18	BANGALORE	66	KADUGODI - ARMY WELFARE ORGANIZATION	ARMY WELFARE ORGANIZATION, ALUMBIC GLASS (EHT), KONDASPURA	13:35	15:05	1:30	LINE CLEAR AVAILED
295	6-Dec-18	GULBARGA	220	KUSTAGI-SUZLON1,2	KUSTAGI_220	10:35	18:30	7:55	LINE CLEAR AVAILED
296	6-Dec-18	GULBARGA	220	RTPS-SEDAM2	SEDAM_220	13:15	17:40	4:25	NBFC
297	6-Dec-18	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	0:00	18:05	18:05	LINE CLEAR AVAILED
298	6-Dec-18	GULBARGA	220	SEDAM-ORIENT CEMENTS	SEDAM_220	7:08	17:25	10:17	LINE CLEAR AVAILED
299	6-Dec-18	GULBARGA	110	HV2	HATTI_110	7:20	7:28	0:08	LOAD CURTAILMENT
300	6-Dec-18	GULBARGA	110	HV1	HANUMASAGAR_110	7:22	7:52	0:30	LOAD CURTAILMENT
301	6-Dec-18	GULBARGA	110	RAICHUR220-SINDHANOOR1	ALKOD_110,SIRWAR_110,BYAGAWAT_110,VALKAMDINNI_110	1:20	1:25	0:05	LINE FAULT
302	6-Dec-18	GULBARGA	110	RAICHUR220-SINDHANOOR1	ALKOD_110,SIRWAR_110,BYAGAWAT_110,VALKAMDINNI_110	6:35	6:40	0:05	LINE FAULT
303	6-Dec-18	GULBARGA	110	RAICHUR220-SINDHANOOR1	ALKOD_110,SIRWAR_110,BYAGAWAT_110,VALKAMDINNI_110	12:49	15:45	2:56	LINE CLEAR AVAILED
304	6-Dec-18	GULBARGA	110	HV1	RAJESHWAR_110	7:27	8:26	0:59	LOAD CURTAILMENT
305	6-Dec-18	GULBARGA	110	HV2	RAJESHWAR_110	7:27	7:45	0:18	LOAD CURTAILMENT
306	6-Dec-18	GULBARGA	110	HV1	SIRWAR_110	7:21	7:33	0:12	LOAD CURTAILMENT
307	6-Dec-18	GULBARGA	110	HV1	TEKKALAKOTE_110	7:21	7:32	0:11	TRANSFORMER FAULT
308	6-Dec-18	GULBARGA	110	HV1	WADAGERA_110	11:45	15:14	3:29	LINE CLEAR AVAILED
309	6-Dec-18	GULBARGA	110	KOLHAR-NSSK	JANAWADA_110	5:27	5:35	0:08	LINE FAULT
310	6-Dec-18	GULBARGA	110	HV2	KOLHAR_110	7:27	7:40	0:13	LOAD CURTAILMENT
311	6-Dec-18	GULBARGA	110	HV1	KAVITAL_110	7:19	7:23	0:04	TRANSFORMER FAULT
312	6-Dec-18	GULBARGA	110	HV2	YADGIR_110	7:19	7:25	0:06	LOAD CURTAILMENT
313	6-Dec-18	GULBARGA	110	HV4,HV3	YELBURGA_110	7:20	7:44	0:24	LOAD CURTAILMENT
314	6-Dec-18	GULBARGA	110	HATTI-GAMESHA	HATTI_110	9:41	18:40	8:59	LINE CLEAR AVAILED
315	6-Dec-18	GULBARGA	110	HV1	KUSTAGI_220	7:19	7:35	0:16	TRANSFORMER FAULT
316	6-Dec-18	GULBARGA	110	HV2	KUSTAGI_220	7:19	7:35	0:16	LINE CLEAR AVAILED
317	6-Dec-18	GULBARGA	110	HV4	KUSTAGI_220	7:19	7:35	0:16	LINE CLEAR AVAILED
318	6-Dec-18	GULBARGA	110	KUSTAGI-KANAKAGIRI	KANAKAGIRI_110,GANADAL_110	8:10	18:00	9:50	LINE CLEAR AVAILED
319	6-Dec-18	GULBARGA	66	KOTTUR-BENNEHALLI	KOTTUR_66,UJJANI_66	11:12	11:16	0:04	LINE CLEAR AVAILED
320	6-Dec-18	MYSORE	66	HV1	BASARALU_66	9:20	15:46	6:26	LINE CLEAR AVAILED
321	6-Dec-18	MYSORE	66	HV2	BASARALU_66	9:20	17:55	8:35	LINE CLEAR AVAILED
322	6-Dec-18	MYSORE	66	HV2	BOOKANAKERE_66	7:52	8:06	0:13	LOAD CURTAILMENT
323	6-Dec-18	MYSORE	66	HV1	HANNUR_66	11:44	14:19	2:35	LINE CLEAR AVAILED
324	6-Dec-18	MYSORE	66	HV1	KOPPA_66	13:18	15:00	1:41	LINE CLEAR AVAILED
325	6-Dec-18	MYSORE	66	HV2	KOPPA_66	11:50	13:20	1:30	LINE CLEAR AVAILED
326	6-Dec-18	MYSORE	66	KR NAGARA-BILIKERE	BILIKERE_66 GVGUDI_66	10:39	17:44	7:05	LINE CLEAR AVAILED
327	6-Dec-18	MYSORE	66	HV3	KUSHALANAGARA_66	12:01	14:20	2:19	LINE CLEAR AVAILED
328	6-Dec-18	MYSORE	66	HV3	KUSHALANAGARA_66	14:22	14:48	0:26	TRANSFORMER FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
329	6-Dec-18	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	7:15	7:19	0:04	LINE FAULT
330	6-Dec-18	MYSORE	66	HV1	YELANDUR_66	7:52	7:55	0:02	LOAD CURTAILMENT
331	6-Dec-18	MYSORE	66	KHB-HOOTAGALLY	KHBCOLONY_66 DMG_HALLI_66	10:00	18:00	8:00	LINE CLEAR AVAILED
332	6-Dec-18	TUMKUR	66	TR-2	AVAREGERE_66	5:13	8:37	3:23	TRANSFORMER FAULT
333	6-Dec-18	TUMKUR	66	TR-2	AVAREGERE_66	14:48	16:53	2:05	LINE CLEAR AVAILED
334	6-Dec-18	TUMKUR	66	TR-1	BAGUR_TMK_66	7:24	7:29	0:05	TRANSFORMER FAULT
335	6-Dec-18	TUMKUR	66	TR-1	BAGUR_TMK_66	14:12	15:16	1:04	LINE CLEAR AVAILED
336	6-Dec-18	TUMKUR	66	TR-1 & TR2	CHANNAGIRI_66	9:09	16:42	7:32	MAIN SUPPLY FAILURE
337	6-Dec-18	TUMKUR	66	CHANNAGIRI-LNGDHLLI	CHANNAGIRI_66	9:09	16:42	7:32	MAIN SUPPLY FAILURE
338	6-Dec-18	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	13:36	13:50	0:14	LINE FAULT
339	6-Dec-18	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:33	12:43	0:09	LINE FAULT
340	6-Dec-18	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	14:13	14:25	0:12	LINE FAULT
341	6-Dec-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:44	17:46	9:02	HAND TRIPPED
342	6-Dec-18	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	6:22	6:29	0:06	LINE FAULT
343	6-Dec-18	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	13:12	13:46	0:33	MAIN SUPPLY FAILURE
344	6-Dec-18	TUMKUR	66	TR-2	HONNALLI_66	18:08	18:21	0:13	TRANSFORMER FAULT
345	6-Dec-18	TUMKUR	66	TR-2	HONNALLI_66	22:16	22:22	0:05	TRANSFORMER FAULT
346	6-Dec-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	9:07	16:22	7:14	LINE CLEAR AVAILED
347	6-Dec-18	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	13:05	15:23	2:17	LINE CLEAR AVAILED
348	6-Dec-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	17:17	17:23	0:05	LINE FAULT
349	6-Dec-18	TUMKUR	66	TR-1	NAGASAMUDRA_66	6:34	6:42	0:07	TRANSFORMER FAULT
350	6-Dec-18	TUMKUR	66	TR-1	NAGASAMUDRA_66	8:44	8:54	0:10	TRANSFORMER FAULT
351	6-Dec-18	TUMKUR	66	TR-1(LV SIDE)	NEELAGUNDA_220	17:20	17:27	0:06	LINE CLEAR AVAILED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
352	6-Dec-18	TUMKUR	66	TR-1	RANGENAHALLI_66	17:53	18:26	0:33	LINE CLEAR AVAILED
353	6-Dec-18	TUMKUR	66	TR-1 & TR2	TAVAREKERE(C)_66	11:27	16:45	5:18	LINE CLEAR AVAILED
354	7-Dec-18	BAGALKOT	220	NAGJHARI 2-BIDNAL	BIDNAL_220	12:51	15:07	2:16	HAND TRIPPED
355	7-Dec-18	BAGALKOT	110	GHATAPRABHA 220-SHIRAGOAN	SHIRAGOAN_110	6:50	6:59	0:09	LINE FAULT
356	7-Dec-18	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	8:48	9:04	0:16	TRANSFORMER FAULT
357	7-Dec-18	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	HIDIKAL_110	6:56	8:19	1:23	LINE FAULT
358	7-Dec-18	BAGALKOT	110	110/11KV,HV1	JAMBAGI_110	12:02	13:02	1:00	HAND TRIPPED
359	7-Dec-18	BAGALKOT	110	JAMBAGI-MUDHOL	MUDHOL_110	13:13	13:21	0:08	LINE FAULT
360	7-Dec-18	BAGALKOT	110	JAMBAGI-MUDHOL	MUDHOL_110	13:21	13:23	0:02	LINE FAULT
361	7-Dec-18	BAGALKOT	110	KERUR-BADAMI	BADAMI_110	0:00	12:35	12:35	HAND TRIPPED
362	7-Dec-18	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	11:12	13:14	2:02	LINE FAULT
363	7-Dec-18	BAGALKOT	220	220/110KV, HV3&LV3	HUBLI_220	12:08	16:46	4:38	LINE CLEAR AVAILED
364	7-Dec-18	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	0:00	16:40	16:40	LINE CLEAR AVAILED
365	7-Dec-18	BAGALKOT	66	BANUVALLY-HARIHAR HOSPET	HARIHAR HOSPET_66	0:00	12:14	12:14	LINE CLEAR AVAILED
366	7-Dec-18	BAGALKOT	110	SOUDATTI220-RAMDURGA	RAMDURGA_110	14:52	17:45	2:53	LINE CLEAR AVAILED
367	7-Dec-18	BAGALKOT	110	SOUDATTI220-SOUDATTI1	SOUDATTI_110	15:28	17:47	2:19	LINE CLEAR AVAILED
368	7-Dec-18	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	12:15	12:46	0:31	TRANSFORMER FAULT
369	7-Dec-18	BAGALKOT	220	HUBLI2-NARENDRA	NARENDRA_220	11:12	11:29	0:17	LINE FAULT
370	7-Dec-18	BAGALKOT	220	NARENDRA-BELGAUM1	BELGAUM_220	12:40	15:31	2:51	LINE CLEAR AVAILED
371	7-Dec-18	BANGALORE	66	HV1	AKKURMOLE	16:25	17:35	1:10	LINE CLEAR AVAILED
372	7-Dec-18	BANGALORE	66	BAGEPALLI - GOWRIBIDANUR 1	PATHPALYA, THIMAMPALLI, SOMANATHAPURA	21:20	21:30	0:10	LINE FAULT
373	7-Dec-18	BANGALORE	66	HV2	CHIKKABALLAPURA URBAN	10:59	11:11	0:12	TRANSFORMER FAULT
374	7-Dec-18	BANGALORE	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	9:44	9:47	0:03	LOAD CHANGE OVER
375	7-Dec-18	BANGALORE	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	14:35	14:38	0:03	LOAD CHANGE OVER
376	7-Dec-18	BANGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	11:05	11:11	0:06	LOAD CHANGE OVER
377	7-Dec-18	BANGALORE	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	12:16	12:29	0:13	LINE FAULT
378	7-Dec-18	BANGALORE	66	HV1	KEMBODI	10:25	10:37	0:12	LINE CLEAR AVAILED
379	7-Dec-18	BANGALORE	66	HV2	KEMBODI	10:36	10:44	0:08	LINE CLEAR AVAILED
380	7-Dec-18	BANGALORE	66	MELUR - SIDLAGHATTA	MELUR	10:10	10:15	0:05	LOAD CHANGE OVER
381	7-Dec-18	BANGALORE	66	MELUR - VIJAYAPURA	MELUR	14:40	14:50	0:10	LOAD CHANGE OVER
382	7-Dec-18	BANGALORE	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	12:29	12:40	0:10	LOAD CHANGE OVER
383	7-Dec-18	BANGALORE	66	RMV - HEBBAL 220	RMV	13:04	13:35	0:30	LOAD CHANGE OVER
384	7-Dec-18	BANGALORE	66	RMV - TATA INSTITUTE (EHT)	TATA INSTITUTE (EHT)	13:26	13:30	0:04	LINE CLEAR AVAILED
385	7-Dec-18	BANGALORE	66	HV1	AMARIYOTHI	14:00	15:16	1:15	LINE CLEAR AVAILED
386	7-Dec-18	BANGALORE	66	AUSTIN TOWN - HSR LAYOUT 220	AUSTIN TOWN	17:15	17:20	0:05	LOAD CHANGE OVER
387	7-Dec-18	BANGALORE	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	15:46	15:51	0:05	LINE CLEAR AVAILED
388	7-Dec-18	BANGALORE	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	13:10	13:20	0:10	LOAD CHANGE OVER
389	7-Dec-18	BANGALORE	66	BOODIGERE - HOSKOTE 220	BOODIGERE	13:21	13:30	0:09	LOAD CHANGE OVER

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
390	7-Dec-18	BANGALORE	66	HV1	ISRO LAYOUT	17:16	17:30	0:13	TRANSFORMER FAULT
391	7-Dec-18	BANGALORE	66	HV2	NGEF	11:26	12:13	0:47	TRANSFORMER FAULT
392	7-Dec-18	BANGALORE	66	NIMHANS 220 - JAYANAGARA	JAYANAGARA	14:03	14:06	0:03	LINE FAULT
393	7-Dec-18	BANGALORE	66	RBI - ELITE PROMENEDE	RBI	14:40	14:45	0:05	LOAD CHANGE OVER
394	7-Dec-18	BANGALORE	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BOMMASANDRA I/A, BIOCON (EHT)	4:53	9:47	4:54	LINE FAULT
395	7-Dec-18	BANGALORE	220	HV2	YARANDANAHALLI 220	4:53	5:15	0:22	TRANSFORMER FAULT
396	7-Dec-18	BANGALORE	66	HV2	YARANDANAHALLI 220	17:35	17:40	0:05	LOAD CHANGE OVER
397	7-Dec-18	BANGALORE	66	HV2	ATTUR YELAHANKA	11:44	14:51	3:07	LINE CLEAR AVAILED
398	7-Dec-18	BANGALORE	66	HV2	YEDUMADU	10:35	10:50	0:15	LINE CLEAR AVAILED
399	7-Dec-18	GULBARGA	110	BETAGERA-KESHAVCEMENTS_SOLAR	BETAGERA_110	6:16	7:02	0:46	LINE FAULT
400	7-Dec-18	GULBARGA	110	BHALKI-BKLISUGAR_IPP	BHALKI_110	12:23	12:29	0:06	LINE CLEAR AVAILED
401	7-Dec-18	GULBARGA	110	BHALKI-HALBURGA	BHALKI_110,LADHA_110	6:25	6:35	0:10	LINE FAULT
402	7-Dec-18	GULBARGA	110	BHALKI-MGSSK_IPP	BHALKI_110	12:30	12:35	0:05	LINE CLEAR AVAILED
403	7-Dec-18	GULBARGA	110	BHALKI-LADHA	LADHA_110	12:30	12:36	0:06	LINE CLEAR AVAILED
404	7-Dec-18	GULBARGA	110	KOLHAR-JANAWADA	JANAWADA_110	5:59	6:09	0:10	LINE FAULT
405	7-Dec-18	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	6:19	6:53	0:34	LINE FAULT
406	7-Dec-18	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110,DONGRAGOA_110,KA MALANAGAR_110	6:23	6:36	0:13	LINE FAULT
407	7-Dec-18	GULBARGA	110	HV2	SRERAMANAGAR_110	9:50	9:59	0:09	TRANSFORMER FAULT
408	7-Dec-18	GULBARGA	110	MALLT-BYGWT-2(IDLE LINE)	MADALAPURA_110,MANVI_110	6:00	8:34	2:34	LINE FAULT
409	7-Dec-18	GULBARGA	110	MALLT-SIRWAR	SIRWAR_110	14:10	14:18	0:08	LINE FAULT
410	7-Dec-18	GULBARGA	110	HATTI-GMSH	HATTI_110	10:08	18:48	8:40	LINE CLEAR AVAILED
411	7-Dec-18	GULBARGA	110	HATTI-GMSH	HATTI_110	18:57	19:03	0:06	LINE CLEAR AVAILED
412	7-Dec-18	GULBARGA	66	ITTAGI-HBHALLI	HAGARIBOMMANAHALLI_66	9:41	14:06	4:25	LINE CLEAR AVAILED
413	7-Dec-18	GULBARGA	66	ITTAGGI-HBHALLI	HAGARIBOMMANAHALLI_66	9:50	14:06	4:16	LINE CLEAR AVAILED
414	7-Dec-18	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:25	23:59	0:34	HAND TRIPPED
415	7-Dec-18	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	10:33	11:43	1:10	LINE CLEAR AVAILED
416	7-Dec-18	HASSAN	110	HV1	BIRUR_110	7:13	7:21	0:08	TRANSFORMER FAULT
417	7-Dec-18	HASSAN	110	MOODAB-GURUPURA	MOODABidre_110	10:32	12:59	2:27	LINE CLEAR AVAILED
418	7-Dec-18	HASSAN	66	HAGARE-HASSAN	HAGARE_66	22:46	23:59	1:13	LOAD CURTAILMENT
419	7-Dec-18	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	9:30	9:38	0:08	LINE FAULT
420	7-Dec-18	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	9:20	9:46	0:26	LOAD CURTAILMENT
421	7-Dec-18	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	11:11	12:19	1:08	LINE CLEAR AVAILED
422	7-Dec-18	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	21:48	22:02	0:14	HAND TRIPPED
423	7-Dec-18	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	22:28	22:42	0:14	LINE FAULT
424	7-Dec-18	MYSORE	66	HV1	CHUNCHUNKATTE_66	13:57	14:01	0:04	HAND TRIPPED
425	7-Dec-18	MYSORE	66	HV1	CHUNCHUNKATTE_66	14:45	17:50	3:05	LINE CLEAR AVAILED
426	7-Dec-18	MYSORE	66	CR NAGARA - KABBALLI	HARVEY_66	3:35	3:42	0:06	LINE FAULT
427	7-Dec-18	MYSORE	66	HV1	HULLAHALLI_66	11:57	12:08	0:11	TRANSFORMER FAULT
428	7-Dec-18	MYSORE	66	HV1	HULLAHALLI_66	12:54	12:56	0:02	TRANSFORMER FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
429	7-Dec-18	MYSORE	66	HV1	HULLAHALLI_66	12:57	12:59	0:02	TRANSFORMER FAULT
430	7-Dec-18	MYSORE	66	HV2	HULLAHALLI_66	12:57	13:00	0:03	HAND TRIPPED
431	7-Dec-18	MYSORE	66	HUNSUR - HOOTAGALLI	HOSURGATE_66	7:21	9:07	1:45	LINE CLEAR AVAILED
432	7-Dec-18	MYSORE	66	HUNSUR - HOOTAGALLI	HOSURGATE_66	16:42	17:33	0:51	LINE CLEAR AVAILED
433	7-Dec-18	MYSORE	66	KIADB MANDYA - MADDUR	MADDUR_66 K_HONNALGERE_66	5:25	5:39	0:13	LINE FAULT
434	7-Dec-18	MYSORE	66	KIADB MANDYA - MADDUR	MADDUR_66 K_HONNALGERE_66	6:21	6:28	0:06	LINE FAULT
435	7-Dec-18	MYSORE	66	KIADB MANDYA - MADDUR	MADDUR_66	13:58	19:01	5:02	LINE CLEAR AVAILED
436	7-Dec-18	MYSORE	66	HV1	KOPPA_66	15:42	16:08	0:26	LINE CLEAR AVAILED
437	7-Dec-18	MYSORE	66	HV2	KOPPA_66	15:24	16:08	0:44	LINE CLEAR AVAILED
438	7-Dec-18	MYSORE	66	MADDUR - K.HONALGERE	MADDUR_66 K_HONNALGERE_66	6:54	10:59	4:05	LINE CLEAR AVAILED
439	7-Dec-18	MYSORE	66	HV1	MADHUVANAHALLI_220	10:25	13:51	3:25	TRANSFORMER FAULT
440	7-Dec-18	MYSORE	66	HV1	MADIKERI_66	11:17	12:32	1:15	LINE CLEAR AVAILED
441	7-Dec-18	MYSORE	66	SFC SIVA - MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66 THUMBLA_66 TNARASIPURA_66	11:49	11:58	0:09	LINE FAULT
442	7-Dec-18	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA_220 1	MADHUGIRI 220kV	17:06	17:47	0:40	LINE CLEAR AVAILED
443	7-Dec-18	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA_220 2	MADHUGIRI 220kV	17:06	18:58	1:51	HAND TRIPPED
444	7-Dec-18	TUMKUR	220	TR-3	HIRIYUR_220	6:15	6:33	0:17	TRANSFORMER FAULT
445	7-Dec-18	TUMKUR	110	TR-1	MAYASANDRA_110	0:16	0:53	0:37	TRANSFORMER FAULT
446	7-Dec-18	TUMKUR	110	TR-1	HALKURKE_110	13:00	13:49	0:48	LINE CLEAR AVAILED
447	7-Dec-18	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	0:43	0:52	0:08	LINE FAULT
448	7-Dec-18	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALI_66	14:22	14:52	0:30	LINE FAULT
449	7-Dec-18	TUMKUR	66	TR-1 & TR-2	CHANNAGIRI_66	14:57	15:23	0:25	TRANSFORMER FAULT
450	7-Dec-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:27	17:54	9:26	HAND TRIPPED
451	7-Dec-18	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	6:20	6:36	0:16	HAND TRIPPED
452	7-Dec-18	TUMKUR	66	HIRIYUR 220KV- ENERCON-2	ENERCON1_IPP_66	6:20	6:36	0:16	HAND TRIPPED
453	7-Dec-18	TUMKUR	66	HIRIYUR 220KV- RKP1	RKP2_IPP_66	6:19	6:37	0:18	HAND TRIPPED
454	7-Dec-18	TUMKUR	66	HIRIYUR 220KV- RKP 2	RKP1_IPP_66	6:19	6:37	0:18	HAND TRIPPED
455	7-Dec-18	TUMKUR	66	TR2	HONNALI_66	14:04	14:19	0:15	TRANSFORMER FAULT
456	7-Dec-18	TUMKUR	66	TR2	HONNALI_66	19:32	19:44	0:12	TRANSFORMER FAULT
457	7-Dec-18	TUMKUR	66	TR-2	HULIYURDURGA_66	11:11	12:00	0:48	TRANSFORMER FAULT
458	7-Dec-18	TUMKUR	66	TR-2	HULIYURDURGA_66	14:33	17:15	2:42	LINE CLEAR AVAILED
459	7-Dec-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:58	8:07	0:08	LINE FAULT
460	7-Dec-18	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	19:29	20:08	0:38	LINE CLEAR AVAILED
461	7-Dec-18	TUMKUR	66	THALLAK 220kV- CHALLAKERE	CHALLAKERE_66, SANIKERE_66	8:59	9:11	0:11	LINE FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
462	7-Dec-18	TUMKUR	66	MADHUGIRI 220kV- NAGALMADIKE	SHYLA PURA_66, NAGALMADIKE_66, LINGADAHALLI_TMK2_66, MANGALWADA_66, YNHOSKOTE_66	11:57	18:14	6:16	LINE CLEAR AVAILED
463	7-Dec-18	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	18:20	18:37	0:16	LINE FAULT
464	8-Dec-18	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	13:56	14:17	0:21	LINE FAULT
465	8-Dec-18	BAGALKOT	110	110/11KV,HV-1	BABALESHWAR_110	8:42	9:47	1:05	HAND TRIPPED
466	8-Dec-18	BAGALKOT	110	110/11KV,HV-1	BILAGI_110	6:38	6:55	0:17	TRANSFORMER FAULT
467	8-Dec-18	BAGALKOT	220	BIDNAL-TADAS 2	BIDNAL_220	12:18	12:45	0:27	HAND TRIPPED
468	8-Dec-18	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	13:45	14:05	0:20	LINE FAULT
469	8-Dec-18	BAGALKOT	110	HUKKERI-KOTTWAGI LIS	HUKKERI_110	14:15	14:35	0:20	LINE FAULT
470	8-Dec-18	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	14:15	14:16	0:01	TRANSFORMER FAULT
471	8-Dec-18	BAGALKOT	110	BPCL-ITNAL	ITNAL_110	9:37	9:50	0:13	MAIN SUPPLY FAILURE
472	8-Dec-18	BAGALKOT	110	BORUKA_ITNAL	ITNAL_10	9:37	9:48	0:11	MAIN SUPPLY FAILURE
473	8-Dec-18	BAGALKOT	110	ITNAL-HIDIKAL2	ITNAL_110	9:38	9:52	0:14	MAIN SUPPLY FAILURE
474	8-Dec-18	BAGALKOT	110	ITNAL-RAIBAG 2	ITNAL_110	9:38	9:52	0:14	MAIN SUPPLY FAILURE
475	8-Dec-18	BAGALKOT	110	SOUDATTI220-SOUDATTI2	SOUDATTI_110	14:48	17:42	2:54	LINE CLEAR AVAILED
476	8-Dec-18	BAGALKOT	110	ENERCON1&2-SOUDATTI	SOUDATTI_110	12:07	12:16	0:09	LINE FAULT
477	8-Dec-18	BAGALKOT	220	SHARAVATHY1-SIRSI	SIRSI_220	10:27	15:49	5:22	HAND TRIPPED
478	8-Dec-18	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	18:10	18:13	0:03	HAND TRIPPED
479	8-Dec-18	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	19:08	19:22	0:14	HAND TRIPPED
480	8-Dec-18	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	14:10	14:20	0:10	MAIN SUPPLY FAILURE
481	8-Dec-18	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	14:10	14:12	0:02	MAIN SUPPLY FAILURE
482	8-Dec-18	BAGALKOT	110	110/11KV, HV1	MRUTHYUNJAY NAGAR_110	12:53	14:09	1:16	LINE CLEAR AVAILED
483	8-Dec-18	BAGALKOT	110	110/11KV, HV2	MRUTHYUNJAY NAGAR_110	7:56	17:56	10:00	LINE CLEAR AVAILED
484	8-Dec-18	BANGALORE	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	16:50	17:01	0:11	HAND TRIPPED
485	8-Dec-18	BANGALORE	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	16:50	17:01	0:11	LINE FAULT
486	8-Dec-18	BANGALORE	66	DB PURA 220 - DEVANAHALLI 1 & 2	KUNDANA, DEVANAHALLI	15:28	15:32	0:04	LINE CLEAR AVAILED
487	8-Dec-18	BANGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	9:43	9:51	0:08	LOAD CHANGE OVER
488	8-Dec-18	BANGALORE	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	10:00	10:10	0:10	LOAD CHANGE OVER
489	8-Dec-18	BANGALORE	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	19:10	19:20	0:10	LOAD CHANGE OVER
490	8-Dec-18	BANGALORE	66	KANASWADI - YELAHANKA 220	KANASWADI	9:45	10:05	0:20	LOAD CHANGE OVER
491	8-Dec-18	BANGALORE	66	KANASWADI - DB PURA 220	KANASWADI	19:15	19:20	0:05	LOAD CHANGE OVER
492	8-Dec-18	BANGALORE	66	KOLAR 220 - MULABAGAL	MULBAGAL, AVANI	0:09	0:15	0:06	LINE FAULT
493	8-Dec-18	BANGALORE	66	KOLAR 220 - MULABAGAL	MULBAGAL, AVANI	2:01	2:15	0:14	LINE FAULT
494	8-Dec-18	BANGALORE	66	KOLAR 220 - MULABAGAL	MULBAGAL, AVANI	2:41	3:08	0:27	LINE FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
495	8-Dec-18	BANGALORE	66	HEBBAL 220 - LR BANDE	LR BANDE	13:56	14:15	0:19	LINE FAULT
496	8-Dec-18	BANGALORE	66	LR BANDE - HBR LAYOUT	HBR LAYOUT	13:55	15:57	2:01	LINE FAULT
497	8-Dec-18	BANGALORE	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	7:55	7:59	0:04	LINE FAULT
498	8-Dec-18	BANGALORE	66	HV1	SOMANAHALLI 220	10:58	12:25	1:27	LINE CLEAR AVAILED
499	8-Dec-18	BANGALORE	66	HV1	HSR LAYOUT 220	23:22	23:27	0:05	TRANSFORMER FAULT
500	8-Dec-18	BANGALORE	66	JIGANI 220 - JIGANI 66	JIGANI 66	13:38	16:13	2:35	LINE CLEAR AVAILED
501	8-Dec-18	BANGALORE	220	HV1	JIGANI 220	14:42	16:13	1:31	LINE CLEAR AVAILED
502	8-Dec-18	BANGALORE	66	HV2	JIGANI 220	14:42	16:13	1:31	LINE CLEAR AVAILED
503	8-Dec-18	BANGALORE	66	HV1	JIGANI 220	14:42	16:13	1:31	LINE CLEAR AVAILED
504	8-Dec-18	BANGALORE	220	HV2	YARANDANAHALLI 220	6:42	7:00	0:17	TRANSFORMER FAULT
505	8-Dec-18	BANGALORE	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSTS (EHT)	6:42	7:26	0:43	LINE FAULT
506	8-Dec-18	BANGALORE	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BOMMASANDRA I/A, BIOCON (EHT)	6:42	7:24	0:42	LINE FAULT
507	8-Dec-18	BANGALORE	220	HV1	TK HALLI 220	12:58	13:15	0:17	TRANSFORMER FAULT
508	8-Dec-18	BANGALORE	66	TK HALLI 220 - BWSSB 3 (EHT)	BWSSB (EHT)	12:58	13:28	0:30	LINE FAULT
509	8-Dec-18	BANGALORE	66	TK HALLI 220 - BWSSB 1 (EHT)	BWSSB (EHT)	12:58	13:18	0:20	MAIN SUPPLY FAILURE
510	8-Dec-18	BANGALORE	66	TK HALLI 220 - BWSSB 4 (EHT)	BWSSB (EHT)	12:58	13:18	0:20	MAIN SUPPLY FAILURE
511	8-Dec-18	BANGALORE	66	HV2	TELECOM LAYOUT	14:34	14:40	0:05	LINE CLEAR AVAILED
512	8-Dec-18	BANGALORE	66	RAJANKUNTE - YELAHANKA 220	RAJANKUNTE	10:20	10:30	0:10	LOAD CHANGE OVER
513	8-Dec-18	BANGALORE	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	19:10	19:20	0:10	LOAD CHANGE OVER
514	8-Dec-18	BANGALORE	66	KHB - YELAHANKA 220	KHB	10:30	10:33	0:03	LOAD CHANGE OVER
515	8-Dec-18	BANGALORE	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	15:01	15:15	0:14	LINE FAULT
516	8-Dec-18	BANGALORE	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR	15:28	15:45	0:16	HAND TRIPPED
517	8-Dec-18	BANGALORE	66	YEDAMADU - HANUMANTHNAGAR	CHATRA, MARALWADI, HANUMANTHNAGAR	16:25	16:35	0:10	LINE FAULT
518	8-Dec-18	BANGALORE	66	YEDAMADU - HANUMANTHNAGAR	CHATRA, MARALWADI, HANUMANTHNAGAR	21:10	21:15	0:05	LINE FAULT
519	8-Dec-18	BANGALORE	66	YEDAMADU - HANUMANTHNAGAR	YEDAMADU	15:01	15:15	0:13	MAIN SUPPLY FAILURE
520	8-Dec-18	BANGALORE	66	HV2	KADUGODI	12:48	13:24	0:36	TRANSFORMER FAULT
521	8-Dec-18	BANGALORE	66	KADUGODI - EPIP 220	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA, ALUMBIC GLASS(EHT)	12:53	13:24	0:31	LINE FAULT
522	8-Dec-18	GULBARGA	220	HV2	HALBURGA_220	9:48	10:26	0:38	LINE CLEAR AVAILED
523	8-Dec-18	GULBARGA	220	HV1	HALBURGA_220	10:13	10:24	0:11	TRANSFORMER FAULT
524	8-Dec-18	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	22:47	23:59	1:12	LINE CLEAR AVAILED
525	8-Dec-18	GULBARGA	110	GURUMITAKAL-GMSHWIND	GURUMITAKAL_110	14:40	16:55	2:15	LINE CLEAR AVAILED
526	8-Dec-18	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	5:06	5:12	0:06	LINE FAULT
527	8-Dec-18	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	1:35	1:45	0:10	LINE FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
528	8-Dec-18	GULBARGA	110	KOLHAR-SHAHI SOLAR	KOLHAR_110	10:37	11:04	0:27	LINE CLEAR AVAILED
529	8-Dec-18	GULBARGA	110	KUSHTAGI-INR_SLR	KUSTAGI_220	11:41	12:01	0:20	LINE FAULT
530	8-Dec-18	GULBARGA	110	HV2	LINGASUGUR_220	14:00	14:09	0:09	TRANSFORMER FAULT
531	8-Dec-18	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,KONKAL_110	12:50	14:05	1:15	LINE CLEAR AVAILED
532	8-Dec-18	GULBARGA	110	YADGIR-KONKAL	KONKAL_110	12:06	23:59	11:53	LINE CLEAR AVAILED
533	8-Dec-18	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	8:05	8:05	HAND TRIPPED
534	8-Dec-18	HASSAN	220	UPCL-KEMAR1	upcl_gen	9:41	13:22	3:41	LINE CLEAR AVAILED
535	8-Dec-18	HASSAN	220	MRSSHM-VARAH1	MRSMG_220	8:52	23:59	15:07	NBFC
536	8-Dec-18	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	10:28	17:23	6:55	LINE CLEAR AVAILED
537	8-Dec-18	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	8:51	23:59	15:08	LINE CLEAR AVAILED
538	8-Dec-18	HASSAN	110	HV5	MRSMG_220	9:36	14:12	4:36	LINE CLEAR AVAILED
539	8-Dec-18	HASSAN	110	HV1	halady_110	16:18	17:28	1:10	LINE CLEAR AVAILED
540	8-Dec-18	HASSAN	110	HV1	BIRUR_110	4:35	9:21	4:46	TRANSFORMER FAULT
541	8-Dec-18	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	13:48	14:47	0:59	LOAD CURTAILMENT
542	8-Dec-18	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	13:48	14:47	0:59	LOAD CURTAILMENT
543	8-Dec-18	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	9:07	9:19	0:12	LINE FAULT
544	8-Dec-18	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	13:42	14:45	1:03	LINE CLEAR AVAILED
545	8-Dec-18	HASSAN	66	HAGARE-HASSAN	HAGARE_66	0:00	1:32	1:32	LOAD CURTAILMENT
546	8-Dec-18	HASSAN	66	HAGARE-HASSAN	HAGARE_66	1:49	2:53	1:04	LOAD CURTAILMENT
547	8-Dec-18	HASSAN	66	HAGARE-HASSAN	HAGARE_66	3:26	7:00	3:34	LOAD CURTAILMENT
548	8-Dec-18	HASSAN	66	HAGARE-HASSAN	HAGARE_66	9:54	12:41	2:47	LOAD CURTAILMENT
549	8-Dec-18	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	14:44	14:58	0:14	LINE FAULT
550	8-Dec-18	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	16:16	17:37	1:21	LINE CLEAR AVAILED
551	8-Dec-18	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	17:42	18:25	0:43	HAND TRIPPED
552	8-Dec-18	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	18:19	18:24	0:05	LINE FAULT
553	8-Dec-18	HASSAN	66	HV1	MAGGE_66	19:29	19:39	0:10	TRANSFORMER FAULT
554	8-Dec-18	HASSAN	66	SAKALE-IPCL2	SAKALESHAPURA_66	10:35	11:06	0:31	LINE CLEAR AVAILED
555	8-Dec-18	HASSAN	66	SAKALE-IPCL2	SAKALESHAPURA_66	14:43	15:07	0:24	LINE CLEAR AVAILED
556	8-Dec-18	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	1:35	1:46	0:11	LINE FAULT
557	8-Dec-18	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	3:14	3:21	0:07	LINE FAULT
558	8-Dec-18	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	14:42	14:46	0:04	HAND TRIPPED
559	8-Dec-18	MYSORE	66	HV1	BASARALU_66	19:57	20:02	0:05	HAND TRIPPED
560	8-Dec-18	MYSORE	66	HV1	BGPURA_66	11:30	14:27	2:57	LINE CLEAR AVAILED
561	8-Dec-18	MYSORE	66	HV2	BGPURA_66	7:50	13:15	5:25	LINE CLEAR AVAILED
562	8-Dec-18	MYSORE	66	HV1	CHUNCHUNKATTE_66	11:11	13:19	2:08	LINE CLEAR AVAILED
563	8-Dec-18	MYSORE	66	CR NAGARA-HONNALLI	ATTIGULIPURA_66, HONNALLY_MYS_66	17:58	18:04	0:05	HAND TRIPPED
564	8-Dec-18	MYSORE	66	CR NAGARA-GUNDLUPETE 2	TERAKANAMBE_66	6:10	6:19	0:08	LINE FAULT
565	8-Dec-18	MYSORE	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	21:10	21:19	0:08	LINE FAULT
566	8-Dec-18	MYSORE	66	DR PETE-KUNTHUR	SANTHEMARAHALLI_66, MUGUR_66 THAYURU_66	17:59	18:25	0:26	LINE FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
567	8-Dec-18	MYSORE	66	KUSHALANAGARA 220-MYSORE-1	MIRLE_66	5:29	5:38	0:08	LINE FAULT
568	8-Dec-18	TUMKUR	66	AMRUTHUR-ANCHEPALYA	AMRUTHUR_66,	10:42	11:14	0:32	LINE CLEAR AVAILED
569	8-Dec-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:03	18:06	10:02	HAND TRIPPED
570	8-Dec-18	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	6:05	6:11	0:05	LINE FAULT
571	8-Dec-18	TUMKUR	66	TR2	HONNALI_66	15:55	16:11	0:15	TRANSFORMER FAULT
572	8-Dec-18	TUMKUR	66	TR-1	KORA_66	10:38	12:06	1:28	LINE CLEAR AVAILED
573	8-Dec-18	TUMKUR	66	TR-1	KORA_66	12:10	12:19	0:08	LINE CLEAR AVAILED
574	8-Dec-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	3:46	3:51	0:05	LINE FAULT
575	8-Dec-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:20	6:26	0:06	LINE FAULT
576	8-Dec-18	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	10:07	10:18	0:11	LINE FAULT
577	8-Dec-18	TUMKUR	66	MADHUGIRI 220kV- NAGALMADIKE	SHYLAPURA_66, NAGALMADIKE_66, LINGADAHALLI_TMK2_66, MANGALWADA_66, YNHOSKOTE_66	5:57	8:05	2:07	LINE CLEAR AVAILED
578	8-Dec-18	TUMKUR	66	MADHUGIRI 220kV- NAGALMADIKE	SHYLAPURA_66, NAGALMADIKE_66, LINGADAHALLI_TMK2_66, MANGALWADA_66, YNHOSKOTE_66	10:06	10:21	0:14	LINE FAULT
579	8-Dec-18	TUMKUR	66	MADHUGIRI 220kV- NAGALMADIKE	SHYLAPURA_66, NAGALMADIKE_66, LINGADAHALLI_TMK2_66, MANGALWADA_66, YNHOSKOTE_66	12:31	12:39	0:08	LINE FAULT
580	8-Dec-18	TUMKUR	66	NAGALAMADIKE-MADHUGIRI	NAGALMADIKE_66	10:06	11:15	1:08	LINE FAULT
581	8-Dec-18	TUMKUR	66	NAGALAMADIKE-MADHUGIRI	NAGALMADIKE_66	12:31	12:45	0:14	LINE FAULT
582	9-Dec-18	BAGALKOT	110	110/11KV,HV-2	BANAHATTI_110	3:48	13:31	9:43	TRANSFORMER FAULT
583	9-Dec-18	BAGALKOT	220	CHIKKODI-BELGAUM 1	CHIKKODI_220	21:57	23:59	2:02	HAND TRIPPED
584	9-Dec-18	BAGALKOT	110	HIREHAL-RON	HIREHAL_110	21:28	23:59	2:31	LINE CLEAR AVAILED
585	9-Dec-18	BAGALKOT	110	MANALI SUGARS-MALGHAN(S)	MALGHAN(S)_110	5:34	5:40	0:06	LINE FAULT
586	9-Dec-18	BAGALKOT	110	MK HUBLI220-BIDI	BIDI_110	5:38	8:07	2:29	LINE FAULT
587	9-Dec-18	BAGALKOT	110	MAHALINGAPUR220-BANAHATTI	BANAHATTI_110	3:10	3:13	0:03	LINE FAULT
588	9-Dec-18	BANGALORE	66	HV2	DODDABELAVANGALA	12:28	12:42	0:14	TRANSFORMER FAULT
589	9-Dec-18	BANGALORE	66	HV2	JIGANI 66	8:25	8:27	0:02	LOAD CHANGE OVER

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
590	9-Dec-18	BANGALORE	66	KANASWADI - YELAHANKA 220	KANASWADI	9:40	9:53	0:13	LOAD CHANGE OVER
591	9-Dec-18	BANGALORE	66	KANASWADI - DB PURA 220	KANASWADI	18:19	18:23	0:04	LOAD CHANGE OVER
592	9-Dec-18	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	17:23	23:59	6:36	LINE FAULT
593	9-Dec-18	BANGALORE	66	ABBIGERE - ATTUR YELAHANKA	ABBIGERE	10:03	10:05	0:02	LOAD CHANGE OVER
594	9-Dec-18	BANGALORE	66	ABBIGERE - WELCAST	ABBIGERE	18:13	18:15	0:02	LOAD CHANGE OVER
595	9-Dec-18	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	13:21	14:15	0:54	LINE CLEAR AVAILED
596	9-Dec-18	BANGALORE	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	15:08	15:18	0:10	LOAD CHANGE OVER
597	9-Dec-18	BANGALORE	66	YEDAMADU - HANUMANTHNAGAR	HANUMANTHNAGAR, CHATRA, MARALWADI	3:05	3:10	0:05	LINE FAULT
598	9-Dec-18	BANGALORE	66	SOMANAHALLI 220 - KANAKAPURA 1	YEDAMADU, HANUMANTHNAGAR, CHATRA, MARALWADI	9:20	9:40	0:20	LINE FAULT
599	9-Dec-18	BANGALORE	66	RBI - SOMANAHALLI 220	RBI	15:15	15:20	0:05	LOAD CHANGE OVER
600	9-Dec-18	BANGALORE	66	RAJANKUNTE - YELAHANKA 220	RAJANKUNTE	9:50	9:55	0:05	LOAD CHANGE OVER
601	9-Dec-18	BANGALORE	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	18:15	18:20	0:05	LOAD CHANGE OVER
602	9-Dec-18	BANGALORE	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD, ITC (EHT)	8:10	8:49	0:39	LINE FAULT
603	9-Dec-18	BANGALORE	66	POTTERY ROAD - HEBBAL 220	POTTERY ROAD, ITC (EHT)	9:34	9:48	0:14	LOAD CHANGE OVER
604	9-Dec-18	BANGALORE	66	HEBBAL 220 - BANASWADI	BANASWADI	9:34	10:00	0:25	LINE FAULT
605	9-Dec-18	BANGALORE	66	HV2	VR DODDI	0:01	0:23	0:22	TRANSFORMER FAULT
606	9-Dec-18	GULBARGA	220	HV1	HALBURGA_220	6:34	6:47	0:13	TRANSFORMER FAULT
607	9-Dec-18	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	0:00	12:08	12:08	LINE CLEAR AVAILED
608	9-Dec-18	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	1:33	11:59	10:26	LINE CLEAR AVAILED
609	9-Dec-18	GULBARGA	110	HALBURGA-BHALKI	BHALKI_110,LADHA_110,SANTHAPUR_110	6:34	6:52	0:18	LINE FAULT
610	9-Dec-18	GULBARGA	110	HV1,HV2	HANUMANAL_110	8:25	10:20	1:55	LINE CLEAR AVAILED
611	9-Dec-18	GULBARGA	110	VARIKAL-HANUMANAL	HANUMANAL_110	11:10	11:20	0:10	LINE FAULT
612	9-Dec-18	GULBARGA	66	MUNIRABAD-MSD LINE	HANASI_66	16:22	16:24	0:02	LINE FAULT
613	9-Dec-18	HASSAN	220	MRSSHM-VARAHI1	MRSMG_220	0:00	19:43	19:43	NBFC
614	9-Dec-18	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	0:00	19:43	19:43	LINE CLEAR AVAILED
615	9-Dec-18	HASSAN	110	HV1	ALKOLA_110	10:10	16:15	6:05	LINE CLEAR AVAILED
616	9-Dec-18	HASSAN	110	HV2	ALKOLA_110	10:10	16:35	6:25	LINE CLEAR AVAILED
617	9-Dec-18	HASSAN	110	HV3	ALKOLA_110	10:10	16:35	6:25	LINE CLEAR AVAILED
618	9-Dec-18	HASSAN	110	HV2	GANDASI_110	18:20	18:45	0:25	TRANSFORMER FAULT
619	9-Dec-18	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	13:50	13:55	0:05	HAND TRIPPED
620	9-Dec-18	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	15:40	15:43	0:03	HAND TRIPPED
621	9-Dec-18	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	20:46	20:56	0:10	LINE FAULT
622	9-Dec-18	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	19:20	20:00	0:40	HAND TRIPPED
623	9-Dec-18	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	19:20	23:10	3:50	HAND TRIPPED
624	9-Dec-18	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	19:20	23:59	4:39	HAND TRIPPED
625	9-Dec-18	MYSORE	66	HV2	HULLAHALLI_66	9:35	9:45	0:09	LINE CLEAR AVAILED
626	9-Dec-18	MYSORE	66	HV2	VIJAYANAGRAMYS_66	11:39	13:16	1:37	LINE CLEAR AVAILED
627	9-Dec-18	MYSORE	66	CR NAGARA-DR PETE 1	DODDARAYAPET_66	10:06	18:23	8:16	LINE CLEAR AVAILED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
628	9-Dec-18	MYSORE	66	CR NAGARA-DR PETE 2	DODDARAYAPET_66	10:06	18:21	8:15	LINE CLEAR AVAILED
629	9-Dec-18	MYSORE	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	11:43	13:34	1:50	LINE CLEAR AVAILED
630	9-Dec-18	MYSORE	66	KADAKOLA-SARGURU 1	JAIPUR_66,ANTHARSANTHE_66, HDKOTE_66 HAMPAPURA(K)_66	6:20	6:29	0:08	LINE FAULT
631	9-Dec-18	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66	16:56	17:04	0:08	LINE FAULT
632	9-Dec-18	MYSORE	66	MADDUR-K.HONALGERE	K_HONNALGERE_66	17:08	17:15	0:07	LINE FAULT
633	9-Dec-18	MYSORE	66	SFC SIVA-MEGHALAPURA	BGPURA_66, CHIDRAVALI_66, THUMBLA_66, TNARASIPURA_66	13:12	13:19	0:06	LINE FAULT
634	9-Dec-18	MYSORE	66	VAJAMANGALA-MEGHALAPURA	MEGALAPURA_66	13:08	13:23	0:15	LINE FAULT
635	9-Dec-18	TUMKUR	66	ANCHEPALYA 220kV- KUNIGAL	KUNIGAL_66	9:15	9:41	0:25	LINE CLEAR AVAILED
636	9-Dec-18	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	23:32	23:48	0:16	LINE FAULT
637	9-Dec-18	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	10:36	10:39	0:02	HAND TRIPPED
638	9-Dec-18	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	16:32	16:46	0:14	LINE FAULT
639	9-Dec-18	TUMKUR	66	TR-1 & TR-2	BAGUR_TMK_66	12:09	18:38	6:28	LINE CLEAR AVAILED
640	9-Dec-18	TUMKUR	66	CHANNAGIRI-LNGDHLI	CHANNAGIRI_66	9:01	16:27	7:25	MAIN SUPPLY FAILURE
641	9-Dec-18	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	9:56	16:37	6:41	MAIN SUPPLY FAILURE
642	9-Dec-18	TUMKUR	66	TR1	DEVARAHALLI_66	9:56	16:39	6:43	MAIN SUPPLY FAILURE
643	9-Dec-18	TUMKUR	66	DYAVARANAHALI-RANGENAHALI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:06	17:32	9:26	HAND TRIPPED
644	9-Dec-18	TUMKUR	66	TR2	HONNALI_66	7:59	8:10	0:10	TRANSFORMER FAULT
645	9-Dec-18	TUMKUR	66	TR2	HONNALI_66	14:04	14:15	0:11	TRANSFORMER FAULT
646	9-Dec-18	TUMKUR	66	TR2	HONNALI_66	17:58	18:13	0:15	TRANSFORMER FAULT
647	9-Dec-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	9:00	16:26	7:26	LINE CLEAR AVAILED
648	9-Dec-18	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	14:39	14:47	0:07	LINE FAULT
649	9-Dec-18	TUMKUR	66	TR-1	NAGASAMUDRA_66	10:07	10:14	0:06	TRANSFORMER FAULT
650	10-Dec-18	BAGALKOT	110	AMBEWADI220-HALIYAL	HALIYAL_110	9:43	17:52	8:09	LINE CLEAR AVAILED
651	10-Dec-18	BAGALKOT	110	AMBEWADI220-KAVALWADA	KAVALWADA_110	9:43	17:52	8:09	LINE CLEAR AVAILED
652	10-Dec-18	BAGALKOT	110	110/11HV,HV2	BANAHATTI_110	11:08	12:35	1:27	LINE CLEAR AVAILED
653	10-Dec-18	BAGALKOT	110	110/11HV,HV2	BANAHATTI_110	14:01	14:03	0:02	HAND TRIPPED
654	10-Dec-18	BAGALKOT	110	110/11HV,HV1	MRUTHYUNJAY NAGAR_110	11:58	12:42	0:44	LINE CLEAR AVAILED
655	10-Dec-18	BAGALKOT	110	110/11HV,HV2	MRUTHYUNJAY NAGAR_110	12:43	13:54	1:11	LINE CLEAR AVAILED
656	10-Dec-18	BAGALKOT	110	110/11HV,HV1	MUNDUGANUR_110	15:11	15:44	0:33	LINE CLEAR AVAILED
657	10-Dec-18	BAGALKOT	220	CHIKKODI-BELGAUM1	CHIKKODI_220	0:00	7:19	7:19	HAND TRIPPED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
658	10-Dec-18	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	15:03	19:46	4:43	LINE FAULT
659	10-Dec-18	BAGALKOT	110	110/11KV,HV2	SHIRGOAN_110	8:49	10:12	1:23	HAND TRIPPED
660	10-Dec-18	BAGALKOT	220	HUBLI1-SIRSI	SIRSI_220	23:23	23:59	0:36	LINE FAULT
661	10-Dec-18	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	9:46	9:50	0:04	HAND TRIPPED
662	10-Dec-18	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	17:42	17:53	0:11	HAND TRIPPED
663	10-Dec-18	BAGALKOT	110	TARIHAL-TADASINAKOPPA	TADASINKOPPA_110	10:36	15:33	4:57	LINE CLEAR AVAILED
664	10-Dec-18	BAGALKOT	220	NAGJHARI2-HUBLI	HUBLI_220	10:16	11:09	0:53	LINE CLEAR AVAILED
665	10-Dec-18	BAGALKOT	110	110/33KV,HV-3	TILUVALLI_110	15:30	17:32	2:02	HAND TRIPPED
666	10-Dec-18	BAGALKOT	110	110/11KV,HV-1	TEREDAL_110	13:59	14:04	0:05	TRANSFORMER FAULT
667	10-Dec-18	BANGALORE	66	HV1	CHAKAVELU	13:14	13:20	0:06	LOAD CHANGE OVER
668	10-Dec-18	BANGALORE	66	HV2	CHAKAVELU	15:53	16:29	0:36	LINE CLEAR AVAILED
669	10-Dec-18	BANGALORE	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	15:54	16:29	0:35	LINE CLEAR AVAILED
670	10-Dec-18	BANGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	1:40	1:48	0:08	LINE FAULT
671	10-Dec-18	BANGALORE	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	12:05	12:15	0:10	LOAD CHANGE OVER
672	10-Dec-18	BANGALORE	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	15:45	15:55	0:10	LOAD CHANGE OVER
673	10-Dec-18	BANGALORE	66	HV1	LAKKUR	18:00	19:30	1:30	LINE CLEAR AVAILED
674	10-Dec-18	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA, KACHAMARANAHALLI	0:00	2:30	2:30	LINE FAULT
675	10-Dec-18	BANGALORE	66	HEBBAL 220 - BANASWADI	BANASWADI	8:40	9:16	0:36	LINE FAULT
676	10-Dec-18	BANGALORE	66	HEBBAL 220 - BANASWADI	BANASWADI	13:39	14:59	1:20	LINE CLEAR AVAILED
677	10-Dec-18	BANGALORE	66	BANASWADI - HEBBAL 220	BANASWADI	9:33	9:39	0:06	LINE FAULT
678	10-Dec-18	BANGALORE	66	HV1	KADUGODI	11:02	17:27	6:25	LINE CLEAR AVAILED
679	10-Dec-18	BANGALORE	66	HV2	KADUGODI	10:55	17:27	6:32	LINE CLEAR AVAILED
680	10-Dec-18	BANGALORE	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI	7:01	8:34	1:33	LINE CLEAR AVAILED
681	10-Dec-18	BANGALORE	66	HANUMANTHNAGAR - YEDUMADU	YEDUMADU	9:10	9:20	0:10	LOAD CHANGE OVER
682	10-Dec-18	BANGALORE	66	HV2	ELECTRONIC CITY PH 2 SEC 1	16:38	16:40	0:01	LINE CLEAR AVAILED
683	10-Dec-18	BANGALORE	66	HV3	ELECTRONIC CITY PH 2 SEC 1	14:15	14:48	0:33	LINE CLEAR AVAILED
684	10-Dec-18	BANGALORE	66	ABBIGERE - ATTUR YELAHANKA	ABBIGERE	14:40	14:45	0:05	LOAD CHANGE OVER
685	10-Dec-18	BANGALORE	66	ABBIGERE - WELCAST	ABBIGERE	15:32	15:42	0:10	LOAD CHANGE OVER
686	10-Dec-18	BANGALORE	66	KHB - SRS PEENYA 220	KHB	6:30	6:35	0:05	LOAD CHANGE OVER
687	10-Dec-18	BANGALORE	66	HV2	SOMANAHALLI 220	10:38	13:38	3:00	LINE CLEAR AVAILED
688	10-Dec-18	BANGALORE	220	SOMANAHALLI 220 - YARANDANAHALLI 220	JIGANI 220, YARANDANAHALLI 220	15:57	16:47	0:50	LINE FAULT
689	10-Dec-18	BANGALORE	220	YARANDANAHALLI 220 - SOMANAHALLI 220	YARANDANAHALLI 220	15:56	16:53	0:57	LINE FAULT
690	10-Dec-18	BANGALORE	66	YARANDANAHALLI 220 - TIMES OF INDIA(EHT)	TIMES OF INDIA(EHT)	15:56	17:00	1:03	MAIN SUPPLY FAILURE
691	10-Dec-18	BANGALORE	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	15:56	16:57	1:00	MAIN SUPPLY FAILURE

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
692	10-Dec-18	BANGALORE	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BOMMASANDRA I/A, BIOCON (EHT)	15:56	17:02	1:06	MAIN SUPPLY FAILURE
693	10-Dec-18	BANGALORE	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	15:56	17:00	1:03	MAIN SUPPLY FAILURE
694	10-Dec-18	BANGALORE	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	15:56	17:00	1:03	MAIN SUPPLY FAILURE
695	10-Dec-18	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	10:04	14:41	4:37	NBFC
696	10-Dec-18	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	11:55	12:20	0:25	LINE FAULT
697	10-Dec-18	GULBARGA	220	HV1	HUMNABAD_220	15:20	16:48	1:28	LINE CLEAR AVAILED
698	10-Dec-18	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	8:31	18:53	10:22	NBFC
699	10-Dec-18	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	15:55	17:15	1:20	NBFC
700	10-Dec-18	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110	6:36	6:58	0:22	LINE FAULT
701	10-Dec-18	GULBARGA	110	BHALKI-LADHA	LADHA_110	6:36	6:58	0:22	LINE FAULT
702	10-Dec-18	GULBARGA	110	HV2	KAMPLI_110	12:37	13:43	1:06	LINE CLEAR AVAILED
703	10-Dec-18	GULBARGA	110	HV1	HUMNABAD_220	11:10	12:25	1:15	LINE CLEAR AVAILED
704	10-Dec-18	GULBARGA	110	GURUMITAKAL-KONKAL LINE	GURUMITAKAL_110,KONKAL_110	20:06	23:59	3:53	LINE CLEAR AVAILED
705	10-Dec-18	GULBARGA	110	TEKKALAKOTE-ABMN_SLR	TEKKALAKOTE_110	23:46	23:59	0:13	LINE FAULT
706	10-Dec-18	GULBARGA	110	YADGIR-KONKAL	KONKAL_110	0:00	19:17	19:17	LINE CLEAR AVAILED
707	10-Dec-18	HASSAN	400	UPCL-HASSAN2	UPCL_GEN	0:00	1:15	1:15	HAND TRIPPED
708	10-Dec-18	HASSAN	400	UPCL-HASSAN2	UPCL_GEN	17:33	23:59	6:26	HAND TRIPPED
709	10-Dec-18	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	11:36	12:59	1:23	HAND TRIPPED
710	10-Dec-18	HASSAN	110	HV1	HALADY_110	10:30	10:54	0:24	LINE CLEAR AVAILED
711	10-Dec-18	HASSAN	66	CHANNARA-UDAYAPURA	CHANNARAYAPATNA_66	0:00	10:44	10:44	HAND TRIPPED
712	10-Dec-18	HASSAN	66	CHANNARA-MALLALI	CHANNARAYAPATNA_66	8:13	10:45	2:32	LINE CLEAR AVAILED
713	10-Dec-18	HASSAN	66	HASSN220-HN PURA	HASSN_220	13:52	14:13	0:21	HAND TRIPPED
714	10-Dec-18	HASSAN	66	HASSN220-HN PURA	HASSN_220	1:24	1:53	0:29	LINE FAULT
715	10-Dec-18	MYSORE	66	CR NAGARA-YELANDUR	YELANDUR_66	5:03	5:14	0:11	LINE FAULT
716	10-Dec-18	MYSORE	66	CR NAGARA-YELANDUR	YELANDUR_66	9:51	9:58	0:06	LINE FAULT
717	10-Dec-18	MYSORE	66	HV1	DEVANOORMYS_66	10:34	16:25	5:50	LINE CLEAR AVAILED
718	10-Dec-18	MYSORE	66	HV2	DEVANOORMYS_66	10:34	16:21	5:47	LINE CLEAR AVAILED
719	10-Dec-18	MYSORE	66	DEVANUR(MYS)-RAJEEV NAGARA	RAJEEVNAGARA_66	10:36	15:19	4:43	LINE CLEAR AVAILED
720	10-Dec-18	MYSORE	66	HARVEY-KABBALLI	HARVEY_66	10:00	17:12	7:12	LINE CLEAR AVAILED
721	10-Dec-18	MYSORE	66	HOOTAGALLI-HUNSUR	HOSURGATE_66	6:09	6:19	0:09	LINE FAULT
722	10-Dec-18	MYSORE	66	KABBALLI-GUNDLUPETE	KABHALLY_66	15:40	15:45	0:05	HAND TRIPPED
723	10-Dec-18	MYSORE	66	KIRUGAVALU-SFC	KIRUGAVALU_66	11:00	17:10	6:10	LINE CLEAR AVAILED
724	10-Dec-18	MYSORE	66	MALIYUR-BANNUR	MALIYURU_66	16:45	16:55	0:10	HAND TRIPPED
725	10-Dec-18	MYSORE	66	MADHUVANAHALLI-YELANDUR	YELANDUR_66	5:03	5:11	0:08	LINE FAULT
726	10-Dec-18	MYSORE	66	MADHUVANAHALLI-YELANDUR	YELANDUR_66	9:51	9:59	0:07	LINE FAULT
727	10-Dec-18	MYSORE	66	SFC SIVA-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66 THUMBLA_66 TNARASIPURA_66	23:15	23:26	0:11	LINE FAULT
728	10-Dec-18	MYSORE	66	SINDUVALLI-BEGUR	BEGUR_66	10:25	16:35	6:10	LINE CLEAR AVAILED
729	10-Dec-18	MYSORE	66	KADAKOLA	SINDHUVALI_66	11:05	12:39	1:34	LINE CLEAR AVAILED
730	10-Dec-18	MYSORE	66	HV1	SINDHUVALI_66	11:05	12:45	1:40	LINE CLEAR AVAILED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
731	10-Dec-18	MYSORE	66	HV2	SINDHUVALI_66	11:05	12:45	1:40	LINE CLEAR AVAILED
732	10-Dec-18	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	7:09	7:17	0:08	LINE FAULT
733	10-Dec-18	MYSORE	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	18:08	18:30	0:21	LINE FAULT
734	10-Dec-18	TUMKUR	220	TR-3(HV-3)	HIRIYUR_220	6:20	6:32	0:11	TRANSFORMER FAULT
735	10-Dec-18	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	11:43	14:24	2:41	LINE CLEAR AVAILED
736	10-Dec-18	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	5:12	5:24	0:12	LINE FAULT
737	10-Dec-18	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	14:43	14:57	0:14	LOAD CURTAILMENT
738	10-Dec-18	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	11:33	13:15	1:41	LOAD CURTAILMENT
739	10-Dec-18	TUMKUR	66	ANTHRASANAHALLI 220kV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	11:33	13:15	1:41	LOAD CURTAILMENT
740	10-Dec-18	TUMKUR	66	TR-2	AVAREGERE_66	16:49	17:16	0:27	TRANSFORMER FAULT
741	10-Dec-18	TUMKUR	66	TR-1	CHANNAGIRI_66	13:14	13:39	0:24	LINE CLEAR AVAILED
742	10-Dec-18	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:17	14:10	1:53	LINE CLEAR AVAILED
743	10-Dec-18	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	15:01	15:21	0:20	LINE FAULT
744	10-Dec-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TM2_66	9:05	17:31	8:26	HAND TRIPPED
745	10-Dec-18	TUMKUR	66	TR-2	HARAPPANAHALLI_66	15:56	17:30	1:34	LINE CLEAR AVAILED
746	10-Dec-18	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	6:27	6:35	0:07	HAND TRIPPED
747	10-Dec-18	TUMKUR	66	HIRIYUR 220KV- ENERCON-2	ENERCON1_IPP_66	6:27	6:35	0:07	HAND TRIPPED
748	10-Dec-18	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	6:26	6:34	0:07	HAND TRIPPED
749	10-Dec-18	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	6:26	6:34	0:07	HAND TRIPPED
750	10-Dec-18	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	4:35	4:38	0:03	LINE FAULT
751	10-Dec-18	TUMKUR	66	TR-1	HONNALI_66	17:13	17:29	0:16	LINE CLEAR AVAILED
752	10-Dec-18	TUMKUR	66	TR-2	HONNALI_66	13:04	13:55	0:51	LINE CLEAR AVAILED
753	10-Dec-18	TUMKUR	66	TR-2	HONNALI_66	16:07	17:30	1:23	LINE CLEAR AVAILED
754	10-Dec-18	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	1:11	1:22	0:10	LINE FAULT
755	10-Dec-18	TUMKUR	66	TR-1	KORA_66	2:03	4:29	2:25	TRANSFORMER FAULT
756	10-Dec-18	TUMKUR	66	TR-1	KORATAGERE_66	12:39	12:48	0:09	TRANSFORMER FAULT
757	10-Dec-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	22:24	22:31	0:07	LINE FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
758	10-Dec-18	TUMKUR	66	TR-2	THOVINAKERE_66	11:40	13:03	1:22	TRANSFORMER FAULT