

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM:25.08.2020 TO 31.08.2020

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
1	25-Aug-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN ,LINE FAULT
2	25-Aug-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN ,LINE FAULT
3	25-Aug-2020	BAGALKOT	110	KUDALSANGAM - ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
4	25-Aug-2020	BAGALKOT	110	VAJRAMATTI220- LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
5	25-Aug-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1& 2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28(30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
6	25-Aug-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46(19.07.0.2020)			LINE OPEN, LINE CLEAR AVAILED
7	25-Aug-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00(21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
8	25-Aug-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
9	25-Aug-2020	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30(01.08.2020)			LINE OPEN, LINE CLEAR AVAILED
10	25-Aug-2020	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
11	25-Aug-2020	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI)	STATION NOT AFFECTED BELGAUM_220	22:18 (04.08.2020)	12:43 (25.08.2020)	494:25hrs	LINE CHARGED
12	25-Aug-2020	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26(17.08.2020)			LINE OPEN, LINE CLEAR AVAILED
13	25-Aug-2020	BAGALKOT	220	GADAG-HARTHI1	GADAG_220	12:19(17.08.2020)			LOAD CURTAILMENT
14	25-Aug-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05(19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
15	25-Aug-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09(20.08.2020)			LINE OPEN, LINE CLEAR AVAILED
16	25-Aug-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09(20.08.2020)			LINE OPEN, LINE CLEAR AVAILED
17	25-Aug-2020	BAGALKOT	110	BELGAUM-CHIKKODI2	BELGAUM_220	13:57 (24.08.2020)	9:04 (25.08.2020)	19:07hrs	LINE CHARGED
18	25-Aug-2020	BAGALKOT	110	220/110,LV2	MK HUBLI_220	13:39(24.08.2020)			TRANSFORMER OPEN ,LINE CLEAR AVAILED
19	25-Aug-2020	BAGALKOT	110	110/11KV, HV1&HV2	AREMALLAPUR_110	8:15	8:20	0:05	TRANSFORMER FAULT
20	25-Aug-2020	BAGALKOT	110	220/110KV, LV1	ATHANI_220	7:10	9:34	2:24	TRANSFORMER FAULT
21	25-Aug-2020	BAGALKOT	110	110/11KV, HV2	BANAHATTI_110	12:15	13:38	1:23	LINE CLEAR AVAILED
22	25-Aug-2020	BAGALKOT	110	BELGAUM220- ANKALGI	ANKALGI_110	9:18	12:52	3:34	LINE CLEAR AVAILED
23	25-Aug-2020	BAGALKOT	110	110/33KV, HV3	GUTTAL_110, HOSARITTI 33	11:59	12:23	0:24	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
24	25-Aug-2020	BAGALKOT	110	MKHUBLI220-HIREBAGEWADI	HIREBAGEWADI_110	10:47	12:59	2:12	LINE FAULT
25	25-Aug-2020	BAGALKOT	110	110/33KV, HV3	MURDESHWAR_110	17:14	18:10	0:56	LINE CLEAR AVAILED
26	25-Aug-2020	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	13:05	16:44	3:39	LINE FAULT
27	25-Aug-2020	BAGALKOT	220	HUBLI- NARENDRA2	HUBLI_220	0:22	10:49	10:27	LOAD CURTAILMENT
28	25-Aug-2020	BAGALKOT	110	RANEBENNUR220-GUTTAL	GUTTAL_110	11:25	13:02	1:37	LINE CLEAR AVAILED
29	25-Aug-2020	BENGALURU	66	HV3	A STATION 66	11:35	13:56	02:21	LINE CLEAR AVAILED
30	25-Aug-2020	BENGALURU	66	GOLF LINK - HAL 220	GOLF LINK	11:50	12:00	00:10	LOAD CHANGE OVER
31	25-Aug-2020	BENGALURU	66	GOLF LINK - HSR LAYOUT 220	GOLF LINK	16:55	17:05	00:10	LOAD CHANGE OVER
32	25-Aug-2020	BENGALURU	66	HAL 220 - ADUGODI 2	AMAR JYOTHI	12:05	12:13	00:08	LINE FAULT
33	25-Aug-2020	BENGALURU	66	LEELA VENTURE - HAL 1	LEELA VENTURE	12:02	12:16	00:14	LOAD CHANGE OVER
34	25-Aug-2020	BENGALURU	66	LEELA VENTURE - HAL 2	LEELA VENTURE	15:42	15:46	00:04	LOAD CHANGE OVER
35	25-Aug-2020	BENGALURU	66	HV2	PADMANABHANAGARA	11:02	11:06	00:04	LINE CLEAR AVAILED
36	25-Aug-2020	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	13:38	13:40	00:02	LINE CLEAR AVAILED
37	25-Aug-2020	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	02:25	02:32	00:07	LINE FAULT
38	25-Aug-2020	BENGALURU	66	HV1	HULLENAHALLI	13:32	18:04	04:32	LINE CLEAR AVAILED
39	25-Aug-2020	BENGALURU	66	HV2	SIDDALAGATTA	14:00	14:49	00:49	LINE CLEAR AVAILED
40	25-Aug-2020	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1 & 2	NO STATION AFFECTED	10:16(17/08/2020)			LINE OPEN, LINE CLEAR AVAILED
41	25-Aug-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN ,LINE FAULT
42	25-Aug-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN ,LINE FAULT
43	25-Aug-2020	GULBARGA	220	RAICHUR-JURALLA2	RAICHUR_220	5:56(19.8.2020)	10:37(25.8.2020)	148:41HRS	LINE CHARGED
44	25-Aug-2020	GULBARGA	220	RAICHUR-RTPS2	RAICHUR_220	12:58(24.8.2020)	14:58(25.8.2020)	26HRS	LINE CHARGED
45	25-Aug-2020	GULBARGA	220	RTPS-LINGASUGUR3	MALLAT_220,LINGASUGUR_220	19:51	20:16	00:25	LINE FAULT
46	25-Aug-2020	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	12:37	12:50	00:13	LINE FAULT
47	25-Aug-2020	GULBARGA	220	HV1	SEDAM_220	12:52	14:33	01:41	LINE CLEAR AVAILED
48	25-Aug-2020	GULBARGA	110	HV1	HUMNABAD_220	12:05	18:25	06:20	LINE CLEAR AVAILED
49	25-Aug-2020	GULBARGA	110	HV1	HUMNABAD_220	18:54	19:05	00:11	TRANSFORMER FAULT
50	25-Aug-2020	GULBARGA	110	YEDRAMI-SHAHABAD	YEDRAMI_110	09:15	15:45	06:30	MAIN SUPPLY FAILURE
51	25-Aug-2020	GULBARGA	110	KAPNOOR-HUMNABAD1	MARAGUTTI_110,MAHAGO AN 110	06:05	06:11	00:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
52	25-Aug-2020	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGSAR FACTORY_IPP,CHOWDAPU R_110	02:19	02:27	00:08	LINE FAULT
53	25-Aug-2020	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGSAR FACTORY_IPP,CHOWDAPU R_110	03:20	03:35	00:15	LINE FAULT
54	25-Aug-2020	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN, LINE CLEAR AVAILED
55	25-Aug-2020	HASSAN	400	TALAGU- NELAMANGALA#2	TALAGUPPA_400	18:10 (24.08.2020)			LINE OPEN, LINE CLEAR AVAILED
56	25-Aug-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:39 (24.08.2020)	6:29 (25.08.2020)	7:50hrs	LINE CHARGED
57	25-Aug-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	10:03 (20.08.2020)	9:56 (25.08.2020)	119:53hrs	LINE CHARGED
58	25-Aug-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:07 (25.08.2020)			LINE OPEN, LINE CLEAR AVAILED
59	25-Aug-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	19:09 (25.08.2020)			LINE OPEN ,LINE FAULT
60	25-Aug-2020	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	19:09 (25.08.2020)			LINE OPEN ,LINE FAULT
61	25-Aug-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	19:27	21:44	02:17	LINE CLEAR AVAILED
62	25-Aug-2020	HASSAN	220	MRSSHM-KBCRS	MRSMG_220	13:06	13:43	00:37	LINE FAULT
63	25-Aug-2020	HASSAN	110	GAJNUR-OUTGOING LINE	GAJANUR_110	13:05	13:15	00:10	HAND TRIPPED
64	25-Aug-2020	HASSAN	110	KADUR-NGNHL	KADUR_220	11:02	12:39	01:37	LINE FAULT
65	25-Aug-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	11:18	11:42	00:24	MAIN SUPPLY FAILURE
66	25-Aug-2020	HASSAN	110	HV1	KONDENALU_110	11:17	11:41	00:24	LINE CLEAR AVAILED
67	25-Aug-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	11:17	11:41	00:24	LINE CLEAR AVAILED
68	25-Aug-2020	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	11:17	11:24	00:07	LINE FAULT
69	25-Aug-2020	HASSAN	66	HV1	BELUR_66	15:35	16:15	00:40	LINE CLEAR AVAILED
70	25-Aug-2020	HASSAN	66	HV2	BELUR_66	15:35	16:15	00:40	LINE CLEAR AVAILED
71	25-Aug-2020	HASSAN	66	HV2	CHIKKAKONDAGOLA_66	14:50	15:39	00:49	TRANSFORMER FAULT
72	25-Aug-2020	HASSAN	66	HV1	HARIHARPURA_66	08:25	10:10	01:45	MAIN SUPPLY FAILURE
73	25-Aug-2020	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	08:14	08:25	00:11	LINE FAULT
74	25-Aug-2020	HASSAN	66	HV1	HNPURA_66	08:14	08:23	00:09	MAIN SUPPLY FAILURE
75	25-Aug-2020	HASSAN	66	HV1	HNPURA_66	11:33	13:25	01:52	LINE CLEAR AVAILED
76	25-Aug-2020	HASSAN	66	HV2	HNPURA_66	08:14	08:23	00:09	MAIN SUPPLY FAILURE
77	25-Aug-2020	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	08:14	08:40	00:26	LINE FAULT
78	25-Aug-2020	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	14:25	14:48	00:23	LINE FAULT
79	25-Aug-2020	MYSURU	66	DUNDANAHALLI- HULIYURDURGA	DUNDANAHALLI_66	16:10	16:45	0:35	MAIN SUPPLY FAILURE
80	25-Aug-2020	MYSURU	66	DUNDANAHALLI- HULIYURDURGA	DUNDANAHALLI_66	22:50	23:10	0:19	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
81	25-Aug-2020	MYSURU	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	18:24	18:34	0:10	LINE FAULT
82	25-Aug-2020	MYSURU	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS EFFECTED	18:24	18:33	0:09	LINE FAULT
83	25-Aug-2020	MYSURU	66	HD KOTE-TARAKA	ANTHARSANTHE STATION INTERRUPTED.	10:45	16:24	5:39	LINE CLEAR AVAILED
84	25-Aug-2020	MYSURU	66	HV2	HULLAHALLI_66	12:33	13:14	0:41	LINE CLEAR AVAILED
85	25-Aug-2020	MYSURU	220	KADAKOLA-BASTIPURA1	NO STATIONS EFFECTED	9:38	13:14	3:36	LINE CLEAR AVAILED
86	25-Aug-2020	MYSURU	220	KADAKOLA-BEGUR 1	NO STATIONS EFFECTED	11:35	13:18	1:43	LINE CLEAR AVAILED
87	25-Aug-2020	MYSURU	66	KADAKOLA-DKMAIDANA	NO STATIONS EFFECTED	6:58	9:10	2:11	LINE CLEAR AVAILED
88	25-Aug-2020	MYSURU	66	KADAKOLA-MYS SOUTH	NO STATIONS EFFECTED	6:58 (25.08.2020)			LINE OPEN, LINE CLEAR AVAILED
89	25-Aug-2020	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	13:06	14:24	1:17	LINE CLEAR AVAILED
90	25-Aug-2020	MYSURU	66	MADHUVANAHALLI-KOLLEGALA1	NO STATIONS EFFECTED	12:16	14:02	1:46	LINE CLEAR AVAILED
91	25-Aug-2020	MYSURU	66	MADHUVANAHALLI-PGPALYA	PGPALYA_66	12:16	13:15	0:59	LINE CLEAR AVAILED
92	25-Aug-2020	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	13:40	15:31	1:50	LINE CLEAR AVAILED
93	25-Aug-2020	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	11:25	12:52	1:27	LINE CLEAR AVAILED
94	25-Aug-2020	MYSURU	66	MADHUVANAHALLI-DODDINADUVADI	NO STATIONS EFFECTED	14:08	15:23	1:15	LINE CLEAR AVAILED
95	25-Aug-2020	MYSURU	66	MADHUVANAHALLI-HANNUR 1	NO STATIONS EFFECTED	9:43	10:52	1:09	LINE CLEAR AVAILED
96	25-Aug-2020	MYSURU	66	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	11:05	12:06	1:01	LINE CLEAR AVAILED
97	25-Aug-2020	MYSURU	66	MYSORE SOUTH-BOGADHI	NO STATIONS EFFECTED	13:22 (25.08.2020)			LINE OPEN, LINE CLEAR AVAILED
98	25-Aug-2020	MYSURU	66	HV1	NANJANGUDU_66	15:20	15:44	0:24	TRANSFORMER FAULT
99	25-Aug-2020	MYSURU	66	HV2	PANDAVAPURA_66	12:10	14:50	2:40	LINE CLEAR AVAILED
100	25-Aug-2020	MYSURU	66	HV2	PANDAVAPURA_66	15:05	15:23	0:17	TRANSFORMER FAULT
101	25-Aug-2020	MYSURU	66	HV2	PANDAVAPURA_66	16:40	16:50	0:10	HAND TRIPPED
102	25-Aug-2020	MYSURU	66	SANTHESARGUR-KADAKOLA 1	SANTHESARAGUR_66	10:00	19:30	9:30	LINE CLEAR AVAILED
103	25-Aug-2020	MYSURU	66	SANTHESARGUR-KADAKOLA 2	SANTHESARAGUR_66	10:00	19:30	9:30	LINE CLEAR AVAILED
104	25-Aug-2020	MYSURU	66	SANTHESARGUR-KABINI 1	NO STATIONS EFFECTED	10:00	19:30	9:30	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
105	25-Aug-2020	MYSURU	66	SANTHESARGUR-KABINI 2	NO STATIONS EFFECTED	10:00	19:30	9:30	LINE CLEAR AVAILED
106	25-Aug-2020	MYSURU	66	SANTHESARGUR-KALSON	NO STATIONS EFFECTED	10:10	19:28	9:18	LINE CLEAR AVAILED
107	25-Aug-2020	MYSURU	66	SANTHESARGUR-MARUTI	NO STATIONS EFFECTED	10:05	19:34	9:29	LINE CLEAR AVAILED
108	25-Aug-2020	MYSURU	66	SANTHESARGUR-B MATTIGERE	B MATKERE_66	10:00	19:30	9:30	LINE CLEAR AVAILED
109	25-Aug-2020	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	21:27	21:33	0:05	LINE FAULT
110	25-Aug-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
111	25-Aug-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
112	25-Aug-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
113	25-Aug-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	6:57	18:09	11:11	LINE CLEAR AVAILED
114	25-Aug-2020	TUMKUR	220	CHITRADURGA 220kv- THALLAK 220	CHITRADURGA_220	6:57	18:02	11:04	LINE CLEAR AVAILED
115	25-Aug-2020	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	6:50	18:08	11:18	LINE CLEAR AVAILED
116	25-Aug-2020	TUMKUR	220	NITTUR 220kv- HASSAN(ARASIKERE)	NITTUR_220	12:04	14:10	2:05	LINE FAULT
117	25-Aug-2020	TUMKUR	220	THALLAK 220kv- CHITRADURGA	THALLAKK_220	6:59	18:02	11:03	LINE CLEAR AVAILED
118	25-Aug-2020	TUMKUR	110	TR-2	HULIYAR_110	13:12	16:39	3:27	LINE CLEAR AVAILED
119	25-Aug-2020	TUMKUR	110	TR-2	KBCROSS_220	12:28	14:28	1:59	TRANSFORMER FAULT
120	25-Aug-2020	TUMKUR	66	ANCHEPALYA 220kv- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	16:10	22:44	6:33	LINE FAULT
121	25-Aug-2020	TUMKUR	66	BELADADARA- KORATAGERE	BELADARA_66	10:36	17:43	7:07	LINE CLEAR AVAILED
122	25-Aug-2020	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	7:00	18:04	11:03	LINE CLEAR AVAILED
123	25-Aug-2020	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	7:01	18:04	11:03	LINE CLEAR AVAILED
124	25-Aug-2020	TUMKUR	66	TR-2	GARAGA_66	16:00	16:32	0:32	LINE CLEAR AVAILED
125	25-Aug-2020	TUMKUR	66	TR-1	HDPURA_66	23:53	23:55	0:02	HAND TRIPPED
126	25-Aug-2020	TUMKUR	66	TR-2	HIREHALLY_66	12:39	13:50	1:10	LINE CLEAR AVAILED
127	25-Aug-2020	TUMKUR	66	HULIYURDURGA- ANCHEPALYA	HULIYURDURGA_66	16:56	22:55	5:58	LINE CLEAR AVAILED
128	25-Aug-2020	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	19:02	19:13	0:10	LINE FAULT
129	26-Aug-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN ,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
130	26-Aug-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN ,LINE FAULT
131	26-Aug-2020	BAGALKOT	110	KUDALSANGAM - ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
132	26-Aug-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
133	26-Aug-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28(30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
134	26-Aug-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46(19.07.0.2020)			LINE OPEN, LINE CLEAR AVAILED
135	26-Aug-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00(21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
136	26-Aug-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
137	26-Aug-2020	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30(01.08.2020)			LINE OPEN, LINE CLEAR AVAILED
138	26-Aug-2020	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
139	26-Aug-2020	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26(17.08.2020)			LINE OPEN, LINE CLEAR AVAILED
140	26-Aug-2020	BAGALKOT	220	GADAG-HARTHI1	STATION NOT AFFECTED GADAG_220	12:19(17.08.2020)			LOAD CURTAILMENT
141	26-Aug-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05(19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
142	26-Aug-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09(20.08.2020)			LINE OPEN, LINE CLEAR AVAILED
143	26-Aug-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09(20.08.2020)			LINE OPEN, LINE CLEAR AVAILED
144	26-Aug-2020	BAGALKOT	110	220/110,LV2	STATION NOT AFFECTED MK HUBLI_220	13:39(24.08.2020)			TRANSFORMER OPEN ,LINE CLEAR AVAILED
145	26-Aug-2020	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	13:53	15:07	1:14	LINE FAULT
146	26-Aug-2020	BAGALKOT	110	SUPA 1&2-AMBEWADI	AMBEWADI_220	9:31	15:24	5:53	LINE CLEAR AVAILED
147	26-Aug-2020	BAGALKOT	110	HIDIKAL-ANKALAGI	ANKALAGI_110	11:23	13:19	1:56	LINE CLEAR AVAILED
148	26-Aug-2020	BAGALKOT	110	110/11KV,HV 3	ANKALI_110	15:39	16:10	0:31	LINE CLEAR AVAILED
149	26-Aug-2020	BAGALKOT	110	110/11KV,HV1	ANKOLA_110	10:31	10:33	0:02	LINE CLEAR AVAILED
150	26-Aug-2020	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	14:34	15:03	0:29	LINE FAULT
151	26-Aug-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	15:41	16:04	0:23	LINE FAULT
152	26-Aug-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR_110	15:41	16:04	0:23	LINE FAULT
153	26-Aug-2020	BAGALKOT	220	ALAMATTI 1-BAGALKOT	BAGALKOT_220	17:41			LINE OPEN, LINE CLEAR AVAILED
154	26-Aug-2020	BAGALKOT	110	CHIKKODI2- RAIBAG	RAIBAG_110	10:50	11:02	0:12	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
155	26-Aug-2020	BAGALKOT	110	NARENDRA220- BELUR	BELUR_110	10:37	13:08	2:31	LINE CLEAR AVAILED
156	26-Aug-2020	BAGALKOT	110	NARENDRA220- MARUTHYUNJAY NAGAR1	MRUTHYUNJAY NAGAR_110	15:15	17:36	2:21	LINE CLEAR AVAILED
157	26-Aug-2020	BAGALKOT	110	MAMADAPUR(B)- SHIRBUR	SHIRBUR_110	16:06	16:10	0:04	HAND TRIPPED
158	26-Aug-2020	BAGALKOT	110	MAMADAPUR(B)- BABLESHWAR	BABLESHWAR_110	16:06	16:51	0:45	LINE CLEAR AVAILED
159	26-Aug-2020	BAGALKOT	110	MAMADAPUR(B)- BELGAUM SOLAR	MAMADAPUR(B)_110	16:06	16:11	0:05	LINE CLEAR AVAILED
160	26-Aug-2020	BAGALKOT	110	MAMADAPUR(B)- BELGAUM SOLAR	MAMADAPUR(B)_110	16:26	16:57	0:31	LINE CLEAR AVAILED
161	26-Aug-2020	BAGALKOT	110	110/11KV, HV3	HUKKERI_110	12:42	14:16	1:34	LINE CLEAR AVAILED
162	26-Aug-2020	BAGALKOT	110	HIDIKAL- RAIBAG (ITANAL)	ITANAL_110	8:35	18:22	9:47	LINE CLEAR AVAILED
163	26-Aug-2020	BAGALKOT	110	110/33KV, HV3	GHATAPRABHA_110, GOKAK MILLS_33, KALLOLI_33	11:36	13:03	1:27	LINE CLEAR AVAILED
164	26-Aug-2020	BAGALKOT	220	BAGEWADI2(NANDIHAL2)- BIJAPUR	BIJAPUR_220, BIJAPUR CITY_110, KIADB BIJAPUR_110, TIKOTA_110, BHUTNAL_110, TORVI_110	18:30	18:52	0:22	LINE FAULT
165	26-Aug-2020	BAGALKOT	220	BAGEWADI1(NANDIHAL1)- BIJAPUR	BIJAPUR_220, BIJAPUR CITY_110, KIADB BIJAPUR_110, TIKOTA_110, BHUTNAL_110, TORVI_110	18:30	18:55	0:25	LINE FAULT
166	26-Aug-2020	BENGALURU	66	HV2	APPAREL PARK	07:58	08:05	00:06	LINE CLEAR AVAILED
167	26-Aug-2020	BENGALURU	66	HV2	APPAREL PARK	18:10	18:20	00:10	LINE CLEAR AVAILED
168	26-Aug-2020	BENGALURU	66	HV2	HOSOR RAMAPURA	14:40	15:50	01:09	TRANSFORMER FAULT
169	26-Aug-2020	BENGALURU	66	HV1	ISRO LAYOUT	08:16	08:25	00:09	TRANSFORMER FAULT
170	26-Aug-2020	BENGALURU	66	HV1	KHODAYS 220	01:15	01:55	00:39	TRANSFORMER FAULT
171	26-Aug-2020	BENGALURU	66	LR BANDE - HBR LAYOUT	LR BANDE	19:45	19:49	00:04	LOAD CHANGE OVER
172	26-Aug-2020	BENGALURU	66	SOUTH CITY - BTM 4TH PHASE	SOUTH CITY	18:20	18:28	00:08	LOAD CHANGE OVER
173	26-Aug-2020	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	09:50	09:55	00:05	LOAD CHANGE OVER
174	26-Aug-2020	BENGALURU	66	PLATINUM CITY - DG 4	PLATINUM CITY	16:00	16:05	00:05	LOAD CHANGE OVER
175	26-Aug-2020	BENGALURU	66	SADLI - MITTEMARI 220	SADLI	05:45	06:04	00:19	LOAD CHANGE OVER
176	26-Aug-2020	BENGALURU	66	HV2	SADLI	12:40	14:05	01:25	LINE CLEAR AVAILED
177	26-Aug-2020	BENGALURU	66	LR BANDE - HEBBAL 220	LR BANDE	18:50	19:25	00:35	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
178	26-Aug-2020	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1 & 2	NO STATION AFFECTED	10:16(17/08/2020)			LINE OPEN, LINE CLEAR AVAILED
179	26-Aug-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN ,LINE FAULT
180	26-Aug-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN ,LINE FAULT
181	26-Aug-2020	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGSAR FACTORY_IPP,CHOWDAPU R 110	00:42	00:51	00:09	LINE FAULT
182	26-Aug-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN ,LINE FAULT
183	26-Aug-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN, LINE CLEAR AVAILED
184	26-Aug-2020	GULBARGA	220	SEDAM-CLN MAX_IPP	SEDAM_220	19:30	21:05	01:35	LINE CLEAR AVAILED
185	26-Aug-2020	GULBARGA	220	LINGASUGUR-SHAHPUR	SHAHAPUR_220	05:00	05:14	00:14	LINE FAULT
186	26-Aug-2020	GULBARGA	220	LINGASUGUR-SHAHPUR	SHAHAPUR_220	05:33	07:47	02:14	LINE FAULT
187	26-Aug-2020	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGSAR FACTORY_IPP,CHOWDAPU R 110	00:42	00:51	00:09	LINE FAULT
188	26-Aug-2020	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGSAR FACTORY_IPP,CHOWDAPU R 110	02:18	02:27	00:09	LINE FAULT
189	26-Aug-2020	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGSAR FACTORY_IPP,CHOWDAPU R 110	03:20	03:35	00:15	LINE FAULT
190	26-Aug-2020	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGAON_110, MARUGUTTI 110	06:04	06:11	00:07	LINE FAULT
191	26-Aug-2020	GULBARGA	110	SHAHPUR-SHAHBAD1	SHAHPUR_110	10:55	11:10	00:15	LINE CLEAR AVAILED
192	26-Aug-2020	GULBARGA	110	HV2	CHICHOLI_110	19:13	19:25	00:12	LOAD CURTAILMENT
193	26-Aug-2020	GULBARGA	110	HV1	GABUR_110	19:14	19:45	00:31	LOAD CURTAILMENT
194	26-Aug-2020	GULBARGA	110	HV3	GULBARGA WEST_110	16:01	16:45	00:44	LINE CLEAR AVAILED
195	26-Aug-2020	GULBARGA	110	HV2	HATTI_110	19:13	19:18	00:05	LOAD CURTAILMENT
196	26-Aug-2020	GULBARGA	110	ITTAGGI-HBHALLI	HAGARIBOMMANAHALLI_66,UPNAYAKANAHALLI 66	12:10	13:10	01:00	LINE CLEAR AVAILED
197	26-Aug-2020	GULBARGA	110	HV3,HV2	ITTAGI_220	16:05	16:50	00:45	LINE CLEAR AVAILED
198	26-Aug-2020	GULBARGA	110	IATTGGI-HIREHADAGALLI1	HIREHADAGALLI_66	18:21	18:31	00:10	LINE FAULT
199	26-Aug-2020	GULBARGA	110	HV2	JEWARGI_110	19:13	19:29	00:16	LOAD CURTAILMENT
200	26-Aug-2020	GULBARGA	110	HV3	KAMPLI_GLB_110	19:13	19:56	00:43	LOAD CURTAILMENT
201	26-Aug-2020	GULBARGA	110	HV1	KURKUNTA_110	19:13	19:35	00:22	LOAD CURTAILMENT
202	26-Aug-2020	GULBARGA	110	HV1	MAHAGOAN_110	19:13	19:38	00:25	LOAD CURTAILMENT
203	26-Aug-2020	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATI 110	01:37	01:45	00:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
204	26-Aug-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	10:30	12:42	02:12	LINE CLEAR AVAILED
205	26-Aug-2020	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVAT TI_110	19:53	20:00	00:07	LINE FAULT
206	26-Aug-2020	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVAT TI_110	20:25	20:32	00:07	LINE FAULT
207	26-Aug-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:28	20:33	00:05	LINE FAULT
208	26-Aug-2020	GULBARGA	110	HV1	RAJESHWAR_110	19:13	19:24	00:11	LOAD CURTAILMENT
209	26-Aug-2020	GULBARGA	110	HV1	SIRWAR_110	19:13	19:25	00:12	LOAD CURTAILMENT
210	26-Aug-2020	GULBARGA	110	HV1	SHAHAPUR_220	14:03	15:52	01:49	LINE CLEAR AVAILED
211	26-Aug-2020	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	19:09 (25.08.2020)	13:52 (26.08.2020)	18:42 hrs	LINE CHARGED
212	26-Aug-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	19:09 (25.08.2020)	13:52 (26.08.2020)	18:42 hrs	LINE CHARGED
213	26-Aug-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:07 (25.08.2020)	6:19 (26.08.2020)	8:11 hrs	LINE CHARGED
214	26-Aug-2020	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN, LINE CLEAR AVAILED
215	26-Aug-2020	HASSAN	400	TALAGU- NELAMANGALA#2	TALAGUPPA_400	18:10 (24.08.2020)			LINE OPEN, LINE CLEAR AVAILED
216	26-Aug-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	17:52 (26.08.2020)			LINE OPEN, LINE CLEAR AVAILED
217	26-Aug-2020	HASSAN	110	MRSSHM-BADRAVATY3	MRSMSG-220	11:44	11:50	00:06	HAND TRIPPED
218	26-Aug-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	05:46	17:29	11:43	LINE CLEAR AVAILED
219	26-Aug-2020	HASSAN	110	HV2	GANDASI_110	19:14	19:28	00:14	LOAD CURTAILMENT
220	26-Aug-2020	HASSAN	110	HV2	GERUMARA_110	19:15	19:45	00:30	LOAD CURTAILMENT
221	26-Aug-2020	HASSAN	110	HV1	JAVAGAL_66	19:15	19:22	00:07	LOAD CURTAILMENT
222	26-Aug-2020	HASSAN	110	JOG-JST1	mghejog_gen	13:20	13:25	00:05	LINE FAULT
223	26-Aug-2020	HASSAN	110	JOG-NK1	mghejog_gen	13:20	13:25	00:05	LINE FAULT
224	26-Aug-2020	HASSAN	110	KADUR-YGTI	KADUR_220	10:37	13:52	03:15	LINE CLEAR AVAILED
225	26-Aug-2020	HASSAN	110	HV1	KONDENALU_110	19:15	19:31	00:16	LOAD CURTAILMENT
226	26-Aug-2020	HASSAN	110	NERALA-TEREKERE	NERALAKERE_110	09:59	11:34	01:35	MAIN SUPPLY FAILURE
227	26-Aug-2020	HASSAN	110	SHIVAPUR-NERLEKERE	SHIVAPURA_66	10:13	11:30	01:17	LINE CLEAR AVAILED
228	26-Aug-2020	HASSAN	66	HV2	BASAVAGHATTA_66	19:14	19:28	00:14	LOAD CURTAILMENT
229	26-Aug-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	19:13	19:19	00:06	LOAD CURTAILMENT
230	26-Aug-2020	HASSAN	66	KIADB HA- RAMESWARNAGAR	KIADB_66	06:23	06:30	00:07	LINE FAULT
231	26-Aug-2020	HASSAN	66	HV1	MALALI_66	20:15	21:09	00:54	TRANSFORMER FAULT
232	26-Aug-2020	HASSAN	66	HV2	RAMESHWARNAGAR_66	19:15	19:36	00:21	LOAD CURTAILMENT
233	26-Aug-2020	HASSAN	66	HV2	SALAGAME_66	19:15	19:23	04:45	LOAD CURTAILMENT
234	26-Aug-2020	MYSURU	220	KADAKOLA-BASTIPURA 2	NO STATIONS EFFECTED	11:00	16:19	5:18	LINE CLEAR AVAILED
235	26-Aug-2020	MYSURU	220	KADAKOLA-BEGUR-2	NO STATIONS EFFECTED	12:10	14:12	2:02	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
236	26-Aug-2020	MYSURU	66	KUSHALANAGARA 220-BYLKUPPE	BYLUKUPPE_66 PERIYAPATNA_66 PONNAMPET_66 VIRAJPET_66 HANAGODU_66	12:04	14:15	2:10	LINE CLEAR AVAILED
237	26-Aug-2020	MYSURU	66	KUSHALANAGARA 220-PERIPATNA-1	BYLUKUPPE_66 PERIYAPATNA_66 PONNAMPET_66 VIRAJPET_66 HANAGODU_66	12:04	14:15	2:10	LINE CLEAR AVAILED
238	26-Aug-2020	MYSURU	66	HV1	KUSHALANAGARA_66	19:18	19:38	0:20	LOAD CURTAILMENT
239	26-Aug-2020	MYSURU	66	HV2	SATHEGALA_66	19:10	19:15	0:05	LOAD CURTAILMENT
240	26-Aug-2020	MYSURU	66	HV1	BESAGARAHALLI_66	19:12	19:18	0:05	LOAD CURTAILMENT
241	26-Aug-2020	MYSURU	66	HV1	BGNAGARA_66	19:14	19:20	0:05	LOAD CURTAILMENT
242	26-Aug-2020	MYSURU	66	HV1	BGPURA_66	19:14	19:35	0:21	LOAD CURTAILMENT
243	26-Aug-2020	MYSURU	66	HV1	BEGUR_66	19:12	19:14	0:01	LOAD CURTAILMENT
244	26-Aug-2020	MYSURU	66	HV1	BILIKERE_66	19:15	19:24	0:09	LOAD CURTAILMENT
245	26-Aug-2020	MYSURU	66	HV1	DODDINADUVADI_66	19:15	19:20	0:05	LOAD CURTAILMENT
246	26-Aug-2020	MYSURU	66	HV1	HANAGODU_66	19:16	19:24	0:08	LOAD CURTAILMENT
247	26-Aug-2020	MYSURU	66	HV1	MEGALAPURA_66	19:14	19:30	0:15	LOAD CURTAILMENT
248	26-Aug-2020	MYSURU	66	HV1	PANDAVAPURA_66	19:15	19:27	0:11	LOAD CURTAILMENT
249	26-Aug-2020	MYSURU	66	HV2	PANDAVAPURA_66	12:19	13:33	1:14	LINE CLEAR AVAILED
250	26-Aug-2020	MYSURU	66	HV1	SATHEGALA_66	19:13	19:15	0:01	LOAD CURTAILMENT
251	26-Aug-2020	MYSURU	66	HV1	YELANDUR_66	19:12	19:19	0:06	LOAD CURTAILMENT
252	26-Aug-2020	MYSURU	66	HV2	ADDIHALLI_66	19:14	19:23	0:09	LOAD CURTAILMENT
253	26-Aug-2020	MYSURU	66	HV2	AKKIHBBAL_66	19:13	19:18	0:05	LOAD CURTAILMENT
254	26-Aug-2020	MYSURU	66	HV2	BOOKANAKERE_66	19:13	19:20	0:07	LOAD CURTAILMENT
255	26-Aug-2020	MYSURU	66	HV2	CHINAKURALI_66	19:13	19:35	0:21	LOAD CURTAILMENT
256	26-Aug-2020	MYSURU	66	HV2	ELAVALA_66	19:14	19:35	0:20	LOAD CURTAILMENT
257	26-Aug-2020	MYSURU	66	HV2	GVGUDI_66	19:15	19:18	0:03	LOAD CURTAILMENT
258	26-Aug-2020	MYSURU	66	HV2	HANNUR_66	19:15	19:30	0:14	LOAD CURTAILMENT
259	26-Aug-2020	MYSURU	66	HV2	KIRUGAVALU_66	19:15	19:45	0:29	LOAD CURTAILMENT
260	26-Aug-2020	MYSURU	66	HV2	KMDODDI_66	19:56	20:07	0:11	HAND TRIPPED
261	26-Aug-2020	MYSURU	66	HV2	SANTHEMARAHALLI_66	19:13	19:14	0:01	LOAD CURTAILMENT
262	26-Aug-2020	MYSURU	66	HV2	TUBINAKERE_220	12:20	12:42	0:22	TRANSFORMER FAULT
263	26-Aug-2020	MYSURU	66	HV2	TUBINAKERE_220	12:47	12:57	0:10	TRANSFORMER FAULT
264	26-Aug-2020	MYSURU	66	HV2	DODDARAYAPET_66	19:15	19:25	0:09	LOAD CURTAILMENT
265	26-Aug-2020	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	8:06	8:20	0:13	LINE FAULT
266	26-Aug-2020	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	21:36	22:33	0:56	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
267	26-Aug-2020	MYSURU	66	VAJAMANGALA-DEVANOOR(MYS)	DEVANOORMYS_66 RAJEEVNAGARA_66	10:07	16:10	6:03	NFBC ISSUED
268	26-Aug-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
269	26-Aug-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
270	26-Aug-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
271	26-Aug-2020	TUMKUR	220	CHITRADURGA 220-GUTTUR 220	CHITRADURGA_220	15:38	19:55	4:16	LINE CLEAR AVAILED
272	26-Aug-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	8:16	17:19	9:03	LINE CLEAR AVAILED
273	26-Aug-2020	TUMKUR	220	GUTTUR 400-CHITRADURGA 220	CHITRADURGA_220	15:35	19:55	4:20	LINE CLEAR AVAILED
274	26-Aug-2020	TUMKUR	110	TR-1	TURUVEKERE_110	19:31	19:57	0:26	TRANSFORMER FAULT
275	26-Aug-2020	TUMKUR	110	TR-1	KALLUR_110	18:27	18:32	0:04	LINE CLEAR AVAILED
276	26-Aug-2020	TUMKUR	110	TR-2	KBCROSS_220	12:09	13:46	1:37	LINE CLEAR AVAILED
277	26-Aug-2020	TUMKUR	66	CHITRADURGA 220kv-HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	7:53	11:06	3:12	LINE CLEAR AVAILED
278	26-Aug-2020	TUMKUR	66	TR-1	LINGDHALLI_66	14:43	14:50	0:06	TRANSFORMER FAULT
279	26-Aug-2020	TUMKUR	66	PAVAGADA-SHYLAPURA	SHYLAPURA_66,YNHOSKOTE_66,LINGDHALLI_66,MAN GALWADA_66	14:43	16:10	1:26	LINE FAULT
280	26-Aug-2020	TUMKUR	66	SIRA- MADHUGIRI 2	SIRA_66	6:56	7:01	0:04	MAIN SUPPLY FAILURE
281	26-Aug-2020	TUMKUR	66	TR-2	TELAGI_66	7:50	8:07	0:17	LINE CLEAR AVAILED
282	26-Aug-2020	TUMKUR	66	TR-2	GULIGENAHALLI_66	12:07	12:45	0:37	LINE CLEAR AVAILED
283	26-Aug-2020	TUMKUR	66	TR-2	HALURAMESHWARA_66	17:47	18:10	0:22	LINE CLEAR AVAILED
284	27-Aug-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN ,LINE FAULT
285	27-Aug-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN ,LINE FAULT
286	27-Aug-2020	BAGALKOT	110	KUDALSANGAM - ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
287	27-Aug-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
288	27-Aug-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28(30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
289	27-Aug-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46(19.07.0.2020)			LINE OPEN, LINE CLEAR AVAILED
290	27-Aug-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00(21.07.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
291	27-Aug-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
292	27-Aug-2020	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN, LINE CLEAR AVAILED
293	27-Aug-2020	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
294	27-Aug-2020	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26 (17.08.2020)			LINE OPEN, LINE CLEAR AVAILED
295	27-Aug-2020	BAGALKOT	220	GADAG-HARTHI1	STATION NOT AFFECTED GADAG_220	12:19 (17.08.2020)			LOAD CURTAILMENT
296	27-Aug-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
297	27-Aug-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09 (20.08.2020)			LINE OPEN, LINE CLEAR AVAILED
298	27-Aug-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09 (20.08.2020)			LINE OPEN, LINE CLEAR AVAILED
299	27-Aug-2020	BAGALKOT	110	220/110,LV2	STATION NOT AFFECTED MK HUBLI_220	13:39 (24.08.2020)	9:42 (27.08.2020)	68:03hrs	TRANSFORMER CHARGED
300	27-Aug-2020	BAGALKOT	220	ALAMATTI 1-BAGALKOT	BAGALKOT_220	17:41 (26.08.2020)	18:33 (27.08.2020)	24:52hrs	LINE CHARGED
301	27-Aug-2020	BAGALKOT	110	110/33KV,HV 1	ANKALI_110 &KHOTAWADI&SHIRAGUP PI_33	3:40	8:28	4:48	TRANSFORMER FAULT
302	27-Aug-2020	BAGALKOT	110	110/33KV,HV 2	ANKOLA_110 &MASTIKATTA&SEABIRD_33	16:48	18:15	1:27	LINE CLEAR AVAILED
303	27-Aug-2020	BAGALKOT	220	AMBEWADI-NARENDRA 1&2	AMBEWADI_220	10:56	15:04	4:08	LINE CLEAR AVAILED
304	27-Aug-2020	BAGALKOT	110	110/11KV,HV2	GOKAK_110	13:07	13:28	0:21	HAND TRIPPED
305	27-Aug-2020	BAGALKOT	110	110/11KV,HV1	GULEDGUDD_110	17:13	17:38	0:25	HAND TRIPPED
306	27-Aug-2020	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	12:46	13:05	0:19	HAND TRIPPED
307	27-Aug-2020	BAGALKOT	220	220/110KV,HV 1	BAGALKOT_220	13:05	14:58	1:53	LINE CLEAR AVAILED
308	27-Aug-2020	BAGALKOT	110	220/110KV,LV 1	BAGALKOT_220	13:05 (27.08.2020)			TRANSFORMER OPEN ,LINE CLEAR AVAILED
309	27-Aug-2020	BAGALKOT	110	HUBLI- KADANKOPPA	KADANKOPPA_110	10:27	12:59	2:32	LINE FAULT
310	27-Aug-2020	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	10:51	14:10	3:19	LINE CLEAR AVAILED
311	27-Aug-2020	BAGALKOT	110	MKHUBLI220- MK HUBLI	MK HUBLI_110	11:36	11:46	0:10	LINE CLEAR AVAILED
312	27-Aug-2020	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	15:25	17:40	2:15	LINE CLEAR AVAILED
313	27-Aug-2020	BAGALKOT	110	110/11KV, HV2	KANABARGI LAYOUT_110	15:21	16:05	0:44	LINE CLEAR AVAILED
314	27-Aug-2020	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	22:14 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
315	27-Aug-2020	BAGALKOT	220	BELGAUM- NARENDRA2	BELGAUM_220	23:18 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
316	27-Aug-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	6:23	6:36	0:13	LINE FAULT
317	27-Aug-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	18:44	18:52	0:08	LINE FAULT
318	27-Aug-2020	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KENGERI SATELLITE TOWN	8:14	8:19	0:05	LOAD CHANGE OVER
319	27-Aug-2020	BENGALURU	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN, SIR MV LAYOUT	2:44	4:13	1:29	MAIN SUPPLY FAILURE
320	27-Aug-2020	BENGALURU	66	KUMBALAGODU - KENGERI SATELLITE TOWN	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	2:45	2:51	0:06	LOAD CHANGE OVER
321	27-Aug-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	7:35	7:51	0:15	LINE FAULT
322	27-Aug-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	7:46	7:52	0:05	MAIN SUPPLY FAILURE
323	27-Aug-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	7:35	7:52	0:16	MAIN SUPPLY FAILURE
324	27-Aug-2020	BENGALURU	66	SOUTH CITY - BTM 4TH PHASE	SOUTH CITY	4:22	4:32	0:10	LOAD CHANGE OVER
325	27-Aug-2020	BENGALURU	66	VRISHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	3:07	3:15	0:07	MAIN SUPPLY FAILURE
326	27-Aug-2020	BENGALURU	220	VRISHBHAVATHI 220 - TATAGUNI 220 (EHT)	VRISHBHAVATHI 220	2:44	3:58	1:14	MAIN SUPPLY FAILURE
327	27-Aug-2020	BENGALURU	66	BAGHMANE WORLD TECH PARK - HAL 2	BAGHMANE WORLD TECH PARK	15:53	16:01	0:07	LOAD CHANGE OVER
328	27-Aug-2020	BENGALURU	66	BAGHMANE WORLD TECH PARK - HOODY 2	BAGHMANE WORLD TECH PARK	15:24	15:28	0:04	LOAD CHANGE OVER
329	27-Aug-2020	BENGALURU	220	SOMANAHALLI 220 - TATAGUNI (EHT)	TATAGUNI (EHT), VRISHBHAVATHI 220	2:44	2:56	0:11	LINE FAULT
330	27-Aug-2020	BENGALURU	220	SOMANAHALLI 220 - TATAGUNI (EHT)	TATAGUNI (EHT)	4:57	7:00	0:11	LINE CLEAR AVAILED
331	27-Aug-2020	BENGALURU	66	SADLI - MITTEMARI 220	SADLI	16:05	18:30	2:25	LINE CLEAR AVAILED
332	27-Aug-2020	BENGALURU	220	LV1	MALUR 220	7:35	7:50	0:14	TRANSFORMER FAULT
333	27-Aug-2020	BENGALURU	66	HV2	MITTEMARI 220	12:11	12:14	0:02	LOAD CHANGE OVER
334	27-Aug-2020	BENGALURU	66	HV1	NARASAPURA	14:31	15:35	1:03	LINE CLEAR AVAILED
335	27-Aug-2020	BENGALURU	66	HV2	REMCO	11:00	11:07	0:06	LINE CLEAR AVAILED
336	27-Aug-2020	BENGALURU	66	HV1	REMCO	4:35	4:49	0:14	LINE CLEAR AVAILED
337	27-Aug-2020	BENGALURU	66	HV1	REMCO	13:05	13:10	0:05	LINE CLEAR AVAILED
338	27-Aug-2020	BENGALURU	66	HV1	VIJAYANAGARA	2:53	3:47	0:53	MAIN SUPPLY FAILURE
339	27-Aug-2020	BENGALURU	220	HV1	VRISHBHAVATHI 220	2:44	3:26	0:41	MAIN SUPPLY FAILURE
340	27-Aug-2020	BENGALURU	220	HV2	VRISHBHAVATHI 220	2:44	3:27	0:42	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
341	27-Aug-2020	BENGALURU	66	HV1	BAGHMANE WORLD TECH PARK	11:40	11:50	0:10	LINE CLEAR AVAILED
342	27-Aug-2020	BENGALURU	66	HV2	BAGHMANE WORLD TECH PARK	9:03	9:15	0:12	LINE CLEAR AVAILED
343	27-Aug-2020	BENGALURU	66	HV1	SADLI	15:15	18:15	3:00	LINE CLEAR AVAILED
344	27-Aug-2020	BENGALURU	66	BAGEPALLI - MITTEMARI 220	BAGEPALLI	12:20	12:25	0:05	LOAD CHANGE OVER
345	27-Aug-2020	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1 & 2	NO STATION AFFECTED	10:16(17/08/2020)	15:59:32	269:43hrs	LINE CHARGED
346	27-Aug-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN ,LINE FAULT
347	27-Aug-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN ,LINE FAULT
348	27-Aug-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN ,LINE FAULT
349	27-Aug-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN, LINE CLEAR AVAILED
350	27-Aug-2020	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	21:44	21:55	00:11	LINE FAULT
351	27-Aug-2020	GULBARGA	110	HV2	HANUMANAL_110	07:20	07:40	00:20	LINE CLEAR AVAILED
352	27-Aug-2020	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGAON_110, MARUGUTTI_110, ALAND_110, KADAGANCHI_110	03:16	03:27	00:11	LINE FAULT
353	27-Aug-2020	GULBARGA	110	MASKI- SINDHANOOR	MASKI_110	01:13	01:25	00:12	MAIN SUPPLY FAILURE
354	27-Aug-2020	GULBARGA	110	MASKI- SINDHANOOR	MASKI_110	03:34	03:46	00:12	MAIN SUPPLY FAILURE
355	27-Aug-2020	GULBARGA	110	MASKI- SINDHANOOR	MASKI_110	05:34	05:50	00:16	MAIN SUPPLY FAILURE
356	27-Aug-2020	GULBARGA	110	SINDHANOOR220-SIRUGUPPA	SIRUGUPPA_110, DHADESUGUR_110, TEKKALKOTE_110, NSLSUGARS IPP	14:57	15:07	00:10	LINE FAULT
357	27-Aug-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	20:44	20:50	00:06	LINE FAULT
358	27-Aug-2020	GULBARGA	110	HV1	KAVITHAL_110	09:30	16:25	06:55	LINE CLEAR AVAILED
359	27-Aug-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	18:10 (24.08.2020)	7:26 (27.08.2020)	61:15 hrs	LINE CHARGED
360	27-Aug-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	17:52 (26.08.2020)	9:18 (27.08.2020)	13:25 hrs	LINE CHARGED
361	27-Aug-2020	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN, LINE CLEAR AVAILED
362	27-Aug-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:28(27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
363	27-Aug-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	19:57 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
364	27-Aug-2020	HASSAN	220	MRSSHM-VARAH12	MRS MG_220	10:17	20:12	09:55	NFBC ISSUED
365	27-Aug-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	10:17	20:13	09:56	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
366	27-Aug-2020	HASSAN	110	HV1	BANAVARA_110	14:00	14:08	00:08	LINE CLEAR AVAILED
367	27-Aug-2020	HASSAN	110	HV1	BANAVARA_110	14:10	14:20	00:10	LINE CLEAR AVAILED
368	27-Aug-2020	HASSAN	110	HV2	BARANGI_66	08:30	08:34	00:04	HAND TRIPPED
369	27-Aug-2020	HASSAN	110	HALADY11-HIRIYADKA	HALADY_110	10:27	12:02	01:35	LINE CLEAR AVAILED
370	27-Aug-2020	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	10:28	11:53	01:25	NFBC ISSUED
371	27-Aug-2020	HASSAN	110	HV1	PUTTUR_110	10:29	14:28	03:59	LINE CLEAR AVAILED
372	27-Aug-2020	HASSAN	110	HV2	PUTTUR_110	10:29	14:28	03:59	LINE CLEAR AVAILED
373	27-Aug-2020	HASSAN	110	HV2	PUTTUR_110	16:14	16:51	00:37	LINE CLEAR AVAILED
374	27-Aug-2020	HASSAN	110	HV4	PUTTUR_110	09:19	11:14	01:55	LINE CLEAR AVAILED
375	27-Aug-2020	HASSAN	66	CRPATNA2-MATTANAVILE	CRPATNA_220	14:38	14:53	00:15	LINE FAULT
376	27-Aug-2020	HASSAN	66	DODDAHA-.HOOTGALLI	DODDAHALLY_66	09:02	11:57	02:55	NFBC ISSUED
377	27-Aug-2020	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	16:59	17:05	0:05	LINE FAULT
378	27-Aug-2020	MYSURU	66	CR NAGARA-DR PETE 1	NO STATIONS EFFECTED	16:49	17:08	0:18	LINE FAULT
379	27-Aug-2020	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	17:00	17:08	0:08	LINE FAULT
380	27-Aug-2020	MYSURU	66	CR NAGARA-YELANDUR	YELANDUR_66 MAMBALLI_66	17:00	17:07	0:07	LINE FAULT
381	27-Aug-2020	MYSURU	66	CR NAGARA-HONNALLI	ATTIGULIPURA_66 HONNALLY_MYS_66	16:59	17:07	0:07	LINE FAULT
382	27-Aug-2020	MYSURU	66	HD KOTE-KADAKOLA	ANTHARSANTHE_66 HDKOTE_66,	13:20	15:53	2:33	LINE CLEAR AVAILED
383	27-Aug-2020	MYSURU	66	HOOTAGALLI-FTS1	NO STATIONS EFFECTED	10:12	12:15	2:03	LINE CLEAR AVAILED
384	27-Aug-2020	MYSURU	220	HOOTAGALLI-KADAKOLA	NO STATIONS EFFECTED	10:50	13:32	2:42	NFBC ISSUED
385	27-Aug-2020	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	10:25	14:20	3:55	LINE CLEAR AVAILED
386	27-Aug-2020	MYSURU	66	KADAKOLA-VAJMANGALA 1	AYRALLI_66 MARADIHUNDI_66	12:08	13:58	1:50	LINE CLEAR AVAILED
387	27-Aug-2020	MYSURU	66	KADAKOLA-VAJMANGALA 2	NO STATIONS INTERRUPTED	12:08	13:58	1:50	LINE CLEAR AVAILED
388	27-Aug-2020	MYSURU	66	HV2	KMDODDI_66	10:45	15:00	4:15	LINE CLEAR AVAILED
389	27-Aug-2020	MYSURU	66	HV2	KMDODDI_66	16:01	17:47	1:46	LINE CLEAR AVAILED
390	27-Aug-2020	MYSURU	66	HV1	MADESWARAPURA_66	12:58	14:45	1:46	LINE CLEAR AVAILED
391	27-Aug-2020	MYSURU	66	HV2	MADESWARAPURA_66	10:10	14:45	4:35	LINE CLEAR AVAILED
392	27-Aug-2020	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	11:10 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
393	27-Aug-2020	MYSURU	66	MADHUVANAHALLI-HANNUR1	NO STATIONS EFFECTED	14:16	14:29	0:13	LINE CLEAR AVAILED
394	27-Aug-2020	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	10:12 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
395	27-Aug-2020	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	10:44	14:47	4:03	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
396	27-Aug-2020	MYSURU	220	HV2	MADHUVANAHALLI_220	11:37	13:40	2:02	LINE CLEAR AVAILED
397	27-Aug-2020	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	13:51	15:18	1:26	LINE CLEAR AVAILED
398	27-Aug-2020	MYSURU	66	MADHUVANAHALLI- HEBBANI	NO STATIONS EFFECTED	12:05	14:49	2:43	LINE CLEAR AVAILED
399	27-Aug-2020	MYSURU	66	HV2	PANDAVAPURA_66	22:04	22:12	0:08	TRANSFORMER FAULT
400	27-Aug-2020	MYSURU	66	HV1	PONNAMPET_66	13:50	16:05	2:14	LINE CLEAR AVAILED
401	27-Aug-2020	MYSURU	66	SANTESARGUR-B MATTIGERE	B MATKERE_66	14:05	15:45	1:40	NFBC ISSUED
402	27-Aug-2020	MYSURU	66	HV1	SINDHUVALI_66	13:10	13:55	0:45	LINE CLEAR AVAILED
403	27-Aug-2020	MYSURU	66	HV2	SINDHUVALI_66	10:15	13:15	3:00	LINE CLEAR AVAILED
404	27-Aug-2020	MYSURU	66	TARIPURA-MHS	NO STATIONS EFFECTED	0:22	0:35	0:12	LINE FAULT
405	27-Aug-2020	MYSURU	66	VIJAYANAGARA- BANNIMANTAP	BANNIMANTAP_66	10:06	16:55	6:49	NFBC ISSUED
406	27-Aug-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
407	27-Aug-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
408	27-Aug-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
409	27-Aug-2020	TUMKUR	220	TR-2	ANCHEPALYA_220	10:15	12:27	2:11	LINE CLEAR AVAILED
410	27-Aug-2020	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	11:28	16:00	4:32	LINE CLEAR AVAILED
411	27-Aug-2020	TUMKUR	110	TR-2	TURUVEKERE_110	8:50	9:22	0:32	TRANSFORMER FAULT
412	27-Aug-2020	TUMKUR	110	TR-1	KALLUR_110	16:00	16:12	0:11	LINE CLEAR AVAILED
413	27-Aug-2020	TUMKUR	66	TR-2(LV SIDE)	ANCHEPALYA_220	10:15	12:27	2:12	LINE CLEAR AVAILED
414	27-Aug-2020	TUMKUR	66	ANCHEPALYA 220kv- YEDIYUR(BG NAGAR)	YEDIYUR_66	20:41	21:04	0:23	LINE FAULT
415	27-Aug-2020	TUMKUR	66	BELADADARA- KORATAGERE	BELADARA_66	9:38	9:47	0:08	LINE CLEAR AVAILED
416	27-Aug-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	12:55	13:06	0:11	LINE FAULT
417	27-Aug-2020	TUMKUR	66	RANGANATHAPURA- WLSUNSOLAR1	WELSPUN SOLAR_IPP_66	17:25	19:08	1:43	LINE FAULT
418	27-Aug-2020	TUMKUR	66	RANGANATHAPURA- WLSUNSOLAR2	WELSPUN SOLAR_IPP_66	17:25	18:58	1:33	LINE FAULT
419	27-Aug-2020	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:49	13:37	3:47	LINE FAULT
420	27-Aug-2020	TUMKUR	66	TR-1	YEDIYUR_66	11:50	13:59	2:09	LINE CLEAR AVAILED
421	28-Aug-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	18:46(19.07.0.2020)			LINE OPEN, LINE CLEAR AVAILED
422	28-Aug-2020	BAGALKOT	110	110/11KV, HV2	SHIROL_110	15:48	15:57	00:09	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
423	28-Aug-2020	BAGALKOT	110	110/11KV,HV 1	AREMALLAPUR_110	15:10	16:30	01:20	LINE CLEAR AVAILED
424	28-Aug-2020	BAGALKOT	110	110/11KV,HV 1	BABALESHWAR_110	12:29	13:00	00:31	LINE CLEAR AVAILED
425	28-Aug-2020	BAGALKOT	110	110/11KV,HV 1	BABALESHWAR_110	17:31	18:22	00:51	LINE CLEAR AVAILED
426	28-Aug-2020	BAGALKOT	110	110/11KV,HV 2	KANABARGI LAY OUT_110	15:48	16:53	01:05	LINE CLEAR AVAILED
427	28-Aug-2020	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
428	28-Aug-2020	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	12:48	18:17	05:29	LINE CLEAR AVAILED
429	28-Aug-2020	BAGALKOT	110	220/110KV,LV 1	BAGALKOT_220	13:05 (27.08.2020)			TRANSFORMER OPEN ,LINE CLEAR AVAILED
430	28-Aug-2020	BAGALKOT	110	BELGAUM220- VADAGOAN	VADAGOAN_110	04:41	11:42	07:01	LINE FAULT
431	28-Aug-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
432	28-Aug-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1& 2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
433	28-Aug-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
434	28-Aug-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN ,LINE FAULT
435	28-Aug-2020	BAGALKOT	110	KUDALSANGAM - ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
436	28-Aug-2020	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN, LINE CLEAR AVAILED
437	28-Aug-2020	BAGALKOT	110	VAJRAMATTI220- LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
438	28-Aug-2020	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED KARWAR_220	11:20	14:33	03:13	LINE CLEAR AVAILED
439	28-Aug-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN ,LINE FAULT
440	28-Aug-2020	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26 (17.08.2020)			LINE OPEN, LINE CLEAR AVAILED
441	28-Aug-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)	18:43 (28.08.2020)	841:17 hrs	LOAD CURTAILMENT
442	28-Aug-2020	BAGALKOT	220	BAGEWADI- BIJAPUR1&2(NANDIHAL1 &2)	STATION NOT AFFECTED BAGEWADI_220	21:07 (28.08.2020)			LOAD CURTAILMENT
443	28-Aug-2020	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	22:14 (27.08.2020)	9:42 (28.08.2020)	11:28 hrs	LINE CHARGED
444	28-Aug-2020	BAGALKOT	220	BELGAUM- NARENDRA2	BELGAUM_220	23:18 (27.08.2020)	8:57 (28.08.2020)	9:39 hrs	LINE CHARGED
445	28-Aug-2020	BAGALKOT	220	BELGAUM- NARENDRA2	BELGAUM_220	20:26 (28.08.2020)			LINE OPEN, LINE CLEAR AVAILED
446	28-Aug-2020	BAGALKOT	220	GADAG-HARTHI1	STATION NOT AFFECTED GADAG_220	12:19 (17.08.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
447	28-Aug-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09(20.08.2020)			LINE OPEN, LINE CLEAR AVAILED
448	28-Aug-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09(20.08.2020)			LINE OPEN, LINE CLEAR AVAILED
449	28-Aug-2020	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	12:48	16:43	03:55	LINE CLEAR AVALIED
450	28-Aug-2020	BAGALKOT	220	KADRA1- KARWAR	KARWAR_220, ARGA_110, ANKOLA_110	01:10	01:30	00:20	LINE FAULT
451	28-Aug-2020	BAGALKOT	220	KADRA1- KARWAR	KARWAR_220, ARGA_110, ANKOLA_110	12:48	14:32	01:44	LINE CLEAR AVALIED
452	28-Aug-2020	BAGALKOT	220	KADRA2- KARWAR	KARWAR_220	01:10	14:35	13:25	LINE FAULT
453	28-Aug-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN ,LINE FAULT
454	28-Aug-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN ,LINE FAULT
455	28-Aug-2020	BENGALURU	66	CHELUR - YENNIGADALE	CHELUR	13:00	13:15	00:15	LINE CLEAR AVALIED
456	28-Aug-2020	BENGALURU	66	HV1	SOMAYAJJANAHALLI	16:09	16:15	00:05	TRANSFORMER FAULT
457	28-Aug-2020	BENGALURU	66	HV1	NARASAPURA	14:00	19:07	05:07	LINE CLEAR AVALIED
458	28-Aug-2020	BENGALURU	66	HV1	KIADB HARDWARE PARK DEVANAHALLI 220	17:13	17:32	00:19	LINE CLEAR AVALIED
459	28-Aug-2020	BENGALURU	66	HV2	SOMAYAJJANAHALLI	16:09	18:15	02:05	MAIN SUPPLY FAILURE
460	28-Aug-2020	BENGALURU	66	HV2	N G HULKUR	12:30	12:59	00:29	TRANSFORMER FAULT
461	28-Aug-2020	BENGALURU	66	SOMAYAJANAHALLI - LAKSHMIPURA	SOMAYAJANAHALLI	16:09	16:13	00:03	LINE FAULT
462	28-Aug-2020	GULBARGA	66	HV2	TAMBRAHALLI_66	10:58	11:04	00:06	TRANSFORMER FAULT
463	28-Aug-2020	GULBARGA	110	HV1	MANVI_110	19:26	19:32	00:06	TRANSFORMER FAULT
464	28-Aug-2020	GULBARGA	110	SEDAM-VICATSAGAR CEMENTS	VICATASAGAR CEMENTS_IPP	06:12	06:32	00:20	LINE FAULT
465	28-Aug-2020	GULBARGA	110	SHAHPUR220-SHAHPUR2	SHAHPUR_110	15:33	15:40	00:07	LINE FAULT
466	28-Aug-2020	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL_IPP	04:00	04:12	00:12	LINE FAULT
467	28-Aug-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN, LINE CLEAR AVAILED
468	28-Aug-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN ,LINE FAULT
469	28-Aug-2020	HASSAN	110	HV2	KONAJE_110	17:33	17:41	00:08	TRANSFORMER FAULT
470	28-Aug-2020	HASSAN	110	HV2	MOODABIDRE_110	10:04	11:15	01:11	LINE CLEAR AVALIED
471	28-Aug-2020	HASSAN	110	HV2	PUTTUR_110	09:09	12:20	03:11	LINE CLEAR AVALIED
472	28-Aug-2020	HASSAN	110	HV4	PUTTUR_110	10:07	18:17	08:10	LINE CLEAR AVALIED
473	28-Aug-2020	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN, LINE CLEAR AVAILED
474	28-Aug-2020	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	10:43	10:59	00:16	HAND TRIPPED
475	28-Aug-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	10:45	10:50	00:05	HAND TRIPPED
476	28-Aug-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	13:46	13:49	00:03	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
477	28-Aug-2020	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	08:49	13:19	04:30	LINE FAULT
478	28-Aug-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:28(27.08.2020)	7:12 (28.08.2020)	7:43 hrs	LINE CHARGED
479	28-Aug-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:24 (28.08.2020)			LINE OPEN, LINE CLEAR AVAILED
480	28-Aug-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	01:28	06:50	05:22	LINE CLEAR AVAILED
481	28-Aug-2020	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	04:04	04:15	00:11	LINE FAULT
482	28-Aug-2020	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	11:19	11:25	00:06	LINE FAULT
483	28-Aug-2020	HASSAN	66	HV1	HANBALU_66	11:45	12:29	00:44	LINE CLEAR AVAILED
484	28-Aug-2020	HASSAN	66	HV2	RAMNATHPURA_66	10:56	11:15	00:19	TRANSFORMER FAULT
485	28-Aug-2020	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	10:36	11:24	00:48	MAIN SUPPLY FAILURE
486	28-Aug-2020	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	10:33	10:56	00:23	LINE CLEAR AVAILED
487	28-Aug-2020	MYSURU	220	HOOTAGALLI-HV2	NO STATIONS EFFECTED	10:44	13:35	02:51	LINE CLEAR AVAILED
488	28-Aug-2020	MYSURU	66	FTS-HOOTAGALLY 2	NO STATIONS EFFECTED	08:50	18:32	09:41	LINE CLEAR AVAILED
489	28-Aug-2020	MYSURU	66	HD KOTE-KADAKOLA	HDKOTE_66 ANTHARSANTHE_66	07:30	09:00	01:30	LINE CLEAR AVAILED
490	28-Aug-2020	MYSURU	66	HD KOTE-TARAKA	NO STATIONS EFFECTED	10:16	10:25	00:08	LINE FAULT
491	28-Aug-2020	MYSURU	66	HOOTAGALLI-BOGADHI	NO STATIONS EFFECTED	10:02	13:46	03:43	LINE CLEAR AVAILED
492	28-Aug-2020	MYSURU	66	HOOTAGALLI-DATAGALLI	NO STATIONS EFFECTED	10:08	13:54	03:45	LINE CLEAR AVAILED
493	28-Aug-2020	MYSURU	66	HOOTAGALLI-VIJAYANAGARA	NO STATIONS EFFECTED	13:39	13:48	00:09	HAND TRIPPED
494	28-Aug-2020	MYSURU	66	HV1	BETTADHAPURA_66	11:39	11:45	00:05	TRANSFORMER FAULT
495	28-Aug-2020	MYSURU	66	HV1	DEVANOORMYS_66	12:59	13:24	00:25	TRANSFORMER FAULT
496	28-Aug-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
497	28-Aug-2020	MYSURU	66	HV2	PANDAVAPURA_66	16:01	16:45	00:43	LINE CLEAR AVAILED
498	28-Aug-2020	MYSURU	66	HV2	PONNAMPET_66	08:54	12:25	03:30	LINE CLEAR AVAILED
499	28-Aug-2020	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	MADESWARAPURA_66 JAKKANAHALLY_66 G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI MANDYA_66 NAGAMANGALA_66	17:34	17:40	00:05	LINE FAULT
500	28-Aug-2020	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	10:12 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
501	28-Aug-2020	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	11:10 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
502	28-Aug-2020	MYSURU	66	PONNAMPETE-VIRAJPET	PONNAMPET_66 HANAGODU_66 VIRAJPET_66	14:05	14:25	00:20	HAND TRIPPED
503	28-Aug-2020	MYSURU	66	SANTESARGUR-B MATTIGERE	B MATKERE_66	16:15	17:50	01:35	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
504	28-Aug-2020	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	09:54	10:00	00:05	HAND TRIPPED
505	28-Aug-2020	TUMKUR	66	BALENAHALI-CHALKERE	BALENAHALI_66	09:11	09:22	00:10	LINE FAULT
506	28-Aug-2020	TUMKUR	66	BALENAHALI- CHITRADURGA	BALENAHALI_66	07:15	07:18	00:02	HAND TRIPPED
507	28-Aug-2020	TUMKUR	66	BALENAHALI- CHITRADURGA	BALENAHALI_66	18:34	18:36	00:01	HAND TRIPPED
508	28-Aug-2020	TUMKUR	66	CHITRADURGA 220kv- CHALLAKERE	BALENAHALI_66, CHALLAKERE_66, SANIKERE_66	07:18	18:33	11:14	LINE CLEAR AVAILED
509	28-Aug-2020	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	07:26	07:49	00:23	LINE CLEAR AVAILED
510	28-Aug-2020	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66 , TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	08:42	08:55	00:12	LINE CLEAR AVAILED
511	28-Aug-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	09:07	09:18	00:11	LINE FAULT
512	28-Aug-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66, MALEBENNUR_66	09:24	09:38	00:13	LINE FAULT
513	28-Aug-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66, BAGUR_66, NEELAGUNDA_66	12:06	14:10	02:03	LINE CLEAR AVAILED
514	28-Aug-2020	TUMKUR	66	MADANAYAKANAHALLI- TURUVANUR	MADANAYAKANAHALLI_66	09:26	09:30	00:04	HAND TRIPPED
515	28-Aug-2020	TUMKUR	66	MADANAYAKANAHALLI- TURUVANUR	MADANAYAKANAHALLI_66	10:26	11:14	00:48	HAND TRIPPED
516	28-Aug-2020	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:55	15:28	04:32	LINE FAULT
517	28-Aug-2020	TUMKUR	66	TR-1	VENKATAPURA_66	06:10	06:23	00:12	TRANSFORMER FAULT
518	28-Aug-2020	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	07:01	18:47	11:45	LINE CLEAR AVAILED
519	28-Aug-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
520	28-Aug-2020	TUMKUR	66	TR-2	CHITRADURGA_220	18:33	18:48	00:14	HAND TRIPPED
521	28-Aug-2020	TUMKUR	66	TR-2	TELAGI_66	13:29	16:48	03:18	LINE CLEAR AVAILED
522	28-Aug-2020	TUMKUR	66	TR-2	URDIGERE_66	13:03	13:50	00:46	LINE CLEAR AVAILED
523	28-Aug-2020	TUMKUR	66	TR-2	URDIGERE_66	16:59	18:05	01:06	LINE CLEAR AVAILED
524	28-Aug-2020	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	07:02	18:48	11:46	LINE CLEAR AVAILED
525	28-Aug-2020	TUMKUR	110	TR-1	AMMASANDRA_110	17:09	18:51	01:42	LINE CLEAR AVAILED
526	28-Aug-2020	TUMKUR	110	TR-1(LV SIDE)	NITTUR_220	12:49	13:21	00:32	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
527	28-Aug-2020	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	10:48	10:53	00:04	LINE CLEAR AVAILED
528	28-Aug-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
529	28-Aug-2020	TUMKUR	110	TR-2(HV SIDE)	NITTUR_220	12:02	12:38	00:35	LINE CLEAR AVAILED
530	28-Aug-2020	TUMKUR	220	CHITRADURGA 220kV- THALLAK 220	CHITRADURGA_220	6:57(28.08.20)			LINE OPEN, LINE CLEAR AVAILED
531	28-Aug-2020	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	06:46	18:46	11:59	LINE CLEAR AVAILED
532	28-Aug-2020	TUMKUR	220	THALLAK 220kV- CHITRADURGA	THALLAKK_220	06:58	14:56	07:58	LINE CLEAR AVAILED
533	28-Aug-2020	TUMKUR	220	TR-1	KBCROSS_220	10:46	10:52	00:05	LINE CLEAR AVAILED
534	29-Aug-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN ,LINE FAULT
535	29-Aug-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN ,LINE FAULT
536	29-Aug-2020	BAGALKOT	110	KUDALSANGAM - ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
537	29-Aug-2020	BAGALKOT	110	VAJRAMATTI220- LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
538	29-Aug-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1& 2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28(30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
539	29-Aug-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46(19.07.0.2020)			LINE OPEN, LINE CLEAR AVAILED
540	29-Aug-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00(21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
541	29-Aug-2020	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30(01.08.2020)			LINE OPEN, LINE CLEAR AVAILED
542	29-Aug-2020	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
543	29-Aug-2020	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26(17.08.2020)			LINE OPEN, LINE CLEAR AVAILED
544	29-Aug-2020	BAGALKOT	220	GADAG-HARTHI1	STATION NOT AFFECTED GADAG_220	12:19(17.08.2020)			LOAD CURTAILMENT
545	29-Aug-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05(19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
546	29-Aug-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09(20.08.2020)			LINE OPEN, LINE CLEAR AVAILED
547	29-Aug-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09(20.08.2020)			LINE OPEN, LINE CLEAR AVAILED
548	29-Aug-2020	BAGALKOT	110	220/110KV,LV 1	STATION NOT AFFECTED BAGALKOT_220	13:05(27.08.2020)			TRANSFORMER OPEN ,LINE CLEAR AVAILED
549	29-Aug-2020	BAGALKOT	220	BELGAUM- NARENDRA2	STATION NOT AFFECTED BELGAUM_220	20:26 (28.08.2020)	7:36(29.08.2020)	11:10hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
550	29-Aug-2020	BAGALKOT	220	BAGEWADI-NANDIHAL2	BAGEWADI_220	21:07 (28.08.2020)	13:05(29.08.2020)	15:58hrs	LINE CHARGED
551	29-Aug-2020	BAGALKOT	220	BAGEWADI-NANDIHAL1	BAGEWADI_220	21:07 (28.08.2020)	12:40(29.08.2020)	15:33hrs	LINE CHARGED
552	29-Aug-2020	BAGALKOT	110	110/11KV, HV2	AREMALLAPUR_110	8:05	8:10	0:05	TRANSFORMER FAULT
553	29-Aug-2020	BAGALKOT	110	110/33KV, HV3	AREMALLAPUR_110, CHALAGERI_33	8:05	8:10	0:05	TRANSFORMER FAULT
554	29-Aug-2020	BAGALKOT	110	110/33KV, HV3	KIADB VIJAYPUR_110, NAGATHAN_33 & HONUTAGI_33	10:20	16:44	6:24	LINE CLEAR AVAILED
555	29-Aug-2020	BAGALKOT	220	BIDNAL-TADAS2 (HIREBENDIGERI2)	BIDNAL_220	11:42(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
556	29-Aug-2020	BAGALKOT	220	VAJRAMATTI-LOKAPUR	STATION NOT AFFECTED LOKAPUR_110	15:35	17:22	1:47	LINE CLEAR AVAILED
557	29-Aug-2020	BAGALKOT	110	SOUDATTI220- RAMDURGA1	RAMDURGA_110	12:46	13:03	0:17	LINE FAULT
558	29-Aug-2020	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	8:25	8:34	0:09	TRANSFORMER FAULT
559	29-Aug-2020	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED RANEENNUR_220	10:36	17:24	6:48	LINE CLEAR AVAILED
560	29-Aug-2020	BAGALKOT	110	RANEENNUR- HIREKERUR,GUTTAL,AREM ALLAPUR	HIREKERUR_110,GUTTAL_1 10,AREMALLAPUR_110	17:25	17:30	0:05	HAND TRIPPED
561	29-Aug-2020	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	23:30(28.08.2020)	10:10(29.08.2020)	10:40	LINE CHARGED
562	29-Aug-2020	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	4:32	10:03	5:31	TRANSFORMER FAULT
563	29-Aug-2020	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	6:13	6:29	0:16	LINE FAULT
564	29-Aug-2020	BAGALKOT	220	ADPH1&2,LINGASUR 1&2	BAGEWADI_220	12:09	13:08	0:59	LINE FAULT
565	29-Aug-2020	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	12:09	13:23	1:14	LINE FAULT
566	29-Aug-2020	BAGALKOT	220	FORTUNE1&2-BAGEWADI	BAGEWADI_220	12:09	13:30	1:21	LINE FAULT
567	29-Aug-2020	BAGALKOT	220	ATRIA1-BAGEWADI	BAGEWADI_220	12:09	13:15	1:06	LINE FAULT
568	29-Aug-2020	BAGALKOT	220	MASUTI LIS-BAGEWADI	BAGEWADI_220	12:09	13:15	1:06	LINE FAULT
569	29-Aug-2020	BAGALKOT	220	BALUTI LIS-BAGEWADI	BAGEWADI_220	12:09	13:40	1:31	LINE FAULT
570	29-Aug-2020	BAGALKOT	220	220/110KV,HV1,LV1&HV2, LV2	BAGEWADI_220,MAMADA PUR1&2,UKKALI_110,CHIM MALAGI_110	12:09	13:11	1:02	TRANSFORMER FAULT
571	29-Aug-2020	BAGALKOT	220	220/110KV,HV3,LV3	BAGEWADI_220,NIDAGUN DI_110,MUDDEBIHAL_110S INDAGI_110	12:09	13:11	1:02	TRANSFORMER FAULT
572	29-Aug-2020	BAGALKOT	110	110/33KV,HV1	BAGEWADI_220,MANAGUL I_33,MUTTAGI_33	12:09	13:13	1:04	TRANSFORMER FAULT
573	29-Aug-2020	BAGALKOT	110	110/33KV,HV2	BAGEWADI_220,TALIKOTI_ 33,BGL WIND_33	12:09	13:13	1:04	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
574	29-Aug-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1&2(NANDIHAL1 &2)	STATION NOT AFFECTED BAGEWADI_220	13:20(29.08.2020)			LOAD CURTAILMENT
575	29-Aug-2020	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	09:08	09:13	00:05	LOAD CHANGE OVER
576	29-Aug-2020	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	18:59	19:04	00:05	LOAD CHANGE OVER
577	29-Aug-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN ,LINE FAULT
578	29-Aug-2020	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN ,LINE FAULT
579	29-Aug-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN ,LINE FAULT
580	29-Aug-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN, LINE CLEAR AVAILED
581	29-Aug-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	07:05			LINE OPEN, LINE CLEAR AVAILED
582	29-Aug-2020	GULBARGA	110	HV1	JEWARGI_110	13:10	14:42	01:32	LINE CLEAR AVAILED
583	29-Aug-2020	GULBARGA	110	SHAHBAD-BAGEWADI2	YEDRAMI_110, MORATGI_110	05:54	05:58	00:04	LINE FAULT
584	29-Aug-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALKAMD INNI_110	17:25	17:35	00:10	LINE FAULT
585	29-Aug-2020	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	09:56	10:11	00:15	LINE FAULT
586	29-Aug-2020	GULBARGA	110	HV1	SHAHAPUR_220	15:25	15:54	00:29	LINE CLEAR AVAILED
587	29-Aug-2020	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,VALKAMDINN I_110	06:48	07:02	00:14	LINE FAULT
588	29-Aug-2020	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,VALKAMDINN I_110	20:06	20:13	00:07	LINE FAULT
589	29-Aug-2020	GULBARGA	220	HV1	RAICHUR_220	12:17	13:13	00:56	LINE CLEAR AVAILED
590	29-Aug-2020	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVAT TI_110	20:05	20:11	00:06	LINE FAULT
591	29-Aug-2020	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVAT TI_110	21:03	21:10	00:07	LINE FAULT
592	29-Aug-2020	GULBARGA	110	HV1	MANVI_110	18:48	18:58	00:10	TRANSFORMER FAULT
593	29-Aug-2020	GULBARGA	66	KOTTUR-BENNEHALLI	KOTTUR_66, UJJAINI_66	00:20	00:25	00:05	LINE FAULT
594	29-Aug-2020	GULBARGA	66	KOTTUR-BENNEHALLI	KOTTUR_66, UJJAINI_66	04:30	04:50	00:20	LINE FAULT
595	29-Aug-2020	GULBARGA	66	KOTTUR-SUZLON1	KOTTUR_66, UJJAINI_66	01:55	02:15	00:20	LINE FAULT
596	29-Aug-2020	GULBARGA	66	HV2	TAMBRAHALLI_66	09:46	09:54	00:08	LINE CLEAR AVAILED
597	29-Aug-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:24 (28.08.2020)	9:28 (29.08.2020)	17:04hrs	LINE CHARGED
598	29-Aug-2020	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN, LINE CLEAR AVAILED
599	29-Aug-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	19:57 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
600	29-Aug-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	18:02 (29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
601	29-Aug-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	00:52	07:51	06:59	LINE CLEAR AVAILED
602	29-Aug-2020	HASSAN	220	UPCL-STNAUX1	upcl_gen	08:26	19:46	11:20	LINE CLEAR AVAILED
603	29-Aug-2020	HASSAN	110	HV4	PUTTUR_110	08:30	11:15	02:45	LINE CLEAR AVAILED
604	29-Aug-2020	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	10:22	12:42	02:20	NFBC ISSUED
605	29-Aug-2020	HASSAN	110	HV2	BARANGI_110	11:37	13:20	01:43	LINE CLEAR AVAILED
606	29-Aug-2020	HASSAN	110	HV3	HIRIYADKA_110	10:12	10:22	00:10	TRANSFORMER FAULT
607	29-Aug-2020	HASSAN	110	KADUR-YGTI	KADUR_220	14:54	15:13	00:19	LINE FAULT
608	29-Aug-2020	HASSAN	110	KAVOOR-MRPL	KAVOOR_220	10:30	21:20	10:50	LINE CLEAR AVAILED
609	29-Aug-2020	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	10:11	13:47	03:36	LINE CLEAR AVAILED
610	29-Aug-2020	HASSAN	110	HV2	NAVUNDA_110	16:40	17:23	00:43	LINE CLEAR AVAILED
611	29-Aug-2020	HASSAN	110	HV	PUTTUR_220	10:38	12:07	01:29	LINE CLEAR AVAILED
612	29-Aug-2020	HASSAN	66	HV2	BAGUR_66	11:15	13:46	02:31	LINE CLEAR AVAILED
613	29-Aug-2020	HASSAN	66	HV1	BYACHANAHALLI_66	18:00	18:05	00:05	TRANSFORMER FAULT
614	29-Aug-2020	HASSAN	66	HV1	HNPURA_66	11:20	12:55	01:35	LINE CLEAR AVAILED
615	29-Aug-2020	HASSAN	66	HV2	HNPURA_66	11:20	12:55	01:35	LINE CLEAR AVAILED
616	29-Aug-2020	HASSAN	66	HV2	HNPURA_66	15:25	15:55	00:30	LINE CLEAR AVAILED
617	29-Aug-2020	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	11:20	12:55	01:35	LINE CLEAR AVAILED
618	29-Aug-2020	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	11:20	12:55	01:35	LINE CLEAR AVAILED
619	29-Aug-2020	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	15:25	15:55	00:30	LINE CLEAR AVAILED
620	29-Aug-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	08:26	09:09	00:43	LINE FAULT
621	29-Aug-2020	HASSAN	66	TAVAREC-IDLE	TAVARECHANAHALLI_66	08:25	09:10	00:45	MAIN SUPPLY FAILURE
622	29-Aug-2020	MYSURU	66	KADAKOLA-THANDYA	NO STATIONS EFFECTED	9:15	11:37	2:22	LINE CLEAR AVAILED
623	29-Aug-2020	MYSURU	66	KADAKOLA-SARGUR 2	NO STATIONS EFFECTED	11:27	12:08	0:40	LINE CLEAR AVAILED
624	29-Aug-2020	MYSURU	66	KADAKOLA-SARGUR 1	NO STATIONS EFFECTED	10:54	11:26	0:32	LINE CLEAR AVAILED
625	29-Aug-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
626	29-Aug-2020	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	11:10 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
627	29-Aug-2020	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	10:12 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
628	29-Aug-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
629	29-Aug-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020			TRANSFORMER OPEN, TRANSFORMER FAULT
630	29-Aug-2020	TUMKUR	220	CHITRADURGA 220kv-THALLAK 220	CHITRADURGA_220	6:57:17(28.08.2020)	19:05:07(29.08.2020)	36:02hrs	LINE CHARGED
631	29-Aug-2020	TUMKUR	220	CHITRADURGA 220-GUTTUR 220	CHITRADURGA_220	6:00	19:47	13:46	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
632	29-Aug-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	8:15	14:07	5:51	LINE CLEAR AVAILED
633	29-Aug-2020	TUMKUR	220	GUTTUR 400-CHITRADURGA 220	CHITRADURGA_220	6:03	19:46	13:43	LINE CLEAR AVAILED
634	29-Aug-2020	TUMKUR	110	TR-2	SHETYKERE_110	11:13	12:02	0:49	LINE CLEAR AVAILED
635	29-Aug-2020	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	18:49	18:51	0:01	HAND TRIPPED
636	29-Aug-2020	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	6:16	6:18	0:01	HAND TRIPPED
637	29-Aug-2020	TUMKUR	66	TR-2	CHITRADURGA_220	18:48	19:07	0:18	TRANSFORMER FAULT
638	29-Aug-2020	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	6:09	19:06	12:57	LINE CLEAR AVAILED
639	29-Aug-2020	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	6:13	19:07	12:54	LINE CLEAR AVAILED
640	29-Aug-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	1:08	1:12	0:04	LINE CLEAR AVAILED
641	29-Aug-2020	TUMKUR	66	TR-1	NYAMATHI_66	14:37	16:34	1:57	LINE CLEAR AVAILED
642	29-Aug-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	19:07	19:09	0:02	MAIN SUPPLY FAILURE
643	29-Aug-2020	TUMKUR	66	THALLAK 220kv-WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	8:40	15:25	6:44	LINE FAULT
644	30-Aug-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN ,LINE FAULT
645	30-Aug-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN ,LINE FAULT
646	30-Aug-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
647	30-Aug-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
648	30-Aug-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28(30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
649	30-Aug-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46(19.07.0.2020)			LINE OPEN, LINE CLEAR AVAILED
650	30-Aug-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00(21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
651	30-Aug-2020	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30(01.08.2020)			LINE OPEN, LINE CLEAR AVAILED
652	30-Aug-2020	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
653	30-Aug-2020	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26(17.08.2020)			LINE OPEN, LINE CLEAR AVAILED
654	30-Aug-2020	BAGALKOT	220	GADAG-HARTHI1	STATION NOT AFFECTED GADAG_220	12:19(17.08.2020)			LOAD CURTAILMENT
655	30-Aug-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05(19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
656	30-Aug-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09(20.08.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
657	30-Aug-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09(20.08.2020)			LINE OPEN, LINE CLEAR AVALIED
658	30-Aug-2020	BAGALKOT	110	220/110KV,LV 1	STATION NOT AFFECTED BAGALKOT_220	13:05(27.08.2020)			TRANSFORMER OPEN ,LINE CLEAR AVALIED
659	30-Aug-2020	BAGALKOT	220	BIDNAL-TADAS2 (HIREBENDIGERI2)	BIDNAL_220	11:42(29.08.2020)			LINE OPEN, LINE CLEAR AVALIED
660	30-Aug-2020	BAGALKOT	220	BAGEWADI- BIJAPUR1&2(NANDIHAL1 &2)	STATION NOT AFFECTED BAGEWADI_220	13:20(29.08.2020)			LOAD CURTAILMENT
661	30-Aug-2020	BAGALKOT	220	AMBEWADI- PONDA1(XELDOM)	PONDA1(XELDOM)_220	16:17	16:49	0:32	LINE FAULT
662	30-Aug-2020	BAGALKOT	220	AMBEWADI- NARENDRA1&2	NARENDRA_220	8:45	10:36	1:51	LINE CLEAR AVALIED
663	30-Aug-2020	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	10:48	11:03	0:15	LINE CLEAR AVALIED
664	30-Aug-2020	BAGALKOT	110	ARGA-ANKOLA	STATION NOT AFFECTED ANKOLA_110	6:40	13:19	6:39	NFBC ISSUED
665	30-Aug-2020	BAGALKOT	110	110/33KV, HV2	ANKOLA_110	16:21	16:34	0:13	TRANSFORMER FAULT
666	30-Aug-2020	BAGALKOT	110	110/11KV,HV4	SADALAGA_110	11:07	13:15	2:08	TRANSFORMER FAULT
667	30-Aug-2020	BAGALKOT	220	NARENDRA-BIDNAL	NARENDRA_220	11:41	11:43	0:02	HAND TRIPPED
668	30-Aug-2020	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	11:47	11:49	0:02	HAND TRIPPED
669	30-Aug-2020	BAGALKOT	220	NARENDRA-AMBEWADI2	NARENDRA_220	11:50	11:51	0:01	HAND TRIPPED
670	30-Aug-2020	BAGALKOT	220	NARENDRA-HAVERI1	NARENDRA_220	11:44	11:45	0:01	HAND TRIPPED
671	30-Aug-2020	BAGALKOT	220	NARENDRA-BELGAUM1	NARENDRA_220	12:06	12:08	0:02	HAND TRIPPED
672	30-Aug-2020	BAGALKOT	220	NARENDRA-BELGAUM2	NARENDRA_220	12:18	12:26	0:08	HAND TRIPPED
673	30-Aug-2020	BAGALKOT	220	NARENDRA-HUBLI1	NARENDRA_220	11:55	14:43	2:48	LINE CLEAR AVALIED
674	30-Aug-2020	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	11:53	11:55	0:02	HAND TRIPPED
675	30-Aug-2020	BAGALKOT	220	220/110KV,HV2,LV2	NARENDRA_220	12:23	12:25	0:02	HAND TRIPPED
676	30-Aug-2020	BAGALKOT	220	220/110KV,HV1,LV1	NARENDRA_220	12:26	12:28	0:02	HAND TRIPPED
677	30-Aug-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	18:05(30.08.2020)			LINE OPEN, LINE CLEAR AVALIED
678	30-Aug-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN ,LINE FAULT
679	30-Aug-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN, LINE CLEAR AVALIED
680	30-Aug-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	07:05			LINE OPEN, LINE CLEAR AVALIED
681	30-Aug-2020	GULBARGA	110	RAJESHWAR-SASTHAPUR	SASTHAPUR_110	16:30(30.08.2020)			LINE OPEN ,LINE FAULT
682	30-Aug-2020	GULBARGA	220	LINGAPUR-KUSHTAGI	KUSHTAGI_220	23:56(30.08.2020)			LINE OPEN ,LINE FAULT
683	30-Aug-2020	GULBARGA	110	HIREGONNAGAR- HANUMANAL	HANUMANAL_110	00:00	01:40	01:40	MAIN SUPPLY FAILURE
684	30-Aug-2020	GULBARGA	110	SHAHABAD-JEWARGI	JEWARGI_110	11:50	14:00	02:10	MAIN SUPPLY FAILURE
685	30-Aug-2020	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110,GANADA L_110	05:35	05:48	00:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
686	30-Aug-2020	GULBARGA	110	HUMNABAD-RAJESHWAR	RAJESHWAR_110	16:30	16:40	00:10	LINE FAULT
687	30-Aug-2020	GULBARGA	110	SEDAM-VICATASAGAR CEMENTS	VICATASAGAR CEMENTS_IPP	04:47	05:00	00:13	LINE FAULT
688	30-Aug-2020	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATI_110	01:36	01:54	00:18	LINE FAULT
689	30-Aug-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	04:09	04:20	00:11	LINE FAULT
690	30-Aug-2020	GULBARGA	110	RAICHUR-SHAHAPUR1	DEODURGA_110,GABUR_110	01:53	01:59	00:06	LINE FAULT
691	30-Aug-2020	GULBARGA	110	RAICHUR-SHAHAPUR1	DEODURGA_110,GABUR_110	04:09	04:20	00:11	LINE FAULT
692	30-Aug-2020	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADALAPUR_110	07:20	07:32	00:12	LINE FAULT
693	30-Aug-2020	GULBARGA	110	HALBARGA-CHIDRI1	CHIDRI_110	04:19	04:27	00:08	LINE FAULT
694	30-Aug-2020	GULBARGA	110	HALBARGA-CHIDRI2	KAMTHANA_110,HABSIKOTE_110	05:59	06:09	00:10	LINE FAULT
695	30-Aug-2020	GULBARGA	66	ITTAGGI-HIREHADAGALLI1	HIREHADAGALLI_66	13:59	14:10	00:11	LINE FAULT
696	30-Aug-2020	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENAHALLI_66,GIRIYAPUR_66, MAGALA_66	13:59	14:08	00:09	LINE FAULT
697	30-Aug-2020	GULBARGA	66	HV2	TAMBRAHALLI_66	16:59	17:10	00:11	LINE CLEAR AVAILED
698	30-Aug-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	18:02 (29.08.2020)	9:32 (30.08.2020)	15:30hrs	LINE CHARGED
699	30-Aug-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	19:57 (27.08.2020)	9:44 (30.08.2020)	222:08hrs	LINE CHARGED
700	30-Aug-2020	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN, LINE CLEAR AVAILED
701	30-Aug-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:22 (30.08.2020)			LINE OPEN, LINE CLEAR AVAILED
702	30-Aug-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:54 (30.08.2020)			LINE OPEN, LINE CLEAR AVAILED
703	30-Aug-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:30	12:30	01:00	LINE CLEAR AVAILED
704	30-Aug-2020	HASSAN	110	HV2	BARANGI_110	10:45	11:22	00:37	LINE CLEAR AVAILED
705	30-Aug-2020	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	08:44	18:55	10:11	LINE CLEAR AVAILED
706	30-Aug-2020	MYSURU	66	KR PETE 220-MADESHWARAPURA	MADESWARAPURA_66 JAKKANAHALLY_66 G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI MANDYA_66 NAGAMANGALA_66	11:02	11:08	0:06	LINE FAULT
707	30-Aug-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
708	30-Aug-2020	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	11:10 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
709	30-Aug-2020	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	10:12 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
710	30-Aug-2020	TUMKUR	400	TR-1	GUTTUR_400	11:34	16:55	5:21	LINE CLEAR AVAILED
711	30-Aug-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
712	30-Aug-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020			TRANSFORMER OPEN, TRANSFORMER FAULT
713	30-Aug-2020	TUMKUR	400	TR-1	GUTTUR_400	11:34	16:55	5:21	LINE CLEAR AVAILED
714	30-Aug-2020	TUMKUR	220	TR-1(HV SIDE)	HIRIYUR_220	18:26	19:03	0:36	TRANSFORMER FAULT
715	30-Aug-2020	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	18:14	18:24	0:10	LINE FAULT
716	30-Aug-2020	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	18:32	19:27	0:54	HAND TRIPPED
717	30-Aug-2020	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	18:35	19:24	0:48	MAIN SUPPLY FAILURE
718	30-Aug-2020	TUMKUR	66	TR-2	HARIYABBE_66	18:26	19:25	0:58	TRANSFORMER FAULT
719	30-Aug-2020	TUMKUR	66	TR-1(LV SIDE)	HIRIYUR_220	18:26	19:03	0:36	TRANSFORMER FAULT
720	30-Aug-2020	TUMKUR	66	TR-1	HDPURA_66	6:40	6:43	0:03	HAND TRIPPED
721	30-Aug-2020	TUMKUR	66	TR-1	HOSADURGA_66	10:35	14:07	3:31	TRANSFORMER FAULT
722	30-Aug-2020	TUMKUR	66	KALAMARANAHALLI-HIRIYUR	KALAMARANAHALLI_66	18:27	19:23	0:55	LINE FAULT
723	30-Aug-2020	TUMKUR	66	KALAMARANAHALLI-BPCLSOLAR IPP_66	BPCLSOLAR_IPP_66	18:27	19:30	1:02	LINE FAULT
724	30-Aug-2020	TUMKUR	66	TR-1	NYAMATHI_66	12:20	16:32	4:11	LINE CLEAR AVAILED
725	31-Aug-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1&2	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN ,LINE FAULT
726	31-Aug-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN ,LINE FAULT
727	31-Aug-2020	BAGALKOT	110	KUDALSANGAM - ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
728	31-Aug-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
729	31-Aug-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28(30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
730	31-Aug-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46(19.07.0.2020			LINE OPEN, LINE CLEAR AVAILED
731	31-Aug-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00(21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
732	31-Aug-2020	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30(01.08.2020)			LINE OPEN, LINE CLEAR AVAILED
733	31-Aug-2020	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
734	31-Aug-2020	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26(17.08.2020)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
735	31-Aug-2020	BAGALKOT	220	GADAG-HARTHI1	STATION NOT AFFECTED GADAG_220	12:19(17.08.2020)			LOAD CURTAILMENT
736	31-Aug-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05(19.08.2020)			LINE OPEN, LINE CLEAR AVAILED
737	31-Aug-2020	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09(20.08.2020)	17:44 (31.08.2020)	267:35hrs	LINE CHARGED
738	31-Aug-2020	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09(20.08.2020)	17:43 (31.08.2020)	267:34hrs	LINE CHARGED
739	31-Aug-2020	BAGALKOT	110	220/110KV,LV 1	STATION NOT AFFECTED BAGALKOT_220	13:05(27.08.2020)			TRANSFORMER OPEN ,LINE CLEAR AVAILED
740	31-Aug-2020	BAGALKOT	220	BIDNAL-TADAS2 (HIREBENDIGERI2)	STATION NOT AFFECTED BIDNAL_220	11:42(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
741	31-Aug-2020	BAGALKOT	220	BAGEWADI- BIJAPUR1&2(NANDIHAL1 &2)	STATION NOT AFFECTED BAGEWADI_220	13:20(29.08.2020)			LOAD CURTAILMENT
742	31-Aug-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	18:05(30.08.2020)	6:53(31.08.2020)	12:48hrs	LINE CHARGED
743	31-Aug-2020	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	12:59	13:47	0:48	LINE FAULT
744	31-Aug-2020	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	14:13	16:49	2:36	LINE FAULT
745	31-Aug-2020	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	17:12	18:57	1:45	LINE CLEAR AVAILED
746	31-Aug-2020	BAGALKOT	220	AMBEWADI-NAGJHARI 1	AMBEWADI_220	17:16	18:18	1:02	LINE CLEAR AVAILED
747	31-Aug-2020	BAGALKOT	220	AMBEWADI-NAGJHARI 2	AMBEWADI_220	17:16(31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
748	31-Aug-2020	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	17:47	18:10	0:23	HAND TRIPPED
749	31-Aug-2020	BAGALKOT	110	SUPA 1&2-AMBEWADI	AMBEWADI_220	17:11	18:21	1:10	LINE CLEAR AVAILED
750	31-Aug-2020	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	17:11	17:43	0:32	HAND TRIPPED
751	31-Aug-2020	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	18:19	18:27	0:08	HAND TRIPPED
752	31-Aug-2020	BAGALKOT	110	AMBEWADI-NK2	KAVALWAD_110	17:11	18:27	1:16	LINE CLEAR AVAILED
753	31-Aug-2020	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	9:16	15:15	10:40	LINE CLEAR AVAILED
754	31-Aug-2020	BAGALKOT	220	BIDNAL-SOUDATTI	SOUDATTI_220	12:51	12:52	0:01	LINE FAULT
755	31-Aug-2020	BAGALKOT	220	BIDNAL-SOUDATTI	SOUDATTI_220	17:12	18:49	1:37	LINE FAULT
756	31-Aug-2020	BAGALKOT	220	BIDNAL-HAVERI	HAVERI_220	17:12	17:52	0:40	LINE FAULT
757	31-Aug-2020	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	15:15(04.08.2020)	17:55(31.08.2020)	650:40hrs	LINE CHARGED
758	31-Aug-2020	BAGALKOT	110	GOPPANAKOPPA-GADAG ROAD	GADAG ROAD_110	17:12	19:05	1:53	MAIN SUPPLY FAILURE
759	31-Aug-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	18:28(30.05.2020)	10:41(31.08.2020)	2224:13hrs	LINE CHARGED
760	31-Aug-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05(31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
761	31-Aug-2020	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	10:23	10:40	0:17	LINE CLEAR AVAILED
762	31-Aug-2020	BAGALKOT	110	HUBLI- KADANKOPPA	KADANKOPPA_110	6:08	12:32	6:24	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
763	31-Aug-2020	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	9:53	15:39	5:46	LINE CLEAR AVAILED
764	31-Aug-2020	BAGALKOT	220	HUBLI- SIRS1	HUBLI_220	13:28	16:49	3:21	LINE FAULT
765	31-Aug-2020	BAGALKOT	220	HUBLI- BIDNAL 1&2	HUBLI_220	17:13	18:33	1:20	LINE CLEAR AVAILED
766	31-Aug-2020	BAGALKOT	110	HUBLI- KADANKOPPA	KADANKOPPA_110	17:11	17:43	0:32	HAND TRIPPED
767	31-Aug-2020	BAGALKOT	110	HUBLI- TARIHAL	TARIHAL_110, TADASINKOPPA_110, NAVANAGAR(H) 110	17:11	17:43	0:32	HAND TRIPPED
768	31-Aug-2020	BAGALKOT	110	HUBLI- ANAND NAGAR	ANAND NAGAR_110	17:11	17:43	0:32	HAND TRIPPED
769	31-Aug-2020	BAGALKOT	110	HUBLI- KALGHATAGI	KALGHATAGI_110	17:11	17:43	0:32	HAND TRIPPED
770	31-Aug-2020	BAGALKOT	110	HUBLI- PH COMPOUND	PH COMPOUND_110	17:11	17:43	0:32	HAND TRIPPED
771	31-Aug-2020	BAGALKOT	110	HUBLI- RAMANKOPPA	RAMANKOPPA_110	17:11	17:43	0:32	HAND TRIPPED
772	31-Aug-2020	BAGALKOT	220	BIDNAL- SOUDATTI	BIDNAL_220	12:52	13:25	0:33	HAND TRIPPED
773	31-Aug-2020	BAGALKOT	110	BIDNAL-NAVALGUND	NO STATION AFFECTED NAVLGUND_110	18:19 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
774	31-Aug-2020	BAGALKOT	220	220/110KV,HV1,LV1,HV2.L V2	NO STATION AFFECTED NARENDRA_220	11:14	18:14	7:00	LINE CLEAR AVAILED
775	31-Aug-2020	BAGALKOT	220	NARENDRA-BELGAUM1&2	STATION NOT AFFECTED NARENDRA_220	11:22	18:29	7:07	LINE CLEAR AVAILED
776	31-Aug-2020	BAGALKOT	220	NARENDRA-HUBLI1&2	STATION NOT AFFECTED NARENDRA_220	11:24	18:17	6:53	LINE CLEAR AVAILED
777	31-Aug-2020	BAGALKOT	220	NARENDRA- AMBEWADI1&2	STATION NOT AFFECTED NARENDRA_220	11:25	18:11	6:46	LINE CLEAR AVAILED
778	31-Aug-2020	BAGALKOT	220	NARENDRA-HAVERI	STATION NOT AFFECTED NARENDRA_220	11:25	18:22	6:57	LINE CLEAR AVAILED
779	31-Aug-2020	BAGALKOT	220	NARENDRA-BIDNAL	STATION NOT AFFECTED NARENDRA_220	11:26	18:20	6:54	LINE CLEAR AVAILED
780	31-Aug-2020	BAGALKOT	110	NARENDRA-KUD DHARWAD	KUD DHARWAD_110	11:12	18:22	7:10	LINE CLEAR AVAILED
781	31-Aug-2020	BAGALKOT	110	NARENDRA-UAS	UAS_110	10:47	18:16	7:29	LINE CLEAR AVAILED
782	31-Aug-2020	BAGALKOT	110	NARENDRA- TADASINAKOPPA	TADASINAKOPPA_110	11:12	18:20	7:08	LINE CLEAR AVAILED
783	31-Aug-2020	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	16:49	17:02	0:13	TRANSFORMER FAULT
784	31-Aug-2020	BAGALKOT	110	NARENDRA- MRUTHYUNJAYANAGAR	MRUTHYUNJAYANAGAR_1 10	10:42	18:24	7:42	NFBC ISSUED
785	31-Aug-2020	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(B)_110	10:04	15:16	5:12	LINE CLEAR AVAILED
786	31-Aug-2020	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	17:50	18:08	0:18	HAND TRIPPED
787	31-Aug-2020	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	9:03	13:05	4:02	LINE CLEAR AVAILED
788	31-Aug-2020	BAGALKOT	110	AMBEWADI(KAVALWADA)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	13:05 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
789	31-Aug-2020	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	16:35	16:42	0:07	TRANSFORMER FAULT
790	31-Aug-2020	BAGALKOT	110	110/33KV,HV4	HIDIKAL_110,ALAGAWADI_ 33	12:13	14:49	2:36	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
791	31-Aug-2020	BAGALKOT	110	110/11KV, HV2	HIDIKAL_110	14:10	14:40	0:30	TRANSFORMER FAULT
792	31-Aug-2020	BAGALKOT	110	GMR SUGARS-HALIYAL	HALIYAL_110	17:13	18:13	1:00	LINE CLEAR AVAILED
793	31-Aug-2020	BAGALKOT	110	GMR SUGARS-HALIYAL	HALIYAL_110	18:57	19:26	0:29	LINE CLEAR AVAILED
794	31-Aug-2020	GULBARGA	220	LINGAPUR-KUSHTAGI	KUSHTAGI_220	23:56(30.08.2020)	8:18(31.08.2020)	8:22 HRS	LINE CHARGED
795	31-Aug-2020	GULBARGA	220	LINGAPUR-SINDHANOOR	SINDHANOOR_220	02:00	02:38	00:38	LINE FAULT
796	31-Aug-2020	GULBARGA	220	LINGAPUR-KUSHTAGI	KUSHTAGI_220	23:56(30.08.2020)	8:18(31.08.2020)	8:22 HRS	LINE CHARGED
797	31-Aug-2020	GULBARGA	220	LINGAPUR-SINDHANOOR	LINGAPUR_220	02:00	02:38	00:38	LINE FAULT
798	31-Aug-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)	15:53(31.8.2020)	3262:38HRS	LINE CHARGED
799	31-Aug-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)	15:50(31.8.2020)	2156:35HRS	MAIN SUPPLY FAILURE
800	31-Aug-2020	GULBARGA	110	RAJESHWAR-SASTHAPUR	SASTHAPUR_110	20:00(31.08.2020)			LINE OPEN ,LINE FAULT
801	31-Aug-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN, LINE CLEAR AVAILED
802	31-Aug-2020	GULBARGA	110	RAJESHWAR-SASTHAPUR	SASTHAPUR_110	16:30(30.08.2020)	13:03(31.8.2020)	20:33HRS	LINE CHARGED
803	31-Aug-2020	GULBARGA	110	KUSTAGI-KANKAGIRI	KANAKAGIRI_110, GANADAL_110	05:38	05:49	00:11	LINE FAULT
804	31-Aug-2020	GULBARGA	110	HANUMANAL-KUSTAGI	HANUMANAL_110	09:35	10:05	00:30	MAIN SUPPLY FAILURE
805	31-Aug-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:49	21:52	00:03	LINE FAULT
806	31-Aug-2020	GULBARGA	110	HUMNABAD-RAJESHWAR	RAJESHWAR_110	20:00	20:20	00:20	LINE FAULT
807	31-Aug-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:22 (30.08.2020)	7:44 (31.08.2020)	31:21 hrs	LINE CHARGED
808	31-Aug-2020	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN, LINE CLEAR AVAILED
809	31-Aug-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:22 (30.08.2020)			LINE OPEN, LINE CLEAR AVAILED
810	31-Aug-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:11 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
811	31-Aug-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	9:11 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
812	31-Aug-2020	HASSAN	220	VARAHI-KEMAR3	varahi_gen	9:11 (31.08.2020)			LINE OPEN, NFBC ISSUED
813	31-Aug-2020	HASSAN	110	HALADY11-HIRIYADKA	HALADY_110	9:27 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
814	31-Aug-2020	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	9:27 (31.08.2020)			LINE OPEN, LINE CLEAR AVAILED
815	31-Aug-2020	HASSAN	220	UPCL-KEMAR1	upcl_gen	08:45	13:41	04:56	LINE CLEAR AVAILED
816	31-Aug-2020	HASSAN	220	KEMAR-UPCL1	KEMAR_220	08:45	13:41	04:56	NFBC ISSUED
817	31-Aug-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:00	11:28	00:28	LINE CLEAR AVAILED
818	31-Aug-2020	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	12:09	12:13	00:04	HAND TRIPPED
819	31-Aug-2020	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	13:45	13:48	00:03	HAND TRIPPED
820	31-Aug-2020	HASSAN	110	JOG-NK1	mghejog_gen	18:45	18:55	00:10	LINE FAULT
821	31-Aug-2020	HASSAN	110	KAVOOR-MRPL	KAVOOR_220	09:47	18:46	08:59	LINE CLEAR AVAILED
822	31-Aug-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	13:30	14:53	01:23	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
823	31-Aug-2020	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	13:29	14:43	01:14	LINE CLEAR AVAILED
824	31-Aug-2020	HASSAN	66	MALALI-CRPATNA	MALALI_66	13:34	14:48	01:14	LINE CLEAR AVAILED
825	31-Aug-2020	HASSAN	66	MALALI-HASSAN	MALALI_66	13:30	14:47	01:17	LINE CLEAR AVAILED
826	31-Aug-2020	HASSAN	66	HV1	MALALI_66	13:30	14:48	01:18	MAIN SUPPLY FAILURE
827	31-Aug-2020	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	10:31	12:57	02:26	LINE CLEAR AVAILED
828	31-Aug-2020	MYSURU	66	DODDARAYAPETE-KUNTHUR	SANTHEMARAHALLI_66	10:57	11:07	0:10	LINE FAULT
829	31-Aug-2020	MYSURU	66	KADAKOLA-SARGUR 2	CHANDRAVADI_66 DOORA_66 HURA_66 HULLAHALLI 66	13:12	13:19	0:07	LINE FAULT
830	31-Aug-2020	MYSURU	66	HV1	KOPPA_66	15:42	16:22	0:39	LINE CLEAR AVAILED
831	31-Aug-2020	MYSURU	66	MADHUVANAHALLI-HANNUR1	NO STATIONS EFFECTED	18:58	19:04	0:05	LINE FAULT
832	31-Aug-2020	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	17:56	18:09	0:12	LINE FAULT
833	31-Aug-2020	MYSURU	66	MUGUR-KUNTHUR	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA 66	10:57	11:10	0:12	LINE FAULT
834	31-Aug-2020	MYSURU	66	HV2	VAJAMANGALA_220	22:46	23:19	0:33	TRANSFORMER FAULT
835	31-Aug-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
836	31-Aug-2020	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	11:10 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
837	31-Aug-2020	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	10:12 (27.08.2020)			LINE OPEN, LINE CLEAR AVAILED
838	31-Aug-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
839	31-Aug-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
840	31-Aug-2020	TUMKUR	110	HONNAVALLI 110-DMKURKE	DMKURKE_110	11:50(31.08.2020)			LINE OPEN ,LINE FAULT
841	31-Aug-2020	TUMKUR	220	TR-2	DAVANGERE_SRS_220	11:42	16:43	5:00	LINE CLEAR AVAILED
842	31-Aug-2020	TUMKUR	220	GUTTUR 400-CHITRADURGA 220	CHITRADURGA_220	13:09	13:12	0:03	LINE CLEAR AVAILED
843	31-Aug-2020	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	16:32	16:49	0:17	LINE CLEAR AVAILED
844	31-Aug-2020	TUMKUR	110	TR-1	KGTEMPLE_110	2:48	9:00	6:11	LINE CLEAR AVAILED
845	31-Aug-2020	TUMKUR	110	K G TEMPLE-NITTUR220	KGTEMPLE_110	9:22	9:29	0:06	HAND TRIPPED
846	31-Aug-2020	TUMKUR	110	TR-1	MAYASANDRA_110	12:01	12:25	0:23	TRANSFORMER FAULT
847	31-Aug-2020	TUMKUR	110	TR-1	MAYASANDRA_110	16:50	18:07	1:17	TRANSFORMER FAULT
848	31-Aug-2020	TUMKUR	110	TR-1	MAYASANDRA_110	18:08	19:57	1:49	TRANSFORMER FAULT
849	31-Aug-2020	TUMKUR	66	TR-2(LV SIDE)	DAVANGERE_SRS_220	12:50	16:41	3:51	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASONS
850	31-Aug-2020	TUMKUR	66	TR-2	HARIYABBE_66	16:33	16:38	0:05	HAND TRIPPED
851	31-Aug-2020	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	7:23	7:35	0:12	LINE FAULT
852	31-Aug-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	8:41	9:33	0:52	LINE CLEAR AVAILED
853	31-Aug-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	5:49	7:03	1:14	LINE CLEAR AVAILED
854	31-Aug-2020	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	17:30	17:40	0:09	LINE FAULT
855	31-Aug-2020	TUMKUR	66	NAYAKANAHATTI66- HIREMALLANHOLE	NAYAKANAHATTI_66	12:10	12:17	0:06	HAND TRIPPED
856	31-Aug-2020	TUMKUR	66	NEELAGUNDA220kv- HARPANAHALLI-1	HARAPPANAHALLI_66	16:12	16:32	0:19	HAND TRIPPED
857	31-Aug-2020	TUMKUR	66	NEELAGUNDA 220kv- HULUVAGALU	HALUVAGALU_66	13:21	14:21	1:00	LINE CLEAR AVAILED
858	31-Aug-2020	TUMKUR	66	NEELAGUNDA 220kv- HULUVAGALU	HALUVAGALU_66	16:12	16:42	0:29	HAND TRIPPED
859	31-Aug-2020	TUMKUR	66	TR-1(HV SIDE)	NEELAGUNDA_220	14:11	16:29	2:17	LINE CLEAR AVAILED
860	31-Aug-2020	TUMKUR	66	TR-1(LV SIDE)	NEELAGUNDA_220	16:21	16:29	0:07	HAND TRIPPED
861	31-Aug-2020	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCH CHANGIDURGA_66,PALLAG ATTE_66, SOKKE_66	16:21	16:30	0:09	HAND TRIPPED
862	31-Aug-2020	TUMKUR	66	NEELAGUNDA 220kv- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	16:12	16:31	0:18	HAND TRIPPED
863	31-Aug-2020	TUMKUR	66	TR-2	TELAGI_66	16:12	16:40	0:27	MAIN SUPPLY FAILURE
864	31-Aug-2020	TUMKUR	66	VENKATAPURA- GOWRIBIDNUR	PALLAGATTE_66,SOKKE_66 ,	7:02	7:32	0:29	MAIN SUPPLY FAILURE