

**400/220/110/66 kV TRANSMISSION OUTAGES FROM : 12.07.22 TO 18.07.2022**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	12-Jul-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN,LINE CLEAR AVAIED
2	12-Jul-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN,LINE CLEAR AVAIED
3	12-Jul-2022	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	8:50 (06.07.2022)			LINE OPEN,LINE FAULT
4	12-Jul-2022	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	13:46 (10.07.2022)			LINE OPEN,LINE CLEAR AVAIED
5	12-Jul-2022	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	13:46 (10.07.2022)			LINE OPEN,LINE CLEAR AVAIED
6	12-Jul-2022	BAGALKOT	110	KUDACHI220-TERDAL (MORAB)	MORAB_110	23:59 (11.07.2022)	00:09 (12.07.2022)	10:00HRS	LINE CHARGED
7	12-Jul-2022	BAGALKOT	220	HUBLI-NAGZARI-1	STATION NOT AFFECTED HUBLI_220	18:40 (11.07.2022)	13:37 (12.07.2022)	18:57HRS	LINE CHARGED
8	12-Jul-2022	BAGALKOT	110	AMBEWADI-NARENDRA-2	STATION NOT AFFECTED AMBEWADI_220	18:31 (11.07.2022)	19:03 (12.07.2022)	24:32HRS	LINE CHARGED
9	12-Jul-2022	BAGALKOT	110	CHIKKODI220-BHOJ (NANADI)	NANADI_110	13:08	13:55	0:47	LINE CLEAR AVAIED
10	12-Jul-2022	BAGALKOT	110	CHIKKODI220-NIPPANI (KHADAKLAT)	KHADAKALAT_110	14:48	15:52	1:04	LINE CLEAR AVAIED
11	12-Jul-2022	BAGALKOT	220	NARENDRA-GHATAPRABHA-1	STATION NOT AFFECTED GHATAPRABHA_220	11:36	13:33	1:57	LINE CLEAR AVAIED
12	12-Jul-2022	BAGALKOT	110	GHATAPRABHA220- GOKAK	GOKAK_110	19:08	19:15	0:07	LINE FAULT
13	12-Jul-2022	BAGALKOT	110	ALMEL-KP SUGAR	STATION NOT AFFECTED ALMEL_110	21:48	22:10	0:22	LINE FAULT
14	12-Jul-2022	BAGALKOT	220	AMBEWADI-NAGJHARI2	STATION NOT AFFECTED AMBEWADI_220	14:46	18:10	3:24	LINE CLEAR AVAIED
15	12-Jul-2022	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED BICANAL_110	6:51	6:59	0:08	TRANSFORMER FAULT
16	12-Jul-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED GULEDGUDD_110	10:47	11:01	0:14	LINE CLEAR AVAIED
17	12-Jul-2022	BAGALKOT	110	HUNGUND-ILKAL2	HUNGUND_110	18:26	18:45	0:19	HAND TRIPPED
18	12-Jul-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED KADAKLAT_110	11:53	17:15	5:22	LINE CLEAR AVAIED
19	12-Jul-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED KADAKLAT_110	22:00	22:05	0:05	TRANSFORMER FAULT
20	12-Jul-2022	BAGALKOT	220	NARENDRA-AM,EWADI2	NARENDRA_220	15:45	17:01	1:16	HAND TRIPPED
21	12-Jul-2022	BAGALKOT	220	NARENDRA-AM,EWADI2	NARENDRA_220	15:45	18:58	19:08	HAND TRIPPED
22	12-Jul-2022	BAGALKOT	110	CHIKKODI220-SADALAGA	SADALAGA_110	12:02	13:59	1:57	LINE CLEAR AVAIED
23	12-Jul-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED NAGNUR_110	1:57	2:14	0:17	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
24	12-Jul-2022	BAGALKOT	110	MUGLD-LN11 Cbreaker (NAGANUR)	NAGANUR_110	2:51	3:00	0:09	LINE FAULT
25	12-Jul-2022	BAGALKOT	110	110/33KV,HV2	CHINCHALI_33 STATION NOT AFFECTED KUDACHI_110	15:58	16:04	0:06	TRANSFORMER FAULT
26	12-Jul-2022	BAGALKOT	220	220/110KV,HV1	STATION NOT AFFECTED KUDACHI_220	12:15	14:12	1:57	HAND TRIPPED
27	12-Jul-2022	BAGALKOT	110	220/110KV,LV1	STATION NOT AFFECTED KUDACHI_220	12:15	14:15	2:00	HAND TRIPPED
28	12-Jul-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED KAMBAGI_110	9:00	9:05	0:05	TRANSFORMER FAULT
29	12-Jul-2022	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
30	12-Jul-2022	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	10:50 (26.03.2022)			LINE OPEN,LINE CLEAR AVAIED
31	12-Jul-2022	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED ATHANI_220	9:41 (06.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAIED
32	12-Jul-2022	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
33	12-Jul-2022	BAGALKOT	220	AMBEWADI-NARENDRA-1	STATION NOT AFFECTED AMBEWADI_220	5:53	14:44	8:51	HAND TRIPPED
34	12-Jul-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KAWALWADA_110	6:55	8:20	1:25	LINE CLEAR AVAIED
35	12-Jul-2022	BAGALKOT	110	ANMOD-GOA-2	ANMOD_110	22:40 (11.07.2022)			LINE OPEN,LINE FAULT
36	12-Jul-2022	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED BELAGAVI_220	11:09	17:55	6:46	LINE CLEAR AVAIED
37	12-Jul-2022	BAGALKOT	110	BAGALKOT220-KALADAGI	KALADAGI_110	7:32	7:41	0:09	LINE FAULT
38	12-Jul-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED VAJJARMATTI_110	10:25	10:30	0:05	TRANSFORMER FAULT
39	12-Jul-2022	BAGALKOT	110	ATHANI220-BALIGERI	BALIGERI_110	19:13	20:25	1:12	LINE CLEAR AVAIED
40	12-Jul-2022	BENGALURU	66	HV2	BG RAOD	16:47	16:49	0:02	TRANSFORMER FAULT
41	12-Jul-2022	BENGALURU	66	HEJJALA - KUMBALAGODU 220	HEJJALA	12:15	12:55	0:40	LINE FAULT
42	12-Jul-2022	BENGALURU	66	HV1	C STATION	15:41	15:42	0:01	LINE CLEAR AVAIED
43	12-Jul-2022	BENGALURU	66	HV1	KENGERI SATELLITE TOWN	12:32	12:40	0:08	TRANSFORMER FAULT
44	12-Jul-2022	BENGALURU	66	TK HALLI 220 - SHIMSHA	SHIMSHA	18:29	18:52	0:23	LINE FAULT
45	12-Jul-2022	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	14:20	16:10	1:50	LINE CLEAR AVAIED
46	12-Jul-2022	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	16:15	19:28	3:13	LINE FAULT
47	12-Jul-2022	BENGALURU	66	HV1	VIDYANAGAR	15:15	15:40	0:24	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
48	12-Jul-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	14:02	14:19	0:17	MAIN SUPPLY FAILURE
49	12-Jul-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	14:02	14:20	0:18	MAIN SUPPLY FAILURE
50	12-Jul-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	14:02	14:20	0:18	MAIN SUPPLY FAILURE
51	12-Jul-2022	BENGALURU	66	TUBGERE - AFLT SOLAR (IPP)	NO STATION AFFECTED	14:02	14:24	0:22	LINE FAULT
52	12-Jul-2022	BENGALURU	220	HV2	DB PURA 220	14:02	23:23	9:21	TRANSFORMER FAULT
53	12-Jul-2022	BENGALURU	220	LV2	DB PURA 220	14:02	23:25	9:23	TRANSFORMER FAULT
54	12-Jul-2022	BENGALURU	66	HV2	SARJAPURA 220	18:20	18:41	0:21	TRANSFORMER FAULT
55	12-Jul-2022	BENGALURU	66	HV1	PATHPALYA	13:23	13:30	0:07	TRANSFORMER FAULT
56	12-Jul-2022	BENGALURU	66	HV1	PATHPALYA	16:41	17:03	0:21	TRANSFORMER FAULT
57	12-Jul-2022	BENGALURU	66	HV2	NANDAGUDI	8:43	8:54	0:10	LINE CLEAR AVAILED
58	12-Jul-2022	BENGALURU	66	HV2	KUNDANA	16:26	17:11	0:44	LINE CLEAR AVAILED
59	12-Jul-2022	BENGALURU	66	HV1	KEMBODI	12:17	12:54	0:37	LINE CLEAR AVAILED
60	12-Jul-2022	BENGALURU	66	HV1	DALSANUR	14:43	15:07	0:24	LINE CLEAR AVAILED
61	12-Jul-2022	BENGALURU	66	TADIGOL CROSS - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	5:18	5:25	0:07	LINE FAULT
62	12-Jul-2022	BENGALURU	66	TADIGOL CROSS - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	5:18	5:27	0:09	LINE FAULT
63	12-Jul-2022	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN,LINE CLEAR AVAILED
64	12-Jul-2022	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN,LINE CLEAR AVAILED
65	12-Jul-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN,LINE CLEAR AVAILED
66	12-Jul-2022	GULBARGA	110	HV1	MADIYAL_110	18:00(09.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
67	12-Jul-2022	GULBARGA	110	HV1	SIRWAR_110	11:05	16:10	5:05	LINE CLEAR AVAILED
68	12-Jul-2022	GULBARGA	110	HV1,HV2	MYLAR_110	21:45	22:05	0:20	LINE CLEAR AVAILED
69	12-Jul-2022	GULBARGA	110	HV2	DEODURGA_110	19:40	19:50	0:10	TRANSFORMER FAULT
70	12-Jul-2022	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	4:25	4:35	0:10	LINE FAULT
71	12-Jul-2022	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	4:52	4:57	0:05	LINE FAULT
72	12-Jul-2022	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	17:10	17:45	0:35	LINE FAULT
73	12-Jul-2022	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110	17:10	17:45	0:35	MAIN SUPPLY FAILURE
74	12-Jul-2022	GULBARGA	110	YAPALADINNI-VADAVATI	YAPALDINNI_110	13:00	13:20	0:20	MAIN SUPPLY FAILURE
75	12-Jul-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:35	21:50	0:15	LINE FAULT
76	12-Jul-2022	GULBARGA	110	SEDAM-VICTSAGAR_IPP	VICATSAGARCEMNETS	4:55	5:05	0:10	LINE FAULT
77	12-Jul-2022	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	13:15	13:20	0:05	LINE FAULT
78	12-Jul-2022	GULBARGA	110	MUNIRABAD-KOPPAL	KIRLOSHKAR_IPP,HARE KRISHNA_IPP, STATR METALIC_IPP	10:19	16:08	5:49	LINE CLEAR AVAILED
79	12-Jul-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:35	21:50	0:15	LINE FAULT
80	12-Jul-2022	GULBARGA	110	RAICHUR-SINDHNOOR1	SIRWAR_110	11:08	12:51	1:43	LINE CLEAR AVAILED
81	12-Jul-2022	GULBARGA	66	HV2	TAMBRAHALLI_66	10:08	10:14	0:06	TRANSFORMER FAULT
82	12-Jul-2022	GULBARGA	66	HV2	HALVAGALU_66	10:20	10:25	0:05	TRANSFORMER FAULT
83	12-Jul-2022	GULBARGA	66	HV2	HALVAGALU_66	11:10	11:15	0:05	TRANSFORMER FAULT
84	12-Jul-2022	GULBARGA	66	HV2	HALVAGALU_66	11:35	11:40	0:05	TRANSFORMER FAULT
85	12-Jul-2022	GULBARGA	66	HV1,HV2	PUNABGHATA_66	15:50	15:55	0:05	LINE CLEAR AVAILED
86	12-Jul-2022	GULBARGA	66	HV1	HARVI_66	9:00	14:00	5:00	LINE CLEAR AVAILED
87	12-Jul-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
88	12-Jul-2022	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
89	12-Jul-2022	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
90	12-Jul-2022	HASSAN	66	HV1	SINGAPURA_66	13:26(05.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
91	12-Jul-2022	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	22:12(12.07.2022)			LINE OPEN,LINE FAULT
92	12-Jul-2022	HASSAN	220	MRSSHM-GEROSOPPA1	MRSMSG_220	22:00 (8.07.2022)	16:54 (11.07.2022)	18:53 hrs	LINE CHARGED
93	12-Jul-2022	HASSAN	220	GERSOPA-STRP1	gerusoppa_gen	22:00(09.07.2022)	17:07 (11.07.2022)	19:06 hrs	LINE CHARGED
94	12-Jul-2022	HASSAN	400	HASSAN4-UPCL2	HASSAN_400	2:00	7:34	5:34	HAND TRIPPED
95	12-Jul-2022	HASSAN	400	UPCL-HASSAN2	upcl_gen	2:00	7:34	5:34	HAND TRIPPED
96	12-Jul-2022	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	9:43	16:49	7:06	NFBC ISSUED
97	12-Jul-2022	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	19:23	21:28	2:05	LINE FAULT
98	12-Jul-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	9:53	16:49	6:56	NFBC ISSUED
99	12-Jul-2022	HASSAN	220	SHRAVTY-SHIMOGA4	gen_sharavathy	20:44	21:33	0:49	HAND TRIPPED
100	12-Jul-2022	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	10:14	11:01	0:47	HAND TRIPPED
101	12-Jul-2022	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	14:30	14:39	0:09	HAND TRIPPED
102	12-Jul-2022	HASSAN	110	HV1	GURUPURA_110	11:19	12:40	1:21	LINE CLEAR AVAILED
103	12-Jul-2022	HASSAN	110	JOG-JST1	JOG_110	15:28	16:32	1:04	LINE CLEAR AVAILED
104	12-Jul-2022	HASSAN	110	HV2	NAVUNDA_110	12:17	13:59	1:42	LINE CLEAR AVAILED
105	12-Jul-2022	HASSAN	110	HV2	NERALEKERE_110	11:33	11:51	0:18	LINE CLEAR AVAILED
106	12-Jul-2022	HASSAN	110	HV1	SAGARA_110	10:49	12:00	1:11	LINE CLEAR AVAILED
107	12-Jul-2022	HASSAN	110	JST1	SAGARA_110	15:27	16:30	1:03	LINE CLEAR AVAILED
108	12-Jul-2022	HASSAN	66	BELUR66-HASSAN	BELUR_66	10:19	10:46	0:27	MAIN SUPPLY FAILURE
109	12-Jul-2022	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	10:19	10:50	0:31	MAIN SUPPLY FAILURE
110	12-Jul-2022	HASSAN	66	HV2	SAKALESHPURA_66	21:29	21:40	0:11	TRANSFORMER FAULT
111	12-Jul-2022	MYSURU	66	HV1	BGPURA_66	11:56	12:30	0:33	LINE CLEAR AVAILED
112	12-Jul-2022	MYSURU	66	HV1	BGPURA_66	13:11	15:50	2:38	LINE CLEAR AVAILED
113	12-Jul-2022	MYSURU	66	HV1	HDKOTE_66	14:25	16:00	1:35	LINE CLEAR AVAILED
114	12-Jul-2022	MYSURU	66	HV2	HDKOTE_66	12:50	14:21	1:31	LINE CLEAR AVAILED
115	12-Jul-2022	MYSURU	66	KUSHALNAGARA- PERIYAPATNA2	HANAGODU_66 PERIYAPATNA_66 VIRAJPETE_66 KAMPLAPURA_66 BYLUKUPPE_66	14:30	17:59	3:28	LINE FAULT
116	12-Jul-2022	MYSURU	66	KUSHALNAGARA-HARANGI	NO STATIONS EFFECTED	11:17	13:29	2:12	LINE FAULT
117	12-Jul-2022	MYSURU	66	KUSHALNAGARA-PERIYAPATNA 1	HANAGODU_66 PERIYAPATNA_66 VIRAJPETE_66 KAMPLAPURA_66 PONNAMPETE_66	16:06	17:58	1:52	LINE CLEAR AVAILED
118	12-Jul-2022	MYSURU	66	PERIAPATNA-KUSHALNAGARA 1	HANAGODU_66 PERIYAPATNA_66 VIRAJPETE_66 KAMPLAPURA_66 PONNAMPETE_66	15:48	15:55	0:06	LINE FAULT
119	12-Jul-2022	MYSURU	66	SFCSIVA-SHIMSA	NO STATIONS EFFECTED	18:29	18:41	0:12	LINE FAULT
120	12-Jul-2022	MYSURU	66	SFCSIVA-PGL	NO STATIONS EFFECTED	18:29	18:38	0:08	LINE FAULT
121	12-Jul-2022	MYSURU	66	SFCSIVA-SOLAR 5MW	NO STATIONS EFFECTED	18:29	18:52	0:22	LINE FAULT
122	12-Jul-2022	MYSURU	66	SFCSIVA-SOLAR 10MW	NO STATIONS EFFECTED	18:29	18:52	0:22	LINE FAULT
123	12-Jul-2022	MYSURU	66	HV1	SRIRANGAPATNA_66	12:48	13:02	0:14	TRANSFORMER FAULT
124	12-Jul-2022	MYSURU	66	THALAKADU-ADANI	NO STATIONS EFFECTED	18:33	19:33	0:59	LINE CLEAR AVAILED
125	12-Jul-2022	MYSURU	66	HV2	TERAKANAMBI_66	16:25	18:11	1:45	LINE CLEAR AVAILED
126	12-Jul-2022	MYSURU	66	KADAKOLA-VAJAMANGALA 2	NO STATIONS EFFECTED	12:40	15:16	2:36	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
127	12-Jul-2022	MYSURU	66	MUGUR-THAYURU	THAYURU_66	19:02	19:07	0:05	LINE FAULT
128	12-Jul-2022	MYSURU	66	HEBBANI-SFC 1	NO STATIONS EFFECTED	18:31	18:39	0:08	LINE FAULT
129	12-Jul-2022	MYSURU	66	CHIKKAMANDYA-MANDYA	CHIKKA_MANDYA_66 HAMPAPURA_66	12:10	12:20	0:10	LINE FAULT
130	12-Jul-2022	MYSURU	66	CHIKKAMANDYA-MANDYA	CHIKKA_MANDYA_66 HAMPAPURA_66	18:30	18:55	0:25	LINE CLEAR AVAILED
131	12-Jul-2022	MYSURU	66	HV2	CHIKKAMANDYA_66	12:10	20:10	8:00	TRANSFORMER FAULT
132	12-Jul-2022	MYSURU	66	HV2	SANTHEBACHALLI_66	15:30	16:50	1:20	LINE CLEAR AVAILED
133	12-Jul-2022	MYSURU	220	MADHUVANAHALLY-WARDHA SOLAR	NO STATIONS EFFECTED	20:32:00 (12.07.2022)			LINE OPEN,LINE CLEAR AVAILED
134	12-Jul-2022	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00 (12.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
135	12-Jul-2022	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
136	12-Jul-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	18:26 (22/04/2022)			LINE OPEN,LINE CLEAR AVAILED
137	12-Jul-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	15:16:00(08/12/2021)			LINE OPEN,LINE CLEAR AVAILED
138	12-Jul-2022	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	15:08	15:16	0:08	HAND TRIPPED
139	12-Jul-2022	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 1	CHITRADURGA_66 OLD MUSS,PANDARAHALLI_66,CHI TRAHALLI_66,HDPURA_66,HO LALKERE_66,RAMGIRI_66	19:37	22:00	2:23	HAND TRIPPED
140	12-Jul-2022	TUMKUR	220	TR1	CHITRADURGA_220	19:38	21:40	2:02	LINE CLEAR AVAILED
141	12-Jul-2022	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	5:59	6:10	0:11	LINE FAULT
142	12-Jul-2022	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	23:19	23:39	0:20	LINE FAULT
143	12-Jul-2022	TUMKUR	66	TR1	DAVANGERE_SRS_220	23:19	23:40	0:21	TRANSFORMER FAULT
144	12-Jul-2022	TUMKUR	220	HONNALLI 220kV- BENKIKERE LINE-1	HONNALLI_220	23:20	23:45	0:25	HAND TRIPPED
145	12-Jul-2022	TUMKUR	220	HONNALLI 220kV- BENKIKERE LINE-2	HONNALLI_220	23:20	23:45	0:25	HAND TRIPPED
146	12-Jul-2022	TUMKUR	220	HONNALLI 220kV- SUZLON LINE- 1	HONNALLI_220	23:20	23:46	0:26	HAND TRIPPED
147	12-Jul-2022	TUMKUR	220	HONNALLI 220kV- SUZLON LINE- 2	HONNALLI_220	23:20	23:46	0:26	HAND TRIPPED
148	12-Jul-2022	TUMKUR	220	TR1	HONNALLI_220	23:20	23:46	0:26	HAND TRIPPED
149	12-Jul-2022	TUMKUR	220	TR2	HONNALLI_220	23:20	23:51	0:31	HAND TRIPPED
150	12-Jul-2022	TUMKUR	66	HONNALI66-HONNALLI220	HONNALLI_66	23:20	23:49	0:29	HAND TRIPPED
151	12-Jul-2022	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	23:20	23:54	0:34	HAND TRIPPED
152	12-Jul-2022	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI 66	23:20	23:49	0:29	HAND TRIPPED
153	12-Jul-2022	TUMKUR	66	HONNALLI 220KV- KUNDUR66	KUNDUR_66,MALEBENNUR_6 6,DEVARABELKERE_66	23:20	23:50	0:30	HAND TRIPPED
154	12-Jul-2022	TUMKUR	66	HONNALLI 220KV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	23:20	23:50	0:30	HAND TRIPPED
155	12-Jul-2022	TUMKUR	66	HONNALLI 220KV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	23:20	23:52	0:32	HAND TRIPPED
156	12-Jul-2022	TUMKUR	66	TR1	HONNALLI_220	23:20	23:49	0:29	HAND TRIPPED
157	12-Jul-2022	TUMKUR	66	TR2	HONNALLI_220	23:20	23:49	0:29	HAND TRIPPED
158	12-Jul-2022	TUMKUR	220	TR1	PAVAGADA_220	5:05	5:15	0:10	TRANSFORMER FAULT
159	12-Jul-2022	TUMKUR	220	TR2	PAVAGADA_220	5:05	5:15	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
160	12-Jul-2022	TUMKUR	66	NAGALAMADIKE 1-PAVAGADA220KV	NAGALMADIKE_66	5:05	5:15	0:10	MAIN SUPPLY FAILURE
161	12-Jul-2022	TUMKUR	66	NAGALAMADIKE 2-PAVAGADA220KV	NAGALMADIKE_66	5:05	5:15	0:10	MAIN SUPPLY FAILURE
162	12-Jul-2022	TUMKUR	66	Y N HOSKOTE66-SHYLAPURA66	Y N HOSKOTE_66	5:05	5:15	0:10	MAIN SUPPLY FAILURE
163	12-Jul-2022	TUMKUR	66	Y N HOSKOTE66-SHYLAPURA66	Y N HOSKOTE_66	7:05	7:10	0:05	MAIN SUPPLY FAILURE
164	12-Jul-2022	TUMKUR	66	PAVAGADA220-SHYLAPURA	SHYLAPURA_66	5:05	5:15	0:10	MAIN SUPPLY FAILURE
165	12-Jul-2022	TUMKUR	66	PAVAGADA220-SHYLAPURA	SHYLAPURA_66	7:05	7:10	0:05	MAIN SUPPLY FAILURE
166	12-Jul-2022	TUMKUR	66	PAVAGADA220-MEDIGESHI	MEDIGESHI_66	12:55	12:58	0:03	MAIN SUPPLY FAILURE
167	12-Jul-2022	TUMKUR	220	TR1 AND TR2	HOSADURGA_220	23:20	0:00	0:40	MAIN SUPPLY FAILURE
168	12-Jul-2022	TUMKUR	66	UCHANGIDURGA- PALLAGATTE	BILCHODU_66	4:45	4:55	0:10	LINE FAULT
169	12-Jul-2022	TUMKUR	66	BEVINAHALLI- CHANGAVARA 66	BEVINAHALLI_66	11:40	13:15	1:35	LINE FAULT
170	12-Jul-2022	TUMKUR	66	BEVINAHALLI- AFTL SOLAR IPP 66	AFTL SOLAR_IPP_66	11:40	14:30	2:50	LINE FAULT
171	12-Jul-2022	TUMKUR	66	HONNALI66-HONNALLI220	HONNALI_66	23:15	23:50	0:35	MAIN SUPPLY FAILURE
172	12-Jul-2022	TUMKUR	66	I D HALLI- KODIGENAHALLI	IDHALLY_66	11:05	11:20	0:15	MAIN SUPPLY FAILURE
173	12-Jul-2022	TUMKUR	66	I D HALLI- KODIGENAHALLI	IDHALLY_66	11:50	12:00	0:10	MAIN SUPPLY FAILURE
174	12-Jul-2022	TUMKUR	66	I D HALLI- KODIGENAHALLI	IDHALLY_66	12:50	13:00	0:10	MAIN SUPPLY FAILURE
175	12-Jul-2022	TUMKUR	66	TR1	SANTEMNAVATTUR_66	16:30	16:50	0:20	LINE CLEAR AVAILED
176	12-Jul-2022	TUMKUR	66	ANCHEPALYA 220kv- YEDIYUR 66	_THIPPUR_66	11:20	15:15	3:55	LINE CLEAR AVAILED
177	12-Jul-2022	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	1:10	1:20	0:10	MAIN SUPPLY FAILURE
178	12-Jul-2022	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	13:10	13:25	0:15	MAIN SUPPLY FAILURE
179	12-Jul-2022	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	13:48	14:10	0:22	MAIN SUPPLY FAILURE
180	12-Jul-2022	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	19:25	19:50	0:25	MAIN SUPPLY FAILURE
181	12-Jul-2022	TUMKUR	66	TR2	HOLALKERE_66	14:55	15:00	0:05	TRANSFORMER FAULT
182	12-Jul-2022	TUMKUR	66	PDKOTE-HARIYABBE	PDKOTE_66	10:25	16:55	6:30	NFBC ISSUED
183	12-Jul-2022	TUMKUR	66	KUKKAWADA-LINGADAHALLI(HONNALLI)	KUKKAWADA_66	22:53	23:10	0:17	LINE FAULT
184	12-Jul-2022	TUMKUR	66	TR-1	SASALUHALLA_66	13:00:00 PM(28.06.2022)	20:00(11.07.2022)	319HRS	TRANSFORMER CHARGED
185	13-Jul-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN,LINE CLEAR AVAILED
186	13-Jul-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN,LINE CLEAR AVAILED
187	13-Jul-2022	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	8:50 (06.07.2022)			LINE OPEN,LINE FAULT
188	13-Jul-2022	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	13:46 (10.07.2022)			LINE OPEN,LINE CLEAR AVAILED
189	13-Jul-2022	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	13:46 (10.07.2022)			LINE OPEN,LINE CLEAR AVAILED
190	13-Jul-2022	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	4:19	4:39	0:20	LINE FAULT
191	13-Jul-2022	BAGALKOT	110	110/11KV,HV2	CHIKKODI_110	11:55	13:25	1:30	TRANSFORMER FAULT
192	13-Jul-2022	BAGALKOT	110	HALIYAL-F2(LIS)	HALIYAL_110	18:05	20:29	2:24	LINE FAULT
193	13-Jul-2022	BAGALKOT	110	ATHANI220-HALIYAL	HALIYAL_110	18:05	18:27	0:22	LINE FAULT
194	13-Jul-2022	BAGALKOT	110	110/11KV,HV1	HIRESMASALI_110	15:08	15:45	0:37	LINE CLEAR AVAILED
195	13-Jul-2022	BAGALKOT	110	110/11KV,HV1	KANABARGI LAY OUT_110	10:38	11:20	0:42	LINE CLEAR AVAILED
196	13-Jul-2022	BAGALKOT	110	110/11KV,HV4	KULIGOD_110	8:31	15:47	7:16	TRANSFORMER FAULT
197	13-Jul-2022	BAGALKOT	110	KADAKLAT-F2(NIPPANI)	KADAKLAT_110	11:58	12:10	0:12	HAND TRIPPED
198	13-Jul-2022	BAGALKOT	110	KADAKLAT-F2(NIPPANI)	KADAKLAT_110	16:09	16:15	0:06	HAND TRIPPED
199	13-Jul-2022	BAGALKOT	110	110/11KV,HV2	MURDESHWAR_110	13:59	14:22	0:23	LINE CLEAR AVAILED
200	13-Jul-2022	BAGALKOT	110	110/11KV,HV2&3	NIPPANI_110	11:55	12:26	0:31	TRANSFORMER FAULT
201	13-Jul-2022	BAGALKOT	110	SAMBAPUR ROAD - GADAG(RAILWAY TRACTION)	SAMBAPUR ROAD_110	10:22	12:26	2:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
202	13-Jul-2022	BAGALKOT	110	110/11KV,HV3	SATTI_110	15:54	17:53	1:59	LINE CLEAR AVAILED
203	13-Jul-2022	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	15:04	15:19	0:15	LINE CLEAR AVAILED
204	13-Jul-2022	BAGALKOT	110	SRS HUBLI-TARIHAL	TARIHAL_110	7:05	9:34	2:29	LINE CLEAR AVAILED
205	13-Jul-2022	BAGALKOT	110	110/11KV,HV1	UGAR KHUD_110	18:24	18:33	0:09	TRANSFORMER FAULT
206	13-Jul-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KANABARGI_110	10:38	11:20	0:42	LINE CLEAR AVAILED
207	13-Jul-2022	BAGALKOT	220	VAJJARMATTI-KUDAGI-1 (2)	220KV VAJJARMATTI	1:26 (13.07.2022)			LINE OPEN,LINE CLEAR AVAILED
208	13-Jul-2022	BAGALKOT	110	VAJJARMATTI-MANTUR-1( KATARAKI)	KATARAKI_110	6:04	6:10	0:06	LINE FAULT
209	13-Jul-2022	BAGALKOT	220	220/110KV, HV2 & LV2	CHIKKODI_220	11:27	11:32	0:05	TRANSFORMER FAULT
210	13-Jul-2022	BAGALKOT	220	220/110KV, HV3 & LV3	STATION NOT AFFECTED CHIKKODI_220	11:52 (1307.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
211	13-Jul-2022	BAGALKOT	220	CHIKKODI-KUDACHI-1	CHIKKODI_220	11:55	12:38	0:43	LINE FAULT
212	13-Jul-2022	BAGALKOT	220	CHIKKODI-AEQUS-1	CHIKKODI_220	11:55	12:19	0:24	LINE FAULT
213	13-Jul-2022	BAGALKOT	220	220/110KV, HV1 & LV1	CHIKKODI_220	11:55	12:03	0:08	TRANSFORMER FAULT
214	13-Jul-2022	BAGALKOT	110	220/110KV, LV2	CHIKKODI_220	12:03	12:04	0:01	TRANSFORMER FAULT
215	13-Jul-2022	BAGALKOT	220	220/110KV, HV2	CHIKKODI_220	11:55	12:04	0:09	TRANSFORMER FAULT
216	13-Jul-2022	BAGALKOT	220	SIRSI-SHARAVATI-2	STATION NOT AFFECTED SIRSI_220	14:37	20:09	5:32	LINE FAULT
217	13-Jul-2022	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	10:15	13:30	3:15	NFBC ISSUED
218	13-Jul-2022	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
219	13-Jul-2022	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	10:50 (26.03.2022)			LINE OPEN,LINE CLEAR AVAILED
220	13-Jul-2022	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED ATHANI_220	9:41 (06.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
221	13-Jul-2022	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
222	13-Jul-2022	BAGALKOT	110	ANMOD-GOA-2	ANMOD_110	22:40 (11.07.2022)			LINE OPEN,LINE FAULT
223	13-Jul-2022	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110, TOLAMATTI_110 BISNAL_110, GIRISAGAR_110	4:05	4:15	0:10	LINE FAULT
224	13-Jul-2022	BAGALKOT	220	CHIKKODI-MUGALKHOD-1	CHIKKODI_220	11:55	12:09	0:14	LINE FAULT
225	13-Jul-2022	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	11:55	12:03	0:08	LINE FAULT
226	13-Jul-2022	BAGALKOT	110	CHIKKODI220-CHIKKODI	CHIKKODI_110	11:55	12:03	0:08	LINE FAULT
227	13-Jul-2022	BAGALKOT	110	CHIKKODI220-KHADAKALAT	KHADAKALAT_110	11:55	12:03	0:08	LINE FAULT
228	13-Jul-2022	BAGALKOT	110	CHIKKODI220-SADALAGA	SADALAGA_110	11:55	12:03	0:08	LINE FAULT
229	13-Jul-2022	BAGALKOT	110	CHIKKODI220-BHOJ	BHOJ_110	11:55	12:03	0:08	LINE FAULT
230	13-Jul-2022	BAGALKOT	110	CHIKKODI220-DKSSKN	DKSSKN_110 CHIIKKODI_220	11:55	12:03	0:08	LINE FAULT
231	13-Jul-2022	BAGALKOT	110	CHIKKODI220-NANADI	NANADI_110	11:55	12:03	0:08	LINE FAULT
232	13-Jul-2022	BAGALKOT	110	RANEBENNUR220-BYADAGI	STATION NOT AFFECTED RANEBENNUR_220	11:35	12:44	1:09	NFBC ISSUED
233	13-Jul-2022	BAGALKOT	220	HAVERI-GUTTUR-2	STATION NOT AFFECTED HAVERI_220	12:10	12:35	0:25	LINE FAULT
234	13-Jul-2022	BAGALKOT	220	HAVERI-GUTTUR-2	STATION NOT AFFECTED HAVERI_220	12:41	17:23	4:42	LINE FAULT
235	13-Jul-2022	BAGALKOT	220	HAVERI-GUTTUR-1	STATION NOT AFFECTED HAVERI_220	14:00	17:23	3:23	LINE CLEAR AVAILED
236	13-Jul-2022	BAGALKOT	110	ATHANI220-HALYAL	HALYAL_110	19:06	19:26	0:20	LINE FAULT
237	13-Jul-2022	BENGALURU	66	HV2	NRS 220	16:36	16:38	0:02	LINE CLEAR AVAILED
238	13-Jul-2022	BENGALURU	66	TAVAREKERE - MAGADI 220	TAVAREKERE	8:29	8:31	0:02	LINE CLEAR AVAILED
239	13-Jul-2022	BENGALURU	66	HV2	TAVAREKERE	8:29	8:31	0:02	LINE CLEAR AVAILED
240	13-Jul-2022	BENGALURU	66	HV1	TORALAKKI	12:35	12:45	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
241	13-Jul-2022	BENGALURU	66	HV1	WELCAST STEEL	13:10	13:13	0:03	LINE CLEAR AVAILED
242	13-Jul-2022	BENGALURU	66	HV2	WELCAST STEEL	11:43	11:46	0:03	LINE CLEAR AVAILED
243	13-Jul-2022	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLI CROSS, YENIGADALE	7:00	20:48	13:48	LINE CLEAR AVAILED
244	13-Jul-2022	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, BURUDAGUNTE	7:00	20:34	13:34	LINE CLEAR AVAILED
245	13-Jul-2022	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, PALLICHERLU	7:00	21:12	14:12	LINE CLEAR AVAILED
246	13-Jul-2022	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, PALLICHERLU	7:00	21:12	14:12	LINE CLEAR AVAILED
247	13-Jul-2022	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66, SM MANGALA	7:00	19:32	12:32	LINE CLEAR AVAILED
248	13-Jul-2022	BENGALURU	66	CHINTAMANI 220 - SRINIVASपुरA	G KODIHALLI, SRINIVASपुरA, YELDUR	7:00	20:42	13:42	LINE CLEAR AVAILED
249	13-Jul-2022	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	7:00	19:34	12:34	LINE CLEAR AVAILED
250	13-Jul-2022	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	7:00	20:44	13:44	LINE CLEAR AVAILED
251	13-Jul-2022	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	6:46	6:55	0:08	LINE FAULT
252	13-Jul-2022	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	7:00	19:54	12:54	LINE CLEAR AVAILED
253	13-Jul-2022	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	19:54	20:28	0:34	LINE CLEAR AVAILED
254	13-Jul-2022	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	7:00	20:56	13:56	LINE CLEAR AVAILED
255	13-Jul-2022	BENGALURU	220	HV1	CHINTAMANI 220	7:00	20:27	13:27	LINE CLEAR AVAILED
256	13-Jul-2022	BENGALURU	220	HV2	CHINTAMANI 220	7:00	19:35	12:35	LINE CLEAR AVAILED
257	13-Jul-2022	BENGALURU	220	HV2	CHINTAMANI 220	19:35	20:36	1:01	TRANSFORMER FAULT
258	13-Jul-2022	BENGALURU	220	HV3	CHINTAMANI 220	7:00	19:31	12:31	LINE CLEAR AVAILED
259	13-Jul-2022	BENGALURU	220	CHINTAMANI 220 - PGCIL 1	CHINTAMANI 220	7:00	19:29	12:29	LINE CLEAR AVAILED
260	13-Jul-2022	BENGALURU	220	CHINTAMANI 220 - PGCIL 2	CHINTAMANI 220	7:00	19:30	12:30	LINE CLEAR AVAILED
261	13-Jul-2022	BENGALURU	66	THAYLUR - N G HULKUR	N G HULKUR	8:59	10:41	1:41	LINE CLEAR AVAILED
262	13-Jul-2022	BENGALURU	66	HV2	NANDGUDI	12:56	12:59	0:02	LINE CLEAR AVAILED
263	13-Jul-2022	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	12:41	12:51	0:10	LINE FAULT
264	13-Jul-2022	BENGALURU	66	LAKSHMIPURA - ADDAGAL	GOWNPALLI, RAYALPADU, ADDAGAL	0:03	0:13	0:09	LINE FAULT
265	13-Jul-2022	BENGALURU	66	KOLAR 220 - PGCIL AUX	PGCIL AUX, SUGUTUR	7:00	19:41	12:41	LINE CLEAR AVAILED
266	13-Jul-2022	BENGALURU	66	MALUR 220 - KGF 2	BANGARPETE	13:04	14:54	1:50	LINE CLEAR AVAILED
267	13-Jul-2022	BENGALURU	66	VENMAGAL - KYALANUR	KYALANUR	8:35	8:50	0:15	LINE FAULT
268	13-Jul-2022	GULBARGA	220	HALAWARTHY-DHONI2	HALAWARTHY_220	7:45(13.7.22)			LINE OPEN,LINE CLEAR AVAILED
269	13-Jul-2022	GULBARGA	220	SEDAM_SHAHAPUR	SEDAM_220	05:48(10/06/2022)			LINE OPEN,LINE CLEAR AVAILED
270	13-Jul-2022	GULBARGA	220	SEDAM-HUMNABAD_1	HUMNABAD_220	14:55(12/07/2022)			LOAD CURTAILMENT
271	13-Jul-2022	GULBARGA	220	HALAWARTHY-DHONI1	HALAWARTHY_220	7:12(13.7.22)			LINE OPEN,LINE CLEAR AVAILED
272	13-Jul-2022	GULBARGA	220	HALAWARTHY-DHONI2	HALAWARTHY_220	7:45(13.7.22)			LINE OPEN,LINE CLEAR AVAILED
273	13-Jul-2022	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	0:53	7:50	6:57	LINE FAULT
274	13-Jul-2022	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN,LINE CLEAR AVAILED
275	13-Jul-2022	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN,LINE CLEAR AVAILED
276	13-Jul-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN,LINE CLEAR AVAILED
277	13-Jul-2022	GULBARGA	110	HV1	MADIYAL_110	18:00(09.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
278	13-Jul-2022	GULBARGA	110	HV3	YELBURGA_110	12:08	12:28	0:20	TRANSFORMER FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
279	13-Jul-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	1:22	1:26	0:04	LINE FAULT
280	13-Jul-2022	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGS SK_IPP,BHALKI SUGAR_IPP	5:48 (08/07/2022)	15:12(13/07/2022)	129:24HRS	LINE CHARGED
281	13-Jul-2022	GULBARGA	110	SHAHABAD-WADI	WADI_110	1:52	7:37	5:45	LINE FAULT
282	13-Jul-2022	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	5:30	5:35	0:05	LINE FAULT
283	13-Jul-2022	GULBARGA	110	SINDANOOR-NIRLOOTI	NIRLOOTI_IPP	2:20	2:30	0:10	LINE FAULT
284	13-Jul-2022	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110,MUDDAPU R_110,MASKI_110,VALAKAMA DINNI_110	4:40	4:50	0:10	LINE FAULT
285	13-Jul-2022	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR _110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	9:30	17:45	8:15	LINE CLEAR AVAILED
286	13-Jul-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	1:22	1:26	0:04	LINE FAULT
287	13-Jul-2022	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGS SK_IPP,BHALKI SUGAR_IPP	5:48 (08/07/2022)	15:12(13/07/2022)	129:24HRS	LINE CHARGED
288	13-Jul-2022	GULBARGA	110	SHAHABAD-WADI	WADI_110	1:52	7:37	5:45	LINE FAULT
289	13-Jul-2022	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	5:30	5:35	0:05	LINE FAULT
290	13-Jul-2022	GULBARGA	110	SINDANOOR-NIRLOOTI	NIRLOOTI_IPP	2:20	2:30	0:10	LINE FAULT
291	13-Jul-2022	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110,MUDDAPU R_110,MASKI_110,VALAKAMA DINNI_110	4:40	4:50	0:10	LINE FAULT
292	13-Jul-2022	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR _110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	9:30	17:45	8:15	LINE CLEAR AVAILED
293	13-Jul-2022	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUR_110	2:19	2:44	0:25	LINE FAULT
294	13-Jul-2022	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUR_110	4:36	4:49	0:13	MAIN SUPPLY FAILURE
295	13-Jul-2022	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	19:49	19:55	0:06	LINE FAULT
296	13-Jul-2022	GULBARGA	110	YELBURGA-KUKUNOOR	KUKUNOOR_110	12:08	12:19	0:11	LINE FAULT
297	13-Jul-2022	GULBARGA	110	YELBURGA-PARAMPOOJIYA	YELBURGA_110	12:08	12:21	0:13	LINE FAULT
298	13-Jul-2022	GULBARGA	110	YELBURGA-TALAKUTAI	YELBURGA_110	12:08	12:20	0:12	LINE FAULT
299	13-Jul-2022	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	21:00	21:10	0:10	LINE FAULT
300	13-Jul-2022	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	23:00	23:07	0:07	LINE FAULT
301	13-Jul-2022	GULBARGA	110	KUKUNOOR-YELABURGA	KUKUNOOR_110	12:10	12:20	0:10	MAIN SUPPLY FAILURE
302	13-Jul-2022	GULBARGA	110	NANDOOR-SHAHABAD	NANDOOR_110	2:28	6:10	3:42	LINE FAULT
303	13-Jul-2022	GULBARGA	110	GHATARGI-SHAHABAD	GHATARGI_110	1:50	2:00	0:10	MAIN SUPPLY FAILURE
304	13-Jul-2022	GULBARGA	110	GHATARGI-SHAHABAD	GHATARGI_110	5:40	5:50	0:10	LINE FAULT
305	13-Jul-2022	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	19:01	19:18	0:17	LINE FAULT
306	13-Jul-2022	GULBARGA	66	HV1	PUNABGHATA_66	10:20	10:30	0:10	LINE CLEAR AVAILED
307	13-Jul-2022	GULBARGA	66	HV1,HV2	PUNABGHATA_66	10:35	10:55	0:20	LINE CLEAR AVAILED
308	13-Jul-2022	GULBARGA	66	HV1,HV2	PUNABGHATA_66	17:05	17:15	0:10	LINE CLEAR AVAILED
309	13-Jul-2022	GULBARGA	66	HV1	HANASI_66	9:30	12:20	2:50	LINE CLEAR AVAILED
310	13-Jul-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
311	13-Jul-2022	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
312	13-Jul-2022	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
313	13-Jul-2022	HASSAN	66	HV1	SINGAPURA_66	13:26(05.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
314	13-Jul-2022	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	22:12(12.07.2022)			LINE OPEN,LINE FAULT
315	13-Jul-2022	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	8:41	9:09	0:28	LINE FAULT
316	13-Jul-2022	HASSAN	220	MRSSHM-CHMLR	MRSMSG_220	8:41	9:11	0:30	LINE FAULT
317	13-Jul-2022	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	8:41	9:12	0:31	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
318	13-Jul-2022	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	8:41	10:33	1:52	LINE FAULT
319	13-Jul-2022	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	8:41	9:12	0:31	LINE FAULT
320	13-Jul-2022	HASSAN	220	HV1	MRSMSG_220	8:41	9:10	0:29	TRANSFORMER FAULT
321	13-Jul-2022	HASSAN	220	HV2	MRSMSG_220	8:41	8:59	0:18	TRANSFORMER FAULT
322	13-Jul-2022	HASSAN	220	HV3	MRSMSG_220	8:41	9:10	0:29	TRANSFORMER FAULT
323	13-Jul-2022	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	8:41	8:58	0:17	LINE FAULT
324	13-Jul-2022	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	8:41	9:20	0:39	LINE FAULT
325	13-Jul-2022	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	8:41	9:09	0:28	LINE FAULT
326	13-Jul-2022	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	8:41	9:20	0:39	LINE FAULT
327	13-Jul-2022	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	8:41	9:00	0:19	LINE FAULT
328	13-Jul-2022	HASSAN	220	VSHARAVATHY4	MRSMSG_220	8:41	9:00	0:19	LINE FAULT
329	13-Jul-2022	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	8:41	9:11	0:30	LINE FAULT
330	13-Jul-2022	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	8:41	9:11	0:30	LINE FAULT
331	13-Jul-2022	HASSAN	220	MRSSHM-VARAH3	MRSMSG_220	8:38	14:50	6:12	LINE FAULT
332	13-Jul-2022	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	8:49	9:03	0:14	LINE FAULT
333	13-Jul-2022	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	8:49	9:02	0:13	LINE FAULT
334	13-Jul-2022	HASSAN	110	VBADRAVATY3	MRSMSG_220	8:41	9:07	0:26	LINE FAULT
335	13-Jul-2022	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	8:50	11:30	2:40	LINE FAULT
336	13-Jul-2022	HASSAN	110	HV5	MRSMSG_220	8:49	9:02	0:13	TRANSFORMER FAULT
337	13-Jul-2022	HASSAN	110	LV1	MRSMSG_220	8:41	9:10	0:29	TRANSFORMER FAULT
338	13-Jul-2022	HASSAN	110	LV2	MRSMSG_220	8:41	9:00	0:19	TRANSFORMER FAULT
339	13-Jul-2022	HASSAN	110	LV3	MRSMSG_220	8:41	9:10	0:29	TRANSFORMER FAULT
340	13-Jul-2022	HASSAN	110	MRSSHM-MPM	MRSMSG_220	8:49	9:05	0:16	LINE FAULT
341	13-Jul-2022	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	8:41	9:07	0:26	LINE FAULT
342	13-Jul-2022	HASSAN	110	MRSSHM-SS1	MRSMSG_220	8:48	9:17	0:29	LINE FAULT
343	13-Jul-2022	HASSAN	110	MRSSHM-SS2	MRSMSG_220	8:49	9:17	0:28	LINE FAULT
344	13-Jul-2022	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	8:49	9:17	0:28	LINE FAULT
345	13-Jul-2022	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	8:49	9:16	0:27	LINE FAULT
346	13-Jul-2022	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	8:41	9:17	0:36	LINE FAULT
347	13-Jul-2022	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	8:41	9:16	0:35	LINE FAULT
348	13-Jul-2022	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	8:49	9:03	0:14	LINE FAULT
349	13-Jul-2022	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	8:41	9:00	0:19	LINE FAULT
350	13-Jul-2022	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	8:41	9:00	0:19	LINE FAULT
351	13-Jul-2022	HASSAN	220	HV2	SHIRALKOPPA_220	8:35	13:09	4:34	LINE CLEAR AVAILED
352	13-Jul-2022	HASSAN	110	LV2	SHIRALKOPPA_220	8:34	13:10	4:36	LINE CLEAR AVAILED
353	13-Jul-2022	HASSAN	220	VARAHI-SHMG3	varahi_gen	11:11	14:58	3:47	NFBC ISSUED
354	13-Jul-2022	HASSAN	110	HV1	ARASIKERE_110	14:37	14:57	0:20	TRANSFORMER FAULT
355	13-Jul-2022	HASSAN	110	HV2	Bhadaravathi_110	16:43	17:11	0:28	LINE CLEAR AVAILED
356	13-Jul-2022	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJANUR_110	9:36	11:33	1:57	NFBC ISSUED
357	13-Jul-2022	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKLERE_110	11:06	12:08	1:02	NFBC ISSUED
358	13-Jul-2022	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	9:56	13:42	3:46	LINE CLEAR AVAILED
359	13-Jul-2022	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	6:20	6:24	0:04	LINE FAULT
360	13-Jul-2022	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:01	12:07	2:06	LINE CLEAR AVAILED
361	13-Jul-2022	HASSAN	110	HV1	KEMAR_220	5:48	7:27	1:39	TRANSFORMER FAULT
362	13-Jul-2022	HASSAN	110	HV1	KEMAR_220	9:34	9:38	0:04	HAND TRIPPED
363	13-Jul-2022	HASSAN	110	HV2	KEMAR_220	9:34	9:36	0:02	HAND TRIPPED
364	13-Jul-2022	HASSAN	110	HV1	KONAJE_110	10:33	13:05	2:32	LINE CLEAR AVAILED
365	13-Jul-2022	HASSAN	110	HV2	KONAJE_110	6:27	631	17:33	MAIN SUPPLY FAILURE
366	13-Jul-2022	HASSAN	110	HV3	KONAJE_110	11:15	14:07	2:52	LINE CLEAR AVAILED
367	13-Jul-2022	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	6:27	6:52	0:25	LINE FAULT
368	13-Jul-2022	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	8:15	9:26	1:11	MAIN SUPPLY FAILURE
369	13-Jul-2022	HASSAN	66	BHADRA-SHMG 1	bhadra_gen	8:15	9:17	1:02	LINE FAULT
370	13-Jul-2022	HASSAN	66	BHADRA-SHMG 2	bhadra_gen	8:15	9:16	1:01	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
371	13-Jul-2022	HASSAN	66	HV2	UDAYAPURA_66	18:45	19:24	0:39	TRANSFORMER FAULT
372	13-Jul-2022	MYSURU	66	HV1	ARAKERA_66	11:52	16:59	5:07	LINE CLEAR AVAILED
373	13-Jul-2022	MYSURU	66	HV1	BGPURA_66	10:31	11:36	1:04	LINE CLEAR AVAILED
374	13-Jul-2022	MYSURU	66	CR NAGAR-HONGANUR	HOGANUR_66 YELANDUR_66	18:19	18:25	0:05	LINE FAULT
375	13-Jul-2022	MYSURU	66	HV1	SANVARSANTHE_66	19:31	19:42	0:10	TRANSFORMER FAULT
376	13-Jul-2022	MYSURU	66	HV2	HOSURGATE_66	17:25	18:05	0:40	LINE CLEAR AVAILED
377	13-Jul-2022	MYSURU	66	SANTHESARGUR-KADAKOLA 1	YERAHALLI_HAND_POST_66 HD_KOTE_66 ANTARSANTE_66	12:20	12:32	0:12	LINE FAULT
378	13-Jul-2022	MYSURU	66	HV1	MUGUR_66	16:15	16:50	0:35	LINE CLEAR AVAILED
379	13-Jul-2022	MYSURU	66	HV2	BYLUKUPPE_66	15:20	17:50	2:30	LINE CLEAR AVAILED
380	13-Jul-2022	MYSURU	66	KUSHALANAGARA-MADIKERI	MADIKERI_66	4:42	11:19	6:37	LINE FAULT
381	13-Jul-2022	MYSURU	66	KUSHALANAGARA-MADIKERI	MADIKERI_66	12:27	14:40	2:13	LINE FAULT
382	13-Jul-2022	MYSURU	66	KUSHALANAGARA-SUNTIKOPPA	SUNTIKOPPA_66	8:49	11:31	2:42	LINE CLEAR AVAILED
383	13-Jul-2022	MYSURU	66	KUSHALANAGARA-SUNTIKOPPA	SUNTIKOPPA_66	22:08	22:15	0:07	LINE FAULT
384	13-Jul-2022	MYSURU	66	KUSHALANAGARA-PERİYAPATNA 2	NO STATIONS EFFECTED	12:27	12:50	0:23	LINE FAULT
385	13-Jul-2022	MYSURU	66	KUSHALANAGARA-PERİYAPATNA 1	PERİYAPATNA_66KAMPLAPUR A_66HANAGODU_66PONNAM PET_66VIRAJPET_66	12:27	12:40	0:13	LINE FAULT
386	13-Jul-2022	MYSURU	66	KUSHALANAGARA-HARANGI	NO STATIONS EFFECTED	12:27	12:40	0:13	LINE FAULT
387	13-Jul-2022	MYSURU	66	KUSHALANAGARA-RAMANATHAPURA 1	KANAGAL_66 ALUR SIDDAPUR_66 CB HALLI_66 RUDRAPATNA_66 RAMANATHAPURA_66	12:27	12:40	0:13	LINE FAULT
388	13-Jul-2022	MYSURU	66	KUSHALANAGARA-MYSORE 1	MIRLE_66	12:27	12:40	0:13	LINE FAULT
389	13-Jul-2022	MYSURU	66	SUNTIKOPPA-MADIKERI	NO STATIONS EFFECTED	4:34:00(13.07.2022)			LINE OPEN,LINE FAULT
390	13-Jul-2022	MYSURU	220	MADHUVANAHALLY-WARDHA SOLAR	NO STATIONS EFFECTED	20:32:00 (12.07.2022)	2:03:00 (13.07.2022)	5:31HRS	LINE CHARGED
391	13-Jul-2022	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00 (12.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
392	13-Jul-2022	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
393	13-Jul-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	18:26 (22/04/2022)			LINE OPEN,LINE CLEAR AVAILED
394	13-Jul-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN,LINE CLEAR AVAILED
395	13-Jul-2022	TUMKUR	220	TR-1(HV SIDE )	CHITRADURGA_220	10:27	14:40	4:13	LINE CLEAR AVAILED
396	13-Jul-2022	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	13:06	13:52	0:46	HAND TRIPPED
397	13-Jul-2022	TUMKUR	220	KB CROSS 220kv- SHIMOGA1	KBCROSS_220	8:49	9:19	0:30	LINE FAULT
398	13-Jul-2022	TUMKUR	110	KATRIKEHAL110-THIMMANAHALLI110	KATRIKEHAL_110	8:40	8:50	0:10	MAIN SUPPLY FAILURE
399	13-Jul-2022	TUMKUR	110	TR-1	TALKERE_66	12:53	14:05	1:11	LINE CLEAR AVAILED
400	13-Jul-2022	TUMKUR	110	TALKERE_110-KB CROSS220	TALKERE_110	13:22	14:05	0:43	LINE CLEAR AVAILED
401	13-Jul-2022	TUMKUR	66	ANCHEPALYA 220kv-KUNIGAL66	KUNIGAL_66	10:10	10:21	0:11	LINE CLEAR AVAILED
402	13-Jul-2022	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	16:24	16:46	0:21	LINE CLEAR AVAILED
403	13-Jul-2022	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	15:50	16:19	0:28	LINE CLEAR AVAILED
404	13-Jul-2022	TUMKUR	66	TR-1	CHALLAKERE_66	2:55	3:00	0:05	TRANSFORMER FAULT
405	13-Jul-2022	TUMKUR	66	TR-2	CHANNAGIRI_66	16:40	16:45	0:05	TRANSFORMER FAULT
406	13-Jul-2022	TUMKUR	66	TR-2	CHANNAGIRI_66	16:50	16:55	0:05	TRANSFORMER FAULT
407	13-Jul-2022	TUMKUR	66	CHANNGIRI-LINGADHALLI	CHANNAGIRI_66	6:50	7:20	0:30	MAIN SUPPLY FAILURE
408	13-Jul-2022	TUMKUR	66	TR-2	GARAGA_66	14:16	14:39	0:23	LINE CLEAR AVAILED
409	13-Jul-2022	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:31	9:34	0:02	MAIN SUPPLY FAILURE
410	13-Jul-2022	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:46	9:54	0:08	MAIN SUPPLY FAILURE
411	13-Jul-2022	TUMKUR	66	TR-1	HONNALLI_220	13:06	14:30	1:24	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
412	13-Jul-2022	TUMKUR	66	TR-2	HONNALLI_220	13:06	14:32	1:25	LINE CLEAR AVAILED
413	13-Jul-2022	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	6:54	7:14	0:19	LINE FAULT
414	13-Jul-2022	TUMKUR	66	TR-1	KORATAGERE_66	11:40	12:20	0:40	LINE CLEAR AVAILED
415	13-Jul-2022	TUMKUR	66	TR-2	KORATAGERE_66	12:25	12:50	0:25	LINE CLEAR AVAILED
416	13-Jul-2022	TUMKUR	66	PANDARAHALLI-CHITRADURGA220 1	PANDARAHALLI_66	10:12	18:04	7:52	MAIN SUPPLY FAILURE
417	13-Jul-2022	TUMKUR	66	PD KOTE66-AZURE POWER _IPP_66	AZURE POWER _IPP_66	10:35	18:32	7:57	LINE CLEAR AVAILED
418	13-Jul-2022	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	10:35	18:28	7:52	LINE CLEAR AVAILED
419	13-Jul-2022	TUMKUR	66	TR-1	PD KOTE_66	10:31	18:26	7:54	LINE CLEAR AVAILED
420	13-Jul-2022	TUMKUR	66	TR-2	PD KOTE_66	10:31	18:26	7:54	LINE CLEAR AVAILED
421	13-Jul-2022	TUMKUR	66	PDKOTE66-HIRIYUR_66	PD KOTE_66	10:31	18:24	7:53	LINE CLEAR AVAILED
422	13-Jul-2022	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	10:35	18:30	7:55	LINE CLEAR AVAILED
423	13-Jul-2022	TUMKUR	66	TR-2	SAVALANGA_66	15:59	16:25	0:25	TRANSFORMER FAULT
424	13-Jul-2022	TUMKUR	66	TR-2	URDIGERE_66	12:00	12:20	0:20	LINE CLEAR AVAILED
425	13-Jul-2022	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	12:00	12:21	0:21	LINE CLEAR AVAILED
426	13-Jul-2022	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 1	CHITRADURGA_66	10:12	12:52	2:40	HAND TRIPPED
427	13-Jul-2022	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_220	10:12	17:44	7:32	LINE CLEAR AVAILED
428	13-Jul-2022	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 1	CHITRADURGA_220	10:12	17:44	7:32	LINE CLEAR AVAILED
429	13-Jul-2022	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA3	CHITRADURGA_66	10:12	17:44	7:32	LINE CLEAR AVAILED
430	13-Jul-2022	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 4	CHITRADURGA_66	10:12	17:44	7:32	LINE CLEAR AVAILED
431	13-Jul-2022	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA IPP 66	16:24	16:40	0:16	HAND TRIPPED
432	13-Jul-2022	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	10:43	17:46	7:02	LINE CLEAR AVAILED
433	13-Jul-2022	TUMKUR	66	CHITRADURGA 220kV-HIRIYUR(HGML)	IMANGALA_66, ENERCON1 IPP_66, HIRIYUR_66	16:24	16:40	0:15	HAND TRIPPED
434	13-Jul-2022	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 1	CHITRADURGA_66	10:12	17:54	7:42	LINE CLEAR AVAILED
435	13-Jul-2022	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 2	CHITRADURGA_66	10:12	17:54	7:42	LINE CLEAR AVAILED
436	13-Jul-2022	TUMKUR	66	CHITRADURGA 66kV-PANDARAHALLI 2	PANDARAHALLI_66	10:13	17:58	7:44	LINE CLEAR AVAILED
437	13-Jul-2022	TUMKUR	66	TR-2	CHITRADURGA_66	10:13	17:54	7:41	LINE CLEAR AVAILED
438	13-Jul-2022	TUMKUR	66	CHITRADURGA 66kV-MEGMICON 1 IPP_66	MEGMICON 1_IPP_66	10:11	18:11	8:00	LINE CLEAR AVAILED
439	13-Jul-2022	TUMKUR	66	CHITRADURGA 66kV-MEGMICON 2 IPP_66	MEGMICON 2_IPP_66	10:11	18:04	7:53	LINE CLEAR AVAILED
440	14-Jul-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN,LINE CLEAR AVAILED
441	14-Jul-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN,LINE CLEAR AVAILED
442	14-Jul-2022	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	8:50 (06.07.2022)			LINE OPEN,LINE FAULT
443	14-Jul-2022	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	13:46 (10.07.2022)	14:34 (14.07.2022)	96:48hrs	LINE CHARGED
444	14-Jul-2022	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	13:46 (10.07.2022)	14:34 (14.07.2022)	96:48hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
445	14-Jul-2022	BAGALKOT	220	VAJJARMATTI-KUDAGI-1 (2)	220KV VAJJARMATTI	1:26 (13.07.2022)	15:44 (14.07.2022)	38:18hrs	LINE CHARGED
446	14-Jul-2022	BAGALKOT	220	220/110KV, HV3 & LV3	STATION NOT AFFECTED CHIKKODI_220	11:52 (13.07.2022)	16:17 (14.07.2022)	28:25hrs	TRANSFORMER CHARGED
447	14-Jul-2022	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	18:04 (14.07.2022)			LINE OPEN,LINE CLEAR AVAILED
448	14-Jul-2022	BAGALKOT	220	SIRSI-SHARAVATI-2	STATION NOT AFFECTED SIRSI_220	22:21	22:59	0:38	LINE FAULT
449	14-Jul-2022	BAGALKOT	110	MUGALKHOD220-KULIGOD	KULIGOD_110	10:26	10:36	0:10	LINE FAULT
450	14-Jul-2022	BAGALKOT	220	HAVERI-GUTTUR-2	STATION NOT AFFECTED HAVERI_220	9:24	16:56	7:32	LINE CLEAR AVAILED
451	14-Jul-2022	BAGALKOT	220	HAVERI-GUTTUR-2	STATION NOT AFFECTED HAVERI_220	17:11	19:15	2:04	HAND TRIPPED
452	14-Jul-2022	BAGALKOT	220	HAVERI-GUTTUR-1	STATION NOT AFFECTED HAVERI_220	15:04	16:57	1:53	LINE CLEAR AVAILED
453	14-Jul-2022	BAGALKOT	220	HAVERI220-HANAGAL (TILUVALI)	TILUVALI_110	15:17	16:19	1:02	LINE FAULT
454	14-Jul-2022	BAGALKOT	220	220/110KV, HV3 & LV3	STATION NOT AFFECTED CHIKKODI_220	18:51 (14.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
455	14-Jul-2022	BAGALKOT	220	AMBEWADI-NAGAJHARI-2	STATION NOT AFFECTED AMBEWADI_220	16:48	21:46	4:58	HAND TRIPPED
456	14-Jul-2022	BAGALKOT	220	AMBEWADI-NAGAJHARI-2	STATION NOT AFFECTED AMBEWADI_220	21:53 (14.07.2022)			LINE OPEN,LINE FAULT
457	14-Jul-2022	BAGALKOT	110	DAMBAL-EILS(L1)	DAMBAL_110	12:31	13:09	0:38	HAND TRIPPED
458	14-Jul-2022	BAGALKOT	110	DAMBAL-GADAG1(L5)	DAMBAL_110	12:31	15:05	2:34	HAND TRIPPED
459	14-Jul-2022	BAGALKOT	110	DAMBAL-SUZLON2((L2)	DAMBAL_110	12:31	13:03	0:32	HAND TRIPPED
460	14-Jul-2022	BAGALKOT	110	DAMBAL-GADAG1(L5)	DAMBAL_110	13:46	15:05	1:19	HAND TRIPPED
461	14-Jul-2022	BAGALKOT	110	110/11KV,HV1A	JAMAKHANDI_110	11:52	21:50	9:58	LINE CLEAR AVAILED
462	14-Jul-2022	BAGALKOT	110	MUNDARAGI-DAMBAL	MUNDARAGI_110	13:46	15:06	1:20	LINE CLEAR AVAILED
463	14-Jul-2022	BAGALKOT	110	MUNDARAGI-VIJAY SUGARS	MUNDARAGI_110	13:46	15:06	1:20	HAND TRIPPED
464	14-Jul-2022	BAGALKOT	110	110/11KV,HV3	RATTIHALI_110	11:32	11:40	0:08	TRANSFORMER FAULT
465	14-Jul-2022	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	16:45	16:54	0:09	TRANSFORMER FAULT
466	14-Jul-2022	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	14:41	17:18	2:37	LINE CLEAR AVAILED
467	14-Jul-2022	BAGALKOT	110	SAVANUR-SOLAR(HAVERI)	SAVANUR_110	18:26	18:38	0:12	LINE FAULT
468	14-Jul-2022	BAGALKOT	110	110/11KV,HV2	SHIRABUR_110	13:24	15:11	1:47	TRANSFORMER FAULT
469	14-Jul-2022	BAGALKOT	110	110/11KV,HV2	SHIRABUR_110	15:11	16:58	1:47	TRANSFORMER FAULT
470	14-Jul-2022	BAGALKOT	110	110/11KV,HV1	VAJRAMATTI_110	20:36	21:01	0:25	TRANSFORMER FAULT
471	14-Jul-2022	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
472	14-Jul-2022	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	10:50 (26.03.2022)			LINE OPEN,LINE CLEAR AVAILED
473	14-Jul-2022	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED ATHANI_220	9:41 (06.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
474	14-Jul-2022	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
475	14-Jul-2022	BAGALKOT	110	ANMOD-GOA-2	ANMOD_110	22:40 (11.07.2022)			LINE OPEN,LINE FAULT
476	14-Jul-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MANTUR_110	13:35	14:10	0:35	LINE CLEAR AVAILED
477	14-Jul-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MANTUR_110	14:10	15:00	0:50	LINE CLEAR AVAILED
478	14-Jul-2022	BAGALKOT	220	AMBEWADI-NAGAJHARI-1	STATION NOT AFFECTED AMBEWADI_220	8:35	8:53	0:18	LINE FAULT
479	14-Jul-2022	BAGALKOT	220	AMBEWADI-NAGAJHARI-1	STATION NOT AFFECTED AMBEWADI_220	11:38	11:54	0:16	LINE FAULT
480	14-Jul-2022	BAGALKOT	220	HUBLI-SRISI-1	STATION NOT AFFECTED HUBLI_220	18:04 (14.07.2022)			LINE OPEN,LINE FAULT
481	14-Jul-2022	BAGALKOT	110	CHIKKODI220- NANADI	NANADI_110	16:43	16:45	0:02	HAND TRIPPED
482	14-Jul-2022	BENGALURU	66	HV1	BIEC	14:27	14:37	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
483	14-Jul-2022	BENGALURU	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT), HMT (EHT)	11:14	11:19	0:05	LOAD CHANGE OVER
484	14-Jul-2022	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	11:14	11:19	0:05	LOAD CHANGE OVER
485	14-Jul-2022	BENGALURU	66	GOKULA - MATHIKERE	MATHIKERE	11:14	11:20	0:06	MAIN SUPPLY FAILURE
486	14-Jul-2022	BENGALURU	66	SARAKKI - JAYADEVA 2	NO STATION AFFECTED	12:39	16:25	3:46	LINE FAULT
487	14-Jul-2022	BENGALURU	66	HV1	JAYADEVA	6:46	6:48	0:02	LINE CLEAR AVOIDED
488	14-Jul-2022	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	11:04	11:09	0:05	LOAD CHANGE OVER
489	14-Jul-2022	BENGALURU	66	RMV - HEBBALA 220	RMV, TATA INSTITUTE (EHT)	16:15	16:20	0:05	LOAD CHANGE OVER
490	14-Jul-2022	BENGALURU	66	HV2	ST JOHN WOOD	22:26	22:30	0:04	LINE CLEAR AVOIDED
491	14-Jul-2022	BENGALURU	220	MANYATHA TECH PARK 220 - HBR LAYOUT 220	MANYATHA TECH PARK 220	17:55	18:09	0:14	LINE FAULT
492	14-Jul-2022	BENGALURU	66	MANYATHA TECH PARK 220 - SHOBHA CITY	SHOBHA CITY	17:55	18:09	0:14	MAIN SUPPLY FAILURE
493	14-Jul-2022	BENGALURU	220	HV2	MANYATHA TECH PARK 220	17:55	18:09	0:14	MAIN SUPPLY FAILURE
494	14-Jul-2022	BENGALURU	66	HV3	MANYATHA TECH PARK 220	17:55	18:09	0:14	MAIN SUPPLY FAILURE
495	14-Jul-2022	BENGALURU	66	HV4	NRS 220	15:26	17:41	2:15	LINE CLEAR AVOIDED
496	14-Jul-2022	BENGALURU	66	HV2	NRS 220	16:57	17:00	0:03	LINE CLEAR AVOIDED
497	14-Jul-2022	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, BIEC	15:00	15:23	0:23	LINE FAULT
498	14-Jul-2022	BENGALURU	66	HV2	AVERAHALLI	5:15	5:40	0:25	TRANSFORMER FAULT
499	14-Jul-2022	BENGALURU	66	AVERAHALLI - DABUSPETE 220	AVERAHALLI	5:15	5:20	0:05	LINE FAULT
500	14-Jul-2022	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI, ID HALLI	19:03	19:45	0:42	LINE FAULT
501	14-Jul-2022	BENGALURU	66	HV1	BOODIGERE	16:40	17:05	0:25	LINE CLEAR AVOIDED
502	14-Jul-2022	BENGALURU	66	HV1	TK HALLI 220	12:37	12:40	0:03	TRANSFORMER FAULT
503	14-Jul-2022	BENGALURU	66	HV1	DASHAVARA	12:06	12:26	0:20	LINE CLEAR AVOIDED
504	14-Jul-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	9:20	9:22	0:02	LOAD CHANGE OVER
505	14-Jul-2022	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT), DOODDABELAVANGALA	14:34	15:05	0:31	LINE FAULT
506	14-Jul-2022	BENGALURU	66	TG HALLI - TAVAREKERE	TAVAREKERE	17:45	19:19	1:33	LINE CLEAR AVOIDED
507	14-Jul-2022	BENGALURU	66	HV2	SADALI	16:50	17:05	0:15	LINE CLEAR AVOIDED
508	14-Jul-2022	BENGALURU	66	PATHPALYA - THIMAMPALLI	THIMMAMPALLI	16:30	18:19	1:49	LINE CLEAR AVOIDED
509	14-Jul-2022	BENGALURU	66	HV2	NANDAGUDI	13:23	13:59	0:35	LINE CLEAR AVOIDED
510	14-Jul-2022	BENGALURU	66	HV1	HULLENAHALLI	7:00	7:05	0:05	LINE CLEAR AVOIDED
511	14-Jul-2022	BENGALURU	66	HV2	GANJIGUNTE	14:51	15:06	0:14	TRANSFORMER FAULT
512	14-Jul-2022	BENGALURU	66	ALUR - NELAMANGALA 66	NO STATION AFFECTED	15:00	19:08	4:08	LINE FAULT
513	14-Jul-2022	BENGALURU	66	HV1	BAIRAKURU	12:00	12:03	0:02	LINE CLEAR AVOIDED
514	14-Jul-2022	BENGALURU	66	HV1	BAIRAKURU	15:31	15:33	0:01	LINE CLEAR AVOIDED
515	14-Jul-2022	BENGALURU	66	HV2	BAIRAKURU	16:25	16:28	0:02	LINE CLEAR AVOIDED
516	14-Jul-2022	BENGALURU	66	HV1	DEVANAHALLI 66	14:10	14:17	0:06	TRANSFORMER FAULT
517	14-Jul-2022	BENGALURU	66	MELUR - DB PURA 220	MELUR	17:45	17:50	0:05	LOAD CHANGE OVER
518	14-Jul-2022	BENGALURU	66	ACHALU - KANAKPURA 220	ACHALU, HONNIGANAHALLI, HALGURU	18:28	18:38	0:10	LINE FAULT
519	14-Jul-2022	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN,LINE CLEAR AVOIDED
520	14-Jul-2022	GULBARGA	220	SEDAM_SHAHAPUR	SEDAM_220	05:48(10/06/2022)			LINE OPEN,LINE CLEAR AVOIDED
521	14-Jul-2022	GULBARGA	220	SEDAM-HUMNABAD_1	HUMNABAD_220	14:55(12/07/2022)			LOAD CURTAILMENT
522	14-Jul-2022	GULBARGA	220	HV1	ALIPUR_220	14:03	14:15	0:12	TRANSFORMER FAULT
523	14-Jul-2022	GULBARGA	220	HV2	ITTAGI_220	10:54	11:05	0:11	LINE CLEAR AVOIDED
524	14-Jul-2022	GULBARGA	220	HALAWARTHY-DHONI1	HALAWARTHY_220	7:12			LINE OPEN,LINE CLEAR AVOIDED
525	14-Jul-2022	GULBARGA	220	HALAWARTHY-DHONI2	HALAWARTHY_220	7:45			LINE OPEN,LINE CLEAR AVOIDED
526	14-Jul-2022	GULBARGA	220	SINDHANOOR-BTPS	SINDHANOOR_220	8:18	12:40	4:22	NFBC ISSUED
527	14-Jul-2022	GULBARGA	220	NEELGUNDA-GUTTUR	NEELGUNDA_220	10:54	11:27	0:33	LINE FAULT
528	14-Jul-2022	GULBARGA	220	NEELGUNDA-ITTAGI	NEELGUNDA_220	10:54	11:27	0:33	LINE FAULT
529	14-Jul-2022	GULBARGA	220	ITTAGI-LINGAPUR	ITTAGI_220	10:50	11:05	0:15	LINE FAULT
530	14-Jul-2022	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN,LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
531	14-Jul-2022	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN,LINE CLEAR AVAILED
532	14-Jul-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN,LINE CLEAR AVAILED
533	14-Jul-2022	GULBARGA	110	HV1	MADIYAL_110	18:00(09.07.2022)	14:20(14.07.2022)	72:00HRS	TRANSFORMER CHARGED
534	14-Jul-2022	GULBARGA	110	HV2	GULBARGAUNIVERSITY_110	10:35	11:00	0:25	LINE CLEAR AVAILED
535	14-Jul-2022	GULBARGA	110	HV2	GULBARGAUNIVERSITY_110	11:05	11:55	0:50	LINE CLEAR AVAILED
536	14-Jul-2022	GULBARGA	110	HV2	DEODURGA_110	12:00	12:30	0:30	TRANSFORMER FAULT
537	14-Jul-2022	GULBARGA	110	HV2	DEODURGA_110	13:20	13:30	0:10	TRANSFORMER FAULT
538	14-Jul-2022	GULBARGA	110	HV1	MASKI_110	15:06	15:14	0:08	LINE CLEAR AVAILED
539	14-Jul-2022	GULBARGA	110	HV3	SREERAMANAGAR_110	17:20	17:31	0:11	TRANSFORMER FAULT
540	14-Jul-2022	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	3:31	3:47	0:16	LINE FAULT
541	14-Jul-2022	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	4:40	7:00	2:20	LINE FAULT
542	14-Jul-2022	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	1:31	1:36	0:05	LINE FAULT
543	14-Jul-2022	GULBARGA	110	YELBURGA-TALAKUTAI	YELBURGA_110	15:15	15:37	0:22	LINE CLEAR AVAILED
544	14-Jul-2022	GULBARGA	110	GANDHINAGAR-SINDHANOOR	GANDHINAGAR_110,TURVIHAL_110	9:02	17:55	8:53	LINE CLEAR AVAILED
545	14-Jul-2022	GULBARGA	110	YERADONA-SINDHANOOR	YERADONA_110	8:15	12:30	4:15	MAIN SUPPLY FAILURE
546	14-Jul-2022	GULBARGA	110	HATTI-SINDHANOOR	HATTI_110	16:02	16:05	0:03	MAIN SUPPLY FAILURE
547	14-Jul-2022	GULBARGA	110	BENNUR-SINDHANOOR	BENNUR_110	8:20	12:40	4:20	MAIN SUPPLY FAILURE
548	14-Jul-2022	GULBARGA	110	MADIYAL-GOUDAGOA(RAILWAY TRACK_110)MADIYAL_110		1:26	1:31	0:05	LINE FAULT
549	14-Jul-2022	GULBARGA	110	MAKI-SINDHANOOR	MASKI_110,HATTI_110	1:30	1:35	0:05	MAIN SUPPLY FAILURE
550	14-Jul-2022	GULBARGA	110	MAKI-SINDHANOOR	MASKI_110,HATTI_110	3:30	3:40	0:10	MAIN SUPPLY FAILURE
551	14-Jul-2022	GULBARGA	110	MAKI-SINDHANOOR	MASKI_110,HATTI_110	4:40	4:48	0:08	MAIN SUPPLY FAILURE
552	14-Jul-2022	GULBARGA	110	MAKI-SINDHANOOR	MASKI_110,HATTI_110	16:02	16:09	0:07	LINE FAULT
553	14-Jul-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	22:31	22:37	0:06	LINE FAULT
554	14-Jul-2022	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHICKSUGUR_110,SHAKTINAGAR_110	13:18	14:16	0:58	LINE CLEAR AVAILED
555	14-Jul-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	5:53	5:58	0:05	LINE FAULT
556	14-Jul-2022	GULBARGA	110	SEDAM-VICTSAGAR_IPP	VICATSAGARCEMNETS	5:05	6:10	1:05	LINE FAULT
557	14-Jul-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	8:14	12:40	4:26	LINE CLEAR AVAILED
558	14-Jul-2022	GULBARGA	110	SINDHANOOR-TURVIHAL	GANDHI NAGAR_110,TURVIHAL_110	9:02	17:55	8:53	LINE CLEAR AVAILED
559	14-Jul-2022	GULBARGA	66	HV1	ITTAGI_220	10:50	11:09	0:19	TRANSFORMER FAULT
560	14-Jul-2022	GULBARGA	66	HV2	HALVAGALU_66	12:25	12:30	0:05	TRANSFORMER FAULT
561	14-Jul-2022	GULBARGA	66	PUNABGHATA-UCHCHANGIDURGA	UCHCHANGIDURGA_66,BILCHOD_66	22:40	22:50	0:10	LINE FAULT
562	14-Jul-2022	GULBARGA	66	UJJAINI-BREIPL_IPP	UJJAINI_66	12:14	12:25	0:11	LINE CLEAR AVAILED
563	14-Jul-2022	GULBARGA	66	BENNEHALLI-ITTAGGI	BENNEHALLI_66,KOTTUR_66	15:00	15:20	0:20	LINE FAULT
564	14-Jul-2022	GULBARGA	66	ITTAGI-HAGARIBOMMANAHALLI	HAGARIBOMMANAHALLI_66,UPANAYAKANAHALLI_66	10:17	16:15	5:58	NFBC ISSUED
565	14-Jul-2022	GULBARGA	66	ITTAGI-BENNEHALLI	BENNEHALLI_66, KOTTUR_66, UJJAINI_66	14:58	15:12	0:14	LINE FAULT
566	14-Jul-2022	GULBARGA	66	ITTAGI-KUDLIGI1	KOGALI_66,KUDLIGI_66,HANAS I_66	21:46	22:00	0:14	LINE FAULT
567	14-Jul-2022	GULBARGA	66	ITTAGI-KUDLIGI1	KOGALI_66,KUDLIGI_66,HANAS I_66	23:33	23:43	0:10	LINE FAULT
568	14-Jul-2022	GULBARGA	66	HIREHADAGALLI-GIRIYAPURA	GIRIYAPURA_66,SOVENAHALLI_66,MAGALA_66	17:25	17:30	0:05	LINE FAULT
569	14-Jul-2022	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavaathy_gen	22:34(14.07.2022)			LINE OPEN,LINE CLEAR AVAILED
570	14-Jul-2022	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	22:34(14.07.2022)			LINE OPEN,LINE CLEAR AVAILED
571	14-Jul-2022	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	10:02	16:33	6:31	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
572	14-Jul-2022	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	11:11	14:59	3:48	LINE CLEAR AVAILED
573	14-Jul-2022	HASSAN	110	HV1	MRSMSG_220	10:40	13:15	2:35	LINE CLEAR AVAILED
574	14-Jul-2022	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavaathy_gen	15:15	18:44	3:29	LINE FAULT
575	14-Jul-2022	HASSAN	220	SHRLKP-SGS	SHIRAALKOPPA_220	15:15	18:44	3:29	LINE FAULT
576	14-Jul-2022	HASSAN	110	SHRLKP-BARANG	SHIRAALKOPPA_220	15:06	15:21	0:15	HAND TRIPPED
577	14-Jul-2022	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRAALKOPPA_220	15:06	15:21	0:15	HAND TRIPPED
578	14-Jul-2022	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRAALKOPPA_220	15:06	15:20	0:14	HAND TRIPPED
579	14-Jul-2022	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRAALKOPPA_220	15:06	15:21	0:15	HAND TRIPPED
580	14-Jul-2022	HASSAN	110	SHRLKP-SORABA	SHIRAALKOPPA_220	15:06	15:21	0:15	HAND TRIPPED
581	14-Jul-2022	HASSAN	220	VARAH1-SHMG3	varahi_gen	11:13	14:59	3:46	NFBC ISSUED
582	14-Jul-2022	HASSAN	110	HV1	BARANGI_110	15:03	17:31	2:28	LINE CLEAR AVAILED
583	14-Jul-2022	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	10:02	14:39	4:37	LINE CLEAR AVAILED
584	14-Jul-2022	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	10:23	14:37	4:14	LINE CLEAR AVAILED
585	14-Jul-2022	HASSAN	110	HV2	PUTTUR_110	13:06	13:18	0:12	TRANSFORMER FAULT
586	14-Jul-2022	HASSAN	66	HV1	AREHALLI_66	8:45	9:46	1:01	LINE CLEAR AVAILED
587	14-Jul-2022	HASSAN	66	HV1	AREHALLI_66	9:52	10:32	0:40	LINE CLEAR AVAILED
588	14-Jul-2022	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	14:04	14:08	0:04	MAIN SUPPLY FAILURE
589	14-Jul-2022	HASSAN	66	HV1	HANGARAHALLI_66	11:31	12:20	0:49	LINE CLEAR AVAILED
590	14-Jul-2022	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	20:52	21:09	0:17	MAIN SUPPLY FAILURE
591	14-Jul-2022	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATANA_66	11:30	11:43	0:13	LINE FAULT
592	14-Jul-2022	HASSAN	66	SAKALE-HASSAN2	SAKLESHPUA_66	14:05	14:25	0:20	LINE FAULT
593	14-Jul-2022	HASSAN	66	SAKALE-HASSAN1	SAKLESHPUA_66	14:05	14:10	0:05	HAND TRIPPED
594	14-Jul-2022	HASSAN	66	SAKALE-HASSAN1	SAKLESHPUA_66	20:51	21:00	0:09	LINE FAULT
595	14-Jul-2022	HASSAN	66	HV2	SAKLESHPUA_66	0:38	0:46	0:08	TRANSFORMER FAULT
596	14-Jul-2022	HASSAN	66	HV1	YESLUR_66	7:12	7:48	0:36	TRANSFORMER FAULT
597	14-Jul-2022	HASSAN	66	HV1	YESLUR_66	16:19	16:42	0:23	TRANSFORMER FAULT
598	14-Jul-2022	MYSURU	66	JYOTHINAGAR-FTS	FTS_66	11:32	11:49	0:17	LINE FAULT
599	14-Jul-2022	MYSURU	66	HV2	MADIKERI_66	6:19	6:33	0:13	HAND TRIPPED
600	14-Jul-2022	MYSURU	66	HV2	SANTHEMARAHALLI_66	14:35	15:10	0:35	TRANSFORMER FAULT
601	14-Jul-2022	MYSURU	66	SHANIVARSANTE-YESSLUR	YESLOR_66	1:31	2:18	0:46	LINE FAULT
602	14-Jul-2022	MYSURU	66	SHANIVARSANTE-YESSLUR	SHANIVARSANTE_66 YESLOR_66	11:29	11:45	0:15	LINE FAULT
603	14-Jul-2022	MYSURU	66	HOOTAGALLY-BARC 2	NO STATIONS EFFECTED	13:13	14:01	0:48	LINE FAULT
604	14-Jul-2022	MYSURU	66	HOOTAGALLY-BANNIKUPPE	NO STATIONS EFFECTED	13:13	14:04	0:51	LINE FAULT
605	14-Jul-2022	MYSURU	66	NAGAMANGALA 220-KOPPA	NO STATIONS EFFECTED	18:30	18:50	0:20	LINE FAULT
606	14-Jul-2022	MYSURU	220	HV2	NAGAMANGALA_220	18:30	18:52	0:22	TRANSFORMER FAULT
607	14-Jul-2022	MYSURU	66	KADAKOLA-MANDAKALLI	MANDAKALLI_66	10:27	10:33	0:06	LINE FAULT
608	14-Jul-2022	MYSURU	220	KADAKOLA-HOOTAGALLI	NO STATIONS EFFECTED	11:28	14:56	3:28	LINE CLEAR AVAILED
609	14-Jul-2022	MYSURU	66	KUSHALANAGARA-MADIKERI	NO STATIONS EFFECTED	9:48	18:25	8:37	LINE CLEAR AVAILED
610	14-Jul-2022	MYSURU	66	KUSHALANAGARA-SUNTIKOPPA	MADIKERE_66 SUNTIKOPPA_66	10:07	18:25	8:18	LINE CLEAR AVAILED
611	14-Jul-2022	MYSURU	66	HV2	CHIKKAMANDYA_66	12:55	13:15	0:20	LINE CLEAR AVAILED
612	14-Jul-2022	MYSURU	66	HALAGURU-HONAGANAHALLI	HALAGURU_66	18:30	18:45	0:15	HAND TRIPPED
613	14-Jul-2022	MYSURU	66	HV2	SHEELUNERE_66	5:20	5:25	0:05	TRANSFORMER FAULT
614	14-Jul-2022	MYSURU	66	K R NAGARA-BHERYA	BHERYA_66	10:45	11:00	0:15	LINE FAULT
615	14-Jul-2022	MYSURU	66	SUNTIKOPPA-MADIKERI	NO STATIONS EFFECTED	14:34 (13.07.2022)			LINE OPEN,LINE FAULT
616	14-Jul-2022	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00 (12.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
617	14-Jul-2022	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
618	14-Jul-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	18:26 (22/04/2022)			LINE OPEN,LINE CLEAR AVAILED
619	14-Jul-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN,LINE CLEAR AVAILED
620	14-Jul-2022	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	10:51	11:23	0:32	LINE FAULT
621	14-Jul-2022	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:04	16:56	1:52	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
622	14-Jul-2022	TUMKUR	66	ANTHRASANAHALI 220kV-KOLTEGERE	KOLTEGERE,CHIKKATOTLUKER E 66,BELADARA 66	10:43	17:50	7:06	LINE CLEAR AVAILED
623	14-Jul-2022	TUMKUR	66	TR-1	BENKIKERE 66	12:56	13:02	0:05	HAND TRIPPED
624	14-Jul-2022	TUMKUR	66	TR-2	BENKIKERE 66	12:23	12:56	0:33	HAND TRIPPED
625	14-Jul-2022	TUMKUR	66	TR-2	CHANNAGIRI 66	20:41	20:47	0:06	TRANSFORMER FAULT
626	14-Jul-2022	TUMKUR	66	TR-1	CHIKKATOTLUKERE 66	10:14	17:59	7:44	LINE CLEAR AVAILED
627	14-Jul-2022	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA 66, TYAVANAGI 66, BASAVAPATNA 66, SANTEBENNUR 66	3:02	3:14	0:11	LINE FAULT
628	14-Jul-2022	TUMKUR	66	HIRIYUR 220KV-ENERCON1 IPP 66	ENERCON1_IPP_66	13:28	13:32	0:04	HAND TRIPPED
629	14-Jul-2022	TUMKUR	66	HIRIYUR 220KV-RANGANATHPURA	RANGANATHAPURA_66	13:28	13:32	0:04	HAND TRIPPED
630	14-Jul-2022	TUMKUR	66	HONNALLI 220kV-CHANNAGIRI(NALLUR )	DEVARAHALLI 66, LINGADAHALLI 66, NALLUR 66, GOPPENAHALLI 66	7:18	8:05	0:46	LINE CLEAR AVAILED
631	14-Jul-2022	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	13:04	13:08	0:03	LINE FAULT
632	14-Jul-2022	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	13:22	13:29	0:07	LINE FAULT
633	14-Jul-2022	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE66	NAYAKANHATTI 66, HIREMALLANAHOLE 66	9:59	10:12	0:12	LINE FAULT
634	14-Jul-2022	TUMKUR	66	PDKOTE66-HIRIYUR 66	PD KOTE 66	9:53	16:07	6:13	LINE CLEAR AVAILED
635	14-Jul-2022	TUMKUR	66	PD KOTE66-AZURE POWER IPP 66	AZURE POWER_IPP_66	9:55	16:14	6:19	LINE CLEAR AVAILED
636	14-Jul-2022	TUMKUR	66	PD KOTE 66-CLEAR SOLAR IPP 66	CLEAR SOLAR_IPP_66	9:55	16:20	6:25	LINE CLEAR AVAILED
637	14-Jul-2022	TUMKUR	66	TR-1	PD KOTE 66	10:43	16:08	5:24	LINE CLEAR AVAILED
638	14-Jul-2022	TUMKUR	66	TR-2	PD KOTE 66	10:43	16:08	5:25	LINE CLEAR AVAILED
639	14-Jul-2022	TUMKUR	66	PD KOTE66-SOLITAIRE_IPP 66	SOLITAIRE_IPP 66	9:55	16:21	6:26	LINE CLEAR AVAILED
640	15-Jul-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL 110	16:13 (04.03.2022)			LINE OPEN,LINE CLEAR AVAILED
641	15-Jul-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI 220	8:55 (23.05.2022)			LINE OPEN,LINE CLEAR AVAILED
642	15-Jul-2022	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA 110	8:50 (06.07.2022)			LINE OPEN,LINE FAULT
643	15-Jul-2022	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI 220	18:04 (14.07.2022)	17:02 (15.07.2022)	22:58hrs	LINE CHARGED
644	15-Jul-2022	BAGALKOT	220	220/110KV, HV3 & LV3	STATION NOT AFFECTED CHIKKODI 220	18:51 (14.07.2022)	17:45 (15.07.2022)	22:54hrs	TRANSFORMER CHARGED
645	15-Jul-2022	BAGALKOT	220	AMBEWADI-NAGAJHARI-2	STATION NOT AFFECTED AMBEWADI 220	21:53 (14.07.2022)	07:47 (15.07.2022)	9:54hrs	LINE CHARGED
646	15-Jul-2022	BAGALKOT	220	BAGEWADI-NANDYAL1(BIJAPUR1)	BAGEWADI_220	10:58	11:00	0:02	HAND TRIPPED
647	15-Jul-2022	BAGALKOT	220	BAGEWADI-NANDYAL2(BIJAPUR2)	BAGEWADI_220	10:58	11:03	0:05	HAND TRIPPED
648	15-Jul-2022	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL 110	5:52	6:00	0:08	LINE FAULT
649	15-Jul-2022	BAGALKOT	110	110/11KV,HV1	BENAKATTI 110	13:55	17:27	3:32	TRANSFORMER FAULT
650	15-Jul-2022	BAGALKOT	110	110/11KV,HV2	BENAKATTI 110	15:19	17:27	2:08	LINE CLEAR AVAILED
651	15-Jul-2022	BAGALKOT	110	110/33KV,HV2	CHIKKODI 110 &KAROSHI&KERUR 33	12:27	12:52	0:25	LINE CLEAR AVAILED
652	15-Jul-2022	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL 220	13:37	15:13	1:36	LINE FAULT
653	15-Jul-2022	BAGALKOT	110	DAMBAL-EILS(1)	DAMABAL 110	10:20	12:29	2:09	HAND TRIPPED
654	15-Jul-2022	BAGALKOT	110	DAMBAL-SUZLON(3)	DAMABAL 110	10:20	12:25	2:05	HAND TRIPPED
655	15-Jul-2022	BAGALKOT	110	DAMBAL-SUZLON(2)	DAMABAL 110	10:20	12:25	2:05	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
656	15-Jul-2022	BAGALKOT	110	110/11KV,HV1	HIREKERUR_110	11:07	11:17	0:10	LINE CLEAR AVAILED
657	15-Jul-2022	BAGALKOT	110	110/11KV,HV1	HOSAHONNATTI_110	15:25	15:40	0:15	LINE CLEAR AVAILED
658	15-Jul-2022	BAGALKOT	110	110/11KV,HV1A	JAMAKHANDI_110	13:24	17:07	3:43	TRANSFORMER FAULT
659	15-Jul-2022	BAGALKOT	110	110/11KV,HV2	KALAGHATGI_110	18:22	18:24	0:02	TRANSFORMER FAULT
660	15-Jul-2022	BAGALKOT	110	110/11KV,HV1	MANTUR(G)_110	15:58	17:20	1:22	LINE CLEAR AVAILED
661	15-Jul-2022	BAGALKOT	110	110/11KV,HV2	MANTUR(G)_110	15:58	17:35	1:37	LINE CLEAR AVAILED
662	15-Jul-2022	BAGALKOT	110	MUNDARAGI-VIJAY SUGARS	MUNDARAGI_110	10:18	10:30	0:12	LINE FAULT
663	15-Jul-2022	BAGALKOT	110	110/11KV,HV1	NARAGUND_110	10:15	10:26	0:11	TRANSFORMER FAULT
664	15-Jul-2022	BAGALKOT	110	110/11KV,HV1	SHIRABUR_110	12:51	18:07	5:16	LINE CLEAR AVAILED
665	15-Jul-2022	BAGALKOT	110	110/11KV,HV2	SULTANPUR_110	14:30	14:44	0:14	LINE CLEAR AVAILED
666	15-Jul-2022	BAGALKOT	110	AMBEWDI220-NK-1	STATION NOT AFFECTED AMBEWADI_220	11:06	12:15	1:09	LINE CLEAR AVAILED
667	15-Jul-2022	BAGALKOT	110	AMBEWDI220-NK-1	STATION NOT AFFECTED AMBEWADI_220	12:28	12:35	0:10	HAND TRIPPED
668	15-Jul-2022	BAGALKOT	220	SIRSI-SHARAVATHI-1	STATION NOT AFFECTED SIRSI_220	12:53	16:43	3:50	HAND TRIPPED
669	15-Jul-2022	BAGALKOT	220	SIRSI-SHARAVATHI-2	STATION NOT AFFECTED SIRSI_220	12:53	16:44	3:51	HAND TRIPPED
670	15-Jul-2022	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
671	15-Jul-2022	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
672	15-Jul-2022	BAGALKOT	220	SIRSI-SHARAVATHI-2	STATION NOT AFFECTED SIRSI_220	20:28	20:37	0:09	HAND TRIPPED
673	15-Jul-2022	BAGALKOT	220	HUBLI-SIRSI-2	STATION NOT AFFECTED HUBLI_220	11:45	17:07	5:22	HAND TRIPPED
674	15-Jul-2022	BAGALKOT	110	MUGALKHOD220-NAGANUR	NAGANUR_110	0:51	1:05	0:15	LINE FAULT
675	15-Jul-2022	BAGALKOT	110	MUGALKHOD220-KULIGOD	KULIGOD_110	9:22	9:38	0:16	LINE FAULT
676	15-Jul-2022	BAGALKOT	220	HAVERI-GUTTUR-1	STATION NOT AFFECTED HAVERI_220	15:12	18:30	3:18	NFBC ISSUED
677	15-Jul-2022	BAGALKOT	220	AMBEWADI-PONDA (XELDOM)-1	AMBEWADI_220	11:44	13:42	1:58	MAIN SUPPLY FAILURE
678	15-Jul-2022	BAGALKOT	220	220/110KV, HV1	AHERI_220	12:58	13:19	0:21	TRANSFORMER FAULT
679	15-Jul-2022	BAGALKOT	110	220/110KV, LV1	AHERI_220	12:58	13:25	0:27	TRANSFORMER FAULT
680	15-Jul-2022	BAGALKOT	220	DHONI400-LGPR (HALAVARTHI)-1&2	STATION NOT AFFECTED DHONI_400	10:35	13:00	2:25	LINE CLEAR AVAILED
681	15-Jul-2022	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
682	15-Jul-2022	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	10:50 (26.03.2022)			LINE OPEN,LINE CLEAR AVAILED
683	15-Jul-2022	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED ATHANI_220	9:41 (06.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
684	15-Jul-2022	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
685	15-Jul-2022	BAGALKOT	110	ANMOD-GOA-2	ANMOD_110	22:40 (11.07.2022)	14:00 (15.07.2022)	15:20hrs	LINE CHARGED
686	15-Jul-2022	BAGALKOT	220	HUBLI-SRISI-1	STATION NOT AFFECTED HUBLI_220	18:04 (14.07.2022)	17:07 (15.07.2022)	23:03hrs	LINE CHARGED
687	15-Jul-2022	BAGALKOT	110	AMBEWADI-SUPA-2	STATION NOT AFFECTED AMBEWADI_220	8:17	11:10	2:53	HAND TRIPPED
688	15-Jul-2022	BAGALKOT	110	AMBEWADI220-HALIYAL	HALIYAL_110	0:00	10:56	10:56	MAIN SUPPLY FAILURE
689	15-Jul-2022	BAGALKOT	110	AMBEWADI TO HALIYAL	110KV HALIYAL	10:56	12:35	1:39	MAIN SUPPLY FAILURE
690	15-Jul-2022	BAGALKOT	110	GOA LINE 2 TO ANMODE	ANMODE_110	15:03	23:59	8:56	LINE FAULT
691	15-Jul-2022	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	9:18	17:07	7:11	HAND TRIPPED
692	15-Jul-2022	BAGALKOT	220	220/110KV, HV2 & LV2	SIRSI_220	12:41	17:15	4:34	HAND TRIPPED
693	15-Jul-2022	BAGALKOT	220	220/110KV, HV1 & LV1	SIRSI_220	12:47	17:15	4:28	HAND TRIPPED
694	15-Jul-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KATARAKI_110	12:02	12:30	0:28	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
695	15-Jul-2022	BAGALKOT	110	INDI220-LACHYAN	LACHYAN_110	17:15	18:00	0:45	HAND TRIPPED
696	15-Jul-2022	BAGALKOT	220	NARENDRA-BELGAUM-2	STATION NOT AFFECTED NARENDRA_220	8:28	19:33	11:05	LINE FAULT
697	15-Jul-2022	BAGALKOT	110	20 MVA TRF -1	110kv Tilavalli	15:20	18:05	2:45	LINE CLEAR AVOIDED
698	15-Jul-2022	BAGALKOT	220	BIJAPUR-AHERI	AHERI_220	12:37	13:07	0:30	MAIN SUPPLY FAILURE
699	15-Jul-2022	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	18:00	18:51	0:51	LINE FAULT
700	15-Jul-2022	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	18:51	20:19	1:28	LINE CLEAR AVOIDED
701	15-Jul-2022	BENGALURU	66	HV2	BG ROAD	19:04	19:12	0:08	TRANSFORMER FAULT
702	15-Jul-2022	BENGALURU	66	HV1	BIEC	9:47	9:50	0:03	TRANSFORMER FAULT
703	15-Jul-2022	BENGALURU	66	ELITA PROMENENDE - RBI	ELITA PROMENENDE	10:58	11:03	0:05	LOAD CHANGE OVER
704	15-Jul-2022	BENGALURU	66	ELITA PROMENENDE - KHODAYS 220	ELITA PROMENENDE	16:32	16:37	0:05	LOAD CHANGE OVER
705	15-Jul-2022	BENGALURU	66	GURUVINAPURA - TK HALLI 220	GURUVINAPURA	9:06	9:13	0:07	MAIN SUPPLY FAILURE
706	15-Jul-2022	BENGALURU	66	GURUVINAPURA - SOMANAHALLI 220	GURUVINAPURA	16:08	16:14	0:06	LOAD CHANGE OVER
707	15-Jul-2022	BENGALURU	66	HV1	HENNUR CROSS	13:22	13:24	0:02	LINE CLEAR AVOIDED
708	15-Jul-2022	BENGALURU	66	K&C VALLEY - KORAMANGALA 220	K&C VALLEY	11:48	15:15	3:27	LINE CLEAR AVOIDED
709	15-Jul-2022	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	7:24	7:29	0:05	LOAD CHANGE OVER
710	15-Jul-2022	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	10:55	11:04	0:09	LOAD CHANGE OVER
711	15-Jul-2022	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	16:10	16:27	0:17	LOAD CHANGE OVER
712	15-Jul-2022	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	11:11	11:18	0:07	LOAD CHANGE OVER
713	15-Jul-2022	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	16:28	16:35	0:07	LOAD CHANGE OVER
714	15-Jul-2022	BENGALURU	66	TK HALLI 220 - BWSSB 4 (EHT)	BWSSB 4 (EHT)	18:02	18:10	0:08	LINE FAULT
715	15-Jul-2022	BENGALURU	66	HV1	TK HALLI 220	15:13	15:14	0:01	LINE CLEAR AVOIDED
716	15-Jul-2022	BENGALURU	66	VR DODDI - TK HALLI 220	VR DODDI	9:06	9:12	0:06	MAIN SUPPLY FAILURE
717	15-Jul-2022	BENGALURU	66	VR DODDI - SOMANAHALLI 220	VR DODDI	16:08	16:14	0:06	LOAD CHANGE OVER
718	15-Jul-2022	BENGALURU	66	HV1	SOUDELLA	11:00	15:15	4:15	LINE CLEAR AVOIDED
719	15-Jul-2022	BENGALURU	66	HV2	SOUDELLA	11:00	15:15	4:15	LINE CLEAR AVOIDED
720	15-Jul-2022	BENGALURU	66	BEVOOR - RAMANAGARA	BEVOOR, SANKALGERE, DASHAVARA	11:17	12:08	0:51	LINE CLEAR AVOIDED
721	15-Jul-2022	BENGALURU	220	HV2	DB PURA 220	10:25	16:38	6:13	LINE CLEAR AVOIDED
722	15-Jul-2022	BENGALURU	66	DB PURA 220 - VIJAYPURA	VIJAYPURA, JANGAMKOTE	10:16	17:04	6:48	LINE CLEAR AVOIDED
723	15-Jul-2022	BENGALURU	220	LV2	DB PURA 220	10:25	16:52	6:27	LINE CLEAR AVOIDED
724	15-Jul-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARDANAHALLI	11:00	16:58	5:58	LINE CLEAR AVOIDED
725	15-Jul-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA 1	TUBGERE	11:00	14:16	3:16	LINE CLEAR AVOIDED
726	15-Jul-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA 1	TUBGERE	16:54	16:57	0:03	LINE CLEAR AVOIDED
727	15-Jul-2022	BENGALURU	66	HV1	MUDIYANUR	13:35	13:40	0:05	LINE CLEAR AVOIDED
728	15-Jul-2022	BENGALURU	66	HV2	MUDIYANUR	14:30	15:40	1:10	LINE CLEAR AVOIDED
729	15-Jul-2022	BENGALURU	66	MUDIYANUR - H GOLLAHALLI	MUDIYANUR	16:15	16:45	0:30	LINE CLEAR AVOIDED
730	15-Jul-2022	BENGALURU	66	TEKAL - KGF 1	TEKAL, BUDIKOTE, THORALAKKI	14:00	14:45	0:45	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
731	15-Jul-2022	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN,LINE CLEAR AVAILED
732	15-Jul-2022	GULBARGA	220	HALAWARTHY-DHONI1	HALAWARTHY_220	7:12(05.7.22)			LINE OPEN,LINE CLEAR AVAILED
733	15-Jul-2022	GULBARGA	220	HALAWARTHY-DHONI2	HALAWARTHY_220	7:45(05.7.22)			LINE OPEN,LINE CLEAR AVAILED
734	15-Jul-2022	GULBARGA	220	SEDAM_SHAHAPUR	SEDAM_220	05:48(10/06/2022)			LINE OPEN,LINE CLEAR AVAILED
735	15-Jul-2022	GULBARGA	220	SEDAM-TANDUR	TANDUR_220	14:02(15/07/2022)			LINE OPEN,LINE FAULT
736	15-Jul-2022	GULBARGA	220	HV2	HUMNABAD_220	10:44	12:40	1:56	LINE CLEAR AVAILED
737	15-Jul-2022	GULBARGA	220	HV1	KUDLIGI_220	17:05	17:45	0:40	LINE CLEAR AVAILED
738	15-Jul-2022	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	11:05	11:29	0:24	LOAD CURTAILMENT
739	15-Jul-2022	GULBARGA	220	MALLAT-RTPS	MALLAT_220	11:03	13:39	2:36	LOAD CURTAILMENT
740	15-Jul-2022	GULBARGA	220	SHAHAPUR-KAPNOOR	SHAHAPUR_220	12:39	16:48	4:09	NFBC ISSUED
741	15-Jul-2022	GULBARGA	220	LINGAPUR-KUSTAGI	LINGAPUR_220	12:41	13:41	1:00	LINE CLEAR AVAILED
742	15-Jul-2022	GULBARGA	220	KUSHTAGI-LINGAPUR	KUSHTAGI_220	12:42	13:52	1:10	LINE CLEAR AVAILED
743	15-Jul-2022	GULBARGA	220	SEDAM-TANDUR	TANDUR_220	10:40	12:00	1:20	LINE FAULT
744	15-Jul-2022	GULBARGA	220	SEDAM-HUMNABAD_1	HUMNABAD_220	14:55(12/07/2022)	13:26(15/07/2022)	70:31HRS	LINE CHARGED
745	15-Jul-2022	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110,KONKAL_110	11:18(15/07/2022)			LINE OPEN,LINE CLEAR AVAILED
746	15-Jul-2022	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN,LINE CLEAR AVAILED
747	15-Jul-2022	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN,LINE CLEAR AVAILED
748	15-Jul-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN,LINE CLEAR AVAILED
749	15-Jul-2022	GULBARGA	110	HV1	ADAVI AMARESHWAR_110	10:00	17:25	7:25	LINE CLEAR AVAILED
750	15-Jul-2022	GULBARGA	110	NIRNA-RENEW SOLAR1	NIRNA_110	11:09	11:30	0:21	LINE CLEAR AVAILED
751	15-Jul-2022	GULBARGA	110	YERADONA-SINDHANOOR	YERADONA_110	20:10	20:20	0:10	MAIN SUPPLY FAILURE
752	15-Jul-2022	GULBARGA	110	CHITGUPPA-ACMSLR	CHITGUPPA_110	11:00	11:20	0:20	LINE FAULT
753	15-Jul-2022	GULBARGA	110	MALLAT-KONDAPURAM SOLAR_IPP	MALLAT_220	14:49	16:24	1:35	LINE FAULT
754	15-Jul-2022	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	14:22	15:52	1:30	LINE CLEAR AVAILED
755	15-Jul-2022	GULBARGA	110	HALBARGA-HUMNABAD	HUMNABAD_110	3:34	3:50	0:16	NFBC ISSUED
756	15-Jul-2022	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,YERAGERA_110,VADAVATTI_110,YAPALDINI_110	3:50	3:57	0:07	LINE FAULT
757	15-Jul-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGAL_110	4:55	4:59	0:04	LINE FAULT
758	15-Jul-2022	GULBARGA	110	KUSHTAGI-KUSHTAGI_SOLAR_IPP	KUSHTAGI_220	14:05	14:12	0:07	LINE CLEAR AVAILED
759	15-Jul-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	4:04	4:11	0:07	LINE FAULT
760	15-Jul-2022	GULBARGA	110	SEDAM-CHITTAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	2:55	3:05	0:10	LINE FAULT
761	15-Jul-2022	GULBARGA	110	SEDAM-VICTSAGAR_IPP	VICATSAGARCEMNETS	3:20	3:40	0:20	LINE FAULT
762	15-Jul-2022	GULBARGA	110	SEDAM-VICTSAGAR_IPP	VICATSAGARCEMNETS	4:10	4:20	0:10	LINE FAULT
763	15-Jul-2022	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	11:56	12:12	0:35	LINE FAULT
764	15-Jul-2022	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	13:30	13:36	0:35	LINE FAULT
765	15-Jul-2022	GULBARGA	66	HV1&HV2	HIREHADAGALLI_66	8:45	12:00	3:15	LINE CLEAR AVAILED
766	15-Jul-2022	GULBARGA	66	HV1&HV2	HIREHADAGALLI_66	18:40	19:40	1:00	LINE CLEAR AVAILED
767	15-Jul-2022	GULBARGA	66	HV2	HALAVAGALU_110	8:50	8:55	0:05	TRANSFORMER FAULT
768	15-Jul-2022	GULBARGA	66	HV2	HALAVAGALU_110	15:05	15:10	0:05	TRANSFORMER FAULT
769	15-Jul-2022	GULBARGA	66	HANASI-BADALADUKU	HANASI_66	16:20	16:50	0:30	MAIN SUPPLY FAILURE
770	15-Jul-2022	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJAINI_66	0:20	0:35	0:15	LINE FAULT
771	15-Jul-2022	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJAINI_66	10:55	11:05	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
772	15-Jul-2022	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCH OD_66,UJJAINI_66	12:00	12:35	0:35	LINE FAULT
773	15-Jul-2022	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCH OD_66,UJJAINI_66	13:00	13:05	0:05	LINE FAULT
774	15-Jul-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
775	15-Jul-2022	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	22:34(14.07.2022)	12:33(15.07.2022)	13:59HRS	LINE CHARGED
776	15-Jul-2022	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	22:34(14.07.2022)	12:33(15.07.2022)	13:59HRS	LINE CHARGED
777	15-Jul-2022	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)	18:35(15.07.2022)	653:23HRS	TRANSFORMER CHARGED
778	15-Jul-2022	HASSAN	66	HV1	SINGAPURA_66	13:26(05.07.2022)	16:16(15.07.2002)	242:50HRS	TRANSFORMER CHARGED
779	15-Jul-2022	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN,LINE FAULT
780	15-Jul-2022	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	20:28(15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
781	15-Jul-2022	HASSAN	66	HV1	SINGAPURA_66	16:36(15.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
782	15-Jul-2022	HASSAN	220	HV2	KAVOOR_220	9:36	16:30	6:54	LINE CLEAR AVAILED
783	15-Jul-2022	HASSAN	110	LV2	KAVOOR_220	9:36	16:31	6:55	LINE CLEAR AVAILED
784	15-Jul-2022	HASSAN	220	HV1	KAVOOR_220	13:46	13:48	0:02	HAND TRIPPED
785	15-Jul-2022	HASSAN	220	HV2	KEMAR_220	13:49	13:52	0:03	HAND TRIPPED
786	15-Jul-2022	HASSAN	220	HV3	KEMAR_220	13:55	13:56	0:01	HAND TRIPPED
787	15-Jul-2022	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:55	13:10	2:15	LINE CLEAR AVAILED
788	15-Jul-2022	HASSAN	110	HV1	KEMAR_220	12:27	12:30	0:03	HAND TRIPPED
789	15-Jul-2022	HASSAN	110	HV2	KEMAR_220	12:27	12:31	0:04	HAND TRIPPED
790	15-Jul-2022	HASSAN	110	LV1	KEMAR_220	13:44	13:48	0:04	HAND TRIPPED
791	15-Jul-2022	HASSAN	110	LV2	KEMAR_220	13:49	13:52	0:03	HAND TRIPPED
792	15-Jul-2022	HASSAN	110	LV3	KEMAR_220	13:55	13:56	0:01	HAND TRIPPED
793	15-Jul-2022	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	10:59	11:28	0:29	LINE FAULT
794	15-Jul-2022	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	8:54	9:38	0:44	LINE FAULT
795	15-Jul-2022	HASSAN	110	HV2	MRSMSG_220	9:15	13:12	3:57	LINE CLEAR AVAILED
796	15-Jul-2022	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	8:54	9:38	0:44	LINE FAULT
797	15-Jul-2022	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	12:54	15:43	2:49	LINE CLEAR AVAILED
798	15-Jul-2022	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	12:54	15:44	2:50	LINE CLEAR AVAILED
799	15-Jul-2022	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE-110	12:06	13:11	1:05	NFBC ISSUED
800	15-Jul-2022	HASSAN	110	JOG-JST2	mghejog_gen	17:06	17:24	0:18	LINE FAULT
801	15-Jul-2022	HASSAN	110	KADUR-NERELEKERE	KADUR_220	10:56	12:15	1:19	LINE FAULT
802	15-Jul-2022	HASSAN	110	KADUR-NERELEKERE	KADUR_220	15:34	16:34	1:00	LINE FAULT
803	15-Jul-2022	HASSAN	110	LPH-LST4	lph_gen	0:45	15:30	14:45	LINE FAULT
804	15-Jul-2022	HASSAN	110	SAGARA-LST4	SAGARA_110	0:45	15:10	14:25	LINE FAULT
805	15-Jul-2022	HASSAN	110	SAGARA-JST2	SAGARA_110	17:05	17:25	0:20	LINE FAULT
806	15-Jul-2022	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	13:43	13:53	0:10	MAIN SUPPLY FAILURE
807	15-Jul-2022	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	13:43	13:53	0:10	MAIN SUPPLY FAILURE
808	15-Jul-2022	HASSAN	66	HV1	ALDUR_66	16:43	16:54	0:11	TRANSFORMER FAULT
809	15-Jul-2022	HASSAN	66	HV1	ALDUR_66	13:43	13:53	0:10	MAIN SUPPLY FAILURE
810	15-Jul-2022	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	2:05	2:16	0:11	LINE FAULT
811	15-Jul-2022	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTIHALLI_66	10:02	17:56	7:54	LINE CLEAR AVAILED
812	15-Jul-2022	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	10:20	17:58	7:38	MAIN SUPPLY FAILURE
813	15-Jul-2022	HASSAN	66	HV1	BYACHANAHALLI_66	10:20	17:58	7:38	MAIN SUPPLY FAILURE
814	15-Jul-2022	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	15:18	16:40	1:22	LINE CLEAR AVAILED
815	15-Jul-2022	HASSAN	66	HV2	RAMPURA_66	9:35	9:41	0:06	TRANSFORMER FAULT
816	15-Jul-2022	HASSAN	66	SAKALE-HASSAN1	SAKLESHPUR_66	15:15	16:38	1:23	LINE CLEAR AVAILED
817	15-Jul-2022	HASSAN	66	HV1	SIGEBAGE_66	8:24	9:38	1:14	LINE CLEAR AVAILED
818	15-Jul-2022	HASSAN	66	HV1	SINGAPURA_66	16:22	16:26	0:04	HAND TRIPPED
819	15-Jul-2022	HASSAN	66	HV1	SINGAPURA_66	16:34	16:36	0:02	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
820	15-Jul-2022	MYSURU	66	HV1	CHUNCHUNKATTE_66	6:38	6:46	0:08	HAND TRIPPED
821	15-Jul-2022	MYSURU	66	HV1	HDKOTE_66	12:15	13:45	1:30	LINE CLEAR AVAILED
822	15-Jul-2022	MYSURU	66	HV2	HDKOTE_66	10:35	12:15	1:40	LINE CLEAR AVAILED
823	15-Jul-2022	MYSURU	66	HV1	SUTTUR_66	11:54	13:28	1:33	LINE CLEAR AVAILED
824	15-Jul-2022	MYSURU	66	HV2	SUTTUR_66	13:32	15:54	2:22	LINE CLEAR AVAILED
825	15-Jul-2022	MYSURU	66	HV1	TERAKANAMBI_66	11:11	14:30	3:18	LINE CLEAR AVAILED
826	15-Jul-2022	MYSURU	66	HV2	TUBINKERE_66	10:34	16:45	6:10	LINE CLEAR AVAILED
827	15-Jul-2022	MYSURU	66	TUBINKERE-NAGAMANGALA1	NO STATIONS EFFECTED	12:15	12:25	0:10	LINE FAULT
828	15-Jul-2022	MYSURU	66	HEBBANI-MEGHALAPURA	SINDHUVALI_66 THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66 CHANDALLY_66 BGPURA_66 MEGHALAPURA_66 THALAKADU_66 PARINAMIPURA_66 TNARASIPIURA_66	14:05	14:25	0:20	LINE FAULT
829	15-Jul-2022	MYSURU	66	BG PURA-HEBBANI	CHANDALLY_66 BGPURA_66 THALAKADU_66 PARINAMIPURA_66	15:22	15:27	0:05	HAND TRIPPED
830	15-Jul-2022	MYSURU	66	BG PURA-HEBBANI	CHANDALLY_66 BGPURA_66 THALAKADU_66 PARINAMIPURA_66	16:07	16:14	0:07	HAND TRIPPED
831	15-Jul-2022	MYSURU	66	HV2	BG PURA-66	15:27	16:10	0:43	HAND TRIPPED
832	15-Jul-2022	MYSURU	220	KUSHALANAGARA-BASTHIPURA2	NO STATIONS EFFECTED	23:13	0:00	0:47	LINE FAULT
833	15-Jul-2022	MYSURU	220	KUSHALANAGARA-HV1	MADIKERE_66 SUNTIKOPPA_66 KANAGAL_66 ALUR SIDDAPUR_66 CB HALLI_66 RUDRAPATNA_66 MIRLE_66 BETTADAPURA_66 KITTUR_66 KR NAGARA_66 CHUNCHUNKATTE_66 RAVANDURU_66 KAMPLAPURA_66 PERIYAPATNA_66 BYLUKUPPE_66 PONNAMPETE_66 VIRAJPETE_66 HANAGODU_66 GAVADGERE_66 GV GUDI_66 BILIKERE_66 BHERYA_66 DMG_HALLI_66	23:13	23:35	0:22	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
834	15-Jul-2022	MYSURU	220	KUSHALANAGARA-HV2	MADIKERE_66 SUNTIKOPPA_66 KANAGAL_66 ALUR SIDDAPUR_66 CB HALLI_66 RUDRAPATNA_66 MIRLE_66 BETTADAPURA_66 KITTUR_66 KR NAGARA_66 CHUNCHUNKATTE_66 RAVANDURU_66 KAMPLAPURA_66 PERIYAPATNA_66 BYLUKUPPE_66 PONNAMPETE_66 VIRAJPETE_66 HANAGODU_66 GAVADGERE_66 GV GUDI_66 BILIKERE_66 BHERYA_66 DMG_HALLI_66	23:13	23:35	0:22	LINE FAULT
835	15-Jul-2022	MYSURU	66	SUNTIKOPPA-MADIKERI	NO STATIONS EFFECTED	16:34(13.07.2022)			LINE OPEN,LINE FAULT
836	15-Jul-2022	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00(12.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
837	15-Jul-2022	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
838	15-Jul-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	18:26 (22/04/2022)			LINE OPEN,LINE CLEAR AVAILED
839	15-Jul-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN,LINE CLEAR AVAILED
840	15-Jul-2022	TUMKUR	220	BENKIKERE-220-HOSADURGA 1	HOSADURGA_66	9:28	11:56	2:27	LINE CLEAR AVAILED
841	15-Jul-2022	TUMKUR	220	BENKIKERE-220-HOSADURGA 2	HOSADURGA_66	9:28	11:57	2:28	LINE CLEAR AVAILED
842	15-Jul-2022	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:12	18:30	3:17	LINE CLEAR AVAILED
843	15-Jul-2022	TUMKUR	110	NITTUR 220-SOMLAPURA110	SOMLAPURA_110	12:26	12:55	0:28	LINE FAULT
844	15-Jul-2022	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	1:29	1:42	0:13	LINE FAULT
845	15-Jul-2022	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	1:54	2:13	0:18	LINE FAULT
846	15-Jul-2022	TUMKUR	66	ANCHEPALYA 220KV- B G NAGARA_66	B G NAGARA_66,JIDDEGERE_66,T HIPPUR_66,YEDIYUR_66	6:06	6:30	0:23	LINE FAULT
847	15-Jul-2022	TUMKUR	66	TR-1	CHANNAGIRI_66	13:03	14:00	0:57	LINE CLEAR AVAILED
848	15-Jul-2022	TUMKUR	66	TR-2	CHANNAGIRI_66	13:03	14:04	1:01	LINE CLEAR AVAILED
849	15-Jul-2022	TUMKUR	66	GUTTUR 400KV- HALASABALU_66	HALASABALU_66	18:25	18:39	0:14	LINE FAULT
850	15-Jul-2022	TUMKUR	66	HIREHALLI - BADDIHALLI	BADDIHALLI_66	12:26	13:00	0:33	LINE CLEAR AVAILED
851	15-Jul-2022	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS- 1	INFOSYS-1	11:49	11:54	0:05	LINE FAULT
852	15-Jul-2022	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS- 1	INFOSYS-1	12:21	12:46	0:25	LINE FAULT
853	15-Jul-2022	TUMKUR	66	TR-1	KALAMARANAHALLI_66	11:17	13:37	2:19	LINE CLEAR AVAILED
854	15-Jul-2022	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	12:00	13:33	1:33	LINE CLEAR AVAILED
855	15-Jul-2022	TUMKUR	66	LOKIKERE66- KUKWADA66(CHYAGALE)	LOKIKERE_66	16:57	16:59	0:01	LINE FAULT
856	15-Jul-2022	TUMKUR	66	PAVAGADA66- VENKATAPURA66	PAVAGADA_66	10:36	14:36	4:00	LINE CLEAR AVAILED
857	15-Jul-2022	TUMKUR	66	PAVAGADA66- VENKATAPURA66	PAVAGADA_66	15:24	15:28	0:03	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
858	15-Jul-2022	TUMKUR	66	PD KOTE66-AZURE POWER IPP_66	AZURE POWER _IPP_66	10:17	10:39	0:21	MAIN SUPPLY FAILURE
859	15-Jul-2022	TUMKUR	66	PD KOTE 66-CLEAR SOLAR IPP_66	CLEAR SOLAR _IPP_66	10:17	10:39	0:21	MAIN SUPPLY FAILURE
860	15-Jul-2022	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	10:17	10:39	0:21	MAIN SUPPLY FAILURE
861	15-Jul-2022	TUMKUR	66	TR-2	SHYLA PURA_66	13:45	13:58	0:13	MAIN SUPPLY FAILURE
862	15-Jul-2022	TUMKUR	66	SASALUHALLA66- CHIKKAJAJUR66(SRS DAVANAGERE)	SASALUHALLA_66	11:10	12:49	1:39	LINE CLEAR AVAILED
863	15-Jul-2022	TUMKUR	66	TR-1	SASALUHALLA_66	12:48	16:31	3:43	LINE CLEAR AVAILED
864	16-Jul-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL 110	16:13 (04.03.2022)			LINE OPEN,LINE CLEAR AVAILED
865	16-Jul-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI 220	8:55 (23.05.2022)			LINE OPEN,LINE CLEAR AVAILED
866	16-Jul-2022	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA 110	8:50 (06.07.2022)			LINE OPEN,LINE FAULT
867	16-Jul-2022	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI 220	19:46 (15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
868	16-Jul-2022	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI 220	19:46 (15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
869	16-Jul-2022	BAGALKOT	220	SIRSI-SHARAVATHI-2	STATION NOT AFFECTED SIRSI 220	9:48	15:42	5:54	HAND TRIPPED
870	16-Jul-2022	BAGALKOT	220	NARENDRA-GHATAPRABHA	STATION NOT AFFECTED GHATAPRABHA 220	11:49	15:51	4:02	NFBC ISSUED
871	16-Jul-2022	BAGALKOT	220	MKHUBLI-NARENDRA-2	STATION NOT AFFECTED MKHUBLI 220	4:10	7:56	3:46	LINE FAULT
872	16-Jul-2022	BAGALKOT	220	HAVERI-GUTTUR-1	STATION NOT AFFECTED HAVERI 220	10:37	15:01	4:24	NFBC ISSUED
873	16-Jul-2022	BAGALKOT	220	HAVERI-GUTTUR-1	STATION NOT AFFECTED HAVERI 220	18:21	18:28	0:07	HAND TRIPPED
874	16-Jul-2022	BAGALKOT	220	HAVERI-GUTTUR-2	STATION NOT AFFECTED HAVERI 220	15:12	18:41	3:29	HAND TRIPPED
875	16-Jul-2022	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL 110	6:47	7:06	0:19	LINE FAULT
876	16-Jul-2022	BAGALKOT	110	110/11KV,HV3	STATION NOT AFFECTED HIREKERUR 110	18:49	19:59	1:10	LINE CLEAR AVAILED
877	16-Jul-2022	BAGALKOT	220	110/11KV,HV3	STATION NOT AFFECTED BAGALKOT 220	5:58	6:09	0:11	TRANSFORMER FAULT
878	16-Jul-2022	BAGALKOT	110	SIRSI220-SHVTY2	STATION NOT AFFECTED SIRSI 220	9:48	15:42	5:54	HAND TRIPPED
879	16-Jul-2022	BAGALKOT	110	SAMBAPUR ROAD-GADAG( RVVNL)	SAMBAPUR ROAD_110,RVVNL	9:45	9:54	0:09	LINE FAULT
880	16-Jul-2022	BAGALKOT	110	110/11KV,HV3	STATION NOT AFFECTED RATTIHALI 110	7:13	7:18	0:05	TRANSFORMER FAULT
881	16-Jul-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED NAGANUR 110	14:18	16:15	1:57	LINE CLEAR AVAILED
882	16-Jul-2022	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED HUBLI 220	15:24	17:03	1:39	LINE CLEAR AVAILED
883	16-Jul-2022	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI 110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
884	16-Jul-2022	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM 110	10:50 (26.03.2022)			LINE OPEN,LINE CLEAR AVAILED
885	16-Jul-2022	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED ATHANI 220	9:41 (06.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
886	16-Jul-2022	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI 220	20:00 (09.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
887	16-Jul-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MANTUR 110	6:55	7:05	0:10	TRANSFORMER FAULT
888	16-Jul-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MANTUR 110	8:05	8:10	0:05	TRANSFORMER FAULT
889	16-Jul-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED BYADAGI 110	17:23	17:30	0:07	TRANSFORMER FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
890	16-Jul-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED BYADAGI 110	17:33	21:44	4:11	LINE CLEAR AVALIED
891	16-Jul-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TILUVALLI 110	10:35	11:20	0:45	LINE CLEAR AVALIED
892	16-Jul-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TILUVALLI 110	12:28	13:00	0:32	LINE CLEAR AVALIED
893	16-Jul-2022	BENGALURU	66	AUSTIN TOWN - EAST DIVISION COMPOUND 220	AUSTIN TOWN	10:05	13:17	3:12	LINE CLEAR AVALIED
894	16-Jul-2022	BENGALURU	66	HV2	AUSTIN TOWN	10:05	13:18	3:13	LINE CLEAR AVALIED
895	16-Jul-2022	BENGALURU	66	HV3	AUSTIN TOWN	10:05	14:48	4:43	LINE CLEAR AVALIED
896	16-Jul-2022	BENGALURU	66	HV1	AUSTIN TOWN	10:05	13:19	3:14	LINE CLEAR AVALIED
897	16-Jul-2022	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	9:35	9:47	0:12	LOAD CHANGE OVER
898	16-Jul-2022	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI	10:30	16:40	6:10	LINE CLEAR AVALIED
899	16-Jul-2022	BENGALURU	66	HV1	ITI 220	10:27	10:30	0:03	LINE CLEAR AVALIED
900	16-Jul-2022	BENGALURU	66	HV2	ITI 220	13:07	13:10	0:03	LINE CLEAR AVALIED
901	16-Jul-2022	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	12:15	12:20	0:05	LINE CLEAR AVALIED
902	16-Jul-2022	BENGALURU	66	KHODAYS 220 - FALCON CITY	FALCON CITY	12:15	12:20	0:05	LINE CLEAR AVALIED
903	16-Jul-2022	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	14:52	14:55	0:03	LINE CLEAR AVALIED
904	16-Jul-2022	BENGALURU	66	KHODAYS 220 - FALCON CITY	FALCON CITY	14:52	14:55	0:03	LINE CLEAR AVALIED
905	16-Jul-2022	BENGALURU	220	NAGANATHPURA 220 - MYLSANDRA 220	NAGANATHPURA 220	10:02	17:20	7:18	LINE CLEAR AVALIED
906	16-Jul-2022	BENGALURU	220	NAGANATHPURA 220 - MYLSANDRA 220	NAGANATHPURA 220	17:20	17:56	0:36	LINE FAULT
907	16-Jul-2022	BENGALURU	220	HV1	NAGANATHPURA 220	10:02	18:04	8:02	LINE CLEAR AVALIED
908	16-Jul-2022	BENGALURU	220	HV2	NAGANATHPURA 220	10:02	18:04	8:02	LINE CLEAR AVALIED
909	16-Jul-2022	BENGALURU	220	HV3	NAGANATHPURA 220	10:02	18:04	8:02	LINE CLEAR AVALIED
910	16-Jul-2022	BENGALURU	66	HV1	NAGANATHPURA 220	10:02	18:05	8:03	LINE CLEAR AVALIED
911	16-Jul-2022	BENGALURU	66	HV2	NAGANATHPURA 220	10:02	18:05	8:03	LINE CLEAR AVALIED
912	16-Jul-2022	BENGALURU	66	HV3	NAGANATHPURA 220	10:02	18:05	8:03	LINE CLEAR AVALIED
913	16-Jul-2022	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2	10:00	18:10	8:10	LINE CLEAR AVALIED
914	16-Jul-2022	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	10:18	16:30	6:12	LINE CLEAR AVALIED
915	16-Jul-2022	BENGALURU	66	HV1	REMC0	6:48	6:50	0:02	LOAD CHANGE OVER
916	16-Jul-2022	BENGALURU	66	HV1	VIJAYANAGARA	11:00	14:00	3:00	LINE CLEAR AVALIED
917	16-Jul-2022	BENGALURU	66	HV2	VIJAYANAGARA	11:00	14:00	3:00	LINE CLEAR AVALIED
918	16-Jul-2022	BENGALURU	66	HV1	VIJAYANAGARA	14:00	15:30	1:30	LINE CLEAR AVALIED
919	16-Jul-2022	BENGALURU	66	HV2	VIJAYANAGARA	14:00	15:19	1:19	LINE CLEAR AVALIED
920	16-Jul-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	BIOCON (EHT), BOMMASANDRA I/A	9:15	9:33	0:18	LINE CLEAR AVALIED
921	16-Jul-2022	BENGALURU	66	HV1	KADUBISANAHALLI	10:10	16:40	6:30	LINE CLEAR AVALIED
922	16-Jul-2022	BENGALURU	66	HV2	KADUBISANAHALLI	14:00	16:40	2:40	LINE CLEAR AVALIED
923	16-Jul-2022	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI	14:00	16:40	2:40	LINE CLEAR AVALIED
924	16-Jul-2022	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	10:00	16:00	6:00	LINE CLEAR AVALIED
925	16-Jul-2022	BENGALURU	66	HV2	NANDAGUDI	15:14	15:49	0:34	LINE CLEAR AVALIED
926	16-Jul-2022	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	14:02	14:06	0:04	LINE FAULT
927	16-Jul-2022	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	13:15	13:30	0:15	LINE CLEAR AVALIED
928	16-Jul-2022	BENGALURU	66	HV2	MAASTHI	19:30	20:02	0:32	TRANSFORMER FAULT
929	16-Jul-2022	BENGALURU	66	SADLI - MITTEMARI 220	SADALI, DIBBURALI, BURUDAGUNTE	7:00	7:14	0:14	LINE FAULT
930	16-Jul-2022	BENGALURU	66	DALSANUR - SRINIVASPURA	SRINIVASPURA, YELDUR	15:35	16:05	0:29	LINE CLEAR AVALIED
931	16-Jul-2022	BENGALURU	66	HV1	BAIRAPATNA(SANKALGERE)	22:06	22:15	0:08	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
932	16-Jul-2022	BENGALURU	66	ARMY WELFARE ORGANISATION - KADUGODI	ARMY WELFARE ORGANISATION	10:30	13:50	3:20	LINE CLEAR AVAILED
933	16-Jul-2022	BENGALURU	66	ARMY WELFARE ORGANISATION - KONDASPURA	ARMY WELFARE ORGANISATION	16:47	16:57	0:10	LOAD CHANGE OVER
934	16-Jul-2022	BENGALURU	66	HV1	HOSKOTE 66	17:15	17:35	0:20	LINE CLEAR AVAILED
935	16-Jul-2022	BENGALURU	220	DB PURA 220 - KIADB DB PURA 220	NO STATION AFFECTED	9:07	10:40	1:33	LINE FAULT
936	16-Jul-2022	GULBARGA	220	HALAWARTHY-DHONI1	HALAWARTHY_220	7:12(05.7.22)			LINE OPEN,LINE CLEAR AVAILED
937	16-Jul-2022	GULBARGA	220	HALAWARTHY-DHONI2	HALAWARTHY_220	7:45(05.7.22)			LINE OPEN,LINE CLEAR AVAILED
938	16-Jul-2022	GULBARGA	400	BTPS-HIRIYUR2	HIRYUR_400	01:07(16/07/2022)			LINE OPEN,LINE CLEAR AVAILED
939	16-Jul-2022	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN,LINE CLEAR AVAILED
940	16-Jul-2022	GULBARGA	220	SEDAM_SHAHAPUR	SEDAM_220	05:48(10/06/2022)			LINE OPEN,LINE CLEAR AVAILED
941	16-Jul-2022	GULBARGA	220	KAPNOOR-HUMNABAD1	HUMANABAD_220	23:31 (16.07.2022)			LINE OPEN,LINE CLEAR AVAILED
942	16-Jul-2022	GULBARGA	220	LINGSUGUR-KUSTAGI	KUSTAGI_220	10:04	10:37	0:33	LINE CLEAR AVAILED
943	16-Jul-2022	GULBARGA	220	LINGSUGUR-SINDHNOOR	LINGSUGUR_220	12:42	15:14	2:32	LINE FAULT
944	16-Jul-2022	GULBARGA	220	LINGSUGUR-SHAHAPUR	SHAHAPUR_220	12:42	12:53	0:11	LINE FAULT
945	16-Jul-2022	GULBARGA	220	LINGSUGUR-RTPS 2	RTPS_220	20:30	20:55	0:25	LINE FAULT
946	16-Jul-2022	GULBARGA	220	SEDAM-TANDUR	TANDUR_220	14:02(15/07/2022)	10:28 (16.07.2022)	20:26 HRS	LINE CHARGED
947	16-Jul-2022	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	12:44	13:01	0:17	MAIN SUPPLY FAILURE
948	16-Jul-2022	GULBARGA	220	SEDAM-CLEAN MAX_IPP	SEDAM_220	11:25	13:01	1:36	LINE CLEAR AVAILED
949	16-Jul-2022	GULBARGA	220	SEDAM-RTPS_1	SEDAM_220	11:30	12:50	1:20	LINE CLEAR AVAILED
950	16-Jul-2022	GULBARGA	220	SEDAM-RTPS_2	SEDAM_220	11:30	12:58	1:28	LINE CLEAR AVAILED
951	16-Jul-2022	GULBARGA	220	SEDAM-HUMNABAD_2	HUMNABAD_220	12:05	12:54	0:49	LINE CLEAR AVAILED
952	16-Jul-2022	GULBARGA	220	SEDAM-HUMNABAD_1	HUMNABAD_220	12:18	12:23	0:05	LINE CLEAR AVAILED
953	16-Jul-2022	GULBARGA	220	SEDAM-SHREE CEMENT_IPP	SEDAM_220	12:16	13:10	0:54	LINE CLEAR AVAILED
954	16-Jul-2022	GULBARGA	220	SEDAM_ORIENT CEMENT_IPP	SEDAM_220	12:09	13:04	0:55	LINE CLEAR AVAILED
955	16-Jul-2022	GULBARGA	220	MALLAT-LINGSUGUR	MALLAT_220	12:43	12:53	0:10	MAIN SUPPLY FAILURE
956	16-Jul-2022	GULBARGA	220	MALLAT-RAICHUR	MALLAT_220	12:43	13:11	0:28	MAIN SUPPLY FAILURE
957	16-Jul-2022	GULBARGA	220	MALLAT-RTPS	MALLAT_220	20:30	21:01	0:31	LINE FAULT
958	16-Jul-2022	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	12:03	12:56	0:53	LINE CLEAR AVAILED
959	16-Jul-2022	GULBARGA	220	HUMNABAD-SEDAM	HUMNABAD_220	12:06	12:53	0:47	LINE CLEAR AVAILED
960	16-Jul-2022	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN,LINE CLEAR AVAILED
961	16-Jul-2022	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN,LINE CLEAR AVAILED
962	16-Jul-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN,LINE CLEAR AVAILED
963	16-Jul-2022	GULBARGA	110	HV3	SHAHAPUR_110	12:49	13:15	0:26	TRANSFORMER FAULT
964	16-Jul-2022	GULBARGA	110	HV3	LADHA_110	17:36	18:17	0:41	TRANSFORMER FAULT
965	16-Jul-2022	GULBARGA	110	NIRNA-RRENEW SOLAR1	NIRNA_110	11:44	12:08	0:24	LINE CLEAR AVAILED
966	16-Jul-2022	GULBARGA	110	HUNASAGI-KEMBHAVI	HUNASAGI_110	21:30	21:40	0:10	MAIN SUPPLY FAILURE
967	16-Jul-2022	GULBARGA	110	HUNASAGI-KEMBHAVI	HUNASAGI_110	19:50	20:10	0:20	MAIN SUPPLY FAILURE
968	16-Jul-2022	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNAS AGI_110	5:05	5:15	0:10	LINE FAULT
969	16-Jul-2022	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	19:35	19:42	0:07	LINE FAULT
970	16-Jul-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,SAIDAPUR_110	19:46	21:24	1:38	LINE FAULT
971	16-Jul-2022	GULBARGA	110	SHAHAPUR-SHAHAPUR_1	SHAHAPUR_110,NALWAR_110	20:12	20:22	0:10	LINE FAULT
972	16-Jul-2022	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNAS AGI_110	21:29	21:35	0:06	LINE FAULT
973	16-Jul-2022	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110,KONKAL_110	11:18(15/07/2022)	20:09 (16.07.2022)	32:51 HRS	LINE CHARGED
974	16-Jul-2022	GULBARGA	110	CHILAKAMUKI-BEVOOR	CHILAKAMUKI_110	20:15	20:45	0:30	MAIN SUPPLY FAILURE
975	16-Jul-2022	GULBARGA	110	NALWAR-SHAHABAD2	JEWARAGI_110	5:40	6:00	0:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
976	16-Jul-2022	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	11:42	11:44	0:02	LINE CLEAR AVAILED
977	16-Jul-2022	GULBARGA	110	SEDAM_VICAT SAGAR_IPP	SEDAM_220	19:55	20:10	0:15	LINE FAULT
978	16-Jul-2022	GULBARGA	110	SEDAM_VICAT SAGAR_IPP	SEDAM_220	20:15	20:33	0:18	LINE FAULT
979	16-Jul-2022	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOA N_110,DIGGI_110	18:59	19:07	0:08	LINE FAULT
980	16-Jul-2022	GULBARGA	110	HALBARGA-KOLHAR1	KOLHAR_110,JANAWADA_110 ,NSSK SUGAR FACTORY	18:59	20:00	1:01	LINE FAULT
981	16-Jul-2022	GULBARGA	110	HALBARGA-KOLHAR2	KOLHAR_110,JANAWADA_110 ,NSSK SUGAR FACTORY	18:59	20:00	1:01	LINE FAULT
982	16-Jul-2022	GULBARGA	110	RAICHUR-SINDHNOOR1	SIRWAR_110	1:02	1:07	0:05	LINE FAULT
983	16-Jul-2022	GULBARGA	110	RAICHUR-SINDHNOOR1	SIRWAR_110	5:15	5:25	0:10	LINE FAULT
984	16-Jul-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGAL_110	5:28	5:40	0:12	LINE FAULT
985	16-Jul-2022	GULBARGA	110	RAICHUR-APMC1&2	APMC_110,CHICKSUGUR_110, SHAKTINAGAR_110	19:32	19:46	0:14	LINE FAULT
986	16-Jul-2022	GULBARGA	110	RAICHUR-APMC1&2	APMC_110,CHICKSUGUR_110, SHAKTINAGAR_110	20:04	20:10	0:06	LINE FAULT
987	16-Jul-2022	GULBARGA	110	RAICHUR-APMC1&2	APMC_110,CHICKSUGUR_110, SHAKTINAGAR_110	20:38	21:05	0:27	LINE FAULT
988	16-Jul-2022	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	21:42	21:52	0:10	LINE FAULT
989	16-Jul-2022	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110, ADVIAMRESHWAR_110	22:12	22:32	0:20	LINE FAULT
990	16-Jul-2022	GULBARGA	66	HV1,HV2	TAMBRAHALLI_66	13:50	14:00	0:10	LINE CLEAR AVAILED
991	16-Jul-2022	GULBARGA	66	HALVAGALU-HARVI	HARVI_66	1:20	1:25	0:05	LINE FAULT
992	16-Jul-2022	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCH OD_66,UJJAINI_66	9:20	9:25	0:05	LINE FAULT
993	16-Jul-2022	GULBARGA	66	ITTAGI-CLEAN MAX_2_IPP	ITTAGI_220	12:05	12:10	0:05	LINE CLEAR AVAILED
994	16-Jul-2022	GULBARGA	400	BTPS-HIRYUR2	HIRYUR_400	01:07(16/07/2022)			LINE OPEN,LINE CLEAR AVAILED
995	16-Jul-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
996	16-Jul-2022	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN,LINE FAULT
997	16-Jul-2022	HASSAN	66	HV1	SINGAPURA_66	16:36(15.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
998	16-Jul-2022	HASSAN	110	HV2	HALADY_110	19:58(16.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
999	16-Jul-2022	HASSAN	110	JOG-JLT3	mghejog_gen	23:41(16.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1000	16-Jul-2022	HASSAN	110	JOG-JLT4	mghejog_gen	23:41(16.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1001	16-Jul-2022	HASSAN	110	JOG-JST1	mghejog_gen	23:41(16.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1002	16-Jul-2022	HASSAN	110	JOG-JST2	mghejog_gen	23:41(16.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1003	16-Jul-2022	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	20:28(15.07.2022)	15:43(16.07.2022)	19:15HRS	LINE CHARGED
1004	16-Jul-2022	HASSAN	220	KADUR-DABUSET	KADUR_220	9:10	13:29	4:19	NFBC ISSUED
1005	16-Jul-2022	HASSAN	220	HV1	KAVOOR_220	16:42	16:43	0:01	LINE CLEAR AVAILED
1006	16-Jul-2022	HASSAN	110	LV1	KAVOOR_220	9:42	16:42	7:00	LINE CLEAR AVAILED
1007	16-Jul-2022	HASSAN	220	KEMAR-Varahi1	KEMAR_220	11:52	16:24	4:32	LINE FAULT
1008	16-Jul-2022	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	1:01	1:53	0:52	LINE FAULT
1009	16-Jul-2022	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	1:58	16:11	14:13	NFBC ISSUED
1010	16-Jul-2022	HASSAN	110	HV3	MRSMSG_220	9:09	13:03	3:54	LINE CLEAR AVAILED
1011	16-Jul-2022	HASSAN	66	LV3	MRSMSG_220	9:29	12:05	2:36	LINE CLEAR AVAILED
1012	16-Jul-2022	HASSAN	220	HV2	SHIRALKOPPA_220	16:33	17:53	1:20	LINE CLEAR AVAILED
1013	16-Jul-2022	HASSAN	110	LV2	SHIRALKOPPA_220	16:33	17:53	1:20	LINE CLEAR AVAILED
1014	16-Jul-2022	HASSAN	220	VARAHI-KEMAR1	varahi_gen	11:52	16:24	4:32	LINE FAULT
1015	16-Jul-2022	HASSAN	110	HV2	HALADY_110	17:07	18:27	1:20	TRANSFORMER FAULT
1016	16-Jul-2022	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	8:27	8:43	0:16	LINE FAULT
1017	16-Jul-2022	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	11:57	13:49	1:52	MAIN SUPPLY FAILURE
1018	16-Jul-2022	HASSAN	110	VITTAL-PUTR_SLTUR	VITLA_110	8:28	8:44	0:16	MAIN SUPPLY FAILURE
1019	16-Jul-2022	HASSAN	110	VITTAL-PUTR_SLTUR	VITLA_110	11:58	13:46	1:48	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1020	16-Jul-2022	HASSAN	66	HV1	BALLUPETE_66	14:14	14:40	0:26	LINE CLEAR AVAILED
1021	16-Jul-2022	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	16:15	16:27	0:12	LINE CLEAR AVAILED
1022	16-Jul-2022	HASSAN	66	HV2	HASSAN_66	12:13	14:22	2:09	LINE CLEAR AVAILED
1023	16-Jul-2022	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	9:56	10:05	0:09	LINE FAULT
1024	16-Jul-2022	HASSAN	66	HV2	KIADB_66	10:33	11:24	0:51	LINE CLEAR AVAILED
1025	16-Jul-2022	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	10:16	10:28	0:12	HAND TRIPPED
1026	16-Jul-2022	HASSAN	66	HV2	S.BELAGOLA_66	10:17	10:42	0:25	LINE CLEAR AVAILED
1027	16-Jul-2022	MYSURU	66	HV2	BGNAGARA_66	10:49	15:34	4:44	LINE CLEAR AVAILED
1028	16-Jul-2022	MYSURU	66	KR PET 66-HUYGONALLY1	KRPET_66 AKKIHEBBAL_66 KIKKERI_66	7:08	7:21	0:13	LINE FAULT
1029	16-Jul-2022	MYSURU	66	KR PET 66-HUYGONALLY2	KRPET_66 AKKIHEBBAL_66 KIKKERI_66	7:08	7:21	0:13	LINE FAULT
1030	16-Jul-2022	MYSURU	66	HV2	MALAVALLI_66	10:26	17:40	7:14	LINE CLEAR AVAILED
1031	16-Jul-2022	MYSURU	66	HV2	MALAVALLI_66	17:46	18:13	0:26	LINE CLEAR AVAILED
1032	16-Jul-2022	MYSURU	66	VAJAMANGALA-KADAKOLA1	AYRALLI_66 MARADIHUNDI_66	11:08	13:28	2:20	NFBC ISSUED
1033	16-Jul-2022	MYSURU	66	HV2	ATTIGULIPURA_66	12:50	13:00	0:10	LINE CLEAR AVAILED
1034	16-Jul-2022	MYSURU	66	MALAVALLI-SHIMSHA	MALAVALLI_66 HADLI_66 KADKOTHANAHALLI_66INTERR UPTED.	9:23	9:33	0:09	HAND TRIPPED
1035	16-Jul-2022	MYSURU	66	KUNTHUR-MADHUVANAHALLI	NO STATIONS EFFECTED	11:10	13:35	2:25	NFBC ISSUED
1036	16-Jul-2022	MYSURU	66	ADDIHALLI-BG NAGARA	BGNAGARA_66 ADICHUNCHANAGIRI_66 KADABALLY_66	6:30	6:36	0:06	LINE FAULT
1037	16-Jul-2022	MYSURU	66	HOOTAGALLI-KAGGERI HAMPAPURA	KAGGERE HAMPAPURA_66	19:13	19:27	0:14	LINE FAULT
1038	16-Jul-2022	MYSURU	66	SUNTIKOPPA-MADIKERI	NO STATIONS EFFECTED	16:34(13.07.2022)			LINE OPEN,LINE FAULT
1039	16-Jul-2022	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00(12.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1040	16-Jul-2022	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1041	16-Jul-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	18:26 (22/04/2022)			LINE OPEN,LINE CLEAR AVAILED
1042	16-Jul-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN,LINE CLEAR AVAILED
1043	16-Jul-2022	TUMKUR	220	KB CROSS 220kV- ANTHRASANAHALLI66	KBCROSS_220	9:25	14:25	5:00	LINE CLEAR AVAILED
1044	16-Jul-2022	TUMKUR	220	ANTHRASANAHALLI 220kV- SHIMOGA	ANTHRASANAHALLI_220	1:01	16:11	15:10	LINE FAULT
1045	16-Jul-2022	TUMKUR	220	NITTUR 220-NELAMANGALA	NITTUR_220	11:02	16:47	5:45	LINE CLEAR AVAILED
1046	16-Jul-2022	TUMKUR	220	NITTUR 220-ARASIKERE	NITTUR_220	9:27	13:30	4:03	LINE CLEAR AVAILED
1047	16-Jul-2022	TUMKUR	220	TR-1 (100MVA )	NITTUR_220	11:10	16:42	5:32	LINE CLEAR AVAILED
1048	16-Jul-2022	TUMKUR	220	TR-2 (100MVA )	NITTUR_220	11:10	16:42	5:32	LINE CLEAR AVAILED
1049	16-Jul-2022	TUMKUR	110	TR-1(LV SIDE)	NITTUR_220	11:15	16:57	5:42	LINE CLEAR AVAILED
1050	16-Jul-2022	TUMKUR	110	TR-2 (LV SIDE)	NITTUR_220	11:15	16:57	5:42	LINE CLEAR AVAILED
1051	16-Jul-2022	TUMKUR	110	NITTUR 220-KALLUR	KALLUR_110	11:05	16:40	5:35	LINE CLEAR AVAILED
1052	16-Jul-2022	TUMKUR	110	NITTUR 220-KADABA	KADABA_110	11:05	16:40	5:35	LINE CLEAR AVAILED
1053	16-Jul-2022	TUMKUR	110	NITTUR 220-GUBBI	GUBBI_110	11:05	16:40	5:35	LINE CLEAR AVAILED
1054	16-Jul-2022	TUMKUR	110	NITTUR 220-K G TEMPLE	KGTEMPLE_110	11:05	16:40	5:35	LINE CLEAR AVAILED
1055	16-Jul-2022	TUMKUR	110	NITTUR 220-DODDAGUNI	DODDAGUNI_110	11:05	16:40	5:35	LINE CLEAR AVAILED
1056	16-Jul-2022	TUMKUR	110	NITTUR 220-SOMLAPURA110	SOMLAPURA_110	11:05	16:40	5:35	LINE CLEAR AVAILED
1057	16-Jul-2022	TUMKUR	110	DODDAGUNI- NITTUR	DODDAGUNI_110	12:55	18:49	5:54	LINE CLEAR AVAILED
1058	16-Jul-2022	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUN SOLAR2	16:58	17:08	0:10	LINE FAULT
1059	16-Jul-2022	TUMKUR	66	BILCHODU66-PALLAGATTE66	BILCHODU_66	9:20	9:25	0:05	MAIN SUPPLY FAILURE
1060	16-Jul-2022	TUMKUR	66	BRAHMASANDRA- THOVINKERE(KORA)	THOVINAKERE_66, KORA_66	7:50	8:04	0:13	LINE FAULT
1061	16-Jul-2022	TUMKUR	66	TR-2	HOLALKERE_66	6:20	6:25	0:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1062	16-Jul-2022	TUMKUR	66	TR-2	HOLALKERE_66	6:30	6:35	0:05	TRANSFORMER FAULT
1063	16-Jul-2022	TUMKUR	66	TR-2	HOLALKERE_66	6:40	6:50	0:10	TRANSFORMER FAULT
1064	16-Jul-2022	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	8:18	8:30	0:12	LINE FAULT
1065	16-Jul-2022	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	13:25	13:30	0:05	LINE FAULT
1066	16-Jul-2022	TUMKUR	66	LINGADHALLI-CHANNAGIRI	LINGADAHALLI_TM2_66	13:25	13:26	0:01	LINE FAULT
1067	16-Jul-2022	TUMKUR	66	BILCHODU66-PALLAGATTE66	BILCHODU_66	16:05	16:10	0:05	MAIN SUPPLY FAILURE
1068	17-Jul-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1069	17-Jul-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN,LINE CLEAR AVAILED
1070	17-Jul-2022	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	8:50 (06.07.2022)			LINE OPEN,LINE FAULT
1071	17-Jul-2022	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1072	17-Jul-2022	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1073	17-Jul-2022	BAGALKOT	220	NARENDRA-BELAGAVI-1	STATION NOT AFFECTED NARENDRA_220	9:11	16:53	7:42	HAND TRIPPED
1074	17-Jul-2022	BAGALKOT	110	GHATAPRABHA220- SOEPL (SORYODAYA SOLAR)	SORYODAYA SOLAR_110 STATION NOT AFFECTED GHATAPRABHA_220	8:09	8:44	0:35	LINE FAULT
1075	17-Jul-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED AINAPUR_110	13:40	13:49	0:09	TRANSFORMER FAULT
1076	17-Jul-2022	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED ANKOLA_110	9:41	9:48	0:07	HAND TRIPPED
1077	17-Jul-2022	BAGALKOT	110	110/11KV,HV1	BAILHONGAL_110	9:40	16:05	6:25	LINE CLEAR AVAILED
1078	17-Jul-2022	BAGALKOT	110	110/11KV,HV4	BAILHONGAL_110	9:40	15:48	6:08	LINE CLEAR AVAILED
1079	17-Jul-2022	BAGALKOT	110	BELLATTI-ENERCON2	ENERCON_110 STATION NOT AFFECTED BELLATTI_110	2:47	16:14	13:27	LINE FAULT
1080	17-Jul-2022	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBUHAL_110	1:26	1:53	0:27	LINE FAULT
1081	17-Jul-2022	BAGALKOT	220	BAGEWADI-RBRK	RBRK IPP_220 STATION NOT AFFECTED BAGEWADI_220	2:59	3:52	0:53	LINE FAULT
1082	17-Jul-2022	BAGALKOT	110	DAMBAL-MUNDARAGI	DAMBAL&MUNDARAGI_110	10:00	14:31	4:31	LINE CLEAR AVAILED
1083	17-Jul-2022	BAGALKOT	110	DAMBAL-EILS	EILS_110 DAMBAL_110	11:10	14:38	3:28	LINE CLEAR AVAILED
1084	17-Jul-2022	BAGALKOT	110	DAMBAL-GADAG1(L5)	DAMBAL_110	10:10	14:31	4:21	LINE CLEAR AVAILED
1085	17-Jul-2022	BAGALKOT	110	DAMBAL-SUZLON2&3	DAMBAL_110	11:10	14:36	3:26	LINE CLEAR AVAILED
1086	17-Jul-2022	BAGALKOT	110	110/11KV,HV3	STATION NOT AFFECTED JAMAKHANDI_110	10:52	11:35	0:43	LINE CLEAR AVAILED
1087	17-Jul-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED KADAKLAT_110	5:45	7:24	1:39	TRANSFORMER FAULT
1088	17-Jul-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED KADAKLAT_110	10:55	12:34	1:39	LINE CLEAR AVAILED
1089	17-Jul-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED KADAKLAT_110	15:03	15:12	0:09	TRANSFORMER FAULT
1090	17-Jul-2022	BAGALKOT	110	MUNDARAGI-VIJAY SUGARS	VIJAY SUGARS_110 MUNDARAGI_110	10:00	14:39	4:39	LINE CLEAR AVAILED
1091	17-Jul-2022	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED TODALBAGI_110	19:13	20:53	1:40	LINE CLEAR AVAILED
1092	17-Jul-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED TODALBAGI_110	19:13 (17.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1093	17-Jul-2022	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED SIRSI_110	4:42	9:00	4:18	TRANSFORMER FAULT
1094	17-Jul-2022	BAGALKOT	110	SAMBAPUR ROAD-DAMBAL	DAMBAL_110	10:11	14:28	4:17	NFBC ISSUED
1095	17-Jul-2022	BAGALKOT	110	SAMBAPUR ROAD-GADAG(RVVNL)	SAMBAPUR ROAD_110,RVVNL	19:48	19:54	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1096	17-Jul-2022	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI 110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1097	17-Jul-2022	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM 110	10:50 (26.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1098	17-Jul-2022	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED ATHANI 220	9:41 (06.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1099	17-Jul-2022	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI 220	20:00 (09.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1100	17-Jul-2022	BAGALKOT	220	BELAGAVI-NARENDRA-1	STATION NOT AFFECTED BELAGAVI 220	9:12	16:53	7:41	LINE CLEAR AVAILED
1101	17-Jul-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MANTUR 110	13:00	13:05	0:05	HAND TRIPPED
1102	17-Jul-2022	BAGALKOT	110	110/33KV, HV2	ADUR/HANAGAL 33 STATION NOT AFFECTED HAVERI 110	10:25	10:35	0:10	TRANSFORMER FAULT
1103	17-Jul-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED BYADAGI 110	7:10	7:23	0:13	TRANSFORMER FAULT
1104	17-Jul-2022	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED HANAGAL 110	15:45	16:05	0:20	TRANSFORMER FAULT
1105	17-Jul-2022	BAGALKOT	110	MKHUBLI220-BAILHONGAL	BAILHONGAL 110	9:40	15:15	5:35	LINE CLEAR AVAILED
1106	17-Jul-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED RATTIHALLI 110	12:25	19:35	7:10	LINE CLEAR AVAILED
1107	17-Jul-2022	BENGALURU	66	HV2	BYADRAHALLI	14:15	14:17	0:02	LINE CLEAR AVAILED
1108	17-Jul-2022	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 220	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	6:53	6:59	0:06	LOAD CHANGE OVER
1109	17-Jul-2022	BENGALURU	66	KODIGEHALLI - BYADRAHALLI	KODIGEHALLI	7:25	7:44	0:19	LOAD CHANGE OVER
1110	17-Jul-2022	BENGALURU	66	KODIGEHALLI - TAVAREKERE	KODIGEHALLI	18:26	18:38	0:12	LOAD CHANGE OVER
1111	17-Jul-2022	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	4:05	4:13	0:08	LINE FAULT
1112	17-Jul-2022	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	13:13	14:07	0:54	LINE FAULT
1113	17-Jul-2022	BENGALURU	66	HV2	NRS 220	22:33	22:38	0:05	LINE CLEAR AVAILED
1114	17-Jul-2022	BENGALURU	66	T GOLLAHALLI 220 - ANDERSONPETE	DODDAKARI, KYASAMBALLI, ANDERSONPETE	19:18	19:31	0:13	LINE FAULT
1115	17-Jul-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	BIOCON (EHT), BOMMASANDRA I/A	13:33	13:38	0:05	LINE CLEAR AVAILED
1116	17-Jul-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	BIOCON (EHT), BOMMASANDRA I/A	14:44	14:46	0:02	LINE CLEAR AVAILED
1117	17-Jul-2022	BENGALURU	220	HV1	SRS PEENYA 220	11:24	18:05	6:41	TRANSFORMER FAULT
1118	17-Jul-2022	BENGALURU	220	HV2	SRS PEENYA 220	11:24	13:53	2:29	TRANSFORMER FAULT
1119	17-Jul-2022	BENGALURU	220	HV3	SRS PEENYA 220	13:45	15:45	2:00	TRANSFORMER FAULT
1120	17-Jul-2022	BENGALURU	66	HV1	CHANDRAPPA CIRCLE	6:30	6:35	0:05	TRANSFORMER FAULT
1121	17-Jul-2022	BENGALURU	66	HV1	T G HALLI	10:12	15:10	4:57	LINE CLEAR AVAILED
1122	17-Jul-2022	BENGALURU	66	HV1	NELAMANGALA 66	15:12	16:01	0:49	LINE CLEAR AVAILED
1123	17-Jul-2022	BENGALURU	66	HV3	NELAMANGALA 66	10:00	16:01	6:01	LINE CLEAR AVAILED
1124	17-Jul-2022	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 1	MANCHENAHALLI, GUNDAMGERE	5:30	5:40	0:10	LINE FAULT
1125	17-Jul-2022	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA CIRCLE	5:41	6:01	0:20	LINE FAULT
1126	17-Jul-2022	BENGALURU	66	LAKSHMIPURA - TADIGOLU CROSS	LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	20:49	21:02	0:13	LINE FAULT
1127	17-Jul-2022	BENGALURU	66	LAKSHMIPURA - ADDGAL	ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	20:49	21:05	0:15	LINE FAULT
1128	17-Jul-2022	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	9:38	18:00	8:22	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1129	17-Jul-2022	BENGALURU	66	DABUSPET 220 - AVERAHALLI	AVERAHALLI	9:53	17:08	7:15	LINE CLEAR AVAILED
1130	17-Jul-2022	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	9:59	17:50	7:51	LINE CLEAR AVAILED
1131	17-Jul-2022	BENGALURU	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	10:07	17:06	6:59	LINE CLEAR AVAILED
1132	17-Jul-2022	BENGALURU	66	DABUSPET 220 - SK STEEL (EHT)	SK STEEL (EHT)	10:06	18:15	8:09	LINE CLEAR AVAILED
1133	17-Jul-2022	BENGALURU	220	HV2	DABUSPETE 220	10:04	17:05	7:01	LINE CLEAR AVAILED
1134	17-Jul-2022	BENGALURU	66	HV1	DABUSPETE 220	10:07	17:51	7:44	LINE CLEAR AVAILED
1135	17-Jul-2022	BENGALURU	66	HV2	DABUSPETE 220	10:07	17:53	7:46	LINE CLEAR AVAILED
1136	17-Jul-2022	BENGALURU	66	HOODY 220 - BMRCL	NO STATION AFFECTED	12:31(17/07/2022)			LINE OPEN,LINE FAULT
1137	17-Jul-2022	GULBARGA	220	HALAWARTHY-DHONI1	HALAWARTHY_220	7:12(05.7.22)			LINE OPEN,LINE CLEAR AVAILED
1138	17-Jul-2022	GULBARGA	220	HALAWARTHY-DHONI2	HALAWARTHY_220	7:45(05.7.22)			LINE OPEN,LINE CLEAR AVAILED
1139	17-Jul-2022	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN,LINE CLEAR AVAILED
1140	17-Jul-2022	GULBARGA	220	SEDAM_SHAHAPUR	SEDAM_220	05:48(10/06/2022)			LINE OPEN,LINE CLEAR AVAILED
1141	17-Jul-2022	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	22:31(17/07/2022)			LINE OPEN,LINE CLEAR AVAILED
1142	17-Jul-2022	GULBARGA	220	HV2	KUSTAGI_220	3:12	7:27	4:15	TRANSFORMER FAULT
1143	17-Jul-2022	GULBARGA	220	HV1	KUSTAGI_220	18:58	19:15	0:17	TRANSFORMER FAULT
1144	17-Jul-2022	GULBARGA	220	HV1	KUSTAGI_220	18:58	19:38	0:40	TRANSFORMER FAULT
1145	17-Jul-2022	GULBARGA	220	HV2	SHAHAPUR_220	22:25	22:38	0:13	TRANSFORMER FAULT
1146	17-Jul-2022	GULBARGA	220	KAPNOOR-HUMNABAD1	HUMANABAD_220	23:31 (16.07.2022)	06:56 (17.07.2022)	07:25HRS	LINE CHARGED
1147	17-Jul-2022	GULBARGA	220	LINGASUGUR-RTPS 2	RTPS_220	23:35	23:52	0:17	LINE FAULT
1148	17-Jul-2022	GULBARGA	220	SHAHAPUR-RTPS_1	SHAHAPUR_220	4:00	4:19	0:19	LINE FAULT
1149	17-Jul-2022	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN,LINE CLEAR AVAILED
1150	17-Jul-2022	GULBARGA	110	MUNIRABAD-VYASANKERE1(IDLE)	DONIMALAI_110	9:08(17.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1151	17-Jul-2022	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN,LINE CLEAR AVAILED
1152	17-Jul-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN,LINE CLEAR AVAILED
1153	17-Jul-2022	GULBARGA	110	LV1	SHAHAPUR_220	19:50	20:06	0:16	TRANSFORMER FAULT
1154	17-Jul-2022	GULBARGA	110	LV1	SHAHAPUR_220	22:25	22:30	0:05	TRANSFORMER FAULT
1155	17-Jul-2022	GULBARGA	110	YELBURGA-PARAMPOOJYA	YELBURGA_110	10:21	10:31	0:10	LINE FAULT
1156	17-Jul-2022	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	2:43	2:47	0:04	LINE FAULT
1157	17-Jul-2022	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	8:50	18:59	10:09	LINE CLEAR AVAILED
1158	17-Jul-2022	GULBARGA	110	HUNASAGI-KEMBHAVI	HUNASAGI_110	22:25	23:00	0:35	MAIN SUPPLY FAILURE
1159	17-Jul-2022	GULBARGA	110	CHICKSUGUR-APMC	CHICKSUGUR_110	19:30	19:53	0:23	MAIN SUPPLY FAILURE
1160	17-Jul-2022	GULBARGA	110	CHICKSUGUR-APMC	CHICKSUGUR_110	20:00	20:27	0:27	MAIN SUPPLY FAILURE
1161	17-Jul-2022	GULBARGA	110	CHICKSUGUR-APMC	CHICKSUGUR_110	20:34	21:10	0:36	MAIN SUPPLY FAILURE
1162	17-Jul-2022	GULBARGA	110	MARGUTTI-CLNSLR	MARGUTTI_110	18:50	20:43	1:53	LINE CLEAR AVAILED
1163	17-Jul-2022	GULBARGA	110	GURMITKAL-KONKAL	GURMITKAL_110	5:45	5:50	0:05	LINE FAULT
1164	17-Jul-2022	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110	19:00	19:05	0:05	MAIN SUPPLY FAILURE
1165	17-Jul-2022	GULBARGA	110	KUSTAGI-VAJRABANDI	VAJRABANDI_110,YELBURAG_110,KUKNOOR_110	18:58	19:20	0:22	LINE FAULT
1166	17-Jul-2022	GULBARGA	110	SHAHPUR-RAICHUR_1	DEODURGA_110	1:43	1:47	0:04	LINE FAULT
1167	17-Jul-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,SAIDAPUR_110	2:29	2:34	0:05	LINE FAULT
1168	17-Jul-2022	GULBARGA	110	SHAHPUR-RAICHUR_1	DEODURGA_110	22:25	22:37	0:12	LINE FAULT
1169	17-Jul-2022	GULBARGA	110	SHAHPUR-RAICHUR_2	DEODURGA_110	22:25	22:37	0:12	LINE FAULT
1170	17-Jul-2022	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	22:48 (17.07.2022)			LINE OPEN,LINE FAULT
1171	17-Jul-2022	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOA_N_110,DIGGI_110	5:04	6:01	0:57	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1172	17-Jul-2022	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGODU_110,SHATHVA HANA_IPP,AGRAWAL_IPP,SUZ LON_IPP,KAMALAPUR_110,M ATRI_110,RBNS FACTORY_110	9:12	17:45	8:33	LINE CLEAR AVAILED
1173	17-Jul-2022	GULBARGA	110	ALIPUR-BELLARI SOUTH	BELLARY SOUTH_110,HALKUNDI_110	9:19	15:40	6:21	LINE FAULT
1174	17-Jul-2022	GULBARGA	110	MUNIRABAD-VYASANKERE2	STARMETALLIC_IPP,JINDALPU MPHOUSE,DONIMALAI_110, NMDC FACTORY	9:08	18:55	9:47	LINE CLEAR AVAILED
1175	17-Jul-2022	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDINNI_110	5:20	5:32	0:12	LINE FAULT
1176	17-Jul-2022	GULBARGA	110	HUMNABAD-MANEIKHELLI	MANAIKHELLI_110	18:51	19:23	0:32	LINE FAULT
1177	17-Jul-2022	GULBARGA	110	SINDHNOOR-NIRLOOTI_IPP	SINDHNOOR_220	4:15	4:25	0:10	LINE FAULT
1178	17-Jul-2022	GULBARGA	110	HUMNABAD-DUBALGUNDI	DUBALGUNDI_110	23:12	23:25	0:13	LINE FAULT
1179	17-Jul-2022	GULBARGA	66	HV1	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCH OD_66,UJJAINI_66	14:05	14:10	0:05	TRANSFORMER FAULT
1180	17-Jul-2022	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCH OD_66,UJJAINI_66	6:00	6:05	0:05	LINE FAULT
1181	17-Jul-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1182	17-Jul-2022	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN,LINE FAULT
1183	17-Jul-2022	HASSAN	66	HV1	SINGAPURA_66	16:36(15.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1184	17-Jul-2022	HASSAN	110	HV2	HALADY_110	19:58(16.07.2022)	12:49(17.07.2022)	16:51HRS	TRANSFORMER CHARGED
1185	17-Jul-2022	HASSAN	110	JOG-JLT3	mghejog_gen	23:41(16.07.2022)	00:03(17.07.2022)	0:22HRS	LINE CHARGED
1186	17-Jul-2022	HASSAN	110	JOG-JLT4	mghejog_gen	23:41(16.07.2022)	00:04(17.07.2022)	0:23HRS	LINE CHARGED
1187	17-Jul-2022	HASSAN	110	JOG-JST1	mghejog_gen	23:41(16.07.2022)	00:03(17.07.2022)	0:22HRS	LINE CHARGED
1188	17-Jul-2022	HASSAN	110	JOG-JST2	mghejog_gen	23:41(16.07.2022)	00:03(17.07.2022)	0:22HRS	LINE CHARGED
1189	17-Jul-2022	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	7:49	8:07	0:18	MAIN SUPPLY FAILURE
1190	17-Jul-2022	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	7:27	7:57	0:30	MAIN SUPPLY FAILURE
1191	17-Jul-2022	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	7:37	7:59	0:22	MAIN SUPPLY FAILURE
1192	17-Jul-2022	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	7:37	7:59	0:22	MAIN SUPPLY FAILURE
1193	17-Jul-2022	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	7:37	7:59	0:22	MAIN SUPPLY FAILURE
1194	17-Jul-2022	HASSAN	66	CRPATNA-CRPTNA1	CRPATNA_220	7:26	7:53	0:27	LINE FAULT
1195	17-Jul-2022	HASSAN	66	CRPATNA-CRPTNA2	CRPATNA_220	7:26	8:06	0:40	LINE FAULT
1196	17-Jul-2022	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATANAHALLI_66	15:04	15:11	0:07	LINE FAULT
1197	17-Jul-2022	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPLU_66	17:52	18:21	0:29	LINE FAULT
1198	17-Jul-2022	MYSURU	66	CR NAGARA-GUNDLUPETE 2	TERAKANAMBI	5:28	5:43	0:14	LINE FAULT
1199	17-Jul-2022	MYSURU	66	CR NAGARA-HONNAHALLI	ARAKALWADI, HONNAHALLI & ATTIGULIPURA	8:06	8:19	0:12	LINE FAULT
1200	17-Jul-2022	MYSURU	66	DR PETE-CR NAGARA 1	NO STATIONS EFFECTED	8:07	8:13	0:06	LINE FAULT
1201	17-Jul-2022	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	18:26	18:40	0:14	LINE FAULT
1202	17-Jul-2022	MYSURU	66	VIJAYANAGARA-FTS	VIJAYANAGARA	10:12	10:52	0:39	LINE CLEAR AVAILED
1203	17-Jul-2022	MYSURU	66	VIJAYANAGARA-HOOTAGALLI	NO STATIONS EFFECTED	10:21	10:54	0:32	LINE CLEAR AVAILED
1204	17-Jul-2022	MYSURU	66	VAJMANGALA -HEBBANI	NO STATIONS EFFECTED	16:51	17:01	0:10	LINE FAULT
1205	17-Jul-2022	MYSURU	66	AYRALLI-HV1	NO STATIONS EFFECTED	16:10	16:20	0:10	LINE FAULT
1206	17-Jul-2022	MYSURU	66	BESAGRALLI-HV1	NO STATIONS EFFECTED	13:05	13:15	0:10	LINE FAULT
1207	17-Jul-2022	MYSURU	66	LOKKANAHALLI-PG PALYA	NO STATIONS EFFECTED	17:35	17:40	0:05	LINE FAULT
1208	17-Jul-2022	MYSURU	66	HEBBANI-VADKEPURA	BANNUR, MALIYUR, VADKEPURA & KIRUGAVALU	18:50	19:09	0:19	LINE FAULT
1209	17-Jul-2022	MYSURU	66	SUNTIKOPPA-MADIKERI	NO STATIONS EFFECTED	16:34(13.07.2022)			LINE OPEN,LINE FAULT
1210	17-Jul-2022	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00(12.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1211	17-Jul-2022	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1212	17-Jul-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	18:26 (22/04/2022)			LINE OPEN,LINE CLEAR AVAILED
1213	17-Jul-2022	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN,LINE CLEAR AVAILED
1214	17-Jul-2022	TUMKUR	110	NITTUR 220-SOMLAPURA110	SOMLAPURA_110	12:45	16:40	3:55	LINE CLEAR AVAILED
1215	17-Jul-2022	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUN SOLAR1	9:00	9:12	0:12	LINE FAULT
1216	17-Jul-2022	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR2	WELSPUN SOLAR2	9:00	9:12	0:12	LINE FAULT
1217	17-Jul-2022	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA &URDIGERE66	KOLALA_66, URDIGERE_66	12:34	14:41	2:07	LINE CLEAR AVAILED
1218	17-Jul-2022	TUMKUR	66	JAVAGONDANAHALLI- HIRIYUR220	JAVAGONDANAHALLI_66	13:55	14:50	0:55	LINE FAULT
1219	17-Jul-2022	TUMKUR	66	KUNDUR- ROHAN WIND IPP 66	ROHAN WIND_IPP_66	14:50	16:20	1:29	LINE CLEAR AVAILED
1220	17-Jul-2022	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	10:16	18:14	7:58	LINE CLEAR AVAILED
1221	17-Jul-2022	TUMKUR	66	BRAHMASANDRA- THOVINKERE(KORA)	THOVINAKERE_66, KORA_66	9:45	15:30	5:45	NFBC ISSUED
1222	18-Jul-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1223	18-Jul-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN,LINE CLEAR AVAILED
1224	18-Jul-2022	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	8:50 (06.07.2022)			LINE OPEN,LINE FAULT
1225	18-Jul-2022	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1226	18-Jul-2022	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1227	18-Jul-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED TODALBAGI_110	19:13 (17.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1228	18-Jul-2022	BAGALKOT	110	110/33KV, HV-2 (HV1)	KABBUR_33 STATION NOT AFFECTED CHIKKODI_110	2:27	2:44	0:17	TRANSFORMER FAULT
1229	18-Jul-2022	BAGALKOT	220	220/110KV, HV-2 & LV2	STATION NOT AFFECTED BELAGAVI_220	13:00	18:01	5:01	LINE CLEAR AVAILED
1230	18-Jul-2022	BAGALKOT	110	110/33KV, HV-3	STATION NOT AFFECTED BAGALKOT_220	10:51	10:53	0:02	HAND TRIPPED
1231	18-Jul-2022	BAGALKOT	110	BAGALKOT220-GULEDGUDDA	GULEDGUDDA_110	19:20	23:00	3:40	LINE FAULT
1232	18-Jul-2022	BAGALKOT	110	MUGALKHOD220-ITNAL-3	STATION NOT AFFECTED MUGALKHOD_220	10:57	13:12	2:15	LINE CLEAR AVAILED
1233	18-Jul-2022	BAGALKOT	110	MUGALKHOD220-NAGANUR	STATION NOT AFFECTED MUGALKHOD_220	12:24	13:27	1:03	LINE CLEAR AVAILED
1234	18-Jul-2022	BAGALKOT	110	MUGALKHOD220- MAHALINGAPUR220	STATION NOT AFFECTED MUGALKHOD_220	14:30 (18.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1235	18-Jul-2022	BAGALKOT	220	HAVERI-GUTTUR-1	STATION NOT AFFECTED HAVERI_220	12:55	13:14	0:19	HAND TRIPPED
1236	18-Jul-2022	BAGALKOT	220	HAVERI-NARENDRA	STATION NOT AFFECTED HAVERI_220	13:15	13:22	0:07	HAND TRIPPED
1237	18-Jul-2022	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED AEQUS_220	16:17	17:20:00	1:03	LINE CLEAR AVAILED
1238	18-Jul-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED BABALESHWAR_110	16:03	16:46	0:43	LINE CLEAR AVAILED
1239	18-Jul-2022	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	21:40	21:50	0:10	LINE FAULT
1240	18-Jul-2022	BAGALKOT	110	BELLATTI-ENERCON2	ENERCON IPP_110 STATION NOT AFFECTED BELLATTI_110	12:11	14:03	1:52	LINE CLEAR AVAILED
1241	18-Jul-2022	BAGALKOT	110	BELLATTI-AB SOLAR	AB SOLAR IPP_110 STATION NOT AFFECTED BELLATTI_110	12:11	14:05	1:54	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1242	18-Jul-2022	BAGALKOT	110	110/33KV,HV2	KERUR_33 STATION NOT AFFECTED CHIKKODI_110	2:27	2:38	0:11	TRANSFORMER FAULT
1243	18-Jul-2022	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED GADAG_110	18:52	19:04	0:12	TRANSFORMER FAULT
1244	18-Jul-2022	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED GOPANAKOPPA_110	10:32	11:06	0:34	LINE CLEAR AVAILED
1245	18-Jul-2022	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED KUDACHI_110	15:16	16:05	0:49	LINE CLEAR AVAILED
1246	18-Jul-2022	BAGALKOT	110	KUDACHI- TERADAL(MORATAGI)	MORAB_110	19:20	19:32	0:12	LINE FAULT
1247	18-Jul-2022	BAGALKOT	110	110/11KV,HV1&3	STATION NOT AFFECTED LAXMESHWAR_110	10:15	17:18	7:03	LINE CLEAR AVAILED
1248	18-Jul-2022	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED MACHE_110	13:25	14:00	0:35	LINE CLEAR AVAILED
1249	18-Jul-2022	BAGALKOT	110	VAJRA220-JK CEMENT	JK CEMENT_110 STATION NOT AFFECTED VAJRAMATTI_220	14:25	14:37	0:12	LINE FAULT
1250	18-Jul-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TODALBAGI_110	15:51	16:56	1:05	HAND TRIPPED
1251	18-Jul-2022	BAGALKOT	110	SHIRATTI-LAXMESWAR	STATION NOT AFFECTED SHIRAHATTI_110	12:06	14:00	1:54	NFBC ISSUED
1252	18-Jul-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED SANKESHWAR_110	17:37	18:12	0:35	LINE CLEAR AVAILED
1253	18-Jul-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED PH COMPOUND_110	12:38	12:52	0:14	LINE CLEAR AVAILED
1254	18-Jul-2022	BAGALKOT	110	MUGHLKHOD220 -NGNUR	STATION NOT AFFECTED NAGANUR_110	12:25	13:27	1:02	NFBC ISSUED
1255	18-Jul-2022	BAGALKOT	110	110/11KV,HV2	NAVALGUND_110	11:09	12:11	1:02	LINE CLEAR AVAILED
1256	18-Jul-2022	BAGALKOT	110	NARENDRA-KU DHARWAD	STATION NOT AFFECTED NARENDRA_220	19:31	21:33	2:02	HAND TRIPPED
1257	18-Jul-2022	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED MUNAVALLI_110	12:05	13:30	1:25	LINE CLEAR AVAILED
1258	18-Jul-2022	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1259	18-Jul-2022	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	10:50 (26.03.2022)			LINE OPEN,LINE CLEAR AVAILED
1260	18-Jul-2022	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED ATHANI_220	9:41 (06.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1261	18-Jul-2022	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1262	18-Jul-2022	BAGALKOT	110	VAJRAMATTI220- KD JAMBAGI	KD JAMBAGI_110 HALKI_110, MUDHOL_110, UTTUR_110 YADWAD_110	14:25	14:45	0:20	LINE FAULT
1263	18-Jul-2022	BAGALKOT	110	110/11KV, HV-1 & HV-2	STATION NOT AFFECTED GIRISAGAR_110	15:40	17:20	1:40	LINE CLEAR AVAILED
1264	18-Jul-2022	BAGALKOT	110	110/11KV, HV-1	STATION NOT AFFECTED BILAGI_110	11:00	11:30	0:30	LINE CLEAR AVAILED
1265	18-Jul-2022	BAGALKOT	110	NARENDRA-SHEDBAL	SHEDBAL_110	19:28	20:56	1:28	LOAD CURTAILMENT
1266	18-Jul-2022	BAGALKOT	110	NARENDRA220-MR NAGAR	STATION NOT AFFECTED MR NAGAR_110	20:15 (18.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1267	18-Jul-2022	BAGALKOT	110	MR NAGAR-UAS DHARWAD	STATION NOT AFFECTED MR NAGAR_110	20:15 (18.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1268	18-Jul-2022	BAGALKOT	110	NARENDRA-KU DHARWAD	STATION NOT AFFECTED KU DHARWAD_110	20:15	21:30	1:15	HAND TRIPPED
1269	18-Jul-2022	BAGALKOT	220	220/110KV, HV2 & LV2	STATION NOT AFFECTED KARWAR_220	10:32 (18.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1270	18-Jul-2022	BENGALURU	66	HV2	BG ROAD	14:38	14:41	0:03	LINE CLEAR AVAILED
1271	18-Jul-2022	BENGALURU	220	HV1	EPIP 220	6:29	6:45	0:16	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1272	18-Jul-2022	BENGALURU	66	EPIP 220 - DIVYASHREE TECH PARK	DIVYASHREE TECH PARK, MINOR IRRIGATION, KACHAMARANAHALLI	6:29	6:48	0:19	MAIN SUPPLY FAILURE
1273	18-Jul-2022	BENGALURU	66	HV1	EPIP 220	6:29	6:48	0:19	MAIN SUPPLY FAILURE
1274	18-Jul-2022	BENGALURU	66	HV3	EPIP 220	6:29	6:48	0:19	MAIN SUPPLY FAILURE
1275	18-Jul-2022	BENGALURU	220	HV1	EPIP 220	13:22	13:29	0:07	TRANSFORMER FAULT
1276	18-Jul-2022	BENGALURU	66	EPIP 220 - DIVYASHREE TECH PARK	DIVYASHREE TECH PARK, MINOR IRRIGATION, KACHAMARANAHALLI	13:22	13:32	0:10	MAIN SUPPLY FAILURE
1277	18-Jul-2022	BENGALURU	66	HV1	EPIP 220	13:22	13:32	0:10	MAIN SUPPLY FAILURE
1278	18-Jul-2022	BENGALURU	66	HV3	EPIP 220	13:22	13:32	0:10	MAIN SUPPLY FAILURE
1279	18-Jul-2022	BENGALURU	66	HANUMANTHNAGARA - KANAKAPURA 220	HANUMANTHNAGARA	20:42	20:45	0:03	LOAD CHANGE OVER
1280	18-Jul-2022	BENGALURU	66	KODIGEHALI - BYADRAHALI	KODIGEHALI	9:40	10:33	0:53	MAIN SUPPLY FAILURE
1281	18-Jul-2022	BENGALURU	66	KODIGEHALI - TK HALLI 220	KODIGEHALI	11:43	11:48	0:05	LOAD CHANGE OVER
1282	18-Jul-2022	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	11:16	11:23	0:07	LOAD CHANGE OVER
1283	18-Jul-2022	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	18:13	18:20	0:07	LOAD CHANGE OVER
1284	18-Jul-2022	BENGALURU	66	SRS PEENYA 220 - BYADRAHALI	BYADRAHALI, SRIGANDA KAVALU	9:42	11:25	1:43	LINE FAULT
1285	18-Jul-2022	BENGALURU	66	SRS PEENYA 220 - BYADRAHALI	BYADRAHALI, SRIGANDA KAVALU	11:05	11:25	0:20	LINE CLEAR AVAILED
1286	18-Jul-2022	BENGALURU	66	SRS PEENYA 220 - BRINDAVANA	NO STATION AFFECTED	9:42	10:35	0:53	LINE FAULT
1287	18-Jul-2022	BENGALURU	66	HV2	SRS PEENYA 220	12:21	12:26	0:05	LINE CLEAR AVAILED
1288	18-Jul-2022	BENGALURU	66	HV2	SRS PEENYA 220	21:53	22:03	0:10	LINE CLEAR AVAILED
1289	18-Jul-2022	BENGALURU	66	T GOLLAHALI 220 - KGF 1	KGF	15:36	15:46	0:10	LINE FAULT
1290	18-Jul-2022	BENGALURU	66	T GOLLAHALI 220 - KGF 1	KGF	15:46	17:31	1:45	LINE FAULT
1291	18-Jul-2022	BENGALURU	66	T GOLLAHALI 220 - KGF 1	KGF	17:31	18:46	1:15	LINE CLEAR AVAILED
1292	18-Jul-2022	BENGALURU	66	T GOLLAHALI 220 - KGF 2	KAMASAMUDRA, BEML	17:31	18:46	1:15	LINE CLEAR AVAILED
1293	18-Jul-2022	BENGALURU	66	HV3	BIDADI 220	9:40	10:03	0:23	TRANSFORMER FAULT
1294	18-Jul-2022	BENGALURU	66	HV3	BIDADI 220	10:34	11:03	0:29	LINE CLEAR AVAILED
1295	18-Jul-2022	BENGALURU	66	HV1	BAGGANADODDI	8:30	9:16	0:46	LINE CLEAR AVAILED
1296	18-Jul-2022	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	15:41	15:48	0:07	LINE FAULT
1297	18-Jul-2022	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	18:50	19:12	0:21	LOAD CURTAILMENT
1298	18-Jul-2022	BENGALURU	66	MALUR 220 - MASTHI	MAASTHI	18:50	19:16	0:26	LOAD CURTAILMENT
1299	18-Jul-2022	BENGALURU	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	18:50	19:19	0:29	LOAD CURTAILMENT
1300	18-Jul-2022	BENGALURU	66	MALUR 220 - KGF 2	BANGARPETE	19:03	19:16	0:12	LOAD CURTAILMENT
1301	18-Jul-2022	BENGALURU	66	HV1	MITTEMARI 220	17:41	17:43	0:02	LINE CLEAR AVAILED
1302	18-Jul-2022	BENGALURU	66	HV2	NANDAGUDI	14:04	14:19	0:14	TRANSFORMER FAULT
1303	18-Jul-2022	BENGALURU	66	HV2	SARJAPURA 220	6:31	6:59	0:28	TRANSFORMER FAULT
1304	18-Jul-2022	BENGALURU	66	HV2	SARJAPURA 220	21:25	21:53	0:27	TRANSFORMER FAULT
1305	18-Jul-2022	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	10:01	10:26	0:25	LINE FAULT
1306	18-Jul-2022	BENGALURU	66	YEDUMADU - KANAKPURA 220	YEDUMADU, HANUMANTHNAGAR	20:40	20:44	0:04	LOAD CHANGE OVER
1307	18-Jul-2022	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA, GUNDLU KOTTUR	20:53	21:35	0:42	LOAD CURTAILMENT
1308	18-Jul-2022	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 1	MANCHENAHALLI, GUNDAMGERE	19:20	20:25	1:05	LOAD CURTAILMENT
1309	18-Jul-2022	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	THONDEBHAVI	19:20	20:25	1:05	LOAD CURTAILMENT
1310	18-Jul-2022	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PLYA, GUDIBANDE, MANDIKAL, PERESANDRA	19:22	20:30	1:08	LOAD CURTAILMENT
1311	18-Jul-2022	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	21:10	21:30	0:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1312	18-Jul-2022	BENGALURU	66	HV2	GOWRIBIDANUR 220	9:42	9:52	0:10	TRANSFORMER FAULT
1313	18-Jul-2022	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLI CROSS, YENIGADALE	19:02	19:46	0:43	LOAD CURTAILMENT
1314	18-Jul-2022	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, BURUDAGUNTE	19:02	19:44	0:41	LOAD CURTAILMENT
1315	18-Jul-2022	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, PALLICHERLU	19:02	19:12	0:09	LOAD CURTAILMENT
1316	18-Jul-2022	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, PALLICHERLU	19:02	19:12	0:09	LOAD CURTAILMENT
1317	18-Jul-2022	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	19:02	19:48	0:45	LOAD CURTAILMENT
1318	18-Jul-2022	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	20:48	20:51	0:03	LOAD CURTAILMENT
1319	18-Jul-2022	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	19:02	19:51	0:48	LOAD CURTAILMENT
1320	18-Jul-2022	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	19:02	19:47	0:44	LOAD CURTAILMENT
1321	18-Jul-2022	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	19:02	19:49	0:46	LOAD CURTAILMENT
1322	18-Jul-2022	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	19:02	19:50	0:47	LOAD CURTAILMENT
1323	18-Jul-2022	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	19:05	21:52	2:47	LOAD CURTAILMENT
1324	18-Jul-2022	BENGALURU	66	KOLAR 220 - THAYLUR	TAMAKA	19:05	22:08	3:03	LOAD CURTAILMENT
1325	18-Jul-2022	BENGALURU	66	KOLAR 220 - PGCIL AUX	PGCIL AUX, SUGUTUR	19:05	21:47	2:42	LOAD CURTAILMENT
1326	18-Jul-2022	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	19:05	21:50	2:45	LOAD CURTAILMENT
1327	18-Jul-2022	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	18:49	21:30	2:40	LOAD CURTAILMENT
1328	18-Jul-2022	BENGALURU	66	HOODY 220 - BMRCL	NO STATION AFFECTED	12:31(17/07/2022)			LINE OPEN,LINE FAULT
1329	18-Jul-2022	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN,LINE CLEAR AVAILED
1330	18-Jul-2022	GULBARGA	400	BTPS-HIRIYUR2	HIRYUR_400	01:07(16/07/2022)			LINE OPEN,LINE CLEAR AVAILED
1331	18-Jul-2022	GULBARGA	400	YTPS-BPS_1	BPS_400	11:26	17:53	6:27	LINE CLEAR AVAILED
1332	18-Jul-2022	GULBARGA	220	HALAWARTHY-DHONI1	HALAWARTHY_220	7:12 (5.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1333	18-Jul-2022	GULBARGA	220	HALAWARTHY-DHONI2	HALAWARTHY_220	7:45 (5.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1334	18-Jul-2022	GULBARGA	220	SEDAM_SHAHAPUR	SEDAM_220	05:48(10/06/2022)			LINE OPEN,LINE CLEAR AVAILED
1335	18-Jul-2022	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	23:05(18/07/2022)			LINE OPEN,LINE CLEAR AVAILED
1336	18-Jul-2022	GULBARGA	220	LINGASUGUR-RTPS1	RTPS_220	0:21	0:37	0:16	LINE FAULT
1337	18-Jul-2022	GULBARGA	220	LINGASUGUR-RTPS2	RTPS_220	1:19	9:41	8:22	LINE FAULT
1338	18-Jul-2022	GULBARGA	220	LINGASUGUR-SINDHANOOR220	SINDHANOOR_220	10:04	19:53	9:49	LINE CLEAR AVAILED
1339	18-Jul-2022	GULBARGA	220	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	0:12	9:41	9:29	LINE FAULT
1340	18-Jul-2022	GULBARGA	220	KAPNOOR-HUMNABAD1	MAHAGAON_110,MARGUTTI_110	4:19	4:24	0:05	LINE FAULT
1341	18-Jul-2022	GULBARGA	220	SINDHNOOR-LINGSUGUR	LINGSUGUR_220	10:35	19:55	9:20	LINE CLEAR AVAILED
1342	18-Jul-2022	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	22:31(17/07/2022)	06:56(18/07/2022)	08:25HRS	LINE CHARGED
1343	18-Jul-2022	GULBARGA	110	HV2	DEODURGA_110	8:15	8:30	0:15	TRANSFORMER FAULT
1344	18-Jul-2022	GULBARGA	110	HV2	VAJARABANDI_110	17:05	17:25	0:20	TRANSFORMER FAULT
1345	18-Jul-2022	GULBARGA	110	HV1	HANUMANAL_110	10:20	11:20	1:00	LINE CLEAR AVAILED
1346	18-Jul-2022	GULBARGA	110	HV1	CHICKSUGUR_110	18:19	18:46	0:27	TRANSFORMER FAULT
1347	18-Jul-2022	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	22:48 (17.07.2022)	11:39 (18.07.2022)	12:51 HRS	LINE CHARGED
1348	18-Jul-2022	GULBARGA	110	DEODURGA-SHAHAPUR	DEODURGA_110	19:15	20:10	0:55	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1349	18-Jul-2022	GULBARGA	110	NALWAR-SHAHAPUR1	NALWAR_110,JEWARGI,CLEAN SOLAR_IPP, WARAD SOLAR_IPP	19:10	20:10	1:00	MAIN SUPPLY FAILURE
1350	18-Jul-2022	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	3:25	3:50	0:25	LINE FAULT
1351	18-Jul-2022	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	21:48	22:08	0:20	LINE FAULT
1352	18-Jul-2022	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	18:36	19:10	0:34	LINE FAULT
1353	18-Jul-2022	GULBARGA	110	SASTHAPUR-LADHA	LADHA_110	20:10	20:20	0:10	LOAD CURTAILMENT
1354	18-Jul-2022	GULBARGA	110	HUNASAGI-KEMBHAVI	HUNASAGI_110	14:45	16:40	1:55	MAIN SUPPLY FAILURE
1355	18-Jul-2022	GULBARGA	110	HUNASAGI-KEMBHAVI	HUNASAGI_110	19:10	20:45	1:35	MAIN SUPPLY FAILURE
1356	18-Jul-2022	GULBARGA	110	MUDDAPUR-HATTI	MUDDAPUR_110	4:56	5:02	0:06	LINE FAULT
1357	18-Jul-2022	GULBARGA	110	MUNIRABAD-VYASANKERE1(IDLE)	DONIMALAI_110	9:08(17.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1358	18-Jul-2022	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	3:10	11:06	7:56	LINE FAULT
1359	18-Jul-2022	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	19:30	20:19	0:49	LOAD CURTAILMENT
1360	18-Jul-2022	GULBARGA	110	SHAHAPUR-KEMBHAVI,KHANAPUR,SHORAPUR,KBJNL,SHAHAPUR 1&2,RAICHUR 1&2,YADGIR	KEMBHAVI_110,KHANAPUR_110,SHORAPUR_110,KBJNL_110,SHAHAPUR 1&2_110,RAICHUR 1&2_110,YADGIR_110,NALWAR_110,SAIDAPUR_110,JEWARGI_110,WADGERA_110	19:11	20:12	1:01	LOAD CURTAILMENT
1361	18-Jul-2022	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	12:16	12:35	0:19	LINE FAULT
1362	18-Jul-2022	GULBARGA	110	SULEKAL-MARALIHALLI	MUKUNDA_110, YEREDONA_110,BENNUR SOLAR_IPP	15:44	15:57	0:13	LINE CLEAR AVAILED
1363	18-Jul-2022	GULBARGA	110	SULEKAL-MARALIHALLI	MUKUNDA_110, YEREDONA_110,BENNUR SOLAR_IPP	23:33	23:40	0:07	LINE FAULT
1364	18-Jul-2022	GULBARGA	110	SINDHNOOR-SINDHNOOR2	SINDHNOOR_110,VALKAMDINI_110,BYAGWAT_110	0:35	0:55	0:20	LINE FAULT
1365	18-Jul-2022	GULBARGA	110	SHAHABAD-WADI	WADI_110	19:05	20:07	1:02	LOAD CURTAILMENT
1366	18-Jul-2022	GULBARGA	110	SHAHABAD-GULBARGAUNIVERSITY2	GULBARGAUNIVERSITY_110	19:05	20:11	1:06	LOAD CURTAILMENT
1367	18-Jul-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	19:05	20:19	1:14	LOAD CURTAILMENT
1368	18-Jul-2022	GULBARGA	110	SHAHABAD-BAGEWADI1	MANDEWAL_110,MORATAGI-DEVANGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	19:05	20:28	1:23	LOAD CURTAILMENT
1369	18-Jul-2022	GULBARGA	110	SHAHABAD-FARHATABAD	FARHATABAD_110,GULBARGA SOUTH_110	19:05	21:39	2:34	LOAD CURTAILMENT
1370	18-Jul-2022	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	0:50	1:02	0:12	LINE FAULT
1371	18-Jul-2022	GULBARGA	110	MALLAT-MADLAPUR_110	MADLAPUR_110, MANVI_110, ADVIAMRESHWAR_110	10:01	20:06	10:05	LINE FAULT
1372	18-Jul-2022	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	19:13	20:05	0:52	LOAD CURTAILMENT
1373	18-Jul-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGAL_110	19:20	20:01	0:41	LOAD CURTAILMENT
1374	18-Jul-2022	GULBARGA	66	HV2	BENNEHALI_66	5:20	5:25	0:05	TRANSFORMER FAULT
1375	18-Jul-2022	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJAINI_66	6:10	6:20	0:10	LINE FAULT
1376	18-Jul-2022	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJAINI_66	9:15	9:25	0:10	LINE CLEAR AVAILED
1377	18-Jul-2022	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINAHADGALI_66,HOLAGUNDI_66	19:05	19:25	0:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1378	18-Jul-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1379	18-Jul-2022	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN,LINE FAULT
1380	18-Jul-2022	HASSAN	66	HV1	SINGAPURA_66	16:36(15.07.2022)	17:07(18.07.2022)	71:31HRS	TRANSFORMER CHARGED
1381	18-Jul-2022	HASSAN	220	KADUR-SHIMOGA	KADUR_220	6:40(18.07.2022)			LINE OPEN,LINE FAULT
1382	18-Jul-2022	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	7:35(18.07.2022)			LINE OPEN,LINE FAULT
1383	18-Jul-2022	HASSAN	220	UPCL-KEMAR1	upcl_gen	6:42	8:39	1:57	NFBC ISSUED
1384	18-Jul-2022	HASSAN	220	UPCL-KEMAR2	upcl_gen	6:42	8:45	2:03	NFBC ISSUED
1385	18-Jul-2022	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	17:10	19:52	2:42	NFBC ISSUED
1386	18-Jul-2022	HASSAN	220	HGUNJE-KEMAR	HEGGUNJE_220	7:37	8:31	0:54	NFBC ISSUED
1387	18-Jul-2022	HASSAN	220	HGUNJE-KEMAR	HEGGUNJE_220	13:28	14:28	1:00	NFBC ISSUED
1388	18-Jul-2022	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	6:38	8:45	2:07	MAIN SUPPLY FAILURE
1389	18-Jul-2022	HASSAN	220	KAVOOR-MSEZ1	KAVOOR_220	6:38	8:45	2:07	MAIN SUPPLY FAILURE
1390	18-Jul-2022	HASSAN	220	KAVOOR-MSEZ2	KAVOOR_220	6:38	8:45	2:07	MAIN SUPPLY FAILURE
1391	18-Jul-2022	HASSAN	110	KAVOOR-Kulashkhara1	KAVOOR_220	6:38	8:45	2:07	MAIN SUPPLY FAILURE
1392	18-Jul-2022	HASSAN	110	KAVOOR-KIOCL	KAVOOR_220	14:02	16:20	2:18	LINE CLEAR AVAILED
1393	18-Jul-2022	HASSAN	220	HV1	KEMAR_220	7:40	8:53	1:13	LINE CLEAR AVAILED
1394	18-Jul-2022	HASSAN	220	HV2	KEMAR_220	6:37	8:40	2:03	LINE CLEAR AVAILED
1395	18-Jul-2022	HASSAN	220	HV3	KEMAR_220	6:37	8:54	2:17	LINE CLEAR AVAILED
1396	18-Jul-2022	HASSAN	220	KEMAR-MSEZ1	KEMAR_220	6:37	8:54	2:17	LINE CLEAR AVAILED
1397	18-Jul-2022	HASSAN	220	KEMAR-MSEZ2	KEMAR_220	6:37	8:55	2:18	LINE CLEAR AVAILED
1398	18-Jul-2022	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	7:43	8:55	1:12	LINE CLEAR AVAILED
1399	18-Jul-2022	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	7:39	8:54	1:15	LINE CLEAR AVAILED
1400	18-Jul-2022	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	8:54	9:32	0:38	LINE CLEAR AVAILED
1401	18-Jul-2022	HASSAN	220	KEMAR-UPCL1	KEMAR_220	6:37	8:39	2:02	LINE CLEAR AVAILED
1402	18-Jul-2022	HASSAN	220	KEMAR-UPCL2	KEMAR_220	6:37	8:45	2:08	LINE CLEAR AVAILED
1403	18-Jul-2022	HASSAN	220	KEMAR-Varahi1	KEMAR_220	7:39	8:41	1:02	LINE CLEAR AVAILED
1404	18-Jul-2022	HASSAN	220	KEMAR-Varahi2	KEMAR_220	7:39	8:49	1:10	LINE CLEAR AVAILED
1405	18-Jul-2022	HASSAN	220	KEMAR-Varahi2	KEMAR_220	10:25	11:33	1:08	LINE CLEAR AVAILED
1406	18-Jul-2022	HASSAN	220	KEMAR-HEGGUNJE	KEMAR_220	7:36	8:54	1:18	LINE CLEAR AVAILED
1407	18-Jul-2022	HASSAN	220	KEMAR-Varahi3	KEMAR_220	13:28	14:28	1:00	LINE CLEAR AVAILED
1408	18-Jul-2022	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	5:57	6:22	0:25	LINE FAULT
1409	18-Jul-2022	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	6:36	9:09	2:33	LINE CLEAR AVAILED
1410	18-Jul-2022	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	6:44	8:57	2:13	LINE CLEAR AVAILED
1411	18-Jul-2022	HASSAN	110	KEMAR-KARAKALA	KEMAR_220	6:36	9:04	2:28	LINE CLEAR AVAILED
1412	18-Jul-2022	HASSAN	110	KEMAR-BELMAN	KEMAR_220	6:36	8:59	2:23	LINE CLEAR AVAILED
1413	18-Jul-2022	HASSAN	110	HV1	KEMAR_220	6:43	8:51	2:08	LINE CLEAR AVAILED
1414	18-Jul-2022	HASSAN	110	HV2	KEMAR_220	6:43	8:47	2:04	LINE CLEAR AVAILED
1415	18-Jul-2022	HASSAN	110	LV1	KEMAR_220	7:40	8:53	1:13	LINE CLEAR AVAILED
1416	18-Jul-2022	HASSAN	110	LV2	KEMAR_220	6:36	8:40	2:04	LINE CLEAR AVAILED
1417	18-Jul-2022	HASSAN	110	LV3	KEMAR_220	6:37	8:54	2:17	LINE CLEAR AVAILED
1418	18-Jul-2022	HASSAN	110	KEMAR-Manipal1	KEMAR_220	7:38	9:00	1:22	LINE CLEAR AVAILED
1419	18-Jul-2022	HASSAN	110	KEMAR-Manipal2	KEMAR_220	7:38	9:00	1:22	LINE CLEAR AVAILED
1420	18-Jul-2022	HASSAN	110	KEMAR-NANDHIKUR	KEMAR_220	6:43	9:01	2:18	LINE CLEAR AVAILED
1421	18-Jul-2022	HASSAN	220	MRSSHM-ARSIKERE	MRSMSG_220	17:10	19:52	2:42	LINE CLEAR AVAILED
1422	18-Jul-2022	HASSAN	220	MRSSHM-DVG1	MRSMSG_220	13:15	14:11	0:56	LINE FAULT
1423	18-Jul-2022	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	6:39	7:35	0:56	LINE FAULT
1424	18-Jul-2022	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	10:38	21:01	10:23	LINE CLEAR AVAILED
1425	18-Jul-2022	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	6:36	8:47	2:11	HAND TRIPPED
1426	18-Jul-2022	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	6:36	8:47	2:11	HAND TRIPPED
1427	18-Jul-2022	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	6:36	8:47	2:11	MAIN SUPPLY FAILURE
1428	18-Jul-2022	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	6:36	8:57	2:21	MAIN SUPPLY FAILURE
1429	18-Jul-2022	HASSAN	110	MSEZ-GSS31	MSEZ_220	6:39	9:08	2:29	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1430	18-Jul-2022	HASSAN	110	MSEZ-GSS32	MSEZ_220	6:39	9:08	2:29	HAND TRIPPED
1431	18-Jul-2022	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	6:38	9:04	2:26	HAND TRIPPED
1432	18-Jul-2022	HASSAN	220	HV1	PUTTUR_220	7:41	8:58	1:17	HAND TRIPPED
1433	18-Jul-2022	HASSAN	220	HV2	PUTTUR_220	7:41	8:58	1:17	HAND TRIPPED
1434	18-Jul-2022	HASSAN	220	PUTTUR-KEMAR1	PUTTUR_220	7:41	8:57	1:16	MAIN SUPPLY FAILURE
1435	18-Jul-2022	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	7:41	9:34	1:53	MAIN SUPPLY FAILURE
1436	18-Jul-2022	HASSAN	110	HV1	PUTTUR_220	7:41	9:01	1:20	HAND TRIPPED
1437	18-Jul-2022	HASSAN	110	LV1	PUTTUR_220	7:41	9:01	1:20	HAND TRIPPED
1438	18-Jul-2022	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	7:41	9:01	1:20	HAND TRIPPED
1439	18-Jul-2022	HASSAN	110	PUTTUR-VITLA	PUTTUR_220	7:41	9:19	1:38	HAND TRIPPED
1440	18-Jul-2022	HASSAN	110	PUTTUR-PUTTUR2	PUTTUR_220	7:41	9:01	1:20	HAND TRIPPED
1441	18-Jul-2022	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	7:41	9:26	1:45	HAND TRIPPED
1442	18-Jul-2022	HASSAN	220	VARAHI-SHMG3	varahi_gen	10:38	21:02	10:24	NFBC ISSUED
1443	18-Jul-2022	HASSAN	110	ALKOLA-SAGAR	ALKOLA_110	19:30	21:15	1:45	HAND TRIPPED
1444	18-Jul-2022	HASSAN	110	BAIKAM-KAVOOR	BAIKAMPADY_110	6:36	9:03	2:27	MAIN SUPPLY FAILURE
1445	18-Jul-2022	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	9:03	9:11	0:08	MAIN SUPPLY FAILURE
1446	18-Jul-2022	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	9:25	16:27	7:02	NFBC ISSUED
1447	18-Jul-2022	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	6:37	9:10	2:33	MAIN SUPPLY FAILURE
1448	18-Jul-2022	HASSAN	110	GURUVAKEMAR2	GURUVAYANAKERE_110	6:37	8:57	2:20	MAIN SUPPLY FAILURE
1449	18-Jul-2022	HASSAN	110	GURUVA-SLPWR	GURUVAYANAKERE_110	6:37	9:02	2:25	MAIN SUPPLY FAILURE
1450	18-Jul-2022	HASSAN	110	HV2	HALADY_110	13:35	15:38	2:03	LINE CLEAR AVAILED
1451	18-Jul-2022	HASSAN	110	HIRIYA-MANIPAL	HIRIYADAKA_110	9:58	14:40	4:42	LINE CLEAR AVAILED
1452	18-Jul-2022	HASSAN	110	HV2	KARAYA_110	11:59	15:00	3:01	LINE CLEAR AVAILED
1453	18-Jul-2022	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	6:36	7:02	0:26	MAIN SUPPLY FAILURE
1454	18-Jul-2022	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	7:41	9:02	1:21	MAIN SUPPLY FAILURE
1455	18-Jul-2022	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	10:10	14:42	4:32	NFBC ISSUED
1456	18-Jul-2022	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	7:40	9:05	1:25	MAIN SUPPLY FAILURE
1457	18-Jul-2022	HASSAN	110	MANIPAL-KEMAR2	MANIPAL_110	7:40	9:10	1:30	MAIN SUPPLY FAILURE
1458	18-Jul-2022	HASSAN	110	SALATHU-VITLSLTHR	SALATHUR_110	10:30	14:52	4:22	NFBC ISSUED
1459	18-Jul-2022	HASSAN	110	SALATHU-VITLSLTHR	SALATHUR_110	7:42	9:06	1:24	MAIN SUPPLY FAILURE
1460	18-Jul-2022	HASSAN	110	SALATHU-VITLSLTHR	SALATHUR_110	9:13	9:20	0:07	MAIN SUPPLY FAILURE
1461	18-Jul-2022	HASSAN	110	VITTAL-PUTR_SLTUR	VITLA_110	10:30	14:52	4:22	LINE CLEAR AVAILED
1462	18-Jul-2022	HASSAN	110	VITTAL-PUTR_SLTUR	VITLA_110	7:42	9:06	1:24	MAIN SUPPLY FAILURE
1463	18-Jul-2022	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	14:42	14:50	0:08	LINE FAULT
1464	18-Jul-2022	HASSAN	66	HV2	KANDLI_66	11:13	14:19	3:06	LINE CLEAR AVAILED
1465	18-Jul-2022	MYSURU	66	HV1	ARAKERE_66	16:53	17:20	0:27	LINE CLEAR AVAILED
1466	18-Jul-2022	MYSURU	66	HV1	CHIKKA_MANDYA_66	5:47	14:20	8:32	LINE CLEAR AVAILED
1467	18-Jul-2022	MYSURU	66	CR NAGARA-HONGANUR	YELANDUR_66 HONGANUR_66	6:08	6:18	0:10	LINE FAULT
1468	18-Jul-2022	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	11:18	11:25	0:07	LINE FAULT
1469	18-Jul-2022	MYSURU	66	HUNSUR-ELWALA	GAVADAGERE_66	8:48	9:02	0:14	LINE FAULT
1470	18-Jul-2022	MYSURU	66	KADAKOLA-SARGUR1	HAMPAPURA(K)_66JAIPUR_66	11:02	13:59	2:57	LINE CLEAR AVAILED
1471	18-Jul-2022	MYSURU	66	HV2	MANDYA_66	10:27	13:32	3:05	LINE CLEAR AVAILED
1472	18-Jul-2022	MYSURU	66	MANDYA-KK HALLI	NO STATIONS EFFECTED	13:37	14:06	0:29	LINE CLEAR AVAILED
1473	18-Jul-2022	MYSURU	66	HV2	MEGALAPURA_66	13:00	13:37	0:37	LINE CLEAR AVAILED
1474	18-Jul-2022	MYSURU	66	HV2	THALAKADU_66	14:16	14:55	0:39	LINE CLEAR AVAILED
1475	18-Jul-2022	MYSURU	66	HV1	THALAKADU_66	14:15	14:55	0:40	LINE CLEAR AVAILED
1476	18-Jul-2022	MYSURU	66	HV1	THALAKADU_66	14:20	17:50	3:30	LINE CLEAR AVAILED
1477	18-Jul-2022	MYSURU	66	HV2	THALAKADU_66	15:30	16:47	1:17	LINE CLEAR AVAILED
1478	18-Jul-2022	MYSURU	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	6:46	7:05	0:19	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1479	18-Jul-2022	MYSURU	66	KUSHALNAGARA-MERCERA-1	MADIKERI_66	10:43	15:49	5:06	LINE CLEAR AVAILED
1480	18-Jul-2022	MYSURU	66	KUSHALNAGARA-SUNTIKOPPA	SUNTIKOPPA_66	10:43	15:49	5:06	LINE CLEAR AVAILED
1481	18-Jul-2022	MYSURU	66	KUSHALNAGARA-BETTADAPURA	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	14:04	14:14	0:10	LINE FAULT
1482	18-Jul-2022	MYSURU	66	HV3	KUSHALANAGARA_66	15:04	15:42	0:38	LINE CLEAR AVAILED
1483	18-Jul-2022	MYSURU	66	SUNTIKOPPA-MADIKERI	NO STATIONS EFFECTED	14:34 (13.07.2022)	15:50:00(18.7.22)	131:16HRS	LINE CHARGED
1484	18-Jul-2022	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00 (12.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1485	18-Jul-2022	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1486	18-Jul-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	18:26 (22/04/2022)			LINE OPEN,LINE CLEAR AVAILED
1487	18-Jul-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN,LINE CLEAR AVAILED
1488	18-Jul-2022	TUMKUR	110	TR-1	TURUVEKERE_110	13:42	14:08	0:25	LINE CLEAR AVAILED
1489	18-Jul-2022	TUMKUR	110	TR-2	TURUVEKERE_110	14:25	14:50	0:25	LINE CLEAR AVAILED
1490	18-Jul-2022	TUMKUR	110	TR-1	NITTUR_220	19:19	20:51	1:32	TRANSFORMER FAULT
1491	18-Jul-2022	TUMKUR	110	NITTUR 220-SOMLAPURA110	SOMLAPURA_110	19:18	20:57	1:39	LINE FAULT
1492	18-Jul-2022	TUMKUR	110	NITTUR 220-SOMLAPURA110	SOMLAPURA_110	20:58	21:28	0:29	LINE FAULT
1493	18-Jul-2022	TUMKUR	110	TR-2	PD KOTE_66	13:22	13:29	0:06	TRANSFORMER FAULT
1494	18-Jul-2022	TUMKUR	66	ANCHEPALYA 220kv-AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,YEDAVANI_66	18:53	19:22	0:28	LOAD CURTAILMENT
1495	18-Jul-2022	TUMKUR	66	ANCHEPALYA 220kv-ANCHEPALYA 1	ANCHEPALYA_66,BHAKTHARAHALLI_66	18:53	19:22	0:28	LOAD CURTAILMENT
1496	18-Jul-2022	TUMKUR	66	ANTHRASANAHALLI 220KV-BELLAVI	BELLAVI_66,MALLASANDRA_66, HEGGERE_66, DODDASARANGI_66	19:25	21:44	2:18	LOAD CURTAILMENT
1497	18-Jul-2022	TUMKUR	66	ANTHRASANAHALLI 220kv-KOLTEGERE	KOLTEGERE,CHIKKATOTLUKERE_66,BELADARA_66	19:21	21:46	2:25	LOAD CURTAILMENT
1498	18-Jul-2022	TUMKUR	66	ANTHRASANAHALLI 220KV-MELEKOTE	MELKOTE_66, BADDIHALLI_66,HONNUDIKE_66	19:21	20:55	1:33	LOAD CURTAILMENT
1499	18-Jul-2022	TUMKUR	66	ANTHRASANAHALLI 220KV-TUMKUR	TUMKUR_66	19:21	20:55	1:33	LOAD CURTAILMENT
1500	18-Jul-2022	TUMKUR	66	ANTHRASANAHALLI 220KV-BELLAVI	BELLAVI_66,MALLASANDRA_66, HEGGERE_66, DODDASARANGI_66	19:21	20:55	1:33	LOAD CURTAILMENT
1501	18-Jul-2022	TUMKUR	66	BEVINAHALLI- AFTL SOLAR IPP_66	AFTL SOLAR_IPP_66	5:40	5:51	0:11	LINE FAULT
1502	18-Jul-2022	TUMKUR	66	BILCHODU66-PALLAGATTE66	BILCHODU_66	9:25	9:35	0:10	MAIN SUPPLY FAILURE
1503	18-Jul-2022	TUMKUR	66	DAVANGERE SRS-CHITRADURGA1	CHITRADURGA_220	1:33	1:45	0:12	LINE FAULT
1504	18-Jul-2022	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:48	10:57	0:09	LINE FAULT
1505	18-Jul-2022	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	5:46	6:23	0:36	LINE FAULT
1506	18-Jul-2022	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	6:25	6:39	0:14	LINE FAULT
1507	18-Jul-2022	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	8:04	8:15	0:11	LINE FAULT
1508	18-Jul-2022	TUMKUR	66	TR-2	HONNUDIKE_66	11:00	11:03	0:02	TRANSFORMER FAULT
1509	18-Jul-2022	TUMKUR	66	TR-1	HULIYURDURGA_66	12:20	13:50	1:30	LINE CLEAR AVAILED
1510	18-Jul-2022	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:02	11:06	0:03	LINE FAULT
1511	18-Jul-2022	TUMKUR	66	KATTIGE- BEDRUGADDE	KATTIGE_66	17:07	17:16	0:09	HAND TRIPPED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1512	18-Jul-2022	TUMKUR	66	KATTIGE- RENEW WIND IPP	RENEW WIND ENERGY_IPP_66	17:07	17:16	0:09	HAND TRIPPED
1513	18-Jul-2022	TUMKUR	66	KUNDUR- HONNALLI	KUNDUR_66	5:47	6:00	0:13	HAND TRIPPED
1514	18-Jul-2022	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	14:57	16:10	1:13	LINE FAULT
1515	18-Jul-2022	TUMKUR	66	TR-2	MALEBENNUR_66	15:53	16:09	0:16	HAND TRIPPED