

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 28.05.2019 to 03.06.2019**

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	28-May-19	BAGALKOT	66	66/11KV,HV 2	HARIHAR-HOSPET_66	17:50	17:56	0:06	HAND TRIPPED
2	28-May-19	BAGALKOT	110	ATHANI-AIGALI	AIGALI_110	5:34	5:52	0:18	LINE FAULT
3	28-May-19	BAGALKOT	110	110/11KV,HV 2	BIJAPUR_110	6:49	8:29	1:40	TRANSFORMER FAULT
4	28-May-19	BAGALKOT	110	SAIDAPUR-DAVALESHWAR	DAVALESHWAR_110	5:39	7:15	1:36	LINE FAULT
5	28-May-19	BAGALKOT	110	110/11KV,HV 2	KALAGHATGI_110	17:16	17:23	0:07	TRANSFORMER FAULT
6	28-May-19	BAGALKOT	220	BAGEWADI-NANDYAL2(BIJAPUR2)	BAGEWADI_220	14:42	17:31	2:49	LINE CLEAR AVAILED
7	28-May-19	BAGALKOT	220	220/110KV,HV 1,2 & LV-1,2	KUDACHI_220,& UGAR_110,TERADAL_110,KUDCHI_11 O,YELPARATTI_110,AINAPUR_110,MO RAB_110	5:20	5:31	0:11	TRANSFORMER FAULT
8	28-May-19	BAGALKOT	220	RANEENNUR-BALLIGAVI (SHIRALKOPPA)	RANEENNUR_220	7:12	10:02	2:50	MAIN SUPPLY FAILURE
9	28-May-19	BAGALKOT	220	RANEENNUR-BALLIGAVI (SHIRALKOPPA)	RANEENNUR_220	13:04	14:45	1:41	MAIN SUPPLY FAILURE
10	28-May-19	BAGALKOT	110	110/33KV,HV4	ZALAKI_110,NEVARAGI_33,DHULKHED _33,HASANGI_33	6:35	6:37	0:02	TRANSFORMER FAULT
11	28-May-19	BAGALKOT	110	RAIBAG-CHIKKODI 2	RAIBAG_110 (STATION NOT INTERRUPTED)	13:15	19:04	5:49	LINE FAULT
12	28-May-19	BAGALKOT	110	110/11KV,HV1	MUNDARAGI_110	7:33	8:21	0:48	LINE CLEAR AVAILED
13	28-May-19	BAGALKOT	110	110/11KV,HV2	MUKARTHAL_110	11:15	11:36	0:21	LINE CLEAR AVAILED
14	28-May-19	BENGALURU	66	YERANDANAHALLI 220 - ELECTRONIC CITY 1	BOMMASANDRA I/A, BIOCON (EHT)	17:29	18:36	1:06	LINE CLEAR AVAILED
15	28-May-19	BENGALURU	220	A STATION 220 - NRS 220	A STATION 220	14:11	14:33	0:21	LINE CLEAR AVAILED
16	28-May-19	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	14:11	14:33	0:21	LINE CLEAR AVAILED
17	28-May-19	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	14:11	14:33	0:21	LINE CLEAR AVAILED
18	28-May-19	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	14:11	14:33	0:21	LINE CLEAR AVAILED
19	28-May-19	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	0:10	23:59	23:49	LINE CLEAR AVAILED
20	28-May-19	GULBARGA	220	HUMNABAD-HALBARGA	HALBARGA_220	11:42	12:59	1:17	MAIN SUPPLY FAILURE
21	28-May-19	GULBARGA	220	HV1	SEDAM_220	10:00	13:29	3:29	LINE CLEAR AVAILED
22	28-May-19	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	11:40	11:48	0:08	LINE FAULT
23	28-May-19	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	12:54	13:09	0:15	LINE FAULT
24	28-May-19	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	13:17	13:19	0:02	LINE CLEAR AVAILED
25	28-May-19	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	0:00	6:03	6:03	LINE CLEAR AVAILED
26	28-May-19	GULBARGA	110	KAPNOOR-HUMNABAD1,2	MAHAGOAN_110,MARAGUTTI_110,A LAND_110,KADAGANCHI_110	11:59	12:03	0:04	MAIN SUPPLY FAILURE
27	28-May-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSL SUGAR FACTORY_IPP,CHOWDAPUR_110	11:40	15:10	3:30	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
28	28-May-19	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAWAT_110,VALKAMDINI_110	2:37	2:58	0:21	LINE FAULT
29	28-May-19	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110, HABSIKOTE_110	2:19	2:39	0:20	LINE FAULT
30	28-May-19	GULBARGA	110	HUMNABAD-SASTHAPUR	SASTHAPUR_110	12:00	12:05	0:05	MAIN SUPPLY FAILURE
31	28-May-19	GULBARGA	110	CHITGUPPA-ACMESLR	ACMESLR_IPP	12:18	12:45	0:27	LINE FAULT
32	28-May-19	GULBARGA	110	SEDAM-MALKHED RAILWAY TRACTION	MALKHED RAILWAY STATION	9:57	13:34	3:37	LINE CLEAR AVAILED
33	28-May-19	GULBARGA	110	DHADESUGUR-SINDHANOOR	DHADESUGUR_110,SIRIGUPPA_110,T EKKALAKOTE_110	17:51	18:28	0:37	LINE CLEAR AVAILED
34	28-May-19	GULBARGA	220	KAPNOOR-SHAHPUR	KAPNOOR_220	6:08	15:10	9:02	LINE FAULT
35	28-May-19	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	0:10	23:59	23:49	LINE CLEAR AVAILED
36	28-May-19	GULBARGA	220	HUMNABAD-HALBARGA	HALBARGA_220	11:42	12:59	1:17	MAIN SUPPLY FAILURE
37	28-May-19	GULBARGA	220	HV1	SEDAM_220	10:00	13:29	3:29	LINE CLEAR AVAILED
38	28-May-19	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	11:40	11:48	0:08	LINE FAULT
39	28-May-19	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	12:54	13:09	0:15	LINE FAULT
40	28-May-19	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	13:17	13:19	0:02	LINE CLEAR AVAILED
41	28-May-19	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	0:00	6:03	6:03	LINE CLEAR AVAILED
42	28-May-19	GULBARGA	110	KAPNOOR-HUMNABAD1,2	MAHAGOAN_110,MARAGUTTI_110,A LAND_110,KADAGANCHI_110	11:59	12:03	0:04	MAIN SUPPLY FAILURE
43	28-May-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSL SUGAR FACTORY_IPP,CHOWDAPUR_110	11:40	15:10	3:30	MAIN SUPPLY FAILURE
44	28-May-19	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAWAT_110,VALKAMDINI_110	2:37	2:58	0:21	LINE FAULT
45	28-May-19	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110, HABSIKOTE_110	2:19	2:39	0:20	LINE FAULT
46	28-May-19	GULBARGA	110	HUMNABAD-SASTHAPUR	SASTHAPUR_110	12:00	12:05	0:05	MAIN SUPPLY FAILURE
47	28-May-19	GULBARGA	110	CHITGUPPA-ACMESLR	ACMESLR_IPP	12:18	12:45	0:27	LINE FAULT
48	28-May-19	GULBARGA	110	SEDAM-MALKHED RAILWAY TRACTION	MALKHED RAILWAY STATION	9:57	13:34	3:37	LINE CLEAR AVAILED
49	28-May-19	GULBARGA	110	DHADESUGUR-SINDHANOOR	DHADESUGUR_110,SIRIGUPPA_110,T EKKALAKOTE_110	17:51	18:28	0:37	LINE CLEAR AVAILED
50	28-May-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	9:04	9:04	LINE CLEAR AVAILED
51	28-May-19	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	0:00	19:47	19:47	LINE CLEAR AVAILED
52	28-May-19	HASSAN	220	KADUR-DABUSET	KADUR_220	0:00	20:13	20:13	LINE CLEAR AVAILED
53	28-May-19	HASSAN	220	SHARVTY-SHIRALKOPPA	SHARAVATY_GEN	14:45	17:50	3:05	LINE CLEAR AVAILED
54	28-May-19	HASSAN	220	SHARVTY-TALAGUPPA 2	SHARAVATY_GEN	0:00	19:47	19:47	LINE CLEAR AVAILED
55	28-May-19	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	14:45	17:50	3:05	LINE CLEAR AVAILED
56	28-May-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	9:05	9:17	0:12	LINE CLEAR AVAILED
57	28-May-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:31	12:00	0:29	LINE CLEAR AVAILED
58	28-May-19	HASSAN	110	HV1	HIRIYADKA_110	10:35	11:35	1:00	LINE CLEAR AVAILED
59	28-May-19	HASSAN	110	HV1	KONAJE_110	11:56	12:01	0:05	HAND TRIPPED
60	28-May-19	HASSAN	110	HV1	KONAJE_110	12:53	12:56	0:03	HAND TRIPPED
61	28-May-19	HASSAN	110	HV2	KONAJE_110	11:56	12:01	0:05	HAND TRIPPED
62	28-May-19	HASSAN	110	HV2	KONAJE_110	12:53	12:56	0:03	HAND TRIPPED
63	28-May-19	HASSAN	110	HV3	KONAJE_110	11:56	12:01	0:05	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
64	28-May-19	HASSAN	110	HV3	KONAJE_110	12:53	12:56	0:03	HAND TRIPPED
65	28-May-19	HASSAN	110	HV2	KUNDAPURA_110	14:05	14:15	0:10	HAND TRIPPED
66	28-May-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	12:12	12:46	0:34	LINE CLEAR AVAILED
67	28-May-19	HASSAN	110	SALATHU-R-NTMDNOR	SALATHUR_110	12:15	12:49	0:34	LINE CLEAR AVAILED
68	28-May-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	12:03	16:41	4:38	LINE CLEAR AVAILED
69	28-May-19	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLY_66	10:53	12:40	1:47	LINE FAULT
70	28-May-19	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	10:12	17:06	6:54	LINE CLEAR AVAILED
71	28-May-19	HASSAN	66	HV2	KANDLI_66	11:33	13:02	1:29	LINE CLEAR AVAILED
72	28-May-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	0:33	0:35	0:02	HAND TRIPPED
73	28-May-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	15:58	16:17	0:19	LINE FAULT
74	28-May-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	16:38	16:44	0:06	HAND TRIPPED
75	28-May-19	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	7:26	18:46	11:20	LINE CLEAR AVAILED
76	28-May-19	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	7:26	18:46	11:20	LINE CLEAR AVAILED
77	28-May-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	10:13	10:47	0:34	LINE CLEAR AVAILED
78	28-May-19	HASSAN	66	HV2	SINGAPURA_66	11:30	12:46	1:16	LINE CLEAR AVAILED
79	28-May-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	9:04	9:04	LINE CLEAR AVAILED
80	28-May-19	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	0:00	19:47	19:47	LINE CLEAR AVAILED
81	28-May-19	HASSAN	220	KADUR-DABUSET	KADUR_220	0:00	20:13	20:13	MAIN SUPPLY FAILURE
82	28-May-19	HASSAN	220	SHARVTY-SHIRALKOPPA	SHARAVATY_GEN	14:45	17:50	3:05	LINE CLEAR AVAILED
83	28-May-19	HASSAN	220	SHARVTY-TALAGUPPA 2	SHARAVATY_GEN	0:00	19:47	19:47	LINE CLEAR AVAILED
84	28-May-19	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	14:45	17:50	3:05	LINE CLEAR AVAILED
85	28-May-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	9:05	9:17	0:12	LINE CLEAR AVAILED
86	28-May-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:31	12:00	0:29	LINE CLEAR AVAILED
87	28-May-19	HASSAN	110	HV1	HIRIYADKA_110	10:35	11:35	1:00	LINE CLEAR AVAILED
88	28-May-19	HASSAN	110	HV1	KONAJE_110	11:56	12:01	0:05	HAND TRIPPED
89	28-May-19	HASSAN	110	HV1	KONAJE_110	12:53	12:56	0:03	HAND TRIPPED
90	28-May-19	HASSAN	110	HV2	KONAJE_110	11:56	12:01	0:05	HAND TRIPPED
91	28-May-19	HASSAN	110	HV2	KONAJE_110	12:53	12:56	0:03	HAND TRIPPED
92	28-May-19	HASSAN	110	HV3	KONAJE_110	11:56	12:01	0:05	HAND TRIPPED
93	28-May-19	HASSAN	110	HV3	KONAJE_110	12:53	12:56	0:03	HAND TRIPPED
94	28-May-19	HASSAN	110	HV2	KUNDAPURA_110	14:05	14:15	0:10	HAND TRIPPED
95	28-May-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	12:12	12:46	0:34	LINE CLEAR AVAILED
96	28-May-19	HASSAN	110	SALATHU-R-NTMDNOR	SALATHUR_110	12:15	12:49	0:34	LINE CLEAR AVAILED
97	28-May-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	12:03	16:41	4:38	LINE CLEAR AVAILED
98	28-May-19	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLY_66	10:53	12:40	1:47	LINE FAULT
99	28-May-19	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	10:12	17:06	6:54	LINE CLEAR AVAILED
100	28-May-19	HASSAN	66	HV2	KANDLI_66	11:33	13:02	1:29	LINE CLEAR AVAILED
101	28-May-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	0:33	0:35	0:02	HAND TRIPPED
102	28-May-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	15:58	16:17	0:19	LINE FAULT
103	28-May-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	16:38	16:44	0:06	HAND TRIPPED
104	28-May-19	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	7:26	18:46	11:20	LINE CLEAR AVAILED
105	28-May-19	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	7:26	18:46	11:20	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
106	28-May-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	10:13	10:47	0:34	LINE CLEAR AVAILED
107	28-May-19	HASSAN	66	HV2	SINGAPURA_66	11:30	12:46	1:16	LINE CLEAR AVAILED
108	28-May-19	MYSORE	66	HV2	BGNAGARA_66	18:07	18:33	0:25	LINE CLEAR AVAILED
109	28-May-19	MYSORE	66	HV1	CHIKKA_MANDYA_66	13:00	23:59	10:58	LINE CLEAR AVAILED
110	28-May-19	MYSORE	66	HV2	CHIKKA_MANDYA_66	11:45	12:55	1:10	LINE CLEAR AVAILED
111	28-May-19	MYSORE	66	HV2	HAMPAPURA_66	23:22	23:54	0:32	TRANSFORMER FAULT
112	28-May-19	MYSORE	66	HV1	K_HONNALGERE_66	17:12	17:37	0:24	MAIN SUPPLY FAILURE
113	28-May-19	MYSORE	66	HV2	K_HONNALGERE_66	17:12	17:37	0:24	MAIN SUPPLY FAILURE
114	28-May-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66 CHIKKA_MANDYA_66 , TUMBEKERE_66 MADDUR_66 SOMANAHALLI_66	22:34	22:43	0:09	LINE FAULT
115	28-May-19	MYSORE	66	VAJAMANGALA-MEGALAPURA	MEGALAPURA_66 THUMLA_66 MALIYURU_66 CHIDRAVALI_66	7:51	8:00	0:09	LINE FAULT
116	28-May-19	TUMKUR	110	KB CROSS 220kv- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	10:41	12:47	2:05	LINE CLEAR AVAILED
117	28-May-19	TUMKUR	110	TR-1	KEREKODI_110	11:56	13:47	1:51	LINE CLEAR AVAILED
118	28-May-19	TUMKUR	110	TR-1	MAYASANDRA_110	16:03	17:03	0:59	LINE CLEAR AVAILED
119	28-May-19	TUMKUR	110	TR-2	MAYASANDRA_110	15:14	16:03	0:48	LINE CLEAR AVAILED
120	28-May-19	TUMKUR	110	MAYASANDRA-KB CROSS	MAYASANDRA_110	15:14	16:03	0:48	LINE CLEAR AVAILED
121	28-May-19	TUMKUR	110	TR-2	TIPTUR_110	18:27	18:38	0:11	TRANSFORMER FAULT
122	28-May-19	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	23:00	23:40	0:40	LINE FAULT
123	28-May-19	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	12:13	17:33	5:19	LINE CLEAR AVAILED
124	28-May-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	12:44	14:48	2:04	LINE CLEAR AVAILED
125	28-May-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	16:47	17:16	0:28	LINE CLEAR AVAILED
126	28-May-19	TUMKUR	66	TR-1	KORATAGERE_66	12:54	13:50	0:56	LINE CLEAR AVAILED
127	28-May-19	TUMKUR	66	TR-1	CHANNAGIRI_66	8:46	9:00	0:13	TRANSFORMER FAULT
128	28-May-19	TUMKUR	66	DODDASARANGI-BHAKTHARAHALLI 66	BHAKTHARAHALLI_66,THIMMASANDR A_66	23:16	23:24	0:07	LINE FAULT
129	28-May-19	TUMKUR	66	GUTUR 66-DAVANGERE SRS	GUTUR_66	12:14	12:18	0:04	LINE CLEAR AVAILED
130	28-May-19	TUMKUR	66	TR-2	GUTUR_66	12:14	12:19	0:05	LINE CLEAR AVAILED
131	28-May-19	TUMKUR	66	MADHUGIRI 220kv- SIRA1	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	14:40	14:43	0:02	HAND TRIPPED
132	28-May-19	TUMKUR	66	MADHUGIRI 220kv- SIRA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	14:33	14:43	0:10	HAND TRIPPED
133	28-May-19	TUMKUR	66	MADHUGIRI 220kv- SIRA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	16:46	17:17	0:30	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
134	28-May-19	TUMKUR	110	KB CROSS 220kv- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	10:41	12:47	2:05	LINE CLEAR AVAILED
135	28-May-19	TUMKUR	110	TR-1	KEREKODI_110	11:56	13:47	1:51	LINE CLEAR AVAILED
136	28-May-19	TUMKUR	110	TR-1	MAYASANDRA_110	16:03	17:03	0:59	LINE CLEAR AVAILED
137	28-May-19	TUMKUR	110	TR-2	MAYASANDRA_110	15:14	16:03	0:48	LINE CLEAR AVAILED
138	28-May-19	TUMKUR	110	MAYASANDRA-KB CROSS	MAYASANDRA_110	15:14	16:03	0:48	LINE CLEAR AVAILED
139	28-May-19	TUMKUR	110	TR-2	TIPTUR_110	18:27	18:38	0:11	TRANSFORMER FAULT
140	28-May-19	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	23:00	23:40	0:40	LINE FAULT
141	28-May-19	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	12:13	17:33	5:19	LINE CLEAR AVAILED
142	28-May-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	12:44	14:48	2:04	LINE CLEAR AVAILED
143	28-May-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	16:47	17:16	0:28	LINE CLEAR AVAILED
144	28-May-19	TUMKUR	66	TR-1	KORATAGERE_66	12:54	13:50	0:56	LINE CLEAR AVAILED
145	28-May-19	TUMKUR	66	TR-1	CHANNAGIRI_66	8:46	9:00	0:13	TRANSFORMER FAULT
146	28-May-19	TUMKUR	66	DODDASARANGI-BHAKTHARAHALLI 66	BHAKTHARAHALLI_66,THIMMASANDR A_66	23:16	23:24	0:07	LINE FAULT
147	28-May-19	TUMKUR	66	GUTUR 66-DAVANGERE SRS	GUTUR_66	12:14	12:18	0:04	LINE CLEAR AVAILED
148	28-May-19	TUMKUR	66	TR-2	GUTUR_66	12:14	12:19	0:05	LINE CLEAR AVAILED
149	28-May-19	TUMKUR	66	MADHUGIRI 220kv- SIRA1	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	14:40	14:43	0:02	HAND TRIPPED
150	28-May-19	TUMKUR	66	MADHUGIRI 220kv- SIRA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	14:33	14:43	0:10	HAND TRIPPED
151	28-May-19	TUMKUR	66	MADHUGIRI 220kv- SIRA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	16:46	17:17	0:30	HAND TRIPPED
152	29-May-19	BENGALURU	66	KOLAR 220 - BANGARPET 1	BANGARPET	0:00	2:39	2:39	LINE FAULT
153	29-May-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	5:37	5:51	0:14	LINE FAULT
154	29-May-19	BENGALURU	66	GANJIGUNTE - DIBBURAHALLI	DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	15:34	15:40	0:06	LINE FAULT
155	29-May-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	18:34	19:00	0:26	LINE FAULT
156	29-May-19	BENGALURU	66	HV1	SADALI	6:50	15:45	8:55	TRANSFORMER FAULT
157	29-May-19	BENGALURU	66	HV2	SARJAPURA 220	15:42	16:05	0:23	LINE CLEAR AVAILED
158	29-May-19	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	6:13	7:15	1:02	LINE FAULT
159	29-May-19	BENGALURU	220	HV2	SARJAPURA 220	6:13	6:25	0:12	TRANSFORMER FAULT
160	29-May-19	BENGALURU	66	HV1	SARJAPURA 220	6:13	6:25	0:12	MAIN SUPPLY FAILURE
161	29-May-19	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	11:30	11:45	0:15	LOAD CHANGE OVER
162	29-May-19	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	17:34	18:02	0:28	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
163	29-May-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	5:05	5:39	0:33	LINE FAULT
164	29-May-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	9:17	11:26	2:09	LINE CLEAR AVAILED
165	29-May-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	5:00	5:36	0:36	LINE FAULT
166	29-May-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	5:05	5:39	0:34	LINE FAULT
167	29-May-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	5:39	7:30	1:51	LINE FAULT
168	29-May-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	7:30	11:25	3:55	LINE FAULT
169	29-May-19	BENGALURU	66	HV2	BAIRAKUR	8:11	8:30	0:18	TRANSFORMER FAULT
170	29-May-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGALI	8:11	8:27	0:15	LINE FAULT
171	29-May-19	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	12:14	12:18	0:04	LOAD CHANGE OVER
172	29-May-19	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	7:57	8:05	0:08	LOAD CHANGE OVER
173	29-May-19	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	HONNIGANAHALLI, HALAGUR, DODDALAHALLI	9:22	9:40	0:18	LINE CLEAR AVAILED
174	29-May-19	BENGALURU	66	HV2	MELEHALLI	17:20	17:30	0:10	LINE CLEAR AVAILED
175	29-May-19	BENGALURU	66	HV2	SRS PEENYA 220	16:24	16:59	0:34	TRANSFORMER FAULT
176	29-May-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, K HONALGERE	22:26	22:56	0:29	LINE FAULT
177	29-May-19	BENGALURU	66	TK HALLI 220 - MANDYA 1	MANDYA	22:26	22:47	0:20	LINE FAULT
178	29-May-19	BENGALURU	66	HV2	MAASTHI	6:24	6:38	0:14	TRANSFORMER FAULT
179	29-May-19	GULBARGA	110	HV1,HV2	DHADESUGUR_110	7:30	8:40	1:10	LINE CLEAR AVAILED
180	29-May-19	GULBARGA	110	DHADESUGUR-SINDHANOOR	SINDHANOOR_110	7:30	8:40	1:10	LINE CLEAR AVAILED
181	29-May-19	GULBARGA	110	DHADESUGUR-SIRIGUPPA	SIRIGUPPA_110,TEKKALKOTE_110,DH ADESUGUR_110,NSL SUGAR_IPP	7:30	8:40	1:10	LINE CLEAR AVAILED
182	29-May-19	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	0:00	18:00	18:00	LINE CLEAR AVAILED
183	29-May-19	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	21:15	23:59	2:44	LINE CLEAR AVAILED
184	29-May-19	GULBARGA	110	DHADESUGUR-SINDHANOOR	SINDHANOOR_110	7:30	8:40	1:10	LINE CLEAR AVAILED
185	29-May-19	HASSAN	220	GERUSOP-TALGUPA1	gerusoppa_gen	10:35	14:12	3:37	LINE CLEAR AVAILED
186	29-May-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	10:33	14:23	3:50	LINE CLEAR AVAILED
187	29-May-19	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	22:03	22:22	0:19	LINE CLEAR AVAILED
188	29-May-19	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	22:03	22:22	0:19	LINE CLEAR AVAILED
189	29-May-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	10:35	14:12	3:37	LINE CLEAR AVAILED
190	29-May-19	HASSAN	110	HV1	GAJNUR_110	14:44	21:19	6:35	TRANSFORMER FAULT
191	29-May-19	HASSAN	110	HV1	GAJNUR_110	21:25	21:53	0:28	HAND TRIPPED
192	29-May-19	HASSAN	110	HV2	HOSANGADI_110	9:01	18:06	9:05	LINE CLEAR AVAILED
193	29-May-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	10:44	10:56	0:12	LINE FAULT
194	29-May-19	HASSAN	110	HV1	SHIKARIPURA_110	14:41	18:36	3:55	LINE CLEAR AVAILED
195	29-May-19	HASSAN	66	SAKALE-IPCL1	SAKALESH PURA_66	7:34	18:46	11:12	LINE CLEAR AVAILED
196	29-May-19	HASSAN	66	SAKALE-IPCL2	SAKALESH PURA_66	7:34	18:46	11:12	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
197	29-May-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	0:08	0:16	0:08	TRANSFORMER FAULT
198	29-May-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	0:28	0:44	0:16	TRANSFORMER FAULT
199	29-May-19	MYSORE	66	HV2	HAMPAPURA_66	15:02	15:16	0:13	HAND TRIPPED
200	29-May-19	MYSORE	66	HV1	HEBBAL_66	13:11	23:59	10:48	LINE CLEAR AVAILED
201	29-May-19	MYSORE	66	HV2	HONNALLY_MYS_66	15:25	16:15	0:50	LINE CLEAR AVAILED
202	29-May-19	MYSORE	66	MADDUR-K.HONALGERE	MADDUR_66	0:10	0:11	0:01	HAND TRIPPED
203	29-May-19	MYSORE	66	HV1	MADHUVANAHALLI_220	4:35	4:56	0:21	TRANSFORMER FAULT
204	29-May-19	MYSORE	66	HV2	THALAKADU_66	14:07	14:14	0:06	TRANSFORMER FAULT
205	29-May-19	MYSORE	66	HV1	VAJAMANGALA_220	13:50	15:24	1:34	LINE CLEAR AVAILED
206	29-May-19	MYSORE	66	KM DODDI-TK HALLI	KMDODDI_66 KOLKARANADODDI_66 CHIKKA_MANDYA_66 , TUMBKERE_66 MADDUR_66 SOMANAHALLI_66	22:25	22:47	0:22	LINE FAULT
207	29-May-19	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHARASAPURA 2	ANTHRASANAHALLI_220	6:37	11:13	4:35	LINE FAULT
208	29-May-19	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	9:57	16:43	6:46	LINE CLEAR AVAILED
209	29-May-19	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110	6:59	7:18	0:19	LINE FAULT
210	29-May-19	TUMKUR	110	TR-2	TIPTUR_110	0:30	0:35	0:04	TRANSFORMER FAULT
211	29-May-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:54	16:03	0:08	HAND TRIPPED
212	29-May-19	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	11:06	14:54	3:48	LINE CLEAR AVAILED
213	29-May-19	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	17:05	17:50	0:45	LINE FAULT
214	29-May-19	TUMKUR	66	MADHUGIRI 220kV- SIRA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	7:07	13:56	6:48	LINE FAULT
215	29-May-19	TUMKUR	66	TR-1	MADHUGIRI_220	5:39	7:07	1:28	TRANSFORMER FAULT
216	29-May-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	15:19	15:24	0:05	LINE FAULT
217	29-May-19	TUMKUR	66	TR-1	MAVINAKATTE_66	12:06	14:04	1:57	LINE CLEAR AVAILED
218	29-May-19	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	21:54	22:07	0:12	LINE FAULT
219	29-May-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	7:02	7:23	0:20	LINE FAULT
220	30-May-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, HALASANGI_33, DHULKED_33, NEVARGI_33	6:25	6:42	0:17	TRANSFORMER FAULT
221	30-May-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, HALASANGI_33, DHULKED_33, NEVARGI_33	7:10	7:21	0:11	TRANSFORMER FAULT
222	30-May-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, HALASANGI_33, DHULKED_33, NEVARGI_33	7:33	7:46	0:13	TRANSFORMER FAULT
223	30-May-19	BAGALKOT	110	110/33KV, HV3	ZALKI_110, HORTI_33	15:42	15:45	0:03	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
224	30-May-19	BAGALKOT	110	BAGEWADI220-MAMDAPUR(B)	MAMDAPUR(B)_110, SHIRBUR_110, TODALBAGI_110	20:25	20:40	0:15	MAIN SUPPLY FAILURE
225	30-May-19	BAGALKOT	110	BELGAUM SOLAR-MAMDAPUR(B)	MAMDAPUR(B)_110	20:48	21:22	0:34	LINE CLEAR AVAILED
226	30-May-19	BAGALKOT	110	KARWAR220-BINAGA	BINAGA_LIS	10:15	20:36	10:21	LINE CLEAR AVAILED
227	30-May-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	13:23	23:59	10:36	LINE CLEAR AVAILED
228	30-May-19	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	18:22	18:55	0:33	LINE CLEAR AVAILED
229	30-May-19	BAGALKOT	110	220/110KV, LV3	HUBLI_220, KADANKOPPA_110	9:20	13:46	4:26	LINE CLEAR AVAILED
230	30-May-19	BAGALKOT	110	HUBLI220-KADANKOPPA	KADANKOPPA_110	9:30	13:20	3:50	LINE CLEAR AVAILED
231	30-May-19	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	13:22	23:59	10:37	LINE FAULT
232	30-May-19	BAGALKOT	110	BAGEWADI220-MUDDEB1HAL	MUDDEBIHAL_110	10:39	10:50	0:11	HAND TRIPPED
233	30-May-19	BAGALKOT	110	BAGEWADI220-MUDDEB1HAL	MUDDEBIHAL_110	17:15	17:19	0:04	HAND TRIPPED
234	30-May-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR 1(B)	MAMADAPUR_110	20:20	20:39	0:19	LINE FAULT
235	30-May-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR 2(B)	MAMADAPUR_110	20:20	20:39	0:19	LINE FAULT
236	30-May-19	BENGALURU	66	HV1	CHANDRA LAYOUT	8:32	8:37	0:04	LINE CLEAR AVAILED
237	30-May-19	BENGALURU	66	HV3	YERANDANAHALLI 220	9:15	9:25	0:10	TRANSFORMER FAULT
238	30-May-19	BENGALURU	220	HSR LAYOUT 220 - HOODY 220	HSR LAYOUT 220	2:54	3:16	0:21	LINE FAULT
239	30-May-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1 & 2	ADUGODI, BOSCH (EHT)	2:54	3:16	0:21	MAIN SUPPLY FAILURE
240	30-May-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	2:54	3:16	0:21	MAIN SUPPLY FAILURE
241	30-May-19	BENGALURU	66	HV1	POTTERY ROAD	9:53	10:45	0:51	LINE CLEAR AVAILED
242	30-May-19	BENGALURU	66	HV2	POTTERY ROAD	12:27	13:26	0:59	LINE CLEAR AVAILED
243	30-May-19	BENGALURU	66	HV2	MELEHALLI	12:39	13:01	0:22	LINE CLEAR AVAILED
244	30-May-19	BENGALURU	66	HV1	HAROBEL	20:32	20:43	0:11	TRANSFORMER FAULT
245	30-May-19	BENGALURU	66	HV2	HONNIGANAHALLI	21:05	22:15	1:09	TRANSFORMER FAULT
246	30-May-19	BENGALURU	220	HV2	DB PURA 220	18:01	18:06	0:05	LINE CLEAR AVAILED
247	30-May-19	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	18:01	18:08	0:07	LINE CLEAR AVAILED
248	30-May-19	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	18:01	18:08	0:07	LINE CLEAR AVAILED
249	30-May-19	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	18:01	18:08	0:07	LINE CLEAR AVAILED
250	30-May-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	18:57	19:23	0:26	LINE FAULT
251	30-May-19	BENGALURU	66	HV1	SOMAYAJANAHALLI	12:50	13:00	0:09	LINE CLEAR AVAILED
252	30-May-19	BENGALURU	66	HV2	TUBUGERE	16:15	16:30	0:15	LINE CLEAR AVAILED
253	30-May-19	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	13:22	13:44	0:22	HAND TRIPPED
254	30-May-19	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	0:00	16:37	16:37	LINE CLEAR AVAILED
255	30-May-19	GULBARGA	220	HV1,HV2	HALBARGA_220	14:03	14:24	0:21	TRANSFORMER FAULT
256	30-May-19	GULBARGA	220	HV1,HV2	HALBARGA_220	17:02	18:00	0:58	TRANSFORMER FAULT
257	30-May-19	GULBARGA	220	ITTAGGI-NEELANGUNDA	NEELANGUNDA_220	18:37	23:59	5:22	LINE CLEAR AVAILED
258	30-May-19	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	5:45	8:33	2:48	LINE CLEAR AVAILED
259	30-May-19	GULBARGA	110	SINDNOOR-MASKI	MASKI_110	0:34	0:39	0:05	LINE FAULT
260	30-May-19	GULBARGA	110	MASKI-HATTI	HATTI_110	0:34	17:40	17:06	LINE FAULT
261	30-May-19	GULBARGA	110	MALLT-BYGWT-1	BYAGAWAT_110	21:20	21:25	0:05	LINE FAULT



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
262	30-May-19	GULBARGA	110	MALLT-BYGWT-2	MADALAPURA_110,MANVI_110	22:55	23:05	0:10	LINE FAULT
263	30-May-19	GULBARGA	110	HALBARGA-CHIDRI2	KAMTHANA_110, HABSIKOTE_110	14:03	23:59	9:56	LINE FAULT
264	30-May-19	GULBARGA	110	HALBARGA-KOLHAR1	JANAWADA_110,KOLHAR_110,NSSK SUGAR FACTORY_IPP	17:02	20:58	3:56	LINE FAULT
265	30-May-19	GULBARGA	110	HALBARGA-KOLHAR2	JANAWADA_110,KOLHAR_110,NSSK SUGAR FACTORY_IPP	17:02	23:59	6:57	LINE FAULT
266	30-May-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	16:45	18:35	1:50	LINE FAULT
267	30-May-19	GULBARGA	110	SINDHANOOR-RAICHUR2	VALKAMDINNI_110,MANVI_110	17:35	18:08	0:33	LINE FAULT
268	30-May-19	GULBARGA	110	SINDHANNO-FUTURE1	TURVIHAL_110	22:20	22:35	0:15	LINE FAULT
269	30-May-19	GULBARGA	110	HV2	CHITGUPPA_110	17:41	17:52	0:11	TRANSFORMER FAULT
270	30-May-19	GULBARGA	110	HV1	CHITGUPPA_110	17:55	18:15	0:20	TRANSFORMER FAULT
271	30-May-19	HASSAN	220	GESOPA-STRP1	gerusoppa_gen	6:17	11:06	4:49	LINE CLEAR AVAILED
272	30-May-19	HASSAN	220	GESOPA-STRP2	gerusoppa_gen	6:23	10:55	4:32	LINE CLEAR AVAILED
273	30-May-19	HASSAN	220	MRSSHM-STRP1	MRSMG_220	6:17	11:07	4:50	LINE CLEAR AVAILED
274	30-May-19	HASSAN	220	HV1	SHIRALKOPPA_220	14:53	17:13	2:20	TRANSFORMER FAULT
275	30-May-19	HASSAN	220	HV1	SHIRALKOPPA_220	17:40	17:52	0:12	TRANSFORMER FAULT
276	30-May-19	HASSAN	220	HV1	SHIRALKOPPA_220	18:02	23:59	5:57	TRANSFORMER FAULT
277	30-May-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	6:23	10:56	4:33	LINE CLEAR AVAILED
278	30-May-19	HASSAN	110	LV1	SHIRALKOPPA_220	14:53	17:13	2:20	TRANSFORMER FAULT
279	30-May-19	HASSAN	110	LV1	SHIRALKOPPA_220	17:40	17:52	0:12	TRANSFORMER FAULT
280	30-May-19	HASSAN	110	LV1	SHIRALKOPPA_220	18:02	23:59	5:57	TRANSFORMER FAULT
281	30-May-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	14:13	14:23	0:10	LINE FAULT
282	30-May-19	HASSAN	110	HV1	PUTTUR_110	10:18	11:13	0:55	LINE CLEAR AVAILED
283	30-May-19	HASSAN	110	HV2	PUTTUR_110	11:50	15:46	3:56	LINE CLEAR AVAILED
284	30-May-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	14:10	14:20	0:10	MAIN SUPPLY FAILURE
285	30-May-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	21:20	22:30	1:10	LINE CLEAR AVAILED
286	30-May-19	HASSAN	110	HV2	BARANGI_110	9:26	12:02	2:36	LINE CLEAR AVAILED
287	30-May-19	HASSAN	110	HV1	GAJANUR_110	16:17	16:54	0:37	LINE CLEAR AVAILED
288	30-May-19	HASSAN	110	HV2	SHIKARIPURA_110	14:06	18:32	4:26	LINE CLEAR AVAILED
289	30-May-19	HASSAN	66	HV1	BYACHANAHALLY_66	10:15	10:20	0:05	LINE CLEAR AVAILED
290	30-May-19	HASSAN	66	HV1	GENDEHALLY_66	12:05	12:32	0:27	LINE CLEAR AVAILED
291	30-May-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	18:45	18:49	0:04	LINE FAULT
292	30-May-19	HASSAN	66	HV2	KANDLI_66	11:35	12:44	1:09	LINE CLEAR AVAILED
293	30-May-19	HASSAN	66	HV2	KANDLI_66	15:36	17:06	1:30	LINE CLEAR AVAILED
294	30-May-19	HASSAN	66	SAKALE-IPCL1	SAKLESHAPURA_66	7:20	19:04	11:44	LINE CLEAR AVAILED
295	30-May-19	HASSAN	66	SAKALE-IPCL2	SAKLESHAPURA_66	7:20	19:04	11:44	LINE CLEAR AVAILED
296	30-May-19	HASSAN	66	HV2	SINGAPURA_66	11:00	16:41	5:41	LINE CLEAR AVAILED
297	30-May-19	MYSORE	66	HV1	KHBCOLONY_66	10:33	10:55	0:21	LINE CLEAR AVAILED
298	30-May-19	MYSORE	66	HV1	KHBCOLONY_66	13:11	14:38	1:27	LINE CLEAR AVAILED
299	30-May-19	MYSORE	66	HV2	THALAKADU_66	14:13	14:18	0:05	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
300	30-May-19	MYSORE	66	TUBINKERE-MANDYA2	MANDYA_66 CHIKKA_MANDYA_66 MALAVALLI_66 HADLI_66 KADKOTHANALLY_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66	22:48	23:01	0:13	LINE FAULT
301	30-May-19	MYSORE	66	TUBINKERE-MANDYA4	MANDYA_66 CHIKKA_MANDYA_66 MALAVALLI_66 HADLI_66 KADKOTHANALLY_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66	22:48	23:01	0:13	LINE FAULT
302	30-May-19	MYSORE	66	TUBINKERE-NAGAMANGLA 2	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 KESLAGERE_66 VADERALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 SHIVALLY_66	22:38	22:44	0:06	LINE FAULT
303	30-May-19	TUMKUR	220	TR-3	HIRIYUR_220	19:18	20:04	0:45	TRANSFORMER FAULT
304	30-May-19	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	8:54	10:17	1:22	LINE CLEAR AVAILED
305	30-May-19	TUMKUR	110	SHETTIKERE- HANDANKERE	SHETYKERE_110	21:47	22:30	0:42	HAND TRIPPED
306	30-May-19	TUMKUR	66	TR-2	BENKIKERE_66	12:53	13:03	0:09	TRANSFORMER FAULT
307	30-May-19	TUMKUR	66	CHITRADURGA 66kV- DAVANAGERE2	CHITRADURGA_66	12:49	13:03	0:14	LINE FAULT
308	30-May-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	12:49	12:59	0:10	LINE FAULT
309	30-May-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 1_IPP_66	12:49	13:01	0:11	LINE FAULT
310	30-May-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:11	13:27	0:15	LINE FAULT
311	30-May-19	TUMKUR	66	TR-2	GARAGA_66	16:30	16:47	0:16	TRANSFORMER FAULT
312	30-May-19	TUMKUR	66	TR-1 & TR-2(HV SIDE )	HONNALLI_220	8:50	9:01	0:10	MAIN SUPPLY FAILURE
313	30-May-19	TUMKUR	66	TR-1 & TR-2(LV SIDE )	HONNALLI_220	8:56	9:00	0:03	MAIN SUPPLY FAILURE
314	30-May-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	8:52	9:01	0:08	MAIN SUPPLY FAILURE
315	30-May-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	8:52	9:11	0:19	MAIN SUPPLY FAILURE
316	30-May-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	8:50	8:59	0:08	MAIN SUPPLY FAILURE
317	30-May-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	8:50	9:01	0:10	MAIN SUPPLY FAILURE
318	30-May-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:40	12:53	0:12	LINE CLEAR AVAILED
319	30-May-19	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	13:35	13:38	0:03	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
320	30-May-19	TUMKUR	66	TR-1	KUNDUR_66	13:34	14:46	1:11	LINE CLEAR AVAILED
321	30-May-19	TUMKUR	66	NEELAGUNDA 220kV-HARAPPANAHALLI	HARAPPANAHALLI_66	19:13	19:57	0:43	LINE FAULT
322	30-May-19	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	19:19	19:26	0:07	HAND TRIPPED
323	30-May-19	TUMKUR	66	TR-2(LV SIDE)	NEELAGUNDA_220	19:13	19:26	0:12	TRANSFORMER FAULT
324	30-May-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJIHALLI_66	19:19	19:27	0:07	HAND TRIPPED
325	31-May-19	BAGALKOT	110	GADAG220-ANNIGERI	ANNIGERI_110	12:00	14:01	2:01	LINE CLEAR AVAILED
326	31-May-19	BAGALKOT	110	110/11KV,HV3	BIJAPUR CITY_110	11:23	11:30	0:07	HAND TRIPPED
327	31-May-19	BAGALKOT	220	220/110KV,HV1&LV1	GHATAPRABHA_220	15:16	15:55	0:39	LINE CLEAR AVAILED
328	31-May-19	BAGALKOT	110	GHATAPRABHA 220-GHATAPRABHA 2	GHATAPRABHA_110	14:33	17:18	2:45	LINE FAULT
329	31-May-19	BAGALKOT	110	KARWAR220-BINAGA	BINAGA_110_EHT	14:12	14:16	0:04	HAND TRIPPED
330	31-May-19	BAGALKOT	220	BAGEWADI-BIJAPUR 2	BAGEWADI_220	9:03	15:54	6:51	LINE CLEAR AVAILED
331	31-May-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALSANGI_33KV,NEVARGI_33KV,DHULKED_33KV	6:21	6:46	0:25	TRANSFORMER FAULT
332	31-May-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALSANGI_33KV,NEVARGI_33KV,DHULKED_33KV	6:57	7:00	0:03	TRANSFORMER FAULT
333	31-May-19	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	VAJRAMATTI_220	20:05	20:47	0:42	LINE FAULT
334	31-May-19	BAGALKOT	110	SOUDATTI220-SOUDATTI1	SOUDATTI_110	9:07	11:17	2:10	LINE CLEAR AVAILED
335	31-May-19	BAGALKOT	110	SOUDATTI220-RAMDURGA1	RAMDURGA_110	9:08	11:15	2:07	LINE CLEAR AVAILED
336	31-May-19	BAGALKOT	220	RANEBENNUR-BALLIGAVI(SHIROLKOPPA)	RANEBENNUR_220	10:37	23:59	13:22	LINE CLEAR AVAILED
337	31-May-19	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	11:12	11:15	0:03	HAND TRIPPED
338	31-May-19	BAGALKOT	110	110/11KV,HV2	KULIGOD_110	16:08	16:55	0:47	LINE CLEAR AVAILED
339	31-May-19	BAGALKOT	110	110/11KV,HV2	NAVANAGAR(B)_110	21:10	21:22	0:12	TRANSFORMER FAULT
340	31-May-19	BAGALKOT	110	110/11KV,HV2	PG HUNSHYAL_110	17:10	17:36	0:26	LINE CLEAR AVAILED
341	31-May-19	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	23:52	23:59	0:07	LINE FAULT
342	31-May-19	BENGALURU	66	HOODY 220 - ITI	ITI	18:31	19:05	0:34	LINE FAULT
343	31-May-19	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	18:31	19:11	0:40	LINE FAULT
344	31-May-19	BENGALURU	66	ITI - HEBBAL	BANASWADI	6:22	6:37	0:15	LINE CLEAR AVAILED
345	31-May-19	BENGALURU	66	ITI - HEBBAL	BANASWADI	12:20	14:16	1:55	LINE CLEAR AVAILED
346	31-May-19	BENGALURU	220	LV2	HSR LAYOUT 220	11:01	11:11	0:09	TRANSFORMER FAULT
347	31-May-19	BENGALURU	66	HV2	KADUGODI	7:59	8:27	0:28	TRANSFORMER FAULT
348	31-May-19	BENGALURU	220	HV2	HSR LAYOUT 220	11:01	11:10	0:08	TRANSFORMER FAULT
349	31-May-19	BENGALURU	66	HV1	TK HALLI 220	17:33	17:41	0:07	TRANSFORMER FAULT
350	31-May-19	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	18:30	19:13	0:43	MAIN SUPPLY FAILURE
351	31-May-19	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	18:30	19:13	0:43	MAIN SUPPLY FAILURE
352	31-May-19	BENGALURU	66	AVANI - KOLAR 220	AVANI, MULBAGAL	17:12	17:31	0:19	LINE FAULT
353	31-May-19	BENGALURU	66	BAGHMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	5:44	6:26	0:41	LINE FAULT
354	31-May-19	BENGALURU	66	BAGHMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	12:14	14:12	1:57	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
355	31-May-19	BENGALURU	66	HV2	BAGHMANE WORLD TECH PARK	13:01	13:16	0:15	TRANSFORMER FAULT
356	31-May-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	15:27	15:37	0:09	LINE FAULT
357	31-May-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	13:40	13:46	0:05	LINE FAULT
358	31-May-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	16:03	16:08	0:05	LINE FAULT
359	31-May-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA, Y HUNSENAHALLI	7:49	8:00	0:10	LINE FAULT
360	31-May-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	18:30	18:50	0:19	MAIN SUPPLY FAILURE
361	31-May-19	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRGAMPALLI, M GOLLAHALLI	18:30	18:50	0:19	MAIN SUPPLY FAILURE
362	31-May-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	18:30	18:50	0:19	MAIN SUPPLY FAILURE
363	31-May-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	18:30	18:50	0:19	MAIN SUPPLY FAILURE
364	31-May-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	18:30	18:50	0:19	MAIN SUPPLY FAILURE
365	31-May-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	SRINIVASPURA, KODIHALLI, YELDUR	18:30	18:50	0:19	MAIN SUPPLY FAILURE
366	31-May-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	18:30	18:50	0:19	MAIN SUPPLY FAILURE
367	31-May-19	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66, SM MANGALA	18:30	18:50	0:19	MAIN SUPPLY FAILURE
368	31-May-19	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	18:30	18:50	0:19	MAIN SUPPLY FAILURE
369	31-May-19	BENGALURU	220	CHINTAMANI 220 - PGCIL 1 & 2	CHINTAMANI 220	18:30	18:45	0:14	MAIN SUPPLY FAILURE
370	31-May-19	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHAPURA	23:49	23:59	0:09	LINE FAULT
371	31-May-19	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	19:26	19:40	0:14	LINE FAULT
372	31-May-19	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 2 (EHT)	RVNL (EHT)	23:57	23:59	0:02	LINE FAULT
373	31-May-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	12:01	12:13	0:12	LINE FAULT
374	31-May-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	17:04	17:44	0:40	LINE FAULT
375	31-May-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	17:04	17:44	0:40	LINE FAULT
376	31-May-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	17:22	17:43	0:20	LINE FAULT
377	31-May-19	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	16:44	17:02	0:18	LINE FAULT
378	31-May-19	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	16:53	17:46	0:53	LINE FAULT
379	31-May-19	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	16:53	17:46	0:53	LINE FAULT
380	31-May-19	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	12:44	13:25	0:41	LINE FAULT
381	31-May-19	BENGALURU	66	JIGANI 66 - BG ROAD	JIGANI 66	14:54	15:52	0:57	LINE CLEAR AVAILED
382	31-May-19	BENGALURU	66	HV2	JANGAMAKOTE	22:42	23:10	0:27	TRANSFORMER FAULT
383	31-May-19	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	14:22	14:36	0:13	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
384	31-May-19	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	18:30	18:59	0:29	MAIN SUPPLY FAILURE
385	31-May-19	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	18:30	18:50	0:19	MAIN SUPPLY FAILURE
386	31-May-19	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	18:30	18:50	0:19	MAIN SUPPLY FAILURE
387	31-May-19	BENGALURU	220	KOLAR 220 - RAILWAYS 1 & 2 (EHT)	BANGARPET RAILWAYS (EHT)	18:30	18:50	0:19	MAIN SUPPLY FAILURE
388	31-May-19	BENGALURU	220	KOLAR 220 - PGCIL 1 & 2	KOLAR 220	18:30	18:50	0:19	MAIN SUPPLY FAILURE
389	31-May-19	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR	18:30	18:59	0:29	MAIN SUPPLY FAILURE
390	31-May-19	BENGALURU	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	18:30	18:59	0:29	MAIN SUPPLY FAILURE
391	31-May-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	18:30	18:59	0:29	MAIN SUPPLY FAILURE
392	31-May-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	18:30	18:59	0:29	MAIN SUPPLY FAILURE
393	31-May-19	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	18:30	18:59	0:29	MAIN SUPPLY FAILURE
394	31-May-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	18:30	19:00	0:29	MAIN SUPPLY FAILURE
395	31-May-19	BENGALURU	66	KOLAR 220 - NARASAPURA 2	MALUR I/A, JADIGENAHALLI	18:30	19:00	0:29	MAIN SUPPLY FAILURE
396	31-May-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGALI	17:01	17:46	0:45	LINE CLEAR AVAILED
397	31-May-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	11:15	12:10	0:55	LINE CLEAR AVAILED
398	31-May-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	18:30	19:14	0:44	LINE FAULT
399	31-May-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	18:30	19:13	0:42	MAIN SUPPLY FAILURE
400	31-May-19	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, BUDHIKOTE, TEKAL, KAMASAMUDRA, KYASAMBALLI, DODDAKARI, ANDERSONPET, BEML(EHT)	18:30	19:13	0:42	MAIN SUPPLY FAILURE
401	31-May-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	18:30	19:13	0:42	MAIN SUPPLY FAILURE
402	31-May-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	18:30	19:13	0:43	MAIN SUPPLY FAILURE
403	31-May-19	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	18:30	19:13	0:42	MAIN SUPPLY FAILURE
404	31-May-19	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	18:30	19:13	0:42	MAIN SUPPLY FAILURE
405	31-May-19	BENGALURU	220	HV1	SARJAPURA 220	12:03	12:43	0:40	LINE CLEAR AVAILED
406	31-May-19	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	12:03	12:43	0:40	LINE CLEAR AVAILED
407	31-May-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:03	12:43	0:40	LINE CLEAR AVAILED
408	31-May-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:03	12:43	0:40	LINE CLEAR AVAILED
409	31-May-19	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	18:30	19:15	0:44	MAIN SUPPLY FAILURE
410	31-May-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	18:30	19:15	0:44	MAIN SUPPLY FAILURE
411	31-May-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	18:30	19:15	0:44	MAIN SUPPLY FAILURE
412	31-May-19	BENGALURU	66	HV2	NRS 220	23:52	0:18	0:24	MAIN SUPPLY FAILURE
413	31-May-19	GULBARGA	220	BMMISPAT-ITTAGGI	ITTAGI_220	20:02	21:51	1:49	LINE FAULT
414	31-May-19	GULBARGA	220	HV1	ITTAGI_220	20:02	21:59	1:57	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
415	31-May-19	GULBARGA	110	PDHALLI-ALIPURA	PDHALLI_110	0:31	1:04	0:33	LINE FAULT
416	31-May-19	GULBARGA	110	PDHALLI-JANAKI_IPP	PDHALLI_110	0:20	0:31	0:11	LINE FAULT
417	31-May-19	GULBARGA	110	KOLHAR-SHAHISOLAR_IPP	KOLHAR_110	9:56	14:11	4:15	LINE CLEAR AVAILED
418	31-May-19	GULBARGA	110	HV1	HATTI_110	12:45	13:05	0:20	TRANSFORMER FAULT
419	31-May-19	GULBARGA	110	HV1	GULUNI_110	13:25	14:43	1:18	TRANSFORMER FAULT
420	31-May-19	GULBARGA	110	SHAHPUR220-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR_IPP	3:37	3:52	0:15	LINE FAULT
421	31-May-19	GULBARGA	110	HALBARGA-KOLHAR2	JANAWADA_110,KOLHAR_110,NSSK SUGAR FACTORY_IPP	0:00	14:07	14:07	LINE FAULT
422	31-May-19	GULBARGA	110	HALBARGA-CHIDRI2	KAMTHANA_110, HABSIKOTE_110	0:00	15:10	15:10	LINE FAULT
423	31-May-19	GULBARGA	110	HALBARGA-CHIDRI2	KAMTHANA_110, HABSIKOTE_110	15:31	23:59	8:28	LINE CLEAR AVAILED
424	31-May-19	GULBARGA	110	LV2	ITTAGI_220	20:02	22:03	2:01	TRANSFORMER FAULT
425	31-May-19	GULBARGA	110	HALBARGA-KOLHAR2	JANAWADA_110,KOLHAR_110,NSSK SUGAR FACTORY_IPP	18:25	18:39	0:14	LINE FAULT
426	31-May-19	GULBARGA	110	HALBARGA-KOLHAR2	JANAWADA_110,KOLHAR_110,NSSK SUGAR FACTORY_IPP	19:51	23:59	4:08	LINE FAULT
427	31-May-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARAGUTTI_110	23:48	23:55	0:07	LINE FAULT
428	31-May-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	18:34	18:44	0:10	LINE FAULT
429	31-May-19	GULBARGA	110	MASKI-RENEWSOLAR	MASKI_110	18:34	19:20	0:46	LINE FAULT
430	31-May-19	GULBARGA	66	ITTAGGI-HBHALLI	HAGARIBOMMANAHALLI_66	19:52	22:20	2:28	LINE FAULT
431	31-May-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	22:25	23:59	1:34	LINE CLEAR AVAILED
432	31-May-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	22:41	23:59	1:18	LINE CLEAR AVAILED
433	31-May-19	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	7:45	13:42	5:57	LINE CLEAR AVAILED
434	31-May-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	22:26	23:59	1:33	LINE CLEAR AVAILED
435	31-May-19	HASSAN	220	HV1	SHIRALKOPPA_220	17:40	17:58	0:18	TRANSFORMER FAULT
436	31-May-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	22:41	23:59	1:18	LINE CLEAR AVAILED
437	31-May-19	HASSAN	110	HV2	BAIKAMPADY_110	0:00	14:50	14:50	LINE CLEAR AVAILED
438	31-May-19	HASSAN	110	HV1	SHIKARIPURA_110	14:40	18:10	3:30	LINE CLEAR AVAILED
439	31-May-19	HASSAN	110	LV1	SHIRALKOPPA_220	17:40	17:58	0:18	TRANSFORMER FAULT
440	31-May-19	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	17:59	18:05	0:06	HAND TRIPPED
441	31-May-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	18:14	18:20	0:06	HAND TRIPPED
442	31-May-19	HASSAN	110	SORABA-SAGARA1	SORABA_110	10:30	10:45	0:15	MAIN SUPPLY FAILURE
443	31-May-19	HASSAN	110	SORABA-SAGARA1	SORABA_110	19:30	19:45	0:15	HAND TRIPPED
444	31-May-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	13:55	14:00	0:05	LINE FAULT
445	31-May-19	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLY_66	10:06	12:30	2:24	LINE CLEAR AVAILED
446	31-May-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	0:01	0:06	0:05	LINE FAULT
447	31-May-19	HASSAN	66	HV2	KANDLI_66	11:07	12:36	1:29	LINE CLEAR AVAILED
448	31-May-19	HASSAN	66	SAKALE-IPCL1	SAKLESHAPURA_66	7:30	19:35	12:05	LINE CLEAR AVAILED
449	31-May-19	HASSAN	66	SAKALE-IPCL2	SAKLESHAPURA_66	7:30	19:35	12:05	LINE CLEAR AVAILED
450	31-May-19	HASSAN	66	HV1	SATHENAHALLY_66	23:46	23:50	0:04	TRANSFORMER FAULT
451	31-May-19	HASSAN	66	HV2	SHANTHIGRAMA_66	12:21	17:54	5:33	LINE CLEAR AVAILED
452	31-May-19	HASSAN	66	HV1	CHANNARAYAPATNA_66	10:31	18:47	8:16	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
453	31-May-19	MYSORE	66	BOOKANKERE-PANDAVA PURA	CHINAKURALI_66 BANANGADI_66	22:36	22:58	0:22	LINE FAULT
454	31-May-19	MYSORE	66	BOOKANKERE-PANDAVA PURA	CHINAKURALI_66 BANANGADI_66	23:00	23:17	0:17	LINE FAULT
455	31-May-19	MYSORE	66	HAMPAPURA-BASARALU	KOPPA_66 BESAGARAHALLI_66	21:19	21:24	0:05	LINE FAULT
456	31-May-19	MYSORE	66	HV2	HAMPAPURA_66	21:40	22:00	0:19	TRANSFORMER FAULT
457	31-May-19	MYSORE	66	HOOTAGALLY-ELWALA	ELAVALA_66 GAVADAGERE_66	23:04	23:32	0:27	LINE FAULT
458	31-May-19	MYSORE	66	JAKKANALLY-NAGMANGLA	G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI MANDYA_66 NAGAMANGALA_66	21:25	21:32	0:06	LINE FAULT
459	31-May-19	MYSORE	66	HV1	KRNAGARA_66	13:41	13:51	0:09	TRANSFORMER FAULT
460	31-May-19	MYSORE	66	KR PETE 220KV-BOOKANKERE	SHEELUNERE_66 GANJIGERE_66 BOOKANAKERE_66 CHINAKURALI_66 BANANGADI_66	22:40	22:54	0:14	LINE FAULT
461	31-May-19	MYSORE	66	KR PETE 220KV-MADESWARAPURA	G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI MANDYA_66 NAGAMANGALA_66 JAKKANAHALLY,MADESWARAPURA,	22:08	22:18	0:09	LINE FAULT
462	31-May-19	MYSORE	66	KUSHALNAGARA 220-MYSORE-1	BHERYA_66 MIRLE_66 KRNAGARA_66BILIKERE_66 GVGUDI_66	6:25	6:44	0:18	LINE FAULT
463	31-May-19	MYSORE	66	HV2	SALIGRAMA_66	12:40	12:50	0:10	TRANSFORMER FAULT
464	31-May-19	MYSORE	66	HV2	SALIGRAMA_66	16:10	19:03	2:53	LINE CLEAR AVAILED
465	31-May-19	MYSORE	66	HV5	SFCSHIVA_66	8:20	12:13	3:53	LINE CLEAR AVAILED
466	31-May-19	MYSORE	66	HV5	SFCSHIVA_66	18:12	23:59	5:46	LINE CLEAR AVAILED
467	31-May-19	MYSORE	66	HV6	SFCSHIVA_66	4:10	12:06	7:56	TRANSFORMER FAULT
468	31-May-19	MYSORE	66	TUBINKERE-MANDYA 2	MANDYA_66 CHIKKA_MANDYA_66 MALAVALLI_66 HADLI_66 KADKOTHANALLY_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66	21:59	22:59	1:00	LINE FAULT
469	31-May-19	MYSORE	66	TUBINKERE-NAGAMANGALA 2	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 KESLAGERE_66 VADERALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 SHIVALLY_66	21:25	21:33	0:07	LINE FAULT
470	31-May-19	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11	14:07	3:55	LINE CLEAR AVAILED
471	31-May-19	TUMKUR	110	TR-1	GUBBI_110	10:58	11:04	0:05	TRANSFORMER FAULT
472	31-May-19	TUMKUR	110	KB CROSS 220kv- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	20:00	20:34	0:33	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
473	31-May-19	TUMKUR	110	TR-1	KEREKODI_110	20:45	22:57	2:12	TRANSFORMER FAULT
474	31-May-19	TUMKUR	110	KEREKODI-HONNAVALLI 110	KEREKODI_110	22:39	22:57	0:18	HAND TRIPPED
475	31-May-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	18:29	20:49	2:20	LINE FAULT
476	31-May-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:17	16:27	0:10	LINE FAULT
477	31-May-19	TUMKUR	66	TR-2	KUNIGAL_66	20:14	21:01	0:47	TRANSFORMER FAULT
478	31-May-19	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	KALLAMBELLA_66, BUKKAPATNA_66	20:22	20:32	0:09	LINE FAULT
479	31-May-19	TUMKUR	66	MADHUGIRI 220kv- SIRA 1	GULIGENAHALLI_66,SIRA_66	20:22	20:31	0:08	LINE FAULT
480	31-May-19	TUMKUR	66	SIRA- MADHUGIRI 1	SIRA_66	18:45	19:01	0:15	LINE FAULT
481	31-May-19	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	20:32	21:35	1:03	LINE FAULT
482	31-May-19	TUMKUR	66	TR-2	THIMMASANDRA_66	7:00	7:09	0:09	TRANSFORMER FAULT
483	1-Jun-19	BAGALKOT	110	110/11KV,HV2	AREMALLAPUR_110	22:11	22:22	0:11	MAIN SUPPLY FAILURE
484	1-Jun-19	BAGALKOT	110	110/33KV,HV3	BAGALKOT_220, KATAGERI_33	22:11	22:19	0:08	MAIN SUPPLY FAILURE
485	1-Jun-19	BAGALKOT	110	110/11KV,HV3	JAMBAGI_110	9:00	9:20	0:20	LINE CLEAR AVAILED
486	1-Jun-19	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	17:07	17:35	0:28	LINE CLEAR AVAILED
487	1-Jun-19	BAGALKOT	110	110/11KV,HV2	KALGHATAGI_110	8:50	8:57	0:07	TRANSFORMER FAULT
488	1-Jun-19	BAGALKOT	110	110/11KV,HV3	KULIGOD_110, ARLIMATTI_33,TIGADI_33	22:11	22:30	0:19	MAIN SUPPLY FAILURE
489	1-Jun-19	BAGALKOT	110	110/11KV,HV1	MUKARTIHAL_110	13:42	13:50	0:08	TRANSFORMER FAULT
490	1-Jun-19	BAGALKOT	110	110/11KV,HV1	RAIBAG_110	22:11	22:17	0:06	MAIN SUPPLY FAILURE
491	1-Jun-19	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	8:50	8:54	0:04	HAND TRIPPED
492	1-Jun-19	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	19:52	19:58	0:06	TRANSFORMER FAULT
493	1-Jun-19	BAGALKOT	220	220/110KV,HV1	RANEBENNUR_220, HIREKERUR_110, GUTTUR_110, HONNATTI_110	14:28	14:40	0:12	TRANSFORMER FAULT
494	1-Jun-19	BAGALKOT	110	110/11KV,HV5	RANEBENNUR_220	14:27	14:42	0:15	TRANSFORMER FAULT
495	1-Jun-19	BAGALKOT	110	110/33KV,HV3	RANEBENNUR_220, HALAGERI_33,GUDURMAIDUR_33	22:12	22:45	0:33	MAIN SUPPLY FAILURE
496	1-Jun-19	BAGALKOT	220	RANEBENNUR-BALLIGAVI(SHIROLKOPPA)	RANEBENNUR_220	0:00	19:07	19:07	LINE CLEAR AVAILED
497	1-Jun-19	BAGALKOT	110	SIRSI-KUMTA1	SIRSI_110	3:42	15:45	12:03	LINE FAULT
498	1-Jun-19	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	13:00	15:45	2:45	NFBC ISSUED
499	1-Jun-19	BAGALKOT	110	MMCL-SOUDATTI220	SOUDATTI_220	12:47	17:35	4:48	LINE CLEAR AVAILED
500	1-Jun-19	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	16:59	18:49	1:50	LINE FAULT
501	1-Jun-19	BAGALKOT	66	66/33KV, HV4	HARIHAR-HOSPET_66	22:40	23:59	1:19	MAIN SUPPLY FAILURE
502	1-Jun-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33KV,DHULKED_33KV,HALASANGI_33KV	23:02	23:11	0:09	TRANSFORMER FAULT
503	1-Jun-19	BAGALKOT	110	110/11KV,HV3	YARAGATTI_110	22:10	22:17	0:07	MAIN SUPPLY FAILURE



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
504	1-Jun-19	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	22:40	22:46	0:06	MAIN SUPPLY FAILURE
505	1-Jun-19	BAGALKOT	110	110/11KV,HV2	TILUVALI_110	22:11	22:22	0:11	MAIN SUPPLY FAILURE
506	1-Jun-19	BAGALKOT	110	110/11KV,HV1	SALAHALLI_110	22:10	22:22	0:12	MAIN SUPPLY FAILURE
507	1-Jun-19	BAGALKOT	110	110/11KV,HV1	MUNDAGANUR_110	22:40	22:44	0:04	MAIN SUPPLY FAILURE
508	1-Jun-19	BAGALKOT	110	110/11KV,HV1	LAKAMANAHALLI_110	22:10	22:40	0:30	MAIN SUPPLY FAILURE
509	1-Jun-19	BAGALKOT	110	110/11KV,HV1	HANGAL_110,PALA_33KV,BOMMANA HALLI_33KV	22:10	22:18	0:08	MAIN SUPPLY FAILURE
510	1-Jun-19	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	22:10	22:20	0:10	MAIN SUPPLY FAILURE
511	1-Jun-19	BENGALURU	66	HV2	AMARJYOTHI	9:05	10:15	1:10	MAIN SUPPLY FAILURE
512	1-Jun-19	BENGALURU	66	HV1	AMARJYOTHI	9:48	9:53	0:05	MAIN SUPPLY FAILURE
513	1-Jun-19	BENGALURU	66	HV2	AMARJYOTHI	11:51	11:55	0:04	LINE CLEAR AVAILED
514	1-Jun-19	BENGALURU	66	HV3	ADUGODI	9:05	9:53	0:48	LINE CLEAR AVAILED
515	1-Jun-19	BENGALURU	66	ADUGODI - HSR LAYOUT 1 & 2	ADUGODI, BOSCH (EHT)	9:48	9:53	0:05	LOAD CHANGE OVER
516	1-Jun-19	BENGALURU	66	HV3	ADUGODI	15:10	15:20	0:10	LINE CLEAR AVAILED
517	1-Jun-19	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN, KORMANGALA	9:05	10:33	1:28	MAIN SUPPLY FAILURE
518	1-Jun-19	BENGALURU	66	AUSTIN TOWN - HSR LAYOUT 220	AUSTIN TOWN, KORMANGALA	11:53	12:08	0:15	LOAD CHANGE OVER
519	1-Jun-19	BENGALURU	66	AUSTIN TOWN - EDC 220	AUSTIN TOWN, KORMANGALA	14:49	15:01	0:12	LOAD CHANGE OVER
520	1-Jun-19	BENGALURU	66	CHANDRALAYOUT - VRISHBHAVATHI 220	CHANDRA LAYOUT	13:51	14:40	0:49	LINE CLEAR AVAILED
521	1-Jun-19	BENGALURU	66	HV1	HSR LAYOUT 220	3:39	5:10	1:31	TRANSFORMER FAULT
522	1-Jun-19	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	0:00	0:34	0:34	LINE FAULT
523	1-Jun-19	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	6:20	6:25	0:05	LOAD CHANGE OVER
524	1-Jun-19	BENGALURU	66	EDC 220 - B STATION	B STATION	8:59	10:30	1:31	MAIN SUPPLY FAILURE
525	1-Jun-19	BENGALURU	66	EDC 220 - B STATION	B STATION	11:56	14:53	2:56	MAIN SUPPLY FAILURE
526	1-Jun-19	BENGALURU	220	EDC 220 - HAL 220	EDC 220	9:10	10:24	1:13	MAIN SUPPLY FAILURE
527	1-Jun-19	BENGALURU	220	EDC 220 - HAL 220	EDC 220	11:55	12:16	0:20	MAIN SUPPLY FAILURE
528	1-Jun-19	BENGALURU	220	HAL 220 - HOODY 1	HAL 220	8:59	10:18	1:18	LINE FAULT
529	1-Jun-19	BENGALURU	220	HAL 220 - HOODY 2	HAL 220	9:19	10:18	0:59	LINE FAULT
530	1-Jun-19	BENGALURU	220	HAL 220 - HOODY 2	HAL 220	11:56	14:35	2:38	LINE CLEAR AVAILED
531	1-Jun-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	9:10	10:23	1:13	MAIN SUPPLY FAILURE
532	1-Jun-19	BENGALURU	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	9:10	10:23	1:13	MAIN SUPPLY FAILURE
533	1-Jun-19	BENGALURU	66	HAL 220 - HAL (EHT)	HAL (EHT)	9:10	10:23	1:13	MAIN SUPPLY FAILURE
534	1-Jun-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	11:53	14:38	2:45	MAIN SUPPLY FAILURE
535	1-Jun-19	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	7:02	8:04	1:01	LINE FAULT
536	1-Jun-19	BENGALURU	66	JAYADEVA - ADUGODI	JAYADEVA	9:06	9:56	0:49	MAIN SUPPLY FAILURE
537	1-Jun-19	BENGALURU	66	JAYADEVA - SARAKKI	JAYADEVA	15:00	15:15	0:15	LOAD CHANGE OVER
538	1-Jun-19	BENGALURU	66	HV1	EDC 220	9:05	10:29	1:24	MAIN SUPPLY FAILURE
539	1-Jun-19	BENGALURU	66	HV1	EDC 220	11:56	12:23	0:27	MAIN SUPPLY FAILURE
540	1-Jun-19	BENGALURU	66	HV1	EDC 220	14:42	14:54	0:12	LINE CLEAR AVAILED
541	1-Jun-19	BENGALURU	66	HV2	EDC 220	9:05	10:30	1:25	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
542	1-Jun-19	BENGALURU	66	HV2	EDC 220	11:56	12:19	0:22	MAIN SUPPLY FAILURE
543	1-Jun-19	BENGALURU	66	HV2	EDC 220	14:41	14:54	0:12	LINE CLEAR AVAILED
544	1-Jun-19	BENGALURU	220	HV1	EDC 220	9:05	10:28	1:23	MAIN SUPPLY FAILURE
545	1-Jun-19	BENGALURU	220	HV2	EDC 220	9:05	10:26	1:21	MAIN SUPPLY FAILURE
546	1-Jun-19	BENGALURU	220	HV1	HAL 220	9:04	10:28	1:24	MAIN SUPPLY FAILURE
547	1-Jun-19	BENGALURU	220	HV2	HAL 220	9:04	10:19	1:15	MAIN SUPPLY FAILURE
548	1-Jun-19	BENGALURU	66	HV1	HAL 220	9:10	10:20	1:10	MAIN SUPPLY FAILURE
549	1-Jun-19	BENGALURU	66	HV1	HAL 220	11:53	14:37	2:43	MAIN SUPPLY FAILURE
550	1-Jun-19	BENGALURU	66	HV2	HAL 220	9:10	10:21	1:11	MAIN SUPPLY FAILURE
551	1-Jun-19	BENGALURU	66	HV2	HAL 220	11:53	14:37	2:44	MAIN SUPPLY FAILURE
552	1-Jun-19	BENGALURU	66	HV2	KADUGODI	17:59	18:15	0:16	LINE CLEAR AVAILED
553	1-Jun-19	BENGALURU	66	HV2	NRS 220	0:00	0:18	0:18	MAIN SUPPLY FAILURE
554	1-Jun-19	BENGALURU	66	HV2	NRS 220	6:25	6:28	0:02	LINE CLEAR AVAILED
555	1-Jun-19	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR	9:04	10:36	1:32	MAIN SUPPLY FAILURE
556	1-Jun-19	BENGALURU	66	NIMHANS 220 - BMTC	BMTC, NATIONAL COLLEGE	9:04	10:35	1:30	MAIN SUPPLY FAILURE
557	1-Jun-19	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR	11:50	14:53	3:03	MAIN SUPPLY FAILURE
558	1-Jun-19	BENGALURU	66	NIMHANS 220 - BMTC	BMTC, NATIONAL COLLEGE	11:50	14:54	3:04	MAIN SUPPLY FAILURE
559	1-Jun-19	BENGALURU	66	HV2	YERANDANAHALLI 220	10:30	10:40	0:10	LINE CLEAR AVAILED
560	1-Jun-19	BENGALURU	66	HV2	YERANDANAHALLI 220	18:20	18:30	0:10	LINE CLEAR AVAILED
561	1-Jun-19	BENGALURU	220	HOODY 400 - HAL 1	HAL 220	9:03	10:14	1:10	LINE FAULT
562	1-Jun-19	BENGALURU	220	HOODY 400 - HAL 1	HAL 220	12:04	14:34	2:30	LINE CLEAR AVAILED
563	1-Jun-19	BENGALURU	220	HOODY 400 - HAL 2	HAL 220	8:58	14:35	5:37	LINE FAULT
564	1-Jun-19	BENGALURU	220	HV1	NIMHANS 220	9:04	10:31	1:27	MAIN SUPPLY FAILURE
565	1-Jun-19	BENGALURU	220	HV1	NIMHANS 220	10:49	14:55	4:06	MAIN SUPPLY FAILURE
566	1-Jun-19	BENGALURU	220	HV2	NIMHANS 220	9:04	10:31	1:27	MAIN SUPPLY FAILURE
567	1-Jun-19	BENGALURU	220	HV2	NIMHANS 220	11:54	14:51	2:57	MAIN SUPPLY FAILURE
568	1-Jun-19	BENGALURU	66	HV1	ATTIBELE	12:58	13:00	0:01	LINE CLEAR AVAILED
569	1-Jun-19	BENGALURU	66	HV1	ATTIBELE	13:15	13:38	0:23	LINE CLEAR AVAILED
570	1-Jun-19	BENGALURU	66	ATTIBELE - SARAJAPURA 220	ATTIBELE	13:15	13:30	0:15	LINE CLEAR AVAILED
571	1-Jun-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	23:04	23:30	0:25	MAIN SUPPLY FAILURE
572	1-Jun-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	23:30	23:59	0:29	MAIN SUPPLY FAILURE
573	1-Jun-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	3:13	3:19	0:05	LINE FAULT
574	1-Jun-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	12:28	12:40	0:12	LINE CLEAR AVAILED
575	1-Jun-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	13:44	14:05	0:21	LINE CLEAR AVAILED
576	1-Jun-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1 & 2	KUNDANA, DEVANAHALLI	12:28	12:40	0:12	LINE CLEAR AVAILED
577	1-Jun-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1 & 2	KUNDANA, DEVANAHALLI	13:44	14:05	0:21	LINE CLEAR AVAILED
578	1-Jun-19	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	10:23	10:30	0:07	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
579	1-Jun-19	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	12:28	12:40	0:11	LINE CLEAR AVAILED
580	1-Jun-19	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	10:23	10:30	0:07	LINE CLEAR AVAILED
581	1-Jun-19	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	12:28	12:40	0:11	LINE CLEAR AVAILED
582	1-Jun-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	12:28	12:40	0:12	LINE CLEAR AVAILED
583	1-Jun-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	13:44	14:05	0:21	LINE CLEAR AVAILED
584	1-Jun-19	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	10:23	10:30	0:07	LINE CLEAR AVAILED
585	1-Jun-19	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	12:28	12:40	0:11	LINE CLEAR AVAILED
586	1-Jun-19	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHAPURA	0:00	0:19	0:19	LINE FAULT
587	1-Jun-19	BENGALURU	66	HONNIGANAHALLI - HALAGUR	HONNIGANAHALLI, DODDALAHALLI	12:20	12:25	0:05	LOAD CHANGE OVER
588	1-Jun-19	BENGALURU	66	HV2	HONNIGANAHALLI	7:20	7:30	0:10	TRANSFORMER FAULT
589	1-Jun-19	BENGALURU	66	HV2	HONNIGANAHALLI	9:45	9:50	0:05	TRANSFORMER FAULT
590	1-Jun-19	BENGALURU	66	HV2	HONNIGANAHALLI	15:00	15:05	0:05	TRANSFORMER FAULT
591	1-Jun-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	23:02	23:58	0:56	MAIN SUPPLY FAILURE
592	1-Jun-19	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	23:01	23:06	0:05	MAIN SUPPLY FAILURE
593	1-Jun-19	BENGALURU	66	DRDO (EHT) - SRINIVASPURA	MALLASANDRA, DALASANUR, YELDUR	23:06	23:58	0:52	MAIN SUPPLY FAILURE
594	1-Jun-19	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	3:15	3:44	0:29	LINE FAULT
595	1-Jun-19	GULBARGA	220	BMMISPAT-ITTAGI	ITTAGI_220	10:29	23:22	12:53	LINE FAULT
596	1-Jun-19	GULBARGA	220	HV1,LV1	ITTAGI_220	10:30	18:40	8:10	TRANSFORMER FAULT
597	1-Jun-19	GULBARGA	110	SHAHPUR-SHAHPUR220	SHAHPUR_110	10:30	12:19	1:49	MAIN SUPPLY FAILURE
598	1-Jun-19	GULBARGA	110	HALBURGA-CHIDRI2	KAMTHANA_110, HABSIKOTE_110	0:00	14:16	14:16	LINE CLEAR AVAILED
599	1-Jun-19	GULBARGA	110	HALBARGA-KOLHAR2	JANAWADA_110,KOLHAR_110,NSSK SUGAR FACTORY_IPP	0:00	14:20	14:20	LINE FAULT
600	1-Jun-19	GULBARGA	110	GULBARGA SOUTH-GULBARGA WEST	GULBARGASOUTH_110	9:20	9:45	0:25	LINE CLEAR AVAILED
601	1-Jun-19	GULBARGA	110	HV1	HANASI_110	6:38	8:57	2:19	LINE CLEAR AVAILED
602	1-Jun-19	GULBARGA	110	HV2	BISIHALLI_110	17:59	18:06	0:07	TRANSFORMER FAULT
603	1-Jun-19	GULBARGA	110	HV1	DHADESUGUR_110	22:10	22:20	0:10	TRANSFORMER FAULT
604	1-Jun-19	GULBARGA	110	HV2	HANUMASAGAR_110	22:05	22:10	0:05	MAIN SUPPLY FAILURE
605	1-Jun-19	GULBARGA	110	LADHA_RNWSLR	RNWSLR_IPP	19:23	23:59	4:36	LINE CLEAR AVAILED
606	1-Jun-19	GULBARGA	110	HV3	YELBURGA_110	22:10	22:30	0:20	MAIN SUPPLY FAILURE
607	1-Jun-19	GULBARGA	110	HV2	HANASI_110	6:40	9:00	2:20	LINE CLEAR AVAILED
608	1-Jun-19	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	5:32	9:25	3:53	LINE CLEAR AVAILED
609	1-Jun-19	GULBARGA	110	SHAHBAD-CHITAPUR	CHITAPUR_110	16:30	16:40	0:10	LINE FAULT
610	1-Jun-19	GULBARGA	66	LV2	ITTAGI_220	10:30	18:40	8:10	TRANSFORMER FAULT
611	1-Jun-19	GULBARGA	66	HV2	CHORNOOR_66	10:35	11:24	0:49	LINE CLEAR AVAILED
612	1-Jun-19	GULBARGA	66	KOTTUR-KUDLIGI	KOTTUR_66	10:30	12:18	1:48	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
613	1-Jun-19	GULBARGA	66	KOGALI-ITTAGI	KOGALI_66	10:30	13:06	2:36	MAIN SUPPLY FAILURE
614	1-Jun-19	GULBARGA	66	ITTAGI-KOTTUR	KOTTUR_66	18:50	19:45	0:55	MAIN SUPPLY FAILURE
615	1-Jun-19	GULBARGA	66	ITTAGI-TAMBRAHALLI	TAMBRAHALLI_66	10:30	12:40	2:10	MAIN SUPPLY FAILURE
616	1-Jun-19	GULBARGA	66	ITTAGI-TAMBRAHALLI	TAMBRAHALLI_66	18:05	19:45	1:40	MAIN SUPPLY FAILURE
617	1-Jun-19	GULBARGA	66	KOGALI-ATRSRLR	ATRSRLR_IPP	13:00	17:45	4:45	LINE CLEAR AVAILED
618	1-Jun-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	1:40	19:49	18:09	LINE CLEAR AVAILED
619	1-Jun-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	0:00	2:22	2:22	LINE CLEAR AVAILED
620	1-Jun-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	9:42	14:32	4:50	LINE CLEAR AVAILED
621	1-Jun-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	0:00	2:26	2:26	LINE CLEAR AVAILED
622	1-Jun-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	10:07	14:28	4:21	LINE CLEAR AVAILED
623	1-Jun-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	0:00	2:11	2:11	LINE CLEAR AVAILED
624	1-Jun-19	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	9:41	14:32	4:51	LINE CLEAR AVAILED
625	1-Jun-19	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	10:05	12:49	2:44	LINE CLEAR AVAILED
626	1-Jun-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	0:00	2:26	2:26	LINE CLEAR AVAILED
627	1-Jun-19	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	10:05	12:50	2:45	NFBC ISSUED
628	1-Jun-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	10:06	14:29	4:23	LINE CLEAR AVAILED
629	1-Jun-19	HASSAN	110	HV3	BAIKAMPADI_110	5:05	5:08	0:03	TRANSFORMER FAULT
630	1-Jun-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	14:20	16:30	2:10	LINE CLEAR AVAILED
631	1-Jun-19	HASSAN	110	HV2	GANDSI_110	22:09	22:18	0:09	MAIN SUPPLY FAILURE
632	1-Jun-19	HASSAN	110	KADUR-YGTI	KADUR_220	16:14	16:15	0:01	HAND TRIPPED
633	1-Jun-19	HASSAN	110	HV1	SAGARA_110	14:22	14:43	0:21	TRANSFORMER FAULT
634	1-Jun-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	23:22	23:59	0:37	LINE FAULT
635	1-Jun-19	HASSAN	110	HV2	SORABA_110	9:55	10:35	0:40	LINE CLEAR AVAILED
636	1-Jun-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	16:37	23:59	7:22	MAIN SUPPLY FAILURE
637	1-Jun-19	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	14:45	14:59	0:14	LINE CLEAR AVAILED
638	1-Jun-19	HASSAN	66	HV1	BYACHANAHALLI_66	4:45	14:59	10:14	LINE CLEAR AVAILED
639	1-Jun-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	16:37	21:22	4:45	LINE FAULT
640	1-Jun-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	21:22	23:59	2:37	LINE FAULT
641	1-Jun-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	13:06	13:12	0:06	HAND TRIPPED
642	1-Jun-19	HASSAN	66	HV2	RAMESHWARNAGAR_66	22:09	22:43	0:34	MAIN SUPPLY FAILURE
643	1-Jun-19	HASSAN	66	SAKALE-IPCL2	SAKLESHUPURA_66	7:43	9:32	1:49	LINE CLEAR AVAILED
644	1-Jun-19	HASSAN	66	SAKALE-IPCL1	SAKLESHUPURA_66	7:42	9:32	1:50	LINE CLEAR AVAILED
645	1-Jun-19	HASSAN	66	HV2	SALAGAME_66	22:10	22:14	0:04	MAIN SUPPLY FAILURE
646	1-Jun-19	HASSAN	66	HV2	SATHENAHALLY_66	8:52	12:19	3:27	LINE CLEAR AVAILED
647	1-Jun-19	HASSAN	66	HV2	SATHENAHALLY_66	22:09	22:14	0:05	MAIN SUPPLY FAILURE
648	1-Jun-19	HASSAN	66	HV2	SHANTHIGRAMMA_66	12:25	13:35	1:10	LINE CLEAR AVAILED
649	1-Jun-19	HASSAN	66	HV2	SHANTHIGRAMMA_66	11:20	12:25	1:05	LINE CLEAR AVAILED
650	1-Jun-19	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGI_66	13:09	13:10	0:01	HAND TRIPPED
651	1-Jun-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	12:55	13:11	0:16	LINE CLEAR AVAILED
652	1-Jun-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	22:08	22:11	0:03	MAIN SUPPLY FAILURE
653	1-Jun-19	MYSORE	66	HV1	BESAGARAHALLI_66	22:08	22:15	0:06	MAIN SUPPLY FAILURE
654	1-Jun-19	MYSORE	66	HV1	BILIKERE_66	13:10	23:59	10:49	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
655	1-Jun-19	MYSORE	66	HV2	BOOKANAKERE_66	14:30	14:51	0:21	TRANSFORMER FAULT
656	1-Jun-19	MYSORE	66	HV2	BOOKANAKERE_66	22:08	22:25	0:16	MAIN SUPPLY FAILURE
657	1-Jun-19	MYSORE	66	HV2	CHINAKURALI_66	22:09	22:41	0:32	MAIN SUPPLY FAILURE
658	1-Jun-19	MYSORE	66	HV2	ELAVALA_66	22:09	22:30	0:21	MAIN SUPPLY FAILURE
659	1-Jun-19	MYSORE	66	HV1	HANAGODU_66	22:09	23:33	1:24	MAIN SUPPLY FAILURE
660	1-Jun-19	MYSORE	66	KADAKOLA-NANJANGUDU 1	NANJANGUDU_66	9:41	13:56	4:15	LINE CLEAR AVAILED
661	1-Jun-19	MYSORE	66	KADAKOLA-NANJANGUDU 2	NANJANGUDU_66 THANDYA_66	9:31	9:40	0:09	LINE FAULT
662	1-Jun-19	MYSORE	66	HV2	KIRUGAVALU_66	22:09	22:26	0:16	MAIN SUPPLY FAILURE
663	1-Jun-19	MYSORE	66	HV1	KRNAGARA_66	15:22	15:35	0:12	TRANSFORMER FAULT
664	1-Jun-19	MYSORE	66	HV1	PANDAVAPURA_66	22:09	22:30	0:20	MAIN SUPPLY FAILURE
665	1-Jun-19	MYSORE	66	HV2	PONNAMPET_66	22:09	22:15	0:05	MAIN SUPPLY FAILURE
666	1-Jun-19	MYSORE	66	HV2	THALAKADU_66	14:38	14:46	0:07	TRANSFORMER FAULT
667	1-Jun-19	MYSORE	66	HV2	THALAKADU_66	15:16	15:22	0:05	TRANSFORMER FAULT
668	1-Jun-19	TUMKUR	220	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	11:14	12:34	1:19	LINE CLEAR AVAILED
669	1-Jun-19	TUMKUR	220	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	14:02	15:15	1:12	LINE CLEAR AVAILED
670	1-Jun-19	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	3:12	3:24	0:12	LINE FAULT
671	1-Jun-19	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	3:12	3:22	0:10	LINE FAULT
672	1-Jun-19	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	3:12	3:25	0:13	LINE FAULT
673	1-Jun-19	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	3:12	3:30	0:18	LINE FAULT
674	1-Jun-19	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	3:12	3:30	0:18	LINE FAULT
675	1-Jun-19	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	3:12	3:30	0:18	LINE FAULT
676	1-Jun-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	3:12	3:31	0:19	LINE FAULT
677	1-Jun-19	TUMKUR	66	HIRIYUR 220kV- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	12:21	12:32	0:11	LINE FAULT
678	1-Jun-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	12:42	14:39	1:56	LINE FAULT
679	1-Jun-19	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	6:07	7:48	1:40	LINE CLEAR AVAILED
680	1-Jun-19	TUMKUR	66	TR-2(LV SIDE)	THALLAKK_220	17:00	17:09	0:09	TRANSFORMER FAULT
681	1-Jun-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	11:27	17:13	5:46	LINE FAULT
682	1-Jun-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	17:09	17:13	0:04	LINE FAULT
683	2-Jun-19	BAGALKOT	110	BAGALKOT220-GULEDGUDDA	GULEDGUDDA_110	21:29	22:08	0:39	LINE FAULT
684	2-Jun-19	BAGALKOT	110	HIREHAL-BADAMI	BADAMI_110	22:11	22:23	0:12	LINE FAULT
685	2-Jun-19	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	6:55	8:13	1:18	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
686	2-Jun-19	BAGALKOT	110	110/11KV,HV3	RAIBAG_110	18:37	22:49	4:12	LINE CLEAR AVAILED
687	2-Jun-19	BAGALKOT	220	RANEENNUR-BALLIGAVI(SHIROLKOPPA)	RANEENNUR_220	6:49	23:59	17:10	LINE CLEAR AVAILED
688	2-Jun-19	BAGALKOT	220	PONDA1(XELDOM)-AMBEWADI	AMBEWADI_220	12:04	13:49	1:45	LINE CLEAR AVAILED
689	2-Jun-19	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	0:00	14:24	14:24	LINE CLEAR AVAILED
690	2-Jun-19	BAGALKOT	220	RAVIURJA1-ATHANI	ATHANI_220	22:24	23:59	1:35	LINE CLEAR AVAILED
691	2-Jun-19	BAGALKOT	220	BAGEWADI-BIJAPUR1	BAGEWADI_220	19:44	22:53	3:09	LINE FAULT
692	2-Jun-19	BAGALKOT	220	BAGEWADI-BIJAPUR2	BAGEWADI_220	19:44	22:54	3:10	LINE FAULT
693	2-Jun-19	BAGALKOT	66	66/33KV, HV4	HARIHAR-HOSPET_66	0:00	11:27	11:27	LINE CLEAR AVAILED
694	2-Jun-19	BENGALURU	66	HV2	AMARJYOTHI	19:21	19:40	0:18	MAIN SUPPLY FAILURE
695	2-Jun-19	BENGALURU	66	HV1	AMARJYOTHI	20:33	20:43	0:10	MAIN SUPPLY FAILURE
696	2-Jun-19	BENGALURU	66	HV3	ADUGODI	19:21	20:41	1:19	LINE CLEAR AVAILED
697	2-Jun-19	BENGALURU	66	ADUGODI - HSR LAYOUT 1 & 2	ADUGODI, BOSCH (EHT)	20:33	20:41	0:08	LOAD CHANGE OVER
698	2-Jun-19	BENGALURU	66	HV3	ADUGODI	23:06	23:12	0:06	LINE CLEAR AVAILED
699	2-Jun-19	BENGALURU	66	HV1	ABBIGERE	23:38	23:42	0:04	LINE CLEAR AVAILED
700	2-Jun-19	BENGALURU	66	HV2	ABBIGERE	21:03	21:26	0:22	TRANSFORMER FAULT
701	2-Jun-19	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN, KORMANGALA	19:21	20:22	1:00	MAIN SUPPLY FAILURE
702	2-Jun-19	BENGALURU	66	AUSTIN TOWN - HSR LAYOUT 220	AUSTIN TOWN, KORMANGALA	20:46	20:51	0:05	LOAD CHANGE OVER
703	2-Jun-19	BENGALURU	66	AUSTIN TOWN - EDC 220	AUSTIN TOWN, KORMANGALA	23:00	23:10	0:10	LOAD CHANGE OVER
704	2-Jun-19	BENGALURU	220	HV1	EDC 220	19:21	20:11	0:49	TRANSFORMER FAULT
705	2-Jun-19	BENGALURU	220	HV2	EDC 220	19:23	20:11	0:48	MAIN SUPPLY FAILURE
706	2-Jun-19	BENGALURU	66	HV1	HAL 220	19:21	20:52	1:31	MAIN SUPPLY FAILURE
707	2-Jun-19	BENGALURU	66	HV2	HAL 220	19:21	20:52	1:31	MAIN SUPPLY FAILURE
708	2-Jun-19	BENGALURU	220	HV1	HAL 220	19:21	20:43	1:21	MAIN SUPPLY FAILURE
709	2-Jun-19	BENGALURU	220	HV2	HAL 220	19:21	20:43	1:21	MAIN SUPPLY FAILURE
710	2-Jun-19	BENGALURU	220	EDC 220 - HAL 220	EDC 220	19:21	22:02	2:40	LINE FAULT
711	2-Jun-19	BENGALURU	66	HAL 220 - B STATION	B STATION	19:21	21:35	2:14	MAIN SUPPLY FAILURE
712	2-Jun-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	19:21	21:04	1:43	LINE FAULT
713	2-Jun-19	BENGALURU	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	19:21	21:04	1:43	MAIN SUPPLY FAILURE
714	2-Jun-19	BENGALURU	66	HAL 220 - HAL (EHT)	HAL (EHT)	19:21	21:04	1:43	MAIN SUPPLY FAILURE
715	2-Jun-19	BENGALURU	220	HAL 220 - HOODY 1	HAL 220	19:21	20:37	1:16	LINE FAULT
716	2-Jun-19	BENGALURU	220	HAL 220 - HOODY 2	HAL 220	19:21	22:35	3:14	LINE FAULT
717	2-Jun-19	BENGALURU	220	HOODY 400 - HAL 1	HAL 220	19:21	22:34	3:12	LINE FAULT
718	2-Jun-19	BENGALURU	220	HOODY 400 - HAL 2	HAL 220	19:21	20:35	1:14	LINE FAULT
719	2-Jun-19	BENGALURU	66	EDC 220 - B STATION	B STATION	19:21	20:18	0:57	MAIN SUPPLY FAILURE
720	2-Jun-19	BENGALURU	66	EDC 220 - B STATION	B STATION	19:21	20:18	0:57	MAIN SUPPLY FAILURE
721	2-Jun-19	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR	19:21	20:29	1:08	MAIN SUPPLY FAILURE
722	2-Jun-19	BENGALURU	66	NIMHANS 220 - BMTC	BMTC, NATIONAL COLLEGE	19:21	20:28	1:07	MAIN SUPPLY FAILURE
723	2-Jun-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	11:46	12:00	0:14	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
724	2-Jun-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	15:38	15:50	0:12	LINE FAULT
725	2-Jun-19	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	20:22	22:11	1:49	LINE FAULT
726	2-Jun-19	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	19:18	20:31	1:13	LINE FAULT
727	2-Jun-19	BENGALURU	66	JAYADEVA - ADUGODI	JAYADEVA	19:22	20:14	0:51	MAIN SUPPLY FAILURE
728	2-Jun-19	BENGALURU	66	JAYADEVA - SARAKKI	JAYADEVA	22:57	23:12	0:15	LOAD CHANGE OVER
729	2-Jun-19	BENGALURU	66	ITI - HEBBAL	BANASWADI	21:45	22:22	0:36	MAIN SUPPLY FAILURE
730	2-Jun-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	22:17	22:30	0:13	LINE FAULT
731	2-Jun-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	22:17	22:30	0:13	LINE FAULT
732	2-Jun-19	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	22:17	22:30	0:13	LINE FAULT
733	2-Jun-19	BENGALURU	66	HV1	MEI LAYOUT	13:08	13:49	0:40	TRANSFORMER FAULT
734	2-Jun-19	BENGALURU	66	HV1	LR BANDE	20:05	20:14	0:09	TRANSFORMER FAULT
735	2-Jun-19	BENGALURU	66	BG ROAD - SOMANAHALLI 220	BG ROAD	15:50	17:09	1:19	MAIN SUPPLY FAILURE
736	2-Jun-19	BENGALURU	66	AVANI - MULBAGAL	MULBAGAL	16:56	17:12	0:16	LINE FAULT
737	2-Jun-19	BENGALURU	66	BAGHMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	19:03	21:55	2:51	LINE FAULT
738	2-Jun-19	BENGALURU	66	BAGHMANE WORLD TECH PARK - HOODY 1	BAGHMANE WORLD TECH PARK, NGEF, NGEF (EHT)	19:26	21:44	2:18	LINE FAULT
739	2-Jun-19	BENGALURU	66	BAGHMANE WORLD TECH PARK - HOODY 2	BAGHMANE WORLD TECH PARK, NGEF, NGEF (EHT)	19:26	21:44	2:18	LINE FAULT
740	2-Jun-19	BENGALURU	66	HV1	BANGARPET	16:06	16:51	0:45	TRANSFORMER FAULT
741	2-Jun-19	BENGALURU	66	HV1	CHANDAPURA	7:24	8:12	0:48	LINE CLEAR AVAILED
742	2-Jun-19	BENGALURU	66	CHELUR - YENNIGADALE	CHELUR	21:24	21:58	0:34	LINE FAULT
743	2-Jun-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	16:15	16:23	0:08	LINE FAULT
744	2-Jun-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	17:39	17:48	0:08	LINE FAULT
745	2-Jun-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	21:22	21:30	0:07	LINE FAULT
746	2-Jun-19	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	21:25	21:28	0:03	LINE FAULT
747	2-Jun-19	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	15:04	18:19	3:15	MAIN SUPPLY FAILURE
748	2-Jun-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	15:04	18:30	3:26	MAIN SUPPLY FAILURE
749	2-Jun-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI	15:04	18:23	3:19	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
750	2-Jun-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	15:04	18:18	3:14	MAIN SUPPLY FAILURE
751	2-Jun-19	BENGALURU	220	CHINTAMANI 220 - PGCIL 1 & 2	CHINTAMANI 220	15:04	18:04	3:00	MAIN SUPPLY FAILURE
752	2-Jun-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	15:04	18:12	3:08	MAIN SUPPLY FAILURE
753	2-Jun-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	15:04	18:09	3:05	MAIN SUPPLY FAILURE
754	2-Jun-19	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	15:04	18:26	3:22	MAIN SUPPLY FAILURE
755	2-Jun-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	15:04	18:10	3:06	MAIN SUPPLY FAILURE
756	2-Jun-19	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66, SM MANGALA	15:04	18:39	3:35	MAIN SUPPLY FAILURE
757	2-Jun-19	BENGALURU	66	SRINIVASPURA - CHINTAMANI 220	SRINIVASPURA	15:04	17:25	2:21	MAIN SUPPLY FAILURE
758	2-Jun-19	BENGALURU	66	SRINIVASPURA - DALASNUR	SRINIVASPURA	18:30	18:35	0:05	LOAD CHANGE OVER
759	2-Jun-19	BENGALURU	66	DALASNUR - SRINIVASPURA	YELDUR	17:10	17:14	0:04	MAIN SUPPLY FAILURE
760	2-Jun-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	19:42	20:09	0:26	LINE FAULT
761	2-Jun-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	19:43	20:11	0:27	LINE FAULT
762	2-Jun-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	19:43	20:11	0:27	LINE FAULT
763	2-Jun-19	BENGALURU	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	19:48	20:13	0:25	LINE FAULT
764	2-Jun-19	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	19:14	19:49	0:35	LINE FAULT
765	2-Jun-19	BENGALURU	66	GOWRIBIDANUR 220 - DB 1	THONDEBHAVI	19:31	19:49	0:18	LINE FAULT
766	2-Jun-19	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 2 (EHT)	RVNL (EHT)	18:00	18:17	0:17	LINE FAULT
767	2-Jun-19	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 2 (EHT)	RVNL (EHT)	21:52	22:34	0:42	LINE FAULT
768	2-Jun-19	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 2 (EHT)	RVNL (EHT)	22:44	23:59	1:15	LINE FAULT
769	2-Jun-19	BENGALURU	66	JIGANI 66 - BG ROAD	JIGANI 66	11:42	12:02	0:20	MAIN SUPPLY FAILURE
770	2-Jun-19	BENGALURU	66	JIGANI 66 - BG ROAD	JIGANI 66	15:35	15:48	0:13	MAIN SUPPLY FAILURE
771	2-Jun-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGALI	14:43	15:49	1:06	LINE FAULT
772	2-Jun-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	16:07	16:43	0:36	LINE FAULT
773	2-Jun-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	6:26	7:18	0:51	LINE CLEAR AVAILED
774	2-Jun-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	18:57	20:00	1:03	LINE FAULT
775	2-Jun-19	BENGALURU	66	TG HALLY - ANCHEPALYA	TG HALLY	19:45	23:30	3:45	MAIN SUPPLY FAILURE
776	2-Jun-19	BENGALURU	66	MAGADI 66 - ANCHEPALYA 220	GUDEMARANAHALLI, MAGADI 66	19:45	23:59	4:14	MAIN SUPPLY FAILURE
777	2-Jun-19	BENGALURU	220	NELAMANGALA 400 - YELAHANKA 220	YELAHANKA 220	19:32	23:59	4:26	LINE FAULT
778	2-Jun-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	15:36	15:44	0:08	LINE FAULT
779	2-Jun-19	BENGALURU	66	HV1	DODDABELAVANGALA	22:35	23:59	1:23	LINE CLEAR AVAILED
780	2-Jun-19	BENGALURU	66	HV2	DODDABELAVANGALA	22:35	23:59	1:23	LINE CLEAR AVAILED
781	2-Jun-19	BENGALURU	66	HV1	KYALANUR	20:16	21:20	1:03	TRANSFORMER FAULT
782	2-Jun-19	BENGALURU	66	HV1	SIDDLAGHATTA	19:56	20:00	0:04	LINE CLEAR AVAILED
783	2-Jun-19	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	18:16	19:46	1:30	LINE FAULT
784	2-Jun-19	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	19:46	19:48	0:02	LINE FAULT



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
785	2-Jun-19	GULBARGA	400	JSWVL-GUTTUR	GUTTUR_400	18:16	23:59	5:43	LINE CLEAR AVAILED
786	2-Jun-19	GULBARGA	220	ALIPUR-GOOTY	ALIPUR_220	9:53	10:56	1:03	LINE CLEAR AVAILED
787	2-Jun-19	GULBARGA	220	BPTPS-LINGAPUR	LINGAPUR_220	20:48	23:48	3:00	LINE FAULT
788	2-Jun-19	GULBARGA	220	HV1	KAPNOOR_220	10:20	11:01	0:41	LINE CLEAR AVAILED
789	2-Jun-19	GULBARGA	220	SHAHPUR-KAPNOOR	KAPNOOR_220	15:37	17:40	2:03	LINE FAULT
790	2-Jun-19	GULBARGA	220	SHAHABAD-BAGEWADI1	SHAHABAD_220	17:11	17:19	0:08	LINE FAULT
791	2-Jun-19	GULBARGA	220	SHAHABAD-BAGEWADI2	SHAHABAD_220	17:11	17:19	0:08	LINE FAULT
792	2-Jun-19	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	15:36	15:58	0:22	LINE FAULT
793	2-Jun-19	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220, MALLAT_220	18:05	19:21	1:16	LINE FAULT
794	2-Jun-19	GULBARGA	220	HV1	KUSHTAGI_220	20:59	22:04	1:05	TRANSFORMER FAULT
795	2-Jun-19	GULBARGA	220	BTPS-LINGAPUR	BTPS_220	20:48	23:47	2:59	LINE FAULT
796	2-Jun-19	GULBARGA	220	ITTAGI-NEELGUNDA	NEELGUNDA_220	0:00	18:35	18:35	LINE FAULT
797	2-Jun-19	GULBARGA	220	HV1	RAICHUR_220	18:10	18:28	0:18	TRANSFORMER FAULT
798	2-Jun-19	GULBARGA	110	HV1	ALAND_110	14:10	14:15	0:05	TRANSFORMER FAULT
799	2-Jun-19	GULBARGA	110	HV2	BISIHALLI_110	19:51	20:02	0:11	TRANSFORMER FAULT
800	2-Jun-19	GULBARGA	110	HV1	CHITGUPPA_110	20:35	21:04	0:29	TRANSFORMER FAULT
801	2-Jun-19	GULBARGA	110	RAICHUR-GABBUR	GABBUR_110	19:26	21:28	2:02	MAIN SUPPLY FAILURE
802	2-Jun-19	GULBARGA	110	HV3	BEVOOR_110	22:25	23:10	0:45	LINE CLEAR AVAILED
803	2-Jun-19	GULBARGA	110	LADHA_RNWSLR	RNWSLR_IPP	0:00	2:07	2:07	LINE CLEAR AVAILED
804	2-Jun-19	GULBARGA	110	SINDHANOOR-MASKI	MASKI_110	19:06	19:28	0:22	MAIN SUPPLY FAILURE
805	2-Jun-19	GULBARGA	110	SEDAM-VICATSAGAR_IPP	VICATSAGAR_IPP	16:58	17:33	0:35	LINE FAULT
806	2-Jun-19	GULBARGA	110	SHAHABAD-FARHATABAD	FARHATABAD_110,GULBARGASOUTH_110	15:36	16:23	0:47	LINE FAULT
807	2-Jun-19	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	SINDHANOR_110	3:28	3:43	0:15	LINE FAULT
808	2-Jun-19	GULBARGA	110	SINDHANOOR220-MUNIRABAD1	KARATAGI_110, SRERAMNAGAR_110,GANGAVATHI_110, VENKATGIRI_110	19:20	19:50	0:30	LINE FAULT
809	2-Jun-19	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	2:26	3:06	0:40	LINE FAULT
810	2-Jun-19	GULBARGA	110	HV1	KOLHAR_110	6:50	7:15	0:25	TRANSFORMER FAULT
811	2-Jun-19	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGWAT_110,VALKAMDINNI_110	18:05	19:09	1:04	LINE FAULT
812	2-Jun-19	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110,DEODURGA_110	18:10	19:17	1:07	LINE FAULT
813	2-Jun-19	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	18:10	19:17	1:07	LINE FAULT
814	2-Jun-19	GULBARGA	110	LV1	RAICHUR_220	18:10	20:55	2:45	TRANSFORMER FAULT
815	2-Jun-19	GULBARGA	66	KOGALI-ATRSLR	ATRSLR_IPP	9:45	10:19	0:34	LINE CLEAR AVAILED
816	2-Jun-19	GULBARGA	66	UPANAYAKANAHALLI-MUNIRABAD	UPANAYAKANAHALLI_66	21:45	23:59	2:14	LINE CLEAR AVAILED
817	2-Jun-19	GULBARGA	66	HV1	HAMPASAGAR_66	20:40	20:50	0:10	TRANSFORMER FAULT
818	2-Jun-19	GULBARGA	66	HV1	HAMPASAGAR_66	23:55	23:59	0:04	TRANSFORMER FAULT
819	2-Jun-19	GULBARGA	66	HV2	CJHALLI_66	15:50	23:59	8:09	TRANSFORMER FAULT
820	2-Jun-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:05	23:59	1:54	LINE CLEAR AVAILED
821	2-Jun-19	HASSAN	220	GER SOPA-TALGUPA1	gerusoppa_gen	7:31	7:35	0:04	LINE CLEAR AVAILED
822	2-Jun-19	HASSAN	220	GER SOPA-TALGUPA2	gerusoppa_gen	7:34	17:38	10:04	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
823	2-Jun-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	7:31	17:36	10:05	LINE CLEAR AVAILED
824	2-Jun-19	HASSAN	220	SHRAVITY-ST3(TALGPPA)	sharavathy_gen	2:48	11:07	8:19	LINE FAULT
825	2-Jun-19	HASSAN	220	TALAGU-SHRAVITY3	TALAGUPPA_400	2:50	11:08	8:18	LINE FAULT
826	2-Jun-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	2:04	17:37	15:33	LINE CLEAR AVAILED
827	2-Jun-19	HASSAN	220	GOPALAP-HNPUR21	GOPALAPURA_220	23:36	23:53	0:17	LINE FAULT
828	2-Jun-19	HASSAN	110	HALDY1-HOSANGADI	HALADY_110	8:23	8:46	0:23	MAIN SUPPLY FAILURE
829	2-Jun-19	HASSAN	110	HV2	HALADY_110	18:17	18:22	0:05	TRANSFORMER FAULT
830	2-Jun-19	HASSAN	110	AJAMPU-KADUR	AJJAMPURA_110	18:09	18:25	0:16	LINE FAULT
831	2-Jun-19	HASSAN	110	ARSK2-BANAVARA	ARASIKERE_220	16:14	17:01	0:47	LINE FAULT
832	2-Jun-19	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	8:24	8:42	0:18	MAIN SUPPLY FAILURE
833	2-Jun-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	8:27	8:43	0:16	MAIN SUPPLY FAILURE
834	2-Jun-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	0:00	0:02	0:02	LINE FAULT
835	2-Jun-19	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	23:36	23:54	0:18	LINE FAULT
836	2-Jun-19	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	23:36	23:53	0:17	LINE FAULT
837	2-Jun-19	HASSAN	66	HMPR2-HASS3	HOLENARASIPURA_220	23:36	23:53	0:17	LINE FAULT
838	2-Jun-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	9:04	19:00	9:56	LINE CLEAR AVAILED
839	2-Jun-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	9:04	19:00	9:56	LINE CLEAR AVAILED
840	2-Jun-19	MYSORE	66	CR NAGARA-KABBAHALLI	HARVEY_66	17:08	17:21	0:12	LINE FAULT
841	2-Jun-19	MYSORE	66	CR NAGARA-KABBAHALLI	HARVEY_66	17:23	23:59	6:35	LINE FAULT
842	2-Jun-19	MYSORE	66	CR NAGARA-KABBAHALLI	HARVEY_66	18:16	23:59	5:42	LINE FAULT
843	2-Jun-19	MYSORE	66	GUNDLUPETE-BEGUR	BEGUR_66 SINDHUVALLI_66	17:08	17:16	0:07	LINE FAULT
844	2-Jun-19	MYSORE	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	17:08	17:17	0:08	LINE FAULT
845	2-Jun-19	MYSORE	66	KADAKOLA-DK MAIDANA	DKMAIDANA_66	17:12	17:18	0:05	LINE FAULT
846	2-Jun-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	22:18	22:33	0:15	LINE FAULT
847	2-Jun-19	MYSORE	66	HV3	KUSHALANAGARA_66	7:35	7:45	0:10	TRANSFORMER FAULT
848	2-Jun-19	MYSORE	66	HV3	KUSHALANAGARA_66	8:19	8:54	0:34	TRANSFORMER FAULT
849	2-Jun-19	MYSORE	66	HV3	KUSHALANAGARA_66	11:43	11:52	0:08	TRANSFORMER FAULT
850	2-Jun-19	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	5:03	10:45	5:41	LINE FAULT
851	2-Jun-19	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	5:05	10:39	5:34	LINE FAULT
852	2-Jun-19	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA_220 1	MADHUGIRI 220kV	17:59	18:15	0:15	LINE FAULT
853	2-Jun-19	TUMKUR	110	TR-3	GUBBI_110	16:38	17:42	1:03	LINE CLEAR AVAILED
854	2-Jun-19	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	5:44	5:59	0:14	LINE FAULT
855	2-Jun-19	TUMKUR	110	TR-1	MAYASANDRA_110	16:46	16:48	0:01	HAND TRIPPED
856	2-Jun-19	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	15:50	16:48	0:57	HAND TRIPPED
857	2-Jun-19	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	17:52	19:36	1:43	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
858	2-Jun-19	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	8:33	8:58	0:25	HAND TRIPPED
859	2-Jun-19	TUMKUR	66	DODDASARANGI-ANCHEPALYA	DODDASARANGI_66	15:22	17:48	2:26	LINE CLEAR AVAILED
860	2-Jun-19	TUMKUR	66	HEGGERE- MALLASANDRA	MALLASANDRA_66	17:34	19:11	1:36	LINE FAULT
861	2-Jun-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	18:56	19:59	1:03	LINE CLEAR AVAILED
862	2-Jun-19	TUMKUR	66	HIRIYUR 220kV- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	23:46	23:51	0:04	LINE FAULT
863	2-Jun-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	19:35	19:37	0:01	HAND TRIPPED
864	2-Jun-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	23:46	23:48	0:01	HAND TRIPPED
865	2-Jun-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	23:46	23:48	0:01	HAND TRIPPED
866	2-Jun-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	23:46	23:48	0:01	HAND TRIPPED
867	2-Jun-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	9:15	9:27	0:12	LINE FAULT
868	2-Jun-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	17:16	17:26	0:09	LINE FAULT
869	2-Jun-19	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR_IPP_66	BPCLSOLAR_IPP_66	18:50	18:55	0:05	MAIN SUPPLY FAILURE
870	3-Jun-19	BAGALKOT	220	ALMATTI 1-BAGEWADI	BAGEWADI_220	19:36	23:59	4:23	LINE FAULT
871	3-Jun-19	BAGALKOT	220	RAVI URJA 1-ATHANI	ATHANI_220	0:00	19:14	19:14	LINE CLEAR AVAILED
872	3-Jun-19	BAGALKOT	220	RAVI URJA 2-ATHANI	ATHANI_220	23:09	23:59	0:50	LINE CLEAR AVAILED
873	3-Jun-19	BAGALKOT	220	220/110KV,HV1,LV1	VAJRAMATTI_220,BILAGI_110,LOKAP UR_110,MUDHOL_110,KATARKI_110, MANTUR1&2_110,VAJRAMATTI_110,J K CEMENT_110	21:43	23:12	1:29	TRANSFORMER FAULT
874	3-Jun-19	BAGALKOT	220	220/110KV,HV2,LV2	VAJRAMATTI_220,BILAGI_110,LOKAP UR_110,MUDHOL_110,KATARKI_110, MANTUR1&2_110,VAJRAMATTI_110,J K CEMENT_110	21:43	23:17	1:34	TRANSFORMER FAULT
875	3-Jun-19	BAGALKOT	220	220/110KV,HV1,LV1	VAJRAMATTI_220,BILAGI_110,LOKAP UR_110,MUDHOL_110,KATARKI_110, MANTUR1&2_110,VAJRAMATTI_110,J K CEMENT_110	23:12	23:59	0:47	HAND TRIPPED
876	3-Jun-19	BAGALKOT	220	220/110KV,HV2,LV2	VAJRAMATTI_220,BILAGI_110,LOKAP UR_110,MUDHOL_110,KATARKI_110, MANTUR1&2_110,VAJRAMATTI_110,J K CEMENT_110	23:22	23:59	0:37	TRANSFORMER FAULT
877	3-Jun-19	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	11:50	14:05	2:15	LINE CLEAR AVAILED
878	3-Jun-19	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	9:11	16:52	7:41	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
879	3-Jun-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	1:15	12:52	11:37	LINE FAULT
880	3-Jun-19	BAGALKOT	220	GUTTURI-HAVERI220	HAVERI_220	10:38	12:52	2:14	LINE CLEAR AVAILED
881	3-Jun-19	BAGALKOT	110	SIRSI-KUMTA1&2	SIRSI_110	21:49	23:59	2:10	LINE CLEAR AVAILED
882	3-Jun-19	BAGALKOT	220	220/110KV,HV1&LV1,HV2&LV2	KUDUCHI_220,KUDUCHI_110,TERDAL_110,AINAPUR_110,YELLAPARHATTI_110,MORAB_110,UGAR KHUD_110	5:01	5:11	0:10	TRANSFORMER FAULT
883	3-Jun-19	BAGALKOT	110	110/11KV,HV1	SALAHALLI_110	15:07	18:58	3:51	TRANSFORMER FAULT
884	3-Jun-19	BAGALKOT	110	SHIRAGUPPI SUGARS TO KAGAWAD	KAGAWADA_110	5:31	5:32	0:01	LINE FAULT
885	3-Jun-19	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	7:16	7:19	0:03	TRANSFORMER FAULT
886	3-Jun-19	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	12:20	12:27	0:07	TRANSFORMER FAULT
887	3-Jun-19	BAGALKOT	110	110/11KV,HV2	ITNAL_110	16:14	17:16	1:02	LINE CLEAR AVAILED
888	3-Jun-19	BAGALKOT	110	110/33KV,HV2	HANGAL_110	18:27	18:32	0:05	TRANSFORMER FAULT
889	3-Jun-19	BAGALKOT	110	110/11KV,HV3&HV4	GOPPANKOPPA_110	12:26	13:26	1:00	LINE CLEAR AVAILED
890	3-Jun-19	BAGALKOT	110	110/33KV,HV1	GOPPANKOPPA_110,KUSUGAL_33KV	13:26	13:38	0:12	LINE CLEAR AVAILED
891	3-Jun-19	BAGALKOT	110	110/33KV,HV2	GAJENDRAGAD_110	20:49	21:21	0:32	TRANSFORMER FAULT
892	3-Jun-19	BAGALKOT	110	ENORCON-BIJAPUR220	BIJAPUR_220	19:31	19:45	0:14	LINE FAULT
893	3-Jun-19	BAGALKOT	110	110/11KV,HV2	BHUTHNAL_110	0:15	0:20	0:05	TRANSFORMER FAULT
894	3-Jun-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33KV,DHULKED_33KV,HALASANGI_33KV	11:11	11:18	0:07	TRANSFORMER FAULT
895	3-Jun-19	BAGALKOT	110	INDI220-ZALKI	ZALKI_110	22:40	23:39	0:59	LINE FAULT
896	3-Jun-19	BAGALKOT	110	110/33KV,HV3	ZALKI_110,HORTI_33KV	20:34	23:59	3:25	LINE CLEAR AVAILED
897	3-Jun-19	BAGALKOT	110	110/33KV,HV3	MAMADAPUR(B)_110,DEVAR GENNUR_33KV	22:01	22:23	0:22	TRANSFORMER FAULT
898	3-Jun-19	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	23:45	23:50	0:05	LOAD CHANGE OVER
899	3-Jun-19	BENGALURU	66	ATTIBELE - SARAJAPURA 220	ATTIBELE	20:45	20:55	0:10	LOAD CHANGE OVER
900	3-Jun-19	BENGALURU	66	BAIRAKUR - KOLAR 220	BAIRAKUR	13:00	13:04	0:03	LINE FAULT
901	3-Jun-19	BENGALURU	66	BAIRAKUR - KOLAR 220	BAIRAKUR	13:05	13:14	0:08	LINE FAULT
902	3-Jun-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	8:33	8:41	0:07	LINE FAULT
903	3-Jun-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	12:15	12:39	0:24	LINE CLEAR AVAILED
904	3-Jun-19	BENGALURU	66	GOWRIBIDANUR 220 - DB 2	THONDEBHAVI, MANCHENAHALLI	16:42	18:38	1:56	LINE FAULT
905	3-Jun-19	BENGALURU	66	HV2	GOWRIBIDANUR 220	14:00	14:15	0:15	TRANSFORMER FAULT
906	3-Jun-19	BENGALURU	66	HV2	JIGANI 66	16:15	16:20	0:05	LINE CLEAR AVAILED
907	3-Jun-19	BENGALURU	66	HV3	JIGANI 66	16:15	16:20	0:05	LINE CLEAR AVAILED
908	3-Jun-19	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	0:50	0:55	0:05	LINE FAULT
909	3-Jun-19	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	0:58	1:30	0:32	LINE FAULT
910	3-Jun-19	BENGALURU	66	KYALANUR - TALAGWARA	KYALANUR	8:30	8:35	0:05	LOAD CHANGE OVER
911	3-Jun-19	BENGALURU	66	HV2	SULIBELE	12:37	12:51	0:14	TRANSFORMER FAULT
912	3-Jun-19	BENGALURU	66	TG HALLY - ANCHEPALYA	TG HALLY	13:00	13:15	0:15	LOAD CHANGE OVER
913	3-Jun-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:05	12:23	0:18	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
914	3-Jun-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	12:05	12:23	0:18	LINE CLEAR AVAILED
915	3-Jun-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	14:03	16:26	2:23	LINE CLEAR AVAILED
916	3-Jun-19	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	19:39	20:35	0:56	LINE CLEAR AVAILED
917	3-Jun-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	19:39	20:47	1:08	MAIN SUPPLY FAILURE
918	3-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT)	19:39	20:42	1:03	MAIN SUPPLY FAILURE
919	3-Jun-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	19:39	20:35	0:56	MAIN SUPPLY FAILURE
920	3-Jun-19	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	19:39	20:45	1:06	MAIN SUPPLY FAILURE
921	3-Jun-19	BENGALURU	220	HV1	MALUR 220	19:39	20:38	0:59	MAIN SUPPLY FAILURE
922	3-Jun-19	BENGALURU	220	HV2	MALUR 220	19:39	20:38	0:59	MAIN SUPPLY FAILURE
923	3-Jun-19	BENGALURU	220	HV1	SARJAPURA 220	23:29	23:42	0:13	MAIN SUPPLY FAILURE
924	3-Jun-19	BENGALURU	220	HV2	SARJAPURA 220	23:29	23:42	0:13	MAIN SUPPLY FAILURE
925	3-Jun-19	BENGALURU	220	HV1	VIKAS TECH PARK 220	23:29	23:42	0:13	MAIN SUPPLY FAILURE
926	3-Jun-19	BENGALURU	220	HV2	VIKAS TECH PARK 220	23:29	23:42	0:13	MAIN SUPPLY FAILURE
927	3-Jun-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	23:29	23:52	0:23	MAIN SUPPLY FAILURE
928	3-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT)	23:29	23:52	0:23	MAIN SUPPLY FAILURE
929	3-Jun-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	23:29	23:42	0:13	MAIN SUPPLY FAILURE
930	3-Jun-19	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	23:29	23:52	0:23	MAIN SUPPLY FAILURE
931	3-Jun-19	BENGALURU	220	HV1	MALUR 220	23:29	23:42	0:13	MAIN SUPPLY FAILURE
932	3-Jun-19	BENGALURU	220	HV2	MALUR 220	23:29	23:42	0:13	MAIN SUPPLY FAILURE
933	3-Jun-19	BENGALURU	220	MALUR 220 - KOLAR 3	SARJAPURA 220, MALUR 220, VIKAS TECH PARK 220	23:29	23:42	0:13	MAIN SUPPLY FAILURE
934	3-Jun-19	BENGALURU	66	HV2	BAGMAME WTP	12:50	13:27	0:37	TRANSFORMER FAULT
935	3-Jun-19	BENGALURU	66	HV2	BAGMAME WTP	16:45	17:05	0:20	TRANSFORMER FAULT
936	3-Jun-19	BENGALURU	66	HV1	ABBIGERE	15:04	15:07	0:02	LINE CLEAR AVAILED
937	3-Jun-19	BENGALURU	66	HV1	ABBIGERE	16:10	16:16	0:06	LINE CLEAR AVAILED
938	3-Jun-19	BENGALURU	66	HV2	BIDADI 220	3:54	6:35	2:41	TRANSFORMER FAULT
939	3-Jun-19	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	13:06	13:31	0:25	LOAD CHANGE OVER
940	3-Jun-19	BENGALURU	66	HV1	BIDADI 220	13:12	13:25	0:12	LOAD CHANGE OVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
941	3-Jun-19	BENGALURU	66	HV2	BIDADI 220	13:12	13:18	0:06	LOAD CHANGE OVER
942	3-Jun-19	BENGALURU	220	HV2	BIDADI 220	13:04	13:18	0:14	TRANSFORMER FAULT
943	3-Jun-19	BENGALURU	66	BIDADI 220 - EPIPL (EHT)	EPIPL (EHT)	13:04	13:26	0:22	LINE FAULT
944	3-Jun-19	BENGALURU	66	BIDADI 220 - BOSCH (EHT)	BOSCH (EHT)	13:04	13:26	0:22	LINE FAULT
945	3-Jun-19	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	11:21	12:17	0:56	LINE CLEAR AVAILED
946	3-Jun-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	11:21	12:17	0:56	LINE CLEAR AVAILED
947	3-Jun-19	BENGALURU	66	NRS 220 - TELECOM LAYOUT	TELECOM LAYOUT	0:46	3:45	2:59	LINE CLEAR AVAILED
948	3-Jun-19	BENGALURU	66	HV2	LR BANDE	13:26	14:18	0:51	LINE CLEAR AVAILED
949	3-Jun-19	BENGALURU	66	HV1	NRS 220	0:46	3:42	2:55	LINE CLEAR AVAILED
950	3-Jun-19	BENGALURU	66	HV3	NRS 220	0:46	3:42	2:55	LINE CLEAR AVAILED
951	3-Jun-19	BENGALURU	66	HV4	NRS 220	0:46	3:42	2:55	LINE CLEAR AVAILED
952	3-Jun-19	BENGALURU	66	HV5	NRS 220	0:46	3:53	3:06	LINE CLEAR AVAILED
953	3-Jun-19	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, BIEC, NELAMANGALA 66	6:36	6:58	0:22	LINE FAULT
954	3-Jun-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	17:24	17:26	0:02	LINE CLEAR AVAILED
955	3-Jun-19	BENGALURU	66	ALUR - NELAMANAGALA 66	ALUR, BIEC	17:05	17:11	0:06	LOAD CHANGE OVER
956	3-Jun-19	BENGALURU	66	HV2	MAASTHI	13:12	15:55	2:43	LINE CLEAR AVAILED
957	3-Jun-19	BENGALURU	66	HV2	GUNDAMGERE	7:40	7:53	0:13	TRANSFORMER FAULT
958	3-Jun-19	BENGALURU	66	GUNDAMGERE - DB PURA 220	GUNDAMGERE	4:50	5:00	0:10	LINE FAULT
959	3-Jun-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	23:29	23:42	0:13	MAIN SUPPLY FAILURE
960	3-Jun-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	23:29	23:42	0:13	MAIN SUPPLY FAILURE
961	3-Jun-19	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	23:29	23:42	0:13	MAIN SUPPLY FAILURE
962	3-Jun-19	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	23:29	23:42	0:13	MAIN SUPPLY FAILURE
963	3-Jun-19	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	23:29	23:42	0:13	MAIN SUPPLY FAILURE
964	3-Jun-19	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	23:29	23:42	0:13	MAIN SUPPLY FAILURE
965	3-Jun-19	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, BIEC, NELAMANGALA 66	23:35	23:59	0:24	LINE FAULT
966	3-Jun-19	BENGALURU	66	HV1	CHIKKENAHALLI	16:20	16:30	0:10	LINE CLEAR AVAILED
967	3-Jun-19	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	0:00	9:46	9:46	LINE FAULT
968	3-Jun-19	GULBARGA	400	JSWVL-GUTTUR	GUTTUR_400	0:00	9:57	9:57	LINE CLEAR AVAILED
969	3-Jun-19	GULBARGA	220	ITTAGI-NEELGUNDA	NEELGUNDA_220	4:25	23:59	19:34	LINE FAULT
970	3-Jun-19	GULBARGA	220	HV1,HV2	ITTAGI_220	4:25	4:35	0:10	TRANSFORMER FAULT
971	3-Jun-19	GULBARGA	220	KAPNOOR-HUMNABAD1	HUMNABAD_220	21:26	23:59	2:33	LINE CLEAR AVAILED
972	3-Jun-19	GULBARGA	220	KAPNOOR-SHAHPUR1	KAPNOOR_220	21:42	23:59	2:17	LINE CLEAR AVAILED
973	3-Jun-19	GULBARGA	220	HUMNABAD-HALBARGA	HALBARGA_220	22:05	23:59	1:54	LINE CLEAR AVAILED
974	3-Jun-19	GULBARGA	110	HV3	BEVOOR_110	7:05	11:00	3:55	LINE CLEAR AVAILED
975	3-Jun-19	GULBARGA	110	KAPNOOR-GULBARGA NORTH1,2	GULBARGANORTH_110	16:43	17:19	0:36	LINE FAULT
976	3-Jun-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110	16:57	17:23	0:26	LINE FAULT
977	3-Jun-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110	17:59	18:29	0:30	LINE FAULT
978	3-Jun-19	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	8:49	8:56	0:07	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
979	3-Jun-19	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	19:15	19:20	0:05	LINE FAULT
980	3-Jun-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	16:11	16:22	0:11	LINE FAULT
981	3-Jun-19	GULBARGA	110	KOLHAR-SHHAI_SLR	KOLHAR_110	15:34	15:35	0:01	LINE FAULT
982	3-Jun-19	GULBARGA	110	KOLHAR-SHHAI_SLR	KOLHAR_110	15:36	16:50	1:14	LINE FAULT
983	3-Jun-19	GULBARGA	110	MARAGUTTI-CLNSLR_IPP	MARAGUTTI_110	20:20	20:35	0:15	LINE FAULT
984	3-Jun-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	8:33	8:51	0:18	LINE CLEAR AVAILED
985	3-Jun-19	GULBARGA	110	RAICHUR-SHAHPUR1,2	GABBUR_110,DEODURGA_110,GOOGLE_110	11:47	19:41	7:54	LINE CLEAR AVAILED
986	3-Jun-19	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	11:47	23:59	12:12	LINE CLEAR AVAILED
987	3-Jun-19	GULBARGA	110	SHAKTHI NAGAR-RAICHURBIO	SHAKTHINAGAR_110	22:37	22:45	0:08	LINE FAULT
988	3-Jun-19	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL_110	11:47	13:55	2:08	LINE CLEAR AVAILED
989	3-Jun-19	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	5:45	9:25	3:40	LINE CLEAR AVAILED
990	3-Jun-19	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	5:50	11:15	5:25	LINE CLEAR AVAILED
991	3-Jun-19	GULBARGA	110	HV2,LV2	KUSHTAGI_220	10:30	10:38	0:08	TRANSFORMER FAULT
992	3-Jun-19	GULBARGA	110	HV1	SEDAM_220	21:55	22:30	0:35	LINE CLEAR AVAILED
993	3-Jun-19	GULBARGA	110	HV1	SEDAM_220	22:35	22:45	0:10	LINE CLEAR AVAILED
994	3-Jun-19	GULBARGA	66	ITTAGI-CLEANMAX2	ITTAGI_220	8:50	8:58	0:08	LINE CLEAR AVAILED
995	3-Jun-19	GULBARGA	66	ITTAGI-RENWSLR2	ITTAGI_220	8:50	9:20	0:30	LINE CLEAR AVAILED
996	3-Jun-19	GULBARGA	66	ITTAGI-BENNEHALLI	BENNEHALLI_66	10:30	10:52	0:22	LINE CLEAR AVAILED
997	3-Jun-19	GULBARGA	66	HV1	HAMPASAGAR_66	19:00	19:15	0:15	TRANSFORMER FAULT
998	3-Jun-19	GULBARGA	66	KOGALI-ASTROSLR	KOGALI_66	8:56	9:35	0:39	LINE CLEAR AVAILED
999	3-Jun-19	GULBARGA	66	UPANAYAKANAHALLI-MUNIRABAD	UPANAYAKANAHALLI_66	4:12	4:16	0:04	LINE CLEAR AVAILED
1000	3-Jun-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	1:30	8:10	6:40	LINE CLEAR AVAILED
1001	3-Jun-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	7:20	14:27	7:07	LINE CLEAR AVAILED
1002	3-Jun-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	3:53	3:53	LINE CLEAR AVAILED
1003	3-Jun-19	HASSAN	220	GER SOPA-TALGUPA1	gerusoppa_gen	7:23	14:25	7:02	LINE CLEAR AVAILED
1004	3-Jun-19	HASSAN	220	GER SOA-TALGUPA2	gerusoppa_gen	7:21	14:29	7:08	LINE CLEAR AVAILED
1005	3-Jun-19	HASSAN	220	HV2	KEMAR_220	5:04	8:42	3:38	LINE CLEAR AVAILED
1006	3-Jun-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	10:17	13:40	3:23	LINE CLEAR AVAILED
1007	3-Jun-19	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	5:23	13:01	7:38	LINE CLEAR AVAILED
1008	3-Jun-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	7:23	14:20	6:57	LINE CLEAR AVAILED
1009	3-Jun-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:22	23:59	12:37	LINE CLEAR AVAILED
1010	3-Jun-19	HASSAN	220	MSEZ-KEMAR2	MSEZ-220	10:24	13:42	3:18	NFBC ISSUED
1011	3-Jun-19	HASSAN	220	HV1	PUTTUR_110	5:30	13:01	7:31	NFBC ISSUED
1012	3-Jun-19	HASSAN	220	SHRAV TY-SHIMO GA4	sharavathy_gen	6:00	23:59	17:59	LINE CLEAR AVAILED
1013	3-Jun-19	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	13:06	15:02	1:56	MAIN SUPPLY FAILURE
1014	3-Jun-19	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	13:06	14:57	1:51	MAIN SUPPLY FAILURE
1015	3-Jun-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	13:06	15:01	1:55	MAIN SUPPLY FAILURE
1016	3-Jun-19	HASSAN	110	HOSNGA-HULIKAL	HOSANGADI_110	13:07	15:03	1:56	MAIN SUPPLY FAILURE
1017	3-Jun-19	HASSAN	110	HOSNGA-VTRG1	HOSANGADI_110	9:38	17:25	7:47	LINE CLEAR AVAILED
1018	3-Jun-19	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	13:04	14:53	1:49	LINE CLEAR AVAILED
1019	3-Jun-19	HASSAN	110	HV2	SHIKARIPURA_110	15:26	17:57	2:31	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1020	3-Jun-19	HASSAN	110	LV2	KEMAR_220	5:04	8:42	3:38	TRANSFORMER FAULT
1021	3-Jun-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	1:46	3:03	1:17	LINE FAULT
1022	3-Jun-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	3:04	12:58	9:54	LINE FAULT
1023	3-Jun-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	3:04	3:14	0:10	LINE FAULT
1024	3-Jun-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	11:03	11:35	0:32	NFBC ISSUED
1025	3-Jun-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	11:04	11:31	0:27	LINE CLEAR AVAILED
1026	3-Jun-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	19:20	19:40	0:20	LINE FAULT
1027	3-Jun-19	HASSAN	66	HV2	RAMPURA_66	14:19	14:42	0:23	LINE CLEAR AVAILED
1028	3-Jun-19	HASSAN	66	SAKALE-IPCL1	SAKLESHUPURA_66	18:45	18:49	0:04	LINE CLEAR AVAILED
1029	3-Jun-19	HASSAN	66	SAKALE-IPCL2	SAKLESHUPURA_66	8:49	18:45	9:56	LINE CLEAR AVAILED
1030	3-Jun-19	MYSORE	66	COWDALLI-MARTHALLI	MARTAHALLI_66 RAMAPURA_MYS_66	10:05	10:11	0:05	LINE FAULT
1031	3-Jun-19	MYSORE	66	HV1	GUNDULPET_66	13:45	23:59	10:14	LINE CLEAR AVAILED
1032	3-Jun-19	MYSORE	66	HV2	GUNDULPET_66	12:11	14:23	2:11	LINE CLEAR AVAILED
1033	3-Jun-19	MYSORE	66	HV2	GUNDULPET_66	15:35	16:15	0:40	LINE CLEAR AVAILED
1034	3-Jun-19	MYSORE	66	HANNUR-KOTTANUR	KOTTANUR_66	10:05	10:15	0:10	LINE FAULT
1035	3-Jun-19	MYSORE	66	HANNUR-MADHUVANAHALLI 2	BANDALLI_66 COWDALLI_66 HANNUR_66 MARTAHALLI_66 RAMAPURA_MYS_66	13:40	13:50	0:10	LINE FAULT
1036	3-Jun-19	MYSORE	66	HANNUR-KOTTANUR	KOTTANUR_66	13:40	13:50	0:10	LINE FAULT
1037	3-Jun-19	MYSORE	220	HV2	MADHUVANAHALLI_220	13:38	14:28	0:50	TRANSFORMER FAULT
1038	3-Jun-19	MYSORE	66	MIRLE-KR NAGARA	MIRLE_66	9:49	11:20	1:30	LINE CLEAR AVAILED
1039	3-Jun-19	TUMKUR	220	TR-1(HV SIDE)	ANTHRASANAHALLI_220	12:06	14:06	2:00	LINE CLEAR AVAILED
1040	3-Jun-19	TUMKUR	220	ANTHRASANAHALLI 220kV- NELAMANGALA	ANTHRASANAHALLI_220	0:24	7:49	7:24	LINE FAULT
1041	3-Jun-19	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	0:24	7:41	7:16	LINE FAULT
1042	3-Jun-19	TUMKUR	220	TR-2(HV SIDE)	MADHUGIRI_220	6:00	10:56	4:56	TRANSFORMER FAULT
1043	3-Jun-19	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA_220 1	MADHUGIRI 220kV	6:02	6:25	0:22	LINE FAULT
1044	3-Jun-19	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA_220 2	MADHUGIRI 220kV	6:06	10:53	4:47	LINE FAULT
1045	3-Jun-19	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	2:51	3:04	0:12	LINE FAULT
1046	3-Jun-19	TUMKUR	110	TR-2	TIPTUR_110	15:29	15:41	0:11	TRANSFORMER FAULT
1047	3-Jun-19	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	ANCHEPALYA_220	6:53	7:06	0:12	LINE FAULT
1048	3-Jun-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	7:05	7:21	0:15	LINE FAULT
1049	3-Jun-19	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	12:06	14:08	2:01	LINE CLEAR AVAILED
1050	3-Jun-19	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 3	CHITRADURGA_66	9:29	9:49	0:20	LINE CLEAR AVAILED
1051	3-Jun-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	9:53	10:52	0:59	LINE FAULT
1052	3-Jun-19	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	1:56	5:41	3:44	LINE FAULT



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1053	3-Jun-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	1:48	6:20	4:32	LINE FAULT
1054	3-Jun-19	TUMKUR	66	TR-1	HALUVAGALU_66	13:07	19:44	6:37	LINE CLEAR AVAILED
1055	3-Jun-19	TUMKUR	66	TR-1	IDHALLY_66	13:38	13:59	0:21	HAND TRIPPED
1056	3-Jun-19	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR_IPP_66	BPCLSOLAR_IPP_66	15:48	16:16	0:28	LINE FAULT
1057	3-Jun-19	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR_IPP_66	TATA SOLAR_IPP_66	15:48	16:30	0:42	LINE FAULT
1058	3-Jun-19	TUMKUR	66	TR-2(LV-2)	MADHUGIRI_220	7:28	10:58	3:30	TRANSFORMER FAULT
1059	3-Jun-19	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	AVNTI_SLR_IPP_66	9:59	10:07	0:08	HAND TRIPPED
1060	3-Jun-19	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	10:17	11:35	1:17	LINE CLEAR AVAILED
1061	3-Jun-19	TUMKUR	66	TR-1	MATHOD_66	16:47	19:08	2:20	LINE CLEAR AVAILED
1062	3-Jun-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	0:23	0:39	0:16	LINE FAULT
1063	3-Jun-19	TUMKUR	66	TR-1	NYAMATHI_66	17:47	18:01	0:14	TRANSFORMER FAULT
1064	3-Jun-19	TUMKUR	66	TR-1	SAVALANGA_66	1:34	7:55	6:21	MAIN SUPPLY FAILURE
1065	3-Jun-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	7:45	8:30	0:45	LINE FAULT
1066	3-Jun-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:32	14:32	5:00	LINE FAULT
1067	3-Jun-19	TUMKUR	66	TR-2	THIMMASANDRA_66	8:41	10:01	1:20	TRANSFORMER FAULT