

400/220/110/66 kV TRANSMISSION OUTAGES FROM:30.11.21 TO 06.12.21

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	30-Nov-21	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	4:30 (10.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
2	30-Nov-21	BAGALKOT	110	110/11KV, HV1	ALBAL_110	11:19	11:30	0:11	TRANSFORMER FAULT
3	30-Nov-21	BAGALKOT	110	110/11KV,HV2	SHIROL_110	12:10	14:00	1:50	LINE CLEAR AVAILED
4	30-Nov-21	BAGALKOT	110	110/33KV,HV1	GADDANAKERI_33,KATAGE RI_33 BAGALKOT_220	15:10	17:03	1:53	LINE CLEAR AVAILED
5	30-Nov-21	BAGALKOT	110	AMBEWADI- NK1	AMBEWADI_220	1:12	16:41	15:29	LINE FAULT
6	30-Nov-21	BAGALKOT	110	BAGALKOT220- KERUR	KERUR_110	11:20	14:03	2:43	NFBC ISSUED
7	30-Nov-21	BAGALKOT	110	BAGALKOT-KERUR	BAGALKOT_220	11:30	14:03	2:33	LINE CLEAR AVAILED
8	30-Nov-21	BAGALKOT	110	BAGALKOT-LOKAPUR	BAGALKOT_220	13:34	14:50	1:16	LINE CLEAR AVAILED
9	30-Nov-21	BAGALKOT	110	BELGAUM-VADAGOAN	VADAGOAN_110	9:01	13:22	4:21	LINE CLEAR AVAILED
10	30-Nov-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
11	30-Nov-21	BAGALKOT	110	HIREHAL- IDLE (BADAMI)	HIREHAL_110	10:55	11:21	0:26	HAND TRIPPED
12	30-Nov-21	BAGALKOT	110	HUBLI 1(ESALE)-SIRSI	SIRSI_110	18:21 (28.11.2021)			LINE OPEN:LINE CLEAR AVAILED
13	30-Nov-21	BAGALKOT	110	HUNGUND- BAGEWADI (KUDAL SANGAM)	HUNGUND_110	7:05	7:15	0:10	LINE FAULT
14	30-Nov-21	BAGALKOT	110	KERUR- BADAMI	KERUR_110	11:20	14:20	3:00	LINE CLEAR AVAILED
15	30-Nov-21	BAGALKOT	110	LOKAPUR- BAGALKOT220	LOKAPUR_110	13:35	17:15	3:40	NFBC ISSUED
16	30-Nov-21	BAGALKOT	110	LOKAPUR- VAJRAMATTI220	LOKAPUR_110	13:20	13:27	0:07	HAND TRIPPED
17	30-Nov-21	BAGALKOT	110	MKHUBLI220-MKHUBLI1	MKHUBLI_220	13:38 (28.11.2021)			LINE OPEN:LINE CLEAR AVAILED
18	30-Nov-21	BAGALKOT	110	RANEENNUR- RATTIHALLI (TUMMINAKATTI)	RANEENNUR_220	8:15	13:52	5:37	LINE CLEAR AVAILED
19	30-Nov-21	BAGALKOT	110	RANEENNUR-HIREKERUR	RANEENNUR_220	8:58 (29.11.2021)			LINE OPEN:LINE CLEAR AVAILED
20	30-Nov-21	BAGALKOT	110	RANEENNUR- TUMMINAKATTE	TUMMINAKATTE_110	8:12	13:56	5:44	LINE CLEAR AVAILED
21	30-Nov-21	BAGALKOT	110	SOUDATTI-MMCL	SOUNDATTI_220	16:13	17:50	1:37	LINE CLEAR AVAILED
22	30-Nov-21	BAGALKOT	220	220/110KV, HV1& LV1	GHATAPRABHA_220	11:38	12:41	1:03	LINE CLEAR AVAILED
23	30-Nov-21	BAGALKOT	220	220/110KV, HV2& LV2	GHATAPRABHA_220	13:08	14:43	1:35	LINE CLEAR AVAILED
24	30-Nov-21	BAGALKOT	220	220/110KV,HV1,LV1	SOUNDATTI_220	10:12	18:10	7:58	LINE CLEAR AVAILED
25	30-Nov-21	BAGALKOT	220	BAGEWADI- FORTUNE FIVE2	BAGEWADI_220	16:42	17:10	0:28	LINE CLEAR AVAILED
26	30-Nov-21	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
27	30-Nov-21	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
28	30-Nov-21	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	23:16 (29.11.2021)	8:06 (30.11.2021)	8:50 hrs	LINE CHARGED
29	30-Nov-21	BAGALKOT	220	BELGAUM-KANABARGI2 (NARENDRA2)	BELGAUM_220	23:37 (29.11.2021)	8:06 (30.11.2021)	8:29 hrs	LINE CHARGED
30	30-Nov-21	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
31	30-Nov-21	BAGALKOT	220	HAVERI- NARENDRA	HAVERI_220	10:19 (31.11.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
32	30-Nov-21	BAGALKOT	220	HAVERI-BIDNAL	HAVERI_220	10:12 (30.11.2021)			LINE OPEN:LINE CLEAR AVAILED
33	30-Nov-21	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
34	30-Nov-21	BAGALKOT	220	MUGALKHOD- GHATAPRABHA2	MUGALKHOD_220	10:25	13:06	2:41	LINE CLEAR AVAILED
35	30-Nov-21	BAGALKOT	220	MUGALKHOD- GHATAPRABHA2	MUGALKHOD_220	10:25	13:06	2:41	LINE CLEAR AVAILED
36	30-Nov-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
37	30-Nov-21	BAGALKOT	220	NARENDRA-BIDNAL	NARENDRA_220	14:44	15:14	0:30	LINE CLEAR AVAILED
38	30-Nov-21	BAGALKOT	220	NARENDRA-HAVERI	NARENDRA_220	10:19 (31.11.2021)			LINE OPEN:LINE CLEAR AVAILED
39	30-Nov-21	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	16:20 (17.11.2021)			LINE OPEN:LINE CLEAR AVAILED
40	30-Nov-21	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	16:20 (24.11.2021)			LINE OPEN:LINE CLEAR AVAILED
41	30-Nov-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
42	30-Nov-21	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
43	30-Nov-21	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	6:14	6:31	0:17	LINE FAULT
44	30-Nov-21	BENGALURU	66	HENNUR CROSS - SAHAKARNAGAR	HENNUR CROSS	9:05	9:10	0:05	LOAD CHANGEOVER
45	30-Nov-21	BENGALURU	66	HV1	NGHULKUR	13:00	13:47	0:47	LINE CLEAR AVAILED
46	30-Nov-21	BENGALURU	66	HV1	GODURU	12:04	14:40	2:35	LINE CLEAR AVAILED
47	30-Nov-21	BENGALURU	66	HV1	AMARIYOTHI	10:45	10:58	0:12	LOAD CHANGEOVER
48	30-Nov-21	BENGALURU	66	HV1	BMTC	12:04	14:08	2:03	LINE CLEAR AVAILED
49	30-Nov-21	BENGALURU	66	HV1	ISRO LAYOUT	12:08	12:11	0:02	LOAD CHANGEOVER
50	30-Nov-21	BENGALURU	66	HV2	DOMMASANDRA	9:25	9:30	0:05	LINE CLEAR AVAILED
51	30-Nov-21	BENGALURU	66	HV2	HAL 220	9:08	9:30	0:21	TRANSFORMER FAULT
52	30-Nov-21	BENGALURU	66	ISKON - SOMANAHALLI 220	ISKON	12:03	12:05	0:02	LOAD CHANGEOVER
53	30-Nov-21	BENGALURU	66	ISKON - SUBRAMANYAPURA 220	ISKON	15:05	15:15	0:10	LOAD CHANGEOVER
54	30-Nov-21	BENGALURU	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	7:11	7:51	0:40	MAIN SUPPLY FAILURE
55	30-Nov-21	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	7:11	7:51	0:40	MAIN SUPPLY FAILURE
56	30-Nov-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU	7:11	8:20	1:09	MAIN SUPPLY FAILURE
57	30-Nov-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	7:11	7:51	0:40	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
58	30-Nov-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJAHALLI, KUNUR	7:11	7:51	0:40	MAIN SUPPLY FAILURE
59	30-Nov-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	ACHALU, HONNIGANAHALLI, HALAGUR, DODDALAHALLI	7:11	8:00	0:49	MAIN SUPPLY FAILURE
60	30-Nov-21	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	6:18	6:26	0:07	LINE FAULT
61	30-Nov-21	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
62	30-Nov-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	6:38	6:43	0:05	LINE FAULT
63	30-Nov-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	15:29	15:35	0:06	LINE FAULT
64	30-Nov-21	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	16:31	16:44	0:13	LOAD CHANGEOVER
65	30-Nov-21	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	12:02	12:08	0:06	LOAD CHANGEOVER
66	30-Nov-21	BENGALURU	220	KOTHIPURA 220 - TUBINKERE	NO STATION AFFECTED	8:57	10:12	1:15	LINE FAULT
67	30-Nov-21	BENGALURU	220	KOTHIPURA 220 - TUBINKERE	NO STATION AFFECTED	10:17	10:47	0:30	LINE FAULT
68	30-Nov-21	BENGALURU	220	KOTHIPURA 220 - TUBINKERE	NO STATION AFFECTED	12:52	13:23	0:31	LINE FAULT
69	30-Nov-21	BENGALURU	220	SOMANAHALLI 220 - HAROHALLI BWSSB (EHT)	HAROHALLI BWSSB (EHT), KANAKAPURA 220	7:11	10:36	3:25	LINE FAULT
70	30-Nov-21	BENGALURU	220	SOMANAHALLI 220 - HAROHALLI BWSSB (EHT)	HAROHALLI BWSSB (EHT)	11:38	11:48	0:10	LINE CLEAR AVAILED
71	30-Nov-21	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
72	30-Nov-21	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	4:55	5:05	0:10	MAIN SUPPLY FAILURE
73	30-Nov-21	GULBARGA	110	CHINCHOLI-SEDAM1	CHINCHOLI_110	6:28	6:35	0:07	LINE FAULT
74	30-Nov-21	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	6:20	6:25	0:05	LINE FAULT
75	30-Nov-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DIGGI_110,DONGARGAON_110	7:59	12:05	4:06	NFBC ISSUED
76	30-Nov-21	GULBARGA	110	HV1	GALAG_110	12:15	12:20	0:05	TRANSFORMER FAULT
77	30-Nov-21	GULBARGA	110	HV3	CHINCHOLI_110	6:28	7:05	0:37	TRANSFORMER FAULT
78	30-Nov-21	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	7:53	12:13	4:20	LINE CLEAR AVAILED
79	30-Nov-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	17:25	17:30	0:05	LINE FAULT
80	30-Nov-21	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDI NNI_110	23:50(29.11.2021)	00:10(30.11.2021)	00:20HRS	LINE CHARGED
81	30-Nov-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110,ADAVI AMARESHWAR_110,	4:51	5:02	0:11	LINE FAULT
82	30-Nov-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
83	30-Nov-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
84	30-Nov-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGURS_IPP,ASKI_IPP,HUN SAGI_110	10:11	12:57	2:46	LINE CLEAR AVAILED
85	30-Nov-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	4:23	4:28	0:05	MAIN SUPPLY FAILURE
86	30-Nov-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YERADON A_110,BENNUR_110,BTPS WATER WORKS,KAMPLI_110	13:33	13:43	0:10	LINE FAULT
87	30-Nov-21	GULBARGA	110	YELBURGA-TALTSRLR_IPP	YELBURGA_110	12:40	12:43	0:03	LOAD CURTAILMENT
88	30-Nov-21	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	13:35	13:45	0:10	MAIN SUPPLY FAILURE
89	30-Nov-21	GULBARGA	220	HUMNABAD-KAPNOOR	HUMNABAD_220	0:32	9:35	9:03	LINE CHARGED
90	30-Nov-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
91	30-Nov-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	4:59	5:23	0:24	LINE FAULT
92	30-Nov-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:02 (29.11.2021)	7:45 (30.11.2021)	10:43 HRS	LINE CHARGED
93	30-Nov-21	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	12:05	12:26	0:21	LINE FAULT
94	30-Nov-21	HASSAN	66	HV1	DODDAKADNUR_66	12:41	13:55	1:14	LINE CLEAR AVAILED
95	30-Nov-21	HASSAN	66	HV1	HALEBEEDU_66	12:00	13:30	1:30	LINE CLEAR AVAILED
96	30-Nov-21	HASSAN	66	HV2	HALEBEEDU_66	11:55	12:50	0:55	LINE CLEAR AVAILED
97	30-Nov-21	HASSAN	110	HV1	GURUPUR	11:14	13:36	2:22	LINE CLEAR AVAILED
98	30-Nov-21	HASSAN	110	HV1	MSEZ_220	10:32	13:17	2:45	LINE CLEAR AVAILED
99	30-Nov-21	HASSAN	110	HV2	ARASIKERE_110	11:15	11:30	0:15	LINE CLEAR AVAILED
100	30-Nov-21	HASSAN	110	HV2	KADUR_220	11:15	11:33	0:18	TRANSFORMER FAULT
101	30-Nov-21	HASSAN	110	KADUR-TNGL	KADUR_220	11:14	12:05	0:51	LINE FAULT
102	30-Nov-21	HASSAN	110	KADUR-YGTI	KADUR_220	11:14	12:12	0:58	LINE FAULT
103	30-Nov-21	HASSAN	110	LPH-LST4	lph_gen	9:00	9:20	0:20	HAND TRIPPED
104	30-Nov-21	HASSAN	110	LV1	MSEZ_220	10:32	13:17	2:45	LINE CLEAR AVAILED
105	30-Nov-21	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:06	14:15	4:09	NFBC ISSUED
106	30-Nov-21	HASSAN	220	KEMAR-Varahi1	KEMAR_220	18:54	19:10	0:16	LINE FAULT
107	30-Nov-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:06	14:15	4:09	LINE CLEAR AVAILED
108	30-Nov-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	18:54	19:10	0:16	LINE FAULT
109	30-Nov-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:28(26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
110	30-Nov-21	MYSORE	66	CR NAGARA-BADANGUPPE2	BANDANGUPPE_66	9:09	16:08	6:59	NFBC ISSUED
111	30-Nov-21	MYSORE	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	10:41	16:45	6:03	LINE CLEAR AVAILED
112	30-Nov-21	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	10:49	10:59	0:10	LINE FAULT
113	30-Nov-21	MYSORE	66	DATAGALLI-HOOTGALLI	NO STATIONS EFFECTED	10:41	12:24	1:42	NFBC ISSUED
114	30-Nov-21	MYSORE	66	FTS-HOOTGALLI 2	NO STATIONS EFFECTED	9:30:01(30.10.2021)			LINE OPEN:LINE CLEAR AVAILED
115	30-Nov-21	MYSORE	66	HARADANAHALLI(JAK)-LAXJEET	NO STATIONS EFFECTED	6:32	6:37	0:04	LINE FAULT
116	30-Nov-21	MYSORE	66	HV1	HAMPAPURA_66	11:10	14:37	3:26	LINE CLEAR AVAILED
117	30-Nov-21	MYSORE	66	HV1	KABHALLY_66	12:43	13:06	0:22	HAND TRIPPED
118	30-Nov-21	MYSORE	66	HV1	MADDUR_66	9:53	9:58	0:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
119	30-Nov-21	MYSORE	66	HV1	MADDUR_66	10:04	11:00	0:55	TRANSFORMER FAULT
120	30-Nov-21	MYSORE	66	HV1	MADDUR_66	11:10	13:30	2:19	LINE CLEAR AVAILED
121	30-Nov-21	MYSORE	66	HV1	MADDUR_66	14:05	18:21	4:16	TRANSFORMER FAULT
122	30-Nov-21	MYSORE	66	HV2	HANNUR_66	10:40	12:22	1:42	LINE CLEAR AVAILED
123	30-Nov-21	MYSORE	66	HV2	TUBINKERE_220	12:21	13:33	1:11	LINE CLEAR AVAILED
124	30-Nov-21	MYSORE	66	KABHALLY-CR NAGARA	NO STATIONS EFFECTED	12:45	12:50	0:05	LINE FAULT
125	30-Nov-21	MYSORE	66	KABHALLY-GUNDULPETE	NO STATIONS EFFECTED	12:45	12:50	0:05	LINE FAULT
126	30-Nov-21	MYSORE	66	KR PETE 220- CHANRAYPATNA	NO STATIONS EFFECTED	14:26	15:51	1:24	LINE CLEAR AVAILED
127	30-Nov-21	MYSORE	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30(24.10.2021)			LINE OPEN:LINE CLEAR AVAILED
128	30-Nov-21	MYSORE	66	RK NAGAR-DATTAGALLI	NO STATIONS EFFECTED	19:12:42(15.11.2021)	10:41:09(30.11.2021)	332:28 hrs	LINE CHARGED
129	30-Nov-21	MYSORE	66	VAJMANGALA-BANNUR	NO STATIONS EFFECTED	16:06	16:16	0:10	LINE FAULT
130	30-Nov-21	MYSORE	220	CR NAGARA-BEGUR1	NO STATIONS EFFECTED	14:24	15:20	0:56	LINE CLEAR AVAILED
131	30-Nov-21	MYSORE	220	CR NAGARA-BEGUR2	NO STATIONS EFFECTED	15:30	16:45	1:15	LINE CLEAR AVAILED
132	30-Nov-21	MYSORE	220	KADAKOLA-CR NAGARA1	NO STATIONS EFFECTED	10:33	11:50	1:17	NFBC ISSUED
133	30-Nov-21	MYSORE	220	TUBINKERE-KOTTHIPURA1	NO STATIONS EFFECTED	10:17:00 (30.11.2021)			LINE OPEN:LINE FAULT
134	30-Nov-21	MYSORE	220	TUBINKERE-KOTTHIPURA2	NO STATIONS EFFECTED	8:52	10:10	1:18	LINE FAULT
135	30-Nov-21	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	JIDDIGERE_66, YEDIYUR_66	17:00	17:12	0:11	LINE FAULT
136	30-Nov-21	TUMKUR	66	DAVANGERE SRS- AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKAT TE_66,KADAJJI_66	10:01	17:11	7:10	LINE CLEAR AVAILED
137	30-Nov-21	TUMKUR	66	DAVANGERE220kV- DAVANGERE SRS	DAVANAGERE_66	11:34	11:50	0:15	LINE FAULT
138	30-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:10	6:17	0:06	LINE FAULT
139	30-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:22	10:33	0:10	LINE FAULT
140	30-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:51	11:22	0:31	LINE FAULT
141	30-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	13:33	13:39	0:05	LINE FAULT
142	30-Nov-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	PANDRAHALLI2	12:11	12:40	0:29	MAIN SUPPLY FAILURE
143	30-Nov-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	6:55	7:05	0:09	LINE FAULT
144	30-Nov-21	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66	12:25	12:33	0:08	LINE FAULT
145	30-Nov-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	JAVAGONDANAHALLI_66	12:15	12:17	0:02	LINE FAULT
146	30-Nov-21	TUMKUR	66	KORATAGERE- HOLAVANHALLI	HOLAVINAHALLI_66,	15:37	16:11	0:34	LOAD CURTAILMENT
147	30-Nov-21	TUMKUR	66	MADANAYAKANAHALLI- TURUVANUR	MADANAYAKANAHALLI_66 ,	19:20	19:46	0:26	LINE FAULT
148	30-Nov-21	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	11:06	11:13	0:07	LINE FAULT
149	30-Nov-21	TUMKUR	66	SASALUHALLA-MAYAKONDA	SAVALANGA_66	10:36	10:54	0:17	MAIN SUPPLY FAILURE
150	30-Nov-21	TUMKUR	66	TR-1(HV & LV SIDE)	HAGALWADI_66	9:01	15:58	6:57	LINE CLEAR AVAILED
151	30-Nov-21	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	11:39	14:10	2:30	LINE CLEAR AVAILED
152	30-Nov-21	TUMKUR	110	TR-2(HV SIDE)	KBCROSS_220	13:13	14:09	0:55	LINE CLEAR AVAILED
153	30-Nov-21	TUMKUR	110	TR-3(HV SIDE)	AMMASANDRA_110	14:36	17:01	2:25	LINE CLEAR AVAILED
154	30-Nov-21	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	3:54	12:28	8:33	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
155	1-Dec-21	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	4:30 (10.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
156	1-Dec-21	BAGALKOT	110	110/11KV, HV1	UKKALI_110	15:02	15:45	0:43	LINE CLEAR AVAILED
157	1-Dec-21	BAGALKOT	110	110/11KV, HV4	HUBLI_220	10:09	14:57	4:48	LINE CLEAR AVAILED
158	1-Dec-21	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	13:30	18:13	4:43	LINE CLEAR AVAILED
159	1-Dec-21	BAGALKOT	110	110/11KV,HV1	KUDACHI_220	15:00	15:26	0:26	TRANSFORMER FAULT
160	1-Dec-21	BAGALKOT	110	110/11KV,HV1	VAJRAMATTI_220	15:32	17:45	2:13	LINE CLEAR AVAILED
161	1-Dec-21	BAGALKOT	110	110/11KV,HV1	AMBEWADI_220	10:20	11:21	1:01	LINE CLEAR AVAILED
162	1-Dec-21	BAGALKOT	110	110/11KV,HV2	ALMEL_110	11:15	11:30	0:15	HAND TRIPPED
163	1-Dec-21	BAGALKOT	110	110/33KV,HV3	LAKAMANAHALLI_110	8:11	8:40	0:29	TRANSFORMER FAULT
164	1-Dec-21	BAGALKOT	110	110/33KV,HV3	LAKAMANAHALLI_110	11:06	13:40	2:34	TRANSFORMER FAULT
165	1-Dec-21	BAGALKOT	110	110/33KV,HV3	LAKAMANAHALLI_110	13:40	19:25	5:45	LINE CLEAR AVAILED
166	1-Dec-21	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110 &ALNAVAR_33	13:40	19:25	5:45	LINE CLEAR AVAILED
167	1-Dec-21	BAGALKOT	110	220/110KV,LV 1	MK HUBLI_220	0:02	6:36	6:34	LINE CLEAR AVAILED
168	1-Dec-21	BAGALKOT	110	220/110KV,LV 2	MK HUBLI_220	0:06	8:05	7:59	LINE CLEAR AVAILED
169	1-Dec-21	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110	14:59	15:38	0:39	LINE FAULT
170	1-Dec-21	BAGALKOT	110	AMBEWADI-NK-1	AMBEWADI_220	8:47	18:50	10:03	LINE CLEAR AVAILED
171	1-Dec-21	BAGALKOT	110	AMBEWADI-NK-2	AMBEWADI_220	8:47	18:50	10:03	LINE CLEAR AVAILED
172	1-Dec-21	BAGALKOT	110	CHIKKODI220- NIPPANI(KADAKLAT)	CHIKKODI_220	22:0 (01.12.2021)			LINE OPEN:LINE FAULT
173	1-Dec-21	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA2	GHATAPRABHA_220	23:36 (01.12.2021)			LINE OPEN:LINE FAULT
174	1-Dec-21	BAGALKOT	110	GHATAPRABHA220-MANTUR	GHATAPRABHA_220	12:00	14:45	2:45	LINE CLEAR AVAILED
175	1-Dec-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
176	1-Dec-21	BAGALKOT	110	HAVERI220- SAVANUR	HAVERI_220	22:52	23:18	4:04	LINE FAULT
177	1-Dec-21	BAGALKOT	110	HUBLI 1(ESALE)-SIRSI	SIRSI_110	18:21 (28.11.2021)			LINE OPEN:LINE CLEAR AVAILED
178	1-Dec-21	BAGALKOT	110	KUDACHI220-AINAPUR	AINAPUR_110	15:07	15:38	0:31	HAND TRIPPED
179	1-Dec-21	BAGALKOT	110	KUDACHI220-KUDACHI	KUDACHI_110	15:07	15:34	0:27	HAND TRIPPED
180	1-Dec-21	BAGALKOT	110	KUDACHI220-TERADAL	TERADAL_110	15:00	15:32	0:32	LINE FAULT
181	1-Dec-21	BAGALKOT	110	KUDACHI220-UGAR KHUD	UGAR KHUD_110	15:09	15:58	0:49	HAND TRIPPED
182	1-Dec-21	BAGALKOT	110	MKHUBLI220-MKHUBLI1	MKHUBLI_220	13:38 (28.11.2021)	14:03 (01.12.2021)	72:25 hrs	LINE CHARGED
183	1-Dec-21	BAGALKOT	110	RANEENNUR-HIREKERUR	RANEENNUR_220	8:58 (29.11.2021)	15:15 (01.12.2021)	54:17 hrs	LINE CHARGED
184	1-Dec-21	BAGALKOT	110	SAVANUR- ASF SOLAR	SAVANUR_110	23:23	23:29	0:06	LINE FAULT
185	1-Dec-21	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	VAJRAMATTI_220	13:45	15:00	1:15	LINE CLEAR AVAILED
186	1-Dec-21	BAGALKOT	110	VAJRAMATTI220-MANTUR1	VAJRAMATTI_220	10:20	13:30	3:04	LINE CLEAR AVAILED
187	1-Dec-21	BAGALKOT	110	VAJRAMATTI-HALKI	HALKI_110	11:45	12:00	0:15	MAIN SUPPLY FAILURE
188	1-Dec-21	BAGALKOT	110	VAJRAMATTI-HALKI	HALKI_110	14:00	14:15	0:15	MAIN SUPPLY FAILURE
189	1-Dec-21	BAGALKOT	110	VAJRAMATTI-MANTUR(KD JAMBAGI)	VAJRAMATTI_220	11:45	14:10	2:25	LINE CLEAR AVAILED
190	1-Dec-21	BAGALKOT	220	220/110KV, HV1&LV1	SOUDATTI_220	16:21	18:19	1:58	LINE CLEAR AVAILED
191	1-Dec-21	BAGALKOT	220	220/110KV,HV1 &LV1	KUDACHI_220	15:12	15:17	0:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
192	1-Dec-21	BAGALKOT	220	220/110KV,HV1&LV1	SOUNDATTI_220	8:20	8:54	0:34	LINE CLEAR AVAILED
193	1-Dec-21	BAGALKOT	220	220/110KV,HV2 & LV2	KUDACHI_220	15:12	15:18	0:06	TRANSFORMER FAULT
194	1-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
195	1-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
196	1-Dec-21	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	22:04	23:29	1:25	LINE CLEAR AVAILED
197	1-Dec-21	BAGALKOT	220	BELGAUM-KANABARGI1(NAREDNRA1)	BELGAUM_220	23:29 (01.12.2021)			LINE OPEN:LINE CLEAR AVAILED
198	1-Dec-21	BAGALKOT	220	BELGAUM-KANABARGI2(NAREDNRA2)	BELGAUM_220	23:29 (01.12.2021)			LINE OPEN:LINE CLEAR AVAILED
199	1-Dec-21	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
200	1-Dec-21	BAGALKOT	220	HAVERI- NARENDRA	HAVERI_220	10:19 (30.11.2021)			LINE OPEN:LINE CLEAR AVAILED
201	1-Dec-21	BAGALKOT	220	HAVERI-BIDNAL	HAVERI_220	10:12 (30.11.2021)			LINE OPEN:LINE CLEAR AVAILED
202	1-Dec-21	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	23:37 (01.12.2021)			LINE OPEN:LINE CLEAR AVAILED
203	1-Dec-21	BAGALKOT	220	KUDACHI-CHIKKODI 2	KUDACHI_220	15:00	15:14	0:14	LINE FAULT
204	1-Dec-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
205	1-Dec-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
206	1-Dec-21	BAGALKOT	220	NARENDRA-HAVERI	NARENDRA_220	10:19 (30.11.2021)			LINE OPEN:LINE CLEAR AVAILED
207	1-Dec-21	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	13:38	13:58	0:20	LINE FAULT
208	1-Dec-21	BAGALKOT	220	NARENDRA-KANABARGI2	NARENDRA_220	1:40	2:23	0:43	LINE FAULT
209	1-Dec-21	BAGALKOT	220	RANEENNUR-GUTTUR	RANEENNUR_220	11:01	17:40	6:39	NFBC ISSUED
210	1-Dec-21	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	16:20 (17.11.2021)			LINE OPEN:LINE CLEAR AVAILED
211	1-Dec-21	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	16:20 (24.11.2021)			LINE OPEN:LINE CLEAR AVAILED
212	1-Dec-21	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
213	1-Dec-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
214	1-Dec-21	BENGALURU	66	DABUSPET 220 - AVERAHALLI	AVERAHALLI	14:16	15:47	1:31	MAIN SUPPLY FAILURE
215	1-Dec-21	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	14:16	15:36	1:20	MAIN SUPPLY FAILURE
216	1-Dec-21	BENGALURU	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	14:16	15:37	1:21	MAIN SUPPLY FAILURE
217	1-Dec-21	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	14:16	15:22	1:06	MAIN SUPPLY FAILURE
218	1-Dec-21	BENGALURU	66	DABUSPET 220 - SK STEEL (EHT)	SK STEEL (EHT)	14:16	15:50	1:34	MAIN SUPPLY FAILURE
219	1-Dec-21	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	14:16	15:33	1:17	MAIN SUPPLY FAILURE
220	1-Dec-21	BENGALURU	66	DOMMASANDRA - KACHMARANAHALLI	DOMMASANDRA	14:30	14:35	0:05	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
221	1-Dec-21	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	13:05	13:10	0:05	LOAD CHANGEOVER
222	1-Dec-21	BENGALURU	66	HV1	NRS 220	11:14	11:15	0:01	LINE CLEAR AVAILED
223	1-Dec-21	BENGALURU	66	HV1	NRS 220	13:46	13:53	0:07	LOAD CHANGEOVER
224	1-Dec-21	BENGALURU	66	HV1	H GOLLAHALLI	15:10	16:00	0:49	LINE CLEAR AVAILED
225	1-Dec-21	BENGALURU	66	HV1	DABUSPETE 220	14:16	15:30	1:14	MAIN SUPPLY FAILURE
226	1-Dec-21	BENGALURU	66	HV2	BAIRAKURU	12:20	13:01	0:41	LINE CLEAR AVAILED
227	1-Dec-21	BENGALURU	66	HV2	DABUSPETE 220	14:16	15:32	1:16	MAIN SUPPLY FAILURE
228	1-Dec-21	BENGALURU	66	HV5	NRS 220	12:38	13:05	0:27	TRANSFORMER FAULT
229	1-Dec-21	BENGALURU	66	IRGAMPALLI - CHINTAMANI 220	IRGAMPALLI	10:45	11:55	1:10	LINE CLEAR AVAILED
230	1-Dec-21	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
231	1-Dec-21	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	10:21	10:31	0:10	LOAD CHANGEOVER
232	1-Dec-21	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	22:05	22:17	0:12	MAIN SUPPLY FAILURE
233	1-Dec-21	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	15:38	15:42	0:04	LOAD CHANGEOVER
234	1-Dec-21	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	12:38	13:09	0:31	LINE FAULT
235	1-Dec-21	BENGALURU	66	NRS 220 - MYSORE ROAD 2	NO STATION AFFECTED	12:38	14:06	1:28	LINE FAULT
236	1-Dec-21	BENGALURU	66	NRS 220 - SRS 1	NO STATION AFFECTED	12:38	13:21	0:43	LINE FAULT
237	1-Dec-21	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	12:38	13:01	0:23	LINE FAULT
238	1-Dec-21	BENGALURU	66	SM MANGALA - KOLAR 220	SM MANGALA	14:30	16:45	2:15	LINE CLEAR AVAILED
239	1-Dec-21	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIGEHALI, SRIGANDA KAVALLU	22:05	22:33	0:28	LINE CLEAR AVAILED
240	1-Dec-21	BENGALURU	220	HV1	DABUSPETE 220	14:16	15:07	0:51	TRANSFORMER FAULT
241	1-Dec-21	BENGALURU	220	HV1	SRS PEENYA 220	22:05(01/12/2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
242	1-Dec-21	BENGALURU	220	HV2	DABUSPETE 220	14:16	15:21	1:05	TRANSFORMER FAULT
243	1-Dec-21	BENGALURU	220	HV3	SRS PEENYA 220	22:05(01/12/2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
244	1-Dec-21	BENGALURU	220	NELMANGALA 400 - DABUSPETE 2	NO STATION AFFECTED	14:18	15:41	1:22	LINE FAULT
245	1-Dec-21	BENGALURU	220	YELAHANKA 220 - PGCIL SINGANAYAKANAHALLI 2	NO STATION AFFECTED	11:17	17:27	6:10	LINE CLEAR AVAILED
246	1-Dec-21	BENGALURU	400	NELAMANGALA 400 - HASAN 400	NO STATION AFFECTED	20:55(1-12-2021)			LINE OPEN:LINE FAULT
247	1-Dec-21	GULBARGA	66	HV1	HARVI_66	12:45	12:55	0:10	TRANSFORMER CHARGED
248	1-Dec-21	GULBARGA	66	HV1,HV2	MYLAR_66	3:20	4:10	0:50	TRANSFORMER CHARGED
249	1-Dec-21	GULBARGA	66	HV3	TELALI_66	9:30	10:30	1:00	LINE CLEAR AVAILED
250	1-Dec-21	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	1:25	1:34	0:09	LINE FAULT
251	1-Dec-21	GULBARGA	110	HV1	KEREHALI_110	15:05	18:35	3:30	TRANSFORMER FAULT
252	1-Dec-21	GULBARGA	110	HV1	KEREHALI_110	7:55	8:45	0:50	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
253	1-Dec-21	GULBARGA	110	HV2	NIRNA_110	18:51	18:54	0:03	TRANSFORMER FAULT
254	1-Dec-21	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	22:46	23:00	0:14	MAIN SUPPLY FAILURE
255	1-Dec-21	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHIKSUGUR_110,SHAKTINAGAR_110	21:38	21:48	0:10	LINE FAULT
256	1-Dec-21	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKSUGUR_110,SHAKTINAGAR_110	21:38	21:49	0:11	LINE FAULT
257	1-Dec-21	GULBARGA	110	RAICHUR-SINDHANOOR2	MANVI_110,KURDI CROSS_110,MADALAPUR_110	19:54	20:03	0:09	LINE FAULT
258	1-Dec-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
259	1-Dec-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
260	1-Dec-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	2:41	2:51	0:10	LINE FAULT
261	1-Dec-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YERADON A_110,BENNUR_110,BTPS WATER WORKS,KAMPLI_110	6:41	6:51	0:10	LINE FAULT
262	1-Dec-21	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR IPP,VOORA IPP,	0:27	0:37	0:10	LINE FAULT
263	1-Dec-21	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR IPP,VOORA IPP,	0:45	0:55	0:10	LINE FAULT
264	1-Dec-21	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	22:06 (01.12.2021)			LINE OPEN:LINE CLEAR AVAILED
265	1-Dec-21	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	0:02	7:03	7:01	LINE CHARGED
266	1-Dec-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
267	1-Dec-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	2:04			LINE OPEN:LINE CLEAR AVAILED
268	1-Dec-21	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	8:08	8:59	0:51	LINE FAULT
269	1-Dec-21	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	18:05	18:23	0:18	LINE FAULT
270	1-Dec-21	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	18:05	18:23	0:18	LINE FAULT
271	1-Dec-21	HASSAN	110	HV1	GURUPURA_110	10:34	13:18	2:44	LINE CLEAR AVAILED
272	1-Dec-21	HASSAN	110	HV1	HOSUR_110	14:31	15:03	0:32	LINE CLEAR AVAILED
273	1-Dec-21	HASSAN	110	HV1	JOG_110	9:54	10:38	0:44	LINE CLEAR AVAILED
274	1-Dec-21	HASSAN	110	HV3	PUTTUR_110	23:33(01.12.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
275	1-Dec-21	HASSAN	110	KADUR-YGTI	KADUR_220	10:15	17:08	6:53	LINE CLEAR AVAILED
276	1-Dec-21	HASSAN	220	KADUR-DABUSET	KADUR_220	12:21	14:58	2:37	LINE CLEAR AVAILED
277	1-Dec-21	HASSAN	220	KADUR-SHIMOGA	KADUR_220	15:54	19:37	3:43	LINE CLEAR AVAILED
278	1-Dec-21	HASSAN	220	MRSSH-M-KADUR	MRSMSG_220	15:55	19:37	3:42	LINE CLEAR AVAILED
279	1-Dec-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	10:55	13:44	2:49	NFBC ISSUED
280	1-Dec-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:28(26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
281	1-Dec-21	MYSORE	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
282	1-Dec-21	MYSORE	66	HV1	MADDUR_66	6:50	7:49	0:59	TRANSFORMER FAULT
283	1-Dec-21	MYSORE	66	HV1	MADDUR_66	10:20	12:10	1:50	LINE CLEAR AVAILED
284	1-Dec-21	MYSORE	66	HV1	DKMAIDANA_66	11:39	11:42	0:03	TRANSFORMER FAULT
285	1-Dec-21	MYSORE	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN:LINE CLEAR AVAILED
286	1-Dec-21	MYSORE	66	MADIKERI-KUSHANAGARA	NO STATIONS EFFECTED	12:19	16:35	4:16	LINE CLEAR AVAILED
287	1-Dec-21	MYSORE	66	MEGALAPURA-HEBBANI	THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66 CHIDRAVALLI_66BGPURA_66	11:20	11:29	0:09	LINE FAULT
288	1-Dec-21	MYSORE	66	TUBINKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66 SHIVALLY_66	3:05	3:10	0:05	LINE FAULT
289	1-Dec-21	MYSORE	220	KUSHALNAGARA-BASTIPURA 2	NO STATIONS EFFECTED	16:27	22:36	6:09	LINE CLEAR AVAILED
290	1-Dec-21	MYSORE	220	TUBINKERE-KOTTHIPURA 2	NO STATIONS EFFECTED	10:17:00 (30.11.2021)	18:50:00 (1.12.2021)	32:33 hrs	LINE CHARGED
291	1-Dec-21	MYSORE	220	TUBINKERE-KOTTIPURA 1	NO STATIONS EFFECTED	10:15	18:50	8:35	LINE CLEAR AVAILED
292	1-Dec-21	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	6:05	6:20	0:15	MAIN SUPPLY FAILURE
293	1-Dec-21	TUMKUR	66	BHARAMAGIRI66-HIRIYUR220KV SRS	BHARAMAGIRI_66	14:04	14:24	0:20	LINE FAULT
294	1-Dec-21	TUMKUR	66	BHARAMAGIRI66-HIRIYUR220KV SRS	BHARAMAGIRI_66	11:24	11:32	0:08	LINE FAULT
295	1-Dec-21	TUMKUR	66	BHARAMAGIRI66-HIRIYUR220KV SRS	BHARAMAGIRI_66	11:33	12:32	0:59	LINE FAULT
296	1-Dec-21	TUMKUR	66	BHARAMAGIRI66-HIRIYUR220KV SRS	BHARAMAGIRI_66	12:51	13:21	0:29	LINE FAULT
297	1-Dec-21	TUMKUR	66	BHARAMAGIRI66-HIRIYUR220KV SRS	BHARAMAGIRI_66	13:52	14:05	0:12	LINE FAULT
298	1-Dec-21	TUMKUR	66	CHITRADURGA 220kv-TURUVANUR	MADANAYAKANAHALLI_66 , TURUVANUR_66, BIDARKERE_66, JAGALUR_66,SOKKE_66	10:13	11:14	1:00	LINE CLEAR AVAILED
299	1-Dec-21	TUMKUR	66	CHITRADURGA 220kv-TURUVANUR	MADANAYAKANAHALLI_66 , TURUVANUR_66, BIDARKERE_66, JAGALUR_66,SOKKE_66	17:52	18:13	0:21	LINE CLEAR AVAILED
300	1-Dec-21	TUMKUR	66	HIRIYUR 220KV-BEVINAHALLI	BEVINAHALLI_66	6:18	6:28	0:10	LINE FAULT
301	1-Dec-21	TUMKUR	66	HIRIYURkv 220kv- SUZLON 2	SUZLON1_IPP_66	12:59	16:29	3:30	LINE CLEAR AVAILED
302	1-Dec-21	TUMKUR	66	HONNALLI 220kv-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	9:48	9:58	0:09	LINE FAULT
303	1-Dec-21	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66, NEELAGUNDA_66	23:24	23:37	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
304	1-Dec-21	TUMKUR	66	JAVAGONDANAHALLI-BEVINAHALLI	JAVAGONDANAHALLI_66	7:18	10:35	3:17	LINE FAULT
305	1-Dec-21	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-1 IPP_66	INFOSYS-1_IPP_66	12:54	12:56	0:02	LINE FAULT
306	1-Dec-21	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-2 IPP_66	INFOSYS-2_IPP_66	12:54	13:44	0:49	LINE FAULT
307	1-Dec-21	TUMKUR	66	MADANAYAKANAHALLI66-O/GLINETURUVANU	MADANAYAKANAHALLI_66 , TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	11:05	11:24	0:19	LINE CLEAR AVAILED
308	1-Dec-21	TUMKUR	66	PAVAGADA-MADHUGIRI(PAVAGADA 220)	PAVAGADA_220	6:21	6:27	0:05	LINE FAULT
309	1-Dec-21	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	6:21	6:30	0:08	LINE FAULT
310	1-Dec-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	RANGANATHAPURA_66	11:24	11:40	0:15	HAND TRIPPED
311	1-Dec-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	RANGANATHAPURA_66	11:24	11:40	0:15	HAND TRIPPED
312	1-Dec-21	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	5:08	5:29	0:21	LINE FAULT
313	1-Dec-21	TUMKUR	66	TR-1	BEVINAHALLI_66	6:05	19:35	13:30	TRANSFORMER FAULT
314	1-Dec-21	TUMKUR	66	TR-1	MADADAKERE_66	8:40	8:53	0:12	TRANSFORMER FAULT
315	1-Dec-21	TUMKUR	66	TR-1	PAVAGADA_66	11:04	11:11	0:06	TRANSFORMER FAULT
316	1-Dec-21	TUMKUR	66	TR-1	BILCHODU_66	12:03	13:42	1:38	LINE CLEAR AVAILED
317	1-Dec-21	TUMKUR	66	TR-2	TAVAREKERE(H)	12:17	12:49	0:31	LINE CLEAR AVAILED
318	1-Dec-21	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	15:36	16:55	1:18	LINE CLEAR AVAILED
319	1-Dec-21	TUMKUR	220	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	6:10	11:40	5:30	LINE CLEAR AVAILED
320	1-Dec-21	TUMKUR	220	KB CROSS 220kv-NELAMANGALA	KBCROSS_220	13:43	15:22	1:39	LINE FAULT
321	1-Dec-21	TUMKUR	220	TR-2(HV SIDE)	KBCROSS_220	15:36	16:53	1:17	LINE CLEAR AVAILED
322	2-Dec-21	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	4:30 (10.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
323	2-Dec-21	BAGALKOT	110	110/11KV, HV2	KULIGOD_110	16:08	17:00	0:52	LINE CLEAR AVAILED
324	2-Dec-21	BAGALKOT	110	110/11KV, HV3	TODALBAGI_110	11:42	11:55	0:13	LINE CLEAR AVAILED
325	2-Dec-21	BAGALKOT	110	110/11KV,HV1	VAJARMATTI_110	22:25	22:30	0:05	TRANSFORMER FAULT
326	2-Dec-21	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	6:06	6:13	0:07	TRANSFORMER FAULT
327	2-Dec-21	BAGALKOT	110	110/11KV,HV3	HIREKERUR_110	11:58	12:29	0:31	LINE CLEAR AVAILED
328	2-Dec-21	BAGALKOT	110	110/1KV,HV1	ALBAL_110	21:15	21:23	0:08	TRANSFORMER FAULT
329	2-Dec-21	BAGALKOT	110	110/33KV,HV3	GADAG_110 &KAPPATAGUDD,MALSAM UDRA,PIONEER 33	10:15	11:17	1:02	LINE CLEAR AVAILED
330	2-Dec-21	BAGALKOT	110	220/110,LV1	MK HUBLI_220	0:30	7:55	7:25	LINE CLEAR AVAILED
331	2-Dec-21	BAGALKOT	110	220/110,LV2	MK HUBLI_220	0:25	6:37	6:12	LINE CLEAR AVAILED
332	2-Dec-21	BAGALKOT	110	BAGEWADI-CHIMMALAGI LIS	BAGEWADI_220	12:05	17:17	5:12	LINE CLEAR AVAILED
333	2-Dec-21	BAGALKOT	110	BELGAUM-VADAGOAN	VADAGOAN_110	9:01	13:22	4:21	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
334	2-Dec-21	BAGALKOT	110	CHIKKODI220-NIPPANI(KADAKLAT)	CHIKKODI_220	22:00 (01.12.2021)	5:40 (02.12.2021)	7:40	LINE CHARGED
335	2-Dec-21	BAGALKOT	110	CHIKKODI220-NIPPANI(KADAKLAT)	CHIKKODI_220	5:40	6:45	1:05	LINE CLEAR AVAILED
336	2-Dec-21	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA2	GHATAPRABHA_220	23:36 (01.12.2021)	00:04 (02.12.2021)	0:28	LINE CHARGED
337	2-Dec-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
338	2-Dec-21	BAGALKOT	110	HUBLI 1(ESALE)-SIRSI	SIRSI_110	18:21 (28.11.2021)	8:26 (02.12.2021)	86:05 hrs	LINE CHARGED
339	2-Dec-21	BAGALKOT	110	INDI-DEVARAHIPPARAGI	DEVARAHIPPARAGI_110,AT HARGA_110,HIREMASALI_110	5:03	5:12	0:09	LINE FAULT
340	2-Dec-21	BAGALKOT	110	INDI-LACHYAN	LACHYAN_110,RODAGI_110	5:03	5:09	0:06	LINE FAULT
341	2-Dec-21	BAGALKOT	110	RANEENNUR-HIREKERUR	RANEENNUR_220	4:34	4:40	0:06	LINE FAULT
342	2-Dec-21	BAGALKOT	110	SAVANUR- ASF SOLAR	SAVANUR_110	6:59	7:11	0:12	HAND TRIPPED
343	2-Dec-21	BAGALKOT	110	SHIRAGUPPI - BILAGI	BILAGI_110,GIRISAGAR_110,BISNAL_110	15:00	15:20	0:20	MAIN SUPPLY FAILURE
344	2-Dec-21	BAGALKOT	110	SHIRAGUPPI - BILAGI	BILAGI_110,GIRISAGAR_110,BISNAL_110	16:10	16:15	0:05	HAND TRIPPED
345	2-Dec-21	BAGALKOT	110	SHIRAGUPPI - VAJRAMATTI	SHIRAGUPPI_110,BILAGI_110,GIRISAGAR_110,BISNAL_110	6:35	6:44	0:09	LINE FAULT
346	2-Dec-21	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110	16:10	16:16	0:06	HAND TRIPPED
347	2-Dec-21	BAGALKOT	110	SIRSI- JOG	SIRSI_110	8:30	19:18	10:48	NFBC ISSUED
348	2-Dec-21	BAGALKOT	110	TUMMINKATTE-RANEENNUR220	TUMMINKATTE_110	15:38	15:50	0:12	LINE FAULT
349	2-Dec-21	BAGALKOT	110	TUMMINKATTE- RATTIHALI	TUMMINKATTE_110	15:38	15:58	0:20	HAND TRIPPED
350	2-Dec-21	BAGALKOT	110	VAJARMATTI220-BILAGI(SHIRAGUPPI)	SHIRAGUPPI_110,BILAGI_110,GIRISAGAR_110,BISNAL_110	6:44	6:50	0:06	LINE FAULT
351	2-Dec-21	BAGALKOT	220	220/110KV,HV2,LV2	SOUDATTI_220	10:03	12:30	2:27	LINE CLEAR AVAILED
352	2-Dec-21	BAGALKOT	220	BAGEWADI-LINGSUGAR2	BAGEWADI_220	13:00	14:17	1:17	LOAD CURTAILMENT
353	2-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
354	2-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
355	2-Dec-21	BAGALKOT	220	BELGAUM-KANABARGI1(NAREDNRA1)	BELGAUM_220	23:29 (01.12.2021)	6:58 (02.12.2021)	7:29	LINE CHARGED
356	2-Dec-21	BAGALKOT	220	BELGAUM-KANABARGI2(NAREDNRA2)	BELGAUM_220	23:29 (01.12.2021)	6:40 (02.12.2021)	7:11	LINE CHARGED
357	2-Dec-21	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	2:57 (02.12.2021)			LINE OPEN:LINE FAULT
358	2-Dec-21	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
359	2-Dec-21	BAGALKOT	220	GHATAPRABHA- NAREDNRA1	GHATAPRABHA_220	6:28	8:58	2:30	LINE FAULT
360	2-Dec-21	BAGALKOT	220	HAVERI- NARENDRA	HAVERI_220	10:19 (30.11.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
361	2-Dec-21	BAGALKOT	220	HAVERI-BIDNAL	HAVERI_220	10:12 (30.11.2021)			LINE OPEN:LINE CLEAR AVAILED
362	2-Dec-21	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	23:37 (01.12.2021)	6:48 (02.12.2021)	7:11	LINE CHARGED
363	2-Dec-21	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
364	2-Dec-21	BAGALKOT	220	MK HUBLI-NARENDRA2	MK HUBLI_220	12:35	16:15	3:40	NFBC ISSUED
365	2-Dec-21	BAGALKOT	220	MK HUBLI-NARENDRA2	MK HUBLI_220	12:35	16:15	3:40	NFBC ISSUED
366	2-Dec-21	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	23:49 (02.12.2021)			LINE OPEN:LINE FAULT
367	2-Dec-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
368	2-Dec-21	BAGALKOT	220	NARENDRA-HAVERI	NARENDRA_220	10:19 (30.11.2021)			LINE OPEN:LINE CLEAR AVAILED
369	2-Dec-21	BAGALKOT	220	RANEENNUR-GUTTUR	RANEENNUR_220	11:19	13:42	2:23	NFBC ISSUED
370	2-Dec-21	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	16:20 (17.11.2021)			LINE OPEN:LINE CLEAR AVAILED
371	2-Dec-21	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	16:20 (24.11.2021)			LINE OPEN:LINE CLEAR AVAILED
372	2-Dec-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
373	2-Dec-21	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
374	2-Dec-21	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	11:55	12:41	0:45	LINE FAULT
375	2-Dec-21	BENGALURU	66	GURUVINAPURA - BV HALLI	BV HALLI	7:25	7:37	0:12	LINE FAULT
376	2-Dec-21	BENGALURU	66	HV1	NANDIGANAHALLI	9:00	9:05	0:05	LINE CLEAR AVAILED
377	2-Dec-21	BENGALURU	66	HV1	NANDIGANAHALLI	10:40	10:55	0:15	LINE CLEAR AVAILED
378	2-Dec-21	BENGALURU	66	HV1	MALLANAYAKANA HALLI	13:24	13:32	0:08	LINE CLEAR AVAILED
379	2-Dec-21	BENGALURU	66	ITI 220 -BAGHMANE TECH PARK	NO STATION AFFECTED	8:48	10:44	1:56	LINE FAULT
380	2-Dec-21	BENGALURU	66	KORAMANGALA 220 - ADUGODI	NO STATION AFFECTED	6:26	13:11	6:45	LINE FAULT
381	2-Dec-21	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
382	2-Dec-21	BENGALURU	66	LV1	MALUR 220	16:34	19:47	3:12	TRANSFORMER FAULT
383	2-Dec-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	16:34	19:53	3:19	LINE FAULT
384	2-Dec-21	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	16:40	17:13	0:33	MAIN SUPPLY FAILURE
385	2-Dec-21	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	19:44	19:48	0:04	LOAD CHANGEOVER
386	2-Dec-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	16:34	17:13	0:38	LINE FAULT
387	2-Dec-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	19:44	19:47	0:03	LOAD CHANGEOVER
388	2-Dec-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	16:34	17:13	0:38	LINE FAULT
389	2-Dec-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	19:44	19:47	0:03	LOAD CHANGEOVER
390	2-Dec-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	16:34	17:51	1:16	LINE FAULT
391	2-Dec-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	16:34	17:49	1:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
392	2-Dec-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	19:44	19:48	0:04	LOAD CHANGEOVER
393	2-Dec-21	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	5:55	6:02	0:07	LOAD CHANGEOVER
394	2-Dec-21	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIGEHALI	5:40	5:44	0:04	LOAD CHANGEOVER
395	2-Dec-21	BENGALURU	66	VIDHURASHRAVATHA - GUNDLU KOTTUR	GUNDLU KOTTUR	16:35	17:15	0:40	LINE FAULT
396	2-Dec-21	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	12:27	13:09	0:41	LINE CLEAR AVAILED
397	2-Dec-21	BENGALURU	220	CHINTAMANI 220 - PGCIL 2	CHINTAMANI 220	12:43	12:57	0:14	LINE FAULT
398	2-Dec-21	BENGALURU	220	DABUSPET 220 - KADUR 220	DABUSPET 220	17:04:48(2-12-2021)			LINE OPEN:LINE FAULT
399	2-Dec-21	BENGALURU	220	HV1	MALUR 220	16:34	19:34	3:00	TRANSFORMER FAULT
400	2-Dec-21	BENGALURU	220	HV1	SRS PEENYA 220	22:05(01/12/2021)	00:55(02/12/2021)	2:50HRS	TRANSFORMER CHARGED
401	2-Dec-21	BENGALURU	220	HV3	SRS PEENYA 220	22:05(01/12/2021)	00:22(02/12/2021)	2:17HRS	TRANSFORMER CHARGED
402	2-Dec-21	BENGALURU	400	NELAMANGALA 400 - HASAN 400	NO STATION AFFECTED	20:55(1-12-2021)			LINE OPEN:LINE FAULT
403	2-Dec-21	GULBARGA	66	HV2	BENNEHALLI_66	9:50	10:00	0:10	TRANSFORMER FAULT
404	2-Dec-21	GULBARGA	66	HV2	BENNEHALLI_66	15:15	15:20	0:05	TRANSFORMER FAULT
405	2-Dec-21	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
406	2-Dec-21	GULBARGA	66	MUNIRABAD-MSD	HANASI_66	6:52	6:57	0:05	LINE FAULT
407	2-Dec-21	GULBARGA	66	MUNIRABAD-MSD	HANASI_66	7:47	7:52	0:05	LINE FAULT
408	2-Dec-21	GULBARGA	66	MYLAR-RANIBENNUR	MYLAR_66	22:05	22:25	0:20	MAIN SUPPLY FAILURE
409	2-Dec-21	GULBARGA	66	MYLAR-RANIBENNUR	MYLAR_66	23:15	23:20	0:05	MAIN SUPPLY FAILURE
410	2-Dec-21	GULBARGA	66	UCHCHANGIDURGA-BILCHOD	BILCHOD_66	3:10	3:15	0:05	LINE FAULT
411	2-Dec-21	GULBARGA	110	CHITGUPPA-ACMESLR	CHITGUPPA_110	19:45	19:55	0:10	LINE FAULT
412	2-Dec-21	GULBARGA	110	CHITGUPPA-HUMNABAD	CHITGUPPA_110,NIRNA_110	20:30	20:40	0:10	MAIN SUPPLY FAILURE
413	2-Dec-21	GULBARGA	110	HATTI-SOMANMARADHI_IPP	HATTI_110	4:51	4:58	0:07	LINE FAULT
414	2-Dec-21	GULBARGA	110	HATTI-SOMANMARADHI_IPP	HATTI_110	5:42	5:46	0:04	LINE FAULT
415	2-Dec-21	GULBARGA	110	HATTI-SOMANMARADHI_IPP	HATTI_110	14:54	17:04	2:10	LINE CLEAR AVAILED
416	2-Dec-21	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITAGUPPA_110,NIRNA_110	19:47	19:53	0:06	LINE FAULT
417	2-Dec-21	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITAGUPPA_110,NIRNA_110	19:57	20:12	0:15	LINE FAULT
418	2-Dec-21	GULBARGA	110	HV1	CHINCHOLI_110	14:56	16:30	1:34	LINE CLEAR AVAILED
419	2-Dec-21	GULBARGA	110	HV2	BISLAHALLI_110	5:24	7:15	1:51	TRANSFORMER FAULT
420	2-Dec-21	GULBARGA	110	HV2	BISLAHALLI_110	9:30	9:44	0:14	TRANSFORMER FAULT
421	2-Dec-21	GULBARGA	110	HV2	BISLAHALLI_110	14:47	15:37	0:50	TRANSFORMER CHARGED
422	2-Dec-21	GULBARGA	110	HV4	KUSTAGI_220	4:34	4:46	0:12	TRANSFORMER FAULT
423	2-Dec-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	10:32	14:52	4:20	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
424	2-Dec-21	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110,GULBARGA SOUTH_110	11:34	11:56	0:22	LINE FAULT
425	2-Dec-21	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110,GULBARGA SOUTH_110	14:25	14:28	0:03	LINE FAULT
426	2-Dec-21	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGU TTI_110	14:55(02.12.2021)			LINE OPEN:LINE CLEAR AVAILED
427	2-Dec-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	12:44	12:55	0:11	LINE FAULT
428	2-Dec-21	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	11:02	15:12	4:10	NFBC ISSUED
429	2-Dec-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	22:45	22:50	0:05	LINE FAULT
430	2-Dec-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
431	2-Dec-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
432	2-Dec-21	GULBARGA	110	SOMMANMARDI-HATTI	HATTI_110	4:51	4:58	0:07	LINE FAULT
433	2-Dec-21	GULBARGA	110	SOMMANMARDI-HATTI	HATTI_110	5:42	5:46	0:04	LINE FAULT
434	2-Dec-21	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	22:06 (01.12.2021)	6:23 (02.12.2021)	8:17 HRS	LINE CHARGED
435	2-Dec-21	GULBARGA	220	HV1,HV2	HALBARGA_220	15:25	16:50	1:25	LINE CLEAR AVAILED
436	2-Dec-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
437	2-Dec-21	GULBARGA	220	HV2	SEDAM_220	4:53	5:18	0:25	TRANSFORMER FAULT
438	2-Dec-21	GULBARGA	220	HV2	KAPNOOR_220	10:18	10:41	0:23	TRANSFORMER FAULT
439	2-Dec-21	GULBARGA	220	HV2,LV2	KAPNOOR_220	13:30	14:50	1:20	LINE CLEAR AVAILED
440	2-Dec-21	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	2:20	2:38	0:18	LINE FAULT
441	2-Dec-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:13 (02.12.2021)			LINE OPEN:LINE CLEAR AVAILED
442	2-Dec-21	GULBARGA	400	BTPSG-GUTTUR	GUTTUR_400	11:48	17:00	5:12	LINE CHARGED
443	2-Dec-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	2:04(01.12.2021)	10:10(02.12.2021)	32:06HRS	LINE CHARGED
444	2-Dec-21	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	12:46	14:07	1:21	NFBC ISSUED
445	2-Dec-21	HASSAN	66	CRPATNA-CRPATNA1	CRPATNA_220	12:43	14:07	1:24	LINE CLEAR AVAILED
446	2-Dec-21	HASSAN	66	HV1	KUDLIGERE_66	9:32	18:40	9:08	LINE CLEAR AVAILED
447	2-Dec-21	HASSAN	66	HV1	MALLIPATNA_66	12:43	14:01	1:18	LINE CLEAR AVAILED
448	2-Dec-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	15:02	19:05	4:03	LINE CLEAR AVAILED
449	2-Dec-21	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	15:03	18:40	3:37	LINE CLEAR AVAILED
450	2-Dec-21	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	15:04	18:36	3:32	LINE CLEAR AVAILED
451	2-Dec-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	12:08	15:04	2:56	NFBC ISSUED
452	2-Dec-21	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	11:00	12:15	1:15	LINE CLEAR AVAILED
453	2-Dec-21	HASSAN	110	HV1	PUTTUR_110	10:09	17:55	7:46	LINE CLEAR AVAILED
454	2-Dec-21	HASSAN	110	HV1	BANTWALA_110	9:35	12:25	2:50	LINE CLEAR AVAILED
455	2-Dec-21	HASSAN	110	HV1	BRAHMAVARA_110	10:52	13:56	3:04	LINE CLEAR AVAILED
456	2-Dec-21	HASSAN	110	HV2	PUTTUR_110	10:09	17:55	7:46	LINE CLEAR AVAILED
457	2-Dec-21	HASSAN	110	HV3	PUTTUR_110	23:33(01.12.2021)	00:07(02.12.2021)	0:33 hrs	TRANSFORMER CHARGED
458	2-Dec-21	HASSAN	110	JOG110-MGHE	JOG_110	8:52	20:03	11:11	NFBC ISSUED
459	2-Dec-21	HASSAN	110	JOG-JLT3	mghejog_gen	8:49	20:04	11:15	LINE CLEAR AVAILED
460	2-Dec-21	HASSAN	110	JOG-JLT4	mghejog_gen	8:58	19:20	10:22	LINE CLEAR AVAILED
461	2-Dec-21	HASSAN	110	JOG-JST1	mghejog_gen	8:58	19:09	10:11	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
462	2-Dec-21	HASSAN	110	JOG-JST2	mghejog_gen	8:58	19:09	10:11	LINE CLEAR AVAILED
463	2-Dec-21	HASSAN	110	JOG-NK2	mghejog_gen	8:42	19:10	10:28	LINE CLEAR AVAILED
464	2-Dec-21	HASSAN	110	KADUR-NERELEKERE	KADUR_220	10:40	10:55	0:15	HAND TRIPPED
465	2-Dec-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	12:08	15:04	2:56	LINE CLEAR AVAILED
466	2-Dec-21	HASSAN	110	LPH-MGHE 2	lph_gen	9:00	19:39	10:39	NFBC ISSUED
467	2-Dec-21	HASSAN	110	SAGARA-JST1	SAGARA_110	9:03	19:06	10:03	NFBC ISSUED
468	2-Dec-21	HASSAN	110	SAGARA-JST2	SAGARA_110	9:03	19:06	10:03	NFBC ISSUED
469	2-Dec-21	HASSAN	400	TALAGUPPA-NELAMANGALA#2	TALAGUPPA_400	23:28(26.11.2021)	7:26(02.12.2021)	7:57 hrs	LINE CHARGED
470	2-Dec-21	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	11:42	11:49	0:06	LINE FAULT
471	2-Dec-21	MYSORE	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 30.10.2021)			LINE OPEN:LINE CLEAR AVAILED
472	2-Dec-21	MYSORE	66	HV1	KRNAGARA_66	12:11	12:26	0:14	LINE CLEAR AVAILED
473	2-Dec-21	MYSORE	66	HV1	MADDUR_66	12:21	13:02	0:40	TRANSFORMER FAULT
474	2-Dec-21	MYSORE	66	HV1	MADDUR_66	15:58	16:58	0:59	TRANSFORMER FAULT
475	2-Dec-21	MYSORE	66	HV1	MADESWARAPURA_66	15:18	17:00	1:41	LINE CLEAR AVAILED
476	2-Dec-21	MYSORE	66	HV2	MADESWARAPURA_66	13:45	15:25	1:40	LINE CLEAR AVAILED
477	2-Dec-21	MYSORE	66	HV2	YELANDUR_66	12:19	12:35	0:16	LINE CLEAR AVAILED
478	2-Dec-21	MYSORE	66	HV2	PERIYAPATNA_66	11:53(2.12.21)			TRANSFORMER OPEN:LINE CLEAR AVAILED
479	2-Dec-21	MYSORE	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN:LINE CLEAR AVAILED
480	2-Dec-21	MYSORE	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	18:09	18:15	0:05	LINE FAULT
481	2-Dec-21	MYSORE	66	VAJMANGALA-MEGALAPURA	THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66 CHIDRAVALLI_66BGPURA_66 MEGALAPURA_66	15:53	16:04	0:11	LINE FAULT
482	2-Dec-21	MYSORE	220	HOOTAGALLI-VAJMANGALA	NO STATIONS EFFECTED	11:30	13:05	1:35	LINE CLEAR AVAILED
483	2-Dec-21	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	15:36:49	16:55:00	1:18	LINE CLEAR AVAILED
484	2-Dec-21	TUMKUR	220	KB CROSS 220KV-NELAMANGALA	KBCROSS_220	13:43	15:22	1:39	LINE FAULT
485	2-Dec-21	TUMKUR	220	TR-2(HV SIDE)	KBCROSS_220	15:36:54	16:53:54	1:17	LINE CLEAR AVAILED
486	3-Dec-21	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	4:30 (10.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
487	3-Dec-21	BAGALKOT	110	110/11KV, HV2	SAVANUR_110	15:12	15:46	0:34	LINE CLEAR AVAILED
488	3-Dec-21	BAGALKOT	110	110/11KV,HV1	HALKI_110	3:55	4:15	0:20	TRANSFORMER FAULT
489	3-Dec-21	BAGALKOT	110	110/11KV,HV1	HOSAHONNATTI_110	12:35	13:09	0:34	LINE CLEAR AVAILED
490	3-Dec-21	BAGALKOT	110	110/11KV,HV1	LAKSHMESHWAR_110	10:13	20:14	10:01	LINE CLEAR AVAILED
491	3-Dec-21	BAGALKOT	110	110/11KV,HV2	ALMEL_110	12:42	12:59	0:17	HAND TRIPPED
492	3-Dec-21	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	12:04	12:42	0:38	LINE CLEAR AVAILED
493	3-Dec-21	BAGALKOT	110	110/11KV,HV2	LAKSHMESHWAR_110	10:13	20:07	9:54	LINE CLEAR AVAILED
494	3-Dec-21	BAGALKOT	110	110/11KV,HV2	THORVI(BJCTY)_110	10:34	11:31	0:57	LINE CLEAR AVAILED
495	3-Dec-21	BAGALKOT	110	110/33KV,HV1	GULEDGUDDA_110& KAMATAGI_33,SHIRUR_33, ACME SOLAR_33	15:17	16:44	1:27	LINE CLEAR AVAILED
496	3-Dec-21	BAGALKOT	110	110/33KV,HV3	LAKSHMESHWAR_110	10:13	20:15	10:02	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
497	3-Dec-21	BAGALKOT	110	220/110KV,HV2,LV2	RANEENNUR_220	16:10	17:35	1:25	LINE CLEAR AVAILED
498	3-Dec-21	BAGALKOT	110	ALNAVAR-HALIYAL	HALIYAL_110	18:12	18:47	0:35	LINE FAULT
499	3-Dec-21	BAGALKOT	110	B BAGEWADI 1-MAMADAPUR(B)	MAMADAPUR(B)_110	20:45	21:13	0:28	LINE CLEAR AVAILED
500	3-Dec-21	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	10:09	10:22	0:13	LINE CLEAR AVAILED
501	3-Dec-21	BAGALKOT	110	BELLATTI-ENERCON2	BELLATTI_110	10:07	20:23	10:16	LINE CLEAR AVAILED
502	3-Dec-21	BAGALKOT	110	BELLATTI-LAXMESHWAR	LAXMESHWAR_110	10:30	20:15	9:45	LINE CLEAR AVAILED
503	3-Dec-21	BAGALKOT	110	DAMBAL-SAMBAPUR (GADAGL4)	SAMBAPUR ROAD_110	10:17	14:30	4:13	NFBC ISSUED
504	3-Dec-21	BAGALKOT	110	GADAG-LAKSHMESHWAR	LAKSHMESHWAR_110	9:29 (03.12.2021)			LINE OPEN:LINE CLEAR AVAILED
505	3-Dec-21	BAGALKOT	110	GOKAK-MAMADAPUR	MAMADAPUR_110	6:15	6:51	0:35	LINE FAULT
506	3-Dec-21	BAGALKOT	110	GOKAK-MAMADAPUR	MAMADAPUR_110	7:30	7:45	0:15	LINE FAULT
507	3-Dec-21	BAGALKOT	110	GOKAK-MAMADAPUR	MAMADAPUR_110	21:35	21:50	0:15	LINE FAULT
508	3-Dec-21	BAGALKOT	110	GOKAK-MAMADAPUR	MAMADAPUR_110	22:25	22:45	0:20	LINE FAULT
509	3-Dec-21	BAGALKOT	110	GOKAK-MAMADAPUR	MAMADAPUR_110	23:50	0:00	0:10	LINE FAULT
510	3-Dec-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
511	3-Dec-21	BAGALKOT	110	HALIYAL-ALNAVAR	HALIYAL_110	18:11	18:47	0:36	LINE FAULT
512	3-Dec-21	BAGALKOT	110	INDI-DEVARAHIPPARAGI	DEVARAHIPPARAGI_110,AT HARGA_110,HIREMASALI_110	6:49	6:59	0:10	LINE FAULT
513	3-Dec-21	BAGALKOT	110	INDI-LACHYAL	LACHYAN_110,RODAGI_110	6:49	6:54	0:05	LINE FAULT
514	3-Dec-21	BAGALKOT	110	MANTUR-MAREGUDDI	MANTUR_110	7:20	7:40	0:20	LINE FAULT
515	3-Dec-21	BAGALKOT	110	MANTUR-MAREGUDDI	MAREGUDDI_110,MUNDU GANUR_110	7:20	7:40	0:20	MAIN SUPPLY FAILURE
516	3-Dec-21	BAGALKOT	110	RANEENNUR- GUTTAL	RANEENNUR_220	11:13	17:48	6:35	LINE CLEAR AVAILED
517	3-Dec-21	BAGALKOT	110	RANEENNUR- HIREKERUR	RANEENNUR_220	11:15	17:45	6:30	LINE CLEAR AVAILED
518	3-Dec-21	BAGALKOT	110	RANEENNUR- HONNATTI	RANEENNUR_220	11:13	17:48	6:35	LINE CLEAR AVAILED
519	3-Dec-21	BAGALKOT	110	RANEENNUR- TUMMINKATTE	RANEENNUR_220	11:13	17:48	6:35	LINE CLEAR AVAILED
520	3-Dec-21	BAGALKOT	110	SAMBAPUR ROAD- GADAG220	SAMBAPUR ROAD_110	10:04	15:42	5:38	LINE CLEAR AVAILED
521	3-Dec-21	BAGALKOT	110	SAVANUR- ASF SOLAR	SAVANUR_110	18:03	18:06	0:03	LINE FAULT
522	3-Dec-21	BAGALKOT	110	SHIRAHATTI- LAKSHMESHWAR	LAKSHMESHWAR_110	9:29	19:57	10:28	NFBC ISSUED
523	3-Dec-21	BAGALKOT	110	SHIRHATTI- LAXMESHWAR	LAXMESHWAR_110	10:30	19:57	9:27	LINE CLEAR AVAILED
524	3-Dec-21	BAGALKOT	110	TODALBAGI- JAMKHANDI SUGARS	TODALBAGI_110	15:59	16:04	0:05	LINE FAULT
525	3-Dec-21	BAGALKOT	220	220/110KV, HV1&LV1	SOUDATTI_220	8:27	18:39	10:12	LINE CLEAR AVAILED
526	3-Dec-21	BAGALKOT	220	220/110KV,HV2,LV2	RANEENNUR_220	11:16	11:47	0:31	HAND TRIPPED
527	3-Dec-21	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	1:10	2:22	1:12	NFBC ISSUED
528	3-Dec-21	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	10:38	12:32	1:54	NFBC ISSUED
529	3-Dec-21	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	11:06	13:49	2:43	NFBC ISSUED
530	3-Dec-21	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	16:25	17:17	0:52	NFBC ISSUED
531	3-Dec-21	BAGALKOT	220	ATHANI220-KUDUCHI220	ATHANI_220	14:10	18:56	4:46	NFBC ISSUED
532	3-Dec-21	BAGALKOT	220	ATHANI-KUDUCHI	ATHANI_220	14:10	18:56	4:46	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
533	3-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
534	3-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
535	3-Dec-21	BAGALKOT	220	BELLIGAVI-RANEENNUR	RANEENNUR_220	12:12	12:35	0:23	MAIN SUPPLY FAILURE
536	3-Dec-21	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	2:57 (02.12.2021)			LINE OPEN:LINE FAULT
537	3-Dec-21	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
538	3-Dec-21	BAGALKOT	220	HAVERI- NARENDRA	HAVERI_220	10:19 (30.11.2021)			LINE OPEN:LINE CLEAR AVAILED
539	3-Dec-21	BAGALKOT	220	HAVERI-BIDNAL	HAVERI_220	10:12 (30.11.2021)			LINE OPEN:LINE CLEAR AVAILED
540	3-Dec-21	BAGALKOT	220	HAVERI-BIDNAL	HAVERI_220	10:12 (30.11.2021)			LINE OPEN:LINE CLEAR AVAILED
541	3-Dec-21	BAGALKOT	220	HAVERI-BIDNAL	HAVERI_220	10:12 (30.11.2021)			LINE OPEN:LINE CLEAR AVAILED
542	3-Dec-21	BAGALKOT	220	KUDACHI- ATHANI	KUDACHI_220	14:09	18:55	4:46	NFBC ISSUED
543	3-Dec-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
544	3-Dec-21	BAGALKOT	220	MK HUBLI-NARENDRA2	MK HUBLI_220	10:46	15:49	5:03	LINE CLEAR AVAILED
545	3-Dec-21	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	23:49 (02.12.2021)			LINE OPEN:LINE FAULT
546	3-Dec-21	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	0:30	2:22	1:52	LINE CLEAR AVAILED
547	3-Dec-21	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	10:38	12:32	1:54	LINE CLEAR AVAILED
548	3-Dec-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
549	3-Dec-21	BAGALKOT	220	NARENDRA-HAVERI	NARENDRA_220	10:19 (30.11.2021)			LINE OPEN:LINE CLEAR AVAILED
550	3-Dec-21	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	16:20 (17.11.2021)			LINE OPEN:LINE CLEAR AVAILED
551	3-Dec-21	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	16:20 (17.11.2021)			LINE OPEN:LINE CLEAR AVAILED
552	3-Dec-21	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	16:20 (17.11.2021)			LINE OPEN:LINE CLEAR AVAILED
553	3-Dec-21	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	16:20 (24.11.2021)			LINE OPEN:LINE CLEAR AVAILED
554	3-Dec-21	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	16:20 (24.11.2021)			LINE OPEN:LINE CLEAR AVAILED
555	3-Dec-21	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	16:20 (24.11.2021)			LINE OPEN:LINE CLEAR AVAILED
556	3-Dec-21	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
557	3-Dec-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
558	3-Dec-21	BENGALURU	66	BEGUR 220 - VIDYANAGAR	VIDYANAGAR	11:57	15:20	3:23	LINE CLEAR AVAILED
559	3-Dec-21	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	10:04	17:29	7:24	LINE CLEAR AVAILED
560	3-Dec-21	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK (EHT)	8:41	9:04	0:23	LINE FAULT
561	3-Dec-21	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	SHOBHA CITY	16:39	16:41	0:02	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
562	3-Dec-21	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	11:59	12:08	0:09	MAIN SUPPLY FAILURE
563	3-Dec-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	14:23	14:29	0:06	LINE CLEAR AVAILED
564	3-Dec-21	BENGALURU	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSURU RAMAPURA, NITRALLI	11:19	11:40	0:20	LINE FAULT
565	3-Dec-21	BENGALURU	66	HV1	BMTC	12:12	12:56	0:44	LINE CLEAR AVAILED
566	3-Dec-21	BENGALURU	66	HV1	BMTC	13:43	16:03	2:20	LINE CLEAR AVAILED
567	3-Dec-21	BENGALURU	66	HV1	HAL 220	12:16	12:20	0:04	LINE CLEAR AVAILED
568	3-Dec-21	BENGALURU	66	HV1	MALLANAYAKANA HALLI	15:40	15:56	0:16	LINE CLEAR AVAILED
569	3-Dec-21	BENGALURU	66	HV2	GANJIGUNTE	15:10	15:15	0:05	LINE CLEAR AVAILED
570	3-Dec-21	BENGALURU	66	HV2	KADUBISANAHALLI	13:02	13:10	0:08	LINE CLEAR AVAILED
571	3-Dec-21	BENGALURU	66	HV2	N G HULKUR	15:10	15:15	0:04	LINE CLEAR AVAILED
572	3-Dec-21	BENGALURU	66	HV2	NRS 220	9:48	9:57	0:09	LOAD CHANGEOVER
573	3-Dec-21	BENGALURU	66	HV3	YARANDANAHALLI	11:48	12:11	0:23	TRANSFORMER FAULT
574	3-Dec-21	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	13:36	13:41	0:05	LINE CLEAR AVAILED
575	3-Dec-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPETE	13:31	13:33	0:02	LINE CLEAR AVAILED
576	3-Dec-21	BENGALURU	66	KOLAR 220 - MULBAGAL	NO STATION AFFECTED	13:19	13:24	0:05	LINE CLEAR AVAILED
577	3-Dec-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	13:24	13:26	0:02	LINE CLEAR AVAILED
578	3-Dec-21	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR	13:43	13:48	0:05	LINE CLEAR AVAILED
579	3-Dec-21	BENGALURU	66	KOLAR 220 - THAYLUR	NO STATION AFFECTED	13:27	13:30	0:03	LINE CLEAR AVAILED
580	3-Dec-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	13:33	13:38	0:05	LINE CLEAR AVAILED
581	3-Dec-21	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
582	3-Dec-21	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	11:22	11:28	0:06	LOAD CHANGEOVER
583	3-Dec-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	1:54	2:01	0:07	LINE FAULT
584	3-Dec-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	12:58	13:05	0:07	LINE CLEAR AVAILED
585	3-Dec-21	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	10:15	17:30	7:15	LINE CLEAR AVAILED
586	3-Dec-21	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	11:57	12:08	0:11	LINE CLEAR AVAILED
587	3-Dec-21	BENGALURU	220	DABUSPET 220 - KADUR 220	DABUSPET 220	12:58	14:16	1:17	LINE FAULT
588	3-Dec-21	BENGALURU	220	DABUSPET 220 - KADUR 220	DABUSPET 220	14:34	18:38	4:04	LINE FAULT
589	3-Dec-21	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	17:04:48(2-12-2021)	12:58:24(3-12-2021)	19:52 hrs	LINE CHARGED
590	3-Dec-21	BENGALURU	400	NELAMANGALA 400 - HASAN 400	NO STATION AFFECTED	17:48:06(3-12-2021)			LINE OPEN:LINE FAULT
591	3-Dec-21	BENGALURU	400	NELAMANGALA 400 - HASAN 400	NO STATION AFFECTED	20:55(1-12-2021)	17:42:55(3-12-2021)	44:46 hrs	LINE CHARGED
592	3-Dec-21	GULBARGA	66	BENNEHALLI-KOTTUR	KOTTUR_66	0:15	0:20	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
593	3-Dec-21	GULBARGA	66	HV2	TELAGI_66	11:10	11:40	0:30	LINE CLEAR AVAILED
594	3-Dec-21	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
595	3-Dec-21	GULBARGA	66	MUNIRABAD-MSD	HANASI_66	6:52	6:57	0:05	LINE FAULT
596	3-Dec-21	GULBARGA	66	MUNIRABAD-MSD	HANASI_66	7:47	7:52	0:05	LINE FAULT
597	3-Dec-21	GULBARGA	66	NELGUNDA-HALAVAGALU	HALAVAGALU_66	1:53	2:06	0:13	LINE FAULT
598	3-Dec-21	GULBARGA	110	BYGWAT-MALLAT	BYGWAT_110	4:30	4:40	0:10	MAIN SUPPLY FAILURE
599	3-Dec-21	GULBARGA	110	BYGWAT-MALLAT	BYGWAT_110	21:55	22:00	0:05	MAIN SUPPLY FAILURE
600	3-Dec-21	GULBARGA	110	CHITGUPPA-ACMSLR	CHITGUPPA_110	10:05	10:14	0:09	LINE CHARGED
601	3-Dec-21	GULBARGA	110	GABBUR-RAICHUR	GABBUR_110	22:45	22:50	0:05	MAIN SUPPLY FAILURE
602	3-Dec-21	GULBARGA	110	GULBARGAUNIVERSITY-GULBARGANORTH	GULBARGAUNIVERSITY_110	15:10	15:20	0:10	MAIN SUPPLY FAILURE
603	3-Dec-21	GULBARGA	110	GULBARGAWEST-KAPNOOR,GULBARGASOUTH	GULBARGAWEST_110	9:10	12:57	3:47	LINE CLEAR AVAILED
604	3-Dec-21	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	6:47	6:53	0:06	LINE FAULT
605	3-Dec-21	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITAGUPPA_110,NIRNA_110	6:46	6:50	0:04	LINE FAULT
606	3-Dec-21	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITAGUPPA_110,NIRNA_110	6:51	6:54	0:03	LINE FAULT
607	3-Dec-21	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITAGUPPA_110,NIRNA_110	7:12	7:20	0:08	LINE FAULT
608	3-Dec-21	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITAGUPPA_110,NIRNA_110	7:53	8:08	0:15	LINE FAULT
609	3-Dec-21	GULBARGA	110	HUMNABAD-SASTHAPUR	RAJESHWAR_110,MANTHAL_110,SASTHAPUR_110	17:30	17:33	0:03	LINE FAULT
610	3-Dec-21	GULBARGA	110	HV1	HANUMANAL_110	15:50	16:20	0:30	LINE CLEAR AVAILED
611	3-Dec-21	GULBARGA	110	HV1	MALLAPURA_110	10:19	17:08	6:49	LINE CLEAR AVAILED
612	3-Dec-21	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110,GULBARGA SOUTH_110	9:16	12:55	3:39	LINE CHARGED
613	3-Dec-21	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	5:00	5:05	0:05	LINE FAULT
614	3-Dec-21	GULBARGA	110	MALLAPURA-SINDHANOOR	KAMPLI_GLB_110	12:20	13:11	0:51	LINE FAULT
615	3-Dec-21	GULBARGA	110	MALLAPUR-MUNIRABAD	MALLAPURA_110	12:20	13:11	0:51	MAIN SUPPLY FAILURE
616	3-Dec-21	GULBARGA	110	MALLAT-MADALAPUR	MADALAPUR_110,MANVI_110,ADAVI AMARESHWAR_110	21:53	22:03	0:10	LINE FAULT
617	3-Dec-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	1:50	1:59	0:09	MAIN SUPPLY FAILURE
618	3-Dec-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	3:10	3:15	0:05	MAIN SUPPLY FAILURE
619	3-Dec-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	5:40	5:48	0:08	MAIN SUPPLY FAILURE
620	3-Dec-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	9:38	9:51	0:13	MAIN SUPPLY FAILURE
621	3-Dec-21	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUR_110	1:50	2:00	0:10	LINE FAULT
622	3-Dec-21	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUR_110	3:10	3:15	0:05	LINE FAULT
623	3-Dec-21	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUR_110	5:41	5:46	0:05	LINE FAULT
624	3-Dec-21	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUR_110	9:39	9:49	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
625	3-Dec-21	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_1 10,KEREHALLI_110,MALLA PUR_110	12:22	12:36	0:14	LINE FAULT
626	3-Dec-21	GULBARGA	110	NANDUR- GULBARGAUNIVERSITY	NANDUR_110	15:10	15:38	0:28	LINE FAULT
627	3-Dec-21	GULBARGA	110	RAICHUR-MATMARI	MATMARI_110	1:35	1:40	0:05	LINE FAULT
628	3-Dec-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	12:10	12:25	0:15	LINE FAULT
629	3-Dec-21	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORAWA R TEMPLE_110	12:01	12:05	0:04	LINE FAULT
630	3-Dec-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
631	3-Dec-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)	14:58 (3.12.2021)	2669:41 HRS	LINE CHARGED
632	3-Dec-21	GULBARGA	110	SINDHANOOR- SINDHANOOR2	SINDHANOOR_110,VALKA MDINNI_110,BYAGAWAT_ 110	11:55	12:05	0:10	LINE FAULT
633	3-Dec-21	GULBARGA	110	STAR METALLICS- MUNIRABAD	MUNIRABAD_220	12:02	12:14	0:12	LINE FAULT
634	3-Dec-21	GULBARGA	110	YERADONA-BENNUR	BENNUR_110	21:30	21:40	0:10	LINE FAULT
635	3-Dec-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
636	3-Dec-21	GULBARGA	220	LINGAPUR-ARREAS STEEL	ARREAS STEEL_220	12:06	18:22	6:16	LINE FAULT
637	3-Dec-21	GULBARGA	220	LINGAPUR-BTPSG	LINGAPUR_220	12:04	18:28	6:24	LINE FAULT
638	3-Dec-21	GULBARGA	220	LINGAPUR-HALAWARTHY1	LINGAPUR_220	12:02	18:34	6:32	LINE FAULT
639	3-Dec-21	GULBARGA	220	LINGAPUR-JINDAL2	LINGAPUR_220	11:45	19:15	7:30	LINE CLEAR AVAILED
640	3-Dec-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:05 (3.12.2021)			LINE OPEN:LINE CLEAR AVAILED
641	3-Dec-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:13 (02.12.2021)	6:52 (03.12.2021)	9:39 HRS	LINE CHARGED
642	3-Dec-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:11(02.12.2021)	6:50(03.12.2021)	8:39HRS	LINE CHARGED
643	3-Dec-21	HASSAN	66	BALEHN-ALDUR	BALEHONNUR_66	15:42	15:55	0:13	LINE FAULT
644	3-Dec-21	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	10:04	13:40	3:36	LINE CLEAR AVAILED
645	3-Dec-21	HASSAN	66	HASSN220-HN PURA	HASSAN_220	14:55	15:25	0:30	LINE FAULT
646	3-Dec-21	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	20:59	21:06	0:07	LINE FAULT
647	3-Dec-21	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	23:12	23:17	0:05	LINE FAULT
648	3-Dec-21	HASSAN	66	HV2	HALEBEEDU_66	11:21	12:30	1:09	LINE CLEAR AVAILED
649	3-Dec-21	HASSAN	66	LV1	CRPATNA_220	10:21	18:01	7:40	LINE CLEAR AVAILED
650	3-Dec-21	HASSAN	66	MALALI-CRPATNA	MALALI_66	21:05	21:11	0:06	MAIN SUPPLY FAILURE
651	3-Dec-21	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	10:04	13:40	3:36	NFBC ISSUED
652	3-Dec-21	HASSAN	110	BARANG	SHIRALKOPPA_220	12:12	12:39	0:27	MAIN SUPPLY FAILURE
653	3-Dec-21	HASSAN	110	HV1	ARASIKERE_220	11:34	14:15	2:41	LINE CLEAR AVAILED
654	3-Dec-21	HASSAN	110	HV1	ESSUR_110	7:36	8:22	0:46	LINE CLEAR AVAILED
655	3-Dec-21	HASSAN	110	HV1	KONDENALU_110	10:07	14:50	4:43	LINE CLEAR AVAILED
656	3-Dec-21	HASSAN	110	HV1	KULASHEKARA_110	10:01	16:15	6:14	LINE CLEAR AVAILED
657	3-Dec-21	HASSAN	110	HV2	KONDENALU_110	10:07	14:50	4:43	LINE CLEAR AVAILED
658	3-Dec-21	HASSAN	110	LPH-LST4	lph_gen	9:39	17:44	8:05	LINE CLEAR AVAILED
659	3-Dec-21	HASSAN	110	LV2	KADUR_220	10:23	14:05	3:42	LINE CLEAR AVAILED
660	3-Dec-21	HASSAN	110	SAGARA-LST4	SAGARA_110	9:37	17:44	8:07	NFBC ISSUED
661	3-Dec-21	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	12:12	12:38	0:26	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
662	3-Dec-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:12	12:37	0:25	MAIN SUPPLY FAILURE
663	3-Dec-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	12:12	12:41	0:29	MAIN SUPPLY FAILURE
664	3-Dec-21	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	12:12	12:42	0:30	MAIN SUPPLY FAILURE
665	3-Dec-21	HASSAN	220	ARSK2-HSN	ARASIKERE_220	10:14	12:57	2:43	NFBC ISSUED
666	3-Dec-21	HASSAN	220	HV1	CRPATNA_220	10:21	18:01	7:40	LINE CLEAR AVAILED
667	3-Dec-21	HASSAN	220	HV2	KADUR_220	10:23	14:02	3:39	LINE CLEAR AVAILED
668	3-Dec-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	13:46	14:06	0:20	LINE FAULT
669	3-Dec-21	HASSAN	220	MRSSHM-VARAH	MRSMSG_220	14:33	17:22	2:49	LINE FAULT
670	3-Dec-21	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	13:46	14:06	0:20	LINE FAULT
671	3-Dec-21	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	12:00	14:53	2:53	LINE FAULT
672	3-Dec-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	12:00	14:53	2:53	LINE FAULT
673	3-Dec-21	HASSAN	220	VARAH-SHIMOGA1	varahi_gen	14:33	17:22	2:49	LINE FAULT
674	3-Dec-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:21(3.12.2021)			LINE OPEN:LINE CLEAR AVAILED
675	3-Dec-21	MYSORE	66	CR NAGARA-CHANDAKAWADI	CHANDAKAWADI_66	9:11	9:17	0:06	LINE FAULT
676	3-Dec-21	MYSORE	66	DK MAIDANA-VAJMANGALA	NO STATIONS EFFECTED	11:22	17:24	6:01	LINE CLEAR AVAILED
677	3-Dec-21	MYSORE	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN:LINE CLEAR AVAILED
678	3-Dec-21	MYSORE	66	HANNUR-KOTTANUR	NO STATIONS EFFECTED	6:43	6:49	0:06	LINE FAULT
679	3-Dec-21	MYSORE	66	HARADANAHALLI(JAK)-LAXJEET	NO STATIONS EFFECTED	13:49	13:55	0:05	LINE FAULT
680	3-Dec-21	MYSORE	66	HOOTGALLY-BELAGOLA	BELAGOLA_66	15:25	17:24	1:59	LINE CLEAR AVAILED
681	3-Dec-21	MYSORE	66	HOOTGALLY-ELVALA	NO STATIONS EFFECTED	12:50	13:13	0:23	LINE FAULT
682	3-Dec-21	MYSORE	66	HOOTGALLY-HAMPAPURA	NO STATIONS EFFECTED	10:37	12:30	1:53	LINE CLEAR AVAILED
683	3-Dec-21	MYSORE	66	HOOTGALLY-HUNSUR	BANNILUPPE_66 HOSURGATE_66	10:46	11:25	0:39	LINE FAULT
684	3-Dec-21	MYSORE	66	HOOTGALLY-VIJAYNAGARA	NO STATIONS EFFECTED	11:44	17:17	5:33	LINE CLEAR AVAILED
685	3-Dec-21	MYSORE	66	HUNSUR-PERIYAPATNA	KAMPLAPURA_66	10:40	13:00	2:20	NFBC ISSUED
686	3-Dec-21	MYSORE	66	HV1	HEBBAL_66	17:16	17:48	0:32	TRANSFORMER FAULT
687	3-Dec-21	MYSORE	66	KADAKOLA-SARGUR1	JAYPURA_66 HAMPAPURA_66	7:49	7:54	0:05	LINE FAULT
688	3-Dec-21	MYSORE	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN:LINE CLEAR AVAILED
689	3-Dec-21	MYSORE	66	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	17:43	17:48	0:05	LINE FAULT
690	3-Dec-21	MYSORE	66	SARGUR-KADKOLA1	HDKOTE_66 ANTHARSANTHE_66 YERAHALLI_66	15:50	17:45	1:55	LINE CLEAR AVAILED
691	3-Dec-21	MYSORE	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66	18:04	18:09	0:05	LINE FAULT
692	3-Dec-21	MYSORE	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66	18:15	18:22	0:06	LINE FAULT
693	3-Dec-21	MYSORE	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66	18:23	18:42	0:18	LINE FAULT
694	3-Dec-21	MYSORE	66	VAJMANGALA-KADAKOLA1	AYRAHALLI_66 MARADIHUNDI_66	17:45	17:54	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
695	3-Dec-21	MYSORE	220	CR NAGARA-MADHUVANALLI2	NO STATIONS EFFECTED	14:15	16:51	2:35	LINE FAULT
696	3-Dec-21	TUMKUR	66	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	17:49	19:06	1:17	LINE FAULT
697	3-Dec-21	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLTEGERE	KOLTEGERE,CHIKKATOTLU KERE_66,BELADARA_66	13:41	14:12	0:31	HAND TRIPPED
698	3-Dec-21	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66 JAGALUR_66	1:44	1:50	0:06	LINE FAULT
699	3-Dec-21	TUMKUR	66	BRAHMASANDRA- SIRA	BRAHMASANDRA_66	15:14	15:24	0:09	LINE FAULT
700	3-Dec-21	TUMKUR	66	BRAHMASANDRA-SUNWIKI STEEL	SUNWIKI STEEL_EHT_66	15:14	15:24	0:09	LINE FAULT
701	3-Dec-21	TUMKUR	66	H D PURA- SUZLON_IPP_66	SUZLON_IPP_66	10:44	18:28	7:44	LINE CLEAR AVAILED
702	3-Dec-21	TUMKUR	66	HIRIYUR 220KV- ENERCON1 IPP_66	ENERCON1_IPP_66	18:15	18:30	0:14	HAND TRIPPED
703	3-Dec-21	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	18:15	18:30	0:14	HAND TRIPPED
704	3-Dec-21	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	18:15	18:30	0:15	HAND TRIPPED
705	3-Dec-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	18:15	18:28	0:12	HAND TRIPPED
706	3-Dec-21	TUMKUR	66	HIRIYUR220-MATHOD	MATHOD_66,HINDASGHAT TA_66,KANCHIPURA_66,GA RAGA_66,PANCHANAHALLI _66,HOSADURGA_66	18:13	18:35	0:22	HAND TRIPPED
707	3-Dec-21	TUMKUR	66	HIRIYUR66- CHITRADURGA220KV	CHITRADURGA_66	18:15	18:28	0:12	HAND TRIPPED
708	3-Dec-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANN GIRI_66	9:58	10:09	0:11	LINE FAULT
709	3-Dec-21	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66, NEELAGUNDA_66	5:21	5:34	0:12	LINE FAULT
710	3-Dec-21	TUMKUR	66	PATTNAYAKANAHALLI66- SIRA66	PATTNAYAKANAHALLI_66	17:46	18:08	0:22	LINE FAULT
711	3-Dec-21	TUMKUR	66	TR-1	MADADAKERE_66	10:59	11:15	0:15	TRANSFORMER FAULT
712	3-Dec-21	TUMKUR	66	TR-1	MATHOD_66	18:08	18:34	0:26	TRANSFORMER FAULT
713	3-Dec-21	TUMKUR	66	TR-1	PAVAGADA_220	9:15	9:18	0:02	TRANSFORMER FAULT
714	3-Dec-21	TUMKUR	66	TR-1(LV SDE)	ANTHRASANAHALLI_220	13:05	13:13	0:08	TRANSFORMER FAULT
715	3-Dec-21	TUMKUR	66	TR-2	BALENAHALLI_66	14:43	14:56	0:13	TRANSFORMER FAULT
716	3-Dec-21	TUMKUR	66	TR-2	KADAJJI_66	10:54	11:02	0:08	TRANSFORMER FAULT
717	3-Dec-21	TUMKUR	66	TR-2	KADAJJI_66	21:57	22:03	0:06	TRANSFORMER FAULT
718	3-Dec-21	TUMKUR	66	TURUVANUR66- CHITRADURGA	TURUVANUR_66	18:10	18:15	0:05	LINE FAULT
719	3-Dec-21	TUMKUR	66	TURUVANUR66-JAGALUR	TURUVANUR_66	18:10	18:17	0:07	LINE FAULT
720	3-Dec-21	TUMKUR	110	TR-1(LV SDE)	KBCROSS_220	15:30	16:43	1:13	LINE CLEAR AVAILED
721	3-Dec-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	13:38	14:01	0:22	HAND TRIPPED
722	3-Dec-21	TUMKUR	220	NITTUR 220-ARASIKERE	NITTUR_220	10:15	12:58	2:42	LINE CLEAR AVAILED
723	3-Dec-21	TUMKUR	220	TR-1(HV SDE)	ANTHRASANAHALLI_220	13:06	13:13	0:06	TRANSFORMER FAULT
724	3-Dec-21	TUMKUR	220	TR-1(HV SDE)	KBCROSS_220	15:30	16:42	1:12	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
725	3-Dec-21	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	18:08	18:23	0:15	TRANSFORMER FAULT
726	4-Dec-21	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	4:30 (10.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
727	4-Dec-21	BAGALKOT	110	110/11KV, HV2	SUVARNASOUDA_110	16:00	18:09	2:09	LINE CLEAR AVAILED
728	4-Dec-21	BAGALKOT	110	110/11KV, HV3	SINDAGI_110	17:10	17:18	0:08	HAND TRIPPED
729	4-Dec-21	BAGALKOT	110	110/11KV,HV1	KADANKOPPA_110	15:11	18:09	2:58	LINE CLEAR AVAILED
730	4-Dec-21	BAGALKOT	110	110/11KV,HV2	KATARAKI_110	9:40	9:52	0:12	TRANSFORMER FAULT
731	4-Dec-21	BAGALKOT	110	110/11KV,HV2	MAREGUDDI_110	18:45	19:50	1:05	LINE CLEAR AVAILED
732	4-Dec-21	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	0:27 (04.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
733	4-Dec-21	BAGALKOT	110	AMBEWADI-NK-1	AMBEWADI_220	13:54	14:03	0:09	HAND TRIPPED
734	4-Dec-21	BAGALKOT	110	ATHANI220-ATHANI110	ATHANI_220	18:17	18:22	0:05	HAND TRIPPED
735	4-Dec-21	BAGALKOT	110	B.BAGEWADI - MAMADAPUR1	MAMADAPUR(B)_110	11:14	12:40	1:26	NFBC ISSUED
736	4-Dec-21	BAGALKOT	110	BABALESHWAR- MAMADAPUR(B)	MAMADAPUR(B)_110	11:15	11:21	0:06	LINE FAULT
737	4-Dec-21	BAGALKOT	110	GADAG-LAKSHMESHVAR	LAKSHMESHVAR_110	9:29 (03.12.2021)			LINE OPEN:LINE CLEAR AVAILED
738	4-Dec-21	BAGALKOT	110	GHATAPRABHA220-GOKAK	GHATAPRABHA_220	18:00	18:21	0:21	LINE FAULT
739	4-Dec-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVTKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
740	4-Dec-21	BAGALKOT	110	HUNGUND-KUDAL SANGAM(BAGEWADI)	KUDALSANGAM_110	0:42	0:52	0:10	LINE FAULT
741	4-Dec-21	BAGALKOT	110	ITNAL-BPCL 2	ITNAL_110	22:41	22:49	0:08	LINE FAULT
742	4-Dec-21	BAGALKOT	110	MAMADAPUR(B)-BELGAUM SOLAR	MAMADAPUR(B)_110	11:14	12:43	1:29	LINE CLEAR AVAILED
743	4-Dec-21	BAGALKOT	110	MAMADAPUR(G)-SOUBHGYA LAKSHMI SUGARS	MAMADAPUR(G)_110	16:20	18:30	2:10	LINE CLEAR AVAILED
744	4-Dec-21	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110,BISNAL_110,TO LAMATTI_110, GIRISAGAR_110	13:40	14:10	0:30	LINE CLEAR AVAILED
745	4-Dec-21	BAGALKOT	110	SHIRAHATTI- BPCL	SHIRAHATTI_110	7:22	7:43	0:21	LINE FAULT
746	4-Dec-21	BAGALKOT	110	TODALBAGI- JAMKHANDI SUGARS	TODALBAGI_110	18:25	18:28	0:03	HAND TRIPPED
747	4-Dec-21	BAGALKOT	110	TODALBAGI- MAMADAPUR(B)	TODALBAGI_110	10:31	10:36	0:05	HAND TRIPPED
748	4-Dec-21	BAGALKOT	110	TODALBAGI- MAMADAPUR(B)	TODALBAGI_110	11:08	11:11	0:03	HAND TRIPPED
749	4-Dec-21	BAGALKOT	110	VAJRAMATTI220- VAJRAMATTI	VAJRAMATTI_110	18:10	18:25	0:15	LINE FAULT
750	4-Dec-21	BAGALKOT	220	220/110KV,HV1&LV1	SOUDATTI_220	8:05	17:23	9:18	LINE CLEAR AVAILED
751	4-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
752	4-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
753	4-Dec-21	BAGALKOT	220	BELGAUM- KANABRG12	BELGAUM_220	19:46	19:51	0:06	LINE FAULT
754	4-Dec-21	BAGALKOT	220	BIDNAL- HARTI2	BIDNAL_220	13:22	16:15	2:53	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
755	4-Dec-21	BAGALKOT	220	BIDNAL-HART1	BIDNAL_220	2:57 (02.12.2021)	16:14 (04.12.2021)	61:17 hrs	LINE CHARGED
756	4-Dec-21	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
757	4-Dec-21	BAGALKOT	220	HAVERI- NARENDRA	HAVERI_220	10:19 (30.11.2021)			LINE OPEN:LINE CLEAR AVAILED
758	4-Dec-21	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
759	4-Dec-21	BAGALKOT	220	MK HUBLI-NARENDRA2	MK HUBLI_220	10:46	15:49	5:03	LINE CLEAR AVAILED
760	4-Dec-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
761	4-Dec-21	BAGALKOT	220	NARENDRA-HAVERI	NARENDRA_220	10:19 (30.11.2021)			LINE OPEN:LINE CLEAR AVAILED
762	4-Dec-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
763	4-Dec-21	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
764	4-Dec-21	BENGALURU	66	AUSTIN TOWN - EAST DIVISION COMPOUND 220	AUSTIN TOWN	18:20	19:45	1:25	MAIN SUPPLY FAILURE
765	4-Dec-21	BENGALURU	66	B STATION - EAST DIVISION COMPOUND 220	B STATION	18:20	18:40	0:20	MAIN SUPPLY FAILURE
766	4-Dec-21	BENGALURU	66	BMTC - EAST DIVISION COMPOUND 220	BMTC	18:20	19:41	1:21	MAIN SUPPLY FAILURE
767	4-Dec-21	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	12:35	12:46	0:11	MAIN SUPPLY FAILURE
768	4-Dec-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	HBR LAYOUT, BELL CERAMICS (EHT)	9:08	9:16	0:08	LINE FAULT
769	4-Dec-21	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	15:15	15:20	0:05	LOAD CHANGEOVER
770	4-Dec-21	BENGALURU	66	HV1	AMARJYOTHI	18:20	18:32	0:12	MAIN SUPPLY FAILURE
771	4-Dec-21	BENGALURU	66	HV1	AMARJYOTHI	18:40	18:42	0:02	MAIN SUPPLY FAILURE
772	4-Dec-21	BENGALURU	66	HV1	KANAKAPURA 66	9:45	14:42	4:57	TRANSFORMER FAULT
773	4-Dec-21	BENGALURU	66	HV1	N G HULKUR	14:10	14:15	0:04	LINE CLEAR AVAILED
774	4-Dec-21	BENGALURU	66	HV2	ATTIBELE	13:45	14:25	0:40	LINE CLEAR AVAILED
775	4-Dec-21	BENGALURU	66	HV2	GOKULA	8:38	8:52	0:14	TRANSFORMER FAULT
776	4-Dec-21	BENGALURU	66	HV2	KENGERI SATELLITE TOWN	6:52	7:04	0:12	TRANSFORMER FAULT
777	4-Dec-21	BENGALURU	66	HV2	N G HULKUR	12:38	12:42	0:03	LINE CLEAR AVAILED
778	4-Dec-21	BENGALURU	66	HV2	SADLI	14:44	15:23	0:38	LINE CLEAR AVAILED
779	4-Dec-21	BENGALURU	66	HV2	SIDDALAGATTA	11:21	12:31	1:09	LINE CLEAR AVAILED
780	4-Dec-21	BENGALURU	66	HV2	VIJAYANAGARA	11:10	12:38	1:28	LINE CLEAR AVAILED
781	4-Dec-21	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	18:20	18:58	0:38	MAIN SUPPLY FAILURE
782	4-Dec-21	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
783	4-Dec-21	BENGALURU	66	KORAMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	18:20	19:36	1:16	MAIN SUPPLY FAILURE
784	4-Dec-21	BENGALURU	66	MAGADI 66 - ANCHEPALYA 220	MAGADI 66	9:00	18:05	9:05	LINE CLEAR AVAILED
785	4-Dec-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	6:12	6:21	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
786	4-Dec-21	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE	18:20	19:46	1:26	MAIN SUPPLY FAILURE
787	4-Dec-21	BENGALURU	66	PADMANABHANAGARA - NIMHANS 220	PADMANABHANAGARA	18:20	18:25	0:05	MAIN SUPPLY FAILURE
788	4-Dec-21	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	10:02	17:33	7:31	LINE CLEAR AVAILED
789	4-Dec-21	BENGALURU	66	VIDYANAGAR - BEGUR 220	VIDYANAGAR, HENNUR CROSS	12:31	12:51	0:20	LOAD CHANGEOVER
790	4-Dec-21	BENGALURU	66	VIDYANAGAR - HOSKOTE 220	VIDYANAGAR, HENNUR CROSS	13:44	13:50	0:06	LOAD CHANGEOVER
791	4-Dec-21	BENGALURU	220	CHINTAMANI 220 - PGCIL 1	NO STATION AFFECTED	10:22	15:23	5:01	LINE CLEAR AVAILED
792	4-Dec-21	BENGALURU	220	EAST DIVISION COMPOUND 220 - HAL 220	EAST DIVISION COMPOUND 220	18:20	19:30	1:10	LINE FAULT
793	4-Dec-21	BENGALURU	220	KOLAR 220 - PGCIL 2	NO STATION AFFECTED	15:44	16:46	1:02	LINE CLEAR AVAILED
794	4-Dec-21	BENGALURU	220	KORAMANGALA 220 - NIMHANS 220	KORAMANGALA 220	18:20	18:35	0:15	MAIN SUPPLY FAILURE
795	4-Dec-21	BENGALURU	220	KORAMANGALA 220 - NIMHANS 220	KORAMANGALA 220	18:40	19:35	0:55	MAIN SUPPLY FAILURE
796	4-Dec-21	BENGALURU	220	NIMHANS 220 - EAST DIVISION COMPOUND 220	NIMHANS 220	18:20	18:32	0:12	MAIN SUPPLY FAILURE
797	4-Dec-21	BENGALURU	220	NIMHANS 220 - EAST DIVISION COMPOUND 220	NIMHANS 220	18:40	19:32	0:52	MAIN SUPPLY FAILURE
798	4-Dec-21	BENGALURU	400	NELAMANGALA 400 - HASAN 400	NO STATION AFFECTED	17:48:06(3-12-2021)			LINE OPEN:LINE FAULT
799	4-Dec-21	GULBARGA	66	HANASI-BADALADUKU	HANSI_66	21:05	21:30	0:25	MAIN SUPPLY FAILURE
800	4-Dec-21	GULBARGA	66	HANASI-BADALADUKU	HANSI_66	17:30	18:25	0:55	MAIN SUPPLY FAILURE
801	4-Dec-21	GULBARGA	66	HV2	KOGALI_66	17:05	17:15	0:10	TRANSFORMER FAULT
802	4-Dec-21	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
803	4-Dec-21	GULBARGA	66	KOGALI-ATRIA SOLAR_IPP	KOGALI_66	19:00(04.12.2021)			LINE OPEN:LINE CLEAR AVAILED
804	4-Dec-21	GULBARGA	66	UCHCHANGIDURGA-BILCHOD	BILCHOD_66	6:15	6:20	0:05	LINE FAULT
805	4-Dec-21	GULBARGA	110	BISLAHALLI-BELLARYNORTH	BISLAHALLI_110	4:37	5:47	1:10	MAIN SUPPLY FAILURE
806	4-Dec-21	GULBARGA	110	BISLAHALLI-BELLARYNORTH	BISLAHALLI_110	8:20	8:28	0:08	MAIN SUPPLY FAILURE
807	4-Dec-21	GULBARGA	110	GABBUR-RAICHUR	GABBUR	22:05	22:10	0:05	MAIN SUPPLY FAILURE
808	4-Dec-21	GULBARGA	110	GULBARGAUNIVERSITY-GULBARGASOUTH	GULBARGAUNIVERSITY_110	17:40	17:45	0:05	MAIN SUPPLY FAILURE
809	4-Dec-21	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110,HABSIKOTE_110	6:11	6:26	0:15	LINE FAULT
810	4-Dec-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	6:38	6:43	0:05	LINE FAULT
811	4-Dec-21	GULBARGA	110	HV3	TEKKALKOTE_110	14:55	17:40	2:45	LINE CLEAR AVAILED
812	4-Dec-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	16:55	20:46	3:51	LINE CHARGED
813	4-Dec-21	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGUTTI_110	16:55	20:45	3:50	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
814	4-Dec-21	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIRE GONNEGAR_110, HANUMNAL_110	4:49	5:02	0:13	LINE FAULT
815	4-Dec-21	GULBARGA	110	KUSTAGI-TAWARGERE	TAWARGERE_110	0:08	0:20	0:12	LINE FAULT
816	4-Dec-21	GULBARGA	110	LADHA-BHALKI	LADHA_110	6:40	6:45	0:05	MAIN SUPPLY FAILURE
817	4-Dec-21	GULBARGA	110	LADHA-RENEWSOLAR_IPP	LADHA_110	16:10	16:30	0:20	LINE FAULT
818	4-Dec-21	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	6:22	6:32	0:10	LINE FAULT
819	4-Dec-21	GULBARGA	110	NANDUR-GULBARGAUNIVERSITY	NANDUR_110	17:40	17:45	0:05	LINE FAULT
820	4-Dec-21	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKSUGUR_110,SHAKTINAGAR_110	14:50	17:50	3:00	LINE CLEAR AVAILED
821	4-Dec-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:28	5:45	0:17	LINE FAULT
822	4-Dec-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	17:51	18:00	0:09	LINE FAULT
823	4-Dec-21	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDI CROSS_110,MADLAPUR_110,MANVI_110	5:45	5:50	0:05	LINE FAULT
824	4-Dec-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YEDRAMI_110,MORTAGI_110	6:20	6:55	0:35	LINE FAULT
825	4-Dec-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
826	4-Dec-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADGERA_110,SANNATHI_110,CORE GREEN SUGUR_IPP	4:07	4:12	0:05	LINE FAULT
827	4-Dec-21	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	11:41	11:51	0:10	LINE FAULT
828	4-Dec-21	GULBARGA	110	SIRIGERICROSS-ALIPUR	SIRIGERICROSS_110	13:48	14:10	0:22	MAIN SUPPLY FAILURE
829	4-Dec-21	GULBARGA	220	HV1,LV1	KAPNOOR_220	12:08	20:20	8:12	LINE CLEAR AVAILED
830	4-Dec-21	GULBARGA	220	HV2	HALBARGA_220	15:14	16:55	1:41	LINE CLEAR AVAILED
831	4-Dec-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
832	4-Dec-21	GULBARGA	220	KUSTAGI-LINGAPUR	LINGAPUR_220	9:32	9:50	0:18	LINE FAULT
833	4-Dec-21	GULBARGA	220	KUSTAGI-LINGAPUR	LINGAPUR_220	13:02	13:22	0:20	LINE FAULT
834	4-Dec-21	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	12:02	18:35	6:33	LINE FAULT
835	4-Dec-21	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	6:00	6:29	0:29	LINE FAULT
836	4-Dec-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:05 (3.12.2021)	7:11 (4.12.2021)	9:06 HRS	LINE CHARGED
837	4-Dec-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:58 (4.12.2021)			LINE OPEN:LINE CLEAR AVAILED
838	4-Dec-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	0:11	6:18	6:07	LINE CHARGED
839	4-Dec-21	GULBARGA	400	BTPSG-RTPS	RTPS_400	5:28	13:49	8:21	LINE FAULT
840	4-Dec-21	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	15:22	15:39	0:17	LINE FAULT
841	4-Dec-21	HASSAN	66	HV1	HAGARE_66	12:26	13:15	0:49	LINE CLEAR AVAILED
842	4-Dec-21	HASSAN	66	HV2	HASSAN_66	19:03	19:24	0:21	TRANSFORMER FAULT
843	4-Dec-21	HASSAN	66	MATTNAV-DIDGTHL	MATTNAVILE_66	6:10	7:02	0:52	LINE FAULT
844	4-Dec-21	HASSAN	66	MATTNAV-DIDGTHL	MATTNAVILE_66	14:07	14:28	0:21	LINE FAULT
845	4-Dec-21	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	15:22	15:39	0:17	LINE FAULT
846	4-Dec-21	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	7:11	7:30	0:19	LINE FAULT
847	4-Dec-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	10:54	14:03	3:09	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
848	4-Dec-21	HASSAN	110	HV1	SHIVAPURA_110	14:22	15:44	1:22	LINE CLEAR AVAILED
849	4-Dec-21	HASSAN	110	HV2	PUTTUR_110	9:20	10:10	0:50	LINE CLEAR AVAILED
850	4-Dec-21	HASSAN	110	HV2	PUTTUR_110	14:52	15:40	0:48	LINE CLEAR AVAILED
851	4-Dec-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:55	14:03	3:08	LINE CLEAR AVAILED
852	4-Dec-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:59	13:32	0:33	LINE FAULT
853	4-Dec-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	12:50	13:40	0:50	LINE FAULT
854	4-Dec-21	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	12:50	13:40	0:50	LINE FAULT
855	4-Dec-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:21(3.12.2021)			LINE OPEN:LINE CLEAR AVAILED
856	4-Dec-21	MYSORE	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN:LINE CLEAR AVAILED
857	4-Dec-21	MYSORE	66	HOOTGALLY-VIJAYNAGARA	NO STATIONS EFFECTED	10:04	12:44	2:40	LINE CLEAR AVAILED
858	4-Dec-21	MYSORE	66	HV2	HOOTGALLY_66	14:35	15:04	0:29	LINE CLEAR AVAILED
859	4-Dec-21	MYSORE	66	KADKOLA-KOZHIKODE	NO STATIONS EFFECTED	8:27:00 (4.12.2021)			LINE OPEN:LINE CLEAR AVAILED
860	4-Dec-21	MYSORE	66	KADKOLA-SARGUR2	NO STATIONS EFFECTED	17:23	17:28	0:05	LINE FAULT
861	4-Dec-21	MYSORE	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN:LINE CLEAR AVAILED
862	4-Dec-21	MYSORE	66	TUBINKERE-MC2	HAMPAPURA_66 BASARALU_66 BESAGARAHALLI_66 KOPPA_66 KESLAGERE_66 KK HALLI_66 MANDYA_66 CHIKMANDYA_66	21:20	21:25	0:05	LINE FAULT
863	4-Dec-21	MYSORE	66	TUBINKERE-MC2	HAMPAPURA_66 BASARALU_66 BESAGARAHALLI_66 KOPPA_66 KESLAGERE_66 KK HALLI_66 MANDYA_66 CHIKMANDYA_66	21:40	21:45	0:05	LINE FAULT
864	4-Dec-21	MYSORE	66	TUBINKERE-MC2	HAMPAPURA_66 BASARALU_66 BESAGARAHALLI_66 KOPPA_66 KESLAGERE_66 KK HALLI_66 MANDYA_66 CHIKMANDYA_66	21:41	22:00	0:19	LINE FAULT
865	4-Dec-21	MYSORE	66	TUBINKERE-MC2	HAMPAPURA_66 BASARALU_66 BESAGARAHALLI_66 KOPPA_66 KESLAGERE_66 KK HALLI_66 MANDYA_66 CHIKMANDYA_66	22:05	22:30	0:25	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
866	4-Dec-21	MYSORE	66	TUBINKERE-MC4	HAMPAPURA_66 BASARALU_66 BESAGARAHALLI_66 KOPPA_66 KESLAGERE_66 KK HALLI_66 MANDYA_66 CHIKMANDYA_66	21:20	21:25	0:05	LINE FAULT
867	4-Dec-21	MYSORE	66	TUBINKERE-MC4	HAMPAPURA_66 BASARALU_66 BESAGARAHALLI_66 KOPPA_66 KESLAGERE_66 KK HALLI_66 MANDYA_66 CHIKMANDYA_66	21:41	22:00	0:19	LINE FAULT
868	4-Dec-21	MYSORE	66	TUBINKERE-MC4	HAMPAPURA_66 BASARALU_66 BESAGARAHALLI_66 KOPPA_66 KESLAGERE_66 KK HALLI_66 MANDYA_66 CHIKMANDYA_66	22:05	22:30	0:25	LINE FAULT
869	4-Dec-21	MYSORE	66	TUBINKERE- NAGAMANGALA2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66 SHIVALLY_66	22:05	22:30	0:25	LINE FAULT
870	4-Dec-21	MYSORE	66	VAJMANGALA-KADKOLA1	AYRAHALLI_66 MARADIHUNDI_66	14:35	15:04	0:29	LINE FAULT
871	4-Dec-21	TUMKUR	66	ANCHEPALYA 220kv- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66, YADAVANI_66	9:03	18:00	8:57	LINE CLEAR AVAILED
872	4-Dec-21	TUMKUR	66	ANCHEPALYA 220kv- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	9:03	18:00	8:57	LINE CLEAR AVAILED
873	4-Dec-21	TUMKUR	66	ANCHEPALYA 220kv- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	9:02	18:11	9:08	LINE CLEAR AVAILED
874	4-Dec-21	TUMKUR	66	ANCHEPALYA 220kv- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	9:03	18:00	8:56	LINE CLEAR AVAILED
875	4-Dec-21	TUMKUR	66	ANCHEPALYA 220kv- T G HALLI	GUDIMARANAHALLI_66,M AGADI_66, TGHALLI_66, VGDODDI_66	9:03	18:01	8:57	LINE CLEAR AVAILED
876	4-Dec-21	TUMKUR	66	ANCHEPALYA 220kv- VIJAYA STEEL	VIJAYA STEEL	9:03	18:13	9:10	LINE CLEAR AVAILED
877	4-Dec-21	TUMKUR	66	ANCHEPALYA 220kv- YEDIYUR(BG NAGAR)	JIDDIGERE_66, YEDIYUR_66	9:03	18:23	9:20	LINE CLEAR AVAILED
878	4-Dec-21	TUMKUR	66	ANCHEPALYA 66kv- ANCHEPALYA-2-KUDUR	ANCHEPALYA 66kv	9:02	18:03	9:00	LINE CLEAR AVAILED
879	4-Dec-21	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	14:06	17:40	3:34	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
880	4-Dec-21	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	4:33	4:47	0:14	LINE FAULT
881	4-Dec-21	TUMKUR	66	BENNEHALLI-RBPL-SUZLON	BENNEHALLI_66	6:41	6:54	0:13	LINE FAULT
882	4-Dec-21	TUMKUR	66	BILCHODU-PALLAGATTE	PALLAGATTE_66	5:54	6:03	0:08	LINE FAULT
883	4-Dec-21	TUMKUR	66	BILCHODU-PALLAGATTE	PALLAGATTE_66	10:01	10:07	0:05	LINE FAULT
884	4-Dec-21	TUMKUR	66	BILCHODU-UCHANGIDURGA	BILCHODU_66	6:15	6:24	0:08	LINE FAULT
885	4-Dec-21	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	11:53	13:27	1:34	LINE CLEAR AVAILED
886	4-Dec-21	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 1_IPP_66	14:58	15:54	0:56	LINE CLEAR AVAILED
887	4-Dec-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	0:03	0:13	0:10	LINE FAULT
888	4-Dec-21	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:24	10:34	0:09	LINE FAULT
889	4-Dec-21	TUMKUR	66	HULIYURDURGA- ANCHEPALYA	HULIYURDURGA_66,	9:38	9:40	0:02	HAND TRIPPED
890	4-Dec-21	TUMKUR	66	LV1	ANCHEPALYA_220	9:04	17:58	8:53	LINE CLEAR AVAILED
891	4-Dec-21	TUMKUR	66	LV2	ANCHEPALYA_220	9:04	17:58	8:53	LINE CLEAR AVAILED
892	4-Dec-21	TUMKUR	66	TR-1	BELLAVI_66	15:06	17:16	2:09	LINE CLEAR AVAILED
893	4-Dec-21	TUMKUR	66	TR-2	BADAVANAHALLI_66	13:00	13:21	0:21	LINE CLEAR AVAILED
894	4-Dec-21	TUMKUR	66	TR-2	NAYAKANAHATTI_66	12:02	12:13	0:10	TRANSFORMER FAULT
895	4-Dec-21	TUMKUR	66	TR-2	NAYAKANAHATTI_66	13:51	13:59	0:07	TRANSFORMER FAULT
896	4-Dec-21	TUMKUR	66	YADAVANI-ANCHEPALYA	YADAVANI_66	18:10	23:04	4:53	MAIN SUPPLY FAILURE
897	5-Dec-21	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	4:30 (10.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
898	5-Dec-21	BAGALKOT	110	110/11KV,HV1	MACHE_110	15:22	15:55	0:33	LINE CLEAR AVAILED
899	5-Dec-21	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	3:05	3:17	0:12	TRANSFORMER FAULT
900	5-Dec-21	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	3:05	3:15	0:10	TRANSFORMER FAULT
901	5-Dec-21	BAGALKOT	110	110/11KV,HV2	MACHE_110	18:02	18:19	0:17	LINE CLEAR AVAILED
902	5-Dec-21	BAGALKOT	110	110/11KV,HV2	MAREGUDDI_110	10:00	11:00	1:00	LINE CLEAR AVAILED
903	5-Dec-21	BAGALKOT	110	110/33KV,HV2	MACHE_110	15:23	17:34	2:11	LINE CLEAR AVAILED
904	5-Dec-21	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	0:27 (04.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
905	5-Dec-21	BAGALKOT	110	BAGALKOT-RAMDURGA	BAGALKOT_220	6:39	8:25	1:46	LINE FAULT
906	5-Dec-21	BAGALKOT	110	BASAVESHWAR SUGARS- MALGHAN(B)	MALGHAN(B)_110	7:09	8:35	1:26	LINE FAULT
907	5-Dec-21	BAGALKOT	110	BELGAUM-VADAGOAN	VADAGOAN_110	8:41	15:17	6:36	LINE CLEAR AVAILED
908	5-Dec-21	BAGALKOT	110	DHAVALESHWAR-SAIDAPUR	SAIDAPUR_110	7:16	7:23	0:07	LINE FAULT
909	5-Dec-21	BAGALKOT	110	GADAG-LAKSHMESHWAR	LAKSHMESHWAR_110	9:29 (03.12.2021)			LINE OPEN:LINE CLEAR AVAILED
910	5-Dec-21	BAGALKOT	110	GHATAPRABHA- SOEPL	GHATAPRABHA_220	7:47	7:58	0:11	LINE FAULT
911	5-Dec-21	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA2	GHATAPRABHA_220	7:12	7:38	0:26	LINE FAULT
912	5-Dec-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
913	5-Dec-21	BAGALKOT	110	HUNGUND-ILKAL 1&2	HUNGUND_110	11:25	18:15	6:50	LINE CLEAR AVAILED
914	5-Dec-21	BAGALKOT	110	ILKAL-AVAADA SOLAR	ILKAL_110	10:45	17:28	6:43	LINE CLEAR AVAILED
915	5-Dec-21	BAGALKOT	110	ILKAL-KUSHTAGI 2	ILKAL_110	10:45	17:18	6:33	LINE CLEAR AVAILED
916	5-Dec-21	BAGALKOT	110	INDI-DEVARAHIPPARAGI	DEVARAHIPPARAGI_110,AT HARGA_110,HIREMASALI_110	7:01	7:05	0:04	LINE FAULT
917	5-Dec-21	BAGALKOT	110	INDI-LACHYAN	LACHYAN_110,RODAGI_11 0,HIREVANUR_110	7:01	7:05	0:04	LINE FAULT
918	5-Dec-21	BAGALKOT	110	INDI-LACHYAN	LACHYAN_110,RODAGI_11 0,HIREVANUR_110	7:09	10:35	3:26	LINE CLEAR AVAILED
919	5-Dec-21	BAGALKOT	110	INDI-LACHYAN	LACHYAN_110,RODAGI_11 0,HIREVANUR_110	10:35	14:08	3:33	LINE CLEAR AVAILED
920	5-Dec-21	BAGALKOT	110	ITNAL-HIDIKAL 1(SULTHANPUR)	ITNAL_110	9:35	17:49	8:14	LINE CLEAR AVAILED
921	5-Dec-21	BAGALKOT	110	ITNAL-HIDIKAL 2(KABBUR 2)	ITNAL_110	18:15	18:59	0:44	LINE FAULT
922	5-Dec-21	BAGALKOT	110	KULGERI CROSS-MRN SUGARS	KULGERI CROSS_110	6:39	6:41	0:02	LINE FAULT
923	5-Dec-21	BAGALKOT	110	KUMTA-SIRSI 1	KUMTA_110	12:10	18:56	6:46	LINE FAULT
924	5-Dec-21	BAGALKOT	110	MK HUBLI220- HIREBAGEWADI	MK HUBLI_220	14:45	17:57	3:12	LINE CLEAR AVAILED
925	5-Dec-21	BAGALKOT	110	MK HUBLI220-MK HUBLI LINE 1	MK HUBLI_220	10:50	17:59	7:09	LINE CLEAR AVAILED
926	5-Dec-21	BAGALKOT	110	MK HUBLI-BEDI	MK HUBLI_220	9:55	17:55	8:00	LINE CLEAR AVAILED
927	5-Dec-21	BAGALKOT	110	MK HUBLI-KHANAPUR	MK HUBLI_220	6:27	6:50	0:23	LINE FAULT
928	5-Dec-21	BAGALKOT	110	MK HUBLI- NARENDRA(KITTUR)	MK HUBLI_110	10:03	17:50	7:47	LINE CLEAR AVAILED
929	5-Dec-21	BAGALKOT	110	MUGALKHOD-ITNAL2	MUGALKHOD_220	18:14	19:00	0:46	LINE FAULT
930	5-Dec-21	BAGALKOT	110	SIRSI- KUMTA1	SIRSI_110	11:55	18:55	7:00	LINE FAULT
931	5-Dec-21	BAGALKOT	110	SIRSI- KUMTA2	SIRSI_110	12:21	18:53	6:32	LINE CLEAR AVAILED
932	5-Dec-21	BAGALKOT	110	TODALBAGI- JAMKHANDI SUGARS	TODALBAGI_110	22:56	23:09	0:13	LINE FAULT
933	5-Dec-21	BAGALKOT	110	VODAGOAN- BELGAUM220	VODAGOAN_110	8:41	15:17	6:36	LINE CLEAR AVAILED
934	5-Dec-21	BAGALKOT	220	220/110KV,HV1&LV1	SOUDATTI_220	8:11	13:06	4:55	LINE CLEAR AVAILED
935	5-Dec-21	BAGALKOT	220	220/110KV,HV2&LV2	SOUDATTI_220	13:41	18:14	4:33	LINE CLEAR AVAILED
936	5-Dec-21	BAGALKOT	220	AMEWADI-NARENDRA2	AMBEWADI_220	10:29	19:20	8:51	LINE CLEAR AVAILED
937	5-Dec-21	BAGALKOT	220	ATHANI220-KUDACHI	ATHANI_220	10:01	14:03	4:02	LINE CLEAR AVAILED
938	5-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
939	5-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
940	5-Dec-21	BAGALKOT	220	BELGAUM- KANABRG1	BELGAUM_220	17:04	17:52	0:48	LINE FAULT
941	5-Dec-21	BAGALKOT	220	BELGAUM- KANABRG2	BELGAUM_220	17:04	17:52	0:48	LINE FAULT
942	5-Dec-21	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
943	5-Dec-21	BAGALKOT	220	HAVERI- NARENDRA	HAVERI_220	10:19 (30.11.2021)			LINE OPEN:LINE CLEAR AVAILED
944	5-Dec-21	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	12:48	19:58	7:10	LINE FAULT
945	5-Dec-21	BAGALKOT	220	KUDACHI- ATHANI	KUDACHI_220	10:01	14:03	4:02	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
946	5-Dec-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
947	5-Dec-21	BAGALKOT	220	NARENDRA- KANABARGI1	NARENDRA_220	10:03	17:52	7:49	LINE CLEAR AVAILED
948	5-Dec-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
949	5-Dec-21	BAGALKOT	220	NARENDRA-HAVERI	NARENDRA_220	10:19 (30.11.2021)			LINE OPEN:LINE CLEAR AVAILED
950	5-Dec-21	BAGALKOT	220	NARENDRA-HUBLI1	NARENDRA_220	12:48	13:08	0:20	LINE FAULT
951	5-Dec-21	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	12:48	19:58	7:10	LINE FAULT
952	5-Dec-21	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
953	5-Dec-21	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
954	5-Dec-21	BENGALURU	66	ANEKAL - YARANDANAHALLI 2	NO STATION AFFECTED	12:58	13:27	0:29	LINE CLEAR AVAILED
955	5-Dec-21	BENGALURU	66	BANGARPETE - MALUR 220	BANGARPETE	11:00	11:05	0:05	LOAD CHANGE OVER
956	5-Dec-21	BENGALURU	66	DODDABELAVANGALA - DB PURA 220	DODDABELAVANGALA	0:55	1:05	0:10	LINE FAULT
957	5-Dec-21	BENGALURU	66	HV1	ANEKAL	11:03	14:03	3:00	LINE CLEAR AVAILED
958	5-Dec-21	BENGALURU	66	HV1	ANJANAPURA	20:42	20:45	0:03	LINE CLEAR AVAILED
959	5-Dec-21	BENGALURU	66	HV1	DODDABELAVANGALA	0:55	1:10	0:15	TRANSFORMER FAULT
960	5-Dec-21	BENGALURU	66	HV1	ITI 220	10:00	10:10	0:10	LINE CLEAR AVAILED
961	5-Dec-21	BENGALURU	66	HV1	KANAKAPURA 66	11:15	14:24	3:09	LINE CLEAR AVAILED
962	5-Dec-21	BENGALURU	66	HV2	ANEKAL	11:03	14:03	3:00	LINE CLEAR AVAILED
963	5-Dec-21	BENGALURU	66	HV2	BYADRAHALLI	11:25	11:30	0:05	LINE CLEAR AVAILED
964	5-Dec-21	BENGALURU	66	HV2	ITI 220	13:45	13:49	0:04	LINE CLEAR AVAILED
965	5-Dec-21	BENGALURU	66	HV2	KODIGEHALI	9:36	10:45	1:09	LINE CLEAR AVAILED
966	5-Dec-21	BENGALURU	66	HV2	VIJAYANAGARA	12:11	12:50	0:39	TRANSFORMER FAULT
967	5-Dec-21	BENGALURU	66	JAYADEVA - SARAKKI	JAYADEVA	6:05	6:08	0:03	LOAD CHANGE OVER
968	5-Dec-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPETE	6:23	7:30	1:06	MAIN SUPPLY FAILURE
969	5-Dec-21	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	6:23	10:16	3:52	MAIN SUPPLY FAILURE
970	5-Dec-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	6:23	8:42	2:18	MAIN SUPPLY FAILURE
971	5-Dec-21	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
972	5-Dec-21	BENGALURU	66	LV2	KOLAR 220	6:23	8:30	2:07	TRANSFORMER FAULT
973	5-Dec-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	6:27	6:37	0:09	LINE FAULT
974	5-Dec-21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	6:33	6:57	0:24	LINE FAULT
975	5-Dec-21	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	5:48	5:52	0:04	LOAD CHANGE OVER
976	5-Dec-21	BENGALURU	66	VICTORIA - A STATION 220	VICTORIA	10:10	17:04	6:54	LINE CLEAR AVAILED
977	5-Dec-21	BENGALURU	66	WELCASTE STEEL - ABBIGERE	WELCASTE STEEL	22:30	22:36	0:06	LOAD CHANGE OVER
978	5-Dec-21	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	NO STATION AFFECTED	23:54(5-12-2021)			MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
979	5-Dec-21	BENGALURU	220	HV2	KOLAR_220	6:23	8:23	1:59	TRANSFORMER FAULT
980	5-Dec-21	BENGALURU	400	NELAMANGALA 400 - HASAN 400	NO STATION AFFECTED	17:48:06(3-12-2021)			LINE OPEN:LINE FAULT
981	5-Dec-21	GULBARGA	66	HV1	HARVI_66	16:30	17:30	1:00	LINE CLEAR AVAILED
982	5-Dec-21	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
983	5-Dec-21	GULBARGA	66	ITTAGI-TAMBARHALLI	TAMBRAHALLI_66,MOREG ERE_66, HAMPASAGAR_66	1:42	2:00	0:18	LINE FAULT
984	5-Dec-21	GULBARGA	66	KOGALI-ATRIA SOLAR_IPP	KOGALI_66	19:00(04.12.2021)	7:50(05.12.2021)	12:50HRS	LINE CHARGED
985	5-Dec-21	GULBARGA	66	PUNABGHATTA-UCHCHANGIDURGA	UCHCHANGIDURGA_66	11:15	11:25	0:10	LINE FAULT
986	5-Dec-21	GULBARGA	110	ADAVIAMERESHWAR-MALLAT	ADAVIAMERESHWAR_110	22:18	22:22	0:04	MAIN SUPPLY FAILURE
987	5-Dec-21	GULBARGA	110	ALIPUR-BALLARY NORTH	SOMASAMUDRA_110,BALLARY NORTH_110,MOKA_110,P D HALLI_110,BISIHALLI_110,J ANAKI_IPP,BASAI STEELS	4:36	4:44	0:08	LINE FAULT
988	5-Dec-21	GULBARGA	110	ALIPUR-BALLARY NORTH	SOMASAMUDRA_110,BALLARY NORTH_110,MOKA_110,P D HALLI_110,BISIHALLI_110,J ANAKI_IPP,BASAI STEELS	8:22	8:27	0:05	LOAD CHANGE OVER
989	5-Dec-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	23:40	23:45	0:05	LINE FAULT
990	5-Dec-21	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	4:45	4:50	0:05	LINE FAULT
991	5-Dec-21	GULBARGA	110	KUSTAGI-ILKAL 1 & 2	ILKAL_110	10:45	17:03	6:18	NFBC ISSUED
992	5-Dec-21	GULBARGA	110	KUSTAGI-TAWARGERERE	TAWARGERERE_110	7:58	8:12	0:14	LINE FAULT
993	5-Dec-21	GULBARGA	110	NANDUR-SHAHABAD2	NANDUR_110	11:50	15:20	3:30	NFBC ISSUED
994	5-Dec-21	GULBARGA	110	RAICHUR-APMC1 & 2	APMC_110,CHIKSUGUR_110,SHAKTINAGAR_110	5:20	5:31	0:11	LINE FAULT
995	5-Dec-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	22:10	22:12	0:02	LINE FAULT
996	5-Dec-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	13:25	13:30	0:05	LINE FAULT
997	5-Dec-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YEDRAMI_110,MORTAGI_110	1:05	1:15	0:10	LINE FAULT
998	5-Dec-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
999	5-Dec-21	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	1:30	6:47	5:17	LINE CHARGED
1000	5-Dec-21	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	22:06 (5.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1001	5-Dec-21	GULBARGA	220	HV1	ITTAGI_220	1:42	1:51	0:09	TRANSFORMER FAULT
1002	5-Dec-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1003	5-Dec-21	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	8:37	15:15	6:38	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1004	5-Dec-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:58 (4.12.2021)	7:02 (5.12.2021)	9:04 HRS	LINE CHARGED
1005	5-Dec-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:05 (5.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1006	5-Dec-21	GULBARGA	400	BTPSG-GUTTUR	GUTTUR_400	6:31(05.12.2021)			LINE OPEN:LINE FAULT
1007	5-Dec-21	HASSAN	66	HV1	SOMANAHALLI_66	14:59	17:07	2:08	LINE CLEAR AVAIED
1008	5-Dec-21	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	5:05	5:21	0:16	LINE FAULT
1009	5-Dec-21	HASSAN	110	HV1	BAIKAMPADI_110	11:18	14:40	3:22	LINE CLEAR AVAIED
1010	5-Dec-21	HASSAN	110	HV1	KONDENALU_110	10:37	19:10	8:33	LINE CLEAR AVAIED
1011	5-Dec-21	HASSAN	110	HV2	HALADY_110	10:05	10:34	0:29	TRANSFORMER FAULT
1012	5-Dec-21	HASSAN	110	HV2	HALADY_110	10:44	1048	13:16	LINE CLEAR AVAIED
1013	5-Dec-21	HASSAN	110	HV2	KONDENALU_110	12:30	13:45	1:15	LINE CLEAR AVAIED
1014	5-Dec-21	HASSAN	110	JOG-NK1	mghejog_gen	11:50	12:15	0:25	LINE FAULT
1015	5-Dec-21	HASSAN	110	JOG-NK2	mghejog_gen	11:50	12:15	0:25	LINE FAULT
1016	5-Dec-21	HASSAN	110	LV1	ARASIKERE_220	5:05	5:18	0:13	TRANSFORMER FAULT
1017	5-Dec-21	HASSAN	220	MRSSSHM-ANTRSNH	MRSMG_220	9:39	17:55	8:16	LINE CLEAR AVAIED
1018	5-Dec-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:21(3.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1019	5-Dec-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:10(05.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1020	5-Dec-21	MYSORE	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01(30.10.2021)			LINE OPEN:LINE CLEAR AVAIED
1021	5-Dec-21	MYSORE	66	KADKOLA-KOZHIKODE	NO STATIONS EFFECTED	8:27:00 (4.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1022	5-Dec-21	MYSORE	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN:LINE CLEAR AVAIED
1023	5-Dec-21	MYSORE	220	HV1	HOOTGALLY_220	9:35	12:00	2:25	LINE CLEAR AVAIED
1024	5-Dec-21	MYSORE	220	HV2	HOOTGALLY_220	12:02	13:43	1:41	LINE CLEAR AVAIED
1025	5-Dec-21	TUMKUR	66	ANTHRASANAHALLI 220KV-BELLAVI	BELLAVI_66	9:34	18:23	8:49	LINE CLEAR AVAIED
1026	5-Dec-21	TUMKUR	66	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	9:34	18:24	8:50	LINE CLEAR AVAIED
1027	5-Dec-21	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	9:34	18:26	8:52	LINE CLEAR AVAIED
1028	5-Dec-21	TUMKUR	66	ANTHRASANAHALLI 220KV-KORA	KORA_66, THOVINAKERE_66	9:34	18:11	8:37	LINE CLEAR AVAIED
1029	5-Dec-21	TUMKUR	66	ANTHRASANAHALLI 220KV-MELEKOTE	MELKOTE_66, BADDIHALLI_66	9:34	18:20	8:46	LINE CLEAR AVAIED
1030	5-Dec-21	TUMKUR	66	ANTHRASANAHALLI 220KV-TUMKUR	TUMKUR_66	9:34	18:08	8:34	LINE CLEAR AVAIED
1031	5-Dec-21	TUMKUR	66	CHITRADURGA 220kv-SUZLON 2	SUZLON2_IPP_66	12:15	12:45	0:30	LINE FAULT
1032	5-Dec-21	TUMKUR	66	DAVANGERE SRS-AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKATE_66,KADAJI_66	16:26	16:35	0:09	HAND TRIPPED
1033	5-Dec-21	TUMKUR	66	DAVANGERE SRS-DAVANGERE	DAVANAGERE_66	16:27	16:36	0:09	HAND TRIPPED
1034	5-Dec-21	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	16:29	16:33	0:04	HAND TRIPPED
1035	5-Dec-21	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	12:52	13:11	0:19	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1036	5-Dec-21	TUMKUR	66	DAVANGERE SRS- HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	16:28	16:34	0:06	HAND TRIPPED
1037	5-Dec-21	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	16:30	16:31	0:01	HAND TRIPPED
1038	5-Dec-21	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	13:01	13:10	0:09	LINE FAULT
1039	5-Dec-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	3:19	3:24	0:05	LINE FAULT
1040	5-Dec-21	TUMKUR	66	MADHUGIRI 220kv- PULLAMAGATTA	PULLAMAGATTA_66	5:37	15:50	10:13	LINE FAULT
1041	5-Dec-21	TUMKUR	66	PAVAGADA 220kv- SHYLAPURA	SHYLAPURA_66	6:20	6:40	0:20	LINE FAULT
1042	5-Dec-21	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	9:34	18:01	8:27	LINE CLEAR AVAILED
1043	5-Dec-21	TUMKUR	66	TR-1	PAVAGADA_220	6:18	6:38	0:20	TRANSFORMER FAULT
1044	5-Dec-21	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	9:34	18:05	8:31	LINE CLEAR AVAILED
1045	5-Dec-21	TUMKUR	66	TR-2	DAVANGERE_SRS_220	16:25	16:37	0:12	HAND TRIPPED
1046	5-Dec-21	TUMKUR	66	TR-2	PAVAGADA_220	6:19	6:39	0:20	TRANSFORMER FAULT
1047	5-Dec-21	TUMKUR	66	TR-3	ANTHRASANAHALLI_220	9:34	18:05	8:31	LINE CLEAR AVAILED
1048	5-Dec-21	TUMKUR	220	ANTHRASANAHALLI 220kv- SHIMOGA	ANTHRASANAHALLI_220	9:38	17:52	8:14	LINE CLEAR AVAILED
1049	5-Dec-21	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 1	ANTHRASANAHALLI_220	10:48	19:39	8:51	LINE CLEAR AVAILED
1050	5-Dec-21	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	10:48	19:39	8:51	LINE CLEAR AVAILED
1051	5-Dec-21	TUMKUR	220	HONNALLI 220kv- SUZLON2	SUZLON_IPP_66	5:49	8:12	2:23	LINE FAULT
1052	5-Dec-21	TUMKUR	220	TR-1	ANTHRASANAHALLI_220	9:34	18:04	8:30	LINE CLEAR AVAILED
1053	5-Dec-21	TUMKUR	220	TR-1	DAVANGERE_SRS_220	16:10	16:30	0:20	TRANSFORMER FAULT
1054	5-Dec-21	TUMKUR	220	TR-2	ANTHRASANAHALLI_220	9:34	18:04	8:30	LINE CLEAR AVAILED
1055	5-Dec-21	TUMKUR	220	TR-3	ANTHRASANAHALLI_220	9:34	17:56	8:22	LINE CLEAR AVAILED
1056	6-Dec-21	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	4:30 (10.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1057	6-Dec-21	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	15:00	17:05	2:05	LINE CLEAR AVAILED
1058	6-Dec-21	BAGALKOT	110	110/11KV, HV1	MUNDAGANUR_110	7:58	9:24	1:26	LINE CLEAR AVAILED
1059	6-Dec-21	BAGALKOT	110	110/11KV, HV1	MUNDAGANUR_110	10:59	11:53	0:54	LINE CLEAR AVAILED
1060	6-Dec-21	BAGALKOT	110	110/11KV, HV1	MUNDAGANUR_110	16:50	17:50	1:00	LINE CLEAR AVAILED
1061	6-Dec-21	BAGALKOT	110	110/11KV, HV2	SINDAGI_110	11:24	14:38	3:14	LINE CLEAR AVAILED
1062	6-Dec-21	BAGALKOT	110	110/11KV,HV 1	ALABAL_110	14:13	16:45	2:32	TRANSFORMER FAULT
1063	6-Dec-21	BAGALKOT	110	110/11KV,HV 1	MACHE_110	13:42	14:11	0:29	TRANSFORMER FAULT
1064	6-Dec-21	BAGALKOT	110	110/11KV,HV1	ANAND NAGAR_110	14:31	14:48	0:17	LINE CLEAR AVAILED
1065	6-Dec-21	BAGALKOT	110	110/11KV,HV1	DADDI_110	11:51	12:38	0:47	LINE CLEAR AVAILED
1066	6-Dec-21	BAGALKOT	110	110/11KV,HV2	ANAND NAGAR_110	11:50	14:30	2:40	LINE CLEAR AVAILED
1067	6-Dec-21	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	0:27 (04.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1068	6-Dec-21	BAGALKOT	110	220/110KV, LV1	BAGALKOT_220	10:42	15:16	4:34	LINE CLEAR AVAILED
1069	6-Dec-21	BAGALKOT	110	AMBEWADI- SUPA1	AMBEWADI_220	11:31	13:38	2:07	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1070	6-Dec-21	BAGALKOT	110	B.BAGEWADI 2-MAMADAPUR(B)	MAMADAPUR(B)_110	17:21	17:30	0:09	LINE CLEAR AVAILED
1071	6-Dec-21	BAGALKOT	110	BABALESHWAR-MAMADAPUR	MAMADAPUR(B)_110	7:10	7:16	0:06	LINE FAULT
1072	6-Dec-21	BAGALKOT	110	BAGALKOT220-KALADAGI	BAGALKOT_220	10:43	10:57	0:14	HAND TRIPPED
1073	6-Dec-21	BAGALKOT	110	BAGALKOT220-KALADAGI	BAGALKOT_220	15:05	15:18	0:13	HAND TRIPPED
1074	6-Dec-21	BAGALKOT	110	BAGALKOT220-NEERABUDIHAL	BAGALKOT_220	10:43	10:57	0:14	HAND TRIPPED
1075	6-Dec-21	BAGALKOT	110	BAGALKOT220-NEERABUDIHAL	BAGALKOT_220	15:05	15:18	0:13	HAND TRIPPED
1076	6-Dec-21	BAGALKOT	110	BAGEWADI-MAMDAPUR 1	MAMADAPUR(B)_110	6:56	7:04	0:08	LINE FAULT
1077	6-Dec-21	BAGALKOT	110	BAGEWADI-MAMDAPUR2	MAMADAPUR(B)_110	6:56	7:04	0:08	LINE FAULT
1078	6-Dec-21	BAGALKOT	110	BIDNAL220-ANNIGERI	ANNIGERI_110	06:12	12:51	6:39	LINE FAULT
1079	6-Dec-21	BAGALKOT	110	GADAG-LAKSHMESHWAR	LAKSHMESHWAR_110	9:29 (03.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1080	6-Dec-21	BAGALKOT	110	GAJENDRAGAD-RON2	RON_110	16:49	18:27	1:38	LINE CLEAR AVAILED
1081	6-Dec-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
1082	6-Dec-21	BAGALKOT	110	HUBLI- KADANKOPPA	HUBLI_220	15:17	18:36	3:19	LINE CLEAR AVAILED
1083	6-Dec-21	BAGALKOT	110	HUBLI-KADANKOPPA	KADANKOPPA_110	15:22	18:36	3:14	NFBC ISSUED
1084	6-Dec-21	BAGALKOT	110	HUNGUND -JINDAL	HUNGUND_110	19:58	20:33	0:35	LINE FAULT
1085	6-Dec-21	BAGALKOT	110	INDI220- DEVARHIPPARAGI	DEVARHIPPARAGI_110, ATHARGA_110, HIEMASALI_110	3:45	3:58	0:13	LINE FAULT
1086	6-Dec-21	BAGALKOT	110	MAMADAPUR(G)-SOUBHAGYA LAKSHMI(GOKAK)	MAMADAPUR(G)_110	12:46	13:45	0:59	LINE CLEAR AVAILED
1087	6-Dec-21	BAGALKOT	110	RANEENNUR220-AREMALLAPUR(HONNATTI)	RANEENNUR_220	6:08	6:13	0:05	LINE FAULT
1088	6-Dec-21	BAGALKOT	110	TAKKALAKI- TIKOTA	TAKKALKI_110	20:23	20:31	0:08	LINE FAULT
1089	6-Dec-21	BAGALKOT	110	TAKKALAKI- TIKOTA	TAKKALKI_110	22:05	22:12	0:07	LINE FAULT
1090	6-Dec-21	BAGALKOT	110	VAJRAMATTI220- MANTUR2	VAJRAMATTI_220	9:40	13:45	4:05	LINE CLEAR AVAILED
1091	6-Dec-21	BAGALKOT	110	VAJRAMATTI220- MELLIGERI	VAJRAMATTI_220	12:55	14:30	1:35	LINE CLEAR AVAILED
1092	6-Dec-21	BAGALKOT	110	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI_220	11:30	13:40	2:10	LINE CLEAR AVAILED
1093	6-Dec-21	BAGALKOT	220	220/110KV, HV1	BAGALKOT_220	10:42	15:15	4:33	LINE CLEAR AVAILED
1094	6-Dec-21	BAGALKOT	220	220/110KV, HV2&LV2	SOUDATTI_220	8:22	18:27	10:05	LINE CLEAR AVAILED
1095	6-Dec-21	BAGALKOT	220	AMBEWADI- NARENDRA2	AMBEWADI_220	10:45 (06.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1096	6-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
1097	6-Dec-21	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN:LINE CLEAR AVAILED
1098	6-Dec-21	BAGALKOT	220	BIJAPUR-BAGEWADI1(NANDIHAL1)	BIJAPUR_220	14:38	15:18	0:40	LINE FAULT
1099	6-Dec-21	BAGALKOT	220	BIJAPUR- INDI2	BIJAPUR_220	14:38	16:29	1:51	LINE FAULT
1100	6-Dec-21	BAGALKOT	220	BIJAPUR- VAISHALI1	BIJAPUR_220	14:38	15:19	0:41	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1101	6-Dec-21	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
1102	6-Dec-21	BAGALKOT	220	CHIKKODI- KUDACHI1	CHIKKODI_220	10:44	13:40	2:56	LINE CLEAR AVAILED
1103	6-Dec-21	BAGALKOT	220	HAVERI- NARENDRA	HAVERI_220	10:19 (30.11.2021)	18:56 (06.12.2021)	152:37 hrs	LINE CHARGED
1104	6-Dec-21	BAGALKOT	220	HAVERI-BIDNAL	HAVERI_220	10:12 (30.11.2021)	18:55 (06.12.2021)	152:43 hrs	LINE CHARGED
1105	6-Dec-21	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	14:30	19:20	4:50	LINE FAULT
1106	6-Dec-21	BAGALKOT	220	KUDUCHI-CHIKKODI1	KUDUCHI_220	2:41	5:57	3:16	LINE CLEAR AVAILED
1107	6-Dec-21	BAGALKOT	220	KUDUCHI-CHIKKODI1	KUDUCHI_220	10:43	13:39	2:56	LINE CLEAR AVAILED
1108	6-Dec-21	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1109	6-Dec-21	BAGALKOT	220	NAGJHARI2- HUBLI	HUBLI_220	12:54	17:35	4:41	LINE FAULT
1110	6-Dec-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
1111	6-Dec-21	BAGALKOT	220	NARENDRA-HAVERI	NARENDRA_220	10:19 (30.11.2021)	18:57 (06.12.2021)	152:38 hrs	LINE CHARGED
1112	6-Dec-21	BAGALKOT	220	SHARAVATHI1- SIRSI	SIRSI_220	10:20	16:49	6:29	LINE CLEAR AVAILED
1113	6-Dec-21	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	16:20 (17.11.2021)			LINE OPEN:LINE CLEAR AVAILED
1114	6-Dec-21	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	16:20 (24.11.2021)			LINE OPEN:LINE CLEAR AVAILED
1115	6-Dec-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
1116	6-Dec-21	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1117	6-Dec-21	BENGALURU	66	ALUR - SOLDEVANAHALLI	ALUR	15:18	15:30	0:12	LOAD CHANGEVER
1118	6-Dec-21	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	15:18	15:30	0:12	LOAD CHANGEVER
1119	6-Dec-21	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	7:17	8:03	0:45	LINE FAULT
1120	6-Dec-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	7:17	7:35	0:17	LINE FAULT
1121	6-Dec-21	BENGALURU	66	CHITAMANI 66 - CHINTAMANI 220	CHINTAMANI 66	7:17	9:55	2:38	LINE FAULT
1122	6-Dec-21	BENGALURU	66	CHITAMANI 66 - SM MANGALA	CHINTAMANI 66	11:54	12:55	1:00	LOAD CHANGEVER
1123	6-Dec-21	BENGALURU	66	DIVYASHREE TEC PARK - KACHMARANAHALLI	KACHMARANAHALLI	9:05	18:00	8:55	LINE CLEAR AVAILED
1124	6-Dec-21	BENGALURU	66	EPIP 220 - HTT(EHT)	HTT(EHT)	17:04	17:10	0:06	LINE CLEAR AVAILED
1125	6-Dec-21	BENGALURU	66	HV1	BRIGADE MEADOWS	10:21	10:25	0:04	LINE CLEAR AVAILED
1126	6-Dec-21	BENGALURU	66	HV1	NAGANATHPURA 220	15:16	15:26	0:10	LINE CLEAR AVAILED
1127	6-Dec-21	BENGALURU	66	HV1	TUBUGERE	11:00	11:51	0:51	LINE CLEAR AVAILED
1128	6-Dec-21	BENGALURU	66	HV1	HOSKOTE 66	15:40	16:00	0:19	LINE CLEAR AVAILED
1129	6-Dec-21	BENGALURU	66	HV1	KGF	13:40	14:10	0:30	LINE CLEAR AVAILED
1130	6-Dec-21	BENGALURU	66	HV2	BRIGADE MEADOWS	13:46	14:03	0:17	LINE CLEAR AVAILED
1131	6-Dec-21	BENGALURU	66	HV2	ELECTRONIC CITY P2 S2	12:55	12:58	0:03	TRANSFORMER FAULT
1132	6-Dec-21	BENGALURU	66	HV2	NAGANATHPURA 220	15:16	15:27	0:11	LINE CLEAR AVAILED
1133	6-Dec-21	BENGALURU	66	HV2	NRS 220	7:39	7:44	0:05	LOAD CHANGEVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1134	6-Dec-21	BENGALURU	66	HV2	SUBRAMANYAPURA 66	12:37	12:46	0:09	TRANSFORMER FAULT
1135	6-Dec-21	BENGALURU	66	HV2	KGF	14:55	15:00	0:05	LINE CLEAR AVAIED
1136	6-Dec-21	BENGALURU	66	HV3	NAGANATHPURA 220	15:16	15:26	0:10	LINE CLEAR AVAIED
1137	6-Dec-21	BENGALURU	66	HV3	YARANDANAHALLI 220	3:02	3:24	0:22	TRANSFORMER FAULT
1138	6-Dec-21	BENGALURU	66	HV3	KGF	17:10	19:10	2:00	LINE CLEAR AVAIED
1139	6-Dec-21	BENGALURU	66	KGF - LINE 1	KGF, BEML(EHT)	11:45	12:30	0:45	LINE CLEAR AVAIED
1140	6-Dec-21	BENGALURU	66	KGF - LINE 1	NO STATION AFFECTED	15:35	16:10	0:35	LINE CLEAR AVAIED
1141	6-Dec-21	BENGALURU	66	KGF - LINE 2	NO STATION AFFECTED	12:30	13:45	1:15	LINE CLEAR AVAIED
1142	6-Dec-21	BENGALURU	66	KGF - LINE 2	NO STATION AFFECTED	16:10	17:15	1:05	LINE CLEAR AVAIED
1143	6-Dec-21	BENGALURU	66	KIADB DB PURA 220 - APPEAREL PARK	APPAREL PARK	16:21	16:26	0:04	LINE CLEAR AVAIED
1144	6-Dec-21	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	13:58	14:03	0:05	LINE CLEAR AVAIED
1145	6-Dec-21	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
1146	6-Dec-21	BENGALURU	66	LV2	CHINTAMANI 220	7:17	7:34	0:16	TRANSFORMER FAULT
1147	6-Dec-21	BENGALURU	66	MITTEMARI 220 - BAGEPALI 2	BAGEPALI, GUNDLU KOTTUR	18:05	18:10	0:05	LINE FAULT
1148	6-Dec-21	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1, ELECTRONIC CITY, INFOSYS(EHT)	15:16	15:33	0:17	LINE CLEAR AVAIED
1149	6-Dec-21	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT)	15:16	15:29	0:13	LINE CLEAR AVAIED
1150	6-Dec-21	BENGALURU	66	SHOBHA FOREST - BRIGADE MEADOWS	SHOBHA FOREST	10:02	14:30	4:28	LINE CLEAR AVAIED
1151	6-Dec-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	15:09	15:19	0:10	LINE FAULT
1152	6-Dec-21	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	NO STATION AFFECTED	23:54(5-12-2021)	6:56(6-12-2021)	7:01	MAIN SUPPLY FAILURE
1153	6-Dec-21	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 1	NO STATION AFFECTED	7:42	20:54	13:12	LINE CLEAR AVAIED
1154	6-Dec-21	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	7:42	20:54	13:12	LINE CLEAR AVAIED
1155	6-Dec-21	BENGALURU	220	HV1	BEGUR 220	10:37	18:47	8:10	LINE CLEAR AVAIED
1156	6-Dec-21	BENGALURU	220	NAGANATHPURA 220 - HSR LAYOUT 220	NO STATION AFFECTED	15:16	16:25	1:09	LINE FAULT
1157	6-Dec-21	BENGALURU	220	NAGANATHPURA 220 - SOMANAHALLI 220	NAGANATHPURA 220	15:16	15:25	0:09	LINE FAULT
1158	6-Dec-21	BENGALURU	400	NELAMANGALA 400 - HASAN 400	NO STATION AFFECTED	17:48:06(3-12-2021)	20:03:20(6-12-2021)	74:14 hrs	LINE CHARGED
1159	6-Dec-21	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1160	6-Dec-21	GULBARGA	66	NEELGUNDA-PUNABGHATA	PUNABGHATA_66,UCHANG IDURGA_66	6:22	6:33	0:11	LINE FAULT
1161	6-Dec-21	GULBARGA	66	PUNABGHATA- UCHCHANGIDURGA	UCHCHANGIDURGA_66	2:00	2:35	0:35	LINE FAULT
1162	6-Dec-21	GULBARGA	66	UCHCHANGIDURGA-BILCHOD	BILCHOD_66	2:55	7:00	4:05	LINE FAULT
1163	6-Dec-21	GULBARGA	110	BENNUR-YARODONA	BENNUR_110	21:50	21:55	0:05	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1164	6-Dec-21	GULBARGA	110	GABBUR-BPSOLAR_IPP	GABBUR_110	17:25(6.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1165	6-Dec-21	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE_110	13:20	13:25	0:05	MAIN SUPPLY FAILURE
1166	6-Dec-21	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,M GSSK_IPP,BHALKI SUGAR_IPP	5:24	5:28	0:04	LINE FAULT
1167	6-Dec-21	GULBARGA	110	HV1	BENNUR_110	11:05	11:20	0:15	TRANSFORMER FAULT
1168	6-Dec-21	GULBARGA	110	HV2	BISLAHALLI_110	13:15	13:20	0:05	TRANSFORMER FAULT
1169	6-Dec-21	GULBARGA	110	KUSTAGI-VAJRABANDI	YELBURGA_110,KUKNOOR 110,VAJRABANDI_110	3:23	3:48	0:25	LINE FAULT
1170	6-Dec-21	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	5:10	5:17	0:07	LINE FAULT
1171	6-Dec-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
1172	6-Dec-21	GULBARGA	110	YELBURGA-VAJARABANDI	YELBURGA_110	3:22	3:42	0:20	MAIN SUPPLY FAILURE
1173	6-Dec-21	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	22:06 (5.12.2021)	6:35 (6.12.2021)	8:29 HRS	LINE CHARGED
1174	6-Dec-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1175	6-Dec-21	GULBARGA	220	HV2	KUSTAGI_220	3:32	3:38	0:06	TRANSFORMER FAULT
1176	6-Dec-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:05 (5.12.2021)	7:25 (6.12.2021)	9:20 HRS	LINE CHARGED
1177	6-Dec-21	GULBARGA	400	BTPSG-GUTTUR	GUTTUR_400	6:31(05.12.2021)	8:02(06.12.2021)	25:31HRS	LINE CHARGED
1178	6-Dec-21	HASSAN	66	CHANNARA-MALLALI	CHANNARAYAPATNA_66	10:50	11:40	0:50	LINE CLEAR AVAILED
1179	6-Dec-21	HASSAN	66	HV1	CRPATNA_220	13:26	14:32	1:06	LINE CLEAR AVAILED
1180	6-Dec-21	HASSAN	66	HV1	HETTUR_66	10:05	11:44	1:39	MAIN SUPPLY FAILURE
1181	6-Dec-21	HASSAN	66	HV1	YESLUR_66	10:06	17:34	7:28	LINE CLEAR AVAILED
1182	6-Dec-21	HASSAN	66	YESLUR-SNVRST	YESLUR_66	10:02	17:33	7:31	LINE CLEAR AVAILED
1183	6-Dec-21	HASSAN	110	AJAMPU-SHIVNI	AJAMPURA_110	2:26	2:39	0:13	LINE FAULT
1184	6-Dec-21	HASSAN	110	HALADY11-HOSANGADI	HALADY_110	11:12	14:59	3:47	LINE CLEAR AVAILED
1185	6-Dec-21	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	11:09	15:07	3:58	LINE CLEAR AVAILED
1186	6-Dec-21	HASSAN	110	HV1	ARASIKERE_220	12:43	15:38	2:55	LINE CLEAR AVAILED
1187	6-Dec-21	HASSAN	110	HV1	GURUVAYANAKERE_110	10:00	14:10	4:10	LINE CLEAR AVAILED
1188	6-Dec-21	HASSAN	110	HV1	JAVAGAL_110	14:14	14:35	0:21	LINE CLEAR AVAILED
1189	6-Dec-21	HASSAN	110	HV1	KALLUSADARAHALLI_110	10:37	17:59	7:22	LINE CLEAR AVAILED
1190	6-Dec-21	HASSAN	110	HV1	KONDENALU_110	15:37	16:01	0:24	LINE CLEAR AVAILED
1191	6-Dec-21	HASSAN	110	HV4	KULASHEKARA_110	1:30	4:30	3:00	TRANSFORMER FAULT
1192	6-Dec-21	HASSAN	110	JOG110-LPH	JOG_110	16:09	17:04	0:55	LINE CLEAR AVAILED
1193	6-Dec-21	HASSAN	110	JOG-JLT4	mghejog_gen	15:15	17:25	2:10	LINE CLEAR AVAILED
1194	6-Dec-21	HASSAN	110	LV1	ARASIKERE_220	12:43	15:38	2:55	LINE CLEAR AVAILED
1195	6-Dec-21	HASSAN	110	SAGARA-LST4	SAGARA_110	13:53	15:08	1:15	LINE CLEAR AVAILED
1196	6-Dec-21	HASSAN	110	TALAGU-L1-LST 3 LPH	TALAGUPPA_400	15:16	16:11	0:55	LINE CLEAR AVAILED
1197	6-Dec-21	HASSAN	220	HGUNJE-VRH1	HEGGUNJE_220	12:50	14:58	2:08	LINE CLEAR AVAILED
1198	6-Dec-21	HASSAN	220	MRSSH-M-SHARAVATHY3	MRSMSG_220	14:24	15:47	1:23	LINE CLEAR AVAILED
1199	6-Dec-21	HASSAN	220	SHRAVITY-SHIMOAGA3	sharavathy_gen	12:50	14:58	2:08	LINE CLEAR AVAILED
1200	6-Dec-21	HASSAN	220	VARAHI-KEMAR3	varahi_gen	12:50	14:58	2:08	NFBC ISSUED
1201	6-Dec-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:21(3.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1202	6-Dec-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:10(05.12.2021)	7:09(06.12.2021)	8:59hrs	LINE CHARGED
1203	6-Dec-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:42(06.12.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1204	6-Dec-21	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	15:43	15:52	0:09	LINE FAULT
1205	6-Dec-21	MYSORE	66	DEVNUR(N'GUD)-HEMMERGALA	DEVANOORNGUDU_66 SUTTUR_66	7:01	17:30	10:28	LINE CLEAR AVAILED
1206	6-Dec-21	MYSORE	66	DEVNUR(N'GUD)-SUTTUR	DEVANOORNGUDU_66 SUTTUR_66	7:00	17:30	10:29	LINE CLEAR AVAILED
1207	6-Dec-21	MYSORE	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1208	6-Dec-21	MYSORE	66	HV1	HEBBAL_66	8:56	9:17	0:21	TRANSFORMER FAULT
1209	6-Dec-21	MYSORE	66	HV1	PONNAMPETE_66	11:28	12:27	0:58	LINE CLEAR AVAILED
1210	6-Dec-21	MYSORE	66	HV2	BILIKERE_66	12:06	16:24	4:17	LINE CLEAR AVAILED
1211	6-Dec-21	MYSORE	66	HV2	KIRUGAVALU_66	11:34	14:24	2:49	LINE CLEAR AVAILED
1212	6-Dec-21	MYSORE	66	HV2	PONNAMPETE_66	11:28	12:28	1:00	LINE CLEAR AVAILED
1213	6-Dec-21	MYSORE	66	HV2	BEGUR_66	11:40	13:08	1:28	LINE CLEAR AVAILED
1214	6-Dec-21	MYSORE	66	KADKOLA-KOZHICODE	NO STATIONS EFFECTED	8:27:00 (4.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1215	6-Dec-21	MYSORE	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1216	6-Dec-21	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	12:57	13:02	0:05	LINE FAULT
1217	6-Dec-21	MYSORE	66	MALLAVALLI-TK HALLI	MALAVALLI_66	13:14	14:43	1:29	NFBC ISSUED
1218	6-Dec-21	MYSORE	66	SHANIVARSANTHE-YESSLUR	YESSLUR_66 HETHUR_66	10:01	11:41	1:39	LINE CLEAR AVAILED
1219	6-Dec-21	MYSORE	66	TALAKADU-ADANI	NO STATIONS EFFECTED	18:13	20:29	2:15	LINE CLEAR AVAILED
1220	6-Dec-21	MYSORE	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	4:22	4:33	0:10	LINE FAULT
1221	6-Dec-21	TUMKUR	66	BHARAMAGIRI-HIRIYUR220	BHARAMAGIRI_66	12:01	13:54	1:52	LINE CLEAR AVAILED
1222	6-Dec-21	TUMKUR	66	BILCHODU-PALLAGATTE	PALLAGATTE_66	7:18	7:57	0:38	HAND TRIPPED
1223	6-Dec-21	TUMKUR	66	BILCHODU-UCHANGIDURGA	BILCHODU_66	3:20	7:22	4:01	LINE CLEAR AVAILED
1224	6-Dec-21	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	4:13	4:35	0:22	LINE FAULT
1225	6-Dec-21	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 1	CHITRADURGA_220	4:13	4:41	0:27	LINE FAULT
1226	6-Dec-21	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 4	CHITRADURGA_220	4:13	4:36	0:22	LINE FAULT
1227	6-Dec-21	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_220	4:13	4:40	0:26	LINE FAULT
1228	6-Dec-21	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 2	CHITRADURGA_66	4:13	4:40	0:26	MAIN SUPPLY FAILURE
1229	6-Dec-21	TUMKUR	66	CHITRADURGA 66kV-MEGMICON 1	MEGMICON 1_IPP_66	4:13	7:09	2:56	MAIN SUPPLY FAILURE
1230	6-Dec-21	TUMKUR	66	CHITRADURGA 66kV-MEGMICON 2	MEGMICON 1_IPP_66	4:34	5:22	0:47	MAIN SUPPLY FAILURE
1231	6-Dec-21	TUMKUR	66	H D PURA-CHITRADURGA220	H D PURA_66	4:13	5:02	0:49	LINE FAULT
1232	6-Dec-21	TUMKUR	66	MADHUGIRI 220kV-PULLAMAGATTA	PULLAMGATTA_66	2:21	2:36	0:15	LINE FAULT
1233	6-Dec-21	TUMKUR	66	MADHUGIRI 220kV-PULLAMAGATTA	PULLAMGATTA_66	2:51	3:13	0:21	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1234	6-Dec-21	TUMKUR	66	PAVAGADA220-PAVAGADA2	PAVAGADA_220	18:16	18:24	0:07	LINE FAULT
1235	6-Dec-21	TUMKUR	66	THERIYUR 66-PAVAGADA	THERIYUR_66	17:04	17:21	0:17	LINE CLEAR AVAILED
1236	6-Dec-21	TUMKUR	66	TR-1	CHANNAGIRI_66	1:39	1:42	0:03	TRANSFORMER FAULT
1237	6-Dec-21	TUMKUR	66	TR-1	KALMARANAHALLI_66	15:43	16:02	0:18	TRANSFORMER FAULT
1238	6-Dec-21	TUMKUR	66	TR-1	THERIYUR_66	17:02	17:22	0:19	LINE CLEAR AVAILED
1239	6-Dec-21	TUMKUR	66	TR-2	HINDASGHATTA_66	9:30	18:35	9:04	LINE CLEAR AVAILED
1240	6-Dec-21	TUMKUR	66	TR-2	SANIKERE_66	18:03	18:45	0:41	LINE CLEAR AVAILED
1241	6-Dec-21	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETTYKERE_110	6:23	6:56	0:32	LINE FAULT
1242	6-Dec-21	TUMKUR	110	CHIKKANAYAKANAHALLI- HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	6:23	8:16	1:52	LINE FAULT
1243	6-Dec-21	TUMKUR	110	NITTUR 220kV- SOMALAPURA	NITTUR_220	16:13	16:30	0:17	LINE CLEAR AVAILED
1244	6-Dec-21	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	6:24	9:58	3:33	LINE FAULT