

## 400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 18.12.2018 to 24.12.2018

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	18-Dec-18	BAGALKOT	110	110/11KV,HV2	BHUTHNAL_110	16:28	16:31	0:03	TRANSFORMER FAULT
2	18-Dec-18	BAGALKOT	110	110/11KV,HV1	DAMBAL_110	15:18	17:00	1:42	LINE CLEAR AVAILED
3	18-Dec-18	BAGALKOT	110	DAVALESHWARA-SAIDAPUR	SAIDAPUR_110	8:29	12:13	3:44	HAND TRIPPED
4	18-Dec-18	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	8:31	12:13	3:42	HAND TRIPPED
5	18-Dec-18	BAGALKOT	110	GAMESHA-KULIGOD	KULIGOD_110	10:57	12:04	1:07	LINE CLEAR AVAILED
6	18-Dec-18	BAGALKOT	110	KUMATA-SIRSI1	SIRSI_110	0:00	10:31	10:31	LINE CLEAR AVAILED
7	18-Dec-18	BAGALKOT	110	KUMATA-SIRSI1	SIRSI_110	16:51	23:59	7:08	HAND TRIPPED
8	18-Dec-18	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	9:46	13:04	3:18	NBFC ISSUED
9	18-Dec-18	BAGALKOT	220	HIREBENDIGERI2-BIDNAL	BIDNAL_220	18:07	23:59	5:52	LINE CLEAR AVAILED
10	18-Dec-18	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	17:54	18:03	0:09	HAND TRIPPED
11	18-Dec-18	BAGALKOT	110	CHIKKODI220-RAIBAG	RAIBAG_110	10:09	10:35	0:26	HAND TRIPPED
12	18-Dec-18	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	12:54	13:43	0:49	NBFC ISSUED
13	18-Dec-18	BANGALORE	66	HV1	AGALAKOTE	9:43	9:49	0:06	TRANSFORMER FAULT
14	18-Dec-18	BANGALORE	66	CHELUR - YENNIGADALE	CHELUR	17:39	18:56	1:17	LINE CLEAR AVAILED
15	18-Dec-18	BANGALORE	66	HV1	H GOLLAHALLI	11:45	15:30	3:45	LINE CLEAR AVAILED
16	18-Dec-18	BANGALORE	66	KANASAWADI - YELAHANKA 220	KANASAWADI	7:10	7:30	0:20	LOAD CHANGE OVER
17	18-Dec-18	BANGALORE	66	KANASWADI - DB PURA 220	KANASWADI	18:00	18:05	0:05	LOAD CHANGE OVER
18	18-Dec-18	BANGALORE	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	11:02	11:25	0:23	MAIN SUPPLY FAILURE
19	18-Dec-18	BANGALORE	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	15:15	15:25	0:10	MAIN SUPPLY FAILURE
20	18-Dec-18	BANGALORE	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	11:03	11:30	0:27	MAIN SUPPLY FAILURE
21	18-Dec-18	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:03	11:30	0:27	MAIN SUPPLY FAILURE
22	18-Dec-18	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA,KACHAMARANAHALLI	11:03	11:30	0:27	MAIN SUPPLY FAILURE
23	18-Dec-18	BANGALORE	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	15:15	15:35	0:20	MAIN SUPPLY FAILURE
24	18-Dec-18	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	15:15	15:35	0:20	MAIN SUPPLY FAILURE
25	18-Dec-18	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA,KACHAMARANAHALLI	15:15	15:35	0:20	MAIN SUPPLY FAILURE
26	18-Dec-18	BANGALORE	66	HV1	SOMAYAJANAHALLI	10:06	10:27	0:21	TRANSFORMER FAULT
27	18-Dec-18	BANGALORE	66	HV1	SOMAYAJANAHALLI	16:50	17:00	0:10	TRANSFORMER FAULT
28	18-Dec-18	BANGALORE	66	HV2	SULIBELE	4:37	6:00	1:23	TRANSFORMER FAULT
29	18-Dec-18	BANGALORE	66	YELAHANKA 220 - LINE 8	RAJANAKUNTE	10:51	11:44	0:53	LINE CLEAR AVAILED
30	18-Dec-18	BANGALORE	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220	11:02	11:22	0:20	LOAD CHANGE OVER
31	18-Dec-18	BANGALORE	220	MALUR 220 - KOLAR 3	SARJAPURA 220	15:15	15:24	0:09	LOAD CHANGE OVER
32	18-Dec-18	BANGALORE	66	HV1	BTM 4TH PHASE	12:09	16:05	3:55	LINE CLEAR AVAILED
33	18-Dec-18	BANGALORE	66	HV1	KENGERI SATELLITE TOWN	13:08	15:32	2:24	LINE CLEAR AVAILED
34	18-Dec-18	BANGALORE	66	KUMBALGODU - CHANDRAPPA CIRCLE	CHANDRAPPA CIRCLE	13:15	16:33	3:17	LINE CLEAR AVAILED
35	18-Dec-18	BANGALORE	66	HV1	NRS 220	0:26	2:29	2:02	LINE CLEAR AVAILED
36	18-Dec-18	BANGALORE	66	HV4	NRS 220	1:59	2:29	0:29	LINE CLEAR AVAILED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
37	18-Dec-18	BANGALORE	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	0:40	1:16	0:35	LINE CLEAR AVAILED
38	18-Dec-18	BANGALORE	66	HV1	TELECOM LAYOUT	12:06	12:11	0:05	LINE CLEAR AVAILED
39	18-Dec-18	BANGALORE	66	TK HALLI 220 - MANDYA 1	MANDYA	11:10	11:19	0:09	LINE FAULT
40	18-Dec-18	BANGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, K HONALGERE	11:10	11:19	0:09	LINE FAULT
41	18-Dec-18	BANGALORE	66	PADMANABHANAGAR - SUBRAMANYAPURA 220	PADMANABHANAGAR	10:38	10:45	0:07	LOAD CHANGE OVER
42	18-Dec-18	BANGALORE	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	9:54	9:58	0:04	LOAD CHANGE OVER
43	18-Dec-18	BANGALORE	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON	7:30	7:48	0:18	LINE FAULT
44	18-Dec-18	BANGALORE	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON	7:52	8:38	0:46	LINE CLEAR AVAILED
45	18-Dec-18	BANGALORE	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON	22:45	23:05	0:20	LINE FAULT
46	18-Dec-18	BANGALORE	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON	23:05	23:47	0:42	LINE FAULT
47	18-Dec-18	BANGALORE	66	ISKON - SUBRAMANYAPURA 220	ISKON	12:15	12:19	0:04	LOAD CHANGE OVER
48	18-Dec-18	BANGALORE	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	7:30	7:55	0:25	MAIN SUPPLY FAILURE
49	18-Dec-18	BANGALORE	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	14:12	14:20	0:08	LOAD CHANGE OVER
50	18-Dec-18	BANGALORE	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	22:45	22:53	0:08	MAIN SUPPLY FAILURE
51	18-Dec-18	BANGALORE	66	HV2	VICTORIA HOSPITAL	13:43	13:47	0:03	LINE CLEAR AVAILED
52	18-Dec-18	BANGALORE	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	11:02	11:23	0:21	MAIN SUPPLY FAILURE
53	18-Dec-18	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	11:02	11:23	0:21	MAIN SUPPLY FAILURE
54	18-Dec-18	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	11:02	11:23	0:21	MAIN SUPPLY FAILURE
55	18-Dec-18	BANGALORE	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK, GLOBAL TECH PARK (EHT)	11:02	11:23	0:21	MAIN SUPPLY FAILURE
56	18-Dec-18	BANGALORE	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	15:15	15:25	0:10	MAIN SUPPLY FAILURE
57	18-Dec-18	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	15:15	15:25	0:10	MAIN SUPPLY FAILURE
58	18-Dec-18	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	15:15	15:25	0:10	MAIN SUPPLY FAILURE
59	18-Dec-18	BANGALORE	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK, GLOBAL TECH PARK (EHT)	15:15	15:25	0:10	MAIN SUPPLY FAILURE
60	18-Dec-18	GULBARGA	220	HV1	RAICHUR_220	15:04	22:16	7:12	LINE CLEAR AVAILED
61	18-Dec-18	GULBARGA	110	ALIPUR-MUNIRABAD	KUDITINI_110,TORANGALLU_110,KURU GOD_110,METRI_110	6:34	7:02	0:28	LINE FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
62	18-Dec-18	GULBARGA	110	HV1	HALBURGA_220	11:19	12:53	1:34	LINE CLEAR AVAILED
63	18-Dec-18	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	2:35	2:45	0:10	LINE FAULT
64	18-Dec-18	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	11:45	15:05	3:20	LINE CLEAR AVAILED
65	18-Dec-18	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110	22:40	22:50	0:10	LINE FAULT
66	18-Dec-18	GULBARGA	110	HV2	MANTHAL_110	16:15	18:05	1:50	LINE CLEAR AVAILED
67	18-Dec-18	GULBARGA	110	HV2	MANTHAL_110	18:04	18:30	0:26	LINE CLEAR AVAILED
68	18-Dec-18	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	10:45	15:25	4:40	LINE CLEAR AVAILED
69	18-Dec-18	GULBARGA	66	HV1	ITTAGI_220	14:45	15:05	0:20	TRANSFORMER FAULT
70	18-Dec-18	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	0:00	6:54	6:54	LINE CLEAR AVAILED
71	18-Dec-18	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	23:35	23:59	0:24	LINE CLEAR AVAILED
72	18-Dec-18	HASSAN	220	UPCL-KEMAR1	UPCL_GEN	12:06	12:36	0:30	LINE FAULT
73	18-Dec-18	HASSAN	220	UPCL-KEMAR2	UPCL_GEN	12:06	12:36	0:30	LINE FAULT
74	18-Dec-18	HASSAN	220	KAVOOR-KEMAR2	KAVOOR_220	12:09	12:43	0:34	LOAD CURTAILMENT
75	18-Dec-18	HASSAN	220	HV1	KEMAR_220	10:27	12:49	2:22	LINE CLEAR AVAILED
76	18-Dec-18	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	12:02	22:36	10:34	LINE FAULT
77	18-Dec-18	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	12:06	22:36	10:30	LINE FAULT
78	18-Dec-18	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	12:06	12:52	0:46	LINE FAULT
79	18-Dec-18	HASSAN	220	PUTTUR-KEMAR1	PUTTUR_220	12:08	12:41	0:33	LOAD CURTAILMENT
80	18-Dec-18	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	12:08	12:44	0:36	LOAD CURTAILMENT
81	18-Dec-18	HASSAN	220	VARAHI-KEMAR1	VARAHI_GEN	12:07	12:39	0:32	LINE FAULT
82	18-Dec-18	HASSAN	220	VARAHI-KEMAR2	VARAHI_GEN	12:07	12:40	0:33	LINE FAULT
83	18-Dec-18	HASSAN	220	VARAHI-KEMAR3	VARAHI_GEN	12:08	13:02	0:54	LINE FAULT
84	18-Dec-18	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	12:44	12:54	0:10	LOAD CURTAILMENT
85	18-Dec-18	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	14:09	17:43	3:34	LINE CLEAR AVAILED
86	18-Dec-18	HASSAN	110	LV1	KAVOOR_220	12:21	12:44	0:23	LOAD CURTAILMENT
87	18-Dec-18	HASSAN	110	LV2	KAVOOR_220	12:21	12:44	0:23	LOAD CURTAILMENT
88	18-Dec-18	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	11:27	14:44	3:17	LINE CLEAR AVAILED
89	18-Dec-18	HASSAN	110	HV1	KEMAR_220	15:44	17:35	1:51	LINE CLEAR AVAILED
90	18-Dec-18	HASSAN	110	LV1	KEMAR_220	10:27	12:50	2:23	LINE CLEAR AVAILED
91	18-Dec-18	HASSAN	110	HV2	HALADY_110	10:12	10:52	0:40	LINE CLEAR AVAILED
92	18-Dec-18	HASSAN	110	HV2	GANDASI_110	10:12	15:05	4:53	LINE CLEAR AVAILED
93	18-Dec-18	HASSAN	110	GURUVAY-KEMAR1	GURUVAYANKERE_110	12:08	12:45	0:37	LOAD CURTAILMENT
94	18-Dec-18	HASSAN	110	GURUVAY-KEMAR2	GURUVAYANKERE_110	11:27	14:44	3:17	NBFC ISSUED
95	18-Dec-18	HASSAN	110	HIRIYADKA-HALADY	HIRIYADKA_110	12:09	12:48	0:39	LOAD CURTAILMENT
96	18-Dec-18	HASSAN	110	HIRIYADKA-MADHUVANA	HIRIYADKA_110	12:08	12:48	0:40	LOAD CURTAILMENT
97	18-Dec-18	HASSAN	110	HOSANGDI-HALDY	HOSNGDI_110	12:08	12:59	0:51	LOAD CURTAILMENT
98	18-Dec-18	HASSAN	110	JOG GEN-NK2	JOG_GEN	12:56	13:45	0:49	LINE CLEAR AVAILED
99	18-Dec-18	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	12:09	13:02	0:53	LOAD CURTAILMENT
100	18-Dec-18	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	12:08	12:48	0:40	LOAD CURTAILMENT
101	18-Dec-18	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	12:08	12:51	0:43	LOAD CURTAILMENT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
102	18-Dec-18	HASSAN	110	MOODABIDRE-GURUPURA	MOODABIDRE_110	10:23	13:01	2:38	LOAD CURTAILMENT
103	18-Dec-18	HASSAN	110	MOODABIDRE-KEMAR	MOODABIDRE_110	10:28	16:51	6:23	LOAD CURTAILMENT
104	18-Dec-18	HASSAN	110	MOODABIDRE-SOHAM1	MOODABIDRE_110	13:04	13:05	0:01	HAND TRIPPED
105	18-Dec-18	HASSAN	110	MOODABIDRE-SOHAM2	MOODABIDRE_110	13:04	13:05	0:01	HAND TRIPPED
106	18-Dec-18	HASSAN	110	HV1	NAVUNDA_110	9:15	18:30	9:15	LINE CLEAR AVAILED
107	18-Dec-18	HASSAN	110	HV2	NAVUNDA_110	9:15	18:30	9:15	LINE CLEAR AVAILED
108	18-Dec-18	HASSAN	110	PUTTUR-SLTR	PUTTUR_110	12:09	12:50	0:41	LOAD CURTAILMENT
109	18-Dec-18	HASSAN	110	PUTTUR-SULIA	PUTTUR_110	12:08	12:47	0:39	LOAD CURTAILMENT
110	18-Dec-18	HASSAN	66	HV1	ALDUR_66	12:40	14:30	1:50	LINE CLEAR AVAILED
111	18-Dec-18	HASSAN	66	ARAKALGUD-MALLIPATNA	ARAKALGUD_66	11:13	11:27	0:14	LINE FAULT
112	18-Dec-18	HASSAN	66	CHIKMANGLRE-L1-ALDUR	CHIKMAGLUR_66	12:29	15:37	3:08	LINE CLEAR AVAILED
113	18-Dec-18	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	11:01	11:53	0:52	LINE CLEAR AVAILED
114	18-Dec-18	HASSAN	66	MRSSHM-DVG2	MRSMG_220	17:07	17:11	0:04	LINE FAULT
115	18-Dec-18	HASSAN	66	SAKLESH PURA-IPCL2	SAKALESH PURA_66	4:00	4:12	0:12	LINE FAULT
116	18-Dec-18	HASSAN	66	HV2	SBELAGOLA_66	10:33	10:43	0:10	TRANSFORMER FAULT
117	18-Dec-18	HASSAN	66	HV2	SHANTHIGRAMA_66	10:51	17:09	6:18	LINE CLEAR AVAILED
118	18-Dec-18	HASSAN	66	HV2	KIADB H_66	10:42	10:50	0:08	HAND TRIPPED
119	18-Dec-18	MYSORE	66	HV2	ADDIHALI_66	11:12	13:36	2:23	LINE CLEAR AVAILED
120	18-Dec-18	MYSORE	66	ANEGOLA-HUYGONAHALLY	ANEGOLAL_66	11:38	15:00	3:21	LINE CLEAR AVAILED
121	18-Dec-18	MYSORE	66	BANNANGADI-HUYGONAHALLY	BANANGADI_66	10:09	17:43	7:34	LINE CLEAR AVAILED
122	18-Dec-18	MYSORE	66	HV1	BANNUR_66	4:01	4:07	0:05	TRANSFORMER FAULT
123	18-Dec-18	MYSORE	66	HV1	BOOKANAKERE_66	9:27	13:32	4:05	LINE CLEAR AVAILED
124	18-Dec-18	MYSORE	66	HV2	BOOKANAKERE_66	9:27	13:32	4:05	LINE CLEAR AVAILED
125	18-Dec-18	MYSORE	66	BYLUKUPPE-KUSHALANAGARA 220	BYLUKUPPE_66	10:04	17:45	7:41	LINE CLEAR AVAILED
126	18-Dec-18	MYSORE	66	DR PETE-KUNTHUR	SANTHEMARAHALLI_66 MUGUR_66 THAYURU_66	9:28	9:35	0:06	LINE FAULT
127	18-Dec-18	MYSORE	66	HV1	DODDABYADARAHALLI_66	11:17	13:07	1:49	LINE CLEAR AVAILED
128	18-Dec-18	MYSORE	220	HV2	HOOTAGALLY_220	12:14	12:35	0:21	LINE CLEAR AVAILED
129	18-Dec-18	MYSORE	220	HOOTAGALLI-HV3	HOOTAGALLY_220	13:51	14:15	0:23	LINE CLEAR AVAILED
130	18-Dec-18	MYSORE	66	HV1	HOOTAGALLY_220	13:29	13:30	0:01	HAND TRIPPED
131	18-Dec-18	MYSORE	66	KADAKOLA-RK NAGARA	RKNAGARA_66 DATTAGALLY_66	8:36	8:41	0:05	LINE FAULT
132	18-Dec-18	MYSORE	66	KM DODDI-TK HALLI	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 K_HONNALGERE_66 MADDUR_66	11:10	11:16	0:06	LINE FAULT
133	18-Dec-18	MYSORE	220	HV2	KRPET_220	10:20	15:45	5:25	LINE CLEAR AVAILED
134	18-Dec-18	MYSORE	66	HV1	MADDUR_66	16:25	17:17	0:51	LINE CLEAR AVAILED
135	18-Dec-18	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	12:50	12:54	0:04	LINE FAULT
136	18-Dec-18	MYSORE	66	PERIYAPATNA-KUSHALANAGARA 1	PERIYAPATNA_66	14:44	18:15	3:31	LINE CLEAR AVAILED
137	18-Dec-18	MYSORE	66	PERIYAPATNA-KUSHALANAGARA 2	PERIYAPATNA_66	14:44	18:15	3:31	LINE CLEAR AVAILED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
138	18-Dec-18	MYSORE	66	PERIYAPATNA-HANAGODU	PERIYAPATNA_66	14:44	18:15	3:31	LINE CLEAR AVAILED
139	18-Dec-18	MYSORE	66	PERIYAPATNA-HUNSUR	PERIYAPATNA_66	14:42	18:34	3:52	LINE CLEAR AVAILED
140	18-Dec-18	MYSORE	66	PERIYAPATNA-HANAGODU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	21:47	21:53	0:05	LINE FAULT
141	18-Dec-18	MYSORE	66	HV1	SALIGRAMA_66	10:30	16:58	6:28	LINE CLEAR AVAILED
142	18-Dec-18	MYSORE	66	HV2	SALIGRAMA_66	10:30	16:58	6:28	LINE CLEAR AVAILED
143	18-Dec-18	MYSORE	66	HV2	SFCSHIVA_66	8:58	12:15	3:17	LINE CLEAR AVAILED
144	18-Dec-18	TUMKUR	220	TR-1(HV SIDE )	MADHUGIRI_220	5:30	8:30	3:00	TRANSFORMER FAULT
145	18-Dec-18	TUMKUR	220	TR-2(HV SIDE )	MADHUGIRI_220	5:30	6:20	0:50	TRANSFORMER FAULT
146	18-Dec-18	TUMKUR	66	ANTHRASANAHALLI 220kV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	6:13	14:04	7:50	LINE FAULT
147	18-Dec-18	TUMKUR	66	BELADADARA-CTKERE	CHIKKATOTLUKERE_66	6:43	14:13	7:29	HAND TRIPPED
148	18-Dec-18	TUMKUR	66	CHANNAGIRI-LNGDHLI	CHANNAGIRI_66	9:03	9:27	0:23	MAIN SUPPLY FAILURE
149	18-Dec-18	TUMKUR	66	CHANNAGIRI-LNGDHLI	CHANNAGIRI_66	10:07	16:57	6:50	MAIN SUPPLY FAILURE
150	18-Dec-18	TUMKUR	66	TR-1 & TR-2	CHANNAGIRI_66	9:03	9:27	0:23	MAIN SUPPLY FAILURE
151	18-Dec-18	TUMKUR	66	TR-1 & TR-2	CHANNAGIRI_66	10:07	16:57	6:50	MAIN SUPPLY FAILURE
152	18-Dec-18	TUMKUR	66	CHAWDANKUPPE-ESENGY_SLR	ESENGY_SLR	18:04	18:30	0:25	LINE FAULT
153	18-Dec-18	TUMKUR	66	TR-2	CHELURU_66	14:06	14:32	0:25	TRANSFORMER FAULT
154	18-Dec-18	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	10:13	16:33	6:20	MAIN SUPPLY FAILURE
155	18-Dec-18	TUMKUR	66	TR-1	DEVARAHALLI_66	10:13	16:33	6:20	MAIN SUPPLY FAILURE
156	18-Dec-18	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	9:33	9:50	0:16	LINE FAULT
157	18-Dec-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:22	17:46	9:24	LINE CLEAR AVAILED
158	18-Dec-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	9:01	16:32	7:31	LINE CLEAR AVAILED
159	18-Dec-18	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	7:19	15:36	8:17	LINE CLEAR AVAILED
160	18-Dec-18	TUMKUR	66	SIRA- KALLAMBELLA	KALLAMBELLA_66	7:19	15:36	8:17	LINE CLEAR AVAILED
161	18-Dec-18	TUMKUR	66	SIRA- MADHUGIRI 1	BUKKAPATNA_66, KALLAMBELLA_66	7:18	15:11	7:52	LINE CLEAR AVAILED
162	18-Dec-18	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	7:18	15:28	8:10	LINE CLEAR AVAILED
163	18-Dec-18	TUMKUR	66	MADHUGIRI 220kV- HOLAVINHALLI	HOLAVINAHALLY_66	6:13	7:13	1:00	LINE FAULT
164	18-Dec-18	TUMKUR	66	MADHUGIRI 220kV- SIRA2	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	4:28	8:10	3:41	LINE FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
165	18-Dec-18	TUMKUR	66	MADHUGIRI 220kV- SIRA1	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	6:13	15:02	8:49	LINE FAULT
166	18-Dec-18	TUMKUR	66	( TR-1LV1)	MADHUGIRI_220	5:30	8:30	3:00	TRANSFORMER FAULT
167	18-Dec-18	TUMKUR	66	MADHUGIRI 220kV- NAGALMADIKE (MEDIGESHI2)	SHYLAPURA_66, NAGALMADIKE_66, LINGADAHALLI_TMK2_66, MANGALWADA_66, YNHOSKOTE_66	6:13	7:04	0:50	LINE FAULT
168	18-Dec-18	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	6:13	8:10	1:57	LINE FAULT
169	19-Dec-18	BAGALKOT	220	HIREBENDIGERI1-BIDNAL	BIDNAL_110	11:01	17:51	6:50	NBFC ISSUED
170	19-Dec-18	BAGALKOT	220	HIREBENDIGERI2-BIDNAL	BIDNAL_110	0:00	17:50	17:50	LINE CLEAR AVAILED
171	19-Dec-18	BAGALKOT	220	HIREBENDIGERI2-BIDNAL	BIDNAL_110	18:05	18:11	0:06	HAND TRIPPED
172	19-Dec-18	BAGALKOT	220	BELGAUM2-CHIKKODI	CHIKKODI_220	16:33	23:59	7:26	LINE FAULT
173	19-Dec-18	BAGALKOT	220	BELGAUM1-CHIKKODI	CHIKKODI_220	17:26	19:03	1:37	LINE FAULT
174	19-Dec-18	BAGALKOT	110	110/11KV,HV2	ANKALI_110	5:46	5:53	0:07	TRANSFORMER FAULT
175	19-Dec-18	BAGALKOT	110	SAIDAPUR-DAVALESHWARA	DAVALESHWARA_110	9:03	14:27	5:24	LINE CLEAR AVAILED
176	19-Dec-18	BAGALKOT	110	110/11KV,HV2	GOPANAKOPPA_110	11:02	14:42	3:40	LINE CLEAR AVAILED
177	19-Dec-18	BAGALKOT	110	PG HUNSYAL-MUDALGI	MUDALGI_110	23:27	23:38	0:11	LINE FAULT
178	19-Dec-18	BAGALKOT	110	SATISH SUGARS-PG HUNSYAL	PG HUNSYAL_110	23:27	23:30	0:03	LINE FAULT
179	19-Dec-18	BAGALKOT	220	CHIKKODI-KUDUCHI	KUDUCHI_220	17:10	17:53	0:43	LINE FAULT
180	19-Dec-18	BAGALKOT	110	110/11KV,HV1	ZALKI_110	14:38	16:04	1:26	HAND TRIPPED
181	19-Dec-18	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	11:08	11:11	0:03	HAND TRIPPED
182	19-Dec-18	BAGALKOT	110	SIRSI-KUMTA1	SIRSI_110	12:46	14:51	2:05	NBFC ISSUED
183	19-Dec-18	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	12:46	14:51	2:05	NBFC ISSUED
184	19-Dec-18	BAGALKOT	220	GHATAPRABHA-CHIKKODI	GHATAPRABHA_220	17:12	17:46	0:34	LINE FAULT
185	19-Dec-18	BANGALORE	66	HV2	BTM 4TH PHASE	12:15	14:58	2:43	LINE CLEAR AVAILED
186	19-Dec-18	BANGALORE	66	HV2	ELECTRONIC CITY PH-2 SEC-1	14:16	15:09	0:53	LINE CLEAR AVAILED
187	19-Dec-18	BANGALORE	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	9:54	9:58	0:04	LOAD CHANGE OVER
188	19-Dec-18	BANGALORE	66	HV1	SOLDEVANAHALLI	13:12	13:14	0:02	LOAD CHANGE OVER
189	19-Dec-18	BANGALORE	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	6:40	6:44	0:04	LOAD CHANGE OVER
190	19-Dec-18	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	2:53	3:07	0:14	LINE FAULT
191	19-Dec-18	BANGALORE	66	HV2	DODDABELAVANGALA	9:02	9:13	0:11	TRANSFORMER FAULT
192	19-Dec-18	BANGALORE	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	7:46	7:56	0:09	LINE FAULT
193	19-Dec-18	BANGALORE	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	7:46	7:56	0:09	LINE FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
194	19-Dec-18	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	9:18	9:54	0:35	MAIN SUPPLY FAILURE
195	19-Dec-18	BANGALORE	66	KOLAR 220 - MULABAGAL	MULBAGAL, AVANI	15:39	18:19	2:40	LINE CLEAR AVAILED
196	19-Dec-18	BANGALORE	66	HV1	NANDAGANAHALLI	14:45	15:15	0:30	LINE CLEAR AVAILED
197	19-Dec-18	BANGALORE	66	HV2	THMAMPALLI	15:13	15:28	0:14	LINE CLEAR AVAILED
198	19-Dec-18	BANGALORE	66	THIMAMPALLI - BAGEPALLI	THMAMPALLI	16:51	17:01	0:10	LINE CLEAR AVAILED
199	19-Dec-18	GULBARGA	220	LINGAPUR-JVSL2	LINGAPUR_220	9:34	15:43	6:09	LINE CLEAR AVAILED
200	19-Dec-18	GULBARGA	220	HV1	RAICHUR_220	10:19	11:06	0:47	LINE CLEAR AVAILED
201	19-Dec-18	GULBARGA	220	HV1	KAPNOOR_220	9:28	13:15	3:47	LINE CLEAR AVAILED
202	19-Dec-18	GULBARGA	220	HV2	KAPNOOR_220	13:18	16:30	3:12	LINE CLEAR AVAILED
203	19-Dec-18	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110,DONGRAGOA_110,KAMALNAGAR_110	6:47	6:58	0:11	LINE FAULT
204	19-Dec-18	GULBARGA	110	HALBURGA-KOLHAR2	KOLHAR_110,JANAWADA_110	6:46	6:57	0:11	LINE FAULT
205	19-Dec-18	GULBARGA	110	LV1, LV2	HALBURGA_220	11:44	12:03	0:19	TRANSFORMER FAULT
206	19-Dec-18	GULBARGA	110	HALBURGA-ACMESOLAR_IPP	HALBURGA_220	12:29	12:47	0:18	LINE FAULT
207	19-Dec-18	GULBARGA	110	RAICHUR-SINDHANOOR1	ALKOD_110,BYAGAWAT_110,SIRWAR_110,VALKAMDINNI_110	1:31	4:50	3:19	LINE FAULT
208	19-Dec-18	GULBARGA	110	RAICHUR-SINDHANOOR1	ALKOD_110,BYAGAWAT_110,SIRWAR_110,VALKAMDINNI_110	6:10	6:15	0:05	LINE FAULT
209	19-Dec-18	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	MUKUNDA_110,KAMPLI_GLB_110,BTPS_WATERWORKS	2:26	2:32	0:06	LINE FAULT
210	19-Dec-18	GULBARGA	110	SINDHANOOR220-MUNIRABAD1	KARTAGI_110,SRERAMANAGAR_110,VENKATAGIRI_110,GANGAVATHI_110	10:10	10:23	0:13	LINE FAULT
211	19-Dec-18	GULBARGA	110	HV1	KAVITAL_110	4:57	7:18	2:21	TRANSFORMER FAULT
212	19-Dec-18	GULBARGA	110	HV1	BISIHALLI_110	16:02	16:30	0:28	TRANSFORMER FAULT
213	19-Dec-18	GULBARGA	110	HV1	ALIPUR_220	15:52	17:08	1:16	LINE CLEAR AVAILED
214	19-Dec-18	GULBARGA	110	HUMNABAD220-MANEKHALLI	MANEKHALLI_110	5:55	6:11	0:16	LINE FAULT
215	19-Dec-18	GULBARGA	110	HUMNABAD220-BIDAR1	HALIKHED_110	6:48	7:11	0:23	LINE FAULT
216	19-Dec-18	GULBARGA	110	GURUGUNTA-LIVL	GURUGUNTA_110	19:30	23:59	4:29	LINE CLEAR AVAILED
217	19-Dec-18	GULBARGA	110	GURUGUNTA-KHEL	GURUGUNTA_110	19:20	19:25	0:05	LINE FAULT
218	19-Dec-18	GULBARGA	110	GURUGUNTA-KHEL	GURUGUNTA_110	21:50	22:05	0:15	LINE CLEAR AVAILED
219	19-Dec-18	GULBARGA	110	HV2	LINGASUGUR_220	17:10	17:20	0:10	TRANSFORMER FAULT
220	19-Dec-18	GULBARGA	110	HV1	LINGASUGUR_220	17:10	17:20	0:10	TRANSFORMER FAULT
221	19-Dec-18	GULBARGA	110	HV3	YADAGIR_110	19:05	19:25	0:20	TRANSFORMER FAULT
222	19-Dec-18	GULBARGA	110	HV3	KOLHAR_110	6:50	7:10	0:20	TRANSFORMER FAULT
223	19-Dec-18	GULBARGA	110	KOLHAR-SHAHISOLAR	KOLHAR_110	12:15	14:20	2:05	LINE FAULT
224	19-Dec-18	GULBARGA	110	KOLHAR-HALBURGA	KOLHAR_110	6:50	7:10	0:20	HAND TRIPPED
225	19-Dec-18	GULBARGA	66	ITTAGI-HIREHADAGALI	HIREHADAGALI_66	16:58	17:03	0:05	LINE CLEAR AVAILED
226	19-Dec-18	GULBARGA	66	TUNGAIPP-ITTAGI1	ITTAGI_220	17:10	17:48	0:38	HAND TRIPPED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
227	19-Dec-18	GULBARGA	66	MUNIRABAD-MSDLNE	HANASI_66	18:40	19:45	1:05	NBFC ISSUED
228	19-Dec-18	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	0:00	6:03	6:03	LINE CLEAR AVAILED
229	19-Dec-18	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	10:25	18:22	7:57	LINE CLEAR AVAILED
230	19-Dec-18	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:12	10:29	1:17	LINE FAULT
231	19-Dec-18	HASSAN	110	MRSSHM-MPM	MRSMSG_220	11:57	13:14	1:17	LINE FAULT
232	19-Dec-18	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	12:17	14:55	2:38	LINE CLEAR AVAILED
233	19-Dec-18	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	9:34	9:43	0:09	LINE FAULT
234	19-Dec-18	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	9:51	12:00	2:09	LINE CLEAR AVAILED
235	19-Dec-18	HASSAN	110	KEMAR-Manipal1	KEMAR_220	10:57	13:08	2:11	LINE CLEAR AVAILED
236	19-Dec-18	HASSAN	110	KEMAR-Manipal2	KEMAR_220	13:12	14:02	0:50	LINE CLEAR AVAILED
237	19-Dec-18	HASSAN	110	HV1	KONAJE_110	9:46	9:54	0:08	MAIN SUPPLY FAILURE
238	19-Dec-18	HASSAN	110	HV2	KONAJE_110	9:46	9:54	0:08	MAIN SUPPLY FAILURE
239	19-Dec-18	HASSAN	110	HV3	KONAJE_110	9:46	9:54	0:08	MAIN SUPPLY FAILURE
240	19-Dec-18	HASSAN	110	HV3	KONAJE_110	10:30	15:56	5:26	LINE CLEAR AVAILED
241	19-Dec-18	HASSAN	110	HV1	KONDENALU_110	10:28	17:23	6:55	LINE CLEAR AVAILED
242	19-Dec-18	HASSAN	110	HV2	KONDENALU_110	10:28	17:23	6:55	LINE CLEAR AVAILED
243	19-Dec-18	HASSAN	110	KULSHE-KAVOOR 2	KULASHEKARA_110	9:33	9:36	0:03	MAIN SUPPLY FAILURE
244	19-Dec-18	HASSAN	110	KULSHE-KAVOOR 2	KULASHEKARA_110	12:27	14:56	2:29	MAIN SUPPLY FAILURE
245	19-Dec-18	HASSAN	110	KULSHE-KERKNJ	KULASHEKARA_110	9:33	9:36	0:03	MAIN SUPPLY FAILURE
246	19-Dec-18	HASSAN	110	KULSHE-KERKNJ	KULASHEKARA_110	12:19	14:56	2:37	MAIN SUPPLY FAILURE
247	19-Dec-18	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	10:59	13:09	2:10	LINE CLEAR AVAILED
248	19-Dec-18	HASSAN	110	MANIPAL-KEMAR2	MANIPAL_110	10:59	13:09	2:10	LINE CLEAR AVAILED
249	19-Dec-18	HASSAN	110	HV4	PUTUR_110	9:25	10:24	0:59	LINE CLEAR AVAILED
250	19-Dec-18	HASSAN	110	HV1	SHIKARIPURA_110	14:00	14:59	0:59	LINE CLEAR AVAILED
251	19-Dec-18	HASSAN	110	HV2	SHIKARIPURA_110	17:50	18:30	0:40	LINE CLEAR AVAILED
252	19-Dec-18	HASSAN	110	HV1	SHIRALKOPPA_220	8:46	14:02	5:16	LINE CLEAR AVAILED
253	19-Dec-18	HASSAN	110	HV1	SHIRALKOPPA_220	14:29	16:28	1:59	LINE CLEAR AVAILED
254	19-Dec-18	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	15:08	15:18	0:10	LINE FAULT
255	19-Dec-18	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	14:29	16:47	2:18	LINE CLEAR AVAILED
256	19-Dec-18	HASSAN	66	HV1	BAGUR_66	15:52	16:07	0:15	LINE CLEAR AVAILED
257	19-Dec-18	HASSAN	66	SIGEBAGE-KDLGRE	SIGEBAGE_66	15:22	15:26	0:04	HAND TRIPPED
258	19-Dec-18	HASSAN	66	SOMNHL-GDNEHALI	SOMNHALLI_66	11:19	16:39	5:20	LINE CLEAR AVAILED
259	19-Dec-18	MYSORE	66	HV1	ATTIGULIPURA_66	18:01	18:06	0:05	TRANSFORMER FAULT
260	19-Dec-18	MYSORE	66	HV2	ATTIGULIPURA_66	18:01	18:06	0:05	TRANSFORMER FAULT
261	19-Dec-18	MYSORE	66	HV1	DEVANOORNGUDU_66	10:40	16:55	6:15	LINE CLEAR AVAILED
262	19-Dec-18	MYSORE	66	HV2	DEVANOORNGUDU_66	10:40	17:10	6:30	LINE CLEAR AVAILED
263	19-Dec-18	MYSORE	66	HV2	DODDINADUVADI_66	10:00	17:10	7:10	LINE CLEAR AVAILED
264	19-Dec-18	MYSORE	66	HV1	DODDINADUVADI_66	10:00	17:29	7:29	LINE CLEAR AVAILED
265	19-Dec-18	MYSORE	66	DR PETE-MADHUVANAHALLI	SANTHEMARAHALI_66 MUGUR_66 THAYURU_66	13:47	14:07	0:20	LINE FAULT



Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
266	19-Dec-18	MYSORE	66	HV1	HAMPAPURA(K)_66	11:35	12:52	1:17	LINE CLEAR AVAILED
267	19-Dec-18	MYSORE	66	HOOTAGALLI-BOGADHI	BOGADHI_66	19:49	20:07	0:18	LINE FAULT
268	19-Dec-18	MYSORE	66	HV1	HOOTAGALLY_220	11:28	11:30	0:02	HAND TRIPPED
269	19-Dec-18	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66	9:26	11:14	1:47	LINE CLEAR AVAILED
270	19-Dec-18	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	10:30	16:18	5:48	LINE CLEAR AVAILED
271	19-Dec-18	MYSORE	66	MADHUVANAHALLI-DODDINDUVADI	DODDINADUVADI_66	10:04	16:56	6:51	LINE CLEAR AVAILED
272	19-Dec-18	MYSORE	66	HV1	MANDYA_66	15:20	17:15	1:55	LINE CLEAR AVAILED
273	19-Dec-18	MYSORE	66	HV2	MANDYA_66	10:19	17:23	7:03	LINE CLEAR AVAILED
274	19-Dec-18	MYSORE	66	HV1	SHIVALLI	10:05	14:20	4:15	LINE CLEAR AVAILED
275	19-Dec-18	MYSORE	66	HV2	SHIVALLI	10:05	14:20	4:15	LINE CLEAR AVAILED
276	19-Dec-18	TUMKUR	220	TR-1 (HV SIDE	ANTHRASANAHALLI_220	18:29	18:33	0:04	LINE CLEAR AVAILED
277	19-Dec-18	TUMKUR	220	TR-2(HV SIDE	ANTHRASANAHALLI_220	18:29	18:35	0:06	LINE CLEAR AVAILED
278	19-Dec-18	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	13:25	13:33	0:07	LINE FAULT
279	19-Dec-18	TUMKUR	220	TR-1(HV SIDE)	HONNALLI_220	13:28	13:42	0:14	HAND TRIPPED
280	19-Dec-18	TUMKUR	220	HONNALLI 220kV- SUZLON1	SUZLON_IPP_66	13:29	13:49	0:20	HAND TRIPPED
281	19-Dec-18	TUMKUR	220	HONNALLI 220kV- SUZLON2	SUZLON_IPP_66	13:29	13:51	0:21	HAND TRIPPED
282	19-Dec-18	TUMKUR	110	TR-2	TURUVEKERE_110	14:54	18:09	3:14	LINE CLEAR AVAILED
283	19-Dec-18	TUMKUR	110	TR-1	KALLUR_110	2:19	2:33	0:13	TRANSFORMER FAULT
284	19-Dec-18	TUMKUR	110	SHETTIKERE- HANDANKERE	SHETYKERE_110	14:07	14:27	0:19	LINE CLEAR AVAILED
285	19-Dec-18	TUMKUR	110	TR-1	SHETYKERE_110	13:50	14:28	0:37	LINE CLEAR AVAILED
286	19-Dec-18	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	10:04	18:34	8:29	LINE CLEAR AVAILED
287	19-Dec-18	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	9:29	19:35	10:05	LINE CLEAR AVAILED
288	19-Dec-18	TUMKUR	66	TR-2(HV SIDE	ANTHRASANAHALLI_220	10:03	18:35	8:31	LINE CLEAR AVAILED
289	19-Dec-18	TUMKUR	66	ANTHRASANAHALLI 220kV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	9:54	19:36	9:42	LINE CLEAR AVAILED
290	19-Dec-18	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	10:04	18:51	8:47	LINE CLEAR AVAILED
291	19-Dec-18	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	10:03	18:36	8:33	LINE CLEAR AVAILED
292	19-Dec-18	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	10:04	19:02	8:58	LINE CLEAR AVAILED
293	19-Dec-18	TUMKUR	66	TR-1((HV SIDE)	HONNALLI_220	13:28	14:00	0:31	HAND TRIPPED
294	19-Dec-18	TUMKUR	66	TR-2((HV SIDE)	HONNALLI_220	13:28	13:46	0:18	HAND TRIPPED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
295	19-Dec-18	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	13:27	13:54	0:26	HAND TRIPPED
296	19-Dec-18	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	14:33	14:43	0:09	LINE FAULT
297	19-Dec-18	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66	7:54	8:02	0:07	LINE FAULT
298	19-Dec-18	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66	13:27	13:57	0:29	HAND TRIPPED
299	19-Dec-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	13:27	13:53	0:25	HAND TRIPPED
300	19-Dec-18	TUMKUR	66	TR-1(LV SIDE	HONNALLI_220	13:28	13:44	0:16	HAND TRIPPED
301	19-Dec-18	TUMKUR	66	TR-2(LV SIDE	HONNALLI_220	13:28	13:52	0:23	HAND TRIPPED
302	19-Dec-18	TUMKUR	66	BADDIHALLI- MELEKOTE	BADDIHALLI_66	16:08	16:52	0:44	HAND TRIPPED
303	19-Dec-18	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	10:47	10:50	0:02	HAND TRIPPED
304	19-Dec-18	TUMKUR	66	TR-1 & TR-2	BELADARA_66	19:15	19:37	0:22	HAND TRIPPED
305	19-Dec-18	TUMKUR	66	BELADADARA- KORATAGERE( ANTHRASANAHALLI)	BELADARA_66	10:49	19:15	8:26	LINE CLEAR AVAILED
306	19-Dec-18	TUMKUR	66	CHELLUR-ANTHRASANAHALLI	CHELURU_66	11:48	18:24	6:35	LINE CLEAR AVAILED
307	19-Dec-18	TUMKUR	66	TR-2	CHELURU_66	11:48	18:24	6:35	LINE CLEAR AVAILED
308	19-Dec-18	TUMKUR	66	CHIKKABANAGERE-GLOBSLR	GLOBAL TECH PARK_66_IPP	10:05	17:17	7:11	LINE CLEAR AVAILED
309	19-Dec-18	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	10:04	17:01	6:57	LINE CLEAR AVAILED
310	19-Dec-18	TUMKUR	66	DODDASARANGI- ANCHEPALYA	DODDASARANGI_66	10:45	18:43	7:58	HAND TRIPPED
311	19-Dec-18	TUMKUR	66	TR-1	HIREMALLANAHOLE_66	11:50	12:04	0:13	LINE CLEAR AVAILED
312	19-Dec-18	TUMKUR	66	TR-2	HULIYURDURGA_66	6:45	7:05	0:19	TRANSFORMER FAULT
313	19-Dec-18	TUMKUR	66	KORA- ANTHRASANAHALLI	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	15:14	19:05	3:51	MAIN SUPPLY FAILURE
314	19-Dec-18	TUMKUR	66	KORA- BRAHMASANDRA	BRAHMASANDRA_66	9:59	15:14	5:15	MAIN SUPPLY FAILURE
315	19-Dec-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:55	11:44	0:48	LINE CLEAR AVAILED
316	19-Dec-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:36	12:46	0:10	LINE FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
317	19-Dec-18	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:31	13:54	0:22	LINE FAULT
318	19-Dec-18	TUMKUR	66	TR-2	MALEBENNUR_66	22:02	22:13	0:10	TRANSFORMER FAULT
319	19-Dec-18	TUMKUR	66	TR-1	TUMKUR_66	9:51	9:59	0:07	HAND TRIPPED
320	20-Dec-18	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	9:53	18:25	8:32	LINE CLEAR AVAILED
321	20-Dec-18	BAGALKOT	220	BELGAUM2-CHIKKODI	CHIKKODI_220	0:00	9:44	9:44	LINE CLEAR AVAILED
322	20-Dec-18	BAGALKOT	110	110/11KV,HV1	DAMBAL_110	10:22	17:37	7:15	LINE CLEAR AVAILED
323	20-Dec-18	BAGALKOT	110	110/33KV,HV2	DAMBAL_110	14:14	17:35	3:21	LINE CLEAR AVAILED
324	20-Dec-18	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	10:44	15:20	4:36	LINE CLEAR AVAILED
325	20-Dec-18	BAGALKOT	110	110/33KV,HV3	GUTTAL_110,HOSARATTI_33	11:34	15:25	3:51	LINE CLEAR AVAILED
326	20-Dec-18	BAGALKOT	110	HAVERI220-GUTTAL	GUTTAL_110	11:35	13:25	1:50	LINE CLEAR AVAILED
327	20-Dec-18	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI	VAJRAMATTI_220	6:31	8:13	1:42	LINE FAULT
328	20-Dec-18	BAGALKOT	110	HUBLI220-KADANKOPPA	KADANKOPPA_110	10:08	17:08	7:00	NBFC ISSUED
329	20-Dec-18	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	10:20	10:40	0:20	TRANSFORMER FAULT
330	20-Dec-18	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	10:25	10:30	0:05	TRANSFORMER FAULT
331	20-Dec-18	BAGALKOT	110	AMBEWADI 220-KIRUVATTI	KIRUVATTI_110	12:41	17:20	4:39	HAND TRIPPED
332	20-Dec-18	BAGALKOT	110	110/33KV,HV1	KADANKOPPA_110,DHUMMAWAD_33,YELLAPUR_33	10:02	17:55	7:53	LINE CLEAR AVAILED
333	20-Dec-18	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,KARADI_33,AMINGAD_33	13:02	13:39	0:37	HAND TRIPPED
334	20-Dec-18	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	10:05	17:15	7:10	LINE CLEAR AVAILED
335	20-Dec-18	BANGALORE	66	ADUGODI - HAL 2	K & C VALLEY	9:01	10:01	1:00	LINE FAULT
336	20-Dec-18	BANGALORE	220	HEBBAL 220 - HOODY 220	HEBBAL 220	2:03	2:12	0:09	MAIN SUPPLY FAILURE
337	20-Dec-18	BANGALORE	66	HEBBAL 220 - BANASWADI	BANASWADI	2:03	2:16	0:13	MAIN SUPPLY FAILURE
338	20-Dec-18	BANGALORE	66	HEBBAL 220 - C STATION 1 & 2	C STATION	2:03	2:18	0:15	MAIN SUPPLY FAILURE
339	20-Dec-18	BANGALORE	66	HEBBAL 220 - IISC	IISC	1:59	2:13	0:14	LINE FAULT
340	20-Dec-18	BANGALORE	66	HEBBAL 220 - LR BANDE	LR BANDE	2:03	2:16	0:13	MAIN SUPPLY FAILURE
341	20-Dec-18	BANGALORE	66	HV1	HEBBAL 220	2:03	2:18	0:15	MAIN SUPPLY FAILURE
342	20-Dec-18	BANGALORE	66	HV2	HEBBAL 220	2:03	2:18	0:15	MAIN SUPPLY FAILURE
343	20-Dec-18	BANGALORE	66	HV3	HEBBAL 220	2:03	2:19	0:16	MAIN SUPPLY FAILURE
344	20-Dec-18	BANGALORE	66	HV1	KENGERI SATELLITE TOWN	11:28	15:00	3:32	LINE CLEAR AVAILED
345	20-Dec-18	BANGALORE	66	HV2	KENGERI SATELLITE TOWN	11:28	12:12	0:44	LINE CLEAR AVAILED
346	20-Dec-18	BANGALORE	66	HV2	KENGERI SATELLITE TOWN	13:29	15:00	1:31	LINE CLEAR AVAILED
347	20-Dec-18	BANGALORE	66	HV2	KENGERI SATELLITE TOWN	16:50	17:10	0:20	LINE CLEAR AVAILED
348	20-Dec-18	BANGALORE	66	HV1	POTTERY ROAD	20:46	21:19	0:33	LINE CLEAR AVAILED
349	20-Dec-18	BANGALORE	220	HOODY 220-BEGUR 220	BEGUR 220	12:16	12:59	0:43	LINE FAULT
350	20-Dec-18	BANGALORE	66	BOODIGERE-BEGUR 220	BOODIGERE	12:16	12:48	0:32	MAIN SUPPLY FAILURE

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
351	20-Dec-18	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	6:35	6:46	0:10	LINE FAULT
352	20-Dec-18	BANGALORE	66	CHINTAMANI - GANJIGUNTE 1	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	5:48	6:00	0:11	LINE FAULT
353	20-Dec-18	BANGALORE	66	CHINTAMANI - GANJIGUNTE 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	5:48	6:00	0:11	LINE FAULT
354	20-Dec-18	BANGALORE	66	HV2	NALLIMARADANAHALLI	15:05	15:45	0:39	LINE CLEAR AVAILED
355	20-Dec-18	BANGALORE	220	DB PURA 220 - BEGUR 220	BEGUR 220	12:16	12:24	0:08	LINE FAULT
356	20-Dec-18	BANGALORE	220	BEGUR 220 - HOODY 220	BEGUR 220, HOSKOTE 220	12:15	13:08	0:52	LINE FAULT
357	20-Dec-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	12:15	12:54	0:39	MAIN SUPPLY FAILURE
358	20-Dec-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	12:15	12:53	0:37	MAIN SUPPLY FAILURE
359	20-Dec-18	BANGALORE	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	12:15	12:54	0:38	MAIN SUPPLY FAILURE
360	20-Dec-18	BANGALORE	66	HOSKOTE 220 - SULIBELE	SULIBELE	12:15	12:54	0:38	MAIN SUPPLY FAILURE
361	20-Dec-18	BANGALORE	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	12:15	12:54	0:38	MAIN SUPPLY FAILURE
362	20-Dec-18	BANGALORE	220	HV1	HOSKOTE 220	12:15	12:51	0:36	MAIN SUPPLY FAILURE
363	20-Dec-18	BANGALORE	220	HV2	HOSKOTE 220	12:15	12:50	0:34	MAIN SUPPLY FAILURE
364	20-Dec-18	BANGALORE	66	YELAHANKA 220 - LINE2	YELAHANKA 220	2:02	2:23	0:21	MAIN SUPPLY FAILURE
365	20-Dec-18	BANGALORE	66	YELAHANKA 220 - LINE3	ESCORTS ( EHT ), MANYATHA TECH PARK, ABBIGERE, ATTUR YELAHANKA	2:02	2:14	0:12	MAIN SUPPLY FAILURE
366	20-Dec-18	BANGALORE	66	YELAHANKA 220 - LINE4	SAHAKARINAGAR, RAILWAYS (EHT)	2:02	2:15	0:13	MAIN SUPPLY FAILURE
367	20-Dec-18	BANGALORE	66	YELAHANKA 220 - LINE5	KHB	2:02	2:22	0:20	MAIN SUPPLY FAILURE
368	20-Dec-18	BANGALORE	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	2:02	2:22	0:20	MAIN SUPPLY FAILURE
369	20-Dec-18	BANGALORE	66	YELAHANKA 220 - LINE7	KANASWADI	2:02	2:22	0:20	MAIN SUPPLY FAILURE
370	20-Dec-18	BANGALORE	66	YELAHANKA 220 - LINE8	RAJANKUNTE	2:02	2:22	0:20	MAIN SUPPLY FAILURE
371	20-Dec-18	BANGALORE	220	YELAHANKA 220 - SINGANAYAKANAHALLI 220	YELAHANKA 220	2:02	2:12	0:10	MAIN SUPPLY FAILURE
372	20-Dec-18	BANGALORE	66	BEGUR 220 - BIAL	BIAL	12:15	12:24	0:08	MAIN SUPPLY FAILURE
373	20-Dec-18	GULBARGA	220	HV1, HV2	HALBURGA_220	10:25	10:32	0:07	TRANSFORMER FAULT
374	20-Dec-18	GULBARGA	220	HV1	HALBURGA_220	12:14	12:20	0:06	TRANSFORMER FAULT
375	20-Dec-18	GULBARGA	220	HV1	HUMNABAD_220	9:15	15:45	6:30	LINE CLEAR AVAILED
376	20-Dec-18	GULBARGA	220	HV2	HUMNABAD_220	14:00	18:25	4:25	LINE CLEAR AVAILED
377	20-Dec-18	GULBARGA	220	SEDAM-TANDUR	TANDUR_220	19:50	20:37	0:47	LINE FAULT
378	20-Dec-18	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURU GOD_110,METRI_110	12:30	13:42	1:12	LINE CLEAR AVAILED
379	20-Dec-18	GULBARGA	110	HV1	GULBARGASOUTH_110	12:00	12:25	0:25	LINE CLEAR AVAILED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
380	20-Dec-18	GULBARGA	110	HV1	HANUMASAGAR_110	0:00	12:00	12:00	LINE CLEAR AVAILED
381	20-Dec-18	GULBARGA	110	KUSTAGI-INR_SLR	KUSTAGI_220	11:31	12:03	0:32	LINE FAULT
382	20-Dec-18	GULBARGA	110	KUSTAGI-INR_SLR	KUSTAGI_220	12:11	12:33	0:22	LINE FAULT
383	20-Dec-18	GULBARGA	110	KUSTAGI-INR_SLR	KUSTAGI_220	13:02	14:28	1:26	LINE FAULT
384	20-Dec-18	GULBARGA	110	HV3	LINGASUGUR_220	11:21	12:02	0:41	LINE CLEAR AVAILED
385	20-Dec-18	GULBARGA	110	RAICHUR220-SINDHANOOR1	ALKOD_110,BYAGAWAT_110,SIRWAR_110,VALKAMDINNI_110	10:05	11:48	1:43	LINE CLEAR AVAILED
386	20-Dec-18	GULBARGA	110	HV4	YELBURGA_110	13:40	14:00	0:20	TRANSFORMER FAULT
387	20-Dec-18	GULBARGA	110	GURGUNTA-LJVL_IPP	GURGUNTA_110	0:00	12:43	12:43	LINE CLEAR AVAILED
388	20-Dec-18	GULBARGA	110	GURGUNTA-KHEL_IPP	GURGUNTA_110	11:10	23:59	12:49	LINE CLEAR AVAILED
389	20-Dec-18	GULBARGA	66	ITTAGI-TUNGAIPP	ITTAGI_220	18:25	18:46	0:21	LINE CLEAR AVAILED
390	20-Dec-18	GULBARGA	66	LV1,LV2	ITTAGI_220	6:45	6:55	0:10	TRANSFORMER FAULT
391	20-Dec-18	GULBARGA	66	ITTAGI-KUDILIGI1,2	KUDILIGI_66,KOGALI_66,CJHALLI_66,HANASI_66,GUDEKOTE_66,BANVEKAL_66,CHORNOOR_66,HOSAHALLI_66	6:59	7:14	0:15	LINE FAULT
392	20-Dec-18	GULBARGA	66	ITTAGI-KUDILIGI1,2	KUDILIGI_66,KOGALI_66,CJHALLI_66,HANASI_66,GUDEKOTE_66,BANVEKAL_66,CHORNOOR_66,HOSAHALLI_66	17:30	17:50	0:20	LINE CLEAR AVAILED
393	20-Dec-18	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	22:41	23:59	1:18	LINE CLEAR AVAILED
394	20-Dec-18	HASSAN	220	HV1	HASSN_220	10:41	11:20	0:39	LINE CLEAR AVAILED
395	20-Dec-18	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	18:05	18:17	0:12	HAND TRIPPED
396	20-Dec-18	HASSAN	110	HV1	ARASIKERE_110	9:50	9:55	0:05	TRANSFORMER FAULT
397	20-Dec-18	HASSAN	110	HV1	ARASIKERE_110	10:35	15:00	4:25	LINE CLEAR AVAILED
398	20-Dec-18	HASSAN	110	ARSKERE220-ARSKR	ARSIKERE_220	10:37	14:55	4:18	LINE CLEAR AVAILED
399	20-Dec-18	HASSAN	110	HV3	BAIKAMPADI_110	19:11	19:18	0:07	TRANSFORMER FAULT
400	20-Dec-18	HASSAN	110	HV1	BHADRAVATHY_110	9:20	17:25	8:05	LINE CLEAR AVAILED
401	20-Dec-18	HASSAN	110	HV2	BHADRAVATHY_110	9:20	17:25	8:05	LINE CLEAR AVAILED
402	20-Dec-18	HASSAN	110	HV3	BHADRAVATHY_110	9:20	17:25	8:05	LINE CLEAR AVAILED
403	20-Dec-18	HASSAN	110	HV2	GANDASI_110	19:18	19:26	0:08	TRANSFORMER FAULT
404	20-Dec-18	HASSAN	110	HIRIYADKA-HALADY	HIRIYADKA_110	9:22	9:37	0:15	MAIN SUPPLY FAILURE
405	20-Dec-18	HASSAN	110	HIRIYADKA-MADHUVANA	HIRIYADKA_110	9:22	9:37	0:15	MAIN SUPPLY FAILURE
406	20-Dec-18	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	9:23	14:38	5:15	MAIN SUPPLY FAILURE
407	20-Dec-18	HASSAN	110	HOSANGD-HULIKAL	HOSANGADI_110	9:23	14:38	5:15	MAIN SUPPLY FAILURE
408	20-Dec-18	HASSAN	110	HV1	HOSANGADI_110	9:23	14:38	5:15	MAIN SUPPLY FAILURE
409	20-Dec-18	HASSAN	110	HV2	HOSANGADI_110	9:23	14:38	5:15	MAIN SUPPLY FAILURE
410	20-Dec-18	HASSAN	110	HOSANGADI-VTRG1	HOSANGADI_110	9:23	14:38	5:15	MAIN SUPPLY FAILURE
411	20-Dec-18	HASSAN	110	HOSANGADI-VTRG2	HOSANGADI_110	9:23	14:38	5:15	MAIN SUPPLY FAILURE
412	20-Dec-18	HASSAN	110	HV1	NAVUNDA_110	9:23	9:40	0:17	LINE CLEAR AVAILED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
413	20-Dec-18	HASSAN	110	HV2	NAVUNDA_110	9:43	14:20	4:37	LINE CLEAR AVAILED
414	20-Dec-18	HASSAN	110	PUTTUR-SLTR	PUTTUR_110	9:40	13:30	3:50	LINE CLEAR AVAILED
415	20-Dec-18	HASSAN	110	PUTTUR-VITLA	PUTTUR_110	9:40	14:30	4:50	LINE CLEAR AVAILED
416	20-Dec-18	HASSAN	110	HV1	KONAJE_110	9:05	9:10	0:05	HAND TRIPPED
417	20-Dec-18	HASSAN	110	HV2	KONAJE_110	9:05	9:10	0:05	HAND TRIPPED
418	20-Dec-18	HASSAN	110	HV3	KONAJE_110	9:05	9:10	0:05	HAND TRIPPED
419	20-Dec-18	HASSAN	110	HV1	KONAJE_110	14:40	14:45	0:05	HAND TRIPPED
420	20-Dec-18	HASSAN	110	HV2	KONAJE_110	14:40	14:45	0:05	HAND TRIPPED
421	20-Dec-18	HASSAN	110	HV3	KONAJE_110	14:40	14:45	0:05	HAND TRIPPED
422	20-Dec-18	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:09	17:08	9:59	NBFC ISSUED
423	20-Dec-18	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	12:55	15:03	2:08	NBFC ISSUED
424	20-Dec-18	HASSAN	66	HV1	ALDUR_66	12:59	15:03	2:04	NBFC ISSUED
425	20-Dec-18	HASSAN	66	HV1	ARAKALGUD_66	12:43	12:56	0:13	LINE CLEAR AVAILED
426	20-Dec-18	HASSAN	66	HV2	BAGUR_66	7:22	19:08	11:46	LINE CLEAR AVAILED
427	20-Dec-18	HASSAN	66	CHIKMAGLUR-L1-ALDUR	CHIKMAGLUR_66	12:51	15:00	2:09	LINE CLEAR AVAILED
428	20-Dec-18	HASSAN	66	HV1	DODDAKADNUR_66	11:00	14:55	3:55	LINE CLEAR AVAILED
429	20-Dec-18	HASSAN	66	HASSAN20-ARAKALGUD	HASSN_220	10:40	11:21	0:41	LINE CLEAR AVAILED
430	20-Dec-18	HASSAN	66	LV1	HASSN_220	10:41	11:20	0:39	LINE CLEAR AVAILED
431	20-Dec-18	HASSAN	66	HASSAN220-R R NAGAR	HASSN_220	10:39	11:20	0:41	LINE CLEAR AVAILED
432	20-Dec-18	HASSAN	66	HV2	RAMESHWARNAGAR_66	10:48	12:17	1:29	LINE CLEAR AVAILED
433	20-Dec-18	HASSAN	66	SALAGME-HIREMANGLUR	SALAGAM_66	11:25	11:30	0:05	NBFC ISSUED
434	20-Dec-18	MYSORE	66	HV1	AKKIHEBBAL_66	12:57	14:25	1:27	LINE CLEAR AVAILED
435	20-Dec-18	MYSORE	66	HV1	AKKIHEBBAL_66	15:15	15:39	0:24	LINE CLEAR AVAILED
436	20-Dec-18	MYSORE	66	HV2	AKKIHEBBAL_66	12:02	13:50	1:47	LINE CLEAR AVAILED
437	20-Dec-18	MYSORE	66	FTS-BANNIMANTAPA	BANNIMANTAP_66	10:02	16:25	6:22	NBFC ISSUED
438	20-Dec-18	MYSORE	66	HV1	HEBBAL_66	10:01	18:17	8:16	LINE CLEAR AVAILED
439	20-Dec-18	MYSORE	66	HV2	HEBBAL_66	10:01	18:18	8:16	LINE CLEAR AVAILED
440	20-Dec-18	MYSORE	66	HV1	KHBCOLONY_66	16:45	23:59	7:14	LINE CLEAR AVAILED
441	20-Dec-18	MYSORE	66	HV1	KOPPA_66	10:02	17:01	6:58	LINE CLEAR AVAILED
442	20-Dec-18	MYSORE	66	HV2	KOPPA_66	10:03	17:02	6:59	LINE CLEAR AVAILED
443	20-Dec-18	MYSORE	66	HV2	KRPET_66	14:59	15:03	0:04	LINE CLEAR AVAILED
444	20-Dec-18	MYSORE	66	HV1	METAGALLY_66	10:02	17:35	7:33	LINE CLEAR AVAILED
445	20-Dec-18	MYSORE	66	HV2	METAGALLY_66	9:08	17:35	8:27	LINE CLEAR AVAILED
446	20-Dec-18	MYSORE	66	PANNIYADAHUNDI-DEVNUR(N'GUD)	KARYA_66	11:50	17:17	5:27	NBFC ISSUED
447	20-Dec-18	MYSORE	66	HV2	PANDYADAHUNDI_66	14:40	15:37	0:57	LINE CLEAR AVAILED
448	20-Dec-18	MYSORE	66	RK NAGARA-DATTAGALLI	RKNAGARA_66	9:53	23:59	14:05	LINE CLEAR AVAILED
449	20-Dec-18	MYSORE	66	RK NAGARA-KADAKOLA	RKNAGARA_66	10:18	17:44	7:25	LINE CLEAR AVAILED
450	20-Dec-18	MYSORE	66	HV1	VIJAYANAGRAMYS_66	17:03	17:08	0:04	HAND TRIPPED
451	20-Dec-18	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	2:18	2:27	0:09	HAND TRIPPED
452	20-Dec-18	TUMKUR	110	TR-2	SAMPIGE_110	10:19	10:28	0:08	TRANSFORMER FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
453	20-Dec-18	TUMKUR	66	BELLAVI-ANTHRASANAHALLI	BELLAVI_66	12:50	13:39	0:49	LINE CLEAR AVAILED
454	20-Dec-18	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	9:52	13:20	3:27	HAND TRIPPED
455	20-Dec-18	TUMKUR	66	TR-1	DEVARAHALLI_66	9:52	13:20	3:27	HAND TRIPPED
456	20-Dec-18	TUMKUR	66	TR-1	DAVANGERE_SRS_220	10:00	17:26	7:25	LINE CLEAR AVAILED
457	20-Dec-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:34	17:40	9:05	LINE CLEAR AVAILED
458	20-Dec-18	TUMKUR	66	TR-3	HOLALKERE_66	9:59	10:02	0:03	HAND TRIPPED
459	20-Dec-18	TUMKUR	66	TR-3	HOLALKERE_66	10:19	11:50	1:30	HAND TRIPPED
460	20-Dec-18	TUMKUR	66	TR-3	HOLALKERE_66	16:53	16:57	0:03	HAND TRIPPED
461	20-Dec-18	TUMKUR	66	TR-2 (LV SIDE)	HONNALLI_220	11:27	13:03	1:35	LINE CLEAR AVAILED
462	20-Dec-18	TUMKUR	66	TR-1	TUMKUR_66	10:40	12:46	2:06	TRANSFORMER FAULT
463	20-Dec-18	TUMKUR	66	TR-1	MYLANAHALLI_66	18:00	18:10	0:09	LINE CLEAR AVAILED
464	21-Dec-18	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	11:00	11:23	0:23	LOAD CURTAILMENT
465	21-Dec-18	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	10:55	17:39	6:44	LINE CLEAR AVAILED
466	21-Dec-18	BAGALKOT	110	ATHANI220-BALLIGERE(TAUSHI)	BALLIGERE(TAUSHI)_110	19:06	19:18	0:12	LINE FAULT
467	21-Dec-18	BAGALKOT	110	KNI SOLAR-ATHARGA	ATHARGA_110, KNI SOLAR_IPP	18:07	19:19	1:12	MAIN SUPPLY FAILURE
468	21-Dec-18	BAGALKOT	110	110/11KV,HV1	GADAG_110	13:42	14:02	0:20	TRANSFORMER FAULT
469	21-Dec-18	BAGALKOT	110	110/11KV,HV1	KUD DHARAWAD_110	13:50	16:39	2:49	LINE CLEAR AVAILED
470	21-Dec-18	BAGALKOT	110	BELGAUM SOLAR-MAMADAPUR(B)	MAMADAPUR(B)_110	18:04	19:48	1:44	LINE CLEAR AVAILED
471	21-Dec-18	BAGALKOT	110	110/33KV,HV2	MATTIHAL_110	23:27	23:29	0:02	TRANSFORMER FAULT
472	21-Dec-18	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	8:00	8:38	0:38	LOAD CURTAILMENT
473	21-Dec-18	BAGALKOT	110	110/33KV,HV1	HANGAL_110,PALA_33	8:00	8:23	0:23	LOAD CURTAILMENT
474	21-Dec-18	BAGALKOT	110	110/33KV, HV3	ZALKI_110, HORTI_33	11:51	11:57	0:06	TRANSFORMER FAULT
475	21-Dec-18	BAGALKOT	110	110/11KV, HV1	ZALKI_110	14:38	16:50	2:12	LINE CLEAR AVAILED
476	21-Dec-18	BAGALKOT	110	110/33KV, HV3	TILUVALLI_110, KALIKERI_33, SHESHGIRI_33, KMML_33	14:27	15:00	0:33	LINE CLEAR AVAILED
477	21-Dec-18	BAGALKOT	110	110/11KV, HV2	TILUVALLI_110	14:26	14:52	0:26	LINE CLEAR AVAILED
478	21-Dec-18	BAGALKOT	110	HUBLI220-TARIHAL2	TARIHAL_110	15:05	23:59	8:54	LINE FAULT
479	21-Dec-18	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	13:06	13:13	0:07	LINE CLEAR AVAILED
480	21-Dec-18	BAGALKOT	110	110/33KV, HV2	SAVALAGI_110,HIREPADASALGI_33, KALBILGI_33, TUNGAL LIS_33	7:50	8:39	0:49	LOAD CURTAILMENT
481	21-Dec-18	BANGALORE	66	HV1	ANDERSONPET	12:04	16:06	4:02	LINE CLEAR AVAILED
482	21-Dec-18	BANGALORE	66	HV2	ANDERSONPET	12:04	14:59	2:55	LINE CLEAR AVAILED
483	21-Dec-18	BANGALORE	66	HV2	ANDERSONPET	16:10	17:13	1:03	LINE CLEAR AVAILED
484	21-Dec-18	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	12:09	13:03	0:53	LINE CLEAR AVAILED
485	21-Dec-18	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSEHANAHALLI, CHEEMANGALA	13:53	13:59	0:05	LINE FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
486	21-Dec-18	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSEHANAHALLI, CHEEMANGALA	14:13	18:24	4:11	LINE CLEAR AVAILED
487	21-Dec-18	BANGALORE	66	HV1	T BEGUR	12:40	12:45	0:04	LINE CLEAR AVAILED
488	21-Dec-18	BANGALORE	66	HV2	T BEGUR	14:31	14:35	0:03	LINE CLEAR AVAILED
489	21-Dec-18	BANGALORE	66	DALASANUR - SRINIVASPURA	YELDUR	12:07	15:41	3:33	LINE CLEAR AVAILED
490	21-Dec-18	BANGALORE	66	AUSTIN TOWN - EDC 220	AUSTIN TOWN	9:54	10:47	0:53	MAIN SUPPLY FAILURE
491	21-Dec-18	BANGALORE	66	AUSTIN TOWN - KORAMANGALA	KORAMANGALA	9:54	10:41	0:47	LINE FAULT
492	21-Dec-18	BANGALORE	66	AUSTIN TOWN - HSR LAYOUT	AUSTIN TOWN	11:26	11:35	0:09	LOAD CHANGE OVER
493	21-Dec-18	BANGALORE	66	KORAMANGALA-ADUGODI	KORAMANGALA	12:58	13:22	0:24	MAIN SUPPLY FAILURE
494	21-Dec-18	BANGALORE	66	BMTC-EDC 220	BMTC	9:53	10:39	0:46	MAIN SUPPLY FAILURE
495	21-Dec-18	BANGALORE	66	BMTC-EDC 220	BMTC	12:56	13:23	0:27	MAIN SUPPLY FAILURE
496	21-Dec-18	BANGALORE	220	HV2	EDC 220	9:53	10:52	0:59	TRANSFORMER FAULT
497	21-Dec-18	BANGALORE	220	KHODAYS 220-SOMANAHALLI 220	KHODAYS 220	15:05	15:08	0:03	LINE FAULT
498	21-Dec-18	BANGALORE	220	KHODAYS 220 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 220	15:05	15:15	0:10	MAIN SUPPLY FAILURE
499	21-Dec-18	BANGALORE	220	HV1	KHODAYS 220	15:05	15:09	0:04	MAIN SUPPLY FAILURE
500	21-Dec-18	BANGALORE	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	15:05	15:13	0:08	MAIN SUPPLY FAILURE
501	21-Dec-18	BANGALORE	66	KHODAYS 220 - ELITA PROMENEDE	ELITA PROMENEDE, RBI	15:05	15:14	0:09	MAIN SUPPLY FAILURE
502	21-Dec-18	BANGALORE	220	NIMHANS 220 - EDC 220	EDC 220	9:53	11:03	1:10	LINE FAULT
503	21-Dec-18	BANGALORE	66	NIMHANS 220 - JAYADEVA	JAYADEVA	12:56	13:19	0:23	MAIN SUPPLY FAILURE
504	21-Dec-18	BANGALORE	66	NIMHANS 220 - JAYANAGARA	JAYANAGARA, NATIONAL COLLEGE	12:56	13:19	0:23	MAIN SUPPLY FAILURE
505	21-Dec-18	BANGALORE	66	NIMHANS 220 - ADUGODI	ADUGODI, BOSCH (EHT)	12:56	13:18	0:22	MAIN SUPPLY FAILURE
506	21-Dec-18	BANGALORE	220	HSR LAYOUT 220 - NIMHANS 220	NIMHANS 220, EDC 220	12:53	13:14	0:21	LINE FAULT
507	21-Dec-18	BANGALORE	220	SUBRAMANYAPURA 220 - KHODAYS 220	SUBRAMANYAPURA 220	15:05	15:15	0:10	MAIN SUPPLY FAILURE
508	21-Dec-18	BANGALORE	66	SUBRAMANYAPURA 220 - PADMANABHANAGAR	PADMANABHANAGAR	15:05	15:17	0:12	MAIN SUPPLY FAILURE
509	21-Dec-18	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	15:05	15:30	0:25	MAIN SUPPLY FAILURE
510	21-Dec-18	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT),RR NAGAR	15:05	15:20	0:15	MAIN SUPPLY FAILURE
511	21-Dec-18	BANGALORE	66	SUBRAMANYAPURA 220 - SARAKKI 1 & 2	ISRO LAYOUT,SARAKKI	15:05	15:18	0:13	MAIN SUPPLY FAILURE
512	21-Dec-18	BANGALORE	66	A STATION 220 - A STATION 66	A STATION 66	12:56	12:57	0:01	LOAD CHANGE OVER
513	21-Dec-18	GULBARGA	220	HV1	HALBURGA_220	8:20	13:20	5:00	LINE CLEAR AVAILED
514	21-Dec-18	GULBARGA	220	RTPS-SHAHAPUR2	SHAHPUR_220	3:12	7:20	4:08	LINE FAULT
515	21-Dec-18	GULBARGA	220	HV2	HUMNABAD_220	17:55	18:25	0:30	TRANSFORMER FAULT
516	21-Dec-18	GULBARGA	220	HUMNABAD-HALBARGA1	HALBARGA_220	16:20	23:59	7:39	LINE CLEAR AVAILED
517	21-Dec-18	GULBARGA	220	HV2	HALBARGA_220	13:24	17:40	4:16	LINE CLEAR AVAILED
518	21-Dec-18	GULBARGA	110	GURGUNTA-LJVL_IPP	GURGUNTA_110	10:25	14:20	3:55	LINE CLEAR AVAILED
519	21-Dec-18	GULBARGA	110	GURGUNTA-KHEL_IPP	GURGUNTA_110	10:25	14:20	3:55	LINE CLEAR AVAILED
520	21-Dec-18	GULBARGA	110	HV4	YELBURGA_110	8:02	8:42	0:40	LOAD CURTAILMENT



Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
521	21-Dec-18	GULBARGA	110	STAR_METALLIC-MUNIRABAD	MUNIRABAD_220	10:29	10:50	0:21	LINE FAULT
522	21-Dec-18	GULBARGA	110	KEMBHAV-UGAR SUGUR_IPP	KEMBHAVI_110	19:15	19:20	0:05	LINE FAULT
523	21-Dec-18	HASSAN	220	HASSAN220-Shomoga	HASSN220	14:30	14:35	0:05	HAND TRIPPED
524	21-Dec-18	HASSAN	110	BANTWA-KAVOOR	BANTWA_110	10:12	10:16	0:04	HAND TRIPPED
525	21-Dec-18	HASSAN	110	KAVOOR- EMAR	KAVOOR_220	10:13	10:17	0:04	HAND TRIPPED
526	21-Dec-18	HASSAN	110	HV3	MRSMSG_220	13:19	13:38	0:19	HAND TRIPPED
527	21-Dec-18	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	15:13	15:18	0:05	LINE FAULT
528	21-Dec-18	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	16:30	16:34	0:04	LINE FAULT
529	21-Dec-18	HASSAN	66	LV3	MRSMSG_220	13:19	13:38	0:19	HAND TRIPPED
530	21-Dec-18	HASSAN	66	HV2	BAGUR_66	10:56	12:30	1:34	LINE CLEAR AVAILED
531	21-Dec-18	HASSAN	66	BYARAPU-BAGUR	K.BYARAPURA_66	22:50	23:00	0:10	LOAD CURTAILMENT
532	21-Dec-18	HASSAN	66	HV1	HARIHARPURA_66	10:00	13:11	3:11	LINE CLEAR AVAILED
533	21-Dec-18	HASSAN	66	HARIHAR-KADUVINKOTE	HARIHARPURA_66	10:00	13:11	3:11	LINE CLEAR AVAILED
534	21-Dec-18	HASSAN	66	HNPR2-S.BELGOLA2	HNPURA_220	12:10	19:20	7:10	LINE CLEAR AVAILED
535	21-Dec-18	HASSAN	66	HV2	RAMPUR	6:40	7:50	1:10	LINE CLEAR AVAILED
536	21-Dec-18	MYSORE	66	HV2	BANNUR_66	12:35	12:40	0:05	TRANSFORMER FAULT
537	21-Dec-18	MYSORE	66	HV2	BETTADHAPURA_66	17:16	17:54	0:38	LINE CLEAR AVAILED
538	21-Dec-18	MYSORE	66	BYLUKUPPA-KUSHALANAGAR 220	BYLUKUPPE_66	11:17	13:18	2:00	LINE CLEAR AVAILED
539	21-Dec-18	MYSORE	66	HV1	CHINAKURALI_66	18:43	19:03	0:20	LINE CLEAR AVAILED
540	21-Dec-18	MYSORE	66	DEVNUR(N'GUD)-PANYADAHUNDI	HEMMARGALA_66 KARYA_66	15:30	17:12	1:41	LINE CLEAR AVAILED
541	21-Dec-18	MYSORE	66	HV1	DUNDANAHALLI_66	10:00	17:20	7:20	LINE CLEAR AVAILED
542	21-Dec-18	MYSORE	66	HV2	DUNDANAHALLI_66	10:00	17:20	7:20	LINE CLEAR AVAILED
543	21-Dec-18	MYSORE	66	HV1	HANAGODU_66	18:01	18:09	0:08	HAND TRIPPED
544	21-Dec-18	MYSORE	66	HV2	HANAGODU_66	18:12	18:15	0:03	HAND TRIPPED
545	21-Dec-18	MYSORE	66	HV2	HAMPAPURA(K)_66	10:35	17:55	7:20	LINE CLEAR AVAILED
546	21-Dec-18	MYSORE	66	HV1	HAMPAPURA(K)_66	10:25	23:59	13:34	LINE CLEAR AVAILED
547	21-Dec-18	MYSORE	66	HV1	KIADBMANDYA_66	17:54	18:12	0:17	TRANSFORMER FAULT
548	21-Dec-18	MYSORE	66	HV2	KMDODDI_66	7:12	8:38	1:26	TRANSFORMER FAULT
549	21-Dec-18	MYSORE	66	HV2	KMDODDI_66	8:50	9:00	0:10	TRANSFORMER FAULT
550	21-Dec-18	MYSORE	66	HV2	KRPET_220	14:51	15:32	0:40	LINE CLEAR AVAILED
551	21-Dec-18	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	17:53	17:58	0:05	LINE FAULT
552	21-Dec-18	TUMKUR	400	TR-2(HV SIDE )	GUTTUR_400	10:29	16:28	5:59	LINE CLEAR AVAILED
553	21-Dec-18	TUMKUR	110	HONNAVALI 110-DMKURKE	DMKURKE_110	10:49	11:43	0:54	LINE CLEAR AVAILED
554	21-Dec-18	TUMKUR	110	TURUVEKERE110-KBCROSS	TURUVEKERE_110	9:59	10:03	0:03	MAIN SUPPLY FAILURE
555	21-Dec-18	TUMKUR	110	TURUVEKERE110-KBCROSS	TURUVEKERE_110	16:31	16:46	0:14	MAIN SUPPLY FAILURE

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
556	21-Dec-18	TUMKUR	66	TR-2	BEVINAHALLI_66	8:25	9:59	1:33	LINE CLEAR AVOIDED
557	21-Dec-18	TUMKUR	66	TR-2	BEVINAHALLI_66	11:58	12:53	0:54	TRANSFORMER FAULT
558	21-Dec-18	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	11:40	12:05	0:24	LINE CLEAR AVOIDED
559	21-Dec-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:36	17:05	8:28	LINE CLEAR AVOIDED
560	21-Dec-18	TUMKUR	66	TR-1	HANAGAL_66	9:58	10:04	0:05	LINE CLEAR AVOIDED
561	21-Dec-18	TUMKUR	66	TR-2	HIREGUNTANUR_66	12:17	12:18	0:01	TRANSFORMER FAULT
562	21-Dec-18	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	CHIKKAJAJUR_66,MAYAKONDA_66,SAS ALUHALLA_66	17:11	17:28	0:17	HAND TRIPPED
563	21-Dec-18	TUMKUR	66	TR-2	HONNALI_66	12:37	13:02	0:24	TRANSFORMER FAULT
564	21-Dec-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	16:15	16:27	0:12	LINE FAULT
565	21-Dec-18	TUMKUR	66	TR-2	KUKKAWADA_66	11:32	11:41	0:08	TRANSFORMER FAULT
566	21-Dec-18	TUMKUR	66	TR-2	MANGALWADA_66	15:42	15:45	0:02	TRANSFORMER FAULT
567	21-Dec-18	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	13:19	14:47	1:27	LINE CLEAR AVOIDED
568	21-Dec-18	TUMKUR	66	MAYAKONDA- ANGODU	MAYAKONDA_66, SASALUHALLA_66, CHIKKAJAJUR_66	15:08	18:36	3:27	HAND TRIPPED
569	21-Dec-18	TUMKUR	66	TAVAREKERE (H)- PATTNAYAKANAHALLI	PATTANAYAKANAHALLI_66	14:33	14:34	0:01	LINE FAULT
570	22-Dec-18	BAGALKOT	220	PONDA 1-AMBEWADI	AMBEWADI_220	2:18	3:00	0:42	LINE FAULT
571	22-Dec-18	BAGALKOT	220	PONDA 2-AMBEWADI	AMBEWADI_220	10:50	23:59	13:09	LINE CLEAR AVOIDED
572	22-Dec-18	BAGALKOT	220	PONDA 1-AMBEWADI	AMBEWADI_220	11:05	18:00	6:55	HAND TRIPPED
573	22-Dec-18	BAGALKOT	110	110/11KV,HV-2	AMBEWADI_220	9:27	13:15	3:48	HAND TRIPPED
574	22-Dec-18	BAGALKOT	110	110/11KV,HV-2	BEDI_110	14:08	17:04	2:56	HAND TRIPPED
575	22-Dec-18	BAGALKOT	220	ALMATTI2-BAGALKOT	BAGALKOT_220	14:59	17:18	2:19	LINE CLEAR AVOIDED
576	22-Dec-18	BAGALKOT	110	110/33KV,HV-2	HUNGUND_110,KARADI_33,AMINGAD_ 33,KUDALASNGAMA_33	10:59	15:45	4:46	LINE CLEAR AVOIDED
577	22-Dec-18	BAGALKOT	110	HUNGUND-JINDAL	HUNGUND_110	11:00	14:38	3:38	LINE CLEAR AVOIDED
578	22-Dec-18	BAGALKOT	110	HUNGUND-KPJNL	HUNGUND_110	11:00	14:38	3:38	LINE CLEAR AVOIDED
579	22-Dec-18	BAGALKOT	110	220/110KV,LV3	MAHALINGAPUR_220	13:48	14:17	0:29	TRANSFORMER FAULT
580	22-Dec-18	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	14:12	14:32	0:20	HAND TRIPPED
581	22-Dec-18	BAGALKOT	110	KUDUCHI220-YELPARATTI	YELLAPARHATTI_110	15:06	15:50	0:44	HAND TRIPPED
582	22-Dec-18	BAGALKOT	110	HUBLI220-TARIHAL2	TARIHAL_110	0:00	13:59	13:59	LINE CLEAR AVOIDED
583	22-Dec-18	BAGALKOT	110	HUBLI220-TARIHAL1	TARIHAL_110	10:37	13:58	3:21	LINE CLEAR AVOIDED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
584	22-Dec-18	BAGALKOT	110	110/11KV,HV2	SHIROL_110	17:46	18:00	0:14	LINE CLEAR AVAILED
585	22-Dec-18	BANGALORE	66	HV1	AREHALLI	15:52	16:08	0:16	LINE CLEAR AVAILED
586	22-Dec-18	BANGALORE	66	BOODIGERE-BEGUR 220	BOODIGERE	12:05	12:14	0:09	MAIN SUPPLY FAILURE
587	22-Dec-18	BANGALORE	66	HV1	DEVARABISANAHALLI	13:42	14:11	0:29	LINE CLEAR AVAILED
588	22-Dec-18	BANGALORE	66	HV1	IISc	11:47	11:54	0:07	LOAD CHANGE OVER
589	22-Dec-18	BANGALORE	66	HV1	JAYANAGARA	12:47	12:50	0:03	LOAD CHANGE OVER
590	22-Dec-18	BANGALORE	66	HV2	KADUGODI	14:05	15:18	1:13	LINE CLEAR AVAILED
591	22-Dec-18	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBELE, KODIHALLI, HUNSENAHALLI, HUKUNDA	7:21	7:33	0:12	LINE FAULT
592	22-Dec-18	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBELE, KODIHALLI, HUNSENAHALLI, HUKUNDA	8:02	8:10	0:08	LINE FAULT
593	22-Dec-18	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBELE, KODIHALLI, HUNSENAHALLI, HUKUNDA	8:16	8:39	0:23	LINE CLEAR AVAILED
594	22-Dec-18	BANGALORE	66	HV1	PRESTIGE SHANTINIKETHAN	12:13	13:39	1:26	LINE CLEAR AVAILED
595	22-Dec-18	BANGALORE	66	T K HALLI-MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:19	15:39	0:20	LINE CLEAR AVAILED
596	22-Dec-18	BANGALORE	66	T K HALLI-MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	22:14	22:35	0:21	LINE FAULT
597	22-Dec-18	BANGALORE	220	YARANDANAHALLI 220 - HOSUR 220	TOI(EHT)	1:03	1:43	0:40	LINE FAULT
598	22-Dec-18	BANGALORE	66	HV1	YARANDANAHALLI	1:03	1:54	0:51	MAIN SUPPLY FAILURE
599	22-Dec-18	BANGALORE	66	HV2	YARANDANAHALLI	1:03	1:54	0:51	MAIN SUPPLY FAILURE
600	22-Dec-18	BANGALORE	66	HV3	YARANDANAHALLI	1:03	1:54	0:51	MAIN SUPPLY FAILURE
601	22-Dec-18	BANGALORE	66	HV1	ANDERSONPET	14:20	14:42	0:21	LINE CLEAR AVAILED
602	22-Dec-18	BANGALORE	66	HV2	ANDERSONPET	14:20	14:42	0:21	LINE CLEAR AVAILED
603	22-Dec-18	BANGALORE	66	BOODIGERE - BEGUR 220	BOODIGERE	12:04	12:16	0:11	MAIN SUPPLY FAILURE
604	22-Dec-18	BANGALORE	66	BEGUR 220 - BIAL	BIAL	12:04	12:16	0:11	MAIN SUPPLY FAILURE
605	22-Dec-18	BANGALORE	220	HV1	BEGUR 220	12:04	12:16	0:11	MAIN SUPPLY FAILURE
606	22-Dec-18	BANGALORE	220	HV2	BEGUR 220	12:04	12:16	0:11	MAIN SUPPLY FAILURE
607	22-Dec-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	12:04	12:19	0:14	MAIN SUPPLY FAILURE
608	22-Dec-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	12:04	12:19	0:14	MAIN SUPPLY FAILURE
609	22-Dec-18	BANGALORE	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	12:04	12:19	0:14	MAIN SUPPLY FAILURE
610	22-Dec-18	BANGALORE	66	HOSKOTE 220 - SULIBELE	SULIBELE	12:04	12:19	0:14	MAIN SUPPLY FAILURE
611	22-Dec-18	BANGALORE	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	12:04	12:19	0:14	MAIN SUPPLY FAILURE
612	22-Dec-18	BANGALORE	220	HV1	HOSKOTE 220	12:04	12:17	0:12	MAIN SUPPLY FAILURE
613	22-Dec-18	BANGALORE	220	HV2	HOSKOTE 220	12:04	12:17	0:12	MAIN SUPPLY FAILURE
614	22-Dec-18	BANGALORE	66	CHELUR - YENNIGADALE	CHELUR	10:48	14:31	3:43	LINE CLEAR AVAILED
615	22-Dec-18	BANGALORE	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	10:46	14:25	3:39	LINE CLEAR AVAILED
616	22-Dec-18	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	16:14	16:22	0:07	LINE FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
617	22-Dec-18	BANGALORE	66	MALUR 220 - HOSKOTE 1	JADIGENAHALLI, MALUR I/A	6:33	6:37	0:03	LINE FAULT
618	22-Dec-18	BANGALORE	66	MALUR 220 - HOSKOTE 1	JADIGENAHALLI, MALUR I/A	7:59	8:10	0:10	LINE FAULT
619	22-Dec-18	BANGALORE	66	MALUR 220 - HOSKOTE 1	JADIGENAHALLI, MALUR I/A	8:19	12:38	4:19	LINE FAULT
620	22-Dec-18	BANGALORE	66	HV2	NANGALI	15:06	15:18	0:11	TRANSFORMER FAULT
621	22-Dec-18	BANGALORE	66	HV2	SOMAYAJJANAHALLI	9:00	9:21	0:20	LINE CLEAR AVAILED
622	22-Dec-18	BANGALORE	66	DB PURA 220 - DG 1	AIR (EHT)	11:21	12:53	1:32	LINE CLEAR AVAILED
623	22-Dec-18	BANGALORE	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:21	12:53	1:32	LINE CLEAR AVAILED
624	22-Dec-18	BANGALORE	220	DB PURA 220 - BIAL 220	BEGUR 220	12:04	12:16	0:11	LINE FAULT
625	22-Dec-18	BANGALORE	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	19:30	19:35	0:05	LOAD CHANGE OVER
626	22-Dec-18	BANGALORE	66	THIMMAMPALLI - BAGEPALLI	THIMMAMPALLI	9:50	14:20	4:30	LINE CLEAR AVAILED
627	22-Dec-18	BANGALORE	66	HV2	THIMMAMPALLI	14:32	14:34	0:01	LOAD CHANGE OVER
628	22-Dec-18	GULBARGA	220	HUMNABAD-HALBARGA1	HALBURGA_220	0:00	14:50	14:50	LINE CLEAR AVAILED
629	22-Dec-18	GULBARGA	220	KAPNOOR-SHAHABAD	KAPNOOR_220	6:16	6:48	0:32	LINE FAULT
630	22-Dec-18	GULBARGA	220	HV1	KUSTAGI_220	4:05	4:43	0:38	TRANSFORMER FAULT
631	22-Dec-18	GULBARGA	220	HV1	KUSTAGI_220	6:30	6:42	0:12	TRANSFORMER FAULT
632	22-Dec-18	GULBARGA	110	HALBURGA-SANTHAPUR	DONGRAGOA_110,KAMALANAGAR_110,SANTHAPUR_110	11:15	11:18	0:03	LINE FAULT
633	22-Dec-18	GULBARGA	110	HALBURGA-SANTHAPUR	DONGRAGOA_110,KAMALANAGAR_110,SANTHAPUR_110	11:35	11:54	0:19	LINE FAULT
634	22-Dec-18	GULBARGA	110	HV2	KOLHAR_110	11:35	12:05	0:30	LINE CLEAR AVAILED
635	22-Dec-18	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	16:53	17:02	0:09	LINE FAULT
636	22-Dec-18	GULBARGA	110	KOLHAR-NSSK	JANAWADA_110	11:23	17:11	5:48	NBFC ISSUED
637	22-Dec-18	GULBARGA	110	HV1	KOLHAR_110	16:10	16:30	0:20	LINE CLEAR AVAILED
638	22-Dec-18	GULBARGA	110	KOLHAR-SHAHI SOLAR	KOLHAR_110	12:50	19:45	6:55	LINE CLEAR AVAILED
639	22-Dec-18	GULBARGA	110	PDHALLI-CLNSLR	PD_HALLI_110	19:10	19:18	0:08	LINE FAULT
640	22-Dec-18	GULBARGA	110	HV2	KAMPLI_GLB_110	15:45	18:04	2:19	LINE CLEAR AVAILED
641	22-Dec-18	GULBARGA	66	ITTAGGI-HUVINAHADAGALLI	HUVINA_HADAGALLI_66	0:27	0:37	0:10	LINE FAULT
642	22-Dec-18	GULBARGA	66	LV1	ITTAGI_220	17:58	18:50	0:52	LOAD CHANGE OVER
643	22-Dec-18	GULBARGA	66	ITTAGGI-KUDLIGI1	KOGALI_66,KUDLIGI_66	17:52	18:05	0:13	LINE FAULT
644	22-Dec-18	HASSAN	220	ARSK2-HSN	ARSIKERE_220	13:58	15:09	1:11	NBFC ISSUED
645	22-Dec-18	HASSAN	110	HV2	HIRIYADKA_110	2:16	2:19	0:03	TRANSFORMER FAULT
646	22-Dec-18	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:39	16:51	6:12	LINE CLEAR AVAILED
647	22-Dec-18	HASSAN	110	MANIPAL-BRAMVR	KONAJE_110	8:31	18:18	9:47	LINE CLEAR AVAILED
648	22-Dec-18	HASSAN	110	HV1	MRSMSG_220	9:24	14:38	5:14	LINE CLEAR AVAILED
649	22-Dec-18	HASSAN	110	HV2	MRSMSG_220	9:25	14:39	5:14	LINE CLEAR AVAILED
650	22-Dec-18	HASSAN	110	HV3	MRSMSG_220	9:24	14:39	5:15	LINE CLEAR AVAILED
651	22-Dec-18	HASSAN	110	HV4	MRSMSG_220	9:24	14:39	5:15	LINE CLEAR AVAILED
652	22-Dec-18	HASSAN	110	HV2	NERALAKERE_110	12:25	12:30	0:05	HAND TRIPPED
653	22-Dec-18	HASSAN	110	NERALA-TEREKERE	NERALAKERE_110	10:14	12:39	2:25	LINE CLEAR AVAILED
654	22-Dec-18	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	11:04	14:01	2:57	LINE CLEAR AVAILED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
655	22-Dec-18	HASSAN	110	HV1	SALATHUR_110	10:35	12:02	1:27	LINE CLEAR AVAILED
656	22-Dec-18	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	11:05	12:02	0:57	LINE CLEAR AVAILED
657	22-Dec-18	HASSAN	66	LV1	MRSMSG_220	9:22	14:41	5:19	LINE CLEAR AVAILED
658	22-Dec-18	HASSAN	66	LV2	MRSMSG_220	10:53	14:41	3:48	LINE CLEAR AVAILED
659	22-Dec-18	HASSAN	66	LV3	MRSMSG_220	9:23	14:41	5:18	LINE CLEAR AVAILED
660	22-Dec-18	HASSAN	66	LV4	MRSMSG_220	9:23	14:41	5:18	LINE CLEAR AVAILED
661	22-Dec-18	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	9:22	14:59	5:37	LINE CLEAR AVAILED
662	22-Dec-18	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	9:19	15:00	5:41	LINE CLEAR AVAILED
663	22-Dec-18	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	9:18	14:47	5:29	LINE CLEAR AVAILED
664	22-Dec-18	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	9:17	14:46	5:29	LINE CLEAR AVAILED
665	22-Dec-18	HASSAN	66	HASSN22-HN PURA	HASSAN_220	12:10	13:36	1:26	LINE CLEAR AVAILED
666	22-Dec-18	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:13	18:26	11:13	LINE CLEAR AVAILED
667	22-Dec-18	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	4:01	4:05	0:04	LINE FAULT
668	22-Dec-18	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:22	10:56	1:34	LINE CLEAR AVAILED
669	22-Dec-18	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	10:07	13:41	3:34	LINE CLEAR AVAILED
670	22-Dec-18	HASSAN	66	HV1	BYACHANAHALLI_66	10:07	13:42	3:35	LINE CLEAR AVAILED
671	22-Dec-18	HASSAN	66	BYARAPU-BAGUR	BYARAPURA_66	4:00	4:05	0:05	MAIN SUPPLY FAILURE
672	22-Dec-18	HASSAN	66	HV1	HOLALUR_66	9:31	14:49	5:18	MAIN SUPPLY FAILURE
673	22-Dec-18	HASSAN	66	HV2	HOLALUR_66	9:31	14:49	5:18	MAIN SUPPLY FAILURE
674	22-Dec-18	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	8:06	18:46	10:40	LINE CLEAR AVAILED
675	22-Dec-18	HASSAN	66	RAMNAT-KUSALNAGARA	RAMNATHPURA_66	8:06	23:59	15:53	LINE CLEAR AVAILED
676	22-Dec-18	HASSAN	66	TAVAREC-MRS	TAVARECHANAHALLI_66	9:22	14:45	5:23	MAIN SUPPLY FAILURE
677	22-Dec-18	MYSORE	66	HV2	BETTADHAPURA_66	10:39	12:23	1:44	LINE CLEAR AVAILED
678	22-Dec-18	MYSORE	66	HV2	BETTADHAPURA_66	21:05	21:29	0:23	LINE CLEAR AVAILED
679	22-Dec-18	MYSORE	66	HV1	BGNAGARA_66	14:32	16:05	1:32	LINE CLEAR AVAILED
680	22-Dec-18	MYSORE	66	HV2	BGNAGARA_66	12:38	14:35	1:57	LINE CLEAR AVAILED
681	22-Dec-18	MYSORE	66	BYLUKUPPE-KUSHALANAGARA 220	BYLUKUPPE_66	14:28	16:34	2:06	NBFC ISSUED
682	22-Dec-18	MYSORE	66	HV1	HANNUR_66	15:27	15:56	0:28	LINE CLEAR AVAILED
683	22-Dec-18	MYSORE	66	HV2	HANNUR_66	15:27	15:56	0:28	LINE CLEAR AVAILED
684	22-Dec-18	MYSORE	66	HV1	JAKKANAHALLY_66	11:16	11:32	0:16	TRANSFORMER FAULT
685	22-Dec-18	MYSORE	66	KADAKOLA-SARGUR2	HURA_66, HULLAHALLI_66, DOORA_66	6:26	6:32	0:06	LINE FAULT
686	22-Dec-18	MYSORE	66	HV2	KHBCOLONY_66	17:15	19:15	2:00	LINE CLEAR AVAILED
687	22-Dec-18	MYSORE	66	HV1	KIADBMANDYA_66	15:22	15:39	0:16	HAND TRIPPED
688	22-Dec-18	MYSORE	66	HV2	KIADBMANDYA_66	15:22	15:39	0:17	HAND TRIPPED
689	22-Dec-18	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66 K_HONNALGERE_66	22:15	22:24	0:09	LINE FAULT
690	22-Dec-18	MYSORE	66	KM DODDI-TK HALLI	KMDODDI_66	9:15	15:50	6:35	LINE CLEAR AVAILED
691	22-Dec-18	MYSORE	66	KR PETE 220-BOOKANAKERE	BOOKANAKERE_66 SHEELUNERE_66 GANJIGERE_66 BANANGADI_66 CHINAKURALI_66	17:10	17:26	0:15	LINE FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
692	22-Dec-18	MYSORE	66	HV1	KUSHALNAGARA_220	10:37	18:18	7:40	LINE CLEAR AVAILED
693	22-Dec-18	MYSORE	220	KUSHALANAGARA 220-HV1	KUSHALNAGARA_220	10:18	17:37	7:18	LINE CLEAR AVAILED
694	22-Dec-18	MYSORE	220	KUSHALANAGARA 220-HV2	KUSHALNAGARA_220	10:40	17:37	6:57	LINE CLEAR AVAILED
695	22-Dec-18	MYSORE	66	KUSHALANAGARA 220-HV3	KUSHALNAGARA_220	10:37	18:18	7:40	LINE CLEAR AVAILED
696	22-Dec-18	MYSORE	66	HV4	KUSHALNAGARA_220	10:39	17:56	7:17	LINE CLEAR AVAILED
697	22-Dec-18	MYSORE	66	KUSHALANAGARA 220-MERCERA-1	MADIKERI_66 SUNTIKOPPA_66	10:36	17:52	7:15	LINE CLEAR AVAILED
698	22-Dec-18	MYSORE	66	KUSHALANAGARA 220-SUNTIKOPPA	MADIKERI_66 SUNTIKOPPA_66	10:36	17:58	7:21	LINE CLEAR AVAILED
699	22-Dec-18	MYSORE	66	KUSHALANAGARA 220-RAMANTHAPURA1	ALUR SIDDAPUR_66 KANAGAL_66	7:31	18:05	10:33	LINE CLEAR AVAILED
700	22-Dec-18	MYSORE	66	MIRLE-HOOTAGALLY	MIRLE_66	14:31	16:24	1:52	NBFC ISSUED
701	22-Dec-18	MYSORE	66	HV2	THALAKADU_66	19:44	19:51	0:06	HAND TRIPPED
702	22-Dec-18	MYSORE	66	HV1	THALAKADU_66	19:44	19:51	0:06	HAND TRIPPED
703	22-Dec-18	MYSORE	66	HV1	THALAKADU_66	23:27	23:33	0:06	HAND TRIPPED
704	22-Dec-18	MYSORE	66	HV2	THALAKADU_66	23:27	23:33	0:06	HAND TRIPPED
705	22-Dec-18	TUMKUR	220	TR-3(HV3	HIRIYUR_220	6:23	6:33	0:10	TRANSFORMER FAULT
706	22-Dec-18	TUMKUR	110	TR-3	AMMASANDRA_110	9:33	9:49	0:16	LINE CLEAR AVAILED
707	22-Dec-18	TUMKUR	110	TR-1	KALLUR_110	11:50	12:04	0:13	LINE CLEAR AVAILED
708	22-Dec-18	TUMKUR	110	TR-2	SAMPIGE_110	9:46	9:51	0:05	TRANSFORMER FAULT
709	22-Dec-18	TUMKUR	110	KALLUR- NITTUR	KALLUR_110	18:09	18:17	0:08	LINE CLEAR AVAILED
710	22-Dec-18	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	6:26	6:37	0:11	HAND TRIPPED
711	22-Dec-18	TUMKUR	66	HIRIYUR 220KV- ENERCON-2	ENERCON1_IPP_66	6:26	6:37	0:11	HAND TRIPPED
712	22-Dec-18	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	6:25	6:38	0:12	HAND TRIPPED
713	22-Dec-18	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	6:25	6:38	0:12	HAND TRIPPED
714	22-Dec-18	TUMKUR	66	TR-2 ((HV SIDE )	ANTHRASANAHALLI_220	15:13	15:26	0:13	LINE CLEAR AVAILED
715	22-Dec-18	TUMKUR	66	TR-2	BENNEHALLI_66	16:00	17:50	1:50	LINE CLEAR AVAILED
716	22-Dec-18	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	12:20	13:19	0:59	HAND TRIPPED
717	22-Dec-18	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	9:10	17:31	8:20	MAIN SUPPLY FAILURE
718	22-Dec-18	TUMKUR	66	TR-1	DEVARAHALLI_66	9:10	17:31	8:20	MAIN SUPPLY FAILURE
719	22-Dec-18	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:17	16:33	0:16	LINE FAULT
720	22-Dec-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	10:37	17:29	6:52	HAND TRIPPED
721	22-Dec-18	TUMKUR	66	HIREHALLI - MELKOTE	HIREHALLY_66	9:56	20:30	10:34	LINE CLEAR AVAILED
722	22-Dec-18	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	8:08	8:11	0:02	MAIN SUPPLY FAILURE
723	22-Dec-18	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	8:26	8:34	0:07	MAIN SUPPLY FAILURE
724	22-Dec-18	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	9:03	9:29	0:25	MAIN SUPPLY FAILURE

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
725	22-Dec-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	9:02	17:31	8:29	LINE CLEAR AVAILED
726	22-Dec-18	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	10:39	17:27	6:48	HAND TRIPPED
727	22-Dec-18	TUMKUR	66	TR-1	KATTIGE_66	16:33	16:53	0:19	TRANSFORMER FAULT
728	22-Dec-18	TUMKUR	66	TR1	KATTIGE_66	22:01	22:11	0:09	TRANSFORMER FAULT
729	22-Dec-18	TUMKUR	66	TR-1	KUNIGAL_66	12:26	12:28	0:02	LINE CLEAR AVAILED
730	22-Dec-18	TUMKUR	66	TR-1	KUNIGAL_66	13:16	14:33	1:17	LINE CLEAR AVAILED
731	22-Dec-18	TUMKUR	66	TR-1	RANGENAHALLI_66	17:04	17:35	0:30	LINE CLEAR AVAILED
732	23-Dec-18	BAGALKOT	110	110/11KV,HV-1	BANAHATTI_110	10:27	13:41	3:14	LINE CLEAR AVAILED
733	23-Dec-18	BAGALKOT	110	BAGEWADI-RAMPUR(NIDAGUNDI)	NIDAGUNDI_110	8:00	9:00	1:00	LINE CLEAR AVAILED
734	23-Dec-18	BAGALKOT	110	BAGEWADI-ACHANUR(MUDDEBIHAL)	MUDDEBIHAL_110	8:00	9:00	1:00	LINE CLEAR AVAILED
735	23-Dec-18	BAGALKOT	110	MAHALINGAPUR-DHAVLESHWAR	DHAVALESHWAR_110	17:48	23:59	6:11	HAND TRIPPED
736	23-Dec-18	BAGALKOT	110	110/11KV,HV-2	GOKAK_110	15:29	15:34	0:05	TRANSFORMER FAULT
737	23-Dec-18	BAGALKOT	110	GOPANAKOPPA-GADAG ROAD	GOPANAKOPPA_110	9:44	9:49	0:05	HAND TRIPPED
738	23-Dec-18	BAGALKOT	110	GOPANAKOPPA-MRUTYUJANAGAR 2	GOPANAKOPPA_110	9:49	18:46	8:57	LINE CLEAR AVAILED
739	23-Dec-18	BAGALKOT	110	GOPANAKOPPA-MRUTYUJANAGAR 2	GOPANAKOPPA_110	9:49	18:46	8:57	LINE CLEAR AVAILED
740	23-Dec-18	BAGALKOT	220	BELGAUM1-CHIKKODI	CHIKKODI_220	2:05	9:05	7:00	HAND TRIPPED
741	23-Dec-18	BAGALKOT	220	BELGAUM1-CHIKKODI	CHIKKODI_220	19:25	23:59	4:34	HAND TRIPPED
742	23-Dec-18	BAGALKOT	220	220/110KV,HV2	MAHALINGAPUR_220,TERDAL_110,RAB KAVI_110,GSM1&2_110,	17:02	17:04	0:02	HAND TRIPPED
743	23-Dec-18	BAGALKOT	110	MAHALINGAPUR220-BANAHATTI	BANAHATTI_110	16:51	17:12	0:21	HAND TRIPPED
744	23-Dec-18	BAGALKOT	110	MAHALINGAPUR220-JAMAKHANDI	JAMAKHANDI_110	16:37	23:59	7:22	MAIN SUPPLY FAILURE
745	23-Dec-18	BANGALORE	66	HV2	APPAREL PARK	16:10	16:39	0:29	TRANSFORMER FAULT
746	23-Dec-18	BANGALORE	66	HV1	AREHALLI	11:05	11:10	0:05	LOAD CHANGE OVER
747	23-Dec-18	BANGALORE	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	8:38	8:42	0:04	LOAD CHANGE OVER
748	23-Dec-18	BANGALORE	66	HV2	IISc	6:23	6:32	0:09	LOAD CHANGE OVER
749	23-Dec-18	BANGALORE	66	MATHIKERE-GOKULA	MATHIKERE	5:30	5:35	0:05	LOAD CHANGE OVER
750	23-Dec-18	BANGALORE	66	MATHIKERE-HEBBAL	MATHIKERE	10:25	10:30	0:05	LOAD CHANGE OVER
751	23-Dec-18	BANGALORE	66	RMV-GOKULA	RMV	5:35	5:39	0:04	LOAD CHANGE OVER
752	23-Dec-18	BANGALORE	66	RMV-HEBBAL	RMV	10:30	10:35	0:05	LOAD CHANGE OVER
753	23-Dec-18	BANGALORE	66	PLATINUM CITY-SRS PEENYA	PLATINUM CITY	5:30	5:40	0:10	LOAD CHANGE OVER
754	23-Dec-18	BANGALORE	66	PLATINUM CITY-PUTTENAHALLI	PLATINUM CITY	10:20	10:30	0:10	LOAD CHANGE OVER
755	23-Dec-18	BANGALORE	66	SIR MV LAYOUT-VRISHABHAVATHI 220	SIR MV LAYOUT	14:35	14:50	0:15	LINE FAULT
756	23-Dec-18	BANGALORE	66	VRISHBHAVATHI 220 - SIR MV LAYOUT	SIR MV LAYOUT, KENGERI SATELLITE TOWN	12:15	12:35	0:20	LINE CLEAR AVAILED
757	23-Dec-18	BANGALORE	66	HV1	YARANDANAHALLI	10:30	10:45	0:15	LOAD CHANGE OVER

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
758	23-Dec-18	BANGALORE	66	HV2	YARANDANAHALLI	10:30	10:45	0:15	LOAD CHANGE OVER
759	23-Dec-18	BANGALORE	66	HV3	YARANDANAHALLI	10:30	10:45	0:15	LOAD CHANGE OVER
760	23-Dec-18	BANGALORE	66	HV1	YARANDANAHALLI	14:23	16:31	2:08	LINE CLEAR AVAILED
761	23-Dec-18	BANGALORE	66	HV2	YARANDANAHALLI	16:34	18:28	1:54	LINE CLEAR AVAILED
762	23-Dec-18	BANGALORE	66	HV1	YARANDANAHALLI	18:32	18:35	0:03	LOAD CHANGE OVER
763	23-Dec-18	BANGALORE	66	HV3	YARANDANAHALLI	18:32	18:35	0:03	LOAD CHANGE OVER
764	23-Dec-18	BANGALORE	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	18:42	19:04	0:22	LINE CLEAR AVAILED
765	23-Dec-18	BANGALORE	66	HV1	HOSKOTE 66	12:56	13:01	0:04	TRANSFORMER FAULT
766	23-Dec-18	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	8:25	9:30	1:05	LINE FAULT
767	23-Dec-18	BANGALORE	220	HV1	KOLAR 220	8:25	9:05	0:40	TRANSFORMER FAULT
768	23-Dec-18	BANGALORE	220	HV2	KOAR 220	8:25	9:05	0:40	TRANSFORMER FAULT
769	23-Dec-18	BANGALORE	66	DALASNUR - SRINIVASPURA	DALASNUR, MALLASANDRA	13:40	14:35	0:55	LINE CLEAR AVAILED
770	23-Dec-18	BANGALORE	66	MALUR 220 - HOSKOTE 1	JADIGENAHALLI, MALUR I/A	9:25	9:39	0:14	LINE FAULT
771	23-Dec-18	BANGALORE	66	MALUR 220 - HOSKOTE 1	JADIGENAHALLI, MALUR I/A	9:39	16:23	6:43	LINE FAULT
772	23-Dec-18	BANGALORE	66	HV1	SUGUTUR	11:38	11:50	0:11	TRANSFORMER FAULT
773	23-Dec-18	BANGALORE	66	SURYANAGAR - YARANDANAHALLI 220	SURYANAGAR	10:27	10:41	0:14	LOAD CHANGE OVER
774	23-Dec-18	BANGALORE	66	SURYANAGAR - ANEKAL	SURYANAGAR	18:39	19:08	0:28	LOAD CHANGE OVER
775	23-Dec-18	BANGALORE	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	5:20	5:35	0:15	LOAD CHANGE OVER
776	23-Dec-18	BANGALORE	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	13:01	13:05	0:04	LOAD CHANGE OVER
777	23-Dec-18	BANGALORE	66	ALUR - SRS PEENYA 220	ALUR	5:30	5:35	0:05	LOAD CHANGE OVER
778	23-Dec-18	BANGALORE	66	ALUR - NELAMANGALA 66	ALUR	10:18	10:23	0:05	LOAD CHANGE OVER
779	23-Dec-18	GULBARGA	110	HALBARGA-SANTHAPUR	DONGRAGO_A_110,SANTHAPUR_110,KAMALANAGAR_110	13:19	13:27	0:08	LINE FAULT
780	23-Dec-18	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	10:03	10:12	0:09	LINE FAULT
781	23-Dec-18	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	10:30	10:36	0:06	LINE FAULT
782	23-Dec-18	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	10:30	10:36	0:06	LINE FAULT
783	23-Dec-18	GULBARGA	110	KEMBHAVI-SHAHPUR,UGAR SUGAR	KEMBHAVI_110	23:10	23:20	0:10	LINE FAULT
784	23-Dec-18	GULBARGA	110	MASKI-RENEWSLR	MASKI_110	10:03	23:59	13:56	LINE FAULT
785	23-Dec-18	HASSAN	110	HV1	KONAJE_110	9:20	9:23	0:03	HAND TRIPPED
786	23-Dec-18	HASSAN	110	HV1	KONAJE_110	16:34	16:37	0:03	HAND TRIPPED
787	23-Dec-18	HASSAN	110	HV2	KONAJE_110	9:20	9:23	0:03	HAND TRIPPED
788	23-Dec-18	HASSAN	110	HV2	KONAJE_110	16:34	16:37	0:03	HAND TRIPPED
789	23-Dec-18	HASSAN	110	HV3	KONAJE_110	9:20	9:23	0:03	HAND TRIPPED
790	23-Dec-18	HASSAN	110	HV3	KONAJE_110	16:34	16:37	0:03	HAND TRIPPED
791	23-Dec-18	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	9:13	9:17	0:04	HAND TRIPPED
792	23-Dec-18	HASSAN	66	HV2	BELUR_66	17:36	17:49	0:13	TRANSFORMER FAULT
793	23-Dec-18	HASSAN	66	GENDEHA-HASSAN	GENDEHALLI_66	14:25	14:45	0:20	LINE FAULT



Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
794	23-Dec-18	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	14:25	14:46	0:21	LINE FAULT
795	23-Dec-18	HASSAN	66	RAMNAT-KUSALNAGARA	RAMNATHPURA_66	0:00	14:40	14:40	LINE CLEAR AVAILED
796	23-Dec-18	MYSORE	66	CR NAGARA-KABBALLI	HARVEY_66 KABHALLY_66	16:21	16:31	0:10	LINE FAULT
797	23-Dec-18	MYSORE	66	GUNDLUPETE-BEGUR	BEGUR_66 SINDHUVALI_66	16:20	16:46	0:26	LINE FAULT
798	23-Dec-18	MYSORE	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	3:43	3:50	0:06	LINE FAULT
799	23-Dec-18	MYSORE	66	JAKKANAHALLI-NAGMANGLA	G MALLIGERE_66, GUDDENAHALLI_66, BOGADHI MANDYA_66 & NAGAMANGALA_66	2:25	2:36	0:10	LINE FAULT
800	23-Dec-18	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66 K_HONNALGERE_66	12:19	13:38	1:18	LINE CLEAR AVAILED
801	23-Dec-18	MYSORE	66	HV2	KRPET_66	13:13	13:23	0:09	LINE CLEAR AVAILED
802	23-Dec-18	MYSORE	66	KR PETE 220-MADESHWARAPURA	MADESWARAPURA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 BOGADHI MANDYA_66 NAGAMANGALA_66	6:21	6:32	0:11	LINE FAULT
803	23-Dec-18	MYSORE	66	HV2	SALIGRAMA_66	12:51	23:59	11:07	LINE CLEAR AVAILED
804	23-Dec-18	TUMKUR	110	KALLUR- NITTUR	KALLUR_110	13:55	15:10	1:15	LINE CLEAR AVAILED
805	23-Dec-18	TUMKUR	110	TR-2	SAMPIGE_110	10:51	10:56	0:04	TRANSFORMER FAULT
806	23-Dec-18	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	12:01	12:19	0:17	LINE FAULT
807	23-Dec-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TM2_66	16:02	16:07	0:05	LINE FAULT
808	23-Dec-18	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	16:02	16:07	0:05	LINE FAULT
809	23-Dec-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	12:54	13:04	0:09	LINE FAULT
810	23-Dec-18	TUMKUR	66	TR-2	HOSADURGA_66	15:33	15:52	0:19	TRANSFORMER FAULT
811	23-Dec-18	TUMKUR	66	KATTIGE- RENEW WIND IPP	RENEWIND_IPP_66	17:56	18:51	0:55	LINE CLEAR AVAILED
812	23-Dec-18	TUMKUR	66	TR-2	PATTANAYAKANAHALLI_66	18:16	18:31	0:15	TRANSFORMER FAULT
813	23-Dec-18	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	18:00	18:03	0:02	LINE FAULT
814	23-Dec-18	TUMKUR	66	TR-1	SAVALANGA_66	18:00	18:07	0:07	TRANSFORMER FAULT
815	24-Dec-18	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	9:31	17:06	7:35	LINE CLEAR AVAILED
816	24-Dec-18	BAGALKOT	220	PONDA 2 -AMBEWADI	AMBEWADI_220	0:00	15:56	15:56	LINE CLEAR AVAILED
817	24-Dec-18	BAGALKOT	220	PONDA 2 -AMBEWADI	AMBEWADI_220	22:07	23:59	1:52	LINE FAULT
818	24-Dec-18	BAGALKOT	220	CHIKKODI 220-BELGAUM 1	CHIKKODI_220	0:00	9:27	9:27	LINE CLEAR AVAILED
819	24-Dec-18	BAGALKOT	110	110/11KV,HV-1	BIDNAL_220	11:15	16:47	5:32	HAND TRIPPED
820	24-Dec-18	BAGALKOT	110	MAHALINGAPUR-DHAVALSHWAR	DHAVALSHWAR_110	0:00	8:44	8:44	LINE CLEAR AVAILED
821	24-Dec-18	BAGALKOT	110	110/33KV,HV3	TILUVALLI_110,SHESAGIRI_33,KALKERI_33	22:00	22:29	0:29	HAND TRIPPED

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
822	24-Dec-18	BAGALKOT	110	TADASINAKOPPA-TARIHAL	TARIHAL_110	9:40	9:50	0:10	HAND TRIPPED
823	24-Dec-18	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	12:53	13:36	0:43	HAND TRIPPED
824	24-Dec-18	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	12:53	13:58	1:05	HAND TRIPPED
825	24-Dec-18	BAGALKOT	110	110/11KV,HV1	KIRUVATTI_110	10:12	17:55	7:43	HAND TRIPPED
826	24-Dec-18	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALI, CHEEMANGALA	13:45	16:59	3:13	LINE FAULT
827	24-Dec-18	BANGALORE	66	MALUR 220 - HOSKOTE 1	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	7:55	8:06	0:11	LINE FAULT
828	24-Dec-18	BANGALORE	66	MALUR 220 - HOSKOTE 1	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	9:00	9:33	0:33	LINE FAULT
829	24-Dec-18	BANGALORE	66	MALUR 220 - HOSKOTE 1	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	9:44	10:25	0:40	LINE FAULT
830	24-Dec-18	BANGALORE	66	YELAHANKA 220 - LINE 6	SOLDEVANAHALI	6:33	6:50	0:17	LINE FAULT
831	24-Dec-18	BANGALORE	66	YELAHANKA 220 - LINE 6	SOLDEVANAHALI	12:39	13:01	0:22	LINE CLEAR AVAILED
832	24-Dec-18	BANGALORE	66	HV2	SARJAPURA 220	3:46	3:56	0:09	TRANSFORMER FAULT
833	24-Dec-18	BANGALORE	66	HOSKOTE 66 - MALUR	MALUR I/A, JADIGENAHALLI	18:45	19:00	0:14	LOAD CHANGE OVER
834	24-Dec-18	BANGALORE	66	ADUGODI-HAL 2	K & C VALLEY,KORAMANGALA	14:10	15:11	1:01	LINE CLEAR AVAILED
835	24-Dec-18	BANGALORE	66	ADUGODI-NIMHANS 66	NIMHANS 66,BOSCH(EHT)	15:03	15:07	0:04	LINE CLEAR AVAILED
836	24-Dec-18	BANGALORE	66	A STATION 220 - A STATION 66	A STATION 66	0:21	0:24	0:03	LOAD CHANGE OVER
837	24-Dec-18	BANGALORE	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	6:38	6:48	0:10	LOAD CHANGE OVER
838	24-Dec-18	BANGALORE	66	HV2	GOKULA	9:35	9:36	0:01	LOAD CHANGE OVER
839	24-Dec-18	BANGALORE	66	HV3	HEBBAL 220	9:28	9:48	0:20	TRANSFORMER FAULT
840	24-Dec-18	BANGALORE	66	HV3	HEBBAL 220	14:32	14:46	0:14	LINE CLEAR AVAILED
841	24-Dec-18	BANGALORE	66	HV3	HEBBAL 220	14:48	16:53	2:05	TRANSFORMER FAULT
842	24-Dec-18	BANGALORE	220	HV2	HOODY 220	16:36	16:59	0:23	TRANSFORMER FAULT
843	24-Dec-18	BANGALORE	66	ITI-HOODY 220	ITI	16:36	21:05	4:29	MAIN SUPPLY FAILURE
844	24-Dec-18	BANGALORE	66	HV2	JAYANAGARA	12:52	13:14	0:22	LINE CLEAR AVAILED
845	24-Dec-18	BANGALORE	66	HV1	KENGERI SATELLITE TOWN	18:47	20:30	1:43	TRANSFORMER FAULT
846	24-Dec-18	BANGALORE	66	HV1	MATHIKERE	14:15	14:20	0:05	LOAD CHANGE OVER
847	24-Dec-18	BANGALORE	66	HV2	MATHIKERE	15:35	15:38	0:03	LOAD CHANGE OVER
848	24-Dec-18	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	8:10	8:25	0:15	LINE FAULT
849	24-Dec-18	BANGALORE	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	14:43	14:48	0:05	LOAD CHANGE OVER
850	24-Dec-18	GULBARGA	220	HV2	ALIPUR_220	14:14	14:28	0:14	TRANSFORMER FAULT
851	24-Dec-18	GULBARGA	110	HV2,HV3	KAMPLI_110	14:33	14:36	0:03	TRANSFORMER FAULT
852	24-Dec-18	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110.KADAGANCHI_110	14:48	14:53	0:05	LINE CLEAR AVAILED
853	24-Dec-18	GULBARGA	110	SINDHANOOR-PGLR_IPP	SIDHANOOR_220	5:42	6:04	0:22	LINE FAULT
854	24-Dec-18	GULBARGA	110	SINDHANOOR-FUTURE-1	TURVIHAL_110	13:32	13:38	0:06	LINE FAULT
855	24-Dec-18	GULBARGA	110	HV3	KUSTAGI_220	13:02	14:26	1:24	TRANSFORMER FAULT
856	24-Dec-18	GULBARGA	110	HV3	KUSTAGI_220	14:36	14:48	0:12	TRANSFORMER FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
857	24-Dec-18	GULBARGA	110	HV3	KUSTAGI_220	16:01	16:41	0:40	TRANSFORMER FAULT
858	24-Dec-18	GULBARGA	110	MASKI-RENEWSLR	MASKI_110	0:00	13:40	13:40	LINE FAULT
859	24-Dec-18	GULBARGA	110	MASKI-RENEWSLR	MASKI_110	18:27	19:22	0:55	LINE CLEAR AVAILED
860	24-Dec-18	GULBARGA	66	HV1,HV2	UPANAYAKANAHALLI_66	10:58	11:38	0:40	LINE CLEAR AVAILED
861	24-Dec-18	HASSAN	220	GERSOPPA-STRP1	GERSOPPA_GEN	11:11	14:12	3:01	LINE CLEAR AVAILED
862	24-Dec-18	HASSAN	220	GERSOPPA-STRP2	GERSOPPA_GEN	11:11	14:12	3:01	LINE CLEAR AVAILED
863	24-Dec-18	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	10:39	14:12	3:33	LINE CLEAR AVAILED
864	24-Dec-18	HASSAN	220	SSHRAVTY-HIRALKOPPA	SHRAVTY_GEN	11:30	14:03	2:33	HAND TRIPPED
865	24-Dec-18	HASSAN	220	SHRLKP-SGS	SHRLKP_220	11:31	12:04	0:33	HAND TRIPPED
866	24-Dec-18	HASSAN	220	SHRLKP-SGS	SHRLKP_220	12:09	12:21	0:12	HAND TRIPPED
867	24-Dec-18	HASSAN	220	SHRLKP-SGS	SHRLKP_220	12:37	13:07	0:30	HAND TRIPPED
868	24-Dec-18	HASSAN	220	SHRLKP-SGS	SHRLKP_220	13:13	14:03	0:50	HAND TRIPPED
869	24-Dec-18	HASSAN	220	TALAGUPPA-STRP2	TALAGUPPA_400	10:32	14:34	4:02	LINE CLEAR AVAILED
870	24-Dec-18	HASSAN	110	ARSKERE2-ARSKR	ARSIKERE_220	10:34	11:15	0:41	LINE CLEAR AVAILED
871	24-Dec-18	HASSAN	110	MOODAB-SOHAM1	MOODAB_110	7:06	7:45	0:39	HAND TRIPPED
872	24-Dec-18	HASSAN	110	MOODAB-SOHAM2	MOODAB_110	7:06	7:45	0:39	HAND TRIPPED
873	24-Dec-18	HASSAN	110	MOODAB-KEMAR	MOODAB_110	7:06	7:35	0:29	LOAD CURTAILMENT
874	24-Dec-18	HASSAN	110	SHRLKP-BARANG	SHRLKP_220	11:18	12:54	1:36	HAND TRIPPED
875	24-Dec-18	HASSAN	110	HV1	SHRLKP_220	12:04	12:22	0:18	LOAD CURTAILMENT
876	24-Dec-18	HASSAN	110	SHRLKP-KITTADAHALLI	SHRLKP_220	11:11	11:53	0:42	HAND TRIPPED
877	24-Dec-18	HASSAN	110	KITTADAHALLI	SHRLKP_220	12:31	13:12	0:41	HAND TRIPPED
878	24-Dec-18	HASSAN	110	SHRLKP-SHIRALKOPPA	SHRLKP_220	11:55	13:04	1:09	HAND TRIPPED
879	24-Dec-18	HASSAN	110	SHRLKP-SORAB	SHRLKP_220	11:56	13:27	1:31	HAND TRIPPED
880	24-Dec-18	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	6:20	7:15	0:55	LOAD CURTAILMENT
881	24-Dec-18	HASSAN	66	HV2	BELUR_66	11:25	12:50	1:25	LINE CLEAR AVAILED
882	24-Dec-18	HASSAN	66	BELUR-MUDIGERE	BELUR_66	11:25	11:40	0:15	LINE CLEAR AVAILED
883	24-Dec-18	HASSAN	66	HV1	BELUR_66	11:25	11:40	0:15	LINE CLEAR AVAILED
884	24-Dec-18	HASSAN	66	HNPR2-HASS1	HNPURA_220	13:47	13:52	0:05	LINE FAULT
885	24-Dec-18	HASSAN	66	HNPR2-MYSOR1	HNPURA_220	8:22	8:30	0:08	LINE FAULT
886	24-Dec-18	HASSAN	66	KANDLI0-SAKLESHPUR	KANDLI_66	11:35	13:08	1:33	LINE CLEAR AVAILED
887	24-Dec-18	HASSAN	66	SAKALESH-HASSAN	SAKALESHPURA_66	11:59	13:09	1:10	LOAD CURTAILMENT
888	24-Dec-18	MYSORE	66	DEVANUR NANJ-SUTTUR	SUTTUR_66	3:20	3:24	0:04	LINE FAULT
889	24-Dec-18	MYSORE	66	HV1	GUDDENAHALLI_66	15:06	16:08	1:02	LINE CLEAR AVAILED
890	24-Dec-18	MYSORE	66	HV1	K_HONNALGERE_66	14:53	15:13	0:20	LINE CLEAR AVAILED
891	24-Dec-18	MYSORE	66	HV3	KIKKERI_66	14:15	15:12	0:56	LINE CLEAR AVAILED
892	24-Dec-18	TUMKUR	110	TR-2	SAMPIGE_110	14:05	14:11	0:06	TRANSFORMER FAULT
893	24-Dec-18	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	12:10	14:07	1:56	LINE CLEAR AVAILED
894	24-Dec-18	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	13:44	13:55	0:11	HAND TRIPPED
895	24-Dec-18	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:29	10:38	0:08	LINE FAULT

Sl.No	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
896	24-Dec-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:54	17:45	8:51	LINE CLEAR AVAILED
897	24-Dec-18	TUMKUR	66	TR-1	HALURAMESHWARA_66	11:47	13:23	1:36	LINE CLEAR AVAILED
898	24-Dec-18	TUMKUR	66	TR-2	HARAPPANAHALLI_66	16:03	18:12	2:08	LINE CLEAR AVAILED
899	24-Dec-18	TUMKUR	66	TR-1	HIREGUNTANUR_66	12:51	13:57	1:06	LINE CLEAR AVAILED
900	24-Dec-18	TUMKUR	66	TR-2	HIREGUNTANUR_66	13:24	13:33	0:09	LINE CLEAR AVAILED
901	24-Dec-18	TUMKUR	66	KATTIGE- RENEW WIND IPP	RENEWIND_IPP_66	18:35	19:48	1:13	LINE CLEAR AVAILED
902	24-Dec-18	TUMKUR	66	MADHUGIRI 220kV- SIRA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	23:01	23:24	0:23	LINE FAULT
903	24-Dec-18	TUMKUR	66	TR-1	MANGALWADA_66	13:59	14:20	0:21	LINE CLEAR AVAILED
904	24-Dec-18	TUMKUR	66	TR-2	MANGALWADA_66	13:55	14:20	0:25	LINE CLEAR AVAILED
905	24-Dec-18	TUMKUR	66	TR-2	SANIKERE_66	19:33	19:54	0:21	TRANSFORMER FAULT
906	24-Dec-18	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	23:22	23:36	0:13	HAND TRIPPED
907	24-Dec-18	TUMKUR	66	SIRA- KALLAMBELLA	KALLAMBELLA_66	2:52	3:01	0:08	LINE FAULT
908	24-Dec-18	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	2:52	3:01	0:08	LINE FAULT
909	24-Dec-18	TUMKUR	66	SAVALANGA 66kV-HNLI220_NYMT	SAVALANGA_66	13:15	14:23	1:08	MAIN SUPPLY FAILURE