

400/220/110/66 kV TRANSMISSION OUTAGES FORM 06.07.21 TO 12.07.21

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	6-Jul-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
2	6-Jul-21	BAGALKOT	110	110/11KV, HV1	SOUDATTI_220	10:31	10:58	0:27	HAND TRIPPED
3	6-Jul-21	BAGALKOT	110	110/11KV, HV1	ZALKI_110	10:28	11:21	0:53	LINE CLEAR AVAILED
4	6-Jul-21	BAGALKOT	110	110/11KV,HV2	CHINCHALI_33 KUDUCHI_110	19:17	19:27	0:10	TRANSFORMER FAULT
5	6-Jul-21	BAGALKOT	110	110/11KV,HV2	MUDDEBIHAL_110	15:38	16:26	0:48	LINE CLEAR AVAILED
6	6-Jul-21	BAGALKOT	110	110/11KV,HV3	BAGALKOT_220	22:12	22:25	0:13	TRANSFORMER FAULT
7	6-Jul-21	BAGALKOT	110	220/110KV, LV1	SOUDATTI_220	10:32	10:57	0:25	HAND TRIPPED
8	6-Jul-21	BAGALKOT	110	220/110KV, LV2	SOUDATTI_220	10:32	10:57	0:25	HAND TRIPPED
9	6-Jul-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
10	6-Jul-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
11	6-Jul-21	BAGALKOT	110	ATHANI220-AIGALI	ATHANI_220	12:50	12:52	0:02	LINE FAULT
12	6-Jul-21	BAGALKOT	110	ATHANI220-AIGALI	ATHANI_220	14:04	14:23	0:19	LINE FAULT
13	6-Jul-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
14	6-Jul-21	BAGALKOT	110	BAGALKOT220-GULEDGUDDA	GULEDGUDDA_110	22:12	22:25	0:13	LINE FAULT
15	6-Jul-21	BAGALKOT	110	BAGALKOT-NEERBUDIHAL	NEERBUDIHAL_110	11:10	11:23	0:13	HAND TRIPPED
16	6-Jul-21	BAGALKOT	110	BAGALKOT-NEERBUDIHAL	NEERBUDIHAL_110	14:57	15:09	0:12	HAND TRIPPED
17	6-Jul-21	BAGALKOT	110	GHATAPRABHA-GHATAPRABHA2	STATION NOT AFFECTED GHATAPRABHA_220	4:07	4:17	0:10	LINE FAULT
18	6-Jul-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
19	6-Jul-21	BAGALKOT	110	HIREBEVANUR-RODAGI	RODAGI_110	14:48	15:19	0:31	LINE FAULT
20	6-Jul-21	BAGALKOT	110	KUDUCHI220-TERDAL	STATION NOT AFFECTED KUDUCHI_220	22:11	22:30	0:19	HAND TRIPPED
21	6-Jul-21	BAGALKOT	110	MAHALINGAPUR(NAVALAGI)-JAMAKHANDI	STATION NOT AFFECTED JAMAKHANDI_110	12:20 (04.07.2021)	10:10 (06.07.2021)	21:50	LINE CHARGED
22	6-Jul-21	BAGALKOT	110	MAHALINGAPUR(NAVALAGI)-JAMAKHANDI	STATION NOT AFFECTED JAMAKHANDI_110	10:32	15:22	4:50	LINE CLEAR AVAILED
23	6-Jul-21	BAGALKOT	110	MAHALINGAPUR(NAVALAGI)-JAMAKHANDI	STATION NOT AFFECTED JAMAKHANDI_110	21:13 (06.07.2021)			LINE OPEN:LINE CLEAR AVAILED
24	6-Jul-21	BAGALKOT	110	MUNAVALLI-ARTAGAL	ARATAGAL_110 MUNAVALLI_110	11:10	11:12	0:02	HAND TRIPPED
25	6-Jul-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
26	6-Jul-21	BAGALKOT	110	PG HUNSHYAL-SATISH SUGARS	SATISH SUGARS_110 STATION NOT AFFECTED PG HUNSHYAL_110	15:38 (01.07.2021)			LINE OPEN:LINE CLEAR AVAILED
27	6-Jul-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
28	6-Jul-21	BAGALKOT	110	RANNABELAGALI-MUDHOL	STATION NOT AFFECTED RANNABELAGALI_110	11:21	17:43	6:22	LINE CLEAR AVAILED
29	6-Jul-21	BAGALKOT	110	SOUDATTI220-MUNAVALLI	MUNAVALLI_110	10:31	11:05	0:34	HAND TRIPPED
30	6-Jul-21	BAGALKOT	110	SOUDATTI220-NARAGUND	NARAGUND_110	10:31	11:03	0:32	HAND TRIPPED
31	6-Jul-21	BAGALKOT	110	SOUDATTI220-RAMDURG1	RAMDURG_110	10:30	11:10	0:40	HAND TRIPPED
32	6-Jul-21	BAGALKOT	110	SOUDATTI220-RAMDURG1	RAMDURG_110	10:30	11:03	0:33	HAND TRIPPED
33	6-Jul-21	BAGALKOT	110	SOUDATTI220-SOUDATTI1	SOUDATTI_110	10:30	11:07	0:37	HAND TRIPPED
34	6-Jul-21	BAGALKOT	110	SOUDATTI220-SOUDATTI1	SOUDATTI_110	10:31	11:07	0:36	HAND TRIPPED
35	6-Jul-21	BAGALKOT	110	SOUDATTI220-UDAKERI	UDAKERI_110	10:37	12:59	2:22	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
36	6-Jul-21	BAGALKOT	110	SLOUDATTI220-YARAGATTI	YARAGATTI_110	10:30	11:04	0:34	HAND TRIPPED
37	6-Jul-21	BAGALKOT	110	UMAMACHAGI-KIRUVATTI	STATION NOT AFFECTED UMMACHAGI_110	8:33 (06.07.2021)			LINE OPEN:LINE CLEAR AVAILED
38	6-Jul-21	BAGALKOT	110	VADAGOAN-BELAGAUM220	VADAGOAN_110	12:08	12:13	0:05	HAND TRIPPED
39	6-Jul-21	BAGALKOT	110	ZALKI-INDI220	ZALKI_110	10:28	18:46	8:18	LINE CLEAR AVAILED
40	6-Jul-21	BAGALKOT	220	220/110KV, HV1	SLOUDATTI_220	10:32	10:54	0:22	LINE CLEAR AVAILED
41	6-Jul-21	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED VAJRAMATTI_220	15:25	17:16	1:51	LINE CLEAR AVAILED
42	6-Jul-21	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED VAJRAMATTI_220	19:27	19:58	0:31	LINE CLEAR AVAILED
43	6-Jul-21	BAGALKOT	220	220/110KV, HV2	SLOUDATTI_220	10:32	10:54	0:22	HAND TRIPPED
44	6-Jul-21	BAGALKOT	220	220/110KV,HV1,LV1	BAGALKOT_220	11:10	15:07	3:57	LINE CLEAR AVAILED
45	6-Jul-21	BAGALKOT	220	220/110KV,HV3,LV3	MAHALINGAPUR_220,HIDIKAL_110,RABAKAVI_110,	9:35	9:46	0:11	TRANSFORMER FAULT
46	6-Jul-21	BAGALKOT	220	AMBEWADI-(PONDA1)XELDOM	XELDOM_220	12:26	13:31	1:05	LINE FAULT
47	6-Jul-21	BAGALKOT	220	AMBEWADI-(PONDA2)PONDA	AMBEWADI_220	13:08 (06.07.2021)			LINE OPEN:LINE FAULT
48	6-Jul-21	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	12:47	19:17	6:30	LOAD CURTAILMENT
49	6-Jul-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	13:06	19:17	6:11	LOAD CURTAILMENT
50	6-Jul-21	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	12:38	16:52	4:14	LINE FAULT
51	6-Jul-21	BAGALKOT	220	BIDNAL-NAGJHARI	STATION NOT AFFECTED BIDNAL_220	12:42	13:15	0:33	LINE FAULT
52	6-Jul-21	BAGALKOT	220	BIDNAL-SLOUDATTI	STATION NOT AFFECTED BIDNAL_220	10:17	10:51	0:34	LINE FAULT
53	6-Jul-21	BAGALKOT	220	CHIKKODI-KUDUCHI1	STATION NOT AFFECTED CHIKKODI_220	9:35	10:42	1:07	LINE FAULT
54	6-Jul-21	BAGALKOT	220	CHIKKODI-KUDUCHI2	STATION NOT AFFECTED CHIKKODI_220	9:35	10:43	1:08	LINE FAULT
55	6-Jul-21	BAGALKOT	220	HUBLI-NAGZARI2	STATION NOT AFFECTED HUBLI_220	10:43	19:01	8:18	LINE CLEAR AVAILED
56	6-Jul-21	BAGALKOT	220	KUDUCHI220-ATHANI	STATION NOT AFFECTED KUDCHI_220	10:53	14:03	3:10	LINE FAULT
57	6-Jul-21	BAGALKOT	220	KUDUCHI220-MAHALINGAPUR	STATION NOT AFFECTED KUDCHI_220	10:53	14:08	3:15	LINE FAULT
58	6-Jul-21	BAGALKOT	220	MAHALINGAPUR-SLOUDATTI	STATION NOT AFFECTED MAHALINGAPUR_220	15:50	16:22	0:32	LINE FAULT
59	6-Jul-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
60	6-Jul-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
61	6-Jul-21	BAGALKOT	220	NARENDRA-BELGAUM1	STATION NOT AFFECTED NARENDRA_220	12:38	18:34	5:56	LINE FAULT
62	6-Jul-21	BAGALKOT	220	NARENDRA-KANABARGI1	STATION NOT AFFECTED NARENDRA_220	18:49	19:13	0:24	LINE CLEAR AVAILED
63	6-Jul-21	BAGALKOT	220	NARENDRA-KANABARGI2	STATION NOT AFFECTED NARENDRA_220	12:38	18:34	5:56	LINE FAULT
64	6-Jul-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	17:46 (03.07.2021)			LINE OPEN:LINE CLEAR AVAILED
65	6-Jul-21	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	10:09 (03.07.2021)			LINE OPEN:LINE CLEAR AVAILED
66	6-Jul-21	BAGALKOT	220	SLOUDATTI-BIDNAL	SLOUDATTI_220	10:32	10:51	0:19	HAND TRIPPED
67	6-Jul-21	BAGALKOT	220	SLOUDATTI-MAHALINGAPUR	SLOUDATTI_220	10:32	11:00	0:28	HAND TRIPPED
68	6-Jul-21	BAGALKOT	220	SLOUDATTI-MAHALINGAPUR	SLOUDATTI_220	11:25	12:53	1:28	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
69	6-Jul-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
70	6-Jul-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
71	6-Jul-21	BAGALKOT	400	400/220KV,ICT2(HV/LV)	STATION NOT AFFECTED DHONI_400	13:43	15:16	1:33	TRANSFORMER FAULT
72	6-Jul-21	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	13:35	13:40	0:05	LOAD CHANGEOVER
73	6-Jul-21	BENGALURU	66	BOODIGERE - HOSKOTE 220	BOODIGERE	18:00	18:05	0:05	LOAD CHANGEOVER
74	6-Jul-21	BENGALURU	66	BRIGADE METROPOLIS - HOODY 220	BRIGADE METROPOLIS	3:30	6:30	3:00	LINE FAULT
75	6-Jul-21	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	12:36	12:49	0:13	LINE FAULT
76	6-Jul-21	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMSANDRA	16:54	17:06	0:12	LINE CLEAR AVAILED
77	6-Jul-21	BENGALURU	66	F1	DODDALAHALLI	17:20	18:27	1:07	LINE FAULT
78	6-Jul-21	BENGALURU	66	HV1	GOKULA	12:42	12:48	0:06	LINE CLEAR AVAILED
79	6-Jul-21	BENGALURU	66	HV1	HEBBALA 220	13:09	13:12	0:03	LINE CLEAR AVAILED
80	6-Jul-21	BENGALURU	66	HV1	NIMHANS 220	13:53	15:30	1:37	TRANSFORMER FAULT
81	6-Jul-21	BENGALURU	66	HV1	R R NAGAR	5:15	5:32	0:17	TRANSFORMER FAULT
82	6-Jul-21	BENGALURU	66	HV1	MATHIKERE NELMANGALA	14:48	15:05	0:17	LINE CLEAR AVAILED
83	6-Jul-21	BENGALURU	66	HV1	MATHIKERE NELMANGALA	15:13	15:32	0:19	LINE CLEAR AVAILED
84	6-Jul-21	BENGALURU	66	HV1	JULLUPALYA	14:20	16:12	1:51	LINE CLEAR AVAILED
85	6-Jul-21	BENGALURU	66	HV1	DALASNUR	16:32	18:00	1:27	LINE CLEAR AVAILED
86	6-Jul-21	BENGALURU	66	HV2	BRIGADE METROPOLIS	3:30	6:40	3:10	TRANSFORMER FAULT
87	6-Jul-21	BENGALURU	66	HV2	GOKULA	12:28	12:36	0:08	LINE CLEAR AVAILED
88	6-Jul-21	BENGALURU	66	HV2	HEBBALA 220	13:21	13:26	0:05	LINE CLEAR AVAILED
89	6-Jul-21	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
90	6-Jul-21	BENGALURU	66	HV3	HEBBALA 220	13:43	13:50	0:07	LINE CLEAR AVAILED
91	6-Jul-21	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	12:16	12:30	0:14	LINE FAULT
92	6-Jul-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	HALAGURU, DODDALAHALLI, HONNIGANAHALLI	7:28	7:38	0:10	LINE FAULT
93	6-Jul-21	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	2:34	2:44	0:10	LINE FAULT
94	6-Jul-21	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	2:48	3:01	0:13	LINE FAULT
95	6-Jul-21	BENGALURU	66	SM MANGALA - SUGUTUR	SUGUTUR	13:35	14:21	0:46	LINE FAULT
96	6-Jul-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
97	6-Jul-21	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	14:32	16:58	2:26	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
98	6-Jul-21	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	18:10:08(29-6-2021)	14:00(6-7-21)	19:48	LINE CHARGED
99	6-Jul-21	BENGALURU	400	NELAMANGALA 400 - HIRIYUR 1	NO STATION AFFECTED	14:53:42(6-7-21)			LINE OPEN:LINE FAULT
100	6-Jul-21	GULBARGA	66	HOSAHALLI-CJHALLI	HOSAHALLI_66	23:30(06.07.2021)			LINE OPEN:LINE FAULT
101	6-Jul-21	GULBARGA	66	HOSAHALLI-SML_WIND	HOSAHALLI_66	19:15	19:25	0:10	LINE FAULT
102	6-Jul-21	GULBARGA	66	HV2	TAMBRAHALLI_66	5:00	5:10	0:10	TRANSFORMER FAULT
103	6-Jul-21	GULBARGA	110	BADALADUKU-GUDEKOTE	GUDEKOTE_66	23:30(6.7.2021)			LINE OPEN:LINE FAULT
104	6-Jul-21	GULBARGA	110	CHINCHOLI-RENEW WIND	CHINCHOLI_110	20:15	23:15	3:00	LINE FAULT
105	6-Jul-21	GULBARGA	110	GULBARGA SOUTH -GULBARGA WEST	GULBARGA SOUTH_110	5:45	5:50	0:05	MAIN SUPPLY FAILURE
106	6-Jul-21	GULBARGA	110	GULBARGA SOUTH -GULBARGA WEST	GULBARGA SOUTH_110	5:55	6:08	0:13	MAIN SUPPLY FAILURE
107	6-Jul-21	GULBARGA	110	GULBARGA WEST-KAPNOOR	GULBARGA WEST_110	5:45	5:50	0:05	MAIN SUPPLY FAILURE
108	6-Jul-21	GULBARGA	110	GULBARGA WEST-KAPNOOR	GULBARGA WEST_110	5:57	6:08	0:11	MAIN SUPPLY FAILURE
109	6-Jul-21	GULBARGA	110	GULBARGA WEST-KAPNOOR	GULBARGA WEST_110	6:11	6:26	0:15	MAIN SUPPLY FAILURE
110	6-Jul-21	GULBARGA	110	HUMNABAD-DUBALGUNDI	DUBALGUNDI_110	19:45	21:25	1:40	LINE FAULT
111	6-Jul-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
112	6-Jul-21	GULBARGA	110	HV2	HANUMNAL_110	6:50	8:45	1:55	LINE CLEAR AVAILED
113	6-Jul-21	GULBARGA	110	HV2	SREERAM NAGAR_110	15:00	15:30	0:30	LINE CLEAR AVAILED
114	6-Jul-21	GULBARGA	110	HV2	SREERAM NAGAR_110	22:20	22:50	0:30	TRANSFORMER FAULT
115	6-Jul-21	GULBARGA	110	HV3	CHINCHOLI_110	21:55	23:18	1:23	LINE CLEAR AVAILED
116	6-Jul-21	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110	6:36	6:38	0:02	MAIN SUPPLY FAILURE
117	6-Jul-21	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSL SUGAR FACTORY_IPP,CHOWDAPUR_110	5:45	5:52	0:07	LINE FAULT
118	6-Jul-21	GULBARGA	110	MALLAPUR-MUNIRABAD	MALLAPUR_110	20:41	20:46	0:05	MAIN SUPPLY FAILURE
119	6-Jul-21	GULBARGA	110	MUNIRABAD-SINDHNOOR2	KAMPLI_110,MUKUNDA_110,KEREHALI_110,MALLAPURA_110	20:42	20:48	0:06	LINE FAULT
120	6-Jul-21	GULBARGA	110	MUNIRABAD-STARMETTALLIC	STAR METTALLIC_110	11:37	11:50	0:13	LINE FAULT
121	6-Jul-21	GULBARGA	110	MUNIRABAD-STARMETTALLIC	STAR METTALLIC_110	12:41	12:47	0:06	LINE FAULT
122	6-Jul-21	GULBARGA	110	MUNIRABAD-STARMETTALLIC	STARMETTALLIC_110	20:34	20:48	0:14	LINE FAULT
123	6-Jul-21	GULBARGA	110	MUNIRABAD-STARMETTALLIC	STARMETTALLIC_110	21:39	21:42	0:03	LINE FAULT
124	6-Jul-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	23:40	23:47	0:07	LINE FAULT
125	6-Jul-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	23:53(05.07.2021)	00:19(06.07.2021)	0:26 HRS	LINE CHARGED
126	6-Jul-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	20:20	20:50	0:30	LINE FAULT
127	6-Jul-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:05	20:10	0:05	LINE FAULT
128	6-Jul-21	GULBARGA	110	SINDHANOOR-ADVIAMARESHWAR	ADAVIAMARESHWARA_110	22:28(05.07.2021)	09:28(06.07.2021)	11:00	LINE CHARGED
129	6-Jul-21	GULBARGA	110	SINDHANOOR-ADVIAMARESHWAR	ADAVIAMARESHWARA_110	20:10	21:40	1:30	LINE FAULT
130	6-Jul-21	GULBARGA	110	SINDHANOOR-ADVIAMARESHWAR	ADAVIAMARESHWARA_110	12:30	13:25	0:55	LINE CLEAR AVAILED
131	6-Jul-21	GULBARGA	110	SINDHANOOR-MASKI	MASKI_110	2:53	3:04	0:11	MAIN SUPPLY FAILURE
132	6-Jul-21	GULBARGA	110	SINDHANOOR-MASKI	MASKI_110	0:22	0:38	0:16	LINE FAULT
133	6-Jul-21	GULBARGA	110	SINDHANOOR-MASKI	MASKI_110	2:53	2:58	0:05	LINE FAULT
134	6-Jul-21	GULBARGA	110	SINDHANOOR-MASKI	MASKI_110	22:25	23:36	1:11	LINE FAULT
135	6-Jul-21	GULBARGA	110	SINDHANOOR-TEKKALKOTE	TEKKALKOTE_110	22:25	23:10	0:45	MAIN SUPPLY FAILURE
136	6-Jul-21	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	22:12	22:45	0:33	LINE FAULT
137	6-Jul-21	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	23:26	23:41	0:15	LINE FAULT
138	6-Jul-21	GULBARGA	110	SINDHANOOR-VALKAMDINI	VALKAMDINI_110	15:15(6.07.2021)			LINE OPEN:LINE CLEAR AVAILED
139	6-Jul-21	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	11:27	11:42	0:15	MAIN SUPPLY FAILURE
140	6-Jul-21	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	12:10	12:25	0:15	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
141	6-Jul-21	GULBARGA	110	YELBURGA-PARAM POOJYA_IPP	YELBURGA_110	13:25	13:55	0:30	LOAD CURTAILMENT
142	6-Jul-21	GULBARGA	220	HV1	KAPNOOR_220	5:55	6:10	0:15	TRANSFORMER FAULT
143	6-Jul-21	GULBARGA	220	HV2	KAPNOOR_220	5:55	6:28	0:33	TRANSFORMER FAULT
144	6-Jul-21	GULBARGA	220	HV2	SINDHANOOR_220	22:25	22:48	0:23	TRANSFORMER FAULT
145	6-Jul-21	GULBARGA	220	HV2	SHAHAPUR_220	4:48	4:54	0:06	TRANSFORMER FAULT
146	6-Jul-21	GULBARGA	220	LINGAPUR-GDHALLI1	LINGAPUR_220	11:44	14:27	2:43	LINE FAULT
147	6-Jul-21	GULBARGA	220	LINGAPUR-GDHALLI2	GDHALLI_220,DHRUVADESH_IPP	12:39	14:22	1:43	LINE FAULT
148	6-Jul-21	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	12:49	12:53	0:04	LINE CLEAR AVAILED
149	6-Jul-21	HASSAN	66	HV1	ALDUR_66	17:17	18:20	1:03	LINE CLEAR AVAILED
150	6-Jul-21	HASSAN	66	HV1	BYACHANAHALLY_66	19:09	19:16	0:07	TRANSFORMER FAULT
151	6-Jul-21	HASSAN	66	HV2	HALEBEEDU_66	15:14	15:44	0:30	LINE CLEAR AVAILED
152	6-Jul-21	HASSAN	110	HV1	NANDIKUR_110	12:07	12:22	0:15	LINE CLEAR AVAILED
153	6-Jul-21	HASSAN	110	HV1	NAVUNDA_110	10:00	13:35	3:35	LINE CLEAR AVAILED
154	6-Jul-21	HASSAN	110	HV2	HALADY_110	12:08	12:43	0:35	LINE CLEAR AVAILED
155	6-Jul-21	HASSAN	110	HV2	KEMAR_220	10:09	12:32	2:23	LINE CLEAR AVAILED
156	6-Jul-21	HASSAN	110	HV2	SHIKARI[URA_110	6:18	9:17	2:59	TRANSFORMER FAULT
157	6-Jul-21	HASSAN	110	HV3	PUTTUR_110	4:29	6:33	2:04	LINE CLEAR AVAILED
158	6-Jul-21	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN:LINE CLEAR AVAILED
159	6-Jul-21	HASSAN	110	KADUR-YGTI	KADUR_220	16:47	17:10	0:23	LINE FAULT
160	6-Jul-21	HASSAN	110	KEMAR-Manipal1	KEMAR_220	10:31	15:25	4:54	NFBC ISSUED
161	6-Jul-21	HASSAN	110	KEMAR-Manipal2	KEMAR_220	10:31	15:25	4:54	NFBC ISSUED
162	6-Jul-21	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	10:01	10:34	0:33	LINE CLEAR AVAILED
163	6-Jul-21	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	11:35	13:13	1:38	LINE CLEAR AVAILED
164	6-Jul-21	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	10:03	15:28	5:25	LINE CLEAR AVAILED
165	6-Jul-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	10:06	15:28	5:22	LINE CLEAR AVAILED
166	6-Jul-21	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	10:05	15:59	5:54	LINE CLEAR AVAILED
167	6-Jul-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	12:55	15:27	2:32	LINE FAULT
168	6-Jul-21	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	15:03	15:13	0:10	HAND TRIPPED
169	6-Jul-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRMSG_220	11:40	13:21	1:41	LINE FAULT
170	6-Jul-21	HASSAN	220	MRSSHM-STRP1	MRMSG_220	12:53	15:25	2:32	LINE FAULT
171	6-Jul-21	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	11:40	13:24	1:44	LINE FAULT
172	6-Jul-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	14:16	15:06	0:50	LINE FAULT
173	6-Jul-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:02 (30.06.2021)	12:03(6.7.2021)	143:01hrs	LINE CHARGED
174	6-Jul-21	MYSORE	66	DEVNUR(N'GUD)-KADAKOLA	DEVANOORNGUDU_66, SUTTUR_66	6:36	6:41	0:05	LINE FAULT
175	6-Jul-21	MYSORE	66	HV1	MANDGERE_66	11:05	11:20	0:15	TRANSFORMER FAULT
176	6-Jul-21	MYSORE	66	HV1	MANDGERE_66	14:30	14:35	0:05	TRANSFORMER FAULT
177	6-Jul-21	MYSORE	66	HV1	THALAKADU_66	11:50	13:15	1:25	LINE CLEAR AVAILED
178	6-Jul-21	MYSORE	66	HV2	KMDODDI_66	18:31	18:36	0:04	TRANSFORMER FAULT
179	6-Jul-21	MYSORE	66	HV2	THALAKADU_66	13:10	14:21	1:10	LINE CLEAR AVAILED
180	6-Jul-21	MYSORE	66	KADAKOLA-SARGUR 2	DOORA_66 HURA_66 HULLAHALLI_66	3:12	3:17	0:05	LINE FAULT
181	6-Jul-21	MYSORE	66	KADAKOLA-SARGUR 2	DOORA_66 HURA_66 HULLAHALLI_66	6:00	6:04	0:03	LINE FAULT
182	6-Jul-21	MYSORE	66	KUNTHUR-DR PETE	NO STATIONS EFFECTED	15:18	17:09	1:51	LINE CLEAR AVAILED
183	6-Jul-21	MYSORE	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
184	6-Jul-21	MYSORE	66	SANTESARGUR-KADAKOLA1	ANTHARSANTHE_66 HDKOTE_66	3:10	3:25	0:15	LINE FAULT
185	6-Jul-21	MYSORE	66	VAJMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	18:44	18:56	0:11	LINE FAULT
186	6-Jul-21	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	17:43	19:50	2:06	LINE CLEAR AVAILED
187	6-Jul-21	TUMKUR	66	BRAHMASANDRA- SIRA	BRAHMASANDRA_66	15:36	15:49	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
188	6-Jul-21	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	12:12	13:05	0:52	LINE CLEAR AVAILED
189	6-Jul-21	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	5:50	6:27	0:36	MAIN SUPPLY FAILURE
190	6-Jul-21	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	2:15	2:24	0:09	MAIN SUPPLY FAILURE
191	6-Jul-21	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	12:36	12:49	0:12	LINE FAULT
192	6-Jul-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	JAVAGONDANAHALLI_66	14:27	14:35	0:07	LINE FAULT
193	6-Jul-21	TUMKUR	66	MADHUGIRI 220- KALLAMBELLA	KALLAMBELLA_66, SIRA_66	23:08	23:20	0:11	LINE FAULT
194	6-Jul-21	TUMKUR	66	MADHUGIRI 220kv- SIRA 1	KALLAMBELLA_66, BUKKAPATNA_66	23:08	23:19	0:10	LINE FAULT
195	6-Jul-21	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	18:37	18:56	0:18	LINE FAULT
196	6-Jul-21	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUN SOLAR2	18:48	18:56	0:07	HAND TRIPPED
197	6-Jul-21	TUMKUR	66	TR-1	AVAREGERE_66	14:10	14:25	0:15	MAIN SUPPLY FAILURE
198	6-Jul-21	TUMKUR	66	TR-1	BENKIKERE_66	13:39	13:43	0:03	TRANSFORMER FAULT
199	6-Jul-21	TUMKUR	66	TR-1	BENKIKERE_66	14:00	14:04	0:03	TRANSFORMER FAULT
200	6-Jul-21	TUMKUR	66	TR-1	BENKIKERE_66	15:14	15:19	0:05	TRANSFORMER FAULT
201	6-Jul-21	TUMKUR	66	TR-1	MATHOD_66	6:32	6:40	0:07	TRANSFORMER FAULT
202	6-Jul-21	TUMKUR	66	TR-1	MAVINAKATTE_66	5:40	5:49	0:08	TRANSFORMER FAULT
203	6-Jul-21	TUMKUR	66	TR-1	PAVAGADA_220	14:43	14:57	0:14	TRANSFORMER FAULT
204	6-Jul-21	TUMKUR	66	TR-1	RANGANATHAPURA_66	9:50	10:35	0:45	LINE CLEAR AVAILED
205	6-Jul-21	TUMKUR	66	TR-1	SOKKE_66	19:18	19:35	0:16	TRANSFORMER FAULT
206	6-Jul-21	TUMKUR	66	TR-2	AVAREGERE_66	14:25	14:30	0:04	TRANSFORMER FAULT
207	6-Jul-21	TUMKUR	66	TR-2	AVAREGERE_66	14:30	15:20	0:49	TRANSFORMER FAULT
208	6-Jul-21	TUMKUR	66	TR-2	AVAREGERE_66	14:10	14:27	0:17	MAIN SUPPLY FAILURE
209	6-Jul-21	TUMKUR	66	TR-2	BELLAVI_66	9:15	10:15	0:59	LINE CLEAR AVAILED
210	6-Jul-21	TUMKUR	66	TR-2	CHANNAGIRI_66	14:00	14:17	0:17	TRANSFORMER FAULT
211	6-Jul-21	TUMKUR	66	TR-2	MALEBENNUR_66	16:08	16:35	0:26	HAND TRIPPED
212	6-Jul-21	TUMKUR	66	TR-3	AVAREGERE_66	8:16	8:18	0:01	TRANSFORMER FAULT
213	6-Jul-21	TUMKUR	66	TR-3	AVAREGERE_66	14:10	14:29	0:19	MAIN SUPPLY FAILURE
214	6-Jul-21	TUMKUR	66	TR-3(HV-3)	THALLAKK_220	18:37	18:50	0:13	TRANSFORMER FAULT
215	6-Jul-21	TUMKUR	66	TR-3(LV-3)	THALLAKK_220	18:37	18:51	0:14	TRANSFORMER FAULT
216	6-Jul-21	TUMKUR	400	GUTUR_400-BEERANAHALLI-1	GUTUR_400	10:12	16:43	6:31	LINE CLEAR AVAILED
1	7-Jul-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
2	7-Jul-21	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	10:42	11:26	0:44	TRANSFORMER FAULT
3	7-Jul-21	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	6:25	10:01	3:36	LINE CLEAR AVAILED
4	7-Jul-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
5	7-Jul-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
6	7-Jul-21	BAGALKOT	110	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	5:36	5:50	0:14	LINE FAULT
7	7-Jul-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
8	7-Jul-21	BAGALKOT	110	BAGEWADI-LINGASUR1	STATION NOT AFFECTED BAGEWADI_220	12:36	14:41	14:41	LINE FAULT
9	7-Jul-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	6:04	6:35	0:31	LINE FAULT
10	7-Jul-21	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR_110	6:04	6:35	0:31	LINE FAULT
11	7-Jul-21	BAGALKOT	110	BELGAUM-HUDALI(ANAKALAGI)	STATION NOT AFFECTED HUDALI_110	12:08	19:58	7:50	LINE CLEAR AVAILED
12	7-Jul-21	BAGALKOT	110	BPCL-NARGUND	STATION NOT AFFECTED NARGUND_110	1:38	1:51	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
13	7-Jul-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
14	7-Jul-21	BAGALKOT	110	MAHALINGAPUR(NAVALAGI)-JAMAKHANDI	STATION NOT AFFECTED JAMAKHANDI_110	21:13 (06.07.2021)			LINE OPEN:LINE CLEAR AVAILED
15	7-Jul-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
16	7-Jul-21	BAGALKOT	110	PG HUNSHYAL-SATISH SUGARS	SATISH SUGARS_110 STATION NOT AFFECTED PG HUNSHYAL_110	15:38 (01.07.2021)	14:13 (07.07.2021)	22:35 hrs	LINE CHARGED
17	7-Jul-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
18	7-Jul-21	BAGALKOT	110	RANEENNUR-TUMMINAKATTI(RATTIHALLI)	STATION NOT AFFECTED TUMMINAKATTI_110	12:18	16:38	4:20	LINE CLEAR AVAILED
19	7-Jul-21	BAGALKOT	110	UMAMACHAGI-KIRUVATTI	STATION NOT AFFECTED UMMACHAGI_110	8:33 (06.07.2021)			LINE OPEN:LINE CLEAR AVAILED
20	7-Jul-21	BAGALKOT	220	AMBEWADI-(PONDA2)PONDA	AMBEWADI_220	13:08 (06.07.2021)	0:02 (07.07.2021)	10:54 hrs	LINE CHARGED
21	7-Jul-21	BAGALKOT	220	AMBEWADI-NAGJHARI2	STATION NOT AFFECTED AMBEWADI_220	8:52	14:44	5:52	LINE FAULT
22	7-Jul-21	BAGALKOT	220	AMBEWADI-XELDOM(PONDA1)	STATION NOT AFFECTED AMBEWADI_220	12:13	17:10	4:57	LINE FAULT
23	7-Jul-21	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	14:08	16:07	1:59	LINE CLEAR AVAILED
24	7-Jul-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	14:08	16:07	1:59	LINE CLEAR AVAILED
25	7-Jul-21	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	14:10	16:06	1:56	LINE CLEAR AVAILED
26	7-Jul-21	BAGALKOT	220	BIDNAL-HUBLI2	STATION NOT AFFECTED BIDNAL_220	9:56	21:02	11:06	NFBC ISSUED
27	7-Jul-21	BAGALKOT	220	HUBLI-BIDNAL2	STATION NOT AFFECTED HUBLI_220	10:56	21:01	10:05	LINE CLEAR AVAILED
28	7-Jul-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
29	7-Jul-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
30	7-Jul-21	BAGALKOT	220	NARENDRA-BELGAUM1	STATION NOT AFFECTED NARENDRA_220	14:14	16:06	1:52	LINE CLEAR AVAILED
31	7-Jul-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	17:46 (03.07.2021)			LINE OPEN:LINE CLEAR AVAILED
32	7-Jul-21	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	10:09 (03.07.2021)			LINE OPEN:LINE CLEAR AVAILED
33	7-Jul-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
34	7-Jul-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
35	7/Jul/21	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	5:56	6:05	0:09	LINE FAULT
36	7/Jul/21	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	14:17	14:32	0:14	LINE FAULT
37	7/Jul/21	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	14:17	14:30	0:13	LOAD CHANGEOVER
38	7/Jul/21	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	16:25	16:37	0:12	LOAD CHANGEOVER
39	7/Jul/21	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	0:57	1:24	0:27	LINE FAULT
40	7/Jul/21	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	14:17	14:30	0:13	LOAD CHANGEOVER
41	7/Jul/21	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	15:35	16:37	1:02	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
42	7/Jul/21	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	0:57	1:25	0:28	LINE FAULT
43	7/Jul/21	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	14:17	15:33	1:16	LOAD CHANGEOVER
44	7/Jul/21	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	16:25	16:37	0:12	LOAD CHANGEOVER
45	7/Jul/21	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	14:17	14:30	0:13	LOAD CHANGEOVER
46	7/Jul/21	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	16:49	16:54	0:05	LOAD CHANGEOVER
47	7/Jul/21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	14:17	14:30	0:13	LOAD CHANGEOVER
48	7/Jul/21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	16:25	16:37	0:12	LOAD CHANGEOVER
49	7-Jul-21	BENGALURU	66	DEVARABISANAHALLI - CESSNA	DEVARABISANAHALLI	15:14	15:22	0:08	LOAD CHANGEOVER
50	7-Jul-21	BENGALURU	66	DEVARABISANAHALLI - HSR LAYOUT 220	DEVARABISANAHALLI	14:11	14:31	0:20	LOAD CHANGEOVER
51	7-Jul-21	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	13:05	13:33	0:28	LINE FAULT
52	7/Jul/21	BENGALURU	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSUR RAMAPURA, NITRALLI	2:11	2:39	0:28	LINE FAULT
53	7-Jul-21	BENGALURU	66	HV1	KANTEERAVA	14:05	14:10	0:05	LINE CLEAR AVAILED
54	7-Jul-21	BENGALURU	66	HV1	NANDINI LAYOUT	13:17	13:20	0:03	LINE CLEAR AVAILED
55	7-Jul-21	BENGALURU	66	HV1	SOLDEVANAHALLI	11:08	11:17	0:09	LINE CLEAR AVAILED
56	7/Jul/21	BENGALURU	66	HV1	THIMMAMPALLI	17:57	18:55	0:57	TRANSFORMER FAULT
57	7/Jul/21	BENGALURU	66	HV1	SIDDALAGATTA	3:34	3:45	0:10	TRANSFORMER FAULT
58	7/Jul/21	BENGALURU	66	HV1	SIDDALAGATTA	9:35	9:55	0:20	LINE CLEAR AVAILED
59	7/Jul/21	BENGALURU	66	HV1	SIDDALAGATTA	16:00	16:10	0:10	TRANSFORMER FAULT
60	7/Jul/21	BENGALURU	66	HV1	KIADB DB PURA 220	1:17	4:10	2:53	TRANSFORMER FAULT
61	7/Jul/21	BENGALURU	66	HV1	KIADB DB PURA 220	12:47	13:17	0:30	LOAD CHANGEOVER
62	7-Jul-21	BENGALURU	66	HV2	KANTEERAVA	11:08	11:10	0:02	LINE CLEAR AVAILED
63	7-Jul-21	BENGALURU	66	HV2	NANDINI LAYOUT	13:21	13:26	0:05	LINE CLEAR AVAILED
64	7/Jul/21	BENGALURU	66	HV2	THIMMAMPALLI	17:57	18:55	0:57	TRANSFORMER FAULT
65	7/Jul/21	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
66	7/Jul/21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	3:46	4:20	0:34	LINE FAULT
67	7/Jul/21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	4:21	4:31	0:10	LINE CLEAR AVAILED
68	7/Jul/21	BENGALURU	66	MANDIKAL - GOWRIBIDANUR 220	MANDIKAL	10:00	11:01	1:01	LINE CLEAR AVAILED
69	7/Jul/21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	12:30	12:37	0:07	MAIN SUPPLY FAILURE
70	7/Jul/21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	16:17	16:20	0:03	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
71	7/Jul/21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	22:00	22:07	0:07	MAIN SUPPLY FAILURE
72	7/Jul/21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	12:30	12:37	0:07	MAIN SUPPLY FAILURE
73	7/Jul/21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	16:17	16:20	0:03	LOAD CHANGEOVER
74	7/Jul/21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	22:00	22:07	0:07	MAIN SUPPLY FAILURE
75	7/Jul/21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	10:24	10:28	0:04	LINE FAULT
76	7/Jul/21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	12:30	12:37	0:07	MAIN SUPPLY FAILURE
77	7/Jul/21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	16:17	16:20	0:03	LOAD CHANGEOVER
78	7/Jul/21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	22:00	22:07	0:07	MAIN SUPPLY FAILURE
79	7/Jul/21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	6:40	6:44	0:04	LOAD CHANGEOVER
80	7/Jul/21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, AFTL SLR	2:52	2:57	0:04	LINE FAULT
81	7/Jul/21	BENGALURU	66	SIDLAGATTA - CHINTAMANI 220	SIDLAGATTA, MELUR	8:16	8:20	0:04	LINE CLEAR AVAILED
82	7/Jul/21	BENGALURU	66	SIDLAGATTA - CHINTAMANI 220	SIDLAGATTA, MELUR	18:42	18:47	0:05	LINE CLEAR AVAILED
83	7/Jul/21	BENGALURU	66	THIMMAMPALLI - PATHPALYA	THIMMAMPALLI	17:57	18:55	0:57	LINE FAULT
84	7/Jul/21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
85	7/Jul/21	BENGALURU	220	HV1	DB PURA 220	14:19	16:24	2:05	LINE CLEAR AVAILED
86	7/Jul/21	BENGALURU	220	HV1	DB PURA 220	22:00	23:16	1:16	LINE CLEAR AVAILED
87	7/Jul/21	BENGALURU	220	LV1	MITTEMARI 220	12:30	16:20	3:50	TRANSFORMER FAULT
88	7/Jul/21	BENGALURU	220	LV1	MITTEMARI 220	22:00	23:16	1:16	TRANSFORMER FAULT
89	7/Jul/21	BENGALURU	400	NELAMANGALA 400 - HIRIYUR 1	NO STATION AFFECTED	14:53:42(6-7-21)	18:48:54(7-7-21)	3:54	LINE CHARGED
90	7-Jul-21	GULBARGA	66	HOSAHALLI-CJHALLI	HOSAHALLI_66	23:30(06.07.2021)	17:15(07.07.2021)	17:45HRS	LINE CHARGED
91	7-Jul-21	GULBARGA	110	BADALADUKU-GUDEKOTE	GUDEKOTE_66	23:30(6.7.2021)	17:10(7.07.2021)	17:40 HRS	LINE CHARGED
92	7-Jul-21	GULBARGA	110	CHITGUPPA-NIRNA	NIRNA_110	23:39	23:41	0:02	MAIN SUPPLY FAILURE
93	7-Jul-21	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	19:45	19:48	0:03	MAIN SUPPLY FAILURE
94	7-Jul-21	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	20:00	21:25	1:25	MAIN SUPPLY FAILURE
95	7-Jul-21	GULBARGA	110	HALBARGA-ACME SOLAR_IPP	HALBARGA_220	18:08(06.07.2021)	01:05(07.07.2021)	6:57HRS	LINE CHARGED
96	7-Jul-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	16:48	16:53	0:05	LINE FAULT
97	7-Jul-21	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110	5:14	5:23	0:09	LINE FAULT
98	7-Jul-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
99	7-Jul-21	GULBARGA	110	HV1	KAMPLI_110	10:45	18:55	8:10	LINE CLEAR AVAILED
100	7-Jul-21	GULBARGA	110	HV1	SHAHAPUR_220	12:25	13:09	0:44	LINE CLEAR AVAILED
101	7-Jul-21	GULBARGA	110	HV2	KAMPLI_110	14:54	16:10	1:16	LINE CLEAR AVAILED
102	7-Jul-21	GULBARGA	110	HV2	MADIYAL_110	14:20	14:25	0:05	TRANSFORMER FAULT
103	7-Jul-21	GULBARGA	110	HV3	CHINCHOLI_110	2:05	2:10	0:05	TRANSFORMER FAULT
104	7-Jul-21	GULBARGA	110	HV3	CHINCHOLI_110	12:10	12:22	0:12	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
105	7-Jul-21	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	16:48	17:15	0:27	LINE FAULT
106	7-Jul-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	4:07	4:31	0:24	LINE FAULT
107	7-Jul-21	GULBARGA	110	MALLA-BYAGAWAT1	BYAGAWAT_110	23:34	23:44	0:10	LINE FAULT
108	7-Jul-21	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	19:21	19:31	0:10	LINE FAULT
109	7-Jul-21	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	13:55	14:05	0:10	LINE FAULT
110	7-Jul-21	GULBARGA	110	NALWAR-CLNSLR	NALWAR_110	16:50	17:00	0:10	LINE FAULT
111	7-Jul-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_00	14:42	14:50	0:08	LINE FAULT
112	7-Jul-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_00	20:21	20:26	0:05	LINE FAULT
113	7-Jul-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SIRWAR_110,ALKOD_110,BYAGAWATH_110,VALKAMDINN I_110(IDLE)	5:53	5:58	0:05	LINE FAULT
114	7-Jul-21	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	18:48	19:43	0:55	LINE CLEAR AVAILED
115	7-Jul-21	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	18:48	19:45	0:57	LINE CLEAR AVAILED
116	7-Jul-21	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	15:28	16:44	1:16	LINE FAULT
117	7-Jul-21	GULBARGA	110	SIDHANOOR-SIRAGUPPA	DHADESUGR_110,SIRIGUPPA,_110,TEKKAALKOTE_110	18:40(07.07.21)			LINE OPEN:LINE CLEAR AVAILED
118	7-Jul-21	GULBARGA	110	SINDHANOOR-110KV SINDHANOOR1	MASKI_110,MUDDAPUR_110	18:45(07.07.21)			LINE OPEN:LINE CLEAR AVAILED
119	7-Jul-21	GULBARGA	110	SINDHANOOR-110KV SINDHANOOR2(IDLE LINE)	SINDHANOOR	14:15(07.07.21)			LINE OPEN:LINE CLEAR AVAILED
120	7-Jul-21	GULBARGA	110	SINDHANOOR-AVDAVIAMARESHWARA	ADAVIAMARESHWARA_110	14:10(07.07.21)			LINE OPEN:LINE CLEAR AVAILED
121	7-Jul-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADONA_110,SR NAGAR_110,MALLAPUR_110	1:45	1:56	0:11	LINE FAULT
122	7-Jul-21	GULBARGA	110	SINDHANOOR-VALKAMDINI	VALKAMDINI_110	15:15(6.07.2021)			LINE OPEN:LINE CLEAR AVAILED
123	7-Jul-21	GULBARGA	220	HV1 & HV2	SEDAM_220	18:48	21:44	2:56	TRANSFORMER FAULT
124	7-Jul-21	GULBARGA	220	HV2	RAICHUR_220	11:12	12:50	1:38	LINE CLEAR AVAILED
125	7-Jul-21	GULBARGA	220	HV2	SHAHAPUR_220	4:48	4:54	0:06	TRANSFORMER FAULT
126	7-Jul-21	GULBARGA	220	LINGAPUR-JINDAL1	LINGAPUR_220	21:32(06.07.2021)	1:29(07.07.2021)	3:57HRS	LINE CHARGED
127	7-Jul-21	GULBARGA	220	LINGAPUR-JINDAL2	LINGAPUR_220	21:32(06.07.2021)	1:38(07.07.2021)	4:06HRS	LINE CHARGED
128	7-Jul-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	23:52(07.07.2021)			LINE OPEN:LINE FAULT
129	7-Jul-21	GULBARGA	220	RAICHUR-JURALA1(IDLE LINE)	RAICHUR_220	15:00(07.07.21)			LINE OPEN:LINE FAULT
130	7-Jul-21	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	18:48	21:44	2:56	LINE CLEAR AVAILED
131	7-Jul-21	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	18:48	21:44	2:56	LINE CLEAR AVAILED
132	7-Jul-21	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	18:48	21:44	2:56	LINE CLEAR AVAILED
133	7-Jul-21	GULBARGA	220	SHAHAPUR-LINGSUGUR	LINGSUGUR_220	12:36	12:57	0:21	LINE FAULT
134	7-Jul-21	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	11:50	11:55	0:05	LINE FAULT
135	7-Jul-21	HASSAN	66	HV2	HOLEHONNUR_66	12:55	15:10	2:15	LINE CLEAR AVAILED
136	7-Jul-21	HASSAN	110	HV1	KEMAR_220	20:49	20:52	0:03	TRANSFORMER FAULT
137	7-Jul-21	HASSAN	110	HV1	HOSANGADI_110	12:49	14:50	2:01	LINE CLEAR AVAILED
138	7-Jul-21	HASSAN	110	HV2	KEMAR_220	20:49	20:53	0:04	TRANSFORMER FAULT
139	7-Jul-21	HASSAN	110	HV2	ANAVATTI_110	23:12	23:20	0:08	TRANSFORMER FAULT
140	7-Jul-21	HASSAN	110	HV2	KULASHEKARA_110	3:23	9:20	5:57	TRANSFORMER FAULT
141	7-Jul-21	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN:LINE CLEAR AVAILED
142	7-Jul-21	HASSAN	110	LV1	KEMAR_220	20:49	20:54	0:05	TRANSFORMER FAULT
143	7-Jul-21	HASSAN	110	LV2	KEMAR_220	19:01	19:02	0:01	TRANSFORMER FAULT
144	7-Jul-21	HASSAN	220	KEMAR-MOBDRE	KEMAR_220	18:21	18:24	0:03	LINE FAULT
145	7-Jul-21	MYSORE	66	BESAGRALLY-DUNDANALLY	NO STATIONS EFFECTED	14:48	14:52	0:03	HAND TRIPPED
146	7-Jul-21	MYSORE	66	HOOTGALLY-ELWALA	NO STATIONS EFFECTED	11:08	13:16	2:08	LINE CLEAR AVAILED
147	7-Jul-21	MYSORE	66	HOOTGALLY-HAMPAPURA	NO STATIONS EFFECTED	10:24	13:35	3:11	LINE CLEAR AVAILED
148	7-Jul-21	MYSORE	66	HOOTGALLY-KHB STATION	NO STATIONS EFFECTED	10:55	13:30	2:35	LINE CLEAR AVAILED
149	7-Jul-21	MYSORE	66	HOOTGALLY-KHB STATION	NO STATIONS EFFECTED	11:09	13:17	2:08	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
150	7-Jul-21	MYSORE	66	HOOTGALLY-MCF	NO STATIONS EFFECTED	9:50	13:45	3:55	LINE CLEAR AVAILED
151	7-Jul-21	MYSORE	66	HV1	JYOTHINAGARA_66	11:00	12:23	1:22	LINE CLEAR AVAILED
152	7-Jul-21	MYSORE	66	HV1	MADHUVANAHALLI_220	9:41	10:03	0:22	TRANSFORMER FAULT
153	7-Jul-21	MYSORE	66	HV2	JYOTHINAGARA_66	12:24	13:32	1:08	LINE CLEAR AVAILED
154	7-Jul-21	MYSORE	66	HV2	SANTHEMARAHALLI_66	12:15	13:36	1:21	LINE CLEAR AVAILED
155	7-Jul-21	MYSORE	66	KADAKOLA-MANDAKALLY	MANDAKALLI_66	7:18	7:30	0:11	LINE FAULT
156	7-Jul-21	MYSORE	66	KUSHALNAGARA-MERCERA-1	MADIKERI_66	10:29	10:50	0:21	LINE FAULT
157	7-Jul-21	MYSORE	66	KUSHALNAGARA-SUNTIKOPPA	SUNTIKOPPA_66	10:29	10:50	0:21	LINE FAULT
158	7-Jul-21	MYSORE	66	MADHUVANAHALLY-DODDINDUVADI	DODDINADUVADI_66 KOTTANUR_66	9:41	10:03	0:22	LINE FAULT
159	7-Jul-21	MYSORE	66	MADHUVANAHALLY-HANNUR 1	AJJIPURA_66 BANDALLI_66 COWDALLI_66 HANNUR_66 MARTAHALLI_66 RAMAPURA_MYS_66	9:41	10:03	0:22	LINE FAULT
160	7-Jul-21	MYSORE	66	MADHUVANAHALLY-HANNUR 2	AJJIPURA_66 BANDALLI_66 COWDALLI_66 HANNUR_66 MARTAHALLI_66 RAMAPURA_MYS_66	9:41	10:03	0:22	LINE FAULT
161	7-Jul-21	MYSORE	66	MADHUVANAHALLY-HEBBANI	NO STATIONS EFFECTED	6:18	6:31	0:12	LINE FAULT
162	7-Jul-21	MYSORE	66	MADHUVANAHALLY-KOLLEGALA 1	NO STATIONS EFFECTED	9:41	9:57	0:16	LINE FAULT
163	7-Jul-21	MYSORE	66	MADHUVANAHALLY-KUNTUR	NO STATIONS EFFECTED	9:41	9:57	0:16	LINE FAULT
164	7-Jul-21	MYSORE	66	MADHUVANAHALLY-MAMBALLI	NO STATIONS EFFECTED	9:41	10:01	0:20	LINE FAULT
165	7-Jul-21	MYSORE	66	MADHUVANAHALLY-PG PALYA	PGPALYA_66	9:41	9:52	0:11	LINE FAULT
166	7-Jul-21	MYSORE	66	MYSORE SOUTH-BOGADHI	NO STATIONS EFFECTED	13:32	14:49	1:17	LINE CLEAR AVAILED
167	7-Jul-21	MYSORE	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
168	7-Jul-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	6:08	6:48	0:40	LINE FAULT
169	7-Jul-21	TUMKUR	66	CHITRADURGA 220kv- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	11:40	12:35	0:55	HAND TRIPPED
170	7-Jul-21	TUMKUR	66	CHITRADURGA 220kv- SUZLON 2	SUZLON1_IPP_66,	11:40	12:36	0:55	HAND TRIPPED
171	7-Jul-21	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	7:18	7:34	0:15	HAND TRIPPED
172	7-Jul-21	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	11:40	12:29	0:49	HAND TRIPPED
173	7-Jul-21	TUMKUR	66	CHITRADURGA 66kv- MEGMICON 1_IPP_66	MEGMICON 1_IPP_66	10:30	10:58	0:28	LINE CLEAR AVAILED
174	7-Jul-21	TUMKUR	66	CHITRADURGA 66kv- MEGMICON 2_IPP_66	MEGMICON 2_IPP_66	10:30	10:59	0:28	LINE CLEAR AVAILED
175	7-Jul-21	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	12:16	12:26	0:10	MAIN SUPPLY FAILURE
176	7-Jul-21	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	12:03	12:17	0:14	HAND TRIPPED
177	7-Jul-21	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	12:02	12:17	0:14	HAND TRIPPED
178	7-Jul-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	12:21	12:29	0:08	LINE FAULT
179	7-Jul-21	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	11:02	11:10	0:07	LINE FAULT
180	7-Jul-21	TUMKUR	66	KORATAGERE-HOLAVANHALLI	KORATAGERE_66	9:20	13:36	4:16	MAIN SUPPLY FAILURE
181	7-Jul-21	TUMKUR	66	TR-1	BENKIKERE_66	18:09	18:18	0:09	TRANSFORMER FAULT
182	7-Jul-21	TUMKUR	66	TR-1	BUKKAPATNA_66	12:50	13:15	0:25	LINE CLEAR AVAILED
183	7-Jul-21	TUMKUR	66	TR-1	GARAGA_66	10:42	16:37	5:54	LINE CLEAR AVAILED
184	7-Jul-21	TUMKUR	66	TR-1	NAGASAMUDRA_66	0:13	0:28	0:14	TRANSFORMER FAULT
185	7-Jul-21	TUMKUR	66	TR-2	BUKKAPATNA_66	11:47	12:48	1:01	LINE CLEAR AVAILED
186	7-Jul-21	TUMKUR	66	TR-2	CHANNAGIRI_66	7:01	7:30	0:29	HAND TRIPPED
187	7-Jul-21	TUMKUR	66	TR-2	GARAGA_66	10:42	16:37	5:54	LINE CLEAR AVAILED
188	7-Jul-21	TUMKUR	66	TR-2	RAMPURA_66	16:21	16:49	0:27	LINE CLEAR AVAILED
189	7-Jul-21	TUMKUR	66	TR-2	SHYLAPURA_66	12:07	12:47	0:40	LINE CLEAR AVAILED
190	7-Jul-21	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	11:42	12:27	0:45	LINE CLEAR AVAILED
191	7-Jul-21	TUMKUR	110	TR-2	MAYASANDRA_110	12:49	14:24	1:34	LINE CLEAR AVAILED
192	7-Jul-21	TUMKUR	110	TR-2	MAYASANDRA_110	16:05	16:30	0:25	LINE CLEAR AVAILED
193	7-Jul-21	TUMKUR	220	TR-1	HIRIYUR_220	12:02	12:12	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
194	7-Jul-21	TUMKUR	220	TR-3	CHITRADURGA_220	11:42	12:25	0:43	LINE CLEAR AVAILED
1	8-Jul-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
2	8-Jul-21	BAGALKOT	110	110/11KV,HV1	HIREKERUR_110	14:33	15:33	1:00	LINE CLEAR AVAILED
3	8-Jul-21	BAGALKOT	110	110/11KV,HV1	HUDLI_110	15:35	16:47	1:12	LINE CLEAR AVAILED
4	8-Jul-21	BAGALKOT	110	110/11KV,HV1	LAXMESHWAR_110	11:09	11:20	0:11	HAND TRIPPED
5	8-Jul-21	BAGALKOT	110	110/11KV,HV1	YELPARHATTI_110	11:36	13:00	1:24	LINE CLEAR AVAILED
6	8-Jul-21	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	15:59	16:24	0:25	LINE CLEAR AVAILED
7	8-Jul-21	BAGALKOT	110	110/11KV,HV2	YELPARHATTI_110	11:36	13:00	1:24	LINE CLEAR AVAILED
8	8-Jul-21	BAGALKOT	110	110/11KV,HV2(HV1)	SALAHALLI_110	16:08	17:36	1:28	TRANSFORMER FAULT
9	8-Jul-21	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	7:51	8:22	0:31	HAND TRIPPED
10	8-Jul-21	BAGALKOT	110	110/11KV,HV3	LAXMESHWAR_110	11:06	11:10	0:04	HAND TRIPPED
11	8-Jul-21	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110 & ALNAVAR_33	1:11	1:15	0:04	TRANSFORMER FAULT
12	8-Jul-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
13	8-Jul-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
14	8-Jul-21	BAGALKOT	110	ANKALAGI-HUDLI(BELGAUM2)	ANKALAGI_110	15:20	16:51	1:31	LINE CLEAR AVAILED
15	8-Jul-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
16	8-Jul-21	BAGALKOT	110	BELLATTI-ENERCON2	BELLATTI_110	7:27	8:16	0:49	HAND TRIPPED
17	8-Jul-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
18	8-Jul-21	BAGALKOT	110	HIDIKAL DAM-GHATAPRABHA	HIDIKAL DAM_110	16:50	20:17	3:27	NFBC ISSUED
19	8-Jul-21	BAGALKOT	110	HUDLI-BSPL	HUDLI_110	15:19	16:46	1:27	LINE CLEAR AVAILED
20	8-Jul-21	BAGALKOT	110	HUNGUND-KBJNL	HUNGUND_110	13:13	13:24	0:11	HAND TRIPPED
21	8-Jul-21	BAGALKOT	110	KUDACHI-AINAPUR(KUDACHI)	AINAPUR_110	14:48	14:51	0:03	LINE FAULT
22	8-Jul-21	BAGALKOT	110	KUDUCHI220-YELPARHATTI	YELPARHATTI_110	11:36	13:00	1:24	LINE CLEAR AVAILED
23	8-Jul-21	BAGALKOT	110	MAHALINGAPUR(NAVALAGI)-JAMAKHANDI	STATION NOT AFFECTED JAMAKHANDI_110	21:13 (06.07.2021)			LINE OPEN:LINE CLEAR AVAILED
24	8-Jul-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
25	8-Jul-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
26	8-Jul-21	BAGALKOT	110	SHIRAHATTI-LAXMESHWAR	SHIRAHATTI_110	7:26	15:49	8:23	LINE CLEAR AVAILED
27	8-Jul-21	BAGALKOT	110	UMAMACHAGI-KIRUVATTI	STATION NOT AFFECTED UMMACHAGI_110	8:33 (06.07.2021)			LINE OPEN:LINE CLEAR AVAILED
28	8-Jul-21	BAGALKOT	220	220/110KV,HV1,LV1	KUDUCHI_220	6:00	6:20	0:20	TRANSFORMER FAULT
29	8-Jul-21	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	5:34	6:04	0:30	HAND TRIPPED
30	8-Jul-21	BAGALKOT	220	BELGAUM-KANABARGI2	STATION NOT AFFECTED BELGAUM_220	5:31	5:58	0:27	LINE FAULT
31	8-Jul-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	10:35	13:22	2:47	LINE CLEAR AVAILED
32	8-Jul-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
33	8-Jul-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
34	8-Jul-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	17:46 (03.07.2021)			LINE OPEN:LINE CLEAR AVAILED
35	8-Jul-21	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	10:09 (03.07.2021)			LINE OPEN:LINE CLEAR AVAILED
36	8-Jul-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
37	8-Jul-21	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
38	8-Jul-21	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	11:34	13:37	2:03	LINE CLEAR AVOIDED
39	8-Jul-21	BENGALURU	66	GUNDLU KOTTUR - MITTEMARI 220	GUNDLU KOTTUR	10:00	10:16	0:16	LINE CLEAR AVOIDED
40	8-Jul-21	BENGALURU	66	HSR LAYOUT - ADUGODI 1	JAKKASANDRA	11:20	11:27	0:07	LINE CLEAR AVOIDED
41	8-Jul-21	BENGALURU	66	HV1	MITTEMARI 220	5:42	6:07	0:25	MAIN SUPPLY FAILURE
42	8-Jul-21	BENGALURU	66	HV1	HUKUNDA	23:30	23:40	0:10	TRANSFORMER FAULT
43	8-Jul-21	BENGALURU	66	HV2	HSR LAYOUT	10:46	11:18	0:32	LINE CLEAR AVOIDED
44	8-Jul-21	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
45	8-Jul-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	6:36	6:42	0:06	LINE FAULT
46	8-Jul-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	11:11	15:42	4:31	LINE CLEAR AVOIDED
47	8-Jul-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	6:36	6:43	0:07	LINE FAULT
48	8-Jul-21	BENGALURU	66	KORAMANGALA 220 - GOLF LINK HAL 2	K & C VALLEY, NAL (EHT)	12:20	12:48	0:28	LINE FAULT
49	8-Jul-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	13:15	15:29	2:14	MAIN SUPPLY FAILURE
50	8-Jul-21	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	13:15	14:48	1:33	MAIN SUPPLY FAILURE
51	8-Jul-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:02	15:10	3:08	MAIN SUPPLY FAILURE
52	8-Jul-21	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	12:02	15:10	3:08	MAIN SUPPLY FAILURE
53	8-Jul-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	13:15	14:47	1:32	MAIN SUPPLY FAILURE
54	8-Jul-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	13:15	14:36	1:21	MAIN SUPPLY FAILURE
55	8-Jul-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	5:42	6:05	0:23	MAIN SUPPLY FAILURE
56	8-Jul-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	5:42	5:56	0:14	MAIN SUPPLY FAILURE
57	8-Jul-21	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	5:42	5:56	0:14	MAIN SUPPLY FAILURE
58	8-Jul-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	5:42	6:05	0:23	MAIN SUPPLY FAILURE
59	8-Jul-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	5:42	5:56	0:14	MAIN SUPPLY FAILURE
60	8-Jul-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	5:42	6:09	0:27	MAIN SUPPLY FAILURE
61	8-Jul-21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	5:42	5:56	0:14	MAIN SUPPLY FAILURE
62	8-Jul-21	BENGALURU	66	VOKKALERI - KOLAR 220	VOKKALERI	14:00	15:30	1:30	LOAD CHANGEVER
63	8-Jul-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
64	8-Jul-21	BENGALURU	66	YEDUMADU - KANAKPURA 220	YEDUMADU	10:16	10:20	0:04	LOAD CHANGEVER
65	8-Jul-21	BENGALURU	220	HV1	MITTEMARI 220	5:42	5:58	0:16	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
66	8-Jul-21	BENGALURU	220	HV2	MITTEMARI 220	5:42	5:55	0:13	TRANSFORMER FAULT
67	8-Jul-21	BENGALURU	220	LV1	MALUR 220	13:15	14:33	1:18	LINE CLEAR AVAILED
68	8-Jul-21	BENGALURU	220	LV2	MALUR 220	13:17	14:35	1:18	LINE CLEAR AVAILED
69	8-Jul-21	GULBARGA	66	HOSAHALLI-CJHALLI	HOSAHALLI_66	6:20	6:40	0:20	MAIN SUPPLY FAILURE
70	8-Jul-21	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALU_110,KUDITINI_110,KURUGOD_110,SHATHVA HANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAMALAPUR_110, METRI_110,RBNSFACTORY_110	5:00	5:09	0:09	LINE FAULT
71	8-Jul-21	GULBARGA	110	ALIPUR-TEKKALKOTE	TEKKALAKOTE_110	5:00	5:10	0:10	MAIN SUPPLY FAILURE
72	8-Jul-21	GULBARGA	110	CHITGUPPA-NIRNA	NIRNA_110	0:37	0:40	0:03	MAIN SUPPLY FAILURE
73	8-Jul-21	GULBARGA	110	GULBARGA SOUTH -GULBARGA UNIVERSITY	GULBARGA SOUTH_110	17:15	17:25	0:10	NFBC ISSUED
74	8-Jul-21	GULBARGA	110	GULBARGA SOUTH -GULBARGA WEST	GULBARGA SOUTH_110	5:30(8.7.21)			LINE OPEN:LINE CLEAR AVAILED
75	8-Jul-21	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	5:50	14:10	8:20	MAIN SUPPLY FAILURE
76	8-Jul-21	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	19:05	19:15	0:10	MAIN SUPPLY FAILURE
77	8-Jul-21	GULBARGA	110	HALBARGA-BHALKI_110	BHALKI_110,MGSSK_IPP,LADHA_110,BHALKI SUGAR_IPP	6:58	7:06	0:08	LINE FAULT
78	8-Jul-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	4:26	4:29	0:03	LINE FAULT
79	8-Jul-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	5:26	5:29	0:03	LINE FAULT
80	8-Jul-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	6:10	6:44	0:34	LINE FAULT
81	8-Jul-21	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	2:57	3:10	0:13	LINE FAULT
82	8-Jul-21	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	5:50	5:57	0:07	MAIN SUPPLY FAILURE
83	8-Jul-21	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110	5:14	5:23	0:09	LINE FAULT
84	8-Jul-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
85	8-Jul-21	GULBARGA	110	HV1	GULBARGA SOUTH_110	5:30	5:40	0:10	TRANSFORMER FAULT
86	8-Jul-21	GULBARGA	110	HV1	SHAHAPUR_220	21:40	21:54	0:14	TRANSFORMER FAULT
87	8-Jul-21	GULBARGA	110	HV1	HUMNABAD_220	12:06	12:58	0:52	LINE CLEAR AVAILED
88	8-Jul-21	GULBARGA	110	HV1	SHAHAPUR_220	20:58	21:16	0:18	TRANSFORMER FAULT
89	8-Jul-21	GULBARGA	110	HV1	SHAHAPUR_220	23:04	23:14	0:10	TRANSFORMER FAULT
90	8-Jul-21	GULBARGA	110	HV2	GULBARGA SOUTH_110	5:30	5:40	0:10	TRANSFORMER FAULT
91	8-Jul-21	GULBARGA	110	HV2	HATTI_110	9:47	9:55	0:08	TRANSFORMER FAULT
92	8-Jul-21	GULBARGA	110	HV2	BELLARY SOUTH_110	12:28	13:00	0:32	LINE CLEAR AVAILED
93	8-Jul-21	GULBARGA	110	HV3	HATTI_110	2:57	3:13	0:16	TRANSFORMER FAULT
94	8-Jul-21	GULBARGA	110	HV3	KEREHALLI_110	21:21	21:56	0:35	TRANSFORMER FAULT
95	8-Jul-21	GULBARGA	110	HV3	KEREHALLI_110	22:05	22:30	0:25	TRANSFORMER FAULT
96	8-Jul-21	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	4:22	4:30	0:08	LINE FAULT
97	8-Jul-21	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	5:20	5:35	0:15	LINE FAULT
98	8-Jul-21	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	19:20	19:30	0:10	LINE FAULT
99	8-Jul-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	2:40	3:15	0:35	LINE FAULT
100	8-Jul-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	4:35	4:45	0:10	LINE FAULT
101	8-Jul-21	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,SUGAR FACTORY,CHOWDAPUR_110	2:40	3:16	0:36	LINE CLEAR AVAILED
102	8-Jul-21	GULBARGA	110	MADIYAL-CHOWDAR	CHOWDAR_110	22:10	22:18	0:08	LINE FAULT
103	8-Jul-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	3:04	3:23	0:19	LINE FAULT
104	8-Jul-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	14:59	15:09	0:10	LINE FAULT
105	8-Jul-21	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	3:16	3:26	0:10	LINE FAULT
106	8-Jul-21	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	19:54	20:08	0:14	LINE FAULT
107	8-Jul-21	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	21:51	22:04	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
108	8-Jul-21	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	2:15	2:50	0:35	LINE FAULT
109	8-Jul-21	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	2:15	2:50	0:35	LINE FAULT
110	8-Jul-21	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	3:26	3:34	0:08	LINE FAULT
111	8-Jul-21	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	4:22	4:34	0:12	LINE FAULT
112	8-Jul-21	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	20:14	20:24	0:10	LINE FAULT
113	8-Jul-21	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	22:17	22:27	0:10	LINE FAULT
114	8-Jul-21	GULBARGA	110	MALLAT-BYAGAWAT2(IDLE LINE)	ADAVIAMARESHWARA_110	23:10	23:22	0:12	LINE FAULT
115	8-Jul-21	GULBARGA	110	MALLAT-VALKAMDINI	VALKAMDINI_110	3:20	3:30	0:10	MAIN SUPPLY FAILURE
116	8-Jul-21	GULBARGA	110	NALWAR-CLNSLR	NALWAR_110	19:05	19:15	0:10	LINE FAULT
117	8-Jul-21	GULBARGA	110	NALWAR-CLNSLR	NALWAR_110	21:00	21:15	0:15	LINE FAULT
118	8-Jul-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SIRWAR_110,ALKOD_110,BYAGAWATH_110,VALKAMDINN I_110(IDLE)	2:45	2:50	0:05	LINE FAULT
119	8-Jul-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SIRWAR_110,ALKOD_110,BYAGAWATH_110,VALKAMDINN I_110(IDLE)	5:18	7:38	2:20	LINE FAULT
120	8-Jul-21	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI_110	4:49	4:59	0:10	LINE FAULT
121	8-Jul-21	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI_110	19:43	19:48	0:05	LINE FAULT
122	8-Jul-21	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI_110	21:48	21:56	0:08	LINE FAULT
123	8-Jul-21	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI_110	23:16	23:20	0:04	LINE FAULT
124	8-Jul-21	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	5:55	10:52	4:57	LINE CLEAR AVAILED
125	8-Jul-21	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	19:10	19:19	0:09	LINE FAULT
126	8-Jul-21	GULBARGA	110	SEDAM-ULTRATECH_IPP	SEDAM_220	23:22	23:38	0:16	LINE FAULT
127	8-Jul-21	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	5:47	18:30	12:43	LINE FAULT
128	8-Jul-21	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	6:00	10:30	4:30	LINE CLEAR AVAILED
129	8-Jul-21	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUK A_IPP,AFZALPUR_110,KARAJAGI_110	1:05	1:10	0:05	LINE FAULT
130	8-Jul-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	1:50	2:03	0:13	LINE FAULT
131	8-Jul-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	3:14	4:08	0:54	LINE FAULT
132	8-Jul-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	21:29	22:08	0:39	LINE FAULT
133	8-Jul-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	23:59(08.07.2021)			LINE OPEN:LINE FAULT
134	8-Jul-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	2:06	2:15	0:09	LINE FAULT
135	8-Jul-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	2:39	2:52	0:13	LINE FAULT
136	8-Jul-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	5:20	5:37	0:17	LINE FAULT
137	8-Jul-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	20:18	2:57	6:39	LINE FAULT
138	8-Jul-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	21:18	21:33	0:15	LINE FAULT
139	8-Jul-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	22:56	23:18	0:22	LINE FAULT
140	8-Jul-21	GULBARGA	110	SHAHBAD-NALWAR	NALWAR_110	2:35	3:15	0:40	MAIN SUPPLY FAILURE
141	8-Jul-21	GULBARGA	110	SIDHANOOR-SIRAGUPPA	DHADESUGR_110,SIRIGUPPA_110,TEKKAALKOTE_110	18:40(07.07.2021)	10:35(08.07.2021)	15:50HRS	LINE CHARGED
142	8-Jul-21	GULBARGA	110	SINDHANOOR-110KV SINDHANOOR1	MASKI_110,MUDDAPUR_110	18:45(07.07.2021)	10:55(08.07.2021)	16:10HRS	LINE CHARGED
143	8-Jul-21	GULBARGA	110	SINDHANOOR-110KV SINDHANOOR2(IDLE LINE)	IDLE LINE	14:15(07.07.2021)	12:20(08.07.2021)	22:05HRS	LINE CHARGED
144	8-Jul-21	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA(IDLE LINE)	ADAVIAMARESHWARA_110	14:10(07.07.2021)	15:30(08.07.2021)	25:20HRS	LINE CHARGED
145	8-Jul-21	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA(IDLE LINE)	ADAVIAMARESHWARA_110	21:35	21:45	0:10	LINE FAULT
146	8-Jul-21	GULBARGA	110	SINDHANOOR-VALKAMDINI	VALKAMDINI_110	15:15(6.07.2021)	20:05(8.7.2021)	52:50HRS	LINE CHARGED
147	8-Jul-21	GULBARGA	220	HALBARGA-HUMNABAD1	HALBARGA_220	6:09	13:15	7:06	LINE FAULT
148	8-Jul-21	GULBARGA	220	HUMNABAD-HALBARGA	HALBARGA_220	6:09	6:34	0:25	LINE FAULT
149	8-Jul-21	GULBARGA	220	HV1	SHAHABAD_220	2:40	4:30	1:50	TRANSFORMER FAULT
150	8-Jul-21	GULBARGA	220	HV1 & HV2	SEDAM_220	5:55	6:41	0:46	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
151	8-Jul-21	GULBARGA	220	HV2	SHAHABAD_220	2:40	3:15	0:35	TRANSFORMER FAULT
152	8-Jul-21	GULBARGA	220	HV2	KAPNOOR_220	2:38	3:09	0:31	TRANSFORMER FAULT
153	8-Jul-21	GULBARGA	220	KAPNOOR-SHAHAPUR	KAPNOOR_220	2:38	3:50	1:12	LINE FAULT
154	8-Jul-21	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	3:48	4:08	0:20	LINE FAULT
155	8-Jul-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	19:48	20:03	0:15	LINE FAULT
156	8-Jul-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	23:52(07.07.2021)	00:22(08.07.2021)	0.:30hrs	LINE CHARGED
157	8-Jul-21	GULBARGA	220	RAICHUR-JURALA1(IDLE LINE)	RAICHUR_220	15:00(07.07.2021)	13:00(08.07.2021)	22:00HRS	LINE CHARGED
158	8-Jul-21	GULBARGA	220	SEDAM-RTPS2	RTPS_220	4:42	5:04	0:22	LINE FAULT
159	8-Jul-21	GULBARGA	220	SHAHABAD-KAPANOOR	KAPANOOR_220	2:40	3:15	0:35	LINE FAULT
160	8-Jul-21	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	2:40	3:20	0:40	LINE FAULT
161	8-Jul-21	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	2:38	3:51	1:13	LINE FAULT
162	8-Jul-21	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	2:38	3:24	0:46	LINE FAULT
163	8-Jul-21	HASSAN	66	HV1	BYACHANAHALLY_66	12:20	13:20	1:00	LINE CLEAR AVAILED
164	8-Jul-21	HASSAN	66	HV1	CHIKMAGALUR_66	15:57	18:53	2:56	LINE CLEAR AVAILED
165	8-Jul-21	HASSAN	66	HV1	BASAVAGHATTA_66	13:58	15:36	1:38	LINE CLEAR AVAILED
166	8-Jul-21	HASSAN	66	HV2	MALLAPURA_66	15:20	15:41	0:21	HAND TRIPPED
167	8-Jul-21	HASSAN	66	HV2	BASAVAGHATTA_66	11:24	14:15	2:51	LINE CLEAR AVAILED
168	8-Jul-21	HASSAN	110	HV1	JAVAGAL_110	17:05	17:20	0:15	TRANSFORMER FAULT
169	8-Jul-21	HASSAN	110	HV1	NANDIKUR_110	13:14	16:19	3:05	LINE CLEAR AVAILED
170	8-Jul-21	HASSAN	110	HV3	PUTTUR_110	10:00	14:42	4:42	LINE CLEAR AVAILED
171	8-Jul-21	HASSAN	110	HV3	PUTTUR_220	10:00	14:42	4:42	LINE CLEAR AVAILED
172	8-Jul-21	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN:LINE CLEAR AVAILED
173	8-Jul-21	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	12:15	16:58	4:43	LINE CLEAR AVAILED
174	8-Jul-21	HASSAN	110	LV3	KEMAR_220	11:50	14:06	2:16	LINE CLEAR AVAILED
175	8-Jul-21	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	12:08	16:54	4:46	LINE CLEAR AVAILED
176	8-Jul-21	HASSAN	110	SHIRAL-SHKARPURA	SHIRAKOPPA_110L	10:09	10:28	0:19	HAND TRIPPED
177	8-Jul-21	HASSAN	110	SHIRAL-SHKARPURA	SHIRAKOPPA_110L	16:28	16:34	0:06	HAND TRIPPED
178	8-Jul-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	10:15	16:33	6:18	LINE CLEAR AVAILED
179	8-Jul-21	HASSAN	220	HV3	KEMAR_220	11:50	14:06	2:16	LINE CLEAR AVAILED
180	8-Jul-21	HASSAN	220	KEMAR-UPCL2	KEMAR_220	13:07	13:20	0:13	LINE FAULT
181	8-Jul-21	HASSAN	220	UPCL-KEMAR1	upcl_gen	13:06	13:17	0:11	LINE FAULT
182	8-Jul-21	HASSAN	220	UPCL-KEMAR2	upcl_gen	13:06	13:20	0:14	LINE FAULT
183	8-Jul-21	MYSORE	66	FTS-BANNIMANTAPA	NO STATIONS EFFECTED	8:44	14:15	5:30	NFBC ISSUED
184	8-Jul-21	MYSORE	66	HV1	DATTAGALLY_66	12:24	17:14	4:49	LINE CLEAR AVAILED
185	8-Jul-21	MYSORE	66	HV1	MANDGERE_66	11:01	11:57	0:56	TRANSFORMER FAULT
186	8-Jul-21	MYSORE	66	HV1	SANIVARASANTHE_66	16:00	16:26	0:26	LINE CLEAR AVAILED
187	8-Jul-21	MYSORE	66	HV2	JAIPUR_66	12:25	13:26	1:01	LINE CLEAR AVAILED
188	8-Jul-21	MYSORE	66	HV2	YELANDUR_66	12:19	12:50	0:31	LINE CLEAR AVAILED
189	8-Jul-21	MYSORE	66	KUSHALNAGARA-HARANGI	NO STATIONS EFFECTED	16:47	17:06	0:19	HAND TRIPPED
190	8-Jul-21	MYSORE	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
191	8-Jul-21	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR _66	YEDIYUR_66,THIPPUR_,JIDDEGERE_66	13:45	13:58	0:12	LINE FAULT
192	8-Jul-21	TUMKUR	66	AVAREGERE 66kV-DAVANGERE SRS	AVAREGERE_66	17:03	17:27	0:24	LINE CLEAR AVAILED
193	8-Jul-21	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	10:07	18:39	8:31	LINE CLEAR AVAILED
194	8-Jul-21	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66,KADAJJI_66,MELEKATTE_66	10:05	13:23	3:17	LINE CLEAR AVAILED
195	8-Jul-21	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	CHIKKAJAJUR_66,MAYAKONDA_66,SASALUHALLA_66	3:01	3:09	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
196	8-Jul-21	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	9:05	9:19	0:13	LINE FAULT
197	8-Jul-21	TUMKUR	66	KUNDUR-SUZLON1_IPP_66	SUZLON1_IPP_66	19:08	19:22	0:13	LINE FAULT
198	8-Jul-21	TUMKUR	66	KUNDUR-SUZLON1_IPP_66	SUZLON1_IPP_66	19:40	19:58	0:18	LINE FAULT
199	8-Jul-21	TUMKUR	66	KUNDUR-SUZLON1_IPP_66	SUZLON1_IPP_66	20:45	20:59	0:14	LINE FAULT
200	8-Jul-21	TUMKUR	66	KUNDUR-SUZLON1_IPP_66	SUZLON1_IPP_66	22:08	22:23	0:14	LINE FAULT
201	8-Jul-21	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	PULAMG_66	0:12	1:16	1:04	LINE CLEAR AVAILED
202	8-Jul-21	TUMKUR	66	PULAMGHATTA66-MADHUGIRI220	PULAMG_66	0:07	1:17	1:10	LINE CLEAR AVAILED
203	8-Jul-21	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	9:24	15:12	5:47	LINE CLEAR AVAILED
204	8-Jul-21	TUMKUR	66	THALLAK 220kv- BGKERE 1	BGKERE_66	19:10	19:37	0:26	LINE FAULT
205	8-Jul-21	TUMKUR	66	THALLAK 220kv- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	19:10	19:51	0:40	LINE FAULT
206	8-Jul-21	TUMKUR	66	THALLAK 220kv- GOWRASAMUDRA	GOWRASAMUDRA_66	19:10	19:40	0:30	LINE FAULT
207	8-Jul-21	TUMKUR	66	THALLAK 220kv- GOWRASAMUDRA	GOWRASAMUDRA_66	19:51	19:57	0:06	LINE FAULT
208	8-Jul-21	TUMKUR	66	THALLAK 220kv- NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLANAHOLE_66	19:25	19:39	0:14	HAND TRIPPED
209	8-Jul-21	TUMKUR	66	TR-1	NYAMATHI_66	9:25	9:55	0:29	TRANSFORMER FAULT
210	8-Jul-21	TUMKUR	66	TR-1	SOKKE_66	9:21	15:12	5:51	LINE CLEAR AVAILED
211	8-Jul-21	TUMKUR	66	TR-1	AVAREGERE_66	10:02	17:03	7:01	LINE CLEAR AVAILED
212	8-Jul-21	TUMKUR	66	TR-2	KOLALA_66	13:30	13:58	0:28	LINE CLEAR AVAILED
213	8-Jul-21	TUMKUR	66	TR-2	AVAREGERE_66	10:02	17:47	7:44	LINE CLEAR AVAILED
214	8-Jul-21	TUMKUR	66	TR-2	AVAREGERE_66	17:27	17:47	0:19	NFBC ISSUED
215	8-Jul-21	TUMKUR	66	TR-2(LV SIDE)	THALLAKK_220	19:10	20:06	0:55	TRANSFORMER FAULT
216	8-Jul-21	TUMKUR	110	TR-2	MAYASANDRA_110	9:18	18:29	9:10	LINE CLEAR AVAILED
217	8-Jul-21	TUMKUR	110	TR-3	GUBBI_110	13:00	16:18	3:18	LINE CLEAR AVAILED
218	9-Jul-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
219	9-Jul-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
220	9-Jul-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
221	9-Jul-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
222	9-Jul-21	BAGALKOT	110	DAMABAL-SUZLON 2	DAMBAL_110	6:05	7:32	1:27	LINE FAULT
223	9-Jul-21	BAGALKOT	110	GM NAVAR - SALAHALLI	SALAHALLI_110	13:30	15:28	1:58	LINE CLEAR AVAILED
224	9-Jul-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
225	9-Jul-21	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	1:40	1:52	0:12	LINE FAULT
226	9-Jul-21	BAGALKOT	110	MAHALINGAPUR(NAVALAGI)-JAMAKHANDI	STATION NOT AFFECTED JAMAKHANDI_110	21:13 (06.07.2021)			LINE OPEN:LINE CLEAR AVAILED
227	9-Jul-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
228	9-Jul-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
229	9-Jul-21	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110	2:32	2:40	0:08	LINE FAULT
230	9-Jul-21	BAGALKOT	110	UMAMACHAGI-KIRUVATTI	STATION NOT AFFECTED UMMACHAGI_110	8:33 (06.07.2021)			LINE OPEN:LINE CLEAR AVAILED
231	9-Jul-21	BAGALKOT	110	VIJAYNAGAR SUGARS- MUNDARGI	MUNDARGI_110	6:05	10:02	3:57	LINE FAULT
232	9-Jul-21	BAGALKOT	220	BAGEWADI-ADPH 2	BAGEWADI_220	12:27	14:43	2:16	LINE FAULT
233	9-Jul-21	BAGALKOT	220	BAGEWADI-FORTUNE FIEVE 1	BAGEWADI_220	15:47	16:52	1:05	LINE CLEAR AVAILED
234	9-Jul-21	BAGALKOT	220	BAGEWADI-NANDIHAL 1&2(BIJAPUR)	BAGEWADI_220	17:16	22:23	5:07	LINE CLEAR AVAILED
235	9-Jul-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
236	9-Jul-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
237	9-Jul-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	17:46 (03.07.2021)			LINE OPEN:LINE CLEAR AVAIED
238	9-Jul-21	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	10:09 (03.07.2021)			LINE OPEN:LINE CLEAR AVAIED
239	9-Jul-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
240	9-Jul-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAIED
241	9-Jul-21	BENGALURU	66	CHINTAMANI 66 - SM MANGALA	SM MANGALA, SUGUTUR	8:39	9:55	1:16	LINE FAULT
242	9-Jul-21	BENGALURU	66	CHINTAMANI 66 - SM MANGALA	SM MANGALA, SUGUTUR	11:40	11:58	0:18	LINE CLEAR AVAIED
243	9-Jul-21	BENGALURU	66	HV1	BANASWADI	11:20	11:22	0:02	LINE CLEAR AVAIED
244	9-Jul-21	BENGALURU	66	HV1	SADLI	11:20	11:30	0:10	LINE CLEAR AVAIED
245	9-Jul-21	BENGALURU	66	HV2	SOMAYAJANAHALLI	3:05	5:40	2:34	TRANSFORMER FAULT
246	9-Jul-21	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
247	9-Jul-21	BENGALURU	66	ISKON - SOMANAHALLI 220	ISKON, SUBRAMANYAPURA 66	14:52	14:58	0:06	LOAD CHANGEOVER
248	9-Jul-21	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI	3:08	5:35	2:26	LINE FAULT
249	9-Jul-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	9:53	9:58	0:05	LOAD CHANGEOVER
250	9-Jul-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	10:20	10:26	0:06	MAIN SUPPLY FAILURE
251	9-Jul-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	15:56	16:01	0:05	LOAD CHANGEOVER
252	9-Jul-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	22:25	22:29	0:04	MAIN SUPPLY FAILURE
253	9-Jul-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	9:53	9:58	0:05	LOAD CHANGEOVER
254	9-Jul-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	10:20	10:26	0:06	MAIN SUPPLY FAILURE
255	9-Jul-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	15:56	16:01	0:05	LOAD CHANGEOVER
256	9-Jul-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	22:25	22:29	0:04	MAIN SUPPLY FAILURE
257	9-Jul-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	9:53	9:58	0:05	LOAD CHANGEOVER
258	9-Jul-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	10:20	10:26	0:06	MAIN SUPPLY FAILURE
259	9-Jul-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	15:56	16:01	0:05	LOAD CHANGEOVER
260	9-Jul-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	22:25	22:29	0:04	MAIN SUPPLY FAILURE
261	9-Jul-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	9:43	9:49	0:06	MAIN SUPPLY FAILURE
262	9-Jul-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	15:56	16:01	0:05	LOAD CHANGEOVER
263	9-Jul-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	22:25	22:29	0:04	MAIN SUPPLY FAILURE
264	9-Jul-21	BENGALURU	66	SOMYAJANAHALLI - TATA SOLAR	TATA SOLAR	3:05	9:20	6:14	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
265	9-Jul-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
266	9-Jul-21	BENGALURU	220	LV1	MITTEMARI 220	9:43	9:58	0:15	TRANSFORMER FAULT
267	9-Jul-21	BENGALURU	220	LV1	MITTEMARI 220	10:20	10:28	0:08	TRANSFORMER FAULT
268	9-Jul-21	BENGALURU	220	LV1	MITTEMARI 220	11:13	11:17	0:04	TRANSFORMER FAULT
269	9-Jul-21	BENGALURU	220	LV1	MITTEMARI 220	15:23	16:00	0:37	LINE CLEAR AVAILED
270	9-Jul-21	BENGALURU	220	LV1	MITTEMARI 220	22:25	22:29	0:04	TRANSFORMER FAULT
271	9-Jul-21	GULBARGA	110	CHITGUPPA-NIRNA	NIRNA_110	5:35	6:00	0:25	MAIN SUPPLY FAILURE
272	9-Jul-21	GULBARGA	110	GULBARGA SOUTH -GULBARGA WEST	GULBARGA SOUTH_110	5:30(08.07.2021)			LINE OPEN:LINE CLEAR AVAILED
273	9-Jul-21	GULBARGA	110	HALBARGA-SANTHPUR	SANTHAPUR_110,DONGARGAON_110,KAMALNAGAR_110	2:57	3:04	0:07	LINE FAULT
274	9-Jul-21	GULBARGA	110	HALBARGA-SANTHPUR	SANTHAPUR_110,DONGARGAON_110,KAMALNAGAR_110	20:55	21:11	0:16	LINE FAULT
275	9-Jul-21	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	5:32	5:45	0:13	LINE FAULT
276	9-Jul-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
277	9-Jul-21	GULBARGA	110	HV1	KAVITHAL_110	19:00	19:05	0:05	TRANSFORMER FAULT
278	9-Jul-21	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	5:15	5:26	0:11	MAIN SUPPLY FAILURE
279	9-Jul-21	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	0:44	0:54	0:10	LINE FAULT
280	9-Jul-21	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	5:21	5:31	0:10	LINE FAULT
281	9-Jul-21	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	19:01	19:11	0:10	LINE FAULT
282	9-Jul-21	GULBARGA	110	MALLAT-BYGWAT	BYGWAT_110	0:35	0:40	0:05	LINE FAULT
283	9-Jul-21	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	5:58	6:13	0:15	LINE FAULT
284	9-Jul-21	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVATHI_110,SRNAGAR_110,KAR ATAGI_110	10:15	11:56	1:41	LINE CLEAR AVAILED
285	9-Jul-21	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI_110	2:02	2:06	0:04	LINE FAULT
286	9-Jul-21	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI_110	5:06	5:13	0:07	LINE FAULT
287	9-Jul-21	GULBARGA	110	SEDAM-ULTRATECH_IPP	SEDAM_220	5:08	5:58	0:50	LINE FAULT
288	9-Jul-21	GULBARGA	110	SEDAM-ULTRATECH_IPP	SEDAM_220	20:23	20:30	0:07	LINE FAULT
289	9-Jul-21	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	11:40	15:58	4:18	LINE FAULT
290	9-Jul-21	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	10:30	10:44	0:14	LINE FAULT
291	9-Jul-21	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	17:56	18:26	0:30	LINE FAULT
292	9-Jul-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	2:20	2:25	0:05	LINE FAULT
293	9-Jul-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	3:55	4:00	0:05	LINE FAULT
294	9-Jul-21	GULBARGA	110	SHAHABAD-CHITHAPUR	CHITHAPUR_110,KORAWAR TEMPLE_110	5:30	5:35	0:05	LINE FAULT
295	9-Jul-21	GULBARGA	110	SHAHABAD-CHITHAPUR	CHITHAPUR_110,KORAWAR TEMPLE_110	18:56	20:45	1:49	LINE FAULT
296	9-Jul-21	GULBARGA	110	SHAHABAD-CHITHAPUR	CHITHAPUR_110,KORAWAR TEMPLE_110	20:45(9.07.21)			LINE OPEN:LINE CLEAR AVAILED
297	9-Jul-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY1(IDLE LINE)	GULBARGA UNIVERSITY_110	6:05	6:40	0:35	LINE FAULT
298	9-Jul-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	23:59(08.07.2021)	1:11(09.2021)	1:12HRS	LINE CHARGED
299	9-Jul-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	1:12	7:18	6:06	LINE FAULT
300	9-Jul-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	13:30	18:35	5:05	LINE CLEAR AVAILED
301	9-Jul-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP,HUNSAGI_110,ASKI_110	5:45	5:54	0:09	LINE FAULT
302	9-Jul-21	GULBARGA	110	SHAKTINAGAR-CHICKSUGUR	SHAKTINAGAR_110	5:06	5:14	0:08	MAIN SUPPLY FAILURE
303	9-Jul-21	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	0:05	0:07	0:02	LINE CLEAR AVAILED
304	9-Jul-21	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	2:55	3:05	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
305	9-Jul-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	22:18	22:28	0:10	LINE FAULT
306	9-Jul-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	2:45	2:50	0:05	MAIN SUPPLY FAILURE
307	9-Jul-21	GULBARGA	220	RTPS-LINGSUGUR1	LINGSUGUR_220	14:25(09.07.2021)			LINE OPEN:LINE FAULT
308	9-Jul-21	GULBARGA	220	RTPS-LINGSUGUR2	LINGSUGUR_220	10:33	10:53	0:20	LINE FAULT
309	9-Jul-21	GULBARGA	220	RTPS-SHAHAPUR2	SHAHAPUR_220	3:02	3:20	0:18	LINE FAULT
310	9-Jul-21	HASSAN	66	ARAKAL-HASSAN	ARAKALGUD_66	12:29	12:31	0:02	HAND TRIPPED
311	9-Jul-21	HASSAN	66	ARAKAL-HASSAN	ARAKALGUD_66	14:15	14:18	0:03	HAND TRIPPED
312	9-Jul-21	HASSAN	66	ARAKAL-MARUTHI GEN	ARAKALGUD_66	12:48	14:13	1:25	LINE CLEAR AVAILED
313	9-Jul-21	HASSAN	66	HV2	RAMNATHPURA_66	14:55	15:27	0:32	LINE CLEAR AVAILED
314	9-Jul-21	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	6:57	8:17	1:20	LINE CLEAR AVAILED
315	9-Jul-21	HASSAN	110	HV1	SHIVAPURA_110	15:19	16:35	1:16	TRANSFORMER FAULT
316	9-Jul-21	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN:LINE CLEAR AVAILED
317	9-Jul-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	13:19	13:24	0:05	LINE FAULT
318	9-Jul-21	MYSORE	66	DEVNUR(N'GUD)-BAS1	NO STATIONS EFFECTED	9:15	17:55	8:39	LINE CLEAR AVAILED
319	9-Jul-21	MYSORE	66	DEVNUR(N'GUD)-BAS2	NO STATIONS EFFECTED	9:14	17:55	8:40	LINE CLEAR AVAILED
320	9-Jul-21	MYSORE	66	DEVNUR(N'GUD)-KADAKOLA	DEVANOORNGUDU_66, SUTTUR_66	16:18	16:52	0:34	HAND TRIPPED
321	9-Jul-21	MYSORE	66	FTS-HOOTGALLY	NO STATIONS EFFECTED	8:20	12:25	4:05	NFBC ISSUED
322	9-Jul-21	MYSORE	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
323	9-Jul-21	MYSORE	66	RAVANDURU-ADANI	NO STATIONS EFFECTED	18:44	19:33	0:49	LINE CLEAR AVAILED
324	9-Jul-21	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	20:15	20:27	0:12	LINE FAULT
325	9-Jul-21	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:41	10:49	0:08	LINE FAULT
326	9-Jul-21	TUMKUR	66	THALLAK 220KV- P R PURA	MADHUGIRI_220	19:13	19:27	0:14	LINE FAULT
327	9-Jul-21	TUMKUR	66	TR-1	GOWRASAMUDRA_66	11:54	13:25	1:30	LINE CLEAR AVAILED
328	9-Jul-21	TUMKUR	66	TR-1	MAVINAKATTE_66	8:07	8:15	0:07	TRANSFORMER FAULT
329	9-Jul-21	TUMKUR	66	TR-1	MAVINAKATTE_66	12:20	12:30	0:10	TRANSFORMER FAULT
330	9-Jul-21	TUMKUR	66	TR-2	SANEKERE_66	10:40	10:54	0:13	TRANSFORMER FAULT
331	9-Jul-21	TUMKUR	66	TR-3(LV-3)	CHITRADURGA_220	20:03	20:24	0:21	TRANSFORMER FAULT
332	9-Jul-21	TUMKUR	220	TR-3	CHITRADURGA_220	20:03	20:22	0:18	TRANSFORMER FAULT
333	10-Jul-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
334	10-Jul-21	BAGALKOT	110	110/11KV ,HV 1	ALMEL_110	12:47	14:52	2:05	LINE CLEAR AVAILED
335	10-Jul-21	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	16:23	16:29	0:06	TRANSFORMER FAULT
336	10-Jul-21	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	20:18	21:37	1:19	TRANSFORMER FAULT
337	10-Jul-21	BAGALKOT	110	110/11KV,HV 1	ACHANUR_110	2:47 (10.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
338	10-Jul-21	BAGALKOT	110	110/11KV,HV 1	AKSHAYA COLONY_110	6:02	15:37	9:35	TRANSFORMER FAULT
339	10-Jul-21	BAGALKOT	110	110/33KV, HV3	LAXMESHVAR_110, SOMESHWAR MILL_33, MMCL_33	19:13	20:03	0:50	TRANSFORMER FAULT
340	10-Jul-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
341	10-Jul-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
342	10-Jul-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
343	10-Jul-21	BAGALKOT	110	BELGAUM-HUKKERI	HUKKERI_110	9:40	11:22	1:42	LINE FAULT
344	10-Jul-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
345	10-Jul-21	BAGALKOT	110	HUNGUND-KUDALSANGAM(BAGEWADI)	KUDALASANGAM_110	16:42	19:25	2:43	LINE CLEAR AVAILED
346	10-Jul-21	BAGALKOT	110	ILKAL 1&2- HUNGUND	HUNGUND_110	11:06	16:42	5:36	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
347	10-Jul-21	BAGALKOT	110	MAHALINGAPUR(NAVALAGI)-JAMAKHANDI	STATION NOT AFFECTED JAMAKHANDI_110	21:13 (06.07.2021)			LINE OPEN:LINE CLEAR AVAILED
348	10-Jul-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
349	10-Jul-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
350	10-Jul-21	BAGALKOT	110	UMAMACHAGI-KIRUVATTI	STATION NOT AFFECTED UMMACHAGI_110	8:33 (06.07.2021)			LINE OPEN:LINE CLEAR AVAILED
351	10-Jul-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
352	10-Jul-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
353	10-Jul-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	17:46 (03.07.2021)			LINE OPEN:LINE CLEAR AVAILED
354	10-Jul-21	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	10:09 (03.07.2021)			LINE OPEN:LINE CLEAR AVAILED
355	10-Jul-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
356	10-Jul-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
357	10-Jul-21	BENGALURU	66	ELECTRONIC CITY P2 S1 - NAGNATHPURA 220	ELECTRONIC CITY P2 S1	9:06	9:16	0:10	LOAD CHANGEVER
358	10-Jul-21	BENGALURU	66	HV1	GUNDLU KOTTUR	1:12	1:20	0:07	TRANSFORMER FAULT
359	10-Jul-21	BENGALURU	66	HV2	NAGNATHPURA 220	10:25	10:38	0:12	LOAD CHANGEVER
360	10-Jul-21	BENGALURU	66	HV2	SOMAYAJJANAHALLI	11:50	18:30	6:40	TRANSFORMER FAULT
361	10-Jul-21	BENGALURU	66	HV2	DODDABELAVANGALA	5:31	5:55	0:23	TRANSFORMER FAULT
362	10-Jul-21	BENGALURU	66	HV2	DALASNUR	0:05	0:32	0:26	TRANSFORMER FAULT
363	10-Jul-21	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
364	10-Jul-21	BENGALURU	66	HV3	NAGNATHPURA 220	10:25	10:38	0:12	LOAD CHANGEVER
365	10-Jul-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	0:00	0:04	0:04	MAIN SUPPLY FAILURE
366	10-Jul-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	0:00	0:04	0:04	MAIN SUPPLY FAILURE
367	10-Jul-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	0:00	0:04	0:04	MAIN SUPPLY FAILURE
368	10-Jul-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	0:00	0:04	0:04	MAIN SUPPLY FAILURE
369	10-Jul-21	BENGALURU	66	SOMYAJANAHALLI - TATA SOLAR	TATA SOLAR	18:30	18:56	0:26	LINE CLEAR AVAILED
370	10-Jul-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
371	10-Jul-21	BENGALURU	220	LV1	MITTEMARI 220	0:00	0:08	0:08	TRANSFORMER FAULT
372	10-Jul-21	BENGALURU	220	LV1	MITTEMARI 220	7:25	7:52	0:27	TRANSFORMER FAULT
373	10-Jul-21	BENGALURU	220	LV1	MITTEMARI 220	13:23	13:27	0:04	LINE CLEAR AVAILED
374	10-Jul-21	GULBARGA	110	GULBARGA SOUTH -GULBARGA WEST	GULBARGA SOUTH_110	5:30(8.7.21)			LINE OPEN:LINE CLEAR AVAILED
375	10-Jul-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
376	10-Jul-21	GULBARGA	110	SHAHABAD-CHITHAPUR	CHITHAPUR_110,KORAWAR TEMPLE_110	20:45(9.07.21)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
377	10-Jul-21	GULBARGA	220	RTPS-LINGSUGUR1	LINGSUGUR_220	14:25(09.07.2021)			LINE OPEN:LINE FAULT
378	10-Jul-21	HASSAN	66	HV1	HOLEHONNUR_66	10:07	17:36	7:29	LINE CLEAR AVAILED
379	10-Jul-21	HASSAN	66	HV1	MAGGE_66	11:01	11:57	0:56	LINE CLEAR AVAILED
380	10-Jul-21	HASSAN	66	HV2	HOLEHONNUR_66	10:07	17:36	7:29	LINE CLEAR AVAILED
381	10-Jul-21	HASSAN	66	HV2	MAGGE_66	3:05	3:20	0:15	TRANSFORMER FAULT
382	10-Jul-21	HASSAN	66	HV2	MAGGE_66	10:20	11:57	1:37	LINE CLEAR AVAILED
383	10-Jul-21	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	17:54	18:03	0:09	LINE FAULT
384	10-Jul-21	HASSAN	110	HV1	NANDIKUR_110	11:22	11:55	0:33	HAND TRIPPED
385	10-Jul-21	HASSAN	110	JOG110-AMBTR1	JOG_110	9:06(10.7.2021)			LINE OPEN:LINE CLEAR AVAILED
386	10-Jul-21	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN:LINE CLEAR AVAILED
387	10-Jul-21	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	17:42	21:12	3:30	LINE FAULT
388	10-Jul-21	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	18:31	18:45	0:14	HAND TRIPPED
389	10-Jul-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	18:31	18:45	0:14	HAND TRIPPED
390	10-Jul-21	HASSAN	220	MRSSHM-VARAH12	MRSMG_220	10:01	12:22	2:21	LINE CLEAR AVAILED
391	10-Jul-21	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	10:01	12:22	2:21	LINE CLEAR AVAILED
392	10-Jul-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:12	14:36	14:24	LINE CLEAR AVAILED
393	10-Jul-21	MYSORE	66	HV1	MANDGERE_66	11:30	12:05	0:35	LINE CLEAR AVAILED
394	10-Jul-21	MYSORE	66	HV1	PERIYAPATNA_66	13:35	17:20	3:45	LINE CLEAR AVAILED
395	10-Jul-21	MYSORE	66	HV2	PERIYAPATNA_66	10:10	17:20	7:10	LINE CLEAR AVAILED
396	10-Jul-21	MYSORE	66	KADAKOLA-DKMAIDANA	NO STATIONS EFFECTED	17:18	17:21	0:03	LINE FAULT
397	10-Jul-21	MYSORE	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	7:29	7:40	0:11	LINE FAULT
398	10-Jul-21	MYSORE	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	8:20	8:31	0:11	LINE FAULT
399	10-Jul-21	MYSORE	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:30	11:36	2:06	NFBC ISSUED
400	10-Jul-21	MYSORE	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
401	10-Jul-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	12:23	12:37	0:14	LINE FAULT
402	10-Jul-21	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	23:19	23:50	0:31	LINE FAULT
403	10-Jul-21	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	5:42	6:07	0:24	MAIN SUPPLY FAILURE
404	10-Jul-21	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	5:40	5:57	0:16	LINE FAULT
405	10-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	11:45	12:19	0:33	LINE FAULT
406	10-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:59	15:10	0:11	LINE FAULT
407	10-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	23:24	23:29	0:04	LINE FAULT
408	10-Jul-21	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	12:30	12:40	0:10	MAIN SUPPLY FAILURE
409	10-Jul-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI	LINGAAHALLI_66	21:42	21:54	0:11	LINE FAULT
410	10-Jul-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	RANGANATHAPURA_66	11:40	11:51	0:10	LOAD CURTAILMENT
411	10-Jul-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	RANGANATHAPURA_66	11:40	11:51	0:10	LOAD CURTAILMENT
412	10-Jul-21	TUMKUR	66	THALLAK 220kv- P R PURA	MADHUGIRI_220	5:42	5:53	0:11	LINE FAULT
413	10-Jul-21	TUMKUR	66	TR-1	CHITRADURGA_66	13:57	15:38	1:40	LINE CLEAR AVAILED
414	10-Jul-21	TUMKUR	66	TR-1	THOVINAKERE_66	11:10	12:19	1:09	LINE CLEAR AVAILED
415	10-Jul-21	TUMKUR	66	TR-2	KORA_66	16:40	16:55	0:15	TRANSFORMER FAULT
416	10-Jul-21	TUMKUR	66	TR-3(LV-3)	CHITRADURGA_220	17:44	17:56	0:12	TRANSFORMER FAULT
417	10-Jul-21	TUMKUR	220	TR-3	CHITRADURGA_220	17:44	17:56	0:12	TRANSFORMER FAULT
418	10-Jul-21	TUMKUR	220	TR-3	CHITRADURGA_220	23:19	23:58	0:39	TRANSFORMER FAULT
419	11-Jul-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
420	11-Jul-21	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	20:52	21:07	0:15	TRANSFORMER FAULT
421	11-Jul-21	BAGALKOT	110	110/11KV, HV1	LAKMANAHALLI_110	9:05	9:40	0:35	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
422	11-Jul-21	BAGALKOT	110	110/11KV, HV1	MUGALKODI_110	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
423	11-Jul-21	BAGALKOT	110	110/11KV, HV2A	JAMKHANDI_110	8:12	8:54	0:42	LINE CLEAR AVAILED
424	11-Jul-21	BAGALKOT	110	110/11KV, HV4	VADAGOAN_110	9:16	16:37	7:21	LINE CLEAR AVAILED
425	11-Jul-21	BAGALKOT	110	110/11KV,HV 1	ACHANUR_110	2:47 (10.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
426	11-Jul-21	BAGALKOT	110	110/11KV,HV 1	AKSHAYA COLONY_110	8:20	9:27	1:07	LINE CLEAR AVAILED
427	11-Jul-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
428	11-Jul-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVAILED
429	11-Jul-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
430	11-Jul-21	BAGALKOT	110	BANAHATTI-NAVALAGI(JAMAKHANDI)	NAVALAGI_110	19:17	19:35	0:18	LINE FAULT
431	11-Jul-21	BAGALKOT	110	BELGAUM220- VADAGOAN	VADAGOAN_110	9:19	16:22	7:03	LINE CLEAR AVAILED
432	11-Jul-21	BAGALKOT	110	GHATAPRABHA-GOKAK	GOKAK_110	0:28	0:35	0:07	LINE FAULT
433	11-Jul-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
434	11-Jul-21	BAGALKOT	110	MAHALINGAPUR- BANAHATTI	BANAHATTI_110	19:44	19:57	0:13	LINE FAULT
435	11-Jul-21	BAGALKOT	110	MAHALINGAPUR(NAVALAGI)-JAMAKHANDI	STATION NOT AFFECTED JAMAKHANDI_110	21:13 (06.07.2021)	12:35 (11.07.2021)	13:07	LINE CHARGED
436	11-Jul-21	BAGALKOT	110	MKHUBLI220- BIDI	BIDI_110	11:59	17:15	5:16	LINE CLEAR AVAILED
437	11-Jul-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVAILED
438	11-Jul-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
439	11-Jul-21	BAGALKOT	110	UMAMACHAGI-KIRUVATTI	STATION NOT AFFECTED UMMACHAGI_110	8:33 (06.07.2021)			LINE OPEN:LINE CLEAR AVAILED
440	11-Jul-21	BAGALKOT	220	220/110KV, HV1&LV1	MKHUBLI_220	9:20	12:48	3:28	LINE CLEAR AVAILED
441	11-Jul-21	BAGALKOT	220	220/110KV, HV2&LV2	MKHUBLI_220	12:58	15:55	2:57	LINE CLEAR AVAILED
442	11-Jul-21	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	18:14 (11.07.2021)			LINE OPEN:LINE CLEAR AVAILED
443	11-Jul-21	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	17:08 (11.07.2021)			LINE OPEN:LINE CLEAR AVAILED
444	11-Jul-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
445	11-Jul-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
446	11-Jul-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	17:46 (03.07.2021)			LINE OPEN:LINE CLEAR AVAILED
447	11-Jul-21	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	10:09 (03.07.2021)			LINE OPEN:LINE CLEAR AVAILED
448	11-Jul-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
449	11-Jul-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
450	11-Jul-21	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	9:00	9:20	0:20	LINE FAULT
451	11-Jul-21	BENGALURU	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	16:38	16:47	0:09	LOAD CHANGEOVER
452	11-Jul-21	BENGALURU	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	10:42	10:51	0:09	LOAD CHANGEOVER
453	11-Jul-21	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI 1	ELECTRONIC CITY, INFOSYS (EHT)	9:13	9:16	0:02	LOAD CHANGEOVER
454	11-Jul-21	BENGALURU	66	ELECTRONIC CITY P2 S1 - ELECTRONIC CITY	ELECTRONIC CITY P2 S1	8:52	9:02	0:10	LOAD CHANGEOVER
455	11-Jul-21	BENGALURU	66	HV1	NAGNATHPURA 220	6:32	6:56	0:24	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
456	11-Jul-21	BENGALURU	66	HV1	YERANDANAHALLI 220	10:13	10:34	0:21	LOAD CHANGEOVER
457	11-Jul-21	BENGALURU	66	HV1	SIDDLAGHATTA	10:00	10:25	0:24	LINE CLEAR AVAILED
458	11-Jul-21	BENGALURU	66	HV1	SADLI	4:15	4:25	0:10	TRANSFORMER FAULT
459	11-Jul-21	BENGALURU	66	HV1	DOMMASANDRA	19:38	19:41	0:03	TRANSFORMER FAULT
460	11-Jul-21	BENGALURU	66	HV1	ATTIBELE	19:45	19:50	0:05	LOAD CHANGEOVER
461	11-Jul-21	BENGALURU	66	HV2	APPAREL PARK	17:45	18:11	0:26	TRANSFORMER FAULT
462	11-Jul-21	BENGALURU	66	HV2	NAGNATHPURA 220	6:32	6:56	0:24	LOAD CHANGEOVER
463	11-Jul-21	BENGALURU	66	HV2	YERANDANAHALLI 220	15:43	15:45	0:02	LOAD CHANGEOVER
464	11-Jul-21	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
465	11-Jul-21	BENGALURU	66	HV3	NAGNATHPURA 220	6:32	6:56	0:24	LOAD CHANGEOVER
466	11-Jul-21	BENGALURU	66	ISKON - SUBRAMANYAPURA 220	ISKON, SUBRAMANYAPURA 66	9:32	9:33	0:01	LOAD CHANGEOVER
467	11-Jul-21	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	10:20	10:35	0:15	MAIN SUPPLY FAILURE
468	11-Jul-21	BENGALURU	66	JIGANI 66 - SOMANHALLI 220	JIGANI 66	20:15	20:22	0:07	LOAD CHANGEOVER
469	11-Jul-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	21:44	22:47	1:02	LINE CLEAR AVAILED
470	11-Jul-21	BENGALURU	66	SIDDLAGHATTA - CHINTAMANI 220	SIDDLAGHATTA, MELUR	10:20	10:25	0:05	LINE CLEAR AVAILED
471	11-Jul-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
472	11-Jul-21	BENGALURU	66	YERANDANAHALLI 220 - ANEKAL	ANEKAL, SURYANAGAR	10:17	10:42	0:25	LOAD CHANGEOVER
473	11-Jul-21	BENGALURU	66	YERANDANAHALLI 220 - ANEKAL	ANEKAL, SURYANAGAR	19:10	19:33	0:23	LOAD CHANGEOVER
474	11-Jul-21	BENGALURU	220	DB PURA 220 - NELAMANGALA 1	NO STATION AFFECTED	19:46	21:10	1:24	LINE CLEAR AVAILED
475	11-Jul-21	BENGALURU	220	DB PURA 220 - NELAMANGALA 2	NO STATION AFFECTED	17:29	21:14	3:44	LINE FAULT
476	11-Jul-21	BENGALURU	220	JIGANI 220 - MYLASANDRA 400	JIGANI 220	10:20	11:06	0:46	LINE CLEAR AVAILED
477	11-Jul-21	BENGALURU	220	JIGANI 220 - YERANDANAHALLI 220	YERANDANAHALLI 220	15:55	16:14	0:19	LOAD CHANGEOVER
478	11-Jul-21	BENGALURU	220	NELMANGALA 400 - DB PURA 1	NO STATION AFFECTED	19:49	21:09	1:20	LINE CLEAR AVAILED
479	11-Jul-21	BENGALURU	220	NELMANGALA 400 - DB PURA 1	NO STATION AFFECTED	17:29	21:13	3:43	LINE FAULT
480	11-Jul-21	GULBARGA	110	GULBARGA SOUTH -GULBARGA WEST	GULBARGA SOUTH_110	5:30(8.7.21)			LINE OPEN:LINE CLEAR AVAILED
481	11-Jul-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
482	11-Jul-21	GULBARGA	110	SHAHABAD-CHITHAPUR	CHITHAPUR_110,KORAWAR TEMPLE_110	20:45(9.07.21)			LINE OPEN:LINE CLEAR AVAILED
483	11-Jul-21	GULBARGA	220	RTPS-LINGSUGUR1	LINGSUGUR_220	14:25(09.07.2021)			LINE OPEN:LINE FAULT
484	11-Jul-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:15	10:30	0:15	LINE FAULT
485	11-Jul-21	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_66	9:02	11:10	2:08	LINE FAULT
486	11-Jul-21	HASSAN	66	HV1	DIDIGA_66	14:54	15:11	0:17	TRANSFORMER FAULT
487	11-Jul-21	HASSAN	66	HV2	S.BELAGOLA_66	10:52	11:05	0:13	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
488	11-Jul-21	HASSAN	110	ANANDA-SHIMOGA	ANANDPURA_110	9:15	10:42	1:27	LINE FAULT
489	11-Jul-21	HASSAN	110	HV1	NAVUNDA_110	23:01	23:11	0:10	TRANSFORMER FAULT
490	11-Jul-21	HASSAN	110	HV1	SHIKARIPURA_110	12:35	15:41	3:06	LINE CLEAR AVAILED
491	11-Jul-21	HASSAN	110	HV2	BAIKAMPADY_110	10:00	11:15	1:15	LINE CLEAR AVAILED
492	11-Jul-21	HASSAN	110	HV2	BIRUR_110	3:11	10:20	7:09	TRANSFORMER FAULT
493	11-Jul-21	HASSAN	110	HV2	SHIKARIPURA_110	10:05	18:20	8:15	LINE CLEAR AVAILED
494	11-Jul-21	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN:LINE CLEAR AVAILED
495	11-Jul-21	HASSAN	110	MRSSSHM-SS2	MRSMG_220	9:15	10:42	1:27	LINE FAULT
496	11-Jul-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:53	12:51	0:58	LINE CLEAR AVAILED
497	11-Jul-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	17:11(11.7.2021)			LINE OPEN:LINE CLEAR AVAILED
498	11-Jul-21	MYSORE	66	HV2	K_HONNALGERE_66	12:50	13:10	0:20	MAIN SUPPLY FAILURE
499	11-Jul-21	MYSORE	66	HVI	K_HONNALGERE_66	12:50	13:10	0:20	MAIN SUPPLY FAILURE
500	11-Jul-21	MYSORE	66	KADAKOLA-DKMAIDANA	NO STATIONS EFFECTED	14:18	14:23	0:05	LINE FAULT
501	11-Jul-21	MYSORE	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
502	11-Jul-21	MYSORE	66	PERIAPATNA-HANGUD	HANAGODU_66, PONNAMPET_66, VIRAJPET_66	15:20	15:36	0:16	LINE FAULT
503	11-Jul-21	TUMKUR	66	ANTHRASANAHALI 220kV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	18:21	18:45	0:23	LINE FAULT
504	11-Jul-21	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	4:40	4:51	0:11	LINE FAULT
505	11-Jul-21	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	5:26	9:59	4:33	LINE CLEAR AVAILED
506	11-Jul-21	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	20:08	20:19	0:10	LINE FAULT
507	11-Jul-21	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	1:56	2:30	0:34	LOAD CURTAILMENT
508	11-Jul-21	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	5:06	5:38	0:31	LOAD CURTAILMENT
509	11-Jul-21	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 1_IPP_66	1:56	3:04	1:08	LOAD CURTAILMENT
510	11-Jul-21	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 1_IPP_66	5:06	5:38	0:31	LOAD CURTAILMENT
511	11-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:07	10:23	0:15	LINE FAULT
512	11-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	11:25	11:30	0:04	LINE FAULT
513	11-Jul-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI	LINGAAHALLI_66	13:27	13:30	0:02	LINE FAULT
514	11-Jul-21	TUMKUR	66	MADANAYAKANAHALLI-CHITRADURGA220	MADANAYAKANAHALLI_66	6:09	10:06	3:57	NFBC ISSUED
515	11-Jul-21	TUMKUR	66	TR-1	HULIYURDURGA_66	8:52	9:00	0:07	TRANSFORMER FAULT
516	11-Jul-21	TUMKUR	66	TR-1	KATTIGE_66	7:35	7:50	0:14	TRANSFORMER FAULT
517	11-Jul-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	12:11	13:21	1:09	LINE CLEAR AVAILED
518	11-Jul-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	20:41	21:20	0:38	HAND TRIPPED
519	11-Jul-21	HASSAN	110	JOG110-AMBTR1	JOG_110	9:06(10.7.2021)			LINE OPEN:LINE CLEAR AVAILED
1	12-Jul-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
2	12-Jul-21	BAGALKOT	110	110/11KV, HV1	MUGALKOD_110	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
3	12-Jul-21	BAGALKOT	110	110/11KV,HV 1	ACHANUR_110	2:47 (10.07.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
4	12-Jul-21	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	1:05	1:10	0:05	TRANSFORMER FAULT
5	12-Jul-21	BAGALKOT	110	110/11KV,HV2	KUD DHARAWAD_110	11:55	11:58	0:03	TRANSFORMER FAULT
6	12-Jul-21	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	17:45 (11.07.2021)	7:33 (12.07.2021)	13:48 hrs	TRANSFORMER CHARGED
7	12-Jul-21	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	23:47	23:50	0:03	LINE FAULT
8	12-Jul-21	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	23:47	23:50	0:03	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
9	12-Jul-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN:LINE CLEAR AVOIDED
10	12-Jul-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN:LINE CLEAR AVOIDED
11	12-Jul-21	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
12	12-Jul-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVOIDED
13	12-Jul-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN:LINE CLEAR AVOIDED
14	12-Jul-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
15	12-Jul-21	BAGALKOT	110	SPV SOLAR- MUKARTIHAL	MUKARTIHAL_110	21:56	22:04	0:08	LINE FAULT
16	12-Jul-21	BAGALKOT	110	UMAMACHAGI-KIRUVATTI	STATION NOT AFFECTED UMMACHAGI_110	8:33 (06.07.2021)			LINE OPEN:LINE CLEAR AVOIDED
17	12-Jul-21	BAGALKOT	110	ZALKI- CHADCHAN (INCHAGERI)	INCHAGERI_110	7:09	7:51	0:42	LINE FAULT
18	12-Jul-21	BAGALKOT	110	ZALKI- CHADCHAN (INCHAGERI)	INCHAGERI_110	9:40	10:38	0:58	LINE CLEAR AVOIDED
19	12-Jul-21	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	18:14 (11.07.2021)			LINE OPEN:LINE CLEAR AVOIDED
20	12-Jul-21	BAGALKOT	220	CHIKKODI- KOLAHUPURA2(MUDASHINGE)	CHIKKODI_220	10:43	19:32	8:49	LINE CLEAR AVOIDED
21	12-Jul-21	BAGALKOT	220	HAVERI- GUTTUR1	HAVERI_220	12:23	13:38	1:15	LINE CLEAR AVOIDED
22	12-Jul-21	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	17:08 (11.07.2021)	11:15 (12.07.2021)	18:07 hrs	LINE CHARGED
23	12-Jul-21	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	17:08 (11.07.2021)	11:07 (12.07.2021)	17:59 hrs	LINE CHARGED
24	12-Jul-21	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	16:17	18:11	1:54	LINE CLEAR AVOIDED
25	12-Jul-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
26	12-Jul-21	BAGALKOT	220	NAGJHARI 2-AMBEWADI	AMBEWADI_220	10:54	14:29	3:35	LINE CLEAR AVOIDED
27	12-Jul-21	BAGALKOT	220	NAGJHARI 2-AMBEWADI	AMBEWADI_220	18:34	18:48	0:14	HAND TRIPPED
28	12-Jul-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
29	12-Jul-21	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	18:01 (12.07.2021)			LINE OPEN:LINE CLEAR AVOIDED
30	12-Jul-21	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	16:18 (12.07.1011)			LINE OPEN:LINE CLEAR AVOIDED
31	12-Jul-21	BAGALKOT	220	SIRSI- SHARAVATHY1	SIRSI_220	11:07	18:01	6:54	LOAD CURTAILMENT
32	12-Jul-21	BAGALKOT	220	SIRSI- SHARAVATHY2	SIRSI_220	11:08	18:02	6:54	LOAD CURTAILMENT
33	12-Jul-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	17:46 (03.07.2021)	11:15 (12.07.2021)	17:29 hrs	LINE CHARGED
34	12-Jul-21	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	10:09 (03.07.2021)	11:08 (12.07.2021)	0:59 hrs	LINE CHARGED
35	12-Jul-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
36	12-Jul-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
37	12-Jul-21	BENGALURU	66	BAGHMANE WORLD TECH PARK - HOODY 220	BAGHMANE WORLD TECH PARK	15:55	16:25	0:30	LOAD CHANGEOVER
38	12-Jul-21	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	17:34	17:40	0:06	LOAD CHANGEOVER
39	12-Jul-21	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	11:25	11:30	0:05	LOAD CHANGEOVER
40	12-Jul-21	BENGALURU	66	HV1	VIJAYAPURA	12:57	13:04	0:06	TRANSFORMER FAULT
41	12-Jul-21	BENGALURU	66	HV1	HUKUNDA	13:50	13:55	0:05	TRANSFORMER FAULT
42	12-Jul-21	BENGALURU	66	HV1	SRINIVASAPURA	14:50	20:30	5:40	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
43	12-Jul-21	BENGALURU	66	HV2	TADIGOLU	12:00	12:52	0:52	LINE CLEAR AVAILED
44	12-Jul-21	BENGALURU	66	HV2	SRINIVASAPURA	14:50	20:30	5:40	LINE CLEAR AVAILED
45	12-Jul-21	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
46	12-Jul-21	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	14:15	14:23	0:08	MAIN SUPPLY FAILURE
47	12-Jul-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	17:46	17:51	0:05	LOAD CHANGEVER
48	12-Jul-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	17:46	17:51	0:05	LOAD CHANGEVER
49	12-Jul-21	BENGALURU	66	NRS 220 - SRS 2	NO STATION AFFECTED	12:07	14:42	2:35	LINE FAULT
50	12-Jul-21	BENGALURU	66	SRINIVASAPURA - CHINTAMANI 220	SRINIVASAPURA	14:50	17:40	2:50	LINE CLEAR AVAILED
51	12-Jul-21	BENGALURU	66	SRS 220 - NRS 2	MAHALAKSHMI LAYOUT	12:35	14:06	1:31	LINE CLEAR AVAILED
52	12-Jul-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
53	12-Jul-21	BENGALURU	220	LV1	MITTEMARI 220	11:35	17:44	6:09	LINE CLEAR AVAILED
54	12-Jul-21	BENGALURU	220	LV2	JIGANI 220	14:15	14:23	0:08	LINE CLEAR AVAILED
55	12-Jul-21	GULBARGA	66	HV2	TAMBRAHALLI_66	10:50	10:55	0:05	TRANSFORMER FAULT
56	12-Jul-21	GULBARGA	66	KOGALI-ITTAGGI	KOGALI_66	15:20	18:12	2:52	MAIN SUPPLY FAILURE
57	12-Jul-21	GULBARGA	66	TUNGABHADRA_IPP-ITTAGGI1,2	ITTAGI_220	12:45	13:45	1:00	LINE FAULT
58	12-Jul-21	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALU_110,KUDITINI_110,KURUGOD_110,KAMALAPUR_110,SHATHAVAHANA_IPP,AGARWAL_IPP	10:25	14:18	3:53	LINE CLEAR AVAILED
59	12-Jul-21	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALU_110,KUDITINI_110,KURUGOD_110,KAMALAPUR_110,SHATHAVAHANA_IPP,AGARWAL_IPP	17:40	17:51	0:11	LINE FAULT
60	12-Jul-21	GULBARGA	110	CHITGUPPA-NIRNA	NIRNA_110	5:40	5:55	0:15	MAIN SUPPLY FAILURE
61	12-Jul-21	GULBARGA	110	CHITGUPPA-NIRNA	NIRNA_110	6:00	6:20	0:20	MAIN SUPPLY FAILURE
62	12-Jul-21	GULBARGA	110	GULBARGA SOUTH -GULBARGA WEST	GULBARGA SOUTH_110	5:30(09.07.2021)	17:30(12.07.2021)	84:00 HRS	LINE CHARGED
63	12-Jul-21	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	5:40	5:50	0:10	LINE FAULT
64	12-Jul-21	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	6:01	6:06	0:05	LINE FAULT
65	12-Jul-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
66	12-Jul-21	GULBARGA	110	HV1	SREERAMANAGAR_110	16:15	16:45	0:30	TRANSFORMER FAULT
67	12-Jul-21	GULBARGA	110	HV1	JEWARGI_110	13:00	16:55	3:55	LINE CLEAR AVAILED
68	12-Jul-21	GULBARGA	110	HV2	SREERAMANAGAR_110	12:05	12:59	0:54	TRANSFORMER FAULT
69	12-Jul-21	GULBARGA	110	HV2	TEKKALKOTE_110	13:40	13:50	0:10	TRANSFORMER FAULT
70	12-Jul-21	GULBARGA	110	HV2	DEODURGA_110	12:59	13:00	0:01	TRANSFORMER FAULT
71	12-Jul-21	GULBARGA	110	HV2	JEWARGI_110	16:40	16:55	0:15	LINE CLEAR AVAILED
72	12-Jul-21	GULBARGA	110	HV3	HALIKHED_110	9:53	9:56	0:03	TRANSFORMER FAULT
73	12-Jul-21	GULBARGA	110	JANAWADA-SANTHAPUR	JANAWADA_110	5:39	5:48	0:09	LINE FAULT
74	12-Jul-21	GULBARGA	110	MANTHAL-SASTHAPUR	MANTHAL_110	0:42	0:49	0:07	MAIN SUPPLY FAILURE
75	12-Jul-21	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	23:01	23:24	0:23	LINE FAULT
76	12-Jul-21	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	23:01	23:10	0:09	MAIN SUPPLY FAILURE
77	12-Jul-21	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	11:50	12:05	0:15	MAIN SUPPLY FAILURE
78	12-Jul-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLR_110	5:00	5:04	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
79	12-Jul-21	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI_110	21:26	21:40	0:14	LINE FAULT
80	12-Jul-21	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	5:50	6:00	0:10	LINE FAULT
81	12-Jul-21	GULBARGA	110	RAJESHWAR-SASTHAPUR	SASTHAPUR_110	19:46	20:02	0:16	LINE FAULT
82	12-Jul-21	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	5:57	6:11	0:14	LINE FAULT
83	12-Jul-21	GULBARGA	110	SEDAM-VICATSAGAR_IP	SEDAM_220	3:44	4:11	0:27	LINE FAULT
84	12-Jul-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNAT I_IPP,COREGREENSUGAR_IPP	20:21	21:02	0:41	LINE FAULT
85	12-Jul-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNAT I_IPP,COREGREENSUGAR_IPP	21:40	21:50	0:10	LINE FAULT
86	12-Jul-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNAT I_IPP,COREGREENSUGAR_IPP	22:48	23:01	0:13	LINE FAULT
87	12-Jul-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	21:50	22:02	0:12	LINE FAULT
88	12-Jul-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:31	20:56	0:25	LINE FAULT
89	12-Jul-21	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	15:19	15:27	0:08	LINE FAULT
90	12-Jul-21	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	13:26	13:56	0:30	MAIN SUPPLY FAILURE
91	12-Jul-21	GULBARGA	220	HV1	SHAHABAD_220	3:30	6:00	2:30	TRANSFORMER FAULT
92	12-Jul-21	GULBARGA	220	HV1	SHAHABAD_220	8:53	9:02	0:09	TRANSFORMER FAULT
93	12-Jul-21	GULBARGA	220	HV1	SHAHABAD_220	10:46	13:46	3:00	TRANSFORMER FAULT
94	12-Jul-21	GULBARGA	220	HV1	SHAHABAD_220	15:10	15:58	0:48	TRANSFORMER FAULT
95	12-Jul-21	GULBARGA	220	HV1	KUSHTAGI_220	13:18	13:40	0:22	TRANSFORMER FAULT
96	12-Jul-21	GULBARGA	220	KAPNOOR-SHAHAPUR	KAPNOOR_220	20:35	21:08	0:33	LINE FAULT
97	12-Jul-21	GULBARGA	220	LINGAPUR-BMMIS	LINGAPUR_220	15:19	15:39	0:20	LINE FAULT
98	12-Jul-21	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	20:31	21:09	0:38	LINE FAULT
99	12-Jul-21	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	1:17			LINE OPEN:LINE CLEAR AVAILED
100	12-Jul-21	HASSAN	66	ARAKAL-HASSAN	ARAKALGUD_66	12:10	12:25	0:15	LINE CLEAR AVAILED
101	12-Jul-21	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	12:05	12:09	0:04	HAND TRIPPED
102	12-Jul-21	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	9:28	9:36	0:08	LINE FAULT
103	12-Jul-21	HASSAN	110	HV1	BARANG_110	8:36	8:52	0:16	TRANSFORMER FAULT
104	12-Jul-21	HASSAN	110	HV1	BIRUR_110	14:45	15:35	0:50	HAND TRIPPED
105	12-Jul-21	HASSAN	110	HV1	KALLUSADARAHALLY_110	12:05	14:17	2:12	LINE CLEAR AVAILED
106	12-Jul-21	HASSAN	110	HV1	SAGARA_110	16:34	17:44	1:10	LINE CLEAR AVAILED
107	12-Jul-21	HASSAN	110	HV2	BARANG_110	13:01	13:27	0:26	LINE CLEAR AVAILED
108	12-Jul-21	HASSAN	110	HV2	KADUR_220	16:40	17:10	0:30	TRANSFORMER FAULT
109	12-Jul-21	HASSAN	110	JOG110-AMBTR1	JOG_110	9:06(10.7.2021)	14:12(12.07.2021)	53:06hrs	LINE CHARGED
110	12-Jul-21	HASSAN	110	JOG110-AMBTR2	JOG_110	14:15	14:23	0:08	LINE CLEAR AVAILED
111	12-Jul-21	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN:LINE CLEAR AVAILED
112	12-Jul-21	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	14:26	14:50	0:24	LINE FAULT
113	12-Jul-21	HASSAN	220	MRSSHM-SHANTHIGRAMA	MRSMG_220	10:01	10:20	0:19	LINE FAULT
114	12-Jul-21	HASSAN	220	MRSSHM-SHANTHIGRAMA	MRSMG_220	12:13	13:11	0:58	HAND TRIPPED
115	12-Jul-21	HASSAN	220	MRSSHM-VARAH13	MRSMG_220	9:28	11:13	1:45	LINE FAULT
116	12-Jul-21	HASSAN	220	VARAHI-SHMG3	varahi_gen	9:28	11:13	1:45	LINE FAULT
117	12-Jul-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	17:11(11.7.2021)	6:27 (12.07.2021)	13:16hrs	LINE CHARGED
118	12-Jul-21	MYSORE	66	DATTAGALLI-HOOTAGALLI	DATTAGALLY_66 RKNAGARA_66	11:52	13:20	1:27	LINE FAULT
119	12-Jul-21	MYSORE	66	HAMPAPURA-BASARALU	BESAGARAHALLI_66, KOPPA_66	14:54	17:27	2:33	LINE CLEAR AVAILED
120	12-Jul-21	MYSORE	66	HAMPAPURA-BASARALU	BESAGARAHALLI_66, KOPPA_66	18:05	19:31	1:26	NFBC ISSUED
121	12-Jul-21	MYSORE	66	HV1	MANDGERE_66	10:20	10:55	0:35	LINE CLEAR AVAILED
122	12-Jul-21	MYSORE	66	HV2	HUNSUR_66	5:15	16:01	10:46	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
123	12-Jul-21	MYSORE	66	HV2	HUNSUR_66	16:02	16:08	0:05	HAND TRIPPED
124	12-Jul-21	MYSORE	66	KUSHALANAGARA-BETTADAPURA	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	0:39	0:55	0:16	LINE FAULT
125	12-Jul-21	MYSORE	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN:LINE CLEAR AVAILED
126	12-Jul-21	MYSORE	66	VAJAMANGALA-DEVNUR(MYS)	NO STATIONS EFFECTED	18:19	18:38	0:18	LINE FAULT
127	12-Jul-21	MYSORE	66	VAJAMANGALA-MEGHALAPURA	MEGHALAPURA_66	18:46	18:51	0:05	LINE FAULT
128	12-Jul-21	MYSORE	220	MADHUVANAHALLI-HEBBANI 1	NO STATIONS EFFECTED	9:50	13:30	3:40	LINE CLEAR AVAILED
129	12-Jul-21	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	17:31	17:38	0:07	HAND TRIPPED
130	12-Jul-21	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	17:11	17:30	0:19	HAND TRIPPED
131	12-Jul-21	TUMKUR	66	BALENAHALLI66-CHITRADURGA	BALENAHALLI_66	12:44	14:00	1:16	MAIN SUPPLY FAILURE
132	12-Jul-21	TUMKUR	66	BALENAHALLI66-FEFCWINDWIND_IPP_66	FEFCWINDWIND_IPP_66	12:44	14:10	1:25	MAIN SUPPLY FAILURE
133	12-Jul-21	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	12:44	14:10	1:25	MAIN SUPPLY FAILURE
134	12-Jul-21	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	12:44	14:00	1:15	LINE CLEAR AVAILED
135	12-Jul-21	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	14:29	14:59	0:30	LINE FAULT
136	12-Jul-21	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	1:30	1:39	0:09	LINE FAULT
137	12-Jul-21	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	12:08	12:44	0:36	LINE FAULT
138	12-Jul-21	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	16:29	17:32	1:03	LINE CLEAR AVAILED
139	12-Jul-21	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	6:05	6:12	0:07	MAIN SUPPLY FAILURE
140	12-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:18	6:31	0:12	LINE FAULT
141	12-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	8:48	9:00	0:12	LINE FAULT
142	12-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:06	10:21	0:14	LINE FAULT
143	12-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:31	10:44	0:13	LINE FAULT
144	12-Jul-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:50	18:56	0:05	LINE FAULT
145	12-Jul-21	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-1_IPP_66	INFOSYS-1_IPP_66	12:44	12:46	0:02	LINE FAULT
146	12-Jul-21	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-1_IPP_66	INFOSYS-1_IPP_66	13:01	13:09	0:07	LINE FAULT
147	12-Jul-21	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	6:13	6:43	0:29	MAIN SUPPLY FAILURE
148	12-Jul-21	TUMKUR	66	PATTNAYAKANAHALLI66-SIRA66	PATTNAYAKANAHALLI_66	16:49	17:35	0:45	LINE CLEAR AVAILED
149	12-Jul-21	TUMKUR	66	SIRA- KALLAMBELLA	SIRA_66	10:34	11:55	1:20	LINE CLEAR AVAILED
150	12-Jul-21	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUN SOLAR1	10:48	11:30	0:41	HAND TRIPPED
151	12-Jul-21	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUN SOLAR2	10:48	11:30	0:41	HAND TRIPPED
152	12-Jul-21	TUMKUR	66	TR-1	HAGALWADI_66	14:24	15:09	0:45	LINE CLEAR AVAILED
153	12-Jul-21	TUMKUR	66	TR-1	MAVINAKATTE_66	14:38	17:53	3:14	LINE CLEAR AVAILED
154	12-Jul-21	TUMKUR	66	TR-1	NIDISALE_66	18:27	19:14	0:47	LINE CLEAR AVAILED
155	12-Jul-21	TUMKUR	66	TR-1	TUMKUR_66	1:44	2:40	0:56	TRANSFORMER FAULT
156	12-Jul-21	TUMKUR	66	TR-1	PAVAGADA_66	11:46	11:48	0:02	HAND TRIPPED
157	12-Jul-21	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	17:12	17:30	0:18	LINE CLEAR AVAILED
158	12-Jul-21	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	17:35	17:37	0:01	LINE CLEAR AVAILED
159	12-Jul-21	TUMKUR	66	TR-2	PAVAGADA_66	11:46	11:49	0:02	HAND TRIPPED
160	12-Jul-21	TUMKUR	66	TR-3(LV-3)	THALLAKK_220	10:20	10:53	0:33	TRANSFORMER FAULT
161	12-Jul-21	TUMKUR	110	TR-1	BIDARE_110	15:44	15:50	0:06	TRANSFORMER FAULT
162	12-Jul-21	TUMKUR	110	TR-2	MAYASANDRA_110	12:06	15:27	3:20	LINE CLEAR AVAILED
163	12-Jul-21	TUMKUR	220	TR-3(HV-3)	THALLAKK_220	10:20	10:49	0:29	TRANSFORMER FAULT