

400/220/110/66 kV TRANSMISSION INTERRUPTIONS DUE TO LC, LS AND FAULTS :14.04.2020 TO 20.04.2020

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	14-Apr-20	BAGALKOT	110	110/11KV, HV2	MUDEDEBIHAL_110	9:36	9:44	0:08	TRANSFORMER FAULT
2	14-Apr-20	BAGALKOT	110	ANNIGERI-GADAG110	ANNIGERI_110	11:58	12:27	0:29	LINE CLEAR AVAILED
3	14-Apr-20	BAGALKOT	110	ATHANI220-BALIGERI(TAUSHI)	BALIGERI(TAUSHI)_110	5:23	5:37	0:14	LINE FAULT
4	14-Apr-20	BAGALKOT	110	HIDIKAL-ITANAL	HIDIKAL_110	0:37	23:59	23:22	LINE CLEAR AVAILED
5	14-Apr-20	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	0:00	12:18	12:18	LINE CLEAR AVAILED
6	14-Apr-20	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	12:15	23:59	11:44	LINE FAULT
7	14-Apr-20	BAGALKOT	220	GUTTUR1-HAVERI	HAVERI_220	17:54	18:20	0:26	LINE CLEAR AVAILED
8	14-Apr-20	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	14:01	17:49	3:48	LINE FAULT
9	14-Apr-20	BAGALKOT	220	HARTI1-BIDNAL	BIDNAL_220	15:07	19:15	4:08	LINE CLEAR AVAILED
10	14-Apr-20	BAGALKOT	220	HARTI1-GADAG	GADAG_220	0:00	14:29	14:29	LINE CLEAR AVAILED
11	14-Apr-20	BAGALKOT	220	HARTI2-BIDNAL	BIDNAL_220	13:29	19:17	5:48	LINE FAULT
12	14-Apr-20	BAGALKOT	220	HARTI2-GADAG	GADAG_220	0:00	20:08	20:08	LINE CLEAR AVAILED
13	14-Apr-20	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	12:54	13:34	0:40	HAND TRIPPED
14	14-Apr-20	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE	13:20	13:50	0:30	MAIN SUPPLY FAILURE
15	14-Apr-20	BENGALURU	66	HEBBALA 220 - BANASAWADI	BANASAWADI	13:14	13:38	0:24	MAIN SUPPLY FAILURE
16	14-Apr-20	BENGALURU	66	HEBBALA 220 - IISc	IISc	13:14	13:31	0:17	MAIN SUPPLY FAILURE
17	14-Apr-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	9:18	9:30	0:12	LINE FAULT
18	14-Apr-20	BENGALURU	66	HV1	YELDUR	12:50	13:04	0:14	TRANSFORMER FAULT
19	14-Apr-20	BENGALURU	66	HV1	HEBBALA 220	13:14	13:30	0:16	MAIN SUPPLY FAILURE
20	14-Apr-20	BENGALURU	66	HV2	HEBBALA 220	13:14	13:30	0:16	MAIN SUPPLY FAILURE
21	14-Apr-20	BENGALURU	66	HV2	MANYATHA TECH PARK 220	13:14	13:54	0:40	MAIN SUPPLY FAILURE
22	14-Apr-20	BENGALURU	66	HV3	HEBBALA 220	13:14	13:30	0:16	MAIN SUPPLY FAILURE
23	14-Apr-20	BENGALURU	66	HV3	MANYATHA TECH PARK 220	13:14	13:54	0:40	MAIN SUPPLY FAILURE
24	14-Apr-20	BENGALURU	66	HV4	MANYATHA TECH PARK 220	13:14	13:54	0:40	MAIN SUPPLY FAILURE
25	14-Apr-20	BENGALURU	66	MANYATHA TECH PARK 220 - SHOBHA CITY(EHT)	SHOBHA CITY(EHT)	13:14	13:54	0:40	MAIN SUPPLY FAILURE
26	14-Apr-20	BENGALURU	220	HEBBALA 220 - YELAHANKA 220	HEBBALA 220	13:14	13:27	0:13	MAIN SUPPLY FAILURE
27	14-Apr-20	BENGALURU	220	MANYATHA TECH PARK 220 - YELAHANKA 220	MANYATHA TECH PARK	13:14	13:54	0:40	MAIN SUPPLY FAILURE
28	14-Apr-20	BENGALURU	220	YELAHANKA 220 - MANYATHA 220	MANYATHA 220, HEBBAL 220	13:14	16:55	3:41	LINE FAULT
29	14-Apr-20	GULBARGA	110	SINDHANOOR220-TURVIHAL	TURVIHAL_110	12:35	12:45	0:10	LINE FAULT
30	14-Apr-20	HASSAN	66	HV1	RAMPURA_66	10:39	10:55	0:16	LINE CLEAR AVAILED
31	14-Apr-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	21:16	21:23	0:07	LINE FAULT
32	14-Apr-20	HASSAN	110	HV1	BIRUR_110	7:47	10:05	2:18	TRANSFORMER FAULT
33	14-Apr-20	HASSAN	110	SAGARA-SORABA	SAGARA_110	10:46	13:25	2:39	LINE CLEAR AVAILED
34	14-Apr-20	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	0:00	10:57	10:57	LINE FAULT
35	14-Apr-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	5:24	5:24	LINE CLEAR AVAILED
36	14-Apr-20	MYSURU	66	HV 1	MADHUVANAHALLI_220	11:24	11:32	0:08	TRANSFORMER FAULT
37	14-Apr-20	MYSURU	66	HV 1	ELAVALA_66	12:57	13:04	0:07	TRANSFORMER FAULT
38	14-Apr-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE(P D KOTE)	HARIYABBE_66	19:08	19:10	0:01	HAND TRIPPED
39	14-Apr-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	17:23	17:34	0:11	LINE FAULT
40	14-Apr-20	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	14:01	14:28	0:27	LINE FAULT
41	14-Apr-20	TUMKUR	66	TR-1	SHYLA PURA_66	6:13	6:23	0:09	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
42	14-Apr-20	TUMKUR	66	TR-2	MANGALWADA_66	18:16	18:20	0:03	TRANSFORMER FAULT
43	14-Apr-20	TUMKUR	66	TR-2	MATHOD_66	9:41	9:47	0:05	TRANSFORMER FAULT
44	14-Apr-20	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	12:23	15:56	3:32	LINE FAULT
45	14-Apr-20	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	12:33	16:06	3:32	LINE FAULT
46	14-Apr-20	TUMKUR	220	GUTTUR 400KV- KAIGA400KV 2	GUTUR_400	14:54	15:15	0:20	LINE FAULT
47	15-Apr-20	BAGALKOT	110	110/11KV,HV2	MUDEDEBIHAL_110	23:25	1:27	2:02	TRANSFORMER FAULT
48	15-Apr-20	BAGALKOT	110	110/11KV,HV2	MUDEDEBIHAL_110	9:25	9:35	0:10	TRANSFORMER FAULT
49	15-Apr-20	BAGALKOT	110	110/11KV,HV3	RAIBAG_10	19:11	19:21	0:10	TRANSFORMER FAULT
50	15-Apr-20	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	17:48	23:59	6:11	LINE CLEAR AVAILED
51	15-Apr-20	BAGALKOT	220	BELGAUM220-NARENDRA1	BELGAUM_220	3:35	3:59	0:24	LINE FAULT
52	15-Apr-20	BAGALKOT	220	CHIKKODI-KUDUCHI	CHIKKODI_220	3:44	4:06	0:22	HAND TRIPPED
53	15-Apr-20	BAGALKOT	220	HARTHI1&2-GADAG	GADAG_220	0:37	23:59	23:22	LINE CLEAR AVAILED
54	15-Apr-20	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	14:03	21:21	7:18	LINE FAULT
55	15-Apr-20	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	18:04	18:48	0:43	LINE FAULT
56	15-Apr-20	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	16:46	16:56	0:10	LINE FAULT
57	15-Apr-20	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	16:56	19:32	2:35	LINE FAULT
58	15-Apr-20	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	19:32	20:52	1:20	LINE FAULT
59	15-Apr-20	BENGALURU	66	HV1	KANAKPURA 66	11:50	11:52	0:02	LINE CLEAR AVAILED
60	15-Apr-20	BENGALURU	66	HV2	KANAKPURA 66	11:00	11:05	0:05	LINE CLEAR AVAILED
61	15-Apr-20	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	2:55	3:29	0:34	LINE FAULT
62	15-Apr-20	BENGALURU	66	ST JOHNS - ADUGODI	ST JOHNS	18:26	18:31	0:05	LOAD CHANGE OVER
63	15-Apr-20	BENGALURU	66	ST JOHNS - HSR LAYOUT 220	ST JOHNS	17:28	17:36	0:08	LINE CLEAR AVAILED
64	15-Apr-20	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR	5:03	5:10	0:06	LINE FAULT
65	15-Apr-20	GULBARGA	110	HV1, HV2	YELBURGA_110	15:26	17:15	1:49	LINE CLEAR AVAILED
66	15-Apr-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	19:51	20:00	0:09	LINE FAULT
67	15-Apr-20	HASSAN	66	HV1	RAMPURA_66	11:57	12:35	0:38	LINE CLEAR AVAILED
68	15-Apr-20	HASSAN	66	HV1	SAKLESH PURA_66	17:46	17:57	0:11	TRANSFORMER FAULT
69	15-Apr-20	HASSAN	66	MRSSHM-DVG2	MRS MG_220	12:09	12:16	0:07	LINE FAULT
70	15-Apr-20	HASSAN	110	HV2	HALADY_110	19:15	19:24	0:09	TRANSFORMER FAULT
71	15-Apr-20	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	18:36	18:55	0:19	LINE CLEAR AVAILED
72	15-Apr-20	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:37	11:36	0:59	LINE CLEAR AVAILED
73	15-Apr-20	HASSAN	110	LV1	KEMAR_220	12:15	12:32	0:17	LINE CLEAR AVAILED
74	15-Apr-20	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	12:10	12:54	0:44	HAND TRIPPED
75	15-Apr-20	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	10:40	11:37	0:57	NFBC ISSUED
76	15-Apr-20	MYSURU	66	HV4	SFC SHIVA_66	14:15	16:33	2:18	LINE CLEAR AVAILED
77	15-Apr-20	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66	5:04	5:19	0:15	LINE FAULT
78	15-Apr-20	MYSURU	66	MADDUR-K.HONNALLGERE	SOMANAHALLI_66	5:03	5:23	0:20	LINE FAULT
79	15-Apr-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66	11:19	11:25	0:05	LINE FAULT
80	15-Apr-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA	22:05	22:27	0:21	MAIN SUPPLY FAILURE
81	15-Apr-20	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 1	KORATAGERE_66, CHIKKATOTLUKERE_66, BELAD	0:22	0:32	0:10	LINE FAULT
82	15-Apr-20	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	13:22	14:55	1:33	MAIN SUPPLY FAILURE
83	15-Apr-20	TUMKUR	66	TR-1	KUNIGAL_66	11:31	15:12	3:40	LINE CLEAR AVAILED
84	15-Apr-20	TUMKUR	66	TR-1	LINGDHALLI_66	15:48	15:54	0:06	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
85	15-Apr-20	TUMKUR	66	TR-1	MAYAKONDA_66	2:12	3:18	1:06	MAIN SUPPLY FAILURE
86	15-Apr-20	TUMKUR	66	TR-2	AVAREGERE_66	13:49	14:23	0:34	LINE CLEAR AVAILED
87	15-Apr-20	TUMKUR	66	TR-2	CHANNAGIRI_66	6:03	6:17	0:13	TRANSFORMER FAULT
88	15-Apr-20	TUMKUR	66	TR-2	CHANNAGIRI_66	8:57	9:43	0:46	TRANSFORMER FAULT
89	15-Apr-20	TUMKUR	66	TR-2	CHANNAGIRI_66	18:53	19:14	0:21	TRANSFORMER FAULT
90	15-Apr-20	TUMKUR	66	TR-2	TAVAREKERE(H)_66	11:17	12:20	1:03	LINE CLEAR AVAILED
91	15-Apr-20	TUMKUR	110	TR-1	KBCROSS_220	5:40	6:09	0:28	TRANSFORMER FAULT
92	15-Apr-20	TUMKUR	110	TR-1	TALKERE_110	13:21	14:04	0:43	LINE CLEAR AVAILED
93	15-Apr-20	TUMKUR	110	TR-2	SAMPIGE_110	12:04	12:55	0:51	LINE CLEAR AVAILED
94	15-Apr-20	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	14:29	16:11	1:42	LINE FAULT
95	15-Apr-20	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	14:29	16:13	1:43	LINE FAULT
96	15-Apr-20	TUMKUR	220	TR-1	ANCHEPALYA_220	11:22	11:29	0:07	TRANSFORMER FAULT
97	16-Apr-20	BAGALKOT	110	110/11KV,HV1	ANKALI_110	11:31	13:12	1:41	TRANSFORMER FAULT
98	16-Apr-20	BAGALKOT	110	110/11KV,HV1	NARAGAL_110	14:01	14:12	0:11	TRANSFORMER FAULT
99	16-Apr-20	BAGALKOT	110	110/11KV,HV1	NARAGAL_110	18:38	18:43	0:05	TRANSFORMER FAULT
100	16-Apr-20	BAGALKOT	110	110/11KV,HV2	AIGALI_110	16:30	17:21	0:51	TRANSFORMER FAULT
101	16-Apr-20	BAGALKOT	110	110/11KV,HV2	HUKKERI_110	17:50	18:00	0:10	TRANSFORMER FAULT
102	16-Apr-20	BAGALKOT	110	110/11KV,HV2	HUKKERI_110	19:05	19:10	0:05	TRANSFORMER FAULT
103	16-Apr-20	BAGALKOT	110	110/11KV,HV2	KHANAPUR_110	15:28	15:51	0:23	HAND TRIPPED
104	16-Apr-20	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	16:54	17:08	0:14	TRANSFORMER FAULT
105	16-Apr-20	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	17:10	18:00	0:50	LINE CLEAR AVAILED
106	16-Apr-20	BAGALKOT	110	110/33KV,HV1	TIKOTA_110,BIDARI_33	15:55	16:00	0:05	TRANSFORMER FAULT
107	16-Apr-20	BAGALKOT	110	110/33KV,HV1	TIKOTA_110,BIDARI_33	16:18	16:23	0:05	TRANSFORMER FAULT
108	16-Apr-20	BAGALKOT	110	110/33KV,HV1	TIKOTA_110,BIDARI_33	16:36	16:43	0:07	TRANSFORMER FAULT
109	16-Apr-20	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA_33,MYTRA SOLAR_33	18:02	18:22	0:20	TRANSFORMER FAULT
110	16-Apr-20	BAGALKOT	110	110/33KV,HV4	ANKALI_110,KOTAWADI&SHIRAGUPPI_33	11:10	14:10	3:00	LINE CLEAR AVAILED
111	16-Apr-20	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	KAVALWADA_110	9:14	18:53	9:39	LINE CLEAR AVAILED
112	16-Apr-20	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	HIDIKAL DAM_110	16:31	17:49	1:18	LINE CLEAR AVAILED
113	16-Apr-20	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	11:43	11:47	0:04	LINE CLEAR AVAILED
114	16-Apr-20	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	5:16	5:21	0:05	LINE FAULT
115	16-Apr-20	BAGALKOT	110	BELGAUM220-ANKALAGI	ANKALAGI_110	15:37	17:33	1:56	LINE FAULT
116	16-Apr-20	BAGALKOT	110	BELGAUM220-HUKKERI(UCHAGOAN)	UCHAGOAN_110	15:37	17:49	2:12	LINE FAULT
117	16-Apr-20	BAGALKOT	110	CHIKKODI220-RAIBAG1	RAIBAG_110	19:14	20:13	0:59	LINE FAULT
118	16-Apr-20	BAGALKOT	110	CHIKKODI220-RAIBAG2	RAIBAG_110	19:14	23:59	4:45	LINE FAULT
119	16-Apr-20	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	17:50	23:59	6:09	LINE CLEAR AVAILED
120	16-Apr-20	BAGALKOT	110	HIDIKAL-ITNAL	ITNAL_110	0:00	17:06	17:06	LINE CLEAR AVAILED
121	16-Apr-20	BAGALKOT	110	KUDUCHI220-AINAPUR(KUDUCHI)	AINAPUR_110	10:22	11:39	1:17	LINE CLEAR AVAILED
122	16-Apr-20	BAGALKOT	220	MAHALINGAPUR-NARENDRA2	MAHALINGAPUR	17:39	19:35	1:56	LINE FAULT
123	16-Apr-20	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	6:47	7:01	0:13	LINE FAULT
124	16-Apr-20	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	5:09	5:27	0:18	LINE FAULT
125	16-Apr-20	BENGALURU	66	GANJIGUNTE - DIBURALLI	SADLI, JULLUPALYA, DIBURALLI	9:24	9:38	0:14	LOAD CHANGE OVER
126	16-Apr-20	BENGALURU	66	HV1	D CROSS	2:00	2:07	0:07	TRANSFORMER FAULT
127	16-Apr-20	BENGALURU	66	HV1	KUMBALGODU	12:56	13:00	0:03	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
128	16-Apr-20	BENGALURU	66	HV2	KODIHALLI(HAROBELE)	13:55	15:21	1:26	LINE CLEAR AVAILED
129	16-Apr-20	BENGALURU	66	HV2	HOSKOTE 66	14:38	16:16	1:38	TRANSFORMER FAULT
130	16-Apr-20	BENGALURU	66	HV2	KUMBALGODU	11:06	11:10	0:03	LINE CLEAR AVAILED
131	16-Apr-20	BENGALURU	66	MANYATHA 220 - PEENYA 2	SAHAKARINAGAR	7:42	10:44	3:02	LINE FAULT
132	16-Apr-20	BENGALURU	66	MELUR - JAGAMKOTE	JAGAMKOTE, VIJAYPURA	9:20	9:26	0:06	LOAD CHANGE OVER
133	16-Apr-20	BENGALURU	66	R R NAGAR - VRUSHABAVATHI 220	R R NAGAR	16:35	16:38	0:03	LOAD CHANGE OVER
134	16-Apr-20	BENGALURU	66	SHOBHA FOREST - SUBRAMANYAPURA 220	SHOBHA FOREST	11:41	12:27	0:46	MAIN SUPPLY FAILURE
135	16-Apr-20	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	15:37	16:29	0:52	LINE FAULT
136	16-Apr-20	BENGALURU	66	SUBRAMANYAPURA 220 - SOMANAHALLI 2	SHOBHA FOREST, BRIGADE MEDOS	11:41	12:15	0:34	LINE FAULT
137	16-Apr-20	BENGALURU	66	SURYANAGAR - ANEKAL	ANEKAL	14:04	14:41	0:36	LINE FAULT
138	16-Apr-20	BENGALURU	66	VG DODDI - ANCHEPALYA	VG DODDI	9:53	12:26	2:32	LINE CLEAR AVAILED
139	16-Apr-20	BENGALURU	66	VIJAYPURA - DB PURA 220	VIJAYPURA, JAGAMKOTE	5:50	6:10	0:20	LOAD CHANGE OVER
140	16-Apr-20	GULBARGA	110	HV2	HATTI_110	14:17	14:30	0:13	TRANSFORMER FAULT
141	16-Apr-20	GULBARGA	110	HV2	HATTI_110	15:10	15:15	0:05	TRANSFORMER FAULT
142	16-Apr-20	GULBARGA	110	HV2	KAVITHAL_110	14:40	15:30	0:50	TRANSFORMER FAULT
143	16-Apr-20	GULBARGA	110	HV2	SHORAPUR_110	14:49	15:52	1:03	TRANSFORMER FAULT
144	16-Apr-20	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPUR_110	21:58	22:16	0:18	LINE FAULT
145	16-Apr-20	GULBARGA	400	JSWVL-GUTTUR	GUTTUR_400	15:00	17:51	2:51	LINE CLEAR AVAILED
146	16-Apr-20	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	9:50	12:18	2:28	LINE CLEAR AVAILED
147	16-Apr-20	HASSAN	66	HV1	KUDLIGERE_66	12:41	15:07	2:26	LINE CLEAR AVAILED
148	16-Apr-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	14:53	15:01	0:08	LINE FAULT
149	16-Apr-20	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	9:13	13:05	3:52	NFBC ISSUED
150	16-Apr-20	HASSAN	110	HV2	HALADY_110	16:12	16:32	0:20	LINE CLEAR AVAILED
151	16-Apr-20	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	9:13	13:05	3:52	LINE CLEAR AVAILED
152	16-Apr-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	14:12	14:16	0:04	LINE FAULT
153	16-Apr-20	HASSAN	220	KEMAR-Varahi2	KEMAR_220	14:12	14:51	0:39	LINE FAULT
154	16-Apr-20	HASSAN	220	TALAGU-STRP1	TALAGUPPA_400	9:58	16:00	6:02	LINE CLEAR AVAILED
155	16-Apr-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	14:12	14:52	0:40	LINE FAULT
156	16-Apr-20	MYSURU	66	HV2	DUNDANAHALLI_66	12:35	12:38	0:02	HAND TRIPPED
157	16-Apr-20	MYSURU	66	HV2	SANTHEMARAHALLI_66	10:49	11:11	0:22	LINE CLEAR AVAILED
158	16-Apr-20	MYSURU	66	HV4	SFCSHIVA_66	9:05	11:08	2:03	LINE CLEAR AVAILED
159	16-Apr-20	MYSURU	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOT	9:50	9:55	0:05	LINE FAULT
160	16-Apr-20	MYSURU	66	KADAKOLA-SARGUR 2	B MATKERE_66, CHANDRAVADI_66, DOORA_66, I	9:50	9:55	0:05	LINE FAULT
161	16-Apr-20	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAG	14:42	14:52	0:10	LINE FAULT
162	16-Apr-20	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAG	15:12	15:21	0:08	LINE FAULT
163	16-Apr-20	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAG	16:35	16:44	0:09	LINE FAULT
164	16-Apr-20	TUMKUR	66	DAVANGERE66-DAVANGERE SRS	DAVANAGERE_66	17:18	17:24	0:06	LINE FAULT
165	16-Apr-20	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	9:10	10:05	0:54	LINE CLEAR AVAILED
166	16-Apr-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	7:51	7:59	0:08	LINE FAULT
167	16-Apr-20	TUMKUR	66	HULIYURDURGA- ANCHEPALYA	HULIYURDURGA_66	12:39	13:05	0:26	LINE FAULT
168	16-Apr-20	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	12:32	12:34	0:01	LINE FAULT
169	16-Apr-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA	0:11	0:18	0:06	LINE FAULT
170	16-Apr-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA	6:16	6:32	0:16	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
171	16-Apr-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA	7:16	7:25	0:09	LINE FAULT
172	16-Apr-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA	8:09	8:49	0:40	LINE FAULT
173	16-Apr-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA	10:11	10:16	0:04	LINE FAULT
174	16-Apr-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA	12:30	12:36	0:06	LINE FAULT
175	16-Apr-20	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	MADHUGIRI_66	14:39	15:06	0:27	LINE CLEAR AVAILED
176	16-Apr-20	TUMKUR	66	MADHUGIRI 66kV- MADHUGIRI	MADHUGIRI_66	14:39	15:06	0:27	LINE CLEAR AVAILED
177	16-Apr-20	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	16:05	16:19	0:14	LINE FAULT
178	16-Apr-20	TUMKUR	66	TR-1	MADHUGIRI_66	14:39	15:06	0:27	LINE CLEAR AVAILED
179	16-Apr-20	TUMKUR	66	TR-2	BRAHMASANDRA_66	17:58	18:31	0:32	LINE CLEAR AVAILED
180	16-Apr-20	TUMKUR	66	TR-2	HALUVAGALU_66	7:57	8:07	0:09	TRANSFORMER FAULT
181	16-Apr-20	TUMKUR	66	TR-2	MADHUGIRI_66	14:39	15:06	0:27	LINE CLEAR AVAILED
182	16-Apr-20	TUMKUR	66	TR-2	MANGALWADA_66	22:01	22:04	0:03	TRANSFORMER FAULT
183	16-Apr-20	TUMKUR	66	TR-2	TELAGI_66	17:53	17:56	0:03	HAND TRIPPED
184	17-Apr-20	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	18:32	18:38	0:06	TRANSFORMER FAULT
185	17-Apr-20	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:37	13:54	1:17	LINE CLEAR AVAILED
186	17-Apr-20	BAGALKOT	110	110/11KV,HV 2	AKSHAYA COLONY_110	11:30	12:17	0:47	TRANSFORMER FAULT
187	17-Apr-20	BAGALKOT	110	110/11KV,HV 2	AMBEWADI_220	11:59	12:02	0:03	TRANSFORMER FAULT
188	17-Apr-20	BAGALKOT	110	110/11KV,HV 2	GOKAK_110	8:19	10:00	1:41	LINE CLEAR AVAILED
189	17-Apr-20	BAGALKOT	110	110/11KV,HV 2	GOKAK_110	14:51	14:54	0:03	TRANSFORMER FAULT
190	17-Apr-20	BAGALKOT	110	110/11KV,HV 4	KANABARGI LAYOUT_110	23:05	23:25	0:20	MAIN SUPPLY FAILURE
191	17-Apr-20	BAGALKOT	110	110/11KV,HV2	KANABARGI LAYOUT_110	23:05	23:20	0:15	MAIN SUPPLY FAILURE
192	17-Apr-20	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARG	8:17	8:24	0:07	TRANSFORMER FAULT
193	17-Apr-20	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARG	17:42	17:46	0:04	TRANSFORMER FAULT
194	17-Apr-20	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	21:13	22:58	1:45	LINE CLEAR AVAILED
195	17-Apr-20	BAGALKOT	110	BELGAUM220-KANABARGI LAYOUT	KANABARGI LAYOUT_110	22:06	23:59	1:53	LINE CLEAR AVAILED
196	17-Apr-20	BAGALKOT	110	HUBLI220-RAMANKOPPA	RAMANKOPPA_110	16:44	17:39	0:55	LINE FAULT
197	17-Apr-20	BAGALKOT	110	KUDACHI-MORAB	MORAB_110	11:05	13:22	2:17	LINE CLEAR AVAILED
198	17-Apr-20	BAGALKOT	110	PG HUSHYAL-MUDALGI	NAGNUR_110, MUDAGI_110	6:07	6:21	0:14	LINE FAULT
199	17-Apr-20	BAGALKOT	110	SOUDATTI220-RAMDURG1	RAMDURG_110	19:22	21:18	1:56	LINE FAULT
200	17-Apr-20	BAGALKOT	110	SOUDATTI220-RAMDURG2	RAMDURG_110	19:22	23:59	4:37	LINE FAULT
201	17-Apr-20	BAGALKOT	110	SOUDATTI220-YARGATTI	YARGATTI_110	20:01	21:22	1:21	LINE FAULT
202	17-Apr-20	BAGALKOT	110	VAJRAMATTI220-MELLIGERI	MELLIGERI_110	10:35	10:52	0:17	HAND TRIPPED
203	17-Apr-20	BAGALKOT	220	220/110KV,HV3&LV3	MAHALINGAPUR_220, HIDIKAL_110, ITANAL_110	11:30	11:52	0:22	LINE CLEAR AVAILED
204	17-Apr-20	BAGALKOT	220	SOUDATTI-BIDNAL	BIDNAL_220	22:21	23:59	1:38	LINE FAULT
205	17-Apr-20	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE	14:10	14:25	0:15	MAIN SUPPLY FAILURE
206	17-Apr-20	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE	14:30	15:08	0:38	MAIN SUPPLY FAILURE
207	17-Apr-20	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE	15:20	16:05	0:45	LINE FAULT
208	17-Apr-20	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	7:34	9:00	1:26	LINE CLEAR AVAILED
209	17-Apr-20	BENGALURU	66	HV1	AGALAKOTE	18:05	18:10	0:05	TRANSFORMER FAULT
210	17-Apr-20	BENGALURU	66	HV1	BAIRKUR	10:31	11:05	0:34	LINE CLEAR AVAILED
211	17-Apr-20	BENGALURU	66	HV2	B G ROAD	4:40	4:47	0:07	TRANSFORMER FAULT
212	17-Apr-20	BENGALURU	66	HV2	GANJIGUNTE	6:24	6:32	0:08	TRANSFORMER FAULT
213	17-Apr-20	BENGALURU	66	HV2	MANYATHA TECH PARK 220	14:03	14:22	0:19	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
214	17-Apr-20	BENGALURU	66	HV3	MANYATHA TECH PARK 220	14:03	14:22	0:19	MAIN SUPPLY FAILURE
215	17-Apr-20	BENGALURU	66	HV4	MANYATHA TECH PARK 220	14:03	14:22	0:19	MAIN SUPPLY FAILURE
216	17-Apr-20	BENGALURU	66	MANYATHA TECH PARK 220 - SHOBHA CITY(EHT)	SHOBHA CITY(EHT)	14:03	14:22	0:19	MAIN SUPPLY FAILURE
217	17-Apr-20	BENGALURU	220	HOODY 220 - MANYATHA TECH PARK 220	MANYATHA TECH PARK 220	14:03	14:22	0:19	LINE CLEAR AVAILED
218	17-Apr-20	GULBARGA	110	GURUMITAKAL-KONKAL	KONKAL_110	9:20	9:35	0:15	LINE CLEAR AVAILED
219	17-Apr-20	GULBARGA	110	HUMNABAD220-SASTHAPUR	RAJESHWAR_110, SASTHAPUR_110, MANTHAL_110	20:47	21:15	0:28	LINE CLEAR AVAILED
220	17-Apr-20	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	15:15	16:20	1:05	LINE FAULT
221	17-Apr-20	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPUR_110	8:58	9:08	0:10	LINE FAULT
222	17-Apr-20	GULBARGA	220	KAPNOOR-SHAHABAD	SHAHABAD_220	17:15(17.04.20)			LINE IS OPEN:LINE FAULT
223	17-Apr-20	GULBARGA	220	KAPNOOR-SHAHPUR	SHAHPUR_220	17:15(17.04.20)			LINE IS OPEN:LINE FAULT
224	17-Apr-20	GULBARGA	220	RTPS-SHAHPUR1	SHAHPUR_220	9:40	17:25	7:45	LINE CLEAR AVAILED
225	17-Apr-20	HASSAN	66	HV1	MAGGE_66	10:39	12:07	1:28	LINE CLEAR AVAILED
226	17-Apr-20	HASSAN	66	HV2	SHANTHIGRAMMA_66	10:46	11:56	1:10	LINE CLEAR AVAILED
227	17-Apr-20	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	16:56	16:59	0:03	HAND TRIPPED
228	17-Apr-20	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	17:24	17:27	0:03	LINE FAULT
229	17-Apr-20	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	16:58	17:18	0:20	MAIN SUPPLY FAILURE
230	17-Apr-20	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	9:35	14:35	5:00	LINE CLEAR AVAILED
231	17-Apr-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	10:06	13:04	2:58	LINE CLEAR AVAILED
232	17-Apr-20	HASSAN	110	HV1	HOSANGADI_110	11:17	12:21	1:04	LINE CLEAR AVAILED
233	17-Apr-20	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	17:05	20:03	2:58	LINE FAULT
234	17-Apr-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:05	13:04	2:59	LINE CLEAR AVAILED
235	17-Apr-20	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:44	13:06	2:22	LINE CLEAR AVAILED
236	17-Apr-20	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	10:43	13:06	2:23	NFBC ISSUED
237	17-Apr-20	HASSAN	220	HV3	KAVOOR_220	9:54	14:30	4:36	LINE CLEAR AVAILED
238	17-Apr-20	MYSORE	66	BANNUR-VAJMANGALA	BANNUR_66	11:16	13:45	2:28	LINE FAULT
239	17-Apr-20	MYSORE	66	HV1	ANEGOLAL_66	5:59	6:17	0:18	HAND TRIPPED
240	17-Apr-20	MYSORE	66	HV1	SFCSHIVA_66	9:54	10:52	0:57	LINE CLEAR AVAILED
241	17-Apr-20	MYSORE	66	HV1	SFCSHIVA_66	15:09	15:28	0:19	HAND TRIPPED
242	17-Apr-20	MYSORE	66	HV1	BANNUR_66	11:11	23:59	12:47	TRANSFORMER FAULT
243	17-Apr-20	MYSORE	66	HV2	HAMPAPURA_66	10:40	11:00	0:20	TRANSFORMER FAULT
244	17-Apr-20	MYSORE	66	HV4	SFCSHIVA_66	8:42	9:51	1:09	LINE CLEAR AVAILED
245	17-Apr-20	MYSORE	66	HV4	SFCSHIVA_66	15:09	15:19	0:10	HAND TRIPPED
246	17-Apr-20	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOT	13:21	13:24	0:02	LINE FAULT
247	17-Apr-20	MYSORE	66	KADAKOLA-SARGUR 2	B MATKERE_66CHANDRAVADI_66, DOORA_66, H	13:21	13:24	0:02	LINE FAULT
248	17-Apr-20	MYSORE	66	MEGHALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66	15:48	15:55	0:07	LINE FAULT
249	17-Apr-20	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAG	16:06	16:14	0:08	LINE FAULT
250	17-Apr-20	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAG	16:42	16:49	0:06	LINE FAULT
251	17-Apr-20	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAG	17:47	17:53	0:05	LINE FAULT
252	17-Apr-20	MYSORE	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66, PANDAVAPURA_66	10:30	10:34	0:04	LINE FAULT
253	17-Apr-20	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	10:13	12:27	2:13	LINE CLEAR AVAILED
254	17-Apr-20	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGA	10:19	12:05	1:46	LINE CLEAR AVAILED
255	17-Apr-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA	6:37	6:46	0:08	LINE FAULT
256	17-Apr-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	3:16	3:27	0:11	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
257	17-Apr-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	19:13	19:25	0:11	LINE FAULT
258	17-Apr-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	18:09	18:19	0:10	LINE FAULT
259	17-Apr-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA	6:19	6:29	0:10	LINE FAULT
260	17-Apr-20	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	9:15	9:25	0:09	LINE FAULT
261	17-Apr-20	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	15:55	16:49	0:53	LINE FAULT
262	17-Apr-20	TUMKUR	66	SASALUHALLA-CKJRKUTT	SASALUHALLA_66	12:39	12:45	0:05	LINE FAULT
263	17-Apr-20	TUMKUR	66	TR-1	CHANNAGIRI_66	6:25	6:31	0:06	TRANSFORMER FAULT
264	17-Apr-20	TUMKUR	66	TR-1	CHANNAGIRI_66	13:11	13:17	0:06	TRANSFORMER FAULT
265	17-Apr-20	TUMKUR	66	TR-1	CHANNAGIRI_66	17:56	18:03	0:06	TRANSFORMER FAULT
266	17-Apr-20	TUMKUR	66	TR-1	SAVALANGA_66	14:14	14:19	0:05	LINE CLEAR AVAILED
267	17-Apr-20	TUMKUR	66	TR-2	CHANNAGIRI_66	13:16	13:20	0:04	TRANSFORMER FAULT
268	17-Apr-20	TUMKUR	66	TR-2	GARAGA_66	16:58	18:35	1:36	LINE CLEAR AVAILED
269	17-Apr-20	TUMKUR	66	TR-2	TAVAREKERE(H)_66	11:52	12:25	0:32	HAND TRIPPED
270	17-Apr-20	TUMKUR	66	TR-2	TELAGI_66	9:31	11:17	1:45	LINE CLEAR AVAILED
271	17-Apr-20	TUMKUR	110	TR-1	MAYASANDRA_110	17:24	18:13	0:49	LINE CLEAR AVAILED
272	17-Apr-20	TUMKUR	220	TR-1(HV SIDE)	GUTTUR_400	11:55	13:33	1:37	LINE CLEAR AVAILED
273	18-Apr-20	BAGALKOT	110	110/11KV, HV2	MUDEDEBIHAL_110	15:17	16:14	0:57	LINE CLEAR AVAILED
274	18-Apr-20	BAGALKOT	110	110/11KV, HV2	MUDEDEBIHAL_110	20:08	20:16	0:08	TRANSFORMER FAULT
275	18-Apr-20	BAGALKOT	110	110/11KV,HV 1	CHIKKODI_110	12:47	14:32	1:45	TRANSFORMER FAULT
276	18-Apr-20	BAGALKOT	110	110/11KV,HV 4	HUKKERI_110	17:17	17:22	0:05	TRANSFORMER FAULT
277	18-Apr-20	BAGALKOT	110	110/11KV,HV1	BILAGI_110	15:34	15:43	0:09	TRANSFORMER FAULT
278	18-Apr-20	BAGALKOT	110	110/11KV,HV2	SHIROL_110	16:51	17:02	0:11	TRANSFORMER FAULT
279	18-Apr-20	BAGALKOT	110	110/33KV,HV 2	ANKOLA_110& 33KV SEA BIRD & MAST	20:55	23:23	2:28	TRANSFORMER FAULT
280	18-Apr-20	BAGALKOT	110	110/33KV,HV 2	GULEDGUDD_110 &33KV SIRUR &KAMATAGI	21:01	21:10	0:09	TRANSFORMER FAULT
281	18-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,DULKHED-33, NEVARC	15:10	15:15	0:05	TRANSFORMER FAULT
282	18-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,DULKHED-33, NEVARC	15:58	16:02	0:04	TRANSFORMER FAULT
283	18-Apr-20	BAGALKOT	110	220/110KV,LV2	MKHUBLI_220	22:58	23:58	1:00	HAND TRIPPED
284	18-Apr-20	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	15:20	16:13	0:53	LINE CLEAR AVAILED
285	18-Apr-20	BAGALKOT	110	BALAGI SUGARS-MUDEDEBIHAL	MUDEDEBIHAL_110	15:21	16:16	0:55	LINE CLEAR AVAILED
286	18-Apr-20	BAGALKOT	110	BANAHATTI-JAMAKHANDI	JAMAKHANDI_110	17:09	17:13	0:04	HAND TRIPPED
287	18-Apr-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	KANABARGI LAYOUT_110	0:00	9:59	9:59	LINE CLEAR AVAILED
288	18-Apr-20	BAGALKOT	110	BPCL-NARAGUND	NARAGUND_110	23:15	23:59	0:44	LINE FAULT
289	18-Apr-20	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	18:59	23:59	5:00	LINE FAULT
290	18-Apr-20	BAGALKOT	110	HIDIKAL-RAIBAG	RAIBAG_110	21:57	22:19	0:22	HAND TRIPPED
291	18-Apr-20	BAGALKOT	110	JOG-SIDDAPUR	SIDDAPUR_110	19:54	21:07	1:13	LINE FAULT
292	18-Apr-20	BAGALKOT	110	JOG-SIRSI	SIRSI_110	19:54	21:01	1:07	LINE FAULT
293	18-Apr-20	BAGALKOT	110	KARAWAR-SOLARIS(BINAGA)	BINAGA (EHT)_110	20:56	23:59	3:03	LINE FAULT
294	18-Apr-20	BAGALKOT	110	KN SOLAR-MUDEDEBIHAL	MUDEDEBIHAL_110	15:21	16:17	0:56	LINE CLEAR AVAILED
295	18-Apr-20	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	20:44	23:59	3:15	LINE FAULT
296	18-Apr-20	BAGALKOT	110	SOUDATTI220-RAMDURG2	RAMDURG_110	0:00	9:06	9:06	LINE CLEAR AVAILED
297	18-Apr-20	BAGALKOT	110	VAJRAMATTI220-BILAGI	BILAGI_110	21:20	21:41	0:21	LINE FAULT
298	18-Apr-20	BAGALKOT	110	YARAGATTI-KATKOL	KATKOL_110	2:57	3:07	0:10	HAND TRIPPED
299	18-Apr-20	BAGALKOT	220	220/110KV, HV1,LV1,HV2,LV2	MAHALINGAPUR_220, DAVLESHWAR_110, TERDA	17:20	17:42	0:22	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
300	18-Apr-20	BAGALKOT	220	220/110KV, HV1,LV1,HV2,LV2	MAHALINGAPUR_220, DAVLESHWAR_110, TERDA	20:27	22:05	1:38	LINE CLEAR AVAILED
301	18-Apr-20	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	13:27	14:49	1:22	LINE FAULT
302	18-Apr-20	BAGALKOT	220	BELGAUM-KANABARGI 1 (NARENDRA1)	BELGAUM_220	23:06	23:59	0:53	HAND TRIPPED
303	18-Apr-20	BAGALKOT	220	NAGJHARI2- HUBLI	HUBLI_220	18:03	23:59	5:56	LINE FAULT
304	18-Apr-20	BAGALKOT	220	NAGJHARI3- HUBLI	HUBLI_220	18:10	23:59	5:49	LINE FAULT
305	18-Apr-20	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	19:38	23:59	4:21	LINE FAULT
306	18-Apr-20	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	0:00	13:48	13:48	LINE CLEAR AVAILED
307	18-Apr-20	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SA	14:36	14:38	0:02	LINE CLEAR AVAILED
308	18-Apr-20	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	14:21	16:19	1:58	LINE FAULT
309	18-Apr-20	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	16:32	16:41	0:09	LINE FAULT
310	18-Apr-20	BENGALURU	66	HV1	SURYANAGAR	17:11	17:29	0:18	LINE CLEAR AVAILED
311	18-Apr-20	BENGALURU	66	HV1	MUDIYANUR	6:05	6:14	0:08	TRANSFORMER FAULT
312	18-Apr-20	BENGALURU	66	HV3	BANASHANKARI	12:21	12:34	0:13	TRANSFORMER FAULT
313	18-Apr-20	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI, EXORA	9:50	10:00	0:10	LOAD CHANGE OVER
314	18-Apr-20	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI, EXORA	6:45	7:00	0:15	LOAD CHANGE OVER
315	18-Apr-20	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	13:28	13:31	0:03	LOAD CHANGE OVER
316	18-Apr-20	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	13:04	13:26	0:22	LOAD CHANGE OVER
317	18-Apr-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAK	13:04	13:26	0:22	LOAD CHANGE OVER
318	18-Apr-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	11:35	11:53	0:18	LOAD CHANGE OVER
319	18-Apr-20	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	8:18	8:29	0:11	LINE FAULT
320	18-Apr-20	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:18	13:03	0:45	LINE CLEAR AVAILED
321	18-Apr-20	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66, UJJAINI_66, BENNEHALLI_66	17:21	23:59	6:38	LINE FAULT
322	18-Apr-20	GULBARGA	66	ITTAGI-HIREHADAGALLI2	HIREHADAGALI_66, GIRIYAPURA_66, SOVENAHA	17:17	17:19	0:02	HAND TRIPPED
323	18-Apr-20	GULBARGA	66	ITTAGI-HIREHADAGALLI2	HIREHADAGALI_66, GIRIYAPURA_66, SOVENAHA	17:44	18:25	0:41	LINE FAULT
324	18-Apr-20	GULBARGA	66	LV2	ITTAGI_220	17:44	18:10	0:26	TRANSFORMER FAULT
325	18-Apr-20	GULBARGA	110	ALIPUR-BELLARYSOUTH	BELLARYSOUTH_110, HALKUNDI_110	15:37	16:05	0:28	HAND TRIPPED
326	18-Apr-20	GULBARGA	110	HV1, HV2	LINGASUGUR_220	15:24	15:39	0:15	TRANSFORMER FAULT
327	18-Apr-20	GULBARGA	110	HV1, HV2	LINGASUGUR_220	20:52	21:19	0:27	TRANSFORMER FAULT
328	18-Apr-20	GULBARGA	110	HV1, HV2	LINGASUGUR_220	22:30	22:42	0:12	TRANSFORMER FAULT
329	18-Apr-20	GULBARGA	110	HV2	HATTI_110	15:20	15:28	0:08	TRANSFORMER FAULT
330	18-Apr-20	GULBARGA	110	HV3	HATTI_110	23:22	23:34	0:12	TRANSFORMER FAULT
331	18-Apr-20	GULBARGA	110	HV3	MANTHAL_110	16:25	17:10	0:45	TRANSFORMER FAULT
332	18-Apr-20	GULBARGA	110	RAJESHWAR-SASTHAPUR	SASTHAPUR_110	14:35	14:50	0:15	LINE FAULT
333	18-Apr-20	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	17:45	19:42	1:57	LINE FAULT
334	18-Apr-20	GULBARGA	110	SIDHANOOR220-SINDHANOOR	SINDHANOOR_110	10:08	10:18	0:10	LINE FAULT
335	18-Apr-20	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARTAGI_110,SREERAMNAGAR_110, GANGAVAT	10:55	13:45	2:50	LINE CLEAR AVAILED
336	18-Apr-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB,BTPS_WATER	10:55	13:35	2:40	LINE CLEAR AVAILED
337	18-Apr-20	GULBARGA	220	HV1	ITTAGI_220	15:54	16:00	0:06	TRANSFORMER FAULT
338	18-Apr-20	GULBARGA	220	LINGAPUR-BMMISPAT	BMMISPAT	15:54	18:53	2:59	LINE FAULT
339	18-Apr-20	GULBARGA	220	LINGAPUR-BTPS	BTPS_220	16:19	20:20	4:01	LINE FAULT
340	18-Apr-20	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	15:01	16:45	1:44	LINE FAULT
341	18-Apr-20	GULBARGA	220	LINGASUGUR-SHAHAPUR	LINGASUGUR_220	15:16	15:58	0:42	LINE FAULT
342	18-Apr-20	GULBARGA	220	LINGASUGUR-SINDHANOOR	SINDHANOOR_220	15:44	16:00	0:16	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
343	18-Apr-20	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHABAD_220	17:15(17.04.20)			LINE IS OPEN:LINE FAULT
344	18-Apr-20	GULBARGA	220	KAPNOOR-SHAHPUR	SHAHPUR_220	17:15(17.04.20)			LINE IS OPEN:LINE FAULT
345	18-Apr-20	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	1:55	2:09	0:14	LINE FAULT
346	18-Apr-20	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTIHALLY_66	10:11	10:18	0:07	LINE FAULT
347	18-Apr-20	HASSAN	66	HASSN22-SKPURA	HASSAN_220	1:55	2:08	0:13	LINE FAULT
348	18-Apr-20	HASSAN	66	HV1	MAGGE_66	1:56	2:12	0:16	MAIN SUPPLY FAILURE
349	18-Apr-20	HASSAN	66	HV1	SAKLESHPURA_66	1:55	2:10	0:15	TRANSFORMER FAULT
350	18-Apr-20	HASSAN	66	HV1	SAKLESHPURA_66	11:25	11:58	0:33	LINE CLEAR AVAILED
351	18-Apr-20	HASSAN	66	HV2	MAGGE_66	1:56	2:12	0:16	MAIN SUPPLY FAILURE
352	18-Apr-20	HASSAN	66	KANDLI-HASSAN	KANDLI_66	1:56	2:15	0:19	LINE FAULT
353	18-Apr-20	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	1:56	2:15	0:19	LINE FAULT
354	18-Apr-20	HASSAN	66	MATTAVAL-DIDGTHL	MATTAVAL_66	23:10	23:25	0:15	MAIN SUPPLY FAILURE
355	18-Apr-20	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	1:55	2:10	0:15	LINE FAULT
356	18-Apr-20	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	11:33	11:45	0:12	LINE FAULT
357	18-Apr-20	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	12:04	13:41	1:37	MAIN SUPPLY FAILURE
358	18-Apr-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	10:09	12:28	2:19	MAIN SUPPLY FAILURE
359	18-Apr-20	HASSAN	110	GURUVA-SLPWR	GURUVAYANAKERE_110	12:05	12:33	0:28	MAIN SUPPLY FAILURE
360	18-Apr-20	HASSAN	110	HV1	KONAJE_110	7:35	7:38	0:03	HAND TRIPPED
361	18-Apr-20	HASSAN	110	HV1	KONAJE_110	12:39	12:43	0:04	HAND TRIPPED
362	18-Apr-20	HASSAN	110	HV2	KONAJE_110	7:35	7:40	0:05	HAND TRIPPED
363	18-Apr-20	HASSAN	110	HV2	KONAJE_110	12:38	12:45	0:07	HAND TRIPPED
364	18-Apr-20	HASSAN	110	HV3	KONAJE_110	7:36	7:39	0:03	HAND TRIPPED
365	18-Apr-20	HASSAN	110	HV3	KONAJE_110	12:39	12:44	0:05	HAND TRIPPED
366	18-Apr-20	HASSAN	110	JOG-NK1	mghe_gen	20:10	21:11	1:01	LINE CLEAR AVAILED
367	18-Apr-20	HASSAN	110	JOG-NK2	mghe_gen	19:54	21:12	1:18	LINE FAULT
368	18-Apr-20	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	12:03	13:41	1:38	LINE FAULT
369	18-Apr-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:09	12:27	2:18	LINE CLEAR AVAILED
370	18-Apr-20	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	10:21	12:45	2:24	LINE CLEAR AVAILED
371	18-Apr-20	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	17:54	19:10	1:16	LINE FAULT
372	18-Apr-20	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	17:53	19:09	1:16	LINE FAULT
373	18-Apr-20	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	17:53	20:04	2:11	LINE FAULT
374	18-Apr-20	HASSAN	110	SAGARA-SORABA	SAGARA_110	20:25	20:30	0:05	HAND TRIPPED
375	18-Apr-20	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	7:40	12:30	4:50	LINE CLEAR AVAILED
376	18-Apr-20	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	19:29	23:59	4:30	LINE FAULT
377	18-Apr-20	HASSAN	220	HV1	GOPALAPURA_220	12:42	12:45	0:03	HAND TRIPPED
378	18-Apr-20	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	11:28	14:27	2:59	LINE FAULT
379	18-Apr-20	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	20:01	23:59	3:58	LINE FAULT
380	18-Apr-20	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	1:56	7:46	5:50	LINE FAULT
381	18-Apr-20	HASSAN	220	MRSSHM-VARAH3	MRSMSG_220	18:12	20:15	2:03	LINE FAULT
382	18-Apr-20	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	11:28	14:27	2:59	LINE FAULT
383	18-Apr-20	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	20:01	23:59	3:58	LINE FAULT
384	18-Apr-20	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	0:00	15:11	15:11	LINE FAULT
385	18-Apr-20	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	0:00	13:52	13:52	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
386	18-Apr-20	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	19:57	23:59	4:02	LINE FAULT
387	18-Apr-20	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	1:56	7:47	5:51	LINE FAULT
388	18-Apr-20	HASSAN	220	VARAHI-SHMG3	varahi_gen	18:12	20:15	2:03	LINE FAULT
389	18-Apr-20	MYSURU	66	HOOTAGALLI-ELWALA	ELAVALA_66	17:51	18:05	0:14	LINE FAULT
390	18-Apr-20	MYSURU	66	HUNSUR-ILAWALA	GAVADAGERE_66	17:51	18:07	0:16	LINE FAULT
391	18-Apr-20	MYSURU	66	HV1	BANNUR_66	0:07	0:18	0:11	HAND TRIPPED
392	18-Apr-20	MYSURU	66	HV1	BANNUR_66	0:27	0:44	0:16	TRANSFORMER FAULT
393	18-Apr-20	MYSURU	66	HV1	BANNUR_66	4:01	6:23	2:22	TRANSFORMER FAULT
394	18-Apr-20	MYSURU	66	HV1	BANNUR_66	6:28	7:47	1:19	TRANSFORMER FAULT
395	18-Apr-20	MYSURU	66	HV1	BANNUR_66	7:52	8:31	0:39	TRANSFORMER FAULT
396	18-Apr-20	MYSURU	66	HV1	BANNUR_66	8:46	9:19	0:33	TRANSFORMER FAULT
397	18-Apr-20	MYSURU	66	HV1	BANNUR_66	9:25	9:54	0:29	TRANSFORMER FAULT
398	18-Apr-20	MYSURU	66	HV1	BANNUR_66	9:59	18:15	8:16	TRANSFORMER FAULT
399	18-Apr-20	MYSURU	66	HV1	DODDABYADARAHALLI_66,	11:57	13:34	1:37	LINE CLEAR AVAILED
400	18-Apr-20	MYSURU	66	HV1	YELANDUR_66	12:50	13:27	0:37	LINE CLEAR AVAILED
401	18-Apr-20	MYSURU	66	HV2	AKKIHEBBAL_66,	8:23	8:53	0:30	LINE CLEAR AVAILED
402	18-Apr-20	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI, HARADANAHALLI, AC GIRI, BG NAGA	0:09	0:15	0:06	LINE FAULT
403	18-Apr-20	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAG,	12:55	13:00	0:05	LINE FAULT
404	18-Apr-20	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAG,	13:09	13:19	0:10	LINE FAULT
405	18-Apr-20	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAG,	14:33	14:44	0:11	LINE FAULT
406	18-Apr-20	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAG,	14:52	15:15	0:23	LINE FAULT
407	18-Apr-20	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAG,	15:28	15:55	0:27	LINE FAULT
408	18-Apr-20	MYSURU	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	6:05	6:15	0:09	LINE FAULT
409	18-Apr-20	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	15:12	16:17	1:04	LINE FAULT
410	18-Apr-20	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66	11:30	12:08	0:37	HAND TRIPPED
411	18-Apr-20	TUMKUR	66	CHITRADURGA 66kv- MEGMICON 1	MEGMICON 1_IPP_66	11:58	12:55	0:56	LINE FAULT
412	18-Apr-20	TUMKUR	66	CHITRADURGA 66kv- MEGMICON 2	MEGMICON 1_IPP_66	11:58	12:55	0:56	LINE FAULT
413	18-Apr-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:35	15:45	0:09	LINE FAULT
414	18-Apr-20	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	4:15	4:27	0:11	LINE FAULT
415	18-Apr-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	14:02	14:16	0:14	LINE FAULT
416	18-Apr-20	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66	10:26	10:37	0:11	LINE FAULT
417	18-Apr-20	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66	17:03	17:14	0:10	LINE FAULT
418	18-Apr-20	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66	23:13	23:25	0:12	LINE FAULT
419	18-Apr-20	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 1	KORATAGERE_66, CHIKKATOTLUKERE_66, BELAD	14:49	14:59	0:10	HAND TRIPPED
420	18-Apr-20	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	21:42	22:10	0:28	HAND TRIPPED
421	18-Apr-20	TUMKUR	66	NEELAGUNDA-HARPANAHALLI-1	HARAPPANAHALLI_66	6:29	6:38	0:09	LINE FAULT
422	18-Apr-20	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	17:48	18:21	0:33	LINE CLEAR AVAILED
423	18-Apr-20	TUMKUR	66	TR-1	CHANNAGIRI_66	17:58	18:41	0:43	TRANSFORMER FAULT
424	18-Apr-20	TUMKUR	66	TR-1	VENKATAPURA_66	14:49	15:33	0:43	LINE CLEAR AVAILED
425	18-Apr-20	TUMKUR	66	TR-1	YEDIYUR_66	18:32	19:02	0:30	TRANSFORMER FAULT
426	18-Apr-20	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	11:18	11:43	0:24	TRANSFORMER FAULT
427	18-Apr-20	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	16:03	16:50	0:46	LINE CLEAR AVAILED
428	18-Apr-20	TUMKUR	110	TR-1	BIDARE_110	11:23	11:44	0:21	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
429	18-Apr-20	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	12:48	16:30	3:41	LINE CLEAR AVAILED
430	18-Apr-20	TUMKUR	220	TR-1(HV SIDE)	CHITRADURGA_220	11:18	11:41	0:23	TRANSFORMER FAULT
431	19-Apr-20	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	7:10	7:13	0:03	TRANSFORMER FAULT
432	19-Apr-20	BAGALKOT	110	110/11KV,HV 1	BEDI_110	14:25	15:59	1:34	TRANSFORMER FAULT
433	19-Apr-20	BAGALKOT	110	110/11KV,HV 2	AREMALLAPUR_110	7:35	17:03	9:28	LINE CLEAR AVAILED
434	19-Apr-20	BAGALKOT	110	110/33KV, HV2	UTTUR_110, YADWAD_33, VANTAGODI_33	14:43	14:50	0:07	TRANSFORMER FAULT
435	19-Apr-20	BAGALKOT	110	AMBEWADI-NK 2	KAVALAWAD_110	12:44	12:52	0:08	HAND TRIPPED
436	19-Apr-20	BAGALKOT	110	AMBEWADI-NK 2	KAVALAWAD_110	17:09	17:31	0:22	LINE CLEAR AVAILED
437	19-Apr-20	BAGALKOT	110	BELLATT-ENERCON2	BELLATTI_110	9:44	12:30	2:46	LINE CLEAR AVAILED
438	19-Apr-20	BAGALKOT	110	BPCL-NARAGUND	NARAGUND_110	0:00	13:37	13:37	LINE CLEAR AVAILED
439	19-Apr-20	BAGALKOT	110	KARAWAR-KUMATA	KUMATA_110	9:57	12:21	2:24	LINE CLEAR AVAILED
440	19-Apr-20	BAGALKOT	110	KARAWAR-SOLARIS(BINAGA)	BINAGA (EHT)_110	0:00	12:16	12:16	LINE CLEAR AVAILED
441	19-Apr-20	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	1:16	16:47	15:31	LINE FAULT
442	19-Apr-20	BAGALKOT	110	MAHALINGAPUR-DHAVALESHWAR	DHAVALESHWAR_110	11:46	12:06	0:20	HAND TRIPPED
443	19-Apr-20	BAGALKOT	110	RANEENNUR220-HIREKERUR	HIREKERUR_110	9:12	10:06	0:54	LINE FAULT
444	19-Apr-20	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	0:00	16:23	16:23	LINE CLEAR AVAILED
445	19-Apr-20	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	23:49	23:59	0:10	LINE CLEAR AVAILED
446	19-Apr-20	BAGALKOT	220	220/110KV, HV1,LV1,HV2,LV2	MAHALINGAPUR_220, DAVLESHWAR_110, TERDA	10:08	10:30	0:22	TRANSFORMER FAULT
447	19-Apr-20	BAGALKOT	220	220/110KV, HV2&LV2	RANEENNUR_220, BYADAGI_110, HIREKERUR_1	2:33	2:36	0:03	HAND TRIPPED
448	19-Apr-20	BAGALKOT	220	AMBEWADI-NARENDRA 1	AMBEWADI_220	7:53	16:50	8:57	LINE CLEAR AVAILED
449	19-Apr-20	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	7:52	16:50	8:58	LINE CLEAR AVAILED
450	19-Apr-20	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	7:14	17:09	9:55	LINE CLEAR AVAILED
451	19-Apr-20	BAGALKOT	220	BALLIGAVI(SHIROLKOPPA)-RANEENNUR	RANEENNUR_220	0:00	22:47	22:47	LINE CLEAR AVAILED
452	19-Apr-20	BAGALKOT	220	BELGAUM-KANABARGI 1 (NARENDRA1)	BELGAUM_220	0:00	6:55	6:55	LINE CLEAR AVAILED
453	19-Apr-20	BAGALKOT	220	GADAG-DHONI 2	GADAG_220	7:48	16:54	9:06	LINE CLEAR AVAILED
454	19-Apr-20	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	2:30	2:35	0:05	HAND TRIPPED
455	19-Apr-20	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	22:47	23:59	1:12	LINE CLEAR AVAILED
456	19-Apr-20	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	7:50	17:11	9:21	LINE CLEAR AVAILED
457	19-Apr-20	BAGALKOT	220	NAGJHARI2- HUBLI	HUBLI_220	0:00	9:23	9:23	LINE CLEAR AVAILED
458	19-Apr-20	BAGALKOT	220	NAGJHARI3- HUBLI	HUBLI_220	0:00	8:08	8:08	LINE CLEAR AVAILED
459	19-Apr-20	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	0:00	14:53	14:53	LINE CLEAR AVAILED
460	19-Apr-20	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	15:03	23:59	8:56	LINE CLEAR AVAILED
461	19-Apr-20	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	0:00	12:23	12:23	LINE CLEAR AVAILED
462	19-Apr-20	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	14:28	23:59	9:31	LINE CLEAR AVAILED
463	19-Apr-20	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	0:00	14:29	14:29	LINE CLEAR AVAILED
464	19-Apr-20	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	12:23	14:28	2:05	LINE CLEAR AVAILED
465	19-Apr-20	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	8:03	8:07	0:04	LOAD CHANGE OVER
466	19-Apr-20	BENGALURU	66	CHINTAMANI 220 - SRINIVASAPURA	SRINIVASAPURA, KODIHALLI	7:35	7:38	0:03	LOAD CHANGE OVER
467	19-Apr-20	BENGALURU	66	DALSANUR - SRINIVASAPURA	SRINIVASAPURA	10:05	10:15	0:10	LOAD CHANGE OVER
468	19-Apr-20	BENGALURU	66	HV1	ANEKAL	10:45	10:50	0:05	LOAD CHANGE OVER
469	19-Apr-20	BENGALURU	66	HV1	ANEKAL	17:40	17:45	0:05	LOAD CHANGE OVER
470	19-Apr-20	BENGALURU	66	HV1	SIDDLAGHATTA	13:15	15:12	1:56	TRANSFORMER FAULT
471	19-Apr-20	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	10:03	10:11	0:08	LOAD CHANGE OVER

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
472	19-Apr-20	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	17:30	17:50	0:20	LOAD CHANGE OVER
473	19-Apr-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DOD	10:03	10:11	0:08	LOAD CHANGE OVER
474	19-Apr-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DOD	17:30	17:50	0:20	LOAD CHANGE OVER
475	19-Apr-20	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	10:03	10:11	0:08	LOAD CHANGE OVER
476	19-Apr-20	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	17:30	17:50	0:20	LOAD CHANGE OVER
477	19-Apr-20	GULBARGA	110	ALIPUR-BTPS	ALIPUR_220	18:53	19:07	0:14	LINE FAULT
478	19-Apr-20	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110, KUDITINI_110, KURUGOD_11	4:40	4:48	0:08	LINE FAULT
479	19-Apr-20	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110, KUDITINI_110, KURUGOD_11	18:53	19:10	0:17	LINE FAULT
480	19-Apr-20	GULBARGA	110	HV1	LINGASUGUR_220	9:30	12:10	2:40	LINE CLEAR AVAILED
481	19-Apr-20	GULBARGA	110	HV1	HANUMASAGAR_110	7:46	8:04	0:18	TRANSFORMER FAULT
482	19-Apr-20	GULBARGA	110	HV1	PDHALLI_110	13:45	14:25	0:40	LINE CLEAR AVAILED
483	19-Apr-20	GULBARGA	110	HV1	PDHALLI_110	18:00	18:51	0:51	LINE CLEAR AVAILED
484	19-Apr-20	GULBARGA	110	HV3	SHORAPUR_110	1:50	2:10	0:20	TRANSFORMER FAULT
485	19-Apr-20	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110	15:01	15:12	0:11	LINE FAULT
486	19-Apr-20	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	15:08	17:13	2:05	LINE CLEAR AVAILED
487	19-Apr-20	GULBARGA	110	SHAHAPUR220-SHAHPUR1	SHAHPUR_110	19:10	20:15	1:05	LINE CLEAR AVAILED
488	19-Apr-20	GULBARGA	110	SINDHANOOR220-SIRUGUPPA	DHAHDESUGUR_110, SIRUGUPPA_110, TEKKALAI	1:42	1:50	0:08	LINE FAULT
489	19-Apr-20	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	11:45	16:40	4:55	LINE FAULT
490	19-Apr-20	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHABAD_220	17:15(17.04.20)			LINE IS OPEN:LINE FAULT
491	19-Apr-20	GULBARGA	220	KAPNOOR-SHAHPUR	SHAHPUR_220	17:15(17.04.20)			LINE IS OPEN:LINE FAULT
492	19-Apr-20	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTIHALLY_66	16:59	17:13	0:14	LINE FAULT
493	19-Apr-20	HASSAN	66	HV1	RAMPURA_66	11:04	11:08	0:04	TRANSFORMER FAULT
494	19-Apr-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	7:48	7:59	0:11	LINE FAULT
495	19-Apr-20	HASSAN	110	HV1	CHANDRAGUTTI_110	17:10	17:18	0:08	MAIN SUPPLY FAILURE
496	19-Apr-20	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	6:56	7:07	0:11	LINE FAULT
497	19-Apr-20	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	7:30	12:27	4:57	LINE FAULT
498	19-Apr-20	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	17:17	17:47	0:30	LINE FAULT
499	19-Apr-20	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:11	12:49	0:38	LINE FAULT
500	19-Apr-20	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	0:00	12:20	12:20	LINE FAULT
501	19-Apr-20	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	0:00	12:08	12:08	LINE FAULT
502	19-Apr-20	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	1:19	6:40	5:21	LINE FAULT
503	19-Apr-20	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	0:00	12:08	12:08	LINE FAULT
504	19-Apr-20	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	20:10	23:59	3:49	LINE FAULT
505	19-Apr-20	HASSAN	220	SHRAVTY-TALAGUPPA 2	sharavathy_gen	19:57	23:59	4:02	LINE FAULT
506	19-Apr-20	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	0:00	13:52	13:52	LINE FAULT
507	19-Apr-20	HASSAN	220	VARAH1-SHMG3	varahi_gen	1:19	6:41	5:22	LINE FAULT
508	19-Apr-20	MYSURU	66	HEBBANI-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66	17:02	17:33	0:31	LINE FAULT
509	19-Apr-20	MYSURU	66	HV1	CHINAKURALI_66	14:45	15:01	0:15	TRANSFORMER FAULT
510	19-Apr-20	MYSURU	66	HV1	HONNALLY_MYS_66	9:05	9:07	0:02	TRANSFORMER FAULT
511	19-Apr-20	MYSURU	66	HV1	YELANDUR_66	21:02	21:16	0:14	TRANSFORMER FAULT
512	19-Apr-20	MYSURU	66	HV2	DODDINADUVADI_66	17:06	17:48	0:42	LINE CLEAR AVAILED
513	19-Apr-20	MYSURU	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOT	12:49	12:54	0:04	LINE FAULT
514	19-Apr-20	MYSURU	66	KADAKOLA-SARGUR 2	B MATKERE_66, CHANDRAVADI_66, DOORA_66, H	12:49	12:54	0:05	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
515	19-Apr-20	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	18:58	19:12	0:13	LINE FAULT
516	19-Apr-20	MYSURU	66	VAJMANGALA-MEGHALAPURA	MEGALAPURA_66	16:58	17:14	0:15	LINE FAULT
517	19-Apr-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA	11:50	11:56	0:06	LINE FAULT
518	19-Apr-20	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	10:39	11:07	0:27	HAND TRIPPED
519	19-Apr-20	TUMKUR	66	TR-1	HALURAMESHWARA_66	0:07	0:10	0:02	TRANSFORMER FAULT
520	19-Apr-20	TUMKUR	66	TR-1	HALURAMESHWARA_66	12:15	12:37	0:21	TRANSFORMER FAULT
521	19-Apr-20	TUMKUR	66	TR-1	MAVINAKATTE_66	9:54	10:14	0:20	LINE CLEAR AVAILED
522	19-Apr-20	TUMKUR	66	TR-1	SASALUHALLA_66	9:02	9:05	0:03	TRANSFORMER FAULT
523	20-Apr-20	BAGALKOT	66	DAVANAGERE-HARIHAR HOSPET	HARIHAR HOSPET_66	0:00	11:46	11:46	LINE CLEAR AVAILED
524	20-Apr-20	BAGALKOT	66	DAVANAGERE-HARIHAR HOSPET	HARIHAR HOSPET_66	14:20	23:59	9:39	LINE CLEAR AVAILED
525	20-Apr-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	HARIHAR HOSPET_66	11:46	14:20	2:34	LOAD CURTAILMENT
526	20-Apr-20	BAGALKOT	110	110/11KV ,HV2	CHIKKODI _110	11:17	11:43	0:26	HAND TRIPPED
527	20-Apr-20	BAGALKOT	110	110/11KV ,HV2	GOKAK _110	2:10	5:10	3:00	TRANSFORMER FAULT
528	20-Apr-20	BAGALKOT	110	110/11KV ,HV2	GOKAK _110	13:52	14:08	0:16	TRANSFORMER FAULT
529	20-Apr-20	BAGALKOT	110	110/11KV,HV1	ZALKI _110	8:35	12:35	4:00	LINE CLEAR AVAILED
530	20-Apr-20	BAGALKOT	110	110/11KV,HV1	ZALKI _110	16:50	16:55	0:05	TRANSFORMER FAULT
531	20-Apr-20	BAGALKOT	110	110/11KV,HV2	PG HUNSYAL_110	10:16	10:46	0:30	HAND TRIPPED
532	20-Apr-20	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	8:02	8:20	0:18	TRANSFORMER FAULT
533	20-Apr-20	BAGALKOT	110	110/11KV,HV2	MUDDEBIHAL_110	10:56	11:04	0:08	TRANSFORMER FAULT
534	20-Apr-20	BAGALKOT	110	110/11KV,HV2	MUDDEBIHAL_110	16:24	16:38	0:14	TRANSFORMER FAULT
535	20-Apr-20	BAGALKOT	110	110/33KV,HV1	BAGEAWADI_220,MANAGULI_33,MUTTAGI_33	16:00	16:35	0:35	HAND TRIPPED
536	20-Apr-20	BAGALKOT	110	110/33KV,HV2	HUNAGUND_110&33 KV KARADI &AMINAGAD	11:09	11:15	0:06	TRANSFORMER FAULT
537	20-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALKI _110	15:09	15:52	0:43	LINE CLEAR AVAILED
538	20-Apr-20	BAGALKOT	110	BAGEWADI-NIDAGUNDI(RAMPUR)	NIDAGUNDI_110	16:15	16:35	0:20	HAND TRIPPED
539	20-Apr-20	BAGALKOT	110	GSML2-MAHALINGAPUR	MAHALINGAPUR_220	12:08	12:47	0:39	LINE CLEAR AVAILED
540	20-Apr-20	BAGALKOT	110	MKHUBLI110-KITTUR	KITTUR_110	14:56	15:15	0:19	LINE FAULT
541	20-Apr-20	BAGALKOT	110	SIRSI-KUMTA1&2	SIRSI_110	22:03	22:53	0:50	LINE FAULT
542	20-Apr-20	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	0:00	14:09	14:09	LINE CLEAR AVAILED
543	20-Apr-20	BAGALKOT	220	220/110KV, HV1&LV1	MK HUBLI_220	20:43	23:59	3:16	TRANSFORMER FAULT
544	20-Apr-20	BAGALKOT	220	220/110KV,HV3,LV3	BAGEWADI_220,SINDAGI_110	15:55	16:25	0:30	TRANSFORMER FAULT
545	20-Apr-20	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	13:29	14:43	1:14	LINE FAULT
546	20-Apr-20	BAGALKOT	220	BALLIGAVI(SHIROLKOPPA)-RANEBENNUR	RANEBENNUR_220	9:52	23:59	14:07	LINE CLEAR AVAILED
547	20-Apr-20	BAGALKOT	220	BIDNAL-NAGJHARI2	BIDNAL_220	17:48	23:59	6:11	LINE FAULT
548	20-Apr-20	BAGALKOT	220	GUTTUR-RANEBENNUR	RANEBENNUR_220	0:00	9:52	9:52	LINE CLEAR AVAILED
549	20-Apr-20	BAGALKOT	220	HUBLI-NAGJHARI1	HUBLI_220	17:53	22:30	4:37	LINE FAULT
550	20-Apr-20	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	10:49	13:20	2:31	LINE CLEAR AVAILED
551	20-Apr-20	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	17:47	22:28	4:41	LINE FAULT
552	20-Apr-20	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	9:40	12:08	2:28	LINE CLEAR AVAILED
553	20-Apr-20	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	14:58	18:45	3:47	LINE FAULT
554	20-Apr-20	BAGALKOT	220	MK HUBLI-NARENDRA2	MK HUBLI_220	13:00	14:31	1:31	LINE FAULT
555	20-Apr-20	BAGALKOT	220	MK HUBLI-NARENDRA2	MK HUBLI_220	16:20	17:11	0:51	LINE CLEAR AVAILED
556	20-Apr-20	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	17:52	22:45	4:53	LINE FAULT
557	20-Apr-20	BENGALURU	66	HV1	SIDDALAGATTA	11:50	12:15	0:24	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
558	20-Apr-20	BENGALURU	66	HV1	TK HALLI 220	17:10	17:56	0:45	LINE CLEAR AVAILED
559	20-Apr-20	BENGALURU	66	HV2	HAL 220	8:47	9:10	0:23	TRANSFORMER FAULT
560	20-Apr-20	BENGALURU	66	HV2	KHODAYS 220	11:35	11:38	0:03	LINE CLEAR AVAILED
561	20-Apr-20	BENGALURU	66	HV2	LEELA VENTURE	14:09	14:24	0:14	LINE CLEAR AVAILED
562	20-Apr-20	BENGALURU	66	HV2	SOMAYAJJANAHALLI	12:59	14:06	1:07	LINE CLEAR AVAILED
563	20-Apr-20	BENGALURU	66	SIDLAGATTA - CHINTAMANI 220	SIDLAGATTA, MELUR	12:08	12:13	0:04	LINE CLEAR AVAILED
564	20-Apr-20	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT	3:56	4:19	0:22	LINE FAULT
565	20-Apr-20	BENGALURU	220	HV1	KANAKAPURA 220	18:45	18:50	0:05	LINE CLEAR AVAILED
566	20-Apr-20	GULBARGA	110	HV1	SHAHPUR_220	20:42	20:59	0:17	TRANSFORMER FAULT
567	20-Apr-20	GULBARGA	110	HV1	DEODURGA_110	18:40	18:55	0:15	TRANSFORMER FAULT
568	20-Apr-20	GULBARGA	110	HV1	SIRWAR_110	18:05	18:10	0:05	TRANSFORMER FAULT
569	20-Apr-20	GULBARGA	110	HV2	SHAHPUR_220	17:39	17:49	0:10	TRANSFORMER FAULT
570	20-Apr-20	GULBARGA	110	HV2	DEODURGA_110	11:42	13:38	1:56	LINE CLEAR AVAILED
571	20-Apr-20	GULBARGA	110	HV2	YELBURGA_110	8:05	8:10	0:05	TRANSFORMER FAULT
572	20-Apr-20	GULBARGA	110	KAPNOOR-GULBARGANORTH1,2	GULBARGANORTH_110,GULBARGASOUTH_110,G	16:20	16:35	0:15	LINE FAULT
573	20-Apr-20	GULBARGA	110	KAPNOOR-GULBARGANORTH1,2	GULBARGANORTH_110,GULBARGASOUTH_110,G	16:38	16:51	0:13	LINE FAULT
574	20-Apr-20	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	12:10	12:47	0:37	LINE FAULT
575	20-Apr-20	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	18:35	18:43	0:08	LINE FAULT
576	20-Apr-20	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110	13:30	13:41	0:11	LINE FAULT
577	20-Apr-20	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110	20:16	20:27	0:11	LINE FAULT
578	20-Apr-20	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110,HUNSAGI_110,ASKI_110	4:37	4:43	0:06	LINE FAULT
579	20-Apr-20	GULBARGA	220	RTPS-SEDAM1	SEDAM_220	14:21	14:50	0:29	LINE FAULT
580	20-Apr-20	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHABAD_220	17:15(17.04.20)			LINE IS OPEN:LINE FAULT
581	20-Apr-20	GULBARGA	220	KAPNOOR-SHAHPUR	SHAHPUR_220	17:15(17.04.20)			LINE IS OPEN:LINE FAULT
582	20-Apr-20	HASSAN	66	HV1	HANGARANAHALLY_66	7:19	7:40	0:21	TRANSFORMER FAULT
583	20-Apr-20	HASSAN	66	HV1	HANGARANAHALLY_66	13:37	14:02	0:25	LINE CLEAR AVAILED
584	20-Apr-20	HASSAN	66	HV1	HANBALU_66	13:14	14:22	1:08	LINE CLEAR AVAILED
585	20-Apr-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	12:21	12:30	0:09	LINE FAULT
586	20-Apr-20	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	21:10	21:17	0:07	LINE FAULT
587	20-Apr-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	10:16	11:57	1:41	NFBC ISSUED
588	20-Apr-20	HASSAN	110	HV1	SHIVPURA_110	14:19	15:00	0:41	LINE CLEAR AVAILED
589	20-Apr-20	HASSAN	110	HV2	ESSUR_110	15:34	16:35	1:01	LINE CLEAR AVAILED
590	20-Apr-20	HASSAN	110	HV2	GERUMARA_110	13:03	14:03	1:00	LINE CLEAR AVAILED
591	20-Apr-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:16	11:56	1:40	LINE CLEAR AVAILED
592	20-Apr-20	HASSAN	110	SAGARA-SORABA	SAGARA_110	12:17	12:22	0:05	HAND TRIPPED
593	20-Apr-20	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	5:02	6:23	1:21	LINE FAULT
594	20-Apr-20	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	12:20	12:25	0:05	HAND TRIPPED
595	20-Apr-20	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	0:05	5:16	5:11	LINE CLEAR AVAILED
596	20-Apr-20	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	1:47	6:52	5:05	LINE FAULT
597	20-Apr-20	HASSAN	220	VARAHI-SHMG3	varahi_gen	1:47	6:59	5:12	LINE FAULT
598	20-Apr-20	MYSORE	66	G UKKADA-METAGALLY	GARUDANAUKADDA_66	12:23	13:17	0:53	LINE CLEAR AVAILED
599	20-Apr-20	MYSORE	66	G UKKADA-PANDAVAPURA	GARUDANAUKADDA_66	11:53	13:17	1:23	LINE CLEAR AVAILED
600	20-Apr-20	MYSORE	66	HV1	BANNUR_66	13:30	16:24	2:54	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
601	20-Apr-20	MYSORE	66	HV1	JAKKANAHALLY_66	4:30	4:45	0:15	TRANSFORMER FAULT
602	20-Apr-20	MYSORE	66	HV2	KMDODDI_66	17:20	17:36	0:15	TRANSFORMER FAULT
603	20-Apr-20	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOT	12:24	12:27	0:03	LINE FAULT
604	20-Apr-20	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOT	12:42	12:46	0:03	LINE FAULT
605	20-Apr-20	MYSORE	66	KADAKOLA-SARGUR 2	B MATKERE_66, CHANDRAVADI_66, DOORA_66, I	12:24	12:27	0:03	LINE FAULT
606	20-Apr-20	MYSORE	66	KADAKOLA-SARGUR 2	B MATKERE_66, CHANDRAVADI_66, DOORA_66, I	12:42	12:45	0:03	LINE FAULT
607	20-Apr-20	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAG	15:04	15:08	0:04	LINE FAULT
608	20-Apr-20	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	13:59	14:00	0:01	MAIN SUPPLY FAILURE
609	20-Apr-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:44	15:58	0:13	LINE FAULT
610	20-Apr-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	10:12	13:55	3:43	LINE CLEAR AVAILED
611	20-Apr-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	10:12	13:56	3:43	LINE CLEAR AVAILED
612	20-Apr-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	10:12	13:56	3:44	LINE CLEAR AVAILED
613	20-Apr-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	18:43	18:55	0:11	LINE CLEAR AVAILED
614	20-Apr-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	19:21	19:32	0:11	LINE CLEAR AVAILED
615	20-Apr-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	10:12	10:14	0:02	LINE CLEAR AVAILED
616	20-Apr-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	13:43	14:00	0:17	LINE CLEAR AVAILED
617	20-Apr-20	TUMKUR	66	HONNALLI 66KV- HONNALLI	HONNALI_66	10:17	14:34	4:17	LINE CLEAR AVAILED
618	20-Apr-20	TUMKUR	66	KUNDUR- HONNALI	KUNDUR_66	10:22	13:42	3:19	LINE CLEAR AVAILED
619	20-Apr-20	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	11:51	12:03	0:11	LINE FAULT
620	20-Apr-20	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	22:20	22:24	0:04	LINE FAULT
621	20-Apr-20	TUMKUR	66	TR-1	CHALLAKERE_66	7:29	7:31	0:01	TRANSFORMER FAULT
622	20-Apr-20	TUMKUR	66	TR-1	HALURAMESHWARA_66	8:11	10:04	1:52	LINE CLEAR AVAILED
623	20-Apr-20	TUMKUR	66	TR-1	HONNALI_66	10:17	14:37	4:19	LINE CLEAR AVAILED
624	20-Apr-20	TUMKUR	66	TR-1	HONNALI_66	17:36	18:33	0:57	HAND TRIPPED
625	20-Apr-20	TUMKUR	66	TR-1	HONNALLI_220	10:14	13:43	3:28	LINE CLEAR AVAILED
626	20-Apr-20	TUMKUR	66	TR-1	KUNDUR_66	10:20	13:45	3:24	LINE CLEAR AVAILED
627	20-Apr-20	TUMKUR	66	TR-1	KUNDUR_66	14:24	14:41	0:16	LINE CLEAR AVAILED
628	20-Apr-20	TUMKUR	66	TR-2	BEVINAHALLI_66	11:47	12:06	0:18	LINE CLEAR AVAILED
629	20-Apr-20	TUMKUR	66	TR-2	HALURAMESHWARA_66	8:11	10:04	1:52	LINE CLEAR AVAILED
630	20-Apr-20	TUMKUR	66	TR-2	HONNALI_66	10:17	14:36	4:18	LINE CLEAR AVAILED
631	20-Apr-20	TUMKUR	66	TR-2	HONNALLI_220	10:14	13:30	3:15	LINE CLEAR AVAILED
632	20-Apr-20	TUMKUR	66	TR-3	HONNALI_66	10:17	14:36	4:19	LINE CLEAR AVAILED
633	20-Apr-20	TUMKUR	66	VENKATAPURA- GOWRIBIDNUR	VENKATAPUR_66	7:35	7:47	0:12	LINE FAULT
634	20-Apr-20	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	7:47	9:25	1:37	LINE FAULT
635	20-Apr-20	TUMKUR	110	TR-1	BANDIHALLI_110	10:43	12:05	1:22	LINE CLEAR AVAILED
636	20-Apr-20	TUMKUR	110	TR-1	HANDANKERE_110	15:58	16:44	0:45	LINE CLEAR AVAILED
637	20-Apr-20	TUMKUR	110	TR-2	SAMPIGE_110	3:10	3:21	0:11	TRANSFORMER FAULT
638	20-Apr-20	TUMKUR	220	HONNALLI 220kV- SUZLON1	SUZLON_IPP_66	13:30	13:32	0:02	HAND TRIPPED
639	20-Apr-20	TUMKUR	220	HONNALLI 220kV- SUZLON2	SUZLON_IPP_66	13:30	13:33	0:03	HAND TRIPPED