

400/220/110/66 kV TRANSMISSION OUTAGES FROM 16.02.2021 TO 22.02.2021

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	16-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
2	16-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN :LINE CLEAR AVAILED
3	16-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
4	16-Feb-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
5	16-Feb-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
6	16-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN :LINE CLEAR AVAILED
7	16-Feb-21	BAGALKOT	110	KANABARGI LAYOUT-NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN :LINE CLEAR AVAILED
8	16-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN :LINE CLEAR AVAILED
9	16-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN :LINE CLEAR AVAILED
10	16-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN :LINE CLEAR AVAILED
11	16-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
12	16-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
13	16-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN :LINE CLEAR AVAILED
14	16-Feb-21	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN :LINE CLEAR AVAILED
15	16-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN :LINE CLEAR AVAILED
16	16-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN :LINE CLEAR AVAILED
17	16-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN :LINE CLEAR AVAILED
18	16-Feb-21	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD_110	12:50 (12.02.2021)	20:30 (16.02.2021)	103:40HRS	LINE CHARGED
19	16-Feb-21	BAGALKOT	110	BELGAUM220-HUDALI	STATION NOT AFFECTED HUDALI_110	14:45 (14.02.2021)			LINE OPEN :LINE CLEAR AVAILED
20	16-Feb-21	BAGALKOT	110	HUKKERI-HATTARAGI	STATION NOT AFFECTED HATTARAGI_110	9:03 (15.02.2021)	14:00 (16.02.2021)	28:57HRS	LINE CHARGED
21	16-Feb-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SIRSI_110	13:54 (15.02.2021)			TRANSFORMER OPEN :LINE CLEAR AVAILED
22	16-Feb-21	BAGALKOT	220	RANEBENNUR-SHIRALKOPPA(BELLIGAVI)	STATION NOT AFFECTED RANEBENNUR_220	23:41 (15.02.2021)			LINE OPEN :LINE CLEAR AVAILED
23	16-Feb-21	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	17:18	18:09	0:51	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
24	16-Feb-21	BAGALKOT	110	BETAGERI-NAREGAL	BETAGERI_110,NAREGAL	20:42	20:46	0:04	LINE FAULT
25	16-Feb-21	BAGALKOT	110	GADAG220-BETAGERI	BETAGERI_110	20:16	20:35	0:19	LINE FAULT
26	16-Feb-21	BAGALKOT	220	BIDNAL-HIREBENDIGERI2	STATION NOT AFFECTED BIDNAL_220	15:34	18:08	2:34	NFBC ISSUED
27	16-Feb-21	BAGALKOT	110	GAJENDRAGA-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	20:19 (16.02.2021)			LINE OPEN: LINE FAULT
28	16-Feb-21	BAGALKOT	110	GAJENDRAGA-RON2	STATION NOT AFFECTED GAJENDRAGAD_110	20:19 (16.02.2021)			LINE OPEN: LINE FAULT
29	16-Feb-21	BAGALKOT	110	KUDUCHI-KUDUCHI	KUDUCHI_110	10:30	15:53	5:23	LINE CLEAR AVAILED
30	16-Feb-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	05:50	18:36	12:46	LINE FAULT
31	16-Feb-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI2	STATION NOT AFFECTED MAHALINGAPUR_220	07:25	17:12	9:47	LINE FAULT
32	16-Feb-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI1	STATION NOT AFFECTED MAHALINGAPUR_220	07:20	18:02	10:42	LINE FAULT
33	16-Feb-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR_220	05:50	18:37	12:47	LINE FAULT
34	16-Feb-21	BAGALKOT	220	MAHALINGAPUR-NARENDRA1	STATION NOT AFFECTED MAHALINGAPUR_220	11:47	18:36	6:49	LINE CLEAR AVAILED
35	16-Feb-21	BAGALKOT	110	10/11KV, HV1	SIRSI_110	06:50	07:05	0:15	LINE CLEAR AVAILED
36	16-Feb-21	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON_110	20:25(16.02.21)			LINE OPEN: LINE FAULT
37	16-Feb-21	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	20:52	21:09	0:17	HAND TRIPPED
38	16-Feb-21	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	20:52	20:55	0:03	HAND TRIPPED
39	16-Feb-21	BAGALKOT	110	RON-GAMESH	STATION NOT AFFECTED RON_110, GAMESH IPP_110	20:52	21:05	0:13	HAND TRIPPED
40	16-Feb-21	BAGALKOT	110	NARAGUND-BPCL IPP	NARAGUND_110, BPCL IPP_110	10:45	17:18	6:33	LINE CLEAR AVAILED
41	16-Feb-21	BAGALKOT	220	VAJJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJJRAMATTI_220	07:24	17:09	9:45	LINE FAULT
42	16-Feb-21	BAGALKOT	220	VAJJRAMATTI-MAHALINGAPUR2	STATION NOT AFFECTED VAJJRAMATTI_220	07:21	17:13	9:52	LINE FAULT
43	16-Feb-21	BAGALKOT	220	VAJJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJJRAMATTI_220	17:38	17:58	0:20	HAND TRIPPED
44	16-Feb-21	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	20:01	20:06	00:05	MAIN SUPPLY FAILURE
45	16-Feb-21	BENGALURU	66	AUSTIN TOWN - EDC 220	AUSTIN TOWN	20:01	20:36	00:35	MAIN SUPPLY FAILURE
46	16-Feb-21	BENGALURU	220	EDC 220 - HAL 220	EDC 220	20:01	20:20	00:19	MAIN SUPPLY FAILURE
47	16-Feb-21	BENGALURU	66	EDC 220 - BMTC	BMTC	20:01	20:44	00:43	LINE CLEAR AVAILED
48	16-Feb-21	BENGALURU	66	EDC 220 - B STATION	B STATION	20:01	20:46	00:45	LINE CLEAR AVAILED
49	16-Feb-21	BENGALURU	220	HV1	EDC 220	20:01	20:23	00:22	LINE CLEAR AVAILED
50	16-Feb-21	BENGALURU	220	HV2	EDC 220	20:01	20:23	00:22	LINE CLEAR AVAILED
51	16-Feb-21	BENGALURU	220	HAL 220 - EDC 220	EDC 220	20:01	20:20	00:19	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
52	16-Feb-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, YEDUMADU, GODUR	08:32	10:00	01:28	LINE CLEAR AVAILED
53	16-Feb-21	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA	01:22	01:43	00:21	MAIN SUPPLY FAILURE
54	16-Feb-21	BENGALURU	66	ATTUR YELAHANKA - DG4	ATTUR YELAHANKA	02:09	02:18	00:09	LOAD CHANGE OVER
55	16-Feb-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	06:35	06:56	00:21	LINE FAULT
56	16-Feb-21	BENGALURU	66	HV2	DODDABELAVANGALA	21:03	21:31	00:28	TRANSFORMER FAULT
57	16-Feb-21	BENGALURU	66	HV2	KANAKAPURA 66	16:45	19:37	02:52	LINE CLEAR AVAILED
58	16-Feb-21	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	10:51	19:15	08:24	LINE FAULT
59	16-Feb-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	17:55	19:15	01:20	LINE CLEAR AVAILED
60	16-Feb-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR, S M MANGALA	10:43	12:29	01:46	LINE CLEAR AVAILED
61	16-Feb-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	16:52	17:12	00:20	LOAD CURTAILMENT
62	16-Feb-21	BENGALURU	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:53	16:05	00:12	LOAD CURTAILMENT
63	16-Feb-21	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	04:17	04:26	00:09	LINE FAULT
64	16-Feb-21	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	07:05	07:14	00:09	LINE FAULT
65	16-Feb-21	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	18:50	19:14	00:24	LINE FAULT
66	16-Feb-21	BENGALURU	66	RANGANADODDI - SOMANAHALLI 220	RANGANADODDI	14:20	14:25	00:05	LOAD CHANGE OVER
67	16-Feb-21	BENGALURU	66	WELCAST - YELAHANKA 220	WELCAST	01:22	01:34	00:12	MAIN SUPPLY FAILURE
68	16-Feb-21	BENGALURU	66	WELCAST - SRS PEENYA 220	WELCAST	07:13	07:20	00:07	LOAD CHANGE OVER
69	16-Feb-21	BENGALURU	66	ABBIGERE - YELAHANKA 220	ABBIGERE	01:22	01:46	00:24	MAIN SUPPLY FAILURE
70	16-Feb-21	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	07:11	07:14	00:03	LOAD CHANGE OVER
71	16-Feb-21	BENGALURU	66	YELAHANKA 220 - LINE 3	ESCORTS (EHT)	01:22	01:33	00:11	LINE FAULT
72	16-Feb-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
73	16-Feb-21	GULBARGA	220	SINDHANOOR-LINGAPUR	SINDHANOOR_220	09:05	12:25	03:20	NFBC ISSUED
74	16-Feb-21	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR2	01:15	01:32	00:17	LINE FAULT
75	16-Feb-21	GULBARGA	220	SINDHNOOR-LINGAPUR	SINDHANOOR_220	09:05	12:25	03:20	LINE CLEAR AVAILED
76	16-Feb-21	GULBARGA	220	HV2	SINDHANOOR_220	17:50	20:05	02:15	TRANSFORMER FAULT
77	16-Feb-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	14:15(15.2.2021)			LINE OPEN :LINE CLEAR AVAILED
78	16-Feb-21	GULBARGA	110	HV3	GULBARGAWEST_110	13:05	14:15	01:10	LINE CLEAR AVAILED
79	16-Feb-21	GULBARGA	110	GULBARGAUNIVERSITY-GULBARGA SOUTH	GULBARGASOUTH_110	12:30	13:25	00:55	LINE CLEAR AVAILED
80	16-Feb-21	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110	17:02	17:12	00:10	LINE FAULT
81	16-Feb-21	GULBARGA	110	LV1 & LV2	HUMNABAD_220	02:08	02:50	00:42	LINE CLEAR AVAILED
82	16-Feb-21	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110	17:32(15.02.2021)	2:35(16.02.2021)	9:03HRS	LINE CHARGED
83	16-Feb-21	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110	22:40(15.02.2021)	2:55(16.02.2021)	4:15HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
84	16-Feb-21	GULBARGA	110	LV1	HUMNABAD_220	11:50	11:56	00:06	LINE CLEAR AVAILED
85	16-Feb-21	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110	18:00	20:05	02:05	LINE CLEAR AVAILED
86	16-Feb-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	02:51	02:55	00:04	LINE FAULT
87	16-Feb-21	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110,GANADAL_110	21:03	21:23	00:20	LINE FAULT
88	16-Feb-21	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110,GANADAL_110	21:29	21:58	00:29	LINE FAULT
89	16-Feb-21	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110,GANADAL_110	22:18	22:52	00:34	LINE FAULT
90	16-Feb-21	GULBARGA	110	HATTI-SINDHANOOR	HATTI_110	05:04	18:02	12:58	LINE FAULT
91	16-Feb-21	GULBARGA	110	HV2	MYLAR_110	03:59	04:02	00:03	TRANSFORMER FAULT
92	16-Feb-21	GULBARGA	110	GULBARGA SOUTH-FARTHABAD	GULBARGASOUTH_110	15:10	15:25	00:15	LINE CLEAR AVAILED
93	16-Feb-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,HATTI_110	05:00	05:08	00:08	LINE FAULT
94	16-Feb-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,HATTI_110	17:55	18:05	00:10	MAIN SUPPLY FAILURE
95	16-Feb-21	GULBARGA	66	HV1 & HV2	KOTTUR_66	10:10	13:55	03:45	LINE CLEAR AVAILED
96	16-Feb-21	GULBARGA	66	HV1 & HV2	KOTTUR_66	10:55	11:45	00:50	LINE CLEAR AVAILED
97	16-Feb-21	HASSAN	220	HV2	MSEZ_220	09:42	14:14	04:32	LINE CLEAR AVAILED
98	16-Feb-21	HASSAN	110	LV2	MSEZ_220	09:47	14:15	04:28	LINE CLEAR AVAILED
99	16-Feb-21	HASSAN	110	JAVGAL	BANAVARA_110	11:10	13:29	02:19	LINE CLEAR AVAILED
100	16-Feb-21	HASSAN	110	IPP IC LINE	GAJNUR_110	14:06	16:05	01:59	LINE CLEAR AVAILED
101	16-Feb-21	HASSAN	110	MDBDRE	GURUPURA_110	09:55	17:08	07:13	NFBC ISSUED
102	16-Feb-21	HASSAN	110	GURUPURA	MOODABIDRE_110	09:55	17:15	07:20	LINE CLEAR AVAILED
103	16-Feb-21	HASSAN	110	HV1	MOODABIDRE_110	09:55	17:17	07:22	LINE CLEAR AVAILED
104	16-Feb-21	HASSAN	110	HV2	MOODABIDRE_110	09:53	17:17	07:24	LINE CLEAR AVAILED
105	16-Feb-21	HASSAN	110	SOHAM1	MOODABIDRE_110	09:53	17:17	07:24	LINE CLEAR AVAILED
106	16-Feb-21	HASSAN	110	SOHAM2	MOODABIDRE_110	09:53	17:17	07:24	LINE CLEAR AVAILED
107	16-Feb-21	HASSAN	110	HV2	SAGARA_110	14:21	15:08	00:47	LINE CLEAR AVAILED
108	16-Feb-21	HASSAN	66	SHMG- BHADRA	bhadra_gen	12:20	15:50	03:30	LINE CLEAR AVAILED
109	16-Feb-21	HASSAN	66	DUDDA	CHIKKAKONDAGOLA_66	12:02	12:30	00:28	LINE CLEAR AVAILED
110	16-Feb-21	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	13:15	14:05	00:50	LINE CLEAR AVAILED
111	16-Feb-21	HASSAN	66	CKNDGL	DUDDA_66	12:05	12:30	00:25	MAIN SUPPLY FAILURE
112	16-Feb-21	HASSAN	66	CHIKAMAGLUR2	HASSAN_220	13:04	13:29	00:25	LINE FAULT
113	16-Feb-21	HASSAN	66	HAASSAN1	HOLENARASIPURA_220	06:27	06:37	00:10	LINE FAULT
114	16-Feb-21	HASSAN	66	SOMANAHALLI	HNPURA_66	06:30	06:40	00:10	MAIN SUPPLY FAILURE
115	16-Feb-21	MYSURU	66	BG PURA-HEBBANI	CHIDRAVALLI_66 MEGALAPURA_66	10:10	16:18	6:08	NFBC ISSUED
116	16-Feb-21	MYSURU	66	HV1	CHIKKA_MANDYA_66	10:50	19:58	9:08	LINE CLEAR AVAILED
117	16-Feb-21	MYSURU	66	HV2	CHIKKA_MANDYA_66	9:00	10:45	1:45	LINE CLEAR AVAILED
118	16-Feb-21	MYSURU	66	HV2	CHIKKA_MANDYA_66	12:55	16:05	3:10	LINE CLEAR AVAILED
119	16-Feb-21	MYSURU	66	CR NAGARA-YELANDUR	YELANDUR_66	18:45	18:50	0:05	LINE FAULT
120	16-Feb-21	MYSURU	66	HV2	DATTAGALLY_66	10:04	13:16	3:11	LINE CLEAR AVAILED
121	16-Feb-21	MYSURU	66	HV2	HARVEY_66	10:35	10:43	0:07	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
122	16-Feb-21	MYSURU	66	HV2	HEBBAL_66	10:23	16:57	6:33	LINE CLEAR AVAILED
123	16-Feb-21	MYSURU	66	HOOTAGALLY-FTS 1	FTS_66	4:39	4:46	0:06	LINE FAULT
124	16-Feb-21	MYSURU	66	HV3	KIKKERI_66	9:39	10:04	0:25	LINE CLEAR AVAILED
125	16-Feb-21	MYSURU	66	MADHUVANAHALLY-MAMBALLI	MAMBALLI_66	18:43	18:49	0:05	LINE FAULT
126	16-Feb-21	MYSURU	66	HV1	MADIKERI_66	11:35	11:40	0:05	HAND TRIPPED
127	16-Feb-21	MYSURU	66	HV1	MADIKERI_66	12:00	13:35	1:35	LINE CLEAR AVAILED
128	16-Feb-21	MYSURU	66	HV2	MADIKERI_66	10:03	11:59	1:55	LINE CLEAR AVAILED
129	16-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 8	NO STATION EFFECTED	11:46	13:08	1:21	NFBC ISSUED
130	16-Feb-21	MYSURU	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	18:38	18:42	0:04	LINE FAULT
131	16-Feb-21	MYSURU	66	VAJMANGALA-MEGHALAPURA	GARGESHWARI_66 THUMBLA_66 MEGALAPURA_66 VYASRAJPURA_66	10:45	17:33	6:48	NFBC ISSUED
132	16-Feb-21	MYSURU	66	HV1	JAKKANAHALLY_66	10:47 (15/02/2021)	15:00 (16/02/2021)	28:12 HRS	TRANSFORMER CHARGED
133	16-Feb-21	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN :LINE CLEAR AVAILED
134	16-Feb-21	TUMKUR	110	HONNAVALI 110-ADAN SOLAR IPP_66	ADAN SOLAR IPP_110	19:03:43 (15.02.2021)	4:14:03 (16.02.201)	9:11HRS	LINE CHARGED
135	16-Feb-21	TUMKUR	220	TR-3(HV SIDE)	CHITRADURGA_220	10:16	12:47	2:30	LINE CLEAR AVAILED
136	16-Feb-21	TUMKUR	220	CHITRADURGA 220kV- THALLAK 220	CHITRADURGA_220	6:35	19:17	12:42	NFBC ISSUED
137	16-Feb-21	TUMKUR	220	TR-1	PAVAGADA_220	13:44	13:48	0:03	HAND TRIPPED
138	16-Feb-21	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	12:53	13:49	0:55	LINE CLEAR AVAILED
139	16-Feb-21	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	16:52	17:58	1:05	LINE CLEAR AVAILED
140	16-Feb-21	TUMKUR	110	TR-1	KBCROSS_220	15:11	15:14	0:02	HAND TRIPPED
141	16-Feb-21	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	22:11	22:20	0:08	HAND TRIPPED
142	16-Feb-21	TUMKUR	66	TR-2	BALENAHALLI_66	11:26	13:11	1:45	LINE CLEAR AVAILED
143	16-Feb-21	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	CHALLAKERE_66,BALENAHALLI_66	10:13	13:09	2:56	LINE CLEAR AVAILED
144	16-Feb-21	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, RELIANCE IPP_66, HIRIYUR_66	10:13	13:17	3:04	LINE CLEAR AVAILED
145	16-Feb-21	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	10:13	12:58	2:45	LINE CLEAR AVAILED
146	16-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:45	6:51	0:06	LINE FAULT
147	16-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	7:41	7:57	0:16	LINE FAULT
148	16-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:33	10:49	0:16	LINE FAULT
149	16-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:06	18:48	0:42	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
150	16-Feb-21	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	14:48	15:02	0:14	MAIN SUPPLY FAILURE
151	16-Feb-21	TUMKUR	66	TR-2	HANAGAL_66	14:54	15:03	0:09	MAIN SUPPLY FAILURE
152	16-Feb-21	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	14:53	15:06	0:12	MAIN SUPPLY FAILURE
153	16-Feb-21	TUMKUR	66	TR-1	HARIHAR_66	11:00	13:28	2:28	LINE CLEAR AVAILED
154	16-Feb-21	TUMKUR	66	TR-2	HARIHAR_66	13:28	17:41	4:13	LINE CLEAR AVAILED
155	16-Feb-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	4:38	4:59	0:21	HAND TRIPPED
156	16-Feb-21	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	11:21	11:38	0:17	LINE FAULT
157	16-Feb-21	TUMKUR	66	TR-1	KATTIGE_66	2:14	2:24	0:09	TRANSFORMER FAULT
158	16-Feb-21	TUMKUR	66	TR-1	KATTIGE_66	8:56	9:13	0:17	TRANSFORMER FAULT
159	16-Feb-21	TUMKUR	66	TR-2	MADHUGIRI_66	9:55	10:03	0:07	TRANSFORMER FAULT
160	16-Feb-21	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	16:55	17:56	1:00	LINE CLEAR AVAILED
161	16-Feb-21	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	13:44	13:48	0:04	HAND TRIPPED
162	16-Feb-21	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	11:19	11:40	0:20	TRANSFORMER FAULT
163	16-Feb-21	TUMKUR	66	PAVAGADA-NAGALAMADIKE	NAGALMADIKE_66	15:40	15:45	0:04	HAND TRIPPED
164	16-Feb-21	TUMKUR	66	TR-1	TAVAREKERE(C)_66	8:02	8:13	0:11	TRANSFORMER FAULT
165	16-Feb-21	TUMKUR	66	TR-1	TAVAREKERE(C)_66	14:15	14:25	0:09	TRANSFORMER FAULT
166	17-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
167	17-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN :LINE CLEAR AVAILED
168	17-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
169	17-Feb-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
170	17-Feb-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
171	17-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN :LINE CLEAR AVAILED
172	17-Feb-21	BAGALKOT	110	KANABARGI LAYOUT-NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN :LINE CLEAR AVAILED
173	17-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN :LINE CLEAR AVAILED
174	17-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN :LINE CLEAR AVAILED
175	17-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN :LINE CLEAR AVAILED
176	17-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
177	17-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
178	17-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN :LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
179	17-Feb-21	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN :LINE CLEAR AVAILED
180	17-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN :LINE CLEAR AVAILED
181	17-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN :LINE CLEAR AVAILED
182	17-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN :LINE CLEAR AVAILED
183	17-Feb-21	BAGALKOT	110	BELGAUM220-HUDALI	STATION NOT AFFECTED HUDALI_110	14:45 (14.02.2021)	20:57 (17.02.2021)	78:12HRS	LINE CHARGED
184	17-Feb-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SIRSI_110	13:54 (15.02.2021)	19:26 (17.02.2021)	53:32HRS	TRANSFORMER CHARGED
185	17-Feb-21	BAGALKOT	220	RANEENNUR- SHIRALKOPPA(BELLIGAVI)	STATION NOT AFFECTED RANEENNUR_220	23:41 (15.02.2021)			LINE OPEN :LINE CLEAR AVAILED
186	17-Feb-21	BAGALKOT	110	GAJENDRAGA-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	20:19 (16.02.2021)	15:22 (17.02.2021)	20:03HRS	LINE CHARGED
187	17-Feb-21	BAGALKOT	110	GAJENDRAGA-RON2	STATION NOT AFFECTED GAJENDRAGAD_110	20:19 (16.02.2021)	15:22 (17.02.2021)	20:03HRS	LINE CHARGED
188	17-Feb-21	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON_110	20:25 (16.02.2021)	12:53 (17.02.2021)	16:28HRS	LINE CHARGED
189	17-Feb-21	BAGALKOT	110	110/33KV,HV3	BELLATTI_110,HOLEITAGI_33, SOORANAGI_33,RWSS JALAWADAGI_33	10:11	17:07	6:56	LINE CLEAR AVALIED
190	17-Feb-21	BAGALKOT	110	110/11KV,HV1	GANESHGUDI_110	10:20	11:50	1:30	LINE CLEAR AVALIED
191	17-Feb-21	BAGALKOT	110	110/33KV,HV2	GANESHGUDI_110 &JOIDA_33	10:39	11:54	1:15	LINE CLEAR AVALIED
192	17-Feb-21	BAGALKOT	110	110/33KV,HV1	HANAGALL_110 & PALA&BASAPUR_33	15:38	15:57	0:19	LOAD CURTAILMENT
193	17-Feb-21	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110 & RUSTUMPUR &BELGAUM_33	19:15	19:34	0:19	TRANSFORMER FAULT
194	17-Feb-21	BAGALKOT	110	HUKKERI-HATTARAGI	HATTARAGI_110	11:25	14:44	3:19	LINE CLEAR AVALIED
195	17-Feb-21	BAGALKOT	110	110/11KV,HV2	KALAGHATGI_110	10:30	10:37	0:07	TRANSFORMER FAULT
196	17-Feb-21	BAGALKOT	110	110/11KV,HV2	KALAGHATGI_110	12:32	14:13	1:41	LINE CLEAR AVALIED
197	17-Feb-21	BAGALKOT	220	220/110KV,HV 1 &LV 1	KARAWAR_220	11:19	12:15	0:56	LINE CLEAR AVALIED
198	17-Feb-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SALAHALLI_110	14:05	14:10	0:05	LINE CLEAR AVALIED
199	17-Feb-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SALAHALLI_110	13:50	14:00	0:10	LINE CLEAR AVALIED
200	17-Feb-21	BAGALKOT	110	RON-HIREHAL	STATION NOT AFFECTED HIREHAL_110	06:30	11:54	5:24	LINE FAULT
201	17-Feb-21	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	06:30	13:09	6:39	LINE FAULT
202	17-Feb-21	BAGALKOT	110	110/11KV, HV1	LAKSHMESHWAR_110	10:05	18:05	8:00	LINE CLEAR AVALIED
203	17-Feb-21	BAGALKOT	110	110/11KV, HV2	LAKSHMESHWAR_110	10:22	17:55	7:33	LINE CLEAR AVALIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
204	17-Feb-21	BAGALKOT	110	110/33KV, HV3	LAKSHMESHWAR_110 MMCL IPP_33, SSM MILL_33	10:04	18:15	8:11	LINE CLEAR AVAILED
205	17-Feb-21	BAGALKOT	220	MAHALINGAPUR-ATHANI	STATION NOT AFFECTED MAHALINGAPUR_220	10:21 (17.02.2021)			LINE OPEN :LINE CLEAR AVAILED
206	17-Feb-21	BAGALKOT	220	MAHALINGAPUR-KUDACHI	STATION NOT AFFECTED MAHALINGAPUR_220	10:33 (17.02.2021)			LINE OPEN :LINE CLEAR AVAILED
207	17-Feb-21	BAGALKOT	220	MAHALINGAPUR-NARENDRA1	STATION NOT AFFECTED MAHALINGAPUR_220	10:31	17:47	7:16	LINE CLEAR AVAILED
208	17-Feb-21	BAGALKOT	220	KUDACHI-MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	10:33 (17.02.2021)			LINE OPEN :LINE CLEAR AVAILED
209	17-Feb-21	BENGALURU	66	APPARAL PARK -KIADB DB PURA 220	APPAREL PARK	12:10	12:15	00:05	LOAD CHANGE OVER
210	17-Feb-21	BENGALURU	66	APPARAL PARK - NRS 220	APPAREL PARK	15:15	15:20	00:05	LOAD CHANGE OVER
211	17-Feb-21	BENGALURU	66	AUSTIN TOWN - KORAMANGALA 220	AUSTIN TOWN	10:30	10:36	00:06	LOAD CHANGE OVER
212	17-Feb-21	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	10:59	11:14	00:15	LINE FAULT
213	17-Feb-21	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	10:38	16:54	06:16	LINE CLEAR AVAILED
214	17-Feb-21	BENGALURU	220	MANYATHA TECH PARK 220 - YELAHANKA 220	MANYATHA TECH PARK 220, HEBBALA 220	16:19	16:35	00:16	LINE FAULT
215	17-Feb-21	BENGALURU	66	MANYATHA TECH PARK 220 - MANYATHA TECH PARK 66	MANYATHA TECH PARK 66	16:19	16:36	00:17	LINE CLEAR AVAILED
216	17-Feb-21	BENGALURU	66	MANYATHA TECH PARK 220 - SHOBHA CITY	SHOBHA CITY	16:19	16:36	00:17	LINE CLEAR AVAILED
217	17-Feb-21	BENGALURU	220	HEBBALA 220 - MANYATHA TECH PARK 220	HEBBALA 220	16:19	16:36	00:17	MAIN SUPPLY FAILURE
218	17-Feb-21	BENGALURU	66	IISC - HEBBAL 220	IISC	16:19	16:33	00:14	MAIN SUPPLY FAILURE
219	17-Feb-21	BENGALURU	66	IISC - NRS 220	IISC	17:20	17:23	00:03	LOAD CHANGE OVER
220	17-Feb-21	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	16:19	16:41	00:22	MAIN SUPPLY FAILURE
221	17-Feb-21	BENGALURU	66	BANASWADI - HEBBALA 220	BANASWADI	16:19	16:42	00:23	MAIN SUPPLY FAILURE
222	17-Feb-21	BENGALURU	66	NRS 220 - NANDINI LAYOUT	NANDINI LAYOUT	13:32	14:22	00:50	LINE FAULT
223	17-Feb-21	BENGALURU	220	HV2	T K HALLI 220	19:40	20:12	00:32	TRANSFORMER FAULT
224	17-Feb-21	BENGALURU	66	T K HALLI 220 - SIMSHA 2	T K HALLI 220	19:40	20:12	00:32	LINE FAULT
225	17-Feb-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	19:40	20:20	00:40	LINE CLEAR AVAILED
226	17-Feb-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	19:40	20:28	00:48	LINE CLEAR AVAILED
227	17-Feb-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	19:40	20:28	00:48	LINE CLEAR AVAILED
228	17-Feb-21	BENGALURU	66	TK HALLI 220 - HAROHALI 2	VR DODDI	19:40	20:37	00:57	LINE CLEAR AVAILED
229	17-Feb-21	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	T K HALLI 220	19:40	20:37	00:57	LINE CLEAR AVAILED
230	17-Feb-21	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	RANGANADODDI	19:40	20:54	01:14	LINE CLEAR AVAILED
231	17-Feb-21	BENGALURU	66	HV1	T K HALLI 220	19:40	20:18	00:38	LINE CLEAR AVAILED
232	17-Feb-21	BENGALURU	66	T K HALLI 220 - SIMSHA 1	T K HALLI 220	19:40	21:32	01:52	LINE CLEAR AVAILED
233	17-Feb-21	BENGALURU	66	TK HALLI 220 - HAROHALI 2	VR DODDI	22:43	23:08	00:25	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
234	17-Feb-21	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	RANGANADODDI	22:43	23:04	00:21	LOAD CURTAILMENT
235	17-Feb-21	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 1	HALAGUR, HONNIGANAHALLI	19:40	22:05	02:25	LINE CLEAR AVAILED
236	17-Feb-21	BENGALURU	66	HV2	YARANDANAHALLI	14:44	14:54	00:10	TRANSFORMER FAULT
237	17-Feb-21	BENGALURU	66	HV3	YARANDANAHALLI	17:34	17:40	00:06	TRANSFORMER FAULT
238	17-Feb-21	BENGALURU	66	DODDABELAVANGALA - APPEREL PARK	DODDABELAVANGALA	17:45	17:52	00:07	LOAD CHANGE OVER
239	17-Feb-21	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	08:28	08:44	00:15	LINE FAULT
240	17-Feb-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	14:00	14:20	00:20	LOAD CURTAILMENT
241	17-Feb-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	09:50	10:19	00:28	LOAD CURTAILMENT
242	17-Feb-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:37	11:00	00:23	LOAD CURTAILMENT
243	17-Feb-21	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	09:12	09:49	00:37	LOAD CURTAILMENT
244	17-Feb-21	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	12:03	12:16	00:13	LOAD CHANGE OVER
245	17-Feb-21	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	15:18	15:29	00:11	LOAD CHANGE OVER
246	17-Feb-21	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	12:03	12:16	00:13	LOAD CHANGE OVER
247	17-Feb-21	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	15:18	15:29	00:11	LOAD CHANGE OVER
248	17-Feb-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	12:00	12:15	00:14	LOAD CHANGE OVER
249	17-Feb-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	17:44	17:58	00:14	LOAD CURTAILMENT
250	17-Feb-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	18:29	18:30	00:01	LINE CLEAR AVAILED
251	17-Feb-21	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	12:02	12:16	00:14	LOAD CHANGE OVER
252	17-Feb-21	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	15:16	15:29	00:12	LOAD CHANGE OVER
253	17-Feb-21	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	17:43	17:45	00:02	LOAD CURTAILMENT
254	17-Feb-21	BENGALURU	66	HV2	DODDABELAVANGALA	12:37	13:10	00:32	LINE CLEAR AVAILED
255	17-Feb-21	BENGALURU	66	HV1	SOMAYAJANAHALLI	14:42	15:05	00:22	LINE CLEAR AVAILED
256	17-Feb-21	BENGALURU	66	HV2	SOMAYAJANAHALLI	13:50	14:43	00:53	LINE CLEAR AVAILED
257	17-Feb-21	BENGALURU	66	HV1	RANGANDODDI	17:55	18:20	00:25	LINE CLEAR AVAILED
258	17-Feb-21	BENGALURU	66	HV2	RANGANDODDI	17:55	18:20	00:25	LINE CLEAR AVAILED
259	17-Feb-21	BENGALURU	66	HV2	MAASTHI	10:06	10:11	00:04	TRANSFORMER FAULT
260	17-Feb-21	BENGALURU	66	HV2	DODDABELAVANGALA	12:37	13:10	00:32	LINE CLEAR AVAILED
261	17-Feb-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
262	17-Feb-21	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	06:59	07:11	00:12	LINE FAULT
263	17-Feb-21	GULBARGA	220	HV1	SEDAM_220	07:02	07:41	00:39	TRANSFORMER FAULT
264	17-Feb-21	GULBARGA	220	HV2	SEDAM_220	07:02	08:28	01:26	TRANSFORMER FAULT
265	17-Feb-21	GULBARGA	110	HATTI-SINDHANOOR	HATTI_110(NO EFFECTED STATION)	18:21(17.2.2021)			LINE OPEN :LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
266	17-Feb-21	GULBARGA	110	NIRNA-RENEW WIND SOLAR_IPP	NIRNA_110	19:40(17.2.2021)			LINE OPEN :LINE CLEAR AVAILED
267	17-Feb-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADAVIAMARESHWAR_110	15:05(14.02.2021)			LINE OPEN :LINE CLEAR AVAILED
268	17-Feb-21	GULBARGA	110	SINDHANOOR-RAICHUR1	MASKI_110,MUDDAPUR_110	15:30(14.02.2021)			LINE OPEN :LINE CLEAR AVAILED
269	17-Feb-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	14:15(15.2.2021)			LINE OPEN :LINE CLEAR AVAILED
270	17-Feb-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,HATTI_110	03:46	03:56	00:10	LINE FAULT
271	17-Feb-21	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_110	12:55	13:59	01:04	LINE CLEAR AVAILED
272	17-Feb-21	GULBARGA	110	HV3	KAMPLI_110	11:42	12:48	01:06	LINE CLEAR AVAILED
273	17-Feb-21	GULBARGA	110	SINDHANOOR-SIRIGUPPA	DHADESUGUR_110,SIRIGUPPA A_110,TEKKALAKTTA_110	01:46	01:56	00:10	LINE FAULT
274	17-Feb-21	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	05:10	05:50	00:40	LINE FAULT
275	17-Feb-21	GULBARGA	110	SEDAM-MALKHEDRAILWAY	SEDAM_220	14:31	17:36	03:05	LINE CLEAR AVAILED
276	17-Feb-21	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	17:58	18:08	00:10	LINE FAULT
277	17-Feb-21	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110,GANADAL_110	18:23	18:56	00:33	LINE FAULT
278	17-Feb-21	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	11:05	13:30	02:25	LINE CLEAR AVAILED
279	17-Feb-21	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	16:05	22:15	06:10	LINE FAULT
280	17-Feb-21	GULBARGA	110	HATTI-SINDHANOOR	HATTI_110	15:42	15:53	00:11	LINE FAULT
281	17-Feb-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABUR_110,DEODURGA_110	16:08	16:20	00:12	LINE FAULT
282	17-Feb-21	GULBARGA	110	MASKI-HATTI	HATTI_110	18:21	18:32	00:11	LINE FAULT
283	17-Feb-21	GULBARGA	110	HV2	NIRNA_110	15:55	16:00	00:05	TRANSFORMER FAULT
284	17-Feb-21	GULBARGA	110	NIRNA-RENEW WIND SOLAR_IPP	NIRNA_110	19:40(17.2.2021)	3:20(18.2.2021)	7:40 HRS	LINE CHARGED
285	17-Feb-21	GULBARGA	66	HV1	HAMPASAGAR	12:30	13:00	00:30	LINE CLEAR AVAILED
286	17-Feb-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
287	17-Feb-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
288	17-Feb-21	HASSAN	110	HV3	BHADRAVATHI_110	07:45	07:50	00:05	HAND TRIPPED
289	17-Feb-21	HASSAN	110	HV3	BHADRAVATHI_110	10:42	10:50	00:08	HAND TRIPPED
290	17-Feb-21	HASSAN	110	HV1	ESSUR_110	16:32	17:36	01:04	LINE CLEAR AVAILED
291	17-Feb-21	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	11:30	13:00	01:30	LINE CLEAR AVAILED
292	17-Feb-21	HASSAN	110	HV1	GURUPURA_110	10:49	13:46	02:57	LINE CLEAR AVAILED
293	17-Feb-21	HASSAN	110	JOG-JST2	mghejog_gen	10:25	12:22	01:57	LINE CLEAR AVAILED
294	17-Feb-21	HASSAN	66	HV1	HOLEHONNUR_66	10:00	10:10	00:10	MAIN SUPPLY FAILURE
295	17-Feb-21	HASSAN	66	HV2	HOLEHONNUR_66	10:00	10:10	00:10	MAIN SUPPLY FAILURE
296	17-Feb-21	HASSAN	66	HV1	HOLEHONNUR_66	14:50	14:55	00:05	MAIN SUPPLY FAILURE
297	17-Feb-21	HASSAN	66	HV2	HOLEHONNUR_66	14:50	14:55	00:05	MAIN SUPPLY FAILURE
298	17-Feb-21	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	14:51	14:56	00:05	LINE FAULT
299	17-Feb-21	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	10:38	10:50	00:12	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
300	17-Feb-21	MYSURU	66	HV1	ATTIGULIPURA_66	11:54	13:09	1:15	LINE CLEAR AVAILED
301	17-Feb-21	MYSURU	66	HV2	ATTIGULIPURA_66	13:10	14:15	1:05	LINE CLEAR AVAILED
302	17-Feb-21	MYSURU	66	HV1	HAMPAPURA_66	10:02	11:11	1:08	LINE CLEAR AVAILED
303	17-Feb-21	MYSURU	66	HV2	HAMPAPURA_66	10:02	19:00	8:57	LINE CLEAR AVAILED
304	17-Feb-21	MYSURU	66	HUNSUR-HANAGODU	HANAGODU_66	9:38	9:47	0:09	LINE CLEAR AVAILED
305	17-Feb-21	MYSURU	66	HV1	JAKKANAHALLY_66	11:27	11:44	0:16	LINE CLEAR AVAILED
306	17-Feb-21	MYSURU	66	HV1	KIRUGAVALU_66	12:38	13:38	0:59	LINE CLEAR AVAILED
307	17-Feb-21	MYSURU	66	KM DODDI-MANDYA	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66 K_HONNALGERE_66 TALAGAVADI_66	19:41	21:07	1:25	MAIN SUPPLY FAILURE
308	17-Feb-21	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATION EFFECTED	8:26	10:13	1:46	LOAD CURTAILMENT
309	17-Feb-21	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	12:05	12:14	0:09	LINE FAULT
310	17-Feb-21	MYSURU	66	HV1	KUNTHUR_66	9:29	12:37	3:07	LINE CLEAR AVAILED
311	17-Feb-21	MYSURU	66	HV2	KUNTHUR_66	9:30	15:00	5:30	LINE CLEAR AVAILED
312	17-Feb-21	MYSURU	66	KUSHALANAGARA 220-BYLUKUPPE	BYLUKUPPE_66	4:43	5:00	0:17	LINE FAULT
313	17-Feb-21	MYSURU	66	MADHUVANAHALLI-HANNUR 1	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66 AJJIPURA_66 HANNUR_66	13:54	16:43	2:49	NFBC ISSUED
314	17-Feb-21	MYSURU	66	MADHUVANAHALLI-HANNUR 2	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66 AJJIPURA_66 HANNUR_66	13:54	16:44	2:50	NFBC ISSUED
315	17-Feb-21	MYSURU	66	MADHUVANAHALLI-HANNUR 1	NO STATION EFFECTED	17:34	17:39	0:05	LINE FAULT
316	17-Feb-21	MYSURU	66	MADHUVANAHALLI-DODDINDUVADI	DODDINADUVADI_66	18:38	18:41	0:02	HAND TRIPPED
317	17-Feb-21	MYSURU	66	HV2	MALAVALLI_66	10:49	13:38	2:49	LINE CLEAR AVAILED
318	17-Feb-21	MYSURU	66	HV1	NAGAMANGALA_66	12:23	12:28	0:05	HAND TRIPPED
319	17-Feb-21	MYSURU	66	HV1	NAGAMANGALA_66	15:59	16:38	0:39	HAND TRIPPED
320	17-Feb-21	MYSURU	66	HV2	NAGAMANGALA_66	16:48	17:09	0:21	HAND TRIPPED
321	17-Feb-21	MYSURU	66	HV2	NAGAMANGALA_66	18:07	18:30	0:23	HAND TRIPPED
322	17-Feb-21	MYSURU	66	HV1	NANJANGUDU_66	13:32	13:55	0:22	LINE CLEAR AVAILED
323	17-Feb-21	MYSURU	66	SFC SIVA-PGL	NO STATION EFFECTED	22:44	22:46	0:02	LINE FAULT
324	17-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 9	NO STATION EFFECTED	10:10	10:11	0:01	HAND TRIPPED
325	17-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 9	NO STATION EFFECTED	10:14	10:16	0:02	HAND TRIPPED
326	17-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 9	NO STATION EFFECTED	10:25	10:26	0:01	HAND TRIPPED
327	17-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 9	NO STATION EFFECTED	10:28	10:29	0:01	HAND TRIPPED
328	17-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 9	NO STATION EFFECTED	12:25	12:26	0:01	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
329	17-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 9	NO STATION EFFECTED	12:29	12:33	0:03	HAND TRIPPED
330	17-Feb-21	MYSURU	220	HV2	TUBINAKERE_220	8:56	11:15	2:18	LINE CLEAR AVAILED
331	17-Feb-21	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN :LINE CLEAR AVAILED
332	17-Feb-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	08:17:54	16:59:02	8:41	NFBC ISSUED
333	17-Feb-21	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	11:40	18:41	7:01	LINE CLEAR AVAILED
334	17-Feb-21	TUMKUR	110	HONNAVALI 110-ADAN SOLAR IPP_66	ADAN SOLAR_IPP_110	6:32:39 PM(18.02.2021)			LINE OPEN :LINE CLEAR AVAILED
335	17-Feb-21	TUMKUR	110	TR-2	TURUVEKERE_110	13:52	14:37	0:45	TRANSFORMER FAULT
336	17-Feb-21	TUMKUR	110	TR-3	GUBBI_110	15:36	18:50	3:14	LINE CLEAR AVAILED
337	17-Feb-21	TUMKUR	110	TR-1	HANDANKERE_110	10:19	12:47	2:27	LINE CLEAR AVAILED
338	17-Feb-21	TUMKUR	110	TR-1	TIMMANAHALLI_110	11:47	12:09	0:22	TRANSFORMER FAULT
339	17-Feb-21	TUMKUR	66	TR-1	CHANNAGIRI_66	6:02	6:08	0:06	TRANSFORMER FAULT
340	17-Feb-21	TUMKUR	66	TR-1	CHANNAGIRI_66	8:13	8:21	0:07	TRANSFORMER FAULT
341	17-Feb-21	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	10:10	15:07	4:56	LINE CLEAR AVAILED
342	17-Feb-21	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	16:00	16:15	0:14	LINE FAULT
343	17-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:29	6:35	0:05	LINE FAULT
344	17-Feb-21	TUMKUR	66	TR-2	HOSADURGA_66	7:40	7:42	0:02	TRANSFORMER FAULT
345	17-Feb-21	TUMKUR	66	TR-1	KUNIGAL_66	0:02	0:06	0:04	TRANSFORMER FAULT
346	17-Feb-21	TUMKUR	66	MEDIGESHI- MADHUGIRI	MEDIGESHI_66	16:06	17:54	1:47	LINE CLEAR AVAILED
347	17-Feb-21	TUMKUR	66	TR-2	RAMPURA_66	12:15	12:24	0:08	TRANSFORMER FAULT
348	17-Feb-21	TUMKUR	66	TR-2	SANIKERE_66	15:53	16:10	0:17	TRANSFORMER FAULT
349	17-Feb-21	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	16:01	16:30	0:28	LINE FAULT
350	17-Feb-21	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	15:04	15:53	0:48	LINE CLEAR AVAILED
351	17-Feb-21	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,S OKKE_66	16:05	16:15	0:09	LINE CLEAR AVAILED
352	18-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
353	18-Feb-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED GUTTAL_110	18:55	19:19	0:24	TRANSFORMER FAULT
354	18-Feb-21	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:02	14:03	2:01	LINE CLEAR AVAILED
355	18-Feb-21	BAGALKOT	110	110/11KV, HV2	SIRSI_110	11:46	17:59	6:13	LINE CLEAR AVAILED
356	18-Feb-21	BAGALKOT	110	110/11KV, HV2	MUDEBIHAL_110	00:49	00:52	0:03	TRANSFORMER FAULT
357	18-Feb-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
358	18-Feb-21	BAGALKOT	110	110/33KV, HV2	RATTIHALLI_110, HALLUR_33, MASUR_33	12:18	13:18	1:00	LINE CLEAR AVAILED
359	18-Feb-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED HIDKALDAM_110, RUSTAMPUR LIS_33, BGMWS STAGE-1,2&3_33	18:57	19:12	0:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
360	18-Feb-21	BAGALKOT	110	110/33KV, HV4(HV3)	STATION NOT AFFECTED GAJENDRAGAD_110 WIND3 IPP_33, WIND4 IPP_33	18:38	20:27	1:49	LINE CLEAR AVAILED
361	18-Feb-21	BAGALKOT	110	AINAPUR-ATHANI SUGARS	STATION NOT AFFECTED AINAPUR_110	17:09	17:24	0:15	LINE FAULT
362	18-Feb-21	BAGALKOT	110	AMBEWADI-NK2	KAVALWAD_110	17:41	18:20	0:39	LINE FAULT
363	18-Feb-21	BAGALKOT	110	BELGAUM220- UCHAGAON(HUKKERI)	UCHAGAON_110, UDYAMBAG_110	14:59	15:59	1:00	LINE FAULT
364	18-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN :LINE CLEAR AVAILED
365	18-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN :LINE CLEAR AVAILED
366	18-Feb-21	BAGALKOT	110	GMSH-KULIGOD	KULIGOD_110,GAMESH_IPP	19:47	19:51	0:04	HAND TRIPPED
367	18-Feb-21	BAGALKOT	110	GOPANAKOPPA-NARAGUND	NARAGUND_110	11:09	11:36	0:27	HAND TRIPPED
368	18-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN :LINE CLEAR AVAILED
369	18-Feb-21	BAGALKOT	110	JAMBAGI-VJRM(MUDHOL)	STATION NOT AFFECTED JAMBAGI_110	13:00 (24.01.2021)	7:05 (18.02.2021)	594:05 hrs	LINE CHARGED
370	18-Feb-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN :LINE CLEAR AVAILED
371	18-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
372	18-Feb-21	BAGALKOT	110	KUDACH220-TERDAL(MORAB)	MORAB_110	10:36	16:14	5:38	LINE CLEAR AVAILED
373	18-Feb-21	BAGALKOT	110	MAHALINGAPUR (RANNABELAGALI) - UTTUR	STATION NOT AFFECTED UTTUR_110	07:08	11:03	3:55	LINE FAULT
374	18-Feb-21	BAGALKOT	110	MAHALINGAPUR- GSML1	MAHALINGAPUR_220	06:34	08:10	1:36	LINE FAULT
375	18-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN :LINE CLEAR AVAILED
376	18-Feb-21	BAGALKOT	110	NAVALGUND- BIDNAL	STATION NOT AFFECTED NAVALGUND_110	15:34	16:46	1:12	LINE CLEAR AVAILED
377	18-Feb-21	BAGALKOT	110	PGHUNSHYAL- NAGNUR (MUDALGI)	NAGNUR_110, MUDALGI_110	18:57	19:06	0:09	LINE FAULT
378	18-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN :LINE CLEAR AVAILED
379	18-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN :LINE CLEAR AVAILED
380	18-Feb-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
381	18-Feb-21	BAGALKOT	110	SOUDATTI- ENERCON1	STATION NOT AFFECTED SOUDATTI_110	16:10	19:48	3:38	LINE CLEAR AVAILED
382	18-Feb-21	BAGALKOT	220	220/110KV, HV2&LV2	NO STATION AFFECTED MAHALINGAPUR_220	06:34	13:10	6:36	TRANSFORMER FAULT
383	18-Feb-21	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN :LINE CLEAR AVAILED
384	18-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN :LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
385	18-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN :LINE CLEAR AVAILED
386	18-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN :LINE CLEAR AVAILED
387	18-Feb-21	BAGALKOT	220	GHATAPRABHA-NARENDRA2	STATION NOT AFFECTED GHATAPRABHA_220	17:13	17:31	0:18	LINE FAULT
388	18-Feb-21	BAGALKOT	220	KUDACHI-MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	10:33 (17.02.2021)			LINE OPEN :LINE CLEAR AVAILED
389	18-Feb-21	BAGALKOT	220	MAHALINGAPUR-ATHANI	STATION NOT AFFECTED MAHALINGAPUR_220	10:21 (17.02.2021)			LINE OPEN :LINE CLEAR AVAILED
390	18-Feb-21	BAGALKOT	220	MAHALINGAPUR-KUDACHI	STATION NOT AFFECTED MAHALINGAPUR_220	10:33 (17.02.2021)			LINE OPEN :LINE CLEAR AVAILED
391	18-Feb-21	BAGALKOT	220	RANEBENNUR- SHIRALKOPPA(BELLIGAVI)	STATION NOT AFFECTED RANEBENNUR_220	23:41 (15.02.2021)			LINE OPEN :LINE CLEAR AVAILED
392	18-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
393	18-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
394	18-Feb-21	BENGALURU	66	AVANI - KOLAR 220	AVANI, MULBAGAL	13:13	13:38	0:25	LINE FAULT
395	18-Feb-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	12:34	12:42	0:07	LOAD CHANGE OVER
396	18-Feb-21	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY , INFOSYS(EHT)	10:53	10:58	0:05	LOAD CHANGE OVER
397	18-Feb-21	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 220	ELECTRONIC CITY , INFOSYS(EHT)	16:53	17:00	0:07	LOAD CHANGE OVER
398	18-Feb-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	17:25	17:39	0:14	LINE FAULT
399	18-Feb-21	BENGALURU	66	HV1	ISRO LAYOUT	14:13	14:20	0:07	LINE CLEAR AVALIED
400	18-Feb-21	BENGALURU	66	HV1	MITTEMARI 220	9:16	9:25	0:09	TRANSFORMER FAULT
401	18-Feb-21	BENGALURU	66	HV1	TEKAL	8:05	8:13	0:08	TRANSFORMER FAULT
402	18-Feb-21	BENGALURU	66	HV2	MEI LAYOUT	20:22	20:32	0:10	TRANSFORMER FAULT
403	18-Feb-21	BENGALURU	66	HV2	KACHMARANAHALLI	8:17	8:30	0:12	LINE CLEAR AVALIED
404	18-Feb-21	BENGALURU	66	KANAKAPURA 220 - T K HALLI 1	HUKUNDA,KODIHALLI,HUNSE NAHALLI,HAROBEL	12:02	15:54	3:52	LINE CLEAR AVALIED
405	18-Feb-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:12	9:24	0:12	LINE FAULT
406	18-Feb-21	BENGALURU	66	WELCAST STEEL - DG 3	WELCAST STEEL	13:07	13:12	0:05	LOAD CHANGE OVER
407	18-Feb-21	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	15:36	15:40	0:04	LOAD CHANGE OVER
408	18-Feb-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16-02-2021)			LINE OPEN: LINE FAULT
409	18-Feb-21	BENGALURU	220	MAGADI 220 - NELAMANGALA 400	NO STATION AFFECTED	6:09	13:12	7:03	LINE FAULT
410	18-Feb-21	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	08:08	08:12	00:04	LINE FAULT
411	18-Feb-21	GULBARGA	110	GUTTAL-MYLAR	MYLAR_110	10:01	17:25	07:24	LINE CLEAR AVALIED
412	18-Feb-21	GULBARGA	110	HALBARGA-CHIDRI2	CHIDRI_110	19:01	19:14	00:13	LINE FAULT
413	18-Feb-21	GULBARGA	110	HATTI-SINDHANOOR	HATTI_110(NO EFFECTED STATION)	18:21(17.2.2021)			LINE OPEN :LINE CLEAR AVAILED
414	18-Feb-21	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110	09:27	09:49	00:22	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
415	18-Feb-21	GULBARGA	110	HV1	KUDITINI_110	21:10	21:15	00:05	TRANSFORMER FAULT
416	18-Feb-21	GULBARGA	110	HV2	VALKAMDINNI_110	13:30	14:00	00:30	LINE CLEAR AVAILED
417	18-Feb-21	GULBARGA	110	KADAGANCHI-KBS CBREAKER(TKB SOLAR)_JPP	KADAGANCHI_110	19:12	19:54	00:42	LINE CLEAR AVAILED
418	18-Feb-21	GULBARGA	110	KAPNOOR-HUMNBAD1	CJHALLI_110,GUDEKOTE_110, HOSAHALLI_110,BANVEKAL_1 10, CHORNOOR_110	19:23	19:29	00:06	LINE FAULT
419	18-Feb-21	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110	01:45	08:47	07:02	LINE FAULT
420	18-Feb-21	GULBARGA	110	LINGASUGUR-MUDGAL	MUDGAL_110	10:20	18:00	07:40	LINE CLEAR AVAILED
421	18-Feb-21	GULBARGA	110	LINGASUGUR-MUDGAL	MUDGAL_110	19:10	19:15	00:05	LINE FAULT
422	18-Feb-21	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110,VALKAMDINNI _110	13:25	13:35	00:10	LINE FAULT
423	18-Feb-21	GULBARGA	110	NIRNA-RENEW WIND SOLAR_IPP	NIRNA_110	19:40(17.2.2021)	3:20(18.2.2021)	7:40 HRS	LINE CHARGED
424	18-Feb-21	GULBARGA	110	SHAHABAD-WADI	WADI_110	11:41	12:52	01:11	LINE CLEAR AVAILED
425	18-Feb-21	GULBARGA	110	SINDHANOOR-RAICHUR1	MASKI_110,MUDDAPUR_110	15:30(14.02.2021)			LINE OPEN :LINE CLEAR AVAILED
426	18-Feb-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADAVIAMARESHWAR_110	15:05(14.02.2021)			LINE OPEN :LINE CLEAR AVAILED
427	18-Feb-21	GULBARGA	110	SINDHNOOR-MUNIRABAD1	KARATAGI_110,SRNAGAR_11 0,GANGAVATHI_110,VENKAT AGIRI_110	09:10	13:35	04:25	LINE CLEAR AVAILED
428	18-Feb-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	14:15(15.2.2021)			LINE OPEN :LINE CLEAR AVAILED
429	18-Feb-21	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	18:47	19:54	01:07	LINE CLEAR AVAILED
430	18-Feb-21	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	18:47	19:23	00:36	LINE CLEAR AVAILED
431	18-Feb-21	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	18:47	20:28	01:41	LINE CLEAR AVAILED
432	18-Feb-21	HASSAN	66	HV2	KANDLI_66	11:19	12:08	00:49	LINE CLEAR AVAILED
433	18-Feb-21	HASSAN	66	HV2	UDAYAPURA_66	08:03	08:07	00:04	TRANSFORMER FAULT
434	18-Feb-21	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
435	18-Feb-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
436	18-Feb-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHANAHALLY_66	16:42	16:50	00:08	LINE FAULT
437	18-Feb-21	HASSAN	110	HV1	BANAVARA_110	12:36	12:52	00:16	HAND TRIPPED
438	18-Feb-21	HASSAN	110	HV1	KALLUSADARAHALLY_110	13:12	13:41	00:29	LINE CLEAR AVAILED
439	18-Feb-21	HASSAN	110	HV2	PUTTUR_110	16:34(18.2.2021)			LINE OPEN :LINE CLEAR AVAILED
440	18-Feb-21	HASSAN	110	HV2	KARAYA_110	10:37	11:26	00:49	LINE CLEAR AVAILED
441	18-Feb-21	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	14:23	14:34	00:11	LINE FAULT
442	18-Feb-21	HASSAN	220	MRSSHM-VARAH1	MRSMG_220	22:45(18.2.2021)			LINE OPEN: LINE FAULT
443	18-Feb-21	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	22:45(18.2.2021)			LINE OPEN: LINE FAULT
444	18-Feb-21	MYSURU	66	DK MAIDANA-VAJAMANGALA	DKMAIDANA_66	10:03	17:26	7:22	LINE CLEAR AVAILED
445	18-Feb-21	MYSURU	66	HANNUR-MADHUVANAHALLI 2	NO STATION EFFECTED	14:02	14:44	0:42	LINE CLEAR AVAILED
446	18-Feb-21	MYSURU	66	HV1	ATTIGULIPURA_66	15:01	16:24	1:23	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
447	18-Feb-21	MYSURU	66	HV1	DEVANOORNGUDU_66	16:09	16:24	0:14	TRANSFORMER FAULT
448	18-Feb-21	MYSURU	66	HV1	DKMAIDANA_66	10:03	16:58	6:54	LINE CLEAR AVAILED
449	18-Feb-21	MYSURU	66	HV1	GUDDENAHALLI_66	10:25	16:02	5:37	LINE CLEAR AVAILED
450	18-Feb-21	MYSURU	66	HV1	KIRUGAVALU_66	11:28	18:46	7:18	LINE CLEAR AVAILED
451	18-Feb-21	MYSURU	66	HV1	KOPPA_66	14:16	14:45	0:28	LINE CLEAR AVAILED
452	18-Feb-21	MYSURU	66	HV1	MALAVALLI_66	10:30	18:32	8:01	LINE CLEAR AVAILED
453	18-Feb-21	MYSURU	66	HV1	NAGAMANGALA_66	11:57	13:24	1:26	LINE CLEAR AVAILED
454	18-Feb-21	MYSURU	66	HV2	DEVANOORNGUDU_66	16:09	16:26	0:16	TRANSFORMER FAULT
455	18-Feb-21	MYSURU	66	HV2	DKMAIDANA_66	10:03	16:57	6:54	LINE CLEAR AVAILED
456	18-Feb-21	MYSURU	66	HV2	GUDDENAHALLI_66	10:25	16:00	5:35	LINE CLEAR AVAILED
457	18-Feb-21	MYSURU	66	HV2	MALAVALLI_66	10:30	18:38	8:07	LINE CLEAR AVAILED
458	18-Feb-21	MYSURU	66	HV2	NAGAMANGALA_66	13:55	15:40	1:45	LINE CLEAR AVAILED
459	18-Feb-21	MYSURU	66	HV2	NAGAMANGALA_66	15:55	15:59	0:04	HAND TRIPPED
460	18-Feb-21	MYSURU	66	HV2	NAGAMANGALA_66	17:07	17:40	0:32	HAND TRIPPED
461	18-Feb-21	MYSURU	66	HV3	KIKKERI_66	13:18	14:25	1:07	LINE CLEAR AVAILED
462	18-Feb-21	MYSURU	66	KADAKOLA-JYOTHINAGARA	DKMAIDANA_66	10:12	16:56	6:44	NFBC ISSUED
463	18-Feb-21	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN :LINE CLEAR AVAILED
464	18-Feb-21	MYSURU	66	MADHUVAHALLI-KUNTHUR	NO STATION EFFECTED	6:32	6:37	0:04	LINE FAULT
465	18-Feb-21	MYSURU	66	MALAVALLI-M2	HADLI_66 MALAVALLI_66	10:31	18:31	8:00	LINE CLEAR AVAILED
466	18-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	11:21	11:25	0:03	HAND TRIPPED
467	18-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	12:02	12:03	0:01	HAND TRIPPED
468	18-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	12:04	12:09	0:05	HAND TRIPPED
469	18-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 2	NO STATION EFFECTED	11:22	11:25	0:03	HAND TRIPPED
470	18-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 6	NO STATION EFFECTED	11:16	11:20	0:03	HAND TRIPPED
471	18-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 6	NO STATION EFFECTED	11:25	11:26	0:01	HAND TRIPPED
472	18-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 6	NO STATION EFFECTED	11:54	11:56	0:01	HAND TRIPPED
473	18-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 7	NO STATION EFFECTED	11:17	11:19	0:02	HAND TRIPPED
474	18-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 9	NO STATION EFFECTED	11:10	11:13	0:03	HAND TRIPPED
475	18-Feb-21	MYSURU	66	TN PURA-THAYUR	TNARASIPURA_66	9:18	18:27	9:09	LINE CLEAR AVAILED
476	18-Feb-21	MYSURU	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	6:30	6:40	0:10	LINE FAULT
477	18-Feb-21	TUMKUR	66	ANCHEPALYA 220kv- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	21:06	21:16	0:10	LINE FAULT
478	18-Feb-21	TUMKUR	66	ANCHEPALYA 220kv- YEDIYUR(BG NAGAR)	YEDIYUR_66	08:37	08:47	0:10	LINE FAULT
479	18-Feb-21	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66 PANDARAHALLI_66,	13:40	13:47	0:06	HAND TRIPPED
480	18-Feb-21	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	HDPURA_66, HOLALKERE_66,RAMAGIRI_66 ,CHITRAHALLI_66	13:41	13:47	0:05	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
481	18-Feb-21	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	13:40	13:48	0:07	HAND TRIPPED
482	18-Feb-21	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	CHITRADURGA_66	13:42	13:47	0:04	HAND TRIPPED
483	18-Feb-21	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	12:03	12:05	0:01	MAIN SUPPLY FAILURE
484	18-Feb-21	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	12:03	12:07	0:03	MAIN SUPPLY FAILURE
485	18-Feb-21	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:03	12:06	0:02	MAIN SUPPLY FAILURE
486	18-Feb-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:03	12:05	0:01	MAIN SUPPLY FAILURE
487	18-Feb-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:35	16:44	0:09	LINE FAULT
488	18-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:03	12:06	0:02	MAIN SUPPLY FAILURE
489	18-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:44	18:53	0:09	LINE FAULT
490	18-Feb-21	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJHALLI_66	12:03	12:05	0:01	MAIN SUPPLY FAILURE
491	18-Feb-21	TUMKUR	66	NAYAKANAHATTI66- HIREMALLANHOLE	NAYAKANAHATTI_66	13:07	13:09	0:01	MAIN SUPPLY FAILURE
492	18-Feb-21	TUMKUR	66	TR-1	TAVAREKERE(C)_66	14:03	14:12	0:09	TRANSFORMER FAULT
493	18-Feb-21	TUMKUR	66	TR-1	SOKKE_66	09:39	09:51	0:12	HAND TRIPPED
494	18-Feb-21	TUMKUR	66	TR-1	RANGANATHAPURA_66	08:37	09:01	0:23	LINE CLEAR AVAILED
495	18-Feb-21	TUMKUR	66	TR-1	KUNDUR_66	11:46	13:42	1:55	LINE CLEAR AVAILED
496	18-Feb-21	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	13:33	13:45	0:11	HAND TRIPPED
497	18-Feb-21	TUMKUR	66	TR-2	SANIKERE_66	15:30	15:41	0:11	TRANSFORMER FAULT
498	18-Feb-21	TUMKUR	66	TR-2(HV SIDE)	CHITRADURGA_220	13:16	13:46	0:30	HAND TRIPPED
499	18-Feb-21	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	11:37	11:58	0:21	LINE CLEAR AVAILED
500	18-Feb-21	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	14:47	15:11	0:24	LINE CLEAR AVAILED
501	18-Feb-21	TUMKUR	110	HANDANKERE_110-K B CROSS 220	HANDANKERE_110	11:13	12:55	1:42	LINE CLEAR AVAILED
502	18-Feb-21	TUMKUR	110	HONNAVALI 110-ADAN SOLAR IPP_66	ADAN SOLAR_IPP_110	6:32:39 PM(18.02.2021)	12:52:37 AM(18.02.2021)	6:30 hrs	LINE CHARGED
503	18-Feb-21	TUMKUR	110	TR-1	DODDAGUNI_110	19:28	20:10	0:41	HAND TRIPPED
504	18-Feb-21	TUMKUR	110	TR-1	HANDANKERE_110	11:13	12:55	1:42	LINE CLEAR AVAILED
505	18-Feb-21	TUMKUR	110	TR-1	HUNSEGHATTA_110	13:39	15:21	1:42	LINE CLEAR AVAILED
506	18-Feb-21	TUMKUR	110	TR-2	KBCROSS_220	15:43	15:46	0:02	HAND TRIPPED
507	18-Feb-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	08:57	15:46	6:48	NFBC ISSUED
508	18-Feb-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	11:03	12:03	1:00	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
509	18-Feb-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	8:43:57 PM(18.02.2021)			LINE OPEN: LINE FAULT
510	18-Feb-21	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	11:15	16:35	5:20	LINE CLEAR AVAILED
511	19-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
512	19-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN :LINE CLEAR AVAILED
513	19-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
514	19-Feb-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
515	19-Feb-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
516	19-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN :LINE CLEAR AVAILED
517	19-Feb-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN :LINE CLEAR AVAILED
518	19-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN :LINE CLEAR AVAILED
519	19-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN :LINE CLEAR AVAILED
520	19-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN :LINE CLEAR AVAILED
521	19-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
522	19-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
523	19-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN :LINE CLEAR AVAILED
524	19-Feb-21	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN :LINE CLEAR AVAILED
525	19-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN :LINE CLEAR AVAILED
526	19-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN :LINE CLEAR AVAILED
527	19-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN :LINE CLEAR AVAILED
528	19-Feb-21	BAGALKOT	220	RANEBENNUR- SHIRALKOPPA(BELLIGAVI)	STATION NOT AFFECTED RANEBENNUR_220	23:41 (15.02.2021)			LINE OPEN :LINE CLEAR AVAILED
529	19-Feb-21	BAGALKOT	220	MAHALINGAPUR-ATHANI	STATION NOT AFFECTED MAHALINGAPUR_220	10:21 (17.02.2021)			LINE OPEN :LINE CLEAR AVAILED
530	19-Feb-21	BAGALKOT	220	MAHALINGAPUR-KUDACHI	STATION NOT AFFECTED MAHALINGAPUR_220	10:33 (17.02.2021)			LINE OPEN :LINE CLEAR AVAILED
531	19-Feb-21	BAGALKOT	220	KUDACHI-MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	10:33 (17.02.2021)			LINE OPEN :LINE CLEAR AVAILED
532	19-Feb-21	BAGALKOT	220	BELGAUM-KANABARGI2	STATION NOT AFFECTED BELGAUM_220	21:04 (19.02.2021)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
533	19-Feb-21	BAGALKOT	110	AMBEWADI220-NK2	STATION NOT AFFECTED KAVALAWADA	17:00	17:07	0:07	HAND TRIPPED
534	19-Feb-21	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110, ATHANI SUGARS_110	12:51	14:36	1:45	NFBC ISSUED
535	19-Feb-21	BAGALKOT	110	AINAPUR-AINAPUR LIS	AINAPUR_110, AINAPUR LIS_110	12:52	14:39	1:47	NFBC ISSUED
536	19-Feb-21	BAGALKOT	110	110/11KV, HV1	BAGALKOT_110	09:11	19:00	9:49	LINE CLEAR AVAILED
537	19-Feb-21	BAGALKOT	110	110/11KV, HV2	BAGALKOT_110	09:17	19:00	9:43	LINE CLEAR AVAILED
538	19-Feb-21	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	06:24	06:36	0:12	LINE FAULT
539	19-Feb-21	BAGALKOT	110	GAJENDRAGAD-KUSHTAGI220	STATION NOT AFFECTED GAJENDRAGAD_110	17:21	17:57	0:36	HAND TRIPPED
540	19-Feb-21	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA2	STATION NOT AFFECTED GHATAPRABHA_110	10:29	10:57	0:28	LINE FAULT
541	19-Feb-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED HIDAKALDAM_110, RUSTAMPUR_LIS_33, BGMWS1_33, BGMWS2&3_33	10:29	11:02	0:33	TRANSFORMER FAULT
542	19-Feb-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED HIDAKALDAM_110, RUSTAMPUR_LIS_33, BGMWS1_33, BGMWS2&3_33	13:46	15:40	1:54	LINE CLEAR AVAILED
543	19-Feb-21	BAGALKOT	110	HUKKERI-VSL IPP	STATION NOT AFFECTED HUKKERI_110, VSL IPP_110	6:47	7:06	0:19	LINE FAULT
544	19-Feb-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED KERUR_110	9:06	10:06	1:00	LINE CLEAR AVAILED
545	19-Feb-21	BAGALKOT	110	KUDACHI220- AINAPUR(KUDACHI)	AINAPUR_110	12:59	14:24	1:25	LINE CLEAR AVAILED
546	19-Feb-21	BAGALKOT	110	KUDACHI220-TERADAL	TERADAL_110	10:05	10:10	0:05	HAND TRIPPED
547	19-Feb-21	BAGALKOT	110	KUMTA-KARWAR	STATION NOT AFFECTED KUMTA_110	13:03	13:34	0:31	LINE CLEAR AVAILED
548	19-Feb-21	BAGALKOT	220	220/110KV, HV1&LV1	NO STATION AFFECTED VAJRAMATTI_220	11:03	13:38	2:35	LINE CLEAR AVAILED
549	19-Feb-21	BAGALKOT	110	SOUDATTI- ENERCON1	SOUDATTI_110	10:12	16:37	6:25	LINE CLEAR AVAILED
550	19-Feb-21	BAGALKOT	110	SOUDATTI- ENERCON2	SOUDATTI_110	16:41	18:57	2:16	LINE CLEAR AVAILED
551	19-Feb-21	BAGALKOT	110	110/11KV, HV1	SIRSI_110	10:09	14:27	4:18	LINE CLEAR AVAILED
552	19-Feb-21	BAGALKOT	110	SIRSI- KUMTA2	STATION NOT AFFECTED SIRSI_110	14:34	18:38	4:04	LINE FAULT
553	19-Feb-21	BAGALKOT	110	110/11KV, HV2	SHIROL_110	11:59	12:15	0:16	LINE CLEAR AVAILED
554	19-Feb-21	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:25	12:28	0:03	LINE CLEAR AVAILED
555	19-Feb-21	BAGALKOT	110	110/33KV, HV2	SAVALAGI_110, HIREPADASALAGI_33, KALABILAGI_33	11:05	11:49	0:44	LINE CLEAR AVAILED
556	19-Feb-21	BAGALKOT	110	SANKESHWAR-HUKKERI	SANKESHWAR_110,HUKKERI_110	06:39	06:44	0:05	HAND TRIPPED
557	19-Feb-21	BAGALKOT	110	110/11KV,HV1,LV1	NAVALAGUND_110	12:25	19:29	7:04	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
558	19-Feb-21	BAGALKOT	110	110/11KV,HV1	NARAGAL_110	08:56	09:05	0:09	TRANSFORMER FAULT
559	19-Feb-21	BAGALKOT	110	110/11KV,HV1	NARAGAL_110	15:19	16:30	1:11	LINE CLEAR AVAILED
560	19-Feb-21	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	17:29	18:36	1:07	LINE CLEAR AVAILED
561	19-Feb-21	BAGALKOT	110	MRUTHYUN-L1 NARENDRA	NO STATION AFFECTED MRUTHYANJANAGAR_110	14:53	16:59	2:06	NFBC ISSUED
562	19-Feb-21	BAGALKOT	110	MAHALINGPUR-TERDAL	NO STATION AFFECTED MAHALINGPUR_220	9:49 (19.02.2021)			LINE OPEN :LINE CLEAR AVAILED
563	19-Feb-21	BENGALURU	66	HV2	DOMMASANDRA	12:27	12:32	0:05	TRANSFORMER FAULT
564	19-Feb-21	BENGALURU	66	HV1	KOLAR 220	13:30	14:39	1:09	LINE CLEAR AVAILED
565	19-Feb-21	BENGALURU	66	HV2	KOLAR 220	13:30	14:39	1:09	LINE CLEAR AVAILED
566	19-Feb-21	BENGALURU	220	LV2	MALUR 220	18:33	18:50	0:17	TRANSFORMER FAULT
567	19-Feb-21	BENGALURU	66	HV2	SADLI	14:31	14:48	0:17	LINE CLEAR AVAILED
568	19-Feb-21	BENGALURU	66	HV2	SARJAPURA 220	18:24	19:00	0:36	MAIN SUPPLY FAILURE
569	19-Feb-21	BENGALURU	220	HV2	SARJAPURA 220	18:24	19:00	0:36	MAIN SUPPLY FAILURE
570	19-Feb-21	BENGALURU	66	HV1	SM MANGALA	8:59	10:47	1:47	LINE CLEAR AVAILED
571	19-Feb-21	BENGALURU	66	HV2	SM MANGALA	8:59	10:47	1:47	LINE CLEAR AVAILED
572	19-Feb-21	BENGALURU	66	HV2	TADIGOLU	8:10	8:59	0:49	LINE CLEAR AVAILED
573	19-Feb-21	BENGALURU	66	HV2	YELAHANKA 220	18:08	18:16	0:08	TRANSFORMER FAULT
574	19-Feb-21	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	16:03	16:23	0:19	LINE CLEAR AVAILED
575	19-Feb-21	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	0:09	0:19	0:10	LINE FAULT
576	19-Feb-21	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	8:08	8:30	0:22	LINE CLEAR AVAILED
577	19-Feb-21	BENGALURU	220	DEVANAHALLI HARDWARE PARK 220 - HOSKOTE 220	HOSKOTE 220	12:46	13:26	0:40	LINE FAULT
578	19-Feb-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	13:28	14:40	1:11	LINE CLEAR AVAILED
579	19-Feb-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	13:29	14:40	1:11	LINE CLEAR AVAILED
580	19-Feb-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	10:13	10:40	0:26	LOAD CURTAILMENT
581	19-Feb-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	13:30	14:41	1:10	LINE CLEAR AVAILED
582	19-Feb-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	13:28	14:30	1:02	LINE CLEAR AVAILED
583	19-Feb-21	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	13:29	14:40	1:11	LINE CLEAR AVAILED
584	19-Feb-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	13:29	14:40	1:11	LINE CLEAR AVAILED
585	19-Feb-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	13:28	14:40	1:11	LINE CLEAR AVAILED
586	19-Feb-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	13:33	14:40	1:07	LINE CLEAR AVAILED
587	19-Feb-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	9:35	10:05	0:30	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
588	19-Feb-21	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	13:30	14:39	1:09	LINE CLEAR AVAILED
589	19-Feb-21	BENGALURU	66	LAKSHMIPURA - CHINTA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	14:20	14:45	0:25	LINE FAULT
590	19-Feb-21	BENGALURU	66	LAKSHMIPURA - CHINTA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	15:05	15:20	0:15	LINE FAULT
591	19-Feb-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	18:33	18:54	0:21	LINE FAULT
592	19-Feb-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	20:37	20:51	0:14	LINE FAULT
593	19-Feb-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	18:33	18:55	0:22	MAIN SUPPLY FAILURE
594	19-Feb-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:02	9:14	0:11	LINE FAULT
595	19-Feb-21	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	18:21	18:42	0:21	LINE FAULT
596	19-Feb-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	18:23	18:53	0:30	LINE FAULT
597	19-Feb-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	18:24	19:01	0:37	MAIN SUPPLY FAILURE
598	19-Feb-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	18:24	19:04	0:40	MAIN SUPPLY FAILURE
599	19-Feb-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	18:23	19:03	0:39	MAIN SUPPLY FAILURE
600	19-Feb-21	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	18:21	18:59	0:38	MAIN SUPPLY FAILURE
601	19-Feb-21	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	17:56	18:10	2:27	LINE FAULT
602	19-Feb-21	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	17:25	17:50	0:25	MAIN SUPPLY FAILURE
603	19-Feb-21	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	21:12	21:15	0:03	LOAD CHANGE OVER
604	19-Feb-21	BENGALURU	66	B G ROAD - SOMANAHALLI 220	B G ROAD	17:09	17:14	0:05	LINE FAULT
605	19-Feb-21	BENGALURU	66	B G ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	17:09	17:19	0:10	LINE FAULT
606	19-Feb-21	BENGALURU	66	B G ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	17:19	17:55	0:36	LINE FAULT
607	19-Feb-21	BENGALURU	66	HV1	BOODIGERE	11:59	12:05	0:06	LINE CLEAR AVAILED
608	19-Feb-21	BENGALURU	66	HV2	BOODIGERE	18:29	18:35	0:06	TRANSFORMER FAULT
609	19-Feb-21	BENGALURU	66	HV2	BYDRAHALLI	12:54	12:56	0:02	LINE CLEAR AVAILED
610	19-Feb-21	BENGALURU	66	HV2	CHATRA	13:00	13:30	0:30	LINE CLEAR AVAILED
611	19-Feb-21	BENGALURU	66	HV1	ELECTRONIC CITY	17:12	17:17	0:05	TRANSFORMER FAULT
612	19-Feb-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	11:26	11:36	0:10	LINE CLEAR AVAILED
613	19-Feb-21	BENGALURU	66	HV1	NGEF	12:45	13:58	1:13	LINE CLEAR AVAILED
614	19-Feb-21	BENGALURU	66	SHOBHA FOREST - SUBRAMANYAPURA 220	SHOBHA FOREST	7:58	8:03	0:05	LOAD CHANGE OVER
615	19-Feb-21	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	17:54	18:53	0:59	LINE FAULT
616	19-Feb-21	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	18:53	20:18	1:25	LINE FAULT
617	19-Feb-21	BENGALURU	66	HV2	SRS PEENYA 220	10:19	10:23	0:04	LINE CLEAR AVAILED
618	19-Feb-21	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	17:25	17:50	0:25	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
619	19-Feb-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	20:55	21:10	0:15	LINE FAULT
620	19-Feb-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	17:09	18:04	0:55	LINE FAULT
621	19-Feb-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	23:24	23:50	0:26	LINE FAULT
622	19-Feb-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16-02-2021)			LINE OPEN: LINE FAULT
623	19-Feb-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	21:23 (19-2-2021)			LINE OPEN: LINE FAULT
624	19-Feb-21	BENGALURU	66	YELAHANKA 220 - LINE7	NO STATION AFFECTED	20:23 (19-2-2021)			LINE OPEN: LINE FAULT
625	19-Feb-21	GULBARGA	110	HATTI-SINDHANOOR	HATTI_110(NO EFFECTED STATION)	18:21(17.2.2021)			LINE OPEN :LINE CLEAR AVAILED
626	19-Feb-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	14:15(15.2.2021)			LINE OPEN :LINE CLEAR AVAILED
627	19-Feb-21	GULBARGA	110	SEDAM-VICATSAGAR CEMENT	VICATSAGAR CEMENT_110	6:45(19.2.2021)			LINE OPEN: LINE FAULT
628	19-Feb-21	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	18:20(19.2.2021)			LINE OPEN :LINE CLEAR AVAILED
629	19-Feb-21	GULBARGA	400	JSWL-GUTTUR	GUTTUR_400	11:37(18.02.2021)	10:21(19.02.2021)	22:44HRS	LINE CHARGED
630	19-Feb-21	GULBARGA	220	HV2	KAPNOOR_220	11:15	12:07	00:52	LINE CLEAR AVAILED
631	19-Feb-21	GULBARGA	220	SEADM - RTPS1,HUMNABAD2,TANDUR(IDLE),ORIENT CEMENT,SHREE CEMENT	SEDAM_220	06:45	10:57	04:12	LINE FAULT
632	19-Feb-21	GULBARGA	220	SEDAM-TANDUR(IDEL)	SEDAM_220	06:45	23:37	16:52	LINE FAULT
633	19-Feb-21	GULBARGA	220	HV1	SEDAM_220	10:59	11:37	00:38	TRANSFORMER FAULT
634	19-Feb-21	GULBARGA	220	HV1	SEDAM_220	13:50	13:55	00:05	TRANSFORMER FAULT
635	19-Feb-21	GULBARGA	110	KUSHTAGI-BEVOOR	BEVOOR_110	13:40	16:00	02:20	MAIN SUPPLY FAILURE
636	19-Feb-21	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	09:35	09:40	00:05	LINE FAULT
637	19-Feb-21	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	03:30	11:45	08:15	MAIN SUPPLY FAILURE
638	19-Feb-21	GULBARGA	110	SINDHANOOR-RAICHUR1	MASKI_110,MUDDAPUR_110	15:30(14.02.2021)	16:15(19.02.2021)	120:45 HRS	LINE CHARGED
639	19-Feb-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADAVIAMARESHWAR_110	15:05(14.02.2021)	17:05(19.02.2021)	122:00 HRS	LINE CHARGED
640	19-Feb-21	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERADONA_110,SRNAGAR_110	01:10	01:25	00:15	LINE FAULT
641	19-Feb-21	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	06:48	12:20	05:32	LINE CLEAR AVAILED
642	19-Feb-21	GULBARGA	110	JANAWADA-SANTHPUR	SANTHPUR_110	14:05	14:55	00:50	LINE CLEAR AVAILED
643	19-Feb-21	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	18:35	18:45	00:10	LINE FAULT
644	19-Feb-21	GULBARGA	110	HV3	GINIGERA_110	15:16	19:09	03:53	LINE CLEAR AVAILED
645	19-Feb-21	GULBARGA	110	HV2	GINIGERA_110	08:35	19:14	10:39	LINE CLEAR AVAILED
646	19-Feb-21	GULBARGA	110	HV3	HALIKHED_110	18:15	18:32	00:17	TRANSFORMER FAULT
647	19-Feb-21	GULBARGA	110	HV1	KUDITINI_110	09:05	10:09	01:04	TRANSFORMER FAULT
648	19-Feb-21	GULBARGA	110	HV1	KUDITINI_110	10:13	10:18	00:05	TRANSFORMER FAULT
649	19-Feb-21	GULBARGA	110	HV1	METRI_110	14:35	14:56	00:21	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
650	19-Feb-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADAVIAMARESHWAR_110	20:24	20:45	00:21	LINE FAULT
651	19-Feb-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERADONA_110,SRNAGAR_110	20:57	21:15	00:18	LINE FAULT
652	19-Feb-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERADONA_110,SRNAGAR_110	21:45	21:58	00:13	LINE FAULT
653	19-Feb-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
654	19-Feb-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
655	19-Feb-21	HASSAN	110	HV2	PUTTUR_110	16:34(18.2.2021)			LINE OPEN :LINE CLEAR AVAILED
656	19-Feb-21	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	22:45(18.2.2021)	8:47 (19.02.2021)	10:02hrs	LINE CHARGED
657	19-Feb-21	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	22:45(18.2.2021)	8:47 (19.02.2021)	10:02hrs	LINE CHARGED
658	19-Feb-21	HASSAN	66	HNPR2-HASS2	HOLENARSIPURA_220	22:29(19.2.2021)			LINE OPEN: LINE FAULT
659	19-Feb-21	HASSAN	220	ARSK2-HSN	ARASIKERE_220	09:44	14:01	04:17	LINE CLEAR AVAILED
660	19-Feb-21	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	16:09	19:25	03:16	LINE FAULT
661	19-Feb-21	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	18:10	19:10	01:00	LINE FAULT
662	19-Feb-21	HASSAN	220	VARAH1-SHMG3	varahi_gen	18:10	19:11	01:01	LINE FAULT
663	19-Feb-21	HASSAN	110	HV2	PUTTUR_110	16:02	16:50	00:48	LINE CLEAR AVAILED
664	19-Feb-21	HASSAN	110	KADUR-AJAMPURA	KADUR_220	10:46	10:51	00:05	HAND TRIPPED
665	19-Feb-21	HASSAN	110	KADUR-NGNHL	KADUR_220	11:02	11:21	00:19	LINE CLEAR AVAILED
666	19-Feb-21	HASSAN	110	KADUR-NGNHL	KADUR_220	12:17	13:06	00:49	LINE CLEAR AVAILED
667	19-Feb-21	HASSAN	110	HV1	SINGATGERE_110	15:13	17:15	02:02	LINE CLEAR AVAILED
668	19-Feb-21	HASSAN	66	HV1	DUDDA_66	12:00	13:00	01:00	LINE CLEAR AVAILED
669	19-Feb-21	HASSAN	66	HV2	DUDDA_66	11:20	12:20	01:00	LINE CLEAR AVAILED
670	19-Feb-21	HASSAN	66	GANGUR-HASSAN	GANGUR_66	10:53	16:00	05:07	MAIN SUPPLY FAILURE
671	19-Feb-21	HASSAN	66	HV1	GANGUR_66	10:53	15:59	05:06	MAIN SUPPLY FAILURE
672	19-Feb-21	HASSAN	66	HAGARE-HASSAN	HAGARE_66	10:48	16:07	05:19	NFBC ISSUED
673	19-Feb-21	HASSAN	66	HV1	HAGARE_66	10:48	16:07	05:19	NFBC ISSUED
674	19-Feb-21	HASSAN	66	HV1	HALEBEEDU_66	10:45	17:00	06:15	LINE CLEAR AVAILED
675	19-Feb-21	HASSAN	66	HV2	HALEBEEDU_66	10:45	17:00	06:15	LINE CLEAR AVAILED
676	19-Feb-21	HASSAN	66	HNPR2-HASS2	HOLENARSIPURA_220	17:37	17:53	00:16	LINE FAULT
677	19-Feb-21	HASSAN	66	HNPR2-HASS2	HOLENARSIPURA_220	19:05	19:23	00:18	LINE FAULT
678	19-Feb-21	HASSAN	66	HNPR2-HASS2	HOLENARSIPURA_220	19:24	20:01	00:37	HAND TRIPPED
679	19-Feb-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	16:59	17:20	00:21	LINE FAULT
680	19-Feb-21	HASSAN	66	HV1	MALALI_66	17:37	19:39	02:02	MAIN SUPPLY FAILURE
681	19-Feb-21	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	09:46	10:15	00:29	LINE CLEAR AVAILED
682	19-Feb-21	HASSAN	66	SHANTHI-MALALI	SHANTHIGRAMA_66	10:15	17:44	07:29	LINE CLEAR AVAILED
683	19-Feb-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	08:46	08:51	00:05	LINE FAULT
684	19-Feb-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	12:25	13:10	00:45	LINE FAULT
685	19-Feb-21	HASSAN	66	HV2	UDAYAPURA_66	10:45	10:50	00:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
686	19-Feb-21	MYSURU	66	HV1	AKKIHEBBAL_66	14:28	15:20	0:52	LINE CLEAR AVAILED
687	19-Feb-21	MYSURU	66	CHINAKURALI-BOOKANAKERE	NO STATION EFFECTED	10:13	19:36	9:22	LINE CLEAR AVAILED
688	19-Feb-21	MYSURU	66	HV1	CHANDAKAVADI_66	16:32	16:44	0:11	TRANSFORMER FAULT
689	19-Feb-21	MYSURU	66	HV1	CHANDAKAVADI_66	16:47	17:32	0:45	TRANSFORMER FAULT
690	19-Feb-21	MYSURU	66	CR NAGARA-HONNALLI	ATTIGULIPURA_66 HONNALLY MYS 66	16:06	16:12	0:05	LINE FAULT
691	19-Feb-21	MYSURU	66	HV1	DEVANOORNGUDU_66	12:35	12:39	0:03	TRANSFORMER FAULT
692	19-Feb-21	MYSURU	66	KM DODDI-TK HALLI	K_HONNALLGERE_66 KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	18:15	18:27	0:12	LINE FAULT
693	19-Feb-21	MYSURU	66	KM DODDI-TK HALLI	NO STATION EFFECTED	20:54	21:07	0:12	LINE FAULT
694	19-Feb-21	MYSURU	220	KR PETE 220-TUBINAKERE	K_HONNALLGERE_66 KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	10:21	19:31	9:10	NFBC ISSUED
695	19-Feb-21	MYSURU	66	KK HALLI-SHIMSHA-1(MALAVALLI)	HADLI_66 MALAVALLI_66	21:15	21:25	0:10	LINE FAULT
696	19-Feb-21	MYSURU	66	HV1	MALAVALLI_66	7:15	7:20	0:04	TRANSFORMER FAULT
697	19-Feb-21	MYSURU	66	HV1	MALAVALLI_66	10:26	18:52	8:25	LINE CLEAR AVAILED
698	19-Feb-21	MYSURU	66	HV2	MALAVALLI_66	10:26	18:52	8:25	LINE CLEAR AVAILED
699	19-Feb-21	MYSURU	66	SHANIVARASANTHE-HV1	SANIVARASANTHE_66	16:57	17:20	0:23	LINE CLEAR AVAILED
700	19-Feb-21	MYSURU	66	SHANIVARASANTHE-HV1	SANIVARASANTHE_66	17:48	17:52	0:04	LINE FAULT
701	19-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	15:15	15:16	0:01	HAND TRIPPED
702	19-Feb-21	MYSURU	66	SFC SIVA-HABBANI 2	NO STATION EFFECTED	15:16	15:17	0:01	HAND TRIPPED
703	19-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 6	NO STATION EFFECTED	15:17	15:18	0:01	HAND TRIPPED
704	19-Feb-21	MYSURU	66	SFC SIVA-HABBANI 7	NO STATION EFFECTED	15:18	15:19	0:01	HAND TRIPPED
705	19-Feb-21	MYSURU	66	SFC SIVA-HABBANI 8	NO STATION EFFECTED	15:19	15:20	0:01	HAND TRIPPED
706	19-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 9	NO STATION EFFECTED	15:19	15:20	0:01	HAND TRIPPED
707	19-Feb-21	MYSURU	66	SFC SIVA-HABBANI 2	NO STATION EFFECTED	17:38	17:42	0:04	HAND TRIPPED
708	19-Feb-21	MYSURU	66	HV2	TERAKANAMBE_66	11:01	13:16	2:14	LINE CLEAR AVAILED
709	19-Feb-21	MYSURU	66	TALAGAVADI-MANDYA	TALAGAVADI_66	18:15	18:40	0:25	LINE FAULT
710	19-Feb-21	MYSURU	66	TALAGAVADI-MANDYA	TALAGAVADI_66	20:55	21:15	0:20	LINE FAULT
711	19-Feb-21	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN :LINE CLEAR AVAILED
712	19-Feb-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	8:43:57 PM(18.02.2021)	12:37:00 PM(19.02.2021)		LINE OPEN :LINE CLEAR AVAILED
713	19-Feb-21	TUMKUR	220	TR-2	ANCHEPALYA_220	8:46	10:29	1:43	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
714	19-Feb-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	9:19	12:34	3:15	LINE CLEAR AVAILED
715	19-Feb-21	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	9:44	14:00	4:15	LINE CLEAR AVAILED
716	19-Feb-21	TUMKUR	220	TR-1	NITTUR_220	11:55	15:13	3:18	LINE CLEAR AVAILED
717	19-Feb-21	TUMKUR	220	TR-2	NITTUR_220	16:22	19:29	3:06	LINE CLEAR AVAILED
718	19-Feb-21	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	14:50	17:31	2:40	LINE CLEAR AVAILED
719	19-Feb-21	TUMKUR	110	TR-2	BANDIHALLI_110	11:11	12:09	0:57	LINE CLEAR AVAILED
720	19-Feb-21	TUMKUR	110	TR-1	KBCROSS_220	9:34	9:52	0:18	HAND TRIPPED
721	19-Feb-21	TUMKUR	110	TR-1(LV SIDE)	NITTUR_220	11:55	15:14	3:18	LINE CLEAR AVAILED
722	19-Feb-21	TUMKUR	110	TR-2(LV SIDE)	NITTUR_220	16:23	19:31	3:07	LINE CLEAR AVAILED
723	19-Feb-21	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	13:17	13:27	0:09	LINE FAULT
724	19-Feb-21	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENHALLI_66	10:26	10:37	0:10	HAND TRIPPED
725	19-Feb-21	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	10:07	10:36	0:28	HAND TRIPPED
726	19-Feb-21	TUMKUR	66	TR-2(LV SIDE)	ANCHEPALYA_220	8:46	10:34	1:48	LINE CLEAR AVAILED
727	19-Feb-21	TUMKUR	66	CHITRADURGA 220kV- HGML	HGML_IPP_66	9:39	10:04	0:25	LINE FAULT
728	19-Feb-21	TUMKUR	66	CHITRADURGA 220kV- HGML	HGML_IPP_66	10:08	10:41	0:32	LINE FAULT
729	19-Feb-21	TUMKUR	66	CHITRADURGA 220kV- HGML	HGML_IPP_66	11:30	11:40	0:10	LINE FAULT
730	19-Feb-21	TUMKUR	66	CHITRADURGA 220kV- HGML	HGML_IPP_66	13:57	14:26	0:29	LINE FAULT
731	19-Feb-21	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	1:20	8:29	7:09	LINE FAULT
732	19-Feb-21	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 2	CHITRADURGA_66	1:20	2:19	0:59	LINE FAULT
733	19-Feb-21	TUMKUR	66	DYAVARANAHALLI-THALLAK	DYAVARANAHALLI_66	11:05	12:06	1:00	LINE CLEAR AVAILED
734	19-Feb-21	TUMKUR	66	TR-2	HARAPPANAHALLI_66	11:00	12:14	1:14	LINE CLEAR AVAILED
735	19-Feb-21	TUMKUR	66	HIREGUNTANUR- CHITRADURGA	HIREGUNTANUR_66	17:20	18:16	0:55	LINE CLEAR AVAILED
736	19-Feb-21	TUMKUR	66	TR-1	HIREGUNTANUR_66	16:51	18:16	1:25	LINE CLEAR AVAILED
737	19-Feb-21	TUMKUR	66	TR-2	HIREGUNTANUR_66	2:43	10:30	7:47	LINE CLEAR AVAILED
738	19-Feb-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:17	16:29	0:11	LINE FAULT
739	19-Feb-21	TUMKUR	66	TR-1	KUKKAWADA_66	6:07	6:17	0:10	TRANSFORMER FAULT
740	20-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
741	20-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN :LINE CLEAR AVAILED
742	20-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
743	20-Feb-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
744	20-Feb-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
745	20-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN :LINE CLEAR AVAILED
746	20-Feb-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN :LINE CLEAR AVAILED
747	20-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN :LINE CLEAR AVAILED
748	20-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN :LINE CLEAR AVAILED
749	20-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN :LINE CLEAR AVAILED
750	20-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
751	20-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
752	20-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN :LINE CLEAR AVAILED
753	20-Feb-21	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN :LINE CLEAR AVAILED
754	20-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN :LINE CLEAR AVAILED
755	20-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN :LINE CLEAR AVAILED
756	20-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN :LINE CLEAR AVAILED
757	20-Feb-21	BAGALKOT	220	RANEENNUR- SHIRALKOPPA(BELLIGAVI)	STATION NOT AFFECTED RANEENNUR_220	23:41 (15.02.2021)	16:01 (20.02.2021)	112:20HRS	LINE CHARGED
758	20-Feb-21	BAGALKOT	220	MAHALINGAPUR-ATHANI	STATION NOT AFFECTED MAHALINGAPUR_220	10:21 (17.02.2021)	14:02 (20.02.2021)	75:41HRS	LINE CHARGED
759	20-Feb-21	BAGALKOT	220	MAHALINGAPUR-KUDACHI	STATION NOT AFFECTED MAHALINGAPUR_220	10:33 (17.02.2021)	14:02 (20.02.2021)	75:33hrs	LINE CHARGED
760	20-Feb-21	BAGALKOT	220	KUDACHI-MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	10:33 (17.02.2021)	14:05 (20.02.2021)	75:32hrs	LINE CHARGED
761	20-Feb-21	BAGALKOT	220	BELGAUM-KANABARGI2	STATION NOT AFFECTED BELGAUM_220	21:04 (19.02.2021)	8:04 (20.02.2021)	11:00hrs	LINE CHARGED
762	20-Feb-21	BAGALKOT	110	MAHALINGPUR-TERDAL	NO STATION AFFECTED MAHALINGPUR_220	9:49 (19.02.2021)	14:25 (20.02.2021)	28:46hrs	LINE CHARGED
763	20-Feb-21	BAGALKOT	110	110/11KV,HV1	ALBAL_110	11:43	15:35	3:52	LINE CLEAR AVAILED
764	20-Feb-21	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	02:44	23:07	20:23	LINE FAULT
765	20-Feb-21	BAGALKOT	110	ATHANI220-HALIYAL	STATION NOT AFFECTED ATHANI_220	11:39	17:59	6:20	LINE CLEAR AVAILED
766	20-Feb-21	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	06:32	06:41	0:09	LINE FAULT
767	20-Feb-21	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	11:10	12:37	1:27	LINE CLEAR AVAILED
768	20-Feb-21	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	16:15 (20.02.2021)			LINE OPEN: LINE FAULT
769	20-Feb-21	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	14:55	15:03	0:08	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
770	20-Feb-21	BAGALKOT	220	NARENDRA-HUBLI1	STATION NOT AFFECTED NARENDRA_220	16:14 (20.02.2021)			LINE OPEN: LINE FAULT
771	20-Feb-21	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	02:45	23:07	20:22	LINE FAULT
772	20-Feb-21	BAGALKOT	66	66/11KV, HV2	HARIHAR HOSPET_66	19:07	19:11	0:04	TRANSFORMER FAULT
773	20-Feb-21	BAGALKOT	66	66/33KV, HV4	HARIHAR HOSPET_66	19:07	19:12	0:05	TRANSFORMER FAULT
774	20-Feb-21	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	18:51	18:58	00:07	LOAD CHANGE OVER
775	20-Feb-21	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, BIEC, NELAMANGALA 66	09:11	11:56	02:45	MAIN SUPPLY FAILURE
776	20-Feb-21	BENGALURU	66	BRIGADE MEADOWS - SUBRAMANYAPURA 220	BRIGADE MEADOWS	07:59	08:03	00:04	LOAD CHANGE OVER
777	20-Feb-21	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	10:03	16:43	06:40	LINE CLEAR AVAILED
778	20-Feb-21	BENGALURU	66	HV2	HOODY 220	10:17	10:19	00:02	LINE CLEAR AVAILED
779	20-Feb-21	BENGALURU	66	HV1	HSR LAYOUT 220	14:09	14:26	00:17	TRANSFORMER FAULT
780	20-Feb-21	BENGALURU	66	HV2	HSR LAYOUT 220	17:50	18:30	00:40	TRANSFORMER FAULT
781	20-Feb-21	BENGALURU	66	KODIGEHALLI - BYDRAHALI	KODIGEHALLI, TAVAREKERE	17:00	17:20	00:20	LINE FAULT
782	20-Feb-21	BENGALURU	66	HV2	PADMANABHANAGARA	10:49	10:52	00:03	LINE CLEAR AVAILED
783	20-Feb-21	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	16:47	17:06	00:19	LOAD CHANGE OVER
784	20-Feb-21	BENGALURU	66	HV2	REMCO	16:40	16:51	00:11	MAIN SUPPLY FAILURE
785	20-Feb-21	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	22:19	22:24	00:05	LOAD CHANGE OVER
786	20-Feb-21	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	REMCO, GLOBAL VILLAGE (EHT)	16:40	16:51	00:11	LINE FAULT
787	20-Feb-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	10:33	11:13	00:40	LINE FAULT
788	20-Feb-21	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	09:13	09:32	00:19	LOAD CHANGE OVER
789	20-Feb-21	BENGALURU	66	ALUR - NEMANGALA 66	ALUR	11:26	11:58	00:32	LOAD CHANGE OVER
790	20-Feb-21	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	17:38	18:39	01:01	LINE FAULT
791	20-Feb-21	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	18:02	18:11	00:09	LOAD CHANGE OVER
792	20-Feb-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	16:50	17:20	00:29	LINE FAULT
793	20-Feb-21	BENGALURU	66	HV1	SM MANGALA	07:17	10:33	03:15	LINE CLEAR AVAILED
794	20-Feb-21	BENGALURU	66	HV2	SM MANGALA	07:18	10:33	03:15	LINE CLEAR AVAILED
795	20-Feb-21	BENGALURU	66	HV1	ALUR	15:31	16:30	00:58	LINE CLEAR AVAILED
796	20-Feb-21	BENGALURU	66	HV1	CHANDAPURA	11:50	12:13	00:23	LINE CLEAR AVAILED
797	20-Feb-21	BENGALURU	66	HV1	MITTEMARI 220	20:04	20:15	00:11	TRANSFORMER FAULT
798	20-Feb-21	BENGALURU	66	HV1	MITTEMARI 220	22:20	22:25	00:05	TRANSFORMER FAULT
799	20-Feb-21	BENGALURU	66	HV1	SM MANGALA	07:17	10:33	03:15	LINE CLEAR AVAILED
800	20-Feb-21	BENGALURU	66	HV2	SM MANGALA	07:18	10:33	03:15	LINE CLEAR AVAILED
801	20-Feb-21	BENGALURU	66	SADLI - MITTEMARI 220	SADLI	03:30	03:35	00:05	LINE CLEAR AVAILED
802	20-Feb-21	BENGALURU	66	SADLI - MITTEMARI 220	SADLI	01:20	01:40	00:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
803	20-Feb-21	BENGALURU	220	HV1	YARANDANAHALLI	10:30	11:10	00:40	TRANSFORMER FAULT
804	20-Feb-21	BENGALURU	66	HV2	YARANDANAHALLI	10:30	11:12	00:42	LINE CLEAR AVAILED
805	20-Feb-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
806	20-Feb-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	21:23 (19-2-2021)	0:16(20.02.21)	2:52hrs	LINE CHARGED
807	20-Feb-21	BENGALURU	66	YELAHANKA 220 - LINE7	NO STATION AFFECTED	20:23 (19-2-2021)	0:24(20.02.21)	4:00HRS	LINE CHARGED
808	20-Feb-21	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	18:20(19.2.2021)			LINE OPEN :LINE CLEAR AVAILED
809	20-Feb-21	GULBARGA	220	HV2	SHAHAPUR_220	12:50	16:10	03:20	LINE CLEAR AVAILED
810	20-Feb-21	GULBARGA	110	HATTI-SINDHANOOR	HATTI_110(NO EFFECTED STATION)	18:21(17.2.2021)	23:25(21.02.2021)	76:14HRS	LINE CHARGED
811	20-Feb-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	14:15(15.2.2021)			LINE OPEN :LINE CLEAR AVAILED
812	20-Feb-21	GULBARGA	110	SEDAM-VICATSAGAR CEMENT	VICATSAGAR CEMENT_110	6:45(19.2.2021)	17:18(20.02.2021)	10:33hrs	LINE CHARGED
813	20-Feb-21	GULBARGA	110	HV1	GINIGERA_110	09:00	18:15	09:15	LINE CLEAR AVAILED
814	20-Feb-21	GULBARGA	110	HV2	SINDHANOOR_110	09:35	09:45	00:10	TRANSFORMER FAULT
815	20-Feb-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	15:15	15:25	00:10	LINE FAULT
816	20-Feb-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	05:38	05:44	00:06	LINE FAULT
817	20-Feb-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	06:03	06:11	00:08	LINE FAULT
818	20-Feb-21	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110	18:36	18:56	00:20	LINE FAULT
819	20-Feb-21	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110	18:58	19:20	00:22	LINE FAULT
820	20-Feb-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	09:20	18:25	09:05	LINE CLEAR AVAILED
821	20-Feb-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERADONA_110,SRNAGAR_110	19:05	19:15	00:10	LINE FAULT
822	20-Feb-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERADONA_110,SRNAGAR_110	22:00	22:10	00:10	LINE FAULT
823	20-Feb-21	GULBARGA	66	HV1	HAMPASAGAR	12:25	12:45	00:20	TRANSFORMER FAULT
824	20-Feb-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
825	20-Feb-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
826	20-Feb-21	HASSAN	66	HNPR2-HASS2	HOLENARSIPURA_220	22:29(19.2.2021)	14:35 (20.02.2021)	16:05 hrs	LINE CHARGED
827	20-Feb-21	HASSAN	220	KADUR-DABUSET	KADUR_220	11:15	17:35	06:20	LINE CLEAR AVAILED
828	20-Feb-21	HASSAN	220	KEMAR-Varahi2	KEMAR_220	12:46	16:42	03:56	LINE FAULT
829	20-Feb-21	HASSAN	220	MRSSH-M-DAVANGERE	MRSMSG_220	09:36	13:21	03:45	LINE CLEAR AVAILED
830	20-Feb-21	HASSAN	220	MRSSH-M-VARAH13	MRSMSG_220	07:44	09:11	01:27	LINE FAULT
831	20-Feb-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	12:46	16:42	03:56	LINE FAULT
832	20-Feb-21	HASSAN	220	VARAHI-SHMG3	varahi_gen	07:44	09:11	01:27	LINE FAULT
833	20-Feb-21	HASSAN	110	ARSK2-GERUMARA	ARASIKERE_220	14:32	14:41	00:09	HAND TRIPPED
834	20-Feb-21	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	09:23	15:10	05:47	LINE CLEAR AVAILED
835	20-Feb-21	HASSAN	110	HV1	KALLUSADARAHALLY_110	12:16	13:57	01:41	LINE CLEAR AVAILED
836	20-Feb-21	HASSAN	110	HV2	KONAJE_110	10:48	10:57	00:09	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
837	20-Feb-21	HASSAN	110	HV1	NAVUNDA_110	15:50	15:56	00:06	TRANSFORMER FAULT
838	20-Feb-21	HASSAN	110	HV3	SAGARA_110	11:05	14:21	03:16	LINE CLEAR AVAILED
839	20-Feb-21	HASSAN	110	HV2	SAGARA_110	15:06	19:02	03:56	LINE CLEAR AVAILED
840	20-Feb-21	HASSAN	66	HV1	ALDUR_66	09:46	09:59	00:13	LINE CLEAR AVAILED
841	20-Feb-21	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	16:16	16:34	00:18	LINE FAULT
842	20-Feb-21	HASSAN	66	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	10:00	11:12	01:12	LINE CLEAR AVAILED
843	20-Feb-21	HASSAN	66	DUDDA-CKNDGL	DUDDA_66	10:06	11:13	01:07	LINE CLEAR AVAILED
844	20-Feb-21	HASSAN	66	HV1	DUDDA_66	11:07	11:25	00:18	LINE CLEAR AVAILED
845	20-Feb-21	HASSAN	66	MALALI-CRPATNA	MALALI_66	10:32	11:45	01:13	MAIN SUPPLY FAILURE
846	20-Feb-21	HASSAN	66	MALALI-CRPATNA	MALALI_66	13:45	14:57	01:12	MAIN SUPPLY FAILURE
847	20-Feb-21	HASSAN	66	MALALI-HASSAN	MALALI_66	08:40	10:35	01:55	NFBC ISSUED
848	20-Feb-21	HASSAN	66	MALALI-HASSAN	MALALI_66	13:00	14:30	01:30	NFBC ISSUED
849	20-Feb-21	HASSAN	66	HV1	MALALI_66	09:18	12:01	02:43	MAIN SUPPLY FAILURE
850	20-Feb-21	HASSAN	66	HV1	MALALI_66	13:40	14:37	00:57	MAIN SUPPLY FAILURE
851	20-Feb-21	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	13:39	14:06	00:27	HAND TRIPPED
852	20-Feb-21	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	14:50	15:11	00:21	HAND TRIPPED
853	20-Feb-21	HASSAN	66	HV1	SAKLESH PURA_66	12:33	12:48	00:15	TRANSFORMER FAULT
854	20-Feb-21	HASSAN	66	HV1	SHANTHIGRAMMA_66	23:43	23:59	00:16	TRANSFORMER FAULT
855	20-Feb-21	HASSAN	66	HV2	SHANTHIGRAMMA_66	23:43	23:59	00:16	TRANSFORMER FAULT
856	20-Feb-21	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHIGRAMMA_66	13:40	14:05	00:25	MAIN SUPPLY FAILURE
857	20-Feb-21	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHIGRAMMA_66	14:48	15:10	00:22	HAND TRIPPED
858	20-Feb-21	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	09:25	11:35	02:10	LINE CLEAR AVAILED
859	20-Feb-21	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	14:38	14:57	00:19	HAND TRIPPED
860	20-Feb-21	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	23:43	23:59	00:16	LINE FAULT
861	20-Feb-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	12:58	13:11	00:13	LINE FAULT
862	20-Feb-21	MYSURU	66	HV2	AKKIEBBAL_66	17:51	18:04	0:12	TRANSFORMER FAULT
863	20-Feb-21	MYSURU	66	HV1	BANNUR_66	10:23	17:55	7:31	LINE CLEAR AVAILED
864	20-Feb-21	MYSURU	66	HV2	BANNUR_66	10:23	17:55	7:32	LINE CLEAR AVAILED
865	20-Feb-21	MYSURU	66	BANNUR-MALIYURU	BANNUR_66	10:31	17:50	7:18	LINE CLEAR AVAILED
866	20-Feb-21	MYSURU	66	BANNUR-VAJAMANGALA	BANNUR_66	10:31	17:50	7:18	LINE CLEAR AVAILED
867	20-Feb-21	MYSURU	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	4:19	4:54	0:34	LINE FAULT
868	20-Feb-21	MYSURU	66	DEVNUR(MYS)-RAJEEV NAGARA	RAJEEVNAGARA_66	10:10	17:29	7:18	NFBC ISSUED
869	20-Feb-21	MYSURU	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66 AJJIPURA_66	11:30	11:44	0:13	LINE CLEAR AVAILED
870	20-Feb-21	MYSURU	66	HV1	HANNUR_66	11:20	11:24	0:04	HAND TRIPPED
871	20-Feb-21	MYSURU	66	HV1	HONNALLY_MYS_66	16:30	16:35	0:04	HAND TRIPPED
872	20-Feb-21	MYSURU	220	HOOTAGALLY-KADAKOLA	NO STATION EFFECTED	9:01	11:52	2:51	LINE CLEAR AVAILED
873	20-Feb-21	MYSURU	66	HV1	HUNSUR_66	14:17	15:01	0:43	LINE CLEAR AVAILED
874	20-Feb-21	MYSURU	66	HV3	KUSHALANAGARA_66	13:30	16:01	2:31	LINE CLEAR AVAILED
875	20-Feb-21	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATION EFFECTED	11:02	14:08	3:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
876	20-Feb-21	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATION EFFECTED	12:11	14:24	2:13	LINE CLEAR AVAILED
877	20-Feb-21	MYSURU	66	MADHUVANAHALLI-HANNUR 1	NO STATION EFFECTED	9:06	13:22	4:16	LINE CLEAR AVAILED
878	20-Feb-21	MYSURU	66	MADHUVANAHALLI-HANNUR 2	NO STATION EFFECTED	14:26	15:34	1:08	LINE CLEAR AVAILED
879	20-Feb-21	MYSURU	66	MADHUVANAHALLI-KOLLEGALA 1	NO STATION EFFECTED	11:34	14:23	2:48	LINE CLEAR AVAILED
880	20-Feb-21	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	7:32	7:38	0:05	LINE FAULT
881	20-Feb-21	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	10:00	13:41	3:40	LINE CLEAR AVAILED
882	20-Feb-21	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATION EFFECTED	12:44	14:54	2:10	LINE CLEAR AVAILED
883	20-Feb-21	MYSURU	66	MADHUVANAHALLI-DODDINDHUVADI	NO STATION EFFECTED	10:31	14:53	4:21	LINE CLEAR AVAILED
884	20-Feb-21	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN :LINE CLEAR AVAILED
885	20-Feb-21	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	9:29	13:32	4:03	LINE CLEAR AVAILED
886	20-Feb-21	TUMKUR	220	HONNALLI 220kv- DAVANAGERE 220kv	HONNALLI_220	9:13	14:21	5:07	LINE CLEAR AVAILED
887	20-Feb-21	TUMKUR	220	TR-1(HV SIDE)	MADHUGIRI_220	14:58	17:17	2:18	TRANSFORMER FAULT
888	20-Feb-21	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	10:24	15:42	5:18	TRANSFORMER FAULT
889	20-Feb-21	TUMKUR	110	TR-1	HANDANKERE_110	1:21	1:59	0:38	TRANSFORMER FAULT
890	20-Feb-21	TUMKUR	110	TR-2	NITTUR_220	11:23	14:52	3:28	LINE CLEAR AVAILED
891	20-Feb-21	TUMKUR	66	ANCHEPALYA 220kv- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	3:22	3:37	0:14	LINE FAULT
892	20-Feb-21	TUMKUR	66	TR-2	CHIKKABANAGERE_66	13:47	14:23	0:36	TRANSFORMER FAULT
893	20-Feb-21	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	9:03	9:10	0:06	HAND TRIPPED
894	20-Feb-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:03	18:57	9:53	LINE CLEAR AVAILED
895	20-Feb-21	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:03	18:57	9:54	LINE CLEAR AVAILED
896	20-Feb-21	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	5:54	6:46	0:52	MAIN SUPPLY FAILURE
897	20-Feb-21	TUMKUR	66	HANAGAL- THALLAK	HANAGAL_66	11:41	11:45	0:03	LINE FAULT
898	20-Feb-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:37	11:48	0:10	LINE FAULT
899	20-Feb-21	TUMKUR	66	TR-1	KATTIGE_66	11:55	14:07	2:11	LINE CLEAR AVAILED
900	20-Feb-21	TUMKUR	66	TR-1	KORA_66	12:34	12:38	0:04	TRANSFORMER FAULT
901	20-Feb-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:14	19:02	9:48	LINE CLEAR AVAILED
902	20-Feb-21	TUMKUR	66	TR-1	KUKKAWADA_66	9:36	19:01	9:25	LINE CLEAR AVAILED
903	20-Feb-21	TUMKUR	66	TR-2	KUKKAWADA_66	9:36	19:03	9:27	LINE CLEAR AVAILED
904	20-Feb-21	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	9:12	19:00	9:47	LINE CLEAR AVAILED
905	20-Feb-21	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	21:59	22:19	0:20	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
906	20-Feb-21	TUMKUR	66	TR-1(LV SIDE)	MADHUGIRI_220	14:58	17:17	2:18	LINE CLEAR AVAILED
907	20-Feb-21	TUMKUR	66	TR-2	MATHOD_66	10:26	10:36	0:10	TRANSFORMER FAULT
908	20-Feb-21	TUMKUR	66	TR-1	TAVAREKERE(C)_66	14:49	14:53	0:04	TRANSFORMER FAULT
909	21-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
910	21-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN :LINE CLEAR AVAILED
911	21-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
912	21-Feb-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
913	21-Feb-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
914	21-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN :LINE CLEAR AVAILED
915	21-Feb-21	BAGALKOT	110	KANABARGI LAYOUT-NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN :LINE CLEAR AVAILED
916	21-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN :LINE CLEAR AVAILED
917	21-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN :LINE CLEAR AVAILED
918	21-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN :LINE CLEAR AVAILED
919	21-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
920	21-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
921	21-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN :LINE CLEAR AVAILED
922	21-Feb-21	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN :LINE CLEAR AVAILED
923	21-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN :LINE CLEAR AVAILED
924	21-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN :LINE CLEAR AVAILED
925	21-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN :LINE CLEAR AVAILED
926	21-Feb-21	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	16:15 (20.02.2021)	15:39 (21.02.2021)	23:24hra	LINE CHARGED
927	21-Feb-21	BAGALKOT	220	NARENDRA-HUBLI1	STATION NOT AFFECTED NARENDRA_220	16:14 (20.02.2021)	15:36 (21.02.2021)	23:20hrs	LINE CHARGED
928	21-Feb-21	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	00:14 (21.02.2021)			LINE OPEN: LINE FAULT
929	21-Feb-21	BAGALKOT	110	110/11KV,HV3	BAILHONGAL_110	13:22	13:40	0:18	HAND TRIPPED
930	21-Feb-21	BAGALKOT	110	110/11KV,HV3	GHATAPRABHA_110	11:00	11:51	0:51	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
931	21-Feb-21	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110 & MAITRA SOLAR &KOLIGUDD_33	17:50	18:36	0:46	TRANSFORMER FAULT
932	21-Feb-21	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110 & BELGAUM W/S &RUSTUMPUR_33	15:31	15:47	0:16	TRANSFORMER FAULT
933	21-Feb-21	BAGALKOT	110	MAHALINGAPUR-JAMAKHANDI	JAMAKHANDI_110	22:54 (21.02.2021)			LINE OPEN: LINE FAULT
934	21-Feb-21	BAGALKOT	110	110/11KV,HV1&HV2	KULAGERI CROSS_110	08:31	10:20	1:49	LINE CLEAR AVAILED
935	21-Feb-21	BAGALKOT	110	BELGAUM220- VADAGAON	STATION NOT AFFECTED VADAGAON_110	09:04	12:54	3:50	LINE CLEAR AVAILED
936	21-Feb-21	BAGALKOT	110	110/33KV, HV2	UTTUR_110, YADWAD_33, VANTAGOD_33	22:01	22:33	0:32	TRANSFORMER FAULT
937	21-Feb-21	BAGALKOT	110	110/11KV, HV1	TUMMINKATTI_110	12:40	13:03	0:23	LINE CLEAR AVAILED
938	21-Feb-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	22:25 (21.02.2021)			LINE OPEN: LINE FAULT
939	21-Feb-21	BAGALKOT	110	110/11KV, HV2	SHIRGOAN_110	13:11	14:13	1:02	LINE CLEAR AVAILED
940	21-Feb-21	BAGALKOT	220	NARENDRA- AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	0:14 (21.02.2021)			LINE OPEN: LINE FAULT
941	21-Feb-21	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MKHUBLI_220	15:06	18:50	3:44	LINE CLEAR AVAILED
942	21-Feb-21	BAGALKOT	110	MKHUBLI220- BEDI	BEDI_110	10:09	16:26	6:17	LINE CLEAR AVAILED
943	21-Feb-21	BAGALKOT	110	110/11KV, HV1	MKHUBLI_110	14:43	15:22	0:39	TRANSFORMER FAULT
944	21-Feb-21	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI2	MAHALINGAPUR_220	22:25 (21.02.2020)			LINE OPEN: LINE FAULT
945	21-Feb-21	BAGALKOT	220	220/110KV, HV3 & LV3	MAHALINGAPUR_220, HIDIKAL_110, ITANAL_110, SULTANPUR_110	17:49	18:29	0:40	TRANSFORMER FAULT
946	21-Feb-21	BAGALKOT	110	MAHALINGAPUR- TERDAL	TERDAL_110	18:03	18:07	0:04	HAND TRIPPED
947	21-Feb-21	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	05:34	05:38	00:04	LOAD CHANGE OVER
948	21-Feb-21	BENGALURU	66	HV1	BYADRAHALLI	11:35	11:40	00:05	LINE CLEAR AVAILED
949	21-Feb-21	BENGALURU	66	HV2	BYADRAHALLI	15:27	15:35	00:08	LINE CLEAR AVAILED
950	21-Feb-21	BENGALURU	220	KANAKAPURA 220 - SOMANAHALLI 220	KANAKAPURA 220	09:40	10:05	00:25	MAIN SUPPLY FAILURE
951	21-Feb-21	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA	09:40	10:05	00:25	LINE CLEAR AVAILED
952	21-Feb-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, YEDUMADU	09:40	10:05	00:25	LINE CLEAR AVAILED
953	21-Feb-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	DODDALAHALLI, HONNIGANAHALLI, HALAGUR	09:40	10:05	00:25	LINE CLEAR AVAILED
954	21-Feb-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	09:40	10:05	00:25	LINE CLEAR AVAILED
955	21-Feb-21	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	05:32	05:37	00:05	LOAD CHANGE OVER
956	21-Feb-21	BENGALURU	66	HV2	REMCO	05:48	05:58	00:10	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
957	21-Feb-21	BENGALURU	220	SOMANAHALLI 220 - HAROHALLI 220	BWSSB, KANAKAPURA 220	09:40	10:01	00:21	LINE FAULT
958	21-Feb-21	BENGALURU	66	SRS PEENYA 220 - T G HALLI 1	BYADRAHALLI, TAVAREKERE, KODIGEHALI	09:41	10:05	00:24	LINE FAULT
959	21-Feb-21	BENGALURU	66	SRS PEENYA 220 - T G HALLI 1	BYADRAHALLI, TAVAREKERE, KODIGEHALI	11:48	13:35	01:47	LINE CLEAR AVAILED
960	21-Feb-21	BENGALURU	66	ATTUR YELAHANKA -DG3	ATTUR YELAHANKA	12:41	12:47	00:06	LOAD CHANGE OVER
961	21-Feb-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	10:50	15:25	04:35	LINE CLEAR AVAILED
962	21-Feb-21	BENGALURU	66	HV2	DODDALAHALLI	09:44	10:08	00:24	LINE CLEAR AVAILED
963	21-Feb-21	BENGALURU	66	HV1	DODDALAHALLI	09:44	10:08	00:23	LINE CLEAR AVAILED
964	21-Feb-21	BENGALURU	66	HV1	MITTEMARI 220	00:17	00:31	00:13	TRANSFORMER FAULT
965	21-Feb-21	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	09:30	09:45	00:15	LOAD CHANGE OVER
966	21-Feb-21	BENGALURU	66	JIGANI 66 - SOMANAHALLI 220	JIGANI 66	18:25	18:52	00:27	LOAD CHANGE OVER
967	21-Feb-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
968	21-Feb-21	GULBARGA	400	BTPS-RTPS	BTPS	01:47	08:05	06:18	LINE CLEAR AVAILED
969	21-Feb-21	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	18:20(19.2.2021)			LINE OPEN :LINE CLEAR AVAILED
970	21-Feb-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	23:18	23:59	00:41	LINE FAULT
971	21-Feb-21	GULBARGA	220	SEDAM-RTPS2	SEDAM	16:55	18:16	01:21	LINE CLEAR AVAILED
972	21-Feb-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	14:15(15.2.2021)	23:20(21.2.2021)	205:05 HRS	LINE CHARGED
973	21-Feb-21	GULBARGA	110	HATTI-SINDHANOOR	HATTI_110(NO EFFECTED STATION)	18:21(17.2.2021)	23:25(21.02.2021)	96:04HRS	LINE CHARGED
974	21-Feb-21	GULBARGA	110	HV1	GINIGERA_110	08:57	09:26	00:29	LINE CLEAR AVAILED
975	21-Feb-21	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	19:33	19:43	00:10	LINE FAULT
976	21-Feb-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	19:55	20:35	00:40	LINE FAULT
977	21-Feb-21	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	21:07	21:37	00:30	LINE FAULT
978	21-Feb-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	22:19	22:29	00:10	LINE FAULT
979	21-Feb-21	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR IPP,ASKI_110	05:06	05:20	00:14	LINE FAULT
980	21-Feb-21	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAWAT_110,VALKAMDINNI_110	02:26	02:40	00:14	LINE FAULT
981	21-Feb-21	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAWAT_110,VALKAMDINNI_110	06:40	06:50	00:10	LINE FAULT
982	21-Feb-21	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	18:05	18:40	00:35	LINE FAULT
983	21-Feb-21	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAWAT_110,VALKAMDINNI_110	20:25	20:40	00:15	LINE FAULT
984	21-Feb-21	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAWAT_110,VALKAMDINNI_110	22:20	22:26	00:06	LINE FAULT
985	21-Feb-21	GULBARGA	110	HALBARGA-CHIDRI1	KAMTHANA_110,HABSIKOTE_110	08:40	08:46	00:06	LINE FAULT
986	21-Feb-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	10:10	16:52	06:42	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
987	21-Feb-21	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SRNAGAR_110,GANGAVATHI_110,VENKATAGIRI_110	16:47	16:57	00:10	LINE FAULT
988	21-Feb-21	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	21:53	22:03	00:10	LINE FAULT
989	21-Feb-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADONA_110,SRNAGAR_110	23:35	23:45	00:10	LINE FAULT
990	21-Feb-21	GULBARGA	66	ITTAGI-HIREHADAGALI	HIREHAHADAGALI_66	09:39	09:52	00:13	LINE FAULT
991	21-Feb-21	HASSAN	66	LV2	MRS MG_220	9:16 (13.11.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
992	21-Feb-21	HASSAN	66	LV4	MRS MG_220	9:16 (13.11.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
993	21-Feb-21	HASSAN	110	TALAGU-L1-LST 3 LPH	TALAGUPPA_110	00:01	12:45	12:44	LINE FAULT
994	21-Feb-21	HASSAN	110	MRSSH-M-BADRAVATY1	MRS MG_220	11:51	11:56	00:05	LINE CLEAR AVAILED
995	21-Feb-21	HASSAN	110	MRSSH-M-BADRAVATY3	MRS MG_220	10:01	11:51	01:50	LINE CLEAR AVAILED
996	21-Feb-21	HASSAN	110	HV2	ANANDAPURA_110	06:06	07:15	01:09	TRANSFORMER FAULT
997	21-Feb-21	HASSAN	110	HV1	BAIKAMPADI_110	14:30	15:46	01:16	LINE CLEAR AVAILED
998	21-Feb-21	HASSAN	110	H5	BAIKAMPADI_110	14:30	15:46	01:16	LINE CLEAR AVAILED
999	21-Feb-21	HASSAN	110	HV2	BAIKAMPADI_110	10:23	15:47	05:24	LINE CLEAR AVAILED
1000	21-Feb-21	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	10:24	10:39	00:15	LINE FAULT
1001	21-Feb-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	19:17	19:30	00:13	LINE CLEAR AVAILED
1002	21-Feb-21	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	18:47	19:08	00:21	LINE CLEAR AVAILED
1003	21-Feb-21	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHIGRAMMA_66	23:43	23:59	00:16	LINE FAULT
1004	21-Feb-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	00:33	00:59	00:26	LINE FAULT
1005	21-Feb-21	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	00:33	00:52	00:19	LINE FAULT
1006	21-Feb-21	MYSURU	66	HV1	FTS_66	10:04	17:24	7:20	LINE CLEAR AVAILED
1007	21-Feb-21	MYSURU	66	HV2	FTS_66	10:04	17:24	7:20	LINE CLEAR AVAILED
1008	21-Feb-21	MYSURU	66	HOOTAGALLI-FTS 1	FTS_66	10:05	17:23	7:18	NFBC ISSUED
1009	21-Feb-21	MYSURU	66	JAKKANAHALLI-NAGAMANGALA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 NAGAMANGALA_66	7:18	7:34	0:15	LINE FAULT
1010	21-Feb-21	MYSURU	66	JYOTHINAGARA-FTS	NO STATION EFFECTED	7:32	18:11	10:39	NFBC ISSUED
1011	21-Feb-21	MYSURU	66	KADAKOLA-NANJANGUDU 1	NANJANGUDU_66	9:45	18:30	8:45	NFBC ISSUED
1012	21-Feb-21	MYSURU	66	KADAKOLA-NANJANGUDU 2	THANDYA_66	9:18	18:19	9:00	NFBC ISSUED
1013	21-Feb-21	MYSURU	66	HV1	KOLLEGALA_66	4:30	7:33	3:02	TRANSFORMER FAULT
1014	21-Feb-21	MYSURU	66	HV4	KUSHALANAGARA_66	7:10	7:30	0:20	TRANSFORMER FAULT
1015	21-Feb-21	MYSURU	66	NANJANGUDU -SINDHUVALLI	NANJANGUDU_66	10:04	17:23	7:19	LINE CLEAR AVAILED
1016	21-Feb-21	MYSURU	66	HV1	NANJANGUDU_66	10:04	17:27	7:22	LINE CLEAR AVAILED
1017	21-Feb-21	MYSURU	66	HV2	NANJANGUDU_66	10:00	17:25	7:25	LINE CLEAR AVAILED
1018	21-Feb-21	MYSURU	66	HV3	NANJANGUDU_66	10:00	17:40	7:40	LINE CLEAR AVAILED
1019	21-Feb-21	MYSURU	66	SFC SIVA-PGL	NO STATION EFFECTED	18:10	18:22	0:11	LINE FAULT
1020	21-Feb-21	MYSURU	66	SFC SIVA-5 MW	NO STATION EFFECTED	18:11	18:19	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1021	21-Feb-21	MYSURU	66	SFC SIVA-10 MW	NO STATION EFFECTED	18:11	18:14	0:03	LINE FAULT
1022	21-Feb-21	MYSURU	66	SFC SIVA-HEBBANI 9	NO STATION EFFECTED	18:10	18:32	0:21	LINE FAULT
1023	21-Feb-21	MYSURU	66	HV2	THANDYA_66	6:12 (21/02/2021)			LINE OPEN :LINE CLEAR AVAILED
1024	21-Feb-21	MYSURU	66	THANDYA-NANJANGUDU	THANDYA_66	9:19	18:38	9:18	NFBC ISSUED
1025	21-Feb-21	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN :LINE CLEAR AVAILED
1026	21-Feb-21	TUMKUR	220	TR-2	ANTHRASANAHALI_220	13:37	13:58	0:20	LINE CLEAR AVAILED
1027	21-Feb-21	TUMKUR	66	TR-1	BALENAHALI_66	1:42	1:49	0:06	TRANSFORMER FAULT
1028	21-Feb-21	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	10:46	14:10	3:24	LINE CLEAR AVAILED
1029	21-Feb-21	TUMKUR	66	TR-1	DYAVARANAHALI_66	14:07	14:15	0:08	TRANSFORMER FAULT
1030	21-Feb-21	TUMKUR	66	JAVAGONDANAHALI- INFOSYS-1	INFOSYS-1	15:27	15:29	0:02	LINE FAULT
1031	21-Feb-21	TUMKUR	66	JAVAGONDANAHALI- INFOSYS-1	INFOSYS-1	15:39	15:50	0:11	LINE FAULT
1032	21-Feb-21	TUMKUR	66	TR-1	KUNDUR_66	3:20	3:29	0:09	TRANSFORMER FAULT
1033	21-Feb-21	TUMKUR	66	TR-1	GARAGA_66	12:59	13:28	0:28	HAND TRIPPED
1034	21-Feb-21	TUMKUR	66	GULIGENAHALLI- SIRA	GULIGENAHALLI_66	13:46	13:52	0:05	HAND TRIPPED
1035	21-Feb-21	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	0:11	0:31	0:20	LINE FAULT
1036	21-Feb-21	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALI	MADHUGIRI_66	19:06	19:33	0:27	LINE FAULT
1037	21-Feb-21	TUMKUR	66	MADHUGIRI 66kV- MADHUGIRI	MADHUGIRI_66	19:06	19:29	0:23	LINE FAULT
1038	21-Feb-21	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR IPP 66	SEL DIAMOND SOLAR_IPP_66	4:09	7:45	3:36	LINE CLEAR AVAILED
1039	21-Feb-21	TUMKUR	66	THALLAK 220kV- NAYAKANHATTI	THALLAKK_220	4:09	7:45	3:36	LINE CLEAR AVAILED
1040	21-Feb-21	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	7:52	8:22	0:30	LINE FAULT
1041	21-Feb-21	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	8:23	9:56	1:32	LINE FAULT
1042	21-Feb-21	TUMKUR	66	TR-2	MATHOD_66	12:11	12:22	0:11	TRANSFORMER FAULT
1043	22-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
1044	22-Feb-21	BAGALKOT	110	110/11KV, HV1	RANNABELAGALI_110	0:20 (22.02.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
1045	22-Feb-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
1046	22-Feb-21	BAGALKOT	110	110/11KV, HV1	HALIYAL_110	11:14	12:41	1:27	LINE CLEAR AVAILED
1047	22-Feb-21	BAGALKOT	110	110/11KV, HV1&2	ANAND NAGAR_110	17:12	19:28	2:16	LINE CLEAR AVAILED
1048	22-Feb-21	BAGALKOT	110	110/11KV, HV2	AKSHAYA COLONY_110	02:39	02:50	0:11	TRANSFORMER FAULT
1049	22-Feb-21	BAGALKOT	110	110/33KV, HV3	HIDIKAL_110 &KOLIGUDDA_33,ALAGAVADI 33	08:20	09:11	0:51	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1050	22-Feb-21	BAGALKOT	110	GADAG220- SAMBAPUR ROAD	SAMBAPUR ROAD_110	15:00	17:57	2:57	LINE CLEAR AVAILED
1051	22-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN :LINE CLEAR AVAILED
1052	22-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN :LINE CLEAR AVAILED
1053	22-Feb-21	BAGALKOT	110	GADAG-SMBAPUR ROAD(DAMBAL1)	SAMBAPUR ROAD_110	14:26	17:58	3:32	LINE FAULT
1054	22-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN :LINE CLEAR AVAILED
1055	22-Feb-21	BAGALKOT	110	HUBLI220- ANAND NAGAR	ANAND NAGAR_110, AKSHAY COLONY_110	15:13	19:27	4:14	LINE FAULT
1056	22-Feb-21	BAGALKOT	110	ITNAL-RAIBAG1(HDKL2)	RAIBAG_110	17:47	20:59	3:12	LINE CLEAR AVAILED
1057	22-Feb-21	BAGALKOT	110	ITNAL-RAIBAG2	RAIBAG_110	17:47	21:01	3:14	LINE CLEAR AVAILED
1058	22-Feb-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN :LINE CLEAR AVAILED
1059	22-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
1060	22-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN :LINE CLEAR AVAILED
1061	22-Feb-21	BAGALKOT	110	MAHALINGAPUR-JAMAKHANDI	JAMAKHANDI_110	22:54 (21.02.2021)			LINE OPEN: LINE FAULT
1062	22-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN :LINE CLEAR AVAILED
1063	22-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN :LINE CLEAR AVAILED
1064	22-Feb-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
1065	22-Feb-21	BAGALKOT	110	SIRSI- JOG1(SIDDAPUR)	SIDDAPUR_110	13:41	15:55	2:14	LINE CLEAR AVAILED
1066	22-Feb-21	BAGALKOT	110	SIRSI- JOG2	SIRSI_110	13:41	15:55	2:14	LINE CLEAR AVAILED
1067	22-Feb-21	BAGALKOT	110	SRS HUBLI-AKSHAYA COLONY	AKSHAYA COLONY_110	15:10 (22.02.2021)			LINE OPEN :LINE CLEAR AVAILED
1068	22-Feb-21	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN :LINE CLEAR AVAILED
1069	22-Feb-21	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	00:14 (21.02.2021)			LINE OPEN: LINE FAULT
1070	22-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN :LINE CLEAR AVAILED
1071	22-Feb-21	BAGALKOT	220	BELGAUM-KANABARGI2	BELGAUM_220	00:02	07:30	7:28	LOAD CURTAILMENT
1072	22-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN :LINE CLEAR AVAILED
1073	22-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN :LINE CLEAR AVAILED
1074	22-Feb-21	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI2	MAHALINGAPUR_220	22:25 (21.02.2021)	13:59 (22.02.2021)	15:33 hrs	LINE CHARGED
1075	22-Feb-21	BAGALKOT	220	NARENDRA- AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	0:14 (21.02.2021)			LINE OPEN: LINE FAULT
1076	22-Feb-21	BAGALKOT	220	SHARAVATHY1- SIRSI	SIRSI_220	10:34 (22.02.2021)			LOAD CURTAILMENT
1077	22-Feb-21	BAGALKOT	220	SHARAVATHY2- SIRSI	SIRSI_220	10:34 (22.02.2021)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1078	22-Feb-21	BAGALKOT	220	SIRSI- HUBLI-1	SIRSI_220	06:07	10:35	4:28	LOAD CURTAILMENT
1079	22-Feb-21	BAGALKOT	220	SIRSI- HUBLI-2	SIRSI_220	06:08	10:35	4:27	LOAD CURTAILMENT
1080	22-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)	6:08 (22.02.2021)	546:34 hrs	LINE CHARGED
1081	22-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)	6:08 (22.02.2021)	553:38 hrs	LINE CHARGED
1082	22-Feb-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	VAJRAMATTI_220	11:35	13:41	2:06	LINE CLEAR AVAILED
1083	22-Feb-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	VAJRAMATTI_220	13:47	17:52	4:05	LINE FAULT
1084	22-Feb-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	22:25 (21.02.2021)	13:54 (22.02.2021)	15:29 hrs	LINE CHARGED
1085	22-Feb-21	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	21:20	21:24	00:04	LOAD CHANGE OVER
1086	22-Feb-21	BENGALURU	66	ATTUR YELAHANKA - DG 4	ATTUR YELAHANKA	13:24	13:38	00:14	LINE FAULT
1087	22-Feb-21	BENGALURU	66	BAGHMANE WORLD TECH PARK - HAL 2	BAGHMANE WORLD TECH PARK, NGEF, NGEF (EHT)	05:55	06:10	00:15	LOAD CHANGE OVER
1088	22-Feb-21	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	09:02	09:55	00:53	LINE CLEAR AVAILED
1089	22-Feb-21	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	16:30	17:28	00:58	LINE CLEAR AVAILED
1090	22-Feb-21	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	00:36	01:14	00:38	LINE FAULT
1091	22-Feb-21	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	01:14	03:00	01:46	LINE FAULT
1092	22-Feb-21	BENGALURU	66	HV1	ALUR	11:41	11:45	00:03	LINE CLEAR AVAILED
1093	22-Feb-21	BENGALURU	66	HV1	HOSPALYA CIRCLE	13:23	13:26	00:03	TRANSFORMER FAULT
1094	22-Feb-21	BENGALURU	66	HV1	YEDUMADU	11:58	12:37	00:39	LINE CLEAR AVAILED
1095	22-Feb-21	BENGALURU	66	HV1	GOKULA	12:07	12:09	00:02	LINE CLEAR AVAILED
1096	22-Feb-21	BENGALURU	66	HV2	SOMAYAJJANAHALLI	10:10	11:00	00:50	TRANSFORMER FAULT
1097	22-Feb-21	BENGALURU	66	HV2	GOKULA	13:36	13:38	00:02	LINE CLEAR AVAILED
1098	22-Feb-21	BENGALURU	66	KADUBISANAHALLI - CESSNA	ISRO (EHT), KADUBISANAHALLI	12:15	12:25	00:10	LOAD CHANGE OVER
1099	22-Feb-21	BENGALURU	66	PLATINUM CITY - DG 4	PLATINUM CITY	13:30	17:25	03:55	MAIN SUPPLY FAILURE
1100	22-Feb-21	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	RBI, SOUTH CITY	17:35	18:00	00:25	LINE FAULT
1101	22-Feb-21	BENGALURU	66	WELCAST STEEL - DG 3	WELCAST STEEL	17:29	17:36	00:07	LOAD CHANGE OVER
1102	22-Feb-21	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	22:10	22:16	00:06	LOAD CHANGE OVER
1103	22-Feb-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16-02-2021)			LINE OPEN: LINE FAULT
1104	22-Feb-21	GULBARGA	66	HV1	HANASI_66	11:00	11:20	00:20	LINE CLEAR AVAILED
1105	22-Feb-21	GULBARGA	66	HV1	HAMPASAGAR_66	13:25	13:34	00:09	TRANSFORMER FAULT
1106	22-Feb-21	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	11:35	11:45	00:10	LINE CLEAR AVAILED
1107	22-Feb-21	GULBARGA	110	HV1	HATTI_110	13:25	13:30	00:05	TRANSFORMER FAULT
1108	22-Feb-21	GULBARGA	110	HV1	HATTI_110	16:35	17:00	00:25	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1109	22-Feb-21	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110	06:05	18:27	12:22	LINE CLEAR AVAILED
1110	22-Feb-21	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110	22:33	22:43	00:10	LINE FAULT
1111	22-Feb-21	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	22:12	22:21	00:09	LINE FAULT
1112	22-Feb-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	01:50	02:00	00:10	LINE FAULT
1113	22-Feb-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	04:22	04:32	00:10	LINE FAULT
1114	22-Feb-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	06:10	06:40	00:30	LINE FAULT
1115	22-Feb-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	01:51	02:09	00:18	LINE FAULT
1116	22-Feb-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	11:36	16:24	04:48	LINE CLEAR AVAILED
1117	22-Feb-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	00:54	00:58	00:04	LINE FAULT
1118	22-Feb-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	11:13	15:48	04:35	LINE CLEAR AVAILED
1119	22-Feb-21	GULBARGA	110	SHAHAPUR-WARDHASOLAR_IPP	SHAHAPUR_220	19:37	22:05	02:28	LINE FAULT
1120	22-Feb-21	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110	00:15	00:25	00:10	LINE FAULT
1121	22-Feb-21	GULBARGA	220	HV2	HUMNABAD_220	15:36	18:55	03:19	LINE CLEAR AVAILED
1122	22-Feb-21	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	08:13	16:12	07:59	LINE CLEAR AVAILED
1123	22-Feb-21	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	18:20(19.2.2021)			LINE OPEN :LINE CLEAR AVAILED
1124	22-Feb-21	GULBARGA	220	RAICHUR-SHAHAPUR2	SHAHAPUR_110	20:20	21:00	00:40	LINE FAULT
1125	22-Feb-21	GULBARGA	220	RAICHUR-SINDHNOOR	SINDHNOOR_110	10:50	11:55	01:05	LINE FAULT
1126	22-Feb-21	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	00:28	00:40	00:12	LINE FAULT
1127	22-Feb-21	HASSAN	66	HV1	SAKLESH PURA_66	10:51	11:08	00:17	TRANSFORMER FAULT
1128	22-Feb-21	HASSAN	66	HV2	UDAYAPURA_66	20:17(22.02.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
1129	22-Feb-21	HASSAN	66	HV2	CHIKMAGALUR_66	12:27	14:38	02:11	LINE CLEAR AVAILED
1130	22-Feb-21	HASSAN	66	LV2	MRS MG_220	9:16 (13.11.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
1131	22-Feb-21	HASSAN	66	LV4	MRS MG_220	9:16 (13.11.2020)			TRANSFORMER OPEN :LINE CLEAR AVAILED
1132	22-Feb-21	HASSAN	66	SAKALE-PCL2	SAKLESH PURA_66	10:51	11:11	00:20	LINE FAULT
1133	22-Feb-21	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	12:44	12:51	00:07	HAND TRIPPED
1134	22-Feb-21	HASSAN	110	HV1	BARANGI_110	10:29	11:43	01:14	LINE CLEAR AVAILED
1135	22-Feb-21	HASSAN	110	HV3	ALKOLA_110	15:48	15:53	00:05	TRANSFORMER FAULT
1136	22-Feb-21	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	12:46	12:50	00:04	HAND TRIPPED
1137	22-Feb-21	HASSAN	220	KEMAR-Varahi1	KEMAR_220	12:10	13:23	01:13	LINE CLEAR AVAILED
1138	22-Feb-21	HASSAN	220	MRSSHM-SHANTHIGRAMA	MRS MG_220	09:17	15:00	05:43	LINE CLEAR AVAILED
1139	22-Feb-21	HASSAN	220	MRSSHM-SHARAVATHY2	MRS MG_220	09:40	16:42	07:02	NFBC ISSUED
1140	22-Feb-21	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	21:33 (22.02.2021)			LINE OPEN :LINE CLEAR AVAILED
1141	22-Feb-21	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	09:39	16:43	07:04	LINE CLEAR AVAILED
1142	22-Feb-21	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	00:35	10:22	09:47	LINE FAULT
1143	22-Feb-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	00:35	10:22	09:47	LINE FAULT
1144	22-Feb-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	12:11	13:23	01:12	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1145	22-Feb-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	01:45	07:03	05:18	LINE CLEAR AVAILED
1146	22-Feb-21	MYSURU	66	HV1	MADIKERI_66	11:17	11:44	0:27	LINE CLEAR AVAILED
1147	22-Feb-21	MYSURU	66	HV1	THANDYA_66	11:52	12:03	0:10	TRANSFORMER FAULT
1148	22-Feb-21	MYSURU	66	HV1	THUMBLA_66	8:52	9:02	0:10	TRANSFORMER FAULT
1149	22-Feb-21	MYSURU	66	HV2	KRPET_66	12:07	14:14	2:07	LINE CLEAR AVAILED
1150	22-Feb-21	MYSURU	66	HV2	PANDAVAPURA_66	12:12	12:29	0:16	LINE CLEAR AVAILED
1151	22-Feb-21	MYSURU	66	HV2	SANTHEMARAHALLI_66	15:04	15:23	0:18	LINE CLEAR AVAILED
1152	22-Feb-21	MYSURU	66	HV2	TUBINAKERE_220	16:00	17:05	1:05	LINE CLEAR AVAILED
1153	22-Feb-21	MYSURU	66	HV2	THANDYA_66	6:12 (21/02/2021)			LINE OPEN :LINE CLEAR AVAILED
1154	22-Feb-21	MYSURU	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN :LINE CLEAR AVAILED
1155	22-Feb-21	MYSURU	66	MEGHALAPURA-SFC	NO STATION EFFECTED	14:23	14:28	0:04	LINE FAULT
1156	22-Feb-21	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	10:09	18:33	8:23	LINE CLEAR AVAILED
1157	22-Feb-21	TUMKUR	66	HIRIYUR 220KV- CHITRADURGA(SIRA)	HIRIYUR_220	11:38	11:46	0:08	HAND TRIPPED
1158	22-Feb-21	TUMKUR	66	TR-1	CHANNAGIRI_66	07:18	07:22	0:04	TRANSFORMER FAULT
1159	22-Feb-21	TUMKUR	66	TR-1	CHIKKATOTLUKERE_66	13:54	13:56	0:01	TRANSFORMER FAULT
1160	22-Feb-21	TUMKUR	66	TR-1	DYAVARANAHALLI_66	12:07	12:22	0:14	TRANSFORMER FAULT
1161	22-Feb-21	TUMKUR	66	TR-1	DYAVARANAHALLI_66	12:56	13:08	0:12	TRANSFORMER FAULT
1162	22-Feb-21	TUMKUR	66	TR-1(LV SIDE)	HIRIYUR_220	11:35	11:43	0:08	TRANSFORMER FAULT
1163	22-Feb-21	TUMKUR	66	TR-2	URDIGERE_66	10:02	18:34	8:32	LINE CLEAR AVAILED
1164	22-Feb-21	TUMKUR	66	URDIGERE-ANTHRASANAHALI	URDIGERE_66	10:04	18:34	8:30	LINE CLEAR AVAILED
1165	22-Feb-21	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	10:04	18:37	8:33	LINE CLEAR AVAILED
1166	22-Feb-21	TUMKUR	110	TR-1	TURUVEKERE_110	00:04	00:15	0:10	TRANSFORMER FAULT
1167	22-Feb-21	TUMKUR	110	TR-1	TURUVEKERE_110	00:16	09:20	9:03	TRANSFORMER FAULT
1168	22-Feb-21	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	21:42	22:32	0:50	TRANSFORMER FAULT
1169	22-Feb-21	TUMKUR	110	TR-2	TURUVEKERE_110	21:28	21:42	0:13	TRANSFORMER FAULT
1170	22-Feb-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	11:58	21:39	9:40	LINE CLEAR AVAILED
1171	22-Feb-21	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	11:58	21:39	9:40	LINE CLEAR AVAILED
1172	22-Feb-21	TUMKUR	220	TR-1	HIRIYUR_220	11:35	11:43	0:08	TRANSFORMER FAULT